

- PRESSURE SWITCH
- PRESSURE INDICATOR
- MONITOR SWITCH
- INDICATING LIGHT
- GLOBE VALVE (N.C.)
- ANGLE GLOBE VALVE (NC)
- STRAINER
- ORIFICE
- CHECK VALVE
- GATE VALVE (N.O.)
- BALL VALVE (N.O.)
- SIDE OUTLET GLOBE VALVE (N.O.)
- UPRIGHT SPRINKLER HEAD (N.C.)
- PENDENT SPRINKLER HEAD (N.C.)
- UNION
- ALARM VALVE
- DRAIN FUNNEL
- CAP
- RETARD CHAMBER
- PLUG
- SPRINKLER WITH CANOPY
- CONCENTRIC REDUCER
- ADDRESSABLE INTERFACE MODULE
- BALL VALVE (N.O.)
- EA-1 NOZZLE WITH 65° DEFLECTOR

NOTES:

1. THE DESIGN OF THIS WET-PIPE SPRINKLER SYSTEM INCLUDES THE FOLLOWING HYDRAULIC DEMAND: 250 GPM FOR INSIDE HOSE AND 750 GPM FOR OUTSIDE HOSE. DEMANDS: 2096.5 GPM @ 99.2 PSI FOR A DENSITY OF 0.9 GPM/SQ.FT.
2. THIS SPRINKLER SYSTEM HAS SPRINKLER HEADS WITH 1/2" ORIFICE AT A TEMPERATURE RATING OF 212°F AND CLOSED HEAD SPRAY NOZZLES WITH A 1/2" ORIFICE AT A TEMPERATURE RATING OF 175°F, WHICH INCLUDES THE FOLLOWING TYPE AND QUANTITY: UPRIGHT SSU - 26 HEADS; PENDENT SSP - 2 HEADS; NOZZLE EA-1 - 8 HEADS (WITH 65° DEFLECTOR).
3. ALL MPL NUMBERS ARE PRECEDED BY 2T43 UNLESS NOTED OTHERWISE.
4. SEE A-50396 FOR ANY VENDOR AND/OR CODE DEVIATIONS APPLICABLE TO THIS SPRINKLER SYSTEM.

REFERENCES:

- A-50396 TRIM PIPING DETAILS
- A-50394 HANGER DRAWINGS
- A-50395 VENDOR DEVIATIONS AND CODE DEVIATIONS
- B-24708 FIRE PROTECTION FCD N.E. WATER CURTAIN EL. 185'-0" SYSTEM NO. 2T43185W06
- H-11902 EQUIPMENT LAYOUT DRAWING - FIRE DETECTION SUPPRESSION MULTIPLEX SYSTEM 2T43 REACTOR BUILDING EL. 185'-0"
- H-21017 UNIT NO. 2 - REACTOR AND RADWASTE BUILDINGS - FIRE PROTECTION SYSTEM P&ID
- H-50392 FIRE PROTECTION - PIPING - SYSTEM NO. 2T43185W06 - ISOMETRIC - FLOOR EL. 185'-0"
- H-50393 FIRE PROTECTION - PIPING - SYSTEM NO. 2T43185W06 - PLAN - FLOOR EL. 185'-0"

LICENSE RENEWAL DOCUMENT

MPL NO. 2T43 ACAD14 HL50276


SOUTHERN COMPANY

LICENSE RENEWAL SCREENING FOR INFORMATION ONLY

EDWIN I. HATCH NUCLEAR PLANT UNIT No.2
FIRE PROTECTION-P&ID-REACTOR BLDG.
FLOOR EL. 185'-0" EAST 185
WATER CURTAIN

BOUNDARY DIAGRAM NO.: 2X43-B01-19
FUNCTION(S) NO.: 2X43-04
2X43-06
PREPARED BY: M D STEPHENS
DATE: 2/6/98
REVIEWED BY: ALEX MORRISON
DATE: 7/13/98

SYSTEM NO. 2T43185W06
N.E. 185 WATER CURTAIN
FLOOR EL. 185'-0"



Revision: A Date: 11-08-99
APPROVED. ISSUED PER LICENSE RENEWAL BOUNDARY PACKAGES. DRAWING CREATED FROM H-50276, REV.1; TRM.

BY	CHK'D	APP'D	DATE	LOCATION	DOCUMENT NUMBER	REVISION
TRM	MDS	ASK			10-502	HL-50276 A

