

March 7, 2000

Carl Terry, BWRVIP Chairman  
Niagara Mohawk Power Company  
Post Office Box 63  
Lycoming, NY 13093

SUBJECT: SUPPLEMENT TO FINAL SAFETY EVALUATION OF THE BWR VESSEL AND  
INTERNALS PROJECT BWRVIP-05 REPORT (TAC NO. MA3395)

Dear Mr. Terry:

By letter dated September 28, 1995, as supplemented by letters dated June 24 and October 29, 1996, May 16, June 4, June 13, and December 18, 1997, and January 13, 1998, you submitted the Electric Power Research Institute (EPRI) proprietary report TR-105697, "BWR Vessel and Internals Project [BWRVIP], BWR Reactor Pressure Vessel Shell Weld Inspection Recommendations (BWRVIP-05)." The BWRVIP-05 report, as modified, proposed several actions, including reducing the scope of inservice inspections of the BWR reactor pressure vessel (RPV) shell welds from essentially 100 percent of all RPV shell welds to essentially 100 percent of the RPV axial shell welds and essentially zero percent of the circumferential RPV shell welds, except for the intersections of the axial and circumferential welds. This proposal was evaluated by the NRC staff and approved in a safety evaluation (SE) dated July 28, 1998. The SE stated that the NRC staff had concluded that a near-term safety concern did not exist due to various conservatisms in the calculations for axial welds, including the use of peak end-of-license (EOL) fluence levels for all postulated flaws and the assumptions of flaw density and flaw location.

However, the NRC staff identified a need to further evaluate the high conditional failure probability levels for axial welds in BWR RPVs determined in the staff's SE. In a request for additional information (RAI) dated June 8, 1998, the staff requested that BWRVIP provide a plan for follow up analyses to determine, on a more realistic basis, the potential for axial weld failures due to cold over-pressure events and appropriate technical approaches for addressing this concern, as necessary. Further, the staff requested that BWRVIP provide the failure frequency of axial welds in BWRs (from the results of probabilistic fracture mechanics evaluations) using specific staff recommendations on input variables and a risk assessment of the impact of inspection, operating procedures, training, etc., on the results of the failure frequency evaluations and the guidance of Regulatory Guide (RG) 1.174.

BWRVIP provided the results of its evaluations on axial weld failure frequency by letter dated December 15, 1998. In a letter dated April 29, 1999, the NRC staff concluded that the BWRVIP response was deficient and provided several options for additional evaluations by BWRVIP. By letter dated November 12, 1999, BWRVIP provided the results of its revised evaluations, which the staff has reviewed in the attached SE.

The staff has determined, based on its evaluation of the information provided, that the RPV failure frequency due to failure of the limiting axial welds in the BWR fleet are below  $5 \times 10^{-6}$  per reactor-year, consistent with RG 1.154, given the assumptions described in the attached SE.

Note that these results apply only for the initial 40-year license period of BWR plants, and that consideration of BWR axial welds for license renewal would require a plant-specific treatment by the license renewal applicant. The staff is presently reviewing the "BWR Reactor Pressure Vessel Inspection and Flaw Evaluation Guidelines (BWRVIP-74)," dated September 21, 1999, to determine the applicability for the extended operating period.

The NRC is conducting an expert elicitation to provide improved guidance on flaw density, distribution and location for RPVs. Thus, the results of this evaluation for axial welds should be considered interim pending the results of the expert elicitation. Should the results of the expert elicitation be more conservative than the assumptions used here, then BWRVIP would be required to re-evaluate BWR axial welds using the results of the expert elicitation.

Also, the staff is enclosing a revised Table 2.6-4, "Summary of Results of NRC Staff and BWRVIP Limiting Plant-Specific Analyses (32 EFPY)," page 28 of the staff's July 28, 1998, "Final Safety Evaluation of the BWR Vessel and Internals Project BWRVIP-05 Report." Specifically, the chemistry factor (CF) for the CB&I circumferential flaw orientation was erroneously reported as 109.5. The correct value is 134.9, as noted in bold in the attached, revised Table 2.6-4. This errata correction reflects an intermediate calculation value and does not change any conclusion in the original SE.

The staff requests that BWRVIP review the enclosed SE, and incorporate the staff's conclusions into a revised BWRVIP-05 report. Please inform the staff within 90 days of the date of this letter as to your proposed actions and schedule for such a revision.

Please contact C. E. (Gene) Carpenter, Jr., of my staff at (301) 415-2169 if you have any further questions regarding this subject.

Sincerely,

**/RA/**

Jack R. Strosnider, Director  
Division of Engineering  
Office of Nuclear Reactor Regulation

Project No. 704

Enclosure: Initial Safety Evaluation Report

cc: See next page

cc:

Bill Eaton, Executive Chair  
Inspection Committee  
Entergy Operations, Inc.  
PO Box 756, Waterloo Rd  
Port Gibson, MS 39150-0756

H. Lewis Sumner, Executive Chairman  
BWRVIP Mitigation Task  
Southern Nuclear Operating Co.  
M/S BIN B051, PO Box 1295  
40 Inverness Center Parkway  
Birmingham, AL 35201

Harry P. Salmon, Executive Chairman  
BWRVIP Integration Task  
New York Power Authority  
123 Main St., M/S 11 D  
White Plains, NY 10601-3104

George T. Jones, Executive Chair  
BWRVIP Repair Task  
Pennsylvania Power & Light, Inc.  
M/S GEN A 61  
2 N 9<sup>th</sup> Street  
Allentown, PA 18101-1139

Robert Carter, EPRI BWRVIP  
Assessment Manager  
Greg Selby, EPRI BWRVIP  
Inspection Manager  
EPRI NDE Center  
P. O. Box 217097  
1300 W. T. Harris Blvd.  
Charlotte, NC 28221

Joe Hagan, BWRVIP Vice Chairman  
PEPCO Energy Co.  
MC 62C-3  
965 Chesterbrook Blvd  
Wayne, PA 19807-5691

Steve Lewis, Technical Chairman  
BWRVIP Assessment Task  
Entergy  
P. O. Box 756  
Waterloo Road  
Port Gibson, MS 39150

Carl Larsen, Technical Chairman  
BWRVIP Inspection Task  
P.O. Box 157  
Vernon, VT 05354

John Wilson, Technical Chairman  
BWRVIP Mitigation Task  
Clinton Power Station, M/C T-31C  
P.O. Box 678  
Clinton, IL 61727

Vaughn Wagoner, Technical Chairman  
BWRVIP Integration Task  
Carolina Power & Light Company  
One Hannover Square 9C1  
P.O. Box 1551  
Raleigh, NC 27612

Bruce McLeod, Technical Chairman  
BWRVIP Repair Task  
Southern Nuclear Operating Co.  
Post Office Box 1295  
40 Inverness Center Parkway  
Birmingham, AL 35201

Tom Mulford, EPRI BWRVIP  
Integration Manager  
Raj Pathania, EPRI BWRVIP  
Mitigation Manager  
Ken Wolfe, EPRI BWRVIP  
Repair Manager  
Electric Power Research Institute  
P. O. Box 10412  
3412 Hillview Ave.  
Palo Alto, CA 94303

Jack Dillich, BWRVIP Liaison  
to EPRI Nuclear Power Council  
Nebraska Public Power District  
1200 Prospect Avenue  
PO Box 98  
Brownville, NE 68321-0098

Note that these results apply only for the initial 40-year license period of BWR plants, and that consideration of BWR axial welds for license renewal would require a plant-specific treatment by the license renewal applicant. The staff is presently reviewing the "BWR Reactor Pressure Vessel Inspection and Flaw Evaluation Guidelines (BWRVIP-74)," dated September 21, 1999, to determine the applicability for the extended operating period.

The NRC is conducting an expert elicitation to provide improved guidance on flaw density, distribution and location for RPVs. Thus, the results of this evaluation for axial welds should be considered interim pending the results of the expert elicitation. Should the results of the expert elicitation be more conservative than the assumptions used here, then BWRVIP would be required to re-evaluate BWR axial welds using the results of the expert elicitation.

Also, the staff is enclosing a revised Table 2.6-4, "Summary of Results of NRC Staff and BWRVIP Limiting Plant-Specific Analyses (32 EFPY)," page 28 of the staff's July 28, 1998, "Final Safety Evaluation of the BWR Vessel and Internals Project BWRVIP-05 Report." Specifically, the chemistry factor (CF) for the CB&I circumferential flaw orientation was erroneously reported as 109.5. The correct value is 134.9, as noted in bold in the attached, revised Table 2.6-4. This errata correction reflects an intermediate calculation value and does not change any conclusion in the original SE.

The staff requests that BWRVIP review the enclosed SE, and incorporate the staff's conclusions into a revised BWRVIP-05 report. Please inform the staff within 90 days of the date of this letter as to your proposed actions and schedule for such a revision.

Please contact C. E. (Gene) Carpenter, Jr., of my staff at (301) 415-2169 if you have any further questions regarding this subject.

Sincerely,

Jack R. Strosnider, Director  
Division of Engineering  
Office of Nuclear Reactor Regulation

Project No. 704

Enclosure: Initial Safety Evaluation Report  
cc: See next page

DISTRIBUTION:

EMCB R/F	via e-mail:	WDLanning, R1	JSWermeil/RCaruso
PUBLIC	GHolahan	BSMallet, R2	KAKavanagh
File Center	MEMayfield	JGrobe, R3	EImbro/KAManoly
ACRS	TYChang	AHowell, R4	JRRajan
	KRWichman		

Document Name: G:\BWRVIP\BWRVIP05 Axial Supp SE.WPD

INDICATE IN BOX: "C"=COPY W/O ATTACHMENT/ENCLOSURE, "E"=COPY W/ATT/ENCL, "N"=NO COPY

EMCB:LPM	E	EMCB:ME	E	EMCB:SC	E	EMCB:BC	E	DE:DD	E	DE:D	E
CECarpenter:cec		ALHiser:alh		KRWichman:krw		WHBateman:whb		RHWessman:rhw		JRStrosnider:jrs	
01/18/2000		02/8/2000		02/9/2000		02/10/2000		02/10/2000		03/07/2000	

U.S. NUCLEAR REGULATORY COMMISSION  
OFFICE OF NUCLEAR REACTOR REGULATION  
SUPPLEMENTAL SAFETY EVALUATION OF EPRI TOPICAL REPORT TR-105697  
"BWR VESSEL AND INTERNALS PROJECT, BWR REACTOR PRESSURE VESSEL  
SHELL WELD INSPECTION RECOMMENDATIONS (BWRVIP-05)"

1.0 INTRODUCTION

1.1 Background

By letter dated September 28, 1995, as supplemented by letters dated June 24 and October 29, 1996, May 16, June 4, June 13, and December 18, 1997, and January 13, 1998, the BWR Vessel and Internals Project (BWRVIP) submitted the Electric Power Research Institute (EPRI) proprietary report TR-105697, "BWR Vessel and Internals Project, BWR Reactor Pressure Vessel Shell Weld Inspection Recommendations (BWRVIP-05)." The BWRVIP-05 report, as modified, proposed several actions, including reducing the scope of inservice inspections of the BWR reactor pressure vessel (RPV) shell welds from essentially 100 percent of all RPV shell welds to essentially 100 percent of the RPV axial shell welds and essentially zero percent of the circumferential RPV shell welds, except for the intersections of the axial and circumferential welds. This proposal was evaluated by the NRC staff and approved in a safety evaluation (SE) dated July 28, 1998, which stated that the NRC staff had concluded that a near-term safety concern did not exist due to various conservatisms in the calculations for axial welds, including the use of peak end-of-license (EOL) fluence levels for all postulated flaws and the assumptions of flaw density and flaw location.

The NRC staff identified a need to further evaluate the high conditional failure probability levels for axial welds in BWR RPVs, which were described in the staff's SE. In a request for additional information (RAI) dated June 8, 1998, the staff requested that BWRVIP provide a plan for follow-up analyses to determine, on a more realistic basis, the potential for axial weld failures due to cold over-pressure events and appropriate technical approaches for addressing this concern, as necessary. Further, the staff requested that BWRVIP provide the failure frequency of axial welds in BWRs (from the results of probabilistic fracture mechanics evaluations) using specific staff recommendations on input variables and a risk-informed assessment of the impact of inspection, operating procedures, training, etc., on the results of the failure frequency evaluations and using the guidance of Regulatory Guide (RG) 1.174.

The BWRVIP provided the results of its evaluations on axial weld failure frequency by letter dated December 15, 1998. In a letter dated April 29, 1999, the NRC staff concluded that the BWRVIP response was deficient and provided several options for additional evaluations by the BWRVIP. By letter dated November 12, 1999, the BWRVIP provided the results of its revised evaluations.

ENCLOSURE

## 1.2 Organization of the Report

Because the BWRVIP-05 report, as supplemented with the revised evaluations, is proprietary, this supplemental safety evaluation (SE) was written to ensure that proprietary information was not compromised. The staff's July 28, 1998, SE, gives a brief summary of the general contents of the BWRVIP-05 report, and that synopsis is not repeated here. Section 2.0 provides a detailed evaluation of the supplemental material provided by the BWRVIP. Because of proprietary information concerns, this SE does not discuss in any detail the provisions of the BWRVIP's revised evaluations, nor the parts of the revised evaluations that the staff finds acceptable.

## 2.0 EVALUATION

### 2.1 Probabilistic Fracture Mechanics Evaluations by BWRVIP

#### *Input Parameters*

Limiting Plants: Consistent with the approach taken in the BWRVIP-05 report and the staff evaluation of the failure frequency for RPV axial and circumferential welds, BWRVIP identified two limiting plants from the fleet of BWR plants, from the standpoint of irradiation embrittlement of the axial welds. More specifically, BWRVIP identified the two plants which have the axial welds with the highest mean  $RT_{NDT}$  levels at EOL conditions, where mean  $RT_{NDT}$  does not include margin terms (M) described in RG 1.99, Revision 2 and the PTS Rule (10 CFR 50.61). The identified plants, Clinton and Pilgrim, have RPVs which were fabricated by Chicago Bridge and Iron (CB&I) and Combustion Engineering, respectively. The material property information used by BWRVIP to define the EOL fracture toughness of each of these plants is summarized in Table 1. Note that the peak RPV fluences at EOL do not correspond to the axial weld locations, with the peak EOL fluences for the axial welds at Pilgrim much below the peak for the overall RPV.

Table 1: Material Property Data for Limiting BWR Axial Welds (BWVIP Data)

Plant Name	Initial $RT_{NDT}$ (°F)	Chemical Composition (Wt. %)		Peak RPV EOL Fluence ( $10^{19}$ n/cm <sup>2</sup> )	EOL Mean $RT_{NDT}$ (°F)
		Copper	Nickel		
Clinton	-30	0.10	1.08	0.69*	91
Pilgrim	0	0.219	0.996	0.2 **	116

\* The peak axial weld fluence is  $0.676 \times 10^{19}$  n/cm<sup>2</sup>.

\*\* The peak axial weld fluence is  $0.148 \times 10^{19}$  n/cm<sup>2</sup>.

Fluence Maps: For the Clinton plant, the beltline portion of the RPV is a single shell course consisting of three axial welds. For the Pilgrim plant, the beltline portion of the RPV contains a circumferential weld, and hence there are a total of six axial welds. For each plant, the EOL fluences were determined for 24 regions of the axial welds, with the mean fluence of each region used to define the fluence for that region.

Flaw Density, Distribution, and Location: These parameters relate to the number, size and position (through the weld thickness) of flaws postulated in probabilistic fracture mechanics (PFM) calculations. As specified by the staff, the BWRVIP calculations used a density of 3 flaws per vessel, with the size distribution of flaws given by the “PVRUF Flaw Depth Distribution.” All of the flaws were assumed to be surface-breaking in the PFM evaluation.

### *VIPER Computations*

The VIPER code was used to perform the PFM evaluations by BWRVIP. The application of this code assumed that a single low-temperature over-pressure transient occurred each year of the simulated 40-year lifetime of each RPV. The cumulative number of failures for the 40-year period was used to determine the conditional failure probability for each RPV.

### *BWRVIP Results*

The results from the BWRVIP evaluation are provided in Table 2. The “conditional failure probability,” or  $P(F|E)$ , is the probability that the vessel will fail, assuming that the transient occurs. The “LTOP frequency” is the frequency of the transient occurring, determined as  $10^{-3}$  per reactor-year in the evaluation of the BWRVIP-05 report. Therefore, the “vessel failure frequency” is the product of the conditional failure probability and the LTOP frequency. The resultant vessel failure frequencies for the limiting BWR axial welds are below  $5 \times 10^{-6}$  per reactor-year, consistent with Regulatory Guide (RG) 1.154, “Format and Content of Plant-Specific Pressurized Thermal Shock Safety Analysis Reports for Pressurized Water Reactors,” dated January 1987, throughout the 40-year license period.

Table 2: Results of BWRVIP Evaluations for Limiting BWR Axial Welds

Plant Name	Conditional Failure Probability $P(F E)$	LTOP Frequency	Vessel Failure Frequency
Clinton	1.52E-3	1E-3	1.52E-6
Pilgrim	1.55E-3	1E-3	1.55E-6

## 2.2 Staff Evaluation

### *Input Parameters*

Limiting Plants: To ensure that the BWR plants identified by BWRVIP are limiting for the entire BWR fleet, NRC staff reviewed information in the Reactor Vessel Integrity Database (RVID). The axial welds identified by RVID as having the highest mean  $RT_{NDT}$  are:

- Oyster Creek (Heat 86054B): 114°F
- Millstone 1 (Heat W5214): 98°F
- Clinton (Heat 76492): 91°F
- Browns Ferry 2 and 3: 84°F

Review of the data for Oyster Creek indicated that the data contained in the RVID represents the docketed, licensing information, provided by the licensee, for the welds in the plant. However, the latest chemical composition data for Combustion Engineering welds (Heat 86054B) indicates substantially lower copper and nickel contents of this weld, such that the EOL mean  $RT_{NDT}$  for Oyster Creek is actually less than 70°F.

Millstone 1 was excluded from consideration since the licensee has discontinued operation of the plant.

Pilgrim was not identified within the RVID as one of the limiting plants because the initial  $RT_{NDT}$  docketed in the RVID is -48°F, as opposed to 0°F, which was used by the BWRVIP. In addition, the peak EOL fluence reported in the RVID is  $0.138 \times 10^{19}$  n/cm<sup>2</sup>, as opposed to  $0.148 \times 10^{19}$  n/cm<sup>2</sup> used by the BWRVIP. As a result, the RVID value of mean  $RT_{NDT}$  for Pilgrim is 64°F instead of the 116°F determined from the BWRVIP input values.

Therefore, the axial welds for the Clinton plant are the limiting welds for the BWR fleet, and vessel failure probability calculations determined for Clinton should bound those for the BWR fleet. Note that the mean  $RT_{NDT}$  for Pilgrim used by BWRVIP also bounds that for all of the axial welds in BWR plants, but in this case the Pilgrim data used by BWRVIP are over-conservative in comparison to the overall BWR fleet.

Flaw Density, Distribution, and Location: The staff evaluation of the BWRVIP-05 report used the results of an examination of the welds in the Pressure Vessel Research Users Facility (PVRUF) vessel at Oak Ridge National Laboratory. This RPV is from a canceled plant and was fabricated by Combustion Engineering. The results from the examination of the PVRUF welds indicated a density of 994 flaws/m<sup>3</sup>. However, none of these flaws were surface-breaking flaws, even using the proximity rules of the ASME Code. Since surface-breaking flaws dominate vessel failure determinations, the staff decided to remove one conservatism by considering only surface-breaking flaws in evaluations for axial welds. Given the results of no surface-breaking flaws with inspection of 800 feet of PVRUF welds, the 95 percent upper confidence bound for the frequency of a surface-breaking flaw is determined as three per 800 feet, or three per vessel.

Note that this flaw density of three flaws per RPV is intended as an interim assumption only to help reduce unnecessary conservatism in the PFM evaluation for BWR axial welds. The NRC has initiated an expert elicitation to provide guidance on the density and distribution of flaws in RPVs. Should the results of that expert elicitation be more conservative than the assumptions used in these calculations, then reconsideration of these results would be necessary.

The sizes of the flaws found in the PVRUF were used to construct the "PVRUF Flaw Depth Distribution," which was used by BWRVIP in its evaluation for axial welds and in previous staff evaluations for the BWRVIP-05 report.

Fluence Maps: The fluence maps provided by BWRVIP were used in calculations for both the Clinton and Pilgrim RPVs.



*FAVOR Code*

The staff performed independent calculations for Clinton and Pilgrim using the FAVOR code developed by the Oak Ridge National Laboratory. These calculations used the EOL fluence maps for each plant. Using the information relevant to the Pilgrim plant, calculations were made using both the BWRVIP input initial  $RT_{NDT}$  of  $0^{\circ}F$  and the RVID docketed value of  $-48^{\circ}F$ .

*Staff Results*

Results from the staff calculations are provided in Table 3. The staff calculations used the basic input information for Pilgrim, with three different assumptions for the initial  $RT_{NDT}$ . The calculations of the actual Pilgrim condition used the docketed initial  $RT_{NDT}$  of  $-48^{\circ}F$  and a mean  $RT_{NDT}$  of  $68^{\circ}F$ . A second calculation, listed as "Mod 1" in Table 3, is consistent with the BWRVIP calculations, with an initial  $RT_{NDT}$  of  $0^{\circ}F$  and a mean  $RT_{NDT}$  of  $116^{\circ}F$ . A third calculation, with an initial  $RT_{NDT}$  of  $-2^{\circ}F$  and a mean  $RT_{NDT}$  of  $114^{\circ}F$ , was chosen to identify the mean value of  $RT_{NDT}$  required to provide a result which closely matches the RPV failure frequency of  $5 \times 10^{-6}$  per reactor-year.

Table 3: Comparison of Results from Staff and BWRVIP

Plant	Initial $RT_{NDT}$ ( $^{\circ}F$ )	Mean $RT_{NDT}$ ( $^{\circ}F$ )	Vessel Failure Freq.	
			Staff	BWRVIP
Clinton	-30	91	2.73E-6	1.52E-6
Pilgrim	-48	68	2.24E-7	-----
Mod 1 *	0	116	5.51E-6	1.55E-6
Mod 2 **	-2	114	5.02E-6	-----

\* A variant of Pilgrim input data, with initial  $RT_{NDT} = 0^{\circ}F$ .

\*\* A variant of Pilgrim input data, with initial  $RT_{NDT} = -2^{\circ}F$ .

The staff calculations tend to give somewhat higher failure frequencies than those reported by BWRVIP. However, both BWRVIP and the NRC staff calculations indicate that the vessel failure frequency due to failure of the axial welds is below  $5 \times 10^{-6}$  per reactor-year for each BWR.

3.0 STAFF CONCLUSIONS

The results of these calculations indicate that the RPV failure frequency due to failure of the limiting axial welds in the BWR fleet are below  $5 \times 10^{-6}$  per reactor-year, given the assumptions on flaw density, distribution and location described previously. Note that these results apply only for the initial 40-year license period of BWR plants, and that consideration of BWR axial welds for license renewal would require a plant-specific treatment by the license renewal applicant.

As described previously, the NRC is conducting an expert elicitation to provide guidance on flaw density, distribution and location for RPVs. The results of this evaluation for axial welds should be considered interim pending the results of the expert elicitation. Should the results of the expert elicitation be more conservative than the assumptions used here, then BWRVIP would be required to re-evaluate BWR axial welds using the results of the expert elicitation.

**TABLE 2.6-4  
SUMMARY OF RESULTS OF NRC STAFF AND BWRVIP LIMITING PLANT-SPECIFIC ANALYSES (32 EFY)**

FLAW ORIENT.	GROUP	Cu	Ni	CF	FLUENCE (10 <sup>19</sup> n/cm <sup>2</sup> )	ΔRT <sub>NDT</sub> (°F)	RT <sub>NDT(U)</sub> (°F)	MEAN RT <sub>NDT</sub> (°F)	P(F E)	
									STAFF	BWRVIP
AXIAL	CE (VIP) <sup>a</sup>	0.26	1.20	276.0	0.15	138.8	-20	118.8	2.94 E-1	1.37 E-2
	CE (CEOG) <sup>b</sup>	0.219	0.996	231.1	0.20	131.6	0	131.6	4.37 E-1	-----
	CB&I	0.10	1.08	135.0	0.69	121.0	-30	91.0	1.42 E-1	1.55 E-2
	B&W	0.25	0.35	142.5	0.125	66.0	10	76.0	5.98 E-2	8.12 E-3
CIRC.	CE (VIP) <sup>a</sup>	0.13	0.71	151.7	0.20	86.4	0	86.4	2.81 E-5	NF (10 <sup>6</sup> ) <sup>c</sup>
	CE (CEOG) <sup>b</sup>	0.183	0.704	172.2	0.20	98.1	0	98.1	6.34 E-5	-----
	CB&I	0.10	0.99	<b>134.9</b>	0.51	109.5	-65	44.5	2 E-7	1 E-6
	B&W	0.31	0.59	196.7	0.095	79.8	20	99.8	8.17 E-5	1 E-6

<sup>a</sup> Chemistry information reported in BWRVIP-05.

<sup>b</sup> Chemistry information reported in CEOG report.

<sup>c</sup> No failures in the indicated number of vessel simulations.

\* Mean RT<sub>NDT</sub> was determined using the peak neutron fluence for the limiting weld.