



Entergy Operations, Inc.  
1448 S.R. 333  
Russellville, AR 72801  
Tel 501 858-5000

February 28, 2000

2CAN020004

U. S. Nuclear Regulatory Commission  
Document Control Desk  
Mail Station P1-137  
Washington, DC 20555


Subject: Arkansas Nuclear One - Unit 2  
Docket No. 50-368  
License No. NPF-6  
1999 Annual Primary Coolant Activity Report

Gentlemen:

Arkansas Nuclear One, Unit 2 (ANO-2), Technical Specification (TS) 6.9.1.5.e requires an annual submittal of the results of the specific activity analysis in which the primary coolant exceeded the limits of TS 3.4.8. The specific activity of the primary coolant, as required by TS 3.4.8, shall be limited to: a) less than or equal to 1.0 microcurie per gram Dose Equivalent I-131, and b) less than or equal to 100/E-bar (where E-bar = average disintegration energy) microcuries per gram. The purpose of this letter is to provide this information for 1999.

During 1999, no samples taken of the primary coolant exceeded the limits of TS 3.4.8. Should you have any questions regarding this submittal, please contact me.

Very truly yours,

  
Jimmy D. Vandergriff  
Director, Nuclear Safety Assurance

JDV/NBM/dsw

A001

cc: Mr. Ellis W. Merschoff  
Regional Administrator  
U. S. Nuclear Regulatory Commission  
Region IV  
611 Ryan Plaza Drive, Suite 400  
Arlington, TX 76011-8064

NRC Senior Resident Inspector  
Arkansas Nuclear One  
P.O. Box 310  
London, AR 72847

Mr. Chris Nolan  
NRR Project Manager Region IV/ANO-2  
U. S. Nuclear Regulatory Commission  
NRR Mail Stop 04-D-3  
One White Flint North  
11555 Rockville Pike  
Rockville, MD 20852