

Westinghouse Non-Proprietary Class 3



WCAP - 15171
Revision 1

**Analysis of Capsule Z from
the Alabama Power
Company Joseph M. Farley
Unit 2 Reactor Vessel
Radiation Surveillance
Program**

Westinghouse Energy Systems



WCAP-15171, Revision 1

**Analysis of Capsule Z from the Alabama Power Company
Joseph M. Farley Unit 2 Reactor Vessel Radiation
Surveillance Program**

**E. Terek
J. D. Perock
R. G. Lott**


February 2000

Approved: _____



D. M. Trombola, Manager
Mechanical Systems Integration

Approved: _____



C. H. Boyd, Manager
Equipment & Materials Technology

Westinghouse Electric Company, LLC
Energy Systems
P.O. Box 355
Pittsburgh, PA 15230-0355

©2000 Westinghouse Electric Company, LLC
All Rights Reserved

TABLE OF CONTENTS

LIST OF TABLES.....	iv
LIST OF FIGURES.....	vii
PREFACE	ix
EXECUTIVE SUMMARY (OR) ABSTRACT.....	x
1 SUMMARY OF RESULTS.....	1-1
2 INTRODUCTION	2-1
3 BACKGROUND	3-1
4 DESCRIPTION OF PROGRAM	4-1
5 TESTING OF SPECIMENS FROM CAPSULE Z.....	5-1
5.1 OVERVIEW.....	5-1
5.2 CHARPY V-NOTCH IMPACT TEST RESULTS	5-3
5.3 TENSILE TEST RESULTS.....	5-5
5.4 1/2T COMPACT TENSION SPECIMEN TESTS.....	5-5
6 RADIATION ANALYSIS AND NEUTRON DOSIMETRY	6-1
6.1 INTRODUCTION	6-1
6.2 DISCRETE ORDINATES ANALYSIS	6-2
6.3 NEUTRON DOSIMETRY	6-5
6.4 PROJECTIONS OF REACTOR VESSEL EXPOSURE	6-8
7 SURVEILLANCE CAPSULE REMOVAL SCHEDULE.....	7-1
8 REFERENCES	8-1
APPENDIX A LOAD-TIME RECORDS FOR CHARPY SPECIMEN TESTS	A-0
APPENDIX B CHARPY V-NOTCH SHIFT RESULTS FOR EACH CAPSULE HAND-DRAWN VS. HYPERBOLIC TANGENT CURVE-FITTING METHOD (CVGRAPGH, VERSION 4.1).....	B-0
APPENDIX C CHARPY V-NOTCH PLOTS FOR EACH CAPSULE USING HYPERBOLIC TANGENT CURVE-FITTING METHOD.....	C-0
APPENDIX D J. M. FARLEY UNIT 2 SURVEILLANCE PROGRAM CREDIBILITY ANALYSIS	D-0

LIST OF TABLES

Table 4-1	Chemical Composition (wt %) of the J. M. Farley Unit 2 Reactor Vessel Surveillance Materials	4-3
Table 4-2	Heat Treatment of the J. M. Farley Unit 2 Reactor Vessel Surveillance Material	4-4
Table 5-1	Charpy V-Notch Data for the J. M. Farley Unit 2 Intermediate Shell Plate B7212-1 Irradiated to a Fluence of 5.28×10^{19} n/cm ² (E > 1.0 MeV) (Longitudinal Orientation)	5-6
Table 5-2	Charpy V-notch Data for the J. M. Farley Unit 2 Intermediate Shell Plate B7212-1 Irradiated to a Fluence of 5.28×10^{19} n/cm ² (E > 1.0 MeV) (Transverse Orientation).....	5-7
Table 5-3	Charpy V-notch Data for the J. M. Farley Unit 2 Surveillance Weld Metal Irradiated to a Fluence of 5.28×10^{19} n/cm ² (E > 1.0 MeV)	5-8
Table 5-4	Charpy V-notch Data for the J. M. Farley Unit 2 Heat-Affected-Zone Material Irradiated to a Fluence of 5.28×10^{19} n/cm ² (E > 1.0 MeV).....	5-9
Table 5-5	Instrumented Charpy Impact Test Results for the J. M. Farley Unit 2 Intermediate Shell Plate B7212-1 Irradiated to a Fluence of 5.28×10^{19} n/cm ² (E > 1.0 MeV) (Longitudinal Orientation)	5-10
Table 5-6	Instrumented Charpy Impact Test Results for the J. M. Farley Unit 2 Intermediate Shell Plate B7212-1 Irradiated to a Fluence of 5.28×10^{19} n/cm ² (E > 1.0 MeV) (Transverse Orientation).....	5-11
Table 5-7	Instrumented Charpy Impact Test Results for the J. M. Farley Unit 2 Surveillance Weld Metal Irradiated to a Fluence of 5.28×10^{19} n/cm ² (E > 1.0MeV)	5-12
Table 5-8	Instrumented Charpy Impact Test Results for the J. M. Farley Unit 2 Heat-Affected-Zone (HAZ) Metal Irradiated to a Fluence of 5.28×10^{19} n/cm ² (E > 1.0MeV)	5-13
Table 5-9	Effect of Irradiation to 5.28×10^{19} n/cm ² (E > 1.0 MeV) on the Notch Toughness Properties of the J. M. Farley Unit 2 Reactor Vessel Surveillance Materials	5-14
Table 5-10	Comparison of the J. M. Farley Unit 2 Surveillance Material 30 ft-lb Transition Temperature Shifts and Upper Shelf Energy Decreases with Regulatory Guide 1.99, Revision 2, Predictions	5-15

LIST OF TABLES (Cont.)

Table 5-11	Tensile Properties of the J. M. Farley Unit 2 Reactor Vessel Surveillance Materials Irradiated to 5.28×10^{19} n/cm ² (E> 1.0MeV).....	5-16
Table 6-1	Calculated Fast Neutron Exposure Rates and Iron Atom Displacement Rates at the Surveillance Capsule Center.....	6-12
Table 6-2	Calculated Azimuthal Variation of Fast Neutron Exposure Rates and Iron Atom Displacement Rates at the Reactor Vessel Clad/Base Metal Interface.....	6-14
Table 6-3	Relative Radial Distribution of $\phi(E > 1.0 \text{ MeV})$ within the Reactor Vessel Wall.....	6-16
Table 6-4	Relative Radial Distribution of $\phi(E > 0.1 \text{ MeV})$ within the Reactor Vessel Wall.....	6-17
Table 6-5	Relative Radial Distribution of dpa/sec within the Reactor Vessel Wall.....	6-18
Table 6-6	Nuclear Parameters used in the Evaluation of Neutron Sensors.....	6-19
Table 6-7	Monthly Thermal Generation During the First Twelve Fuel Cycles of the Farley Unit 2 Reactor.....	6-20
Table 6-8	Measured Sensor Activities and Reaction Rates - Surveillance Capsule U..... - Surveillance Capsule W..... - Surveillance Capsule X..... - Surveillance Capsule Z.....	6-22 6-23 6-24 6-25
Table 6-9	Summary of Neutron Dosimetry Results Surveillance Capsules U, W, X and Z.....	6-26
Table 6-10	Comparison of Measured, Calculated and Best Estimate Reaction Rates at the Surveillance Capsule Center.....	6-27
Table 6-11	Best Estimate Neutron Energy Spectrum at the Center of Surveillance Capsules - Capsule U..... - Capsule W..... - Capsule X..... - Capsule Z.....	6-29 6-30 6-31 6-32
Table 6-12	Comparison of Calculated and Best Estimate Integrated Neutron Exposure of Farley Unit 2 Surveillance Capsule U, W, X and Z.....	6-33
Table 6-13	Azimuthal Variations of the Neutron Exposure Projections on the Reactor Vessel Clad/Base Metal Interface at Core Midplane.....	6-34

LIST OF TABLES (Cont.)

Table 6-14	Neutron Exposure Values within the Farley Unit 2 Reactor Vessel.....	6-36
Table 6-15	Updated Lead Factors for the J. M. Farley Unit 2 Surveillance Capsules.....	6-38
Table 7-1	J. M. Farley Unit 2 Reactor Vessel Surveillance Capsule Withdrawal Schedule	7-1

LIST OF FIGURES

Figure 4-1	Arrangement of Surveillance Capsules in the J. M. Farley Unit 2 Reactor Vessel.....	4-5
Figure 4-2	Capsule Z Diagram Showing the Location of Specimens, Thermal Monitors, and Dosimeters.....	4-6
Figure 5-1	Charpy V-Notch Impact Energy vs. Temperature for J. M. Farley Unit 2 Reactor Vessel Intermediate Shell Plate B7212-1 (Longitudinal Orientation)	5-17
Figure 5-2	Charpy V-Notch Lateral Expansion vs. Temperature for J. M. Farley Unit 2 Reactor Vessel Intermediate Shell Plate B7212-1 (Longitudinal Orientation).....	5-18
Figure 5-3	Charpy V-Notch Percent Shear vs. Temperature for J. M. Farley Unit 2 Reactor Vessel Intermediate Shell Plate B7212-1 (Longitudinal Orientation)	5-19
Figure 5-4	Charpy V-Notch Impact Energy vs. Temperature for J. M. Farley Unit 2 Reactor Vessel Intermediate Shell Plate B7212-1 (Transverse Orientation).....	5-20
Figure 5-5	Charpy V-Notch Lateral Expansion vs. Temperature for J. M. Farley Unit 2 Reactor Vessel Intermediate Shell Plate B7212-1 (Transverse Orientation)	5-21
Figure 5-6	Charpy V-Notch Percent Shear vs. Temperature for J. M. Farley Unit 2 Reactor Vessel Intermediate Shell Plate B7212-1 (Transverse Orientation).....	5-22
Figure 5-7	Charpy V-Notch Impact Energy vs. Temperature for J. M. Farley Unit 2 Reactor Vessel Weld Metal	5-23
Figure 5-8	Charpy V-Notch Lateral Expansion vs. Temperature for J. M. Farley Unit 2 Reactor Vessel Weld Metal	5-24
Figure 5-9	Charpy V-Notch Percent Shear vs. Temperature for J. M. Farley Unit 2 Reactor Vessel Weld Metal	5-25
Figure 5-10	Charpy V-Notch Impact Energy vs. Temperature for J. M. Farley Unit 2 Reactor Vessel Heat-Affected-Zone Material.....	5-26
Figure 5-11	Charpy V-Notch Lateral Expansion vs. Temperature for J. M. Farley Unit 2 Reactor Vessel Heat-Affected-Zone Material.....	5-27
Figure 5-12	Charpy V-Notch Percent Shear vs. Temperature for J. M. Farley Unit 2 Reactor Vessel Heat-Affected-Zone Material.....	5-28
Figure 5-13	Charpy Impact Specimen Fracture Surfaces for J. M. Farley Unit 2 Reactor Vessel Intermediate Shell Plate B7212-1 (Longitudinal Orientation)	5-29

LIST OF FIGURES (Cont.)

Figure 5-14	Charpy Impact Specimen Fracture Surfaces for J. M. Farley Unit 2 Reactor Vessel Intermediate Shell Plate B7212-1 (Transverse Orientation)	5-30
Figure 5-15	Charpy Impact Specimen Fracture Surfaces for J. M. Farley Unit 2 Reactor Vessel Weld Metal	5-31
Figure 5-16	Charpy Impact Specimen Fracture Surfaces for J. M. Farley Unit 2 Reactor Vessel Heat-Affected-Zone Metal	5-32
Figure 5-17	Tensile Properties for J. M. Farley Unit 2 Reactor Vessel Intermediate Shell Plate B7212-1 (Longitudinal Orientation)	5-33
Figure 5-18	Tensile Properties for J. M. Farley Unit 2 Reactor Vessel Intermediate Shell Plate B7212-1 (Transverse Orientation)	5-34
Figure 5-19	Tensile Properties for J. M. Farley Unit 2 Reactor Vessel Weld Metal	5-35
Figure 5-20	Fractured Tensile Specimens from J. M. Farley Unit 2 Reactor Vessel Intermediate Shell Plate B7212-1 (Longitudinal Orientation)	5-36
Figure 5-21	Fractured Tensile Specimens from J. M. Farley Unit 2 Reactor Vessel Intermediate Shell Plate B7212-1 (Transverse Orientation)	5-37
Figure 5-22	Fractured Tensile Specimens from J. M. Farley Unit 2 Reactor Vessel Weld Metal	5-38
Figure 5-23	Engineering Stress-Strain Curves for Intermediate Shell Plate B7212-1 Tensile Specimens CL16, CL17 and CL18 (Longitudinal Orientation)	5-39
Figure 5-24	Engineering Stress-Strain Curve for Intermediate Shell Plate B7212-1 Tensile Specimen CT16, CT17 and CT18 (Transverse Orientation)	5-40
Figure 5-25	Engineering Stress-Strain Curves for Weld Metal Tensile Specimens CW16, CW17 and CW18	5-41
Figure 6-1	Plan View of a Dual Reactor Vessel Surveillance Capsule	6-11

PREFACE

Revision 1:


The purpose of this revision is to re-evaluate the credibility evaluation of the intermediate shell plate B7212-1 surveillance program data without rounding the individual Charpy test data points. Contained in Appendix D is the revised credibility evaluation and this revised evaluation indicates that both the intermediate shell plate B7212-1 and weld metal surveillance data are credible. The balance of the report has been updated, as necessary, to reflect this re-evaluation.

This report has been technically reviewed and verified by:

Reviewer:

Sections 1 through 5, 7, 8, Appendices A, B and C

T. J. Laubham



Section 6

S. L. Anderson



EXECUTIVE SUMMARY

The purpose of this report is to document the results of the testing of surveillance capsule Z from the J. M. Farley Unit 2 reactor vessel. Capsule Z was removed at 13.24 EFPY and post irradiation mechanical tests of the Charpy V-notch and tensile specimens was performed, along with a fluence evaluation. The peak clad base/metal interface vessel fluence after 13.24 EFPY of plant operation was 1.75×10^{19} n/cm². A brief summary of the Charpy V-notch testing results can be found in Section 1 while the detailed results can be found in Sections 5 and 6. These results indicate that the measured 30 ft-lb shifts are in good agreement with the Regulatory Guide 1.99, Revision 2, predictions. All beltline materials exhibit a more than adequate upper shelf energy level for continued safe plant operation. The updated capsule removal schedule can be found in Section 7 and indicates that the remaining surveillance capsules are standby. A surveillance program credibility evaluation can be found in Appendix D. This evaluation indicates that the J. M. Farley Unit 2 surveillance program material (intermediate shell plate B7212-1 and weld metal Heat # BOLA) test data is credible.

1 SUMMARY OF RESULTS

The analysis of the reactor vessel materials contained in surveillance capsule Z, the fourth capsule to be removed from the J. M. Farley Unit 2 reactor pressure vessel, led to the following conclusions:

- The Charpy V-notch data presented in WCAP-8956[1], WCAP-10425[2], WCAP-11438[3], and WCAP-12471[4] were based on hand-fit Charpy curves using engineering judgment. However, the results presented in this report are based on a re-plot of all capsule data using CVGRAPH, Version 4.1, which is a hyperbolic tangent curve-fitting program. Appendix B presents a comparison of the Charpy V-Notch test results for each capsule based on hand fit vs. hyperbolic tangent fit. Appendix C presents the CVGRAPH, Version 4.1, Charpy V-notch plots and the program input data.
- Fluence projections for future operation were based on the assumption that the exposure rates averaged over Cycle 9 through 12 (low-leakage loading pattern) would continue to be applicable throughout plant life.
- The capsule received an average fast neutron fluence ($E > 1.0$ MeV) of 5.28×10^{19} n/cm² after 13.24 effective full power years (EFPY) of plant operation.
- Irradiation of the reactor vessel intermediate shell plate B7212-1 Charpy specimens, oriented with the longitudinal axis of the specimen parallel to the major rolling direction (Longitudinal orientation), to 5.28×10^{19} n/cm² ($E > 1.0$ MeV) resulted in a 30 ft-lb transition temperature increase of 200.24°F and a 50 ft-lb transition temperature increase of 198.87°F. This results in an irradiated 30 ft-lb transition temperature of 177.59°F and an irradiated 50 ft-lb transition temperature of 208.74°F for the longitudinal oriented specimens.
- Irradiation of the reactor vessel intermediate shell plate B7212-1 Charpy specimens, oriented with the longitudinal axis of the specimen perpendicular to the major rolling direction of the plate (Transverse orientation), to 5.28×10^{19} n/cm² ($E > 1.0$ MeV) resulted in a 30 ft-lb transition temperature increase of 195.5°F and a 50 ft-lb transition temperature increase of 197.45°F. This results in an irradiated 30 ft-lb transition temperature of 188.06°F and an irradiated 50 ft-lb transition temperature of 231.12°F for transverse oriented specimens.
- Irradiation of the weld metal Charpy specimens to 5.28×10^{19} n/cm² ($E > 1.0$ MeV) resulted in a 30 ft-lb transition temperature increase of 10.0°F and a 50 ft-lb transition temperature increase of 14.2°F. This results in an irradiated 30 ft-lb transition temperature of -24.7°F and an irradiated 50 ft-lb transition temperature of -1.4°F.
- Irradiation of the weld Heat-Affected-Zone (HAZ) metal Charpy specimens to 5.28×10^{19} n/cm² ($E > 1.0$ MeV) resulted in a 30 ft-lb transition temperature increase of 142.6°F and a 50 ft-lb transition temperature increase of 113.6°F. This results in an irradiated 30 ft-lb transition temperature of -32.8°F and an irradiated 50 ft-lb transition temperature of -3.2°F.

-
- The average upper shelf energy of the intermediate shell plate B7212-1 (Longitudinal orientation) resulted in an average energy decrease of 36 ft-lb after irradiation to $5.28 \times 10^{19} \text{ n/cm}^2$ ($E > 1.0 \text{ MeV}$). This results in an irradiated average upper shelf energy of 94 ft-lb for the longitudinal oriented specimens.
 - The average upper shelf energy of the intermediate shell plate B7212-1 (Transverse orientation) resulted in an average energy decrease of 27 ft-lb after irradiation to $5.28 \times 10^{19} \text{ n/cm}^2$ ($E > 1.0 \text{ MeV}$). Hence, this results in an irradiated average upper shelf energy of 68 ft-lb for the transverse oriented specimens.
 - The average upper shelf energy of the weld metal Charpy specimens resulted an average energy decrease of 11 ft-lb after irradiation to $5.28 \times 10^{19} \text{ n/cm}^2$ ($E > 1.0 \text{ MeV}$). Hence, this results in an irradiated average upper shelf energy of 133 ft-lb for the weld metal specimens.
 - The average upper shelf energy of the weld HAZ metal Charpy specimens resulted in an average energy decrease of 32 ft-lb after irradiation to $5.28 \times 10^{19} \text{ n/cm}^2$ ($E > 1.0 \text{ MeV}$). This results in an irradiated average upper shelf energy of 126 ft-lb for the weld HAZ metal.
 - A comparison of the J. M. Farley Unit 2 reactor vessel beltline material test results with the Regulatory Guide 1.99, Revision 2^[5] predictions led to the following conclusions:
 - The measured 30 ft-lb shift in transition temperature of the transverse oriented surveillance plate material contained in capsule X is in good agreement with the Regulatory Guide 1.99, Revision 2, prediction (i.e. within 5°F of the predicted 30 ft-lb shift). The measured 30 ft-lb shift in transition temperature values of all other surveillance results are less than the Regulatory Guide 1.99, Revision 2, predictions.
 - The measured percent decrease in upper shelf energy (USE) of the capsule U surveillance plate material is in good agreement with the Regulatory Guide 1.99, Revision 2, prediction (i.e. within 1 or 2 percent of the predicted USE). The measured percent decrease in upper shelf energy for all other surveillance materials is less than the Regulatory Guide 1.99, Revision 2, predictions.

- The calculated and best estimate end-of-license (36 EFPY) neutron fluence ($E > 1.0$ MeV) at the core midplane for the J. M. Farley Unit 2 reactor vessel using the Regulatory Guide 1.99, Revision 2 attenuation formula (ie. Equation # 3 in the guide) is as follows:

Calculated: Vessel inner radius* = 4.28×10^{19} n/cm²
 Vessel 1/4 thickness = 2.67×10^{19} n/cm²
 Vessel 3/4 thickness = 1.04×10^{19} n/cm²

Best Estimate: Vessel inner radius* = 3.71×10^{19} n/cm²
 Vessel 1/4 thickness = 2.31×10^{19} n/cm²
 Vessel 3/4 thickness = 8.99×10^{18} n/cm²

*Clad/base metal interface

- The credibility evaluation of the J. M. Farley Unit 2 surveillance program presented in Appendix D of this report indicates that the surveillance results for intermediate shell plate B7212-1 and the surveillance results for the weld metal are credible.
- All beltline materials exhibit a more than adequate upper shelf energy level for continued safe plant operation and are expected to maintain an upper shelf energy greater than 50 ft-lb throughout the life of the vessel (36 EFPY) as required by 10CFR50, Appendix G[6].
- The calculated and best estimate end-of-license (54 EFPY) neutron fluence ($E > 1.0$ MeV) at the core midplane for the J. M. Farley Unit 2 reactor vessel using the Regulatory Guide 1.99, Revision 2 attenuation formula (ie. Equation # 3 in the guide) is as follows:

Calculated: Vessel inner radius* = 6.29×10^{19} n/cm²
 Vessel 1/4 thickness = 3.92×10^{19} n/cm²
 Vessel 3/4 thickness = 1.52×10^{19} n/cm²

Best Estimate: Vessel inner radius* = 5.44×10^{19} n/cm²
 Vessel 1/4 thickness = 3.39×10^{19} n/cm²
 Vessel 3/4 thickness = 1.32×10^{19} n/cm²

*Clad/base metal interface

- All beltline materials exhibit a more than adequate upper shelf energy level for continued safe plant operation and are expected to maintain an upper shelf energy greater than 50 ft-lb through a life extension of the vessel (i.e. through 54 EFPY) as required by 10CFR50, Appendix G[6].

2 INTRODUCTION

This report presents the results of the examination of Capsule Z, the fourth capsule removed from the reactor in the continuing surveillance program which monitors the effects of neutron irradiation on the Alabama Power Company J. M. Farley Unit 2 reactor pressure vessel materials under actual operating conditions.

The surveillance program for the J. M. Farley Unit 2 reactor pressure vessel materials was designed and recommended by the Westinghouse Electric Company. A description of the surveillance program and the preirradiation mechanical properties of the reactor vessel materials is presented in WCAP-8956, "Alabama Power Company Joseph M. Farley Nuclear Plant Unit No. 2 Reactor Vessel Radiation Surveillance Program"^[1]. The surveillance program was planned to cover the 40-year design life of the reactor pressure vessel and was based on ASTM E185-73, "Standard Recommended Practice for Surveillance Tests for Nuclear Reactor Vessels"^[7]. Capsule Z was removed from the reactor after 13.24 EFPY of exposure and shipped to the Westinghouse Science and Technology Center Hot Cell Facility, where the postirradiation mechanical testing of the Charpy V-notch impact and tensile surveillance specimens was performed.

The Charpy V-notch data presented in WCAP-8956^[1], WCAP-10425^[2], WCAP-11438^[3], and WCAP-12471^[4] were based on hand-fit Charpy curves using engineering judgment. However, the results presented in this report are based on a re-plot of all capsule data using CVGRAPH, Version 4.1, which is a hyperbolic tangent curve-fitting program. Appendix B presents a comparison of the Charpy V-Notch test results for each capsule based on hand fit vs. hyperbolic tangent fit. Appendix C presents the CVGRAPH, Version 4.1, Charpy V-notch plots and the program input data.

This report summarizes the testing of and the post-irradiation data obtained from surveillance capsule Z removed from the Alabama Power Company J. M. Farley Unit 2 reactor vessel and discusses the analysis of the data.

3 BACKGROUND

The ability of the large steel pressure vessel containing the reactor core and its primary coolant to resist fracture constitutes an important factor in ensuring safety in the nuclear industry. The beltline region of the reactor pressure vessel is the most critical region of the vessel because it is subjected to significant fast neutron bombardment. The overall effects of fast neutron irradiation on the mechanical properties of low alloy, ferritic pressure vessel steels such as SA533 Grade B Class 1 plate (base material of the J. M. Farley Unit 2 reactor pressure vessel beltline) are well documented in the literature. Generally, low alloy ferritic materials show an increase in hardness and tensile properties and a decrease in ductility and toughness during high-energy irradiation.

A method for ensuring the integrity of reactor pressure vessels has been presented in "Fracture Toughness Criteria for Protection Against Failure," Appendix G to Section XI of the ASME Boiler and Pressure Vessel Code^[8]. The method uses fracture mechanics concepts and is based on the reference nil-ductility transition temperature (RT_{NDT}).

RT_{NDT} is defined as the greater of either the drop weight nil-ductility transition temperature (NDTT per ASTM E-208^[9]) or the temperature 60°F less than the 50 ft-lb (and 35-mil lateral expansion) temperature as determined from Charpy specimens oriented perpendicular (transverse) to the major rolling direction of the plate. The RT_{NDT} of a given material is used to index that material to a reference stress intensity factor curve (K_{Ia} curve) which appears in Appendix G to the ASME Code^[8]. The K_{Ia} curve is a lower bound of dynamic, crack arrest, and static fracture toughness results obtained from several heats of pressure vessel steel. When a given material is indexed to the K_{Ia} curve, allowable stress intensity factors can be obtained for this material as a function of temperature. Allowable operating limits can then be determined using these allowable stress intensity factors.

RT_{NDT} and, in turn, the operating limits of nuclear power plants can be adjusted to account for the effects of radiation on the reactor vessel material properties. The changes in mechanical properties of a given reactor pressure vessel steel, due to irradiation, can be monitored by a reactor surveillance program, such as the J. M. Farley Unit 2 reactor vessel radiation surveillance program^[11], in which a surveillance capsule is periodically removed from the operating nuclear reactor and the encapsulated specimens tested. The increase in the average Charpy V-notch 30 ft-lb temperature (ΔRT_{NDT}) due to irradiation is added to the initial RT_{NDT} , along with a margin (M) to cover uncertainties, to adjust the RT_{NDT} (ART) for radiation embrittlement. This ART (RT_{NDT} initial + M + ΔRT_{NDT}) is used to index the material to the K_{Ia} curve and, in turn, to set operating limits for the nuclear power plant that take into account the effects of irradiation on the reactor vessel materials.

4 DESCRIPTION OF PROGRAM

Six surveillance capsules for monitoring the effects of neutron exposure on the J. M. Farley Unit 2 reactor pressure vessel core region (beltline) materials were inserted in the reactor vessel prior to initial plant start-up. The six capsules were positioned in the reactor vessel between the neutron pads and the vessel wall as shown in Figure 4-1. The vertical center of the capsules is opposite the vertical center of the core. The capsules contain specimens made from intermediate shell plate B7212-1 (Heat No. C7466-1), weld metal fabricated with ¼-inch E8018C3 weld filler wire heat number BOLA, which is identical to that used in the actual fabrication of the intermediate shell longitudinal weld seam 19-923B.

Capsule Z was removed after 13.24 effective full power years (EFPY) of plant operation. This capsule contained Charpy V-notch, tensile, and ½T-CT fracture mechanics specimens made from intermediate shell plate B7212-1 and manual arc weld metal identical intermediate shell longitudinal weld seam 19-923B. In addition, this capsule contained Charpy V-notch specimens from the weld Heat-Affected-Zone (HAZ) of intermediate shell plate B7212-1.

Test material obtained from intermediate shell plate B7212-1 (after the thermal heat treatment and forming of the plate) was taken at least one plate thickness from the quenched ends of the plate. All test specimens were machined from the ¼ and ¾ thickness locations of the plate after performing a simulated post-weld stress-relieving treatment on the test material. Specimens from weld metal and heat-affected-zone metal were machined from a stress-relieved weldment joining intermediate shell plate B7212-1 and intermediate shell plate B7203-1. All heat-affected-zone specimens were obtained from the weld heat-affected-zone of intermediate shell plate B7212-1.

Charpy V-notch impact specimens from intermediate shell plate B7212-1 were machined both in the longitudinal orientation (longitudinal axis of the specimen parallel to the major rolling direction) and transverse orientation (longitudinal axis of the specimen perpendicular to the major rolling direction). The core region weld Charpy impact specimens were machined from the weldment such that the long dimension of each Charpy specimen was perpendicular to the weld direction. The notch of the weld metal Charpy specimens was machined such that the direction of crack propagation in the specimen was in the welding direction.

Tensile specimens from intermediate shell plate B7212-1 were machined in both the longitudinal and transverse orientation. Tensile specimens from the weld metal were oriented with the long dimension of the specimen perpendicular to the weld direction.

Compact tension test specimens from plate B7212-1 were machined in both the longitudinal and transverse orientations. Compact tension test specimens from the weld metal were machined perpendicular to the weld direction with the notch oriented in the direction of the weld. All specimens were fatigue precracked according to ASTM E399.

The chemical composition and heat treatment of the surveillance material is presented in Tables 4-1 through 4-2. The chemical analysis reported in Table 4-1 was obtained from unirradiated material used in the surveillance program^[1] and from irradiated capsule W specimens^[3].

Capsule Z contained dosimeter wires of pure copper, iron, nickel, and aluminum-0.15 weight percent cobalt (cadmium-shielded and unshielded). In addition, cadmium shielded dosimeters of neptunium (Np^{237}) and uranium (U^{238}) were placed in the capsule to measure the integrated flux at specific neutron energy levels.

The capsule contained thermal monitors made from two low-melting-point eutectic alloys and sealed in Pyrex tubes. These thermal monitors were used to define the maximum temperature attained by the test specimens during irradiation. The composition of the two eutectic alloys and their melting points are as follows:

2.5% Ag, 97.5% Pb Melting Point: 579°F (304°C)

1.75% Ag, 0.75% Sn, 97.5% Pb Melting Point: 590°F (310°C)

The arrangement of the various mechanical specimens, dosimeters and thermal monitors contained in capsule Z is shown in Figure 4-2.

Element	Plate B7212-1		Weld Metal	
	Unirradiated Data	Capsule W ^(b)	Unirradiated Data	Capsule W ^(b)
C	0.21	0.224	<0.086	0.139
Mn	1.30	1.38	0.95	0.91
P	0.018	0.008	0.004	0.006
S	0.016	0.016	0.014	0.013
Si	0.24	0.208	0.34	0.291
Ni	0.60	0.59	0.90	0.88
Mo	0.49	0.49	0.23	0.243
Cr	0.15 ^(a)	0.153	<0.01	0.27
Cu	0.20	0.186	0.03	0.026
Al	0.04	--	0.003	--
Co	0.027	0.005	0.010	0.005
V	0.003 ^(a)	<0.002	0.006	0.003
Sn	0.011 ^(a)	--	0.002	--
N ₂	0.006 ^(a)	--	0.007	--

Notes:

- Chemical Analysis by Westinghouse.
- Chemical Analysis by Westinghouse on irradiated Charpy specimens CL-34 and CW-41 removed from Capsule W.
- This weld was fabricated by CE, Inc. by a manual metal arc process with ¼ inch E8018C3 weld filler wire heat number BOLA. This weld is identical to that used for intermediate shell weld seam 19-923B.

Table 4-2 Heat Treatment of the J. M. Farley Unit 2 Reactor Vessel Surveillance Material^[1]

Material	Temperature (°F)	Time (hrs.)	Coolant
Surveillance Program Test	Austenitizing: 1550/1650	4	Water-quenched
Plate B7212-1	Tempered: 1225 ± 25	4	Air Cooled
	Stress Relief: 1150 ± 25	18	Furnace Cooled to 600°F
Weldment	1150 ± 25	13	Furnace Cooled




Figure 4-1 Arrangement of Surveillance Capsules in the J. M. Farley Unit 2 Reactor Vessel

SPECIMEN CODE:

CT - PLATE B7212-1 (TRANSVERSE ORIENTATION)

CL - PLATE B7212-1 (LONGITUDINAL ORIENTATION)

CW - CORE REGION WELD METAL

CH - HEAT-AFFECTED-ZONE METAL

CAPSULE

Z

Np²³⁷
U²³⁸




Figure 4-2 Capsule Z Diagram Showing the Location of Specimens, Thermal Monitors, and Dosimeters

5 TESTING OF SPECIMENS FROM CAPSULE Z

5.1 OVERVIEW

The post-irradiation mechanical testing of the Charpy V-notch impact specimens and tensile specimens was performed in the Remote Metallographic Facility (RMF) at the Westinghouse Science and Technology Center. Testing was performed in accordance with 10CFR50, Appendices G^[6] and H^[10], ASTM Specification E185-82^[11], and Westinghouse Procedure RMF 8402, Revision 2 as modified by Westinghouse RMF Procedures 8102, Revision 1, and 8103, Revision 1.

Upon receipt of the capsule at the hot cell laboratory, the specimens and spacer blocks were carefully removed, inspected for identification number, and checked against the master list in WCAP-8956^[11]. No discrepancies were found.

Examination of the two low-melting point 579°F (304°C) and 590°F (310°C) eutectic alloys indicated no melting of either type of thermal monitor. Based on this examination, the maximum temperature to which the test specimens were exposed was less than 579°F (304°C).

The Charpy impact tests were performed per ASTM Specification E23-93a^[12] and RMF Procedure 8103, Revision 1, on a Tinius-Olsen Model 74, 358J machine. The tup (striker) of the Charpy impact test machine is instrumented with a GRC 930-I instrumentation system, feeding information into an IBM compatible computer. With this system, load-time and energy-time signals can be recorded in addition to the standard measurement of Charpy energy (E_D). From the load-time curve (Appendix A), the load of general yielding (P_{GY}), the time to general yielding (t_{GY}), the maximum load (P_M), and the time to maximum load (t_M) can be determined. Under some test conditions, a sharp drop in load indicative of fast fracture was observed. The load at which fast fracture was initiated is identified as the fast fracture load (P_F), and the load at which fast fracture terminated is identified as the arrest load (P_A). The energy at maximum load (E_M) was determined by comparing the energy-time record and the load-time record. The energy at maximum load is approximately equivalent to the energy required to initiate a crack in the specimen. Therefore, the propagation energy for the crack (E_p) is the difference between the total energy to fracture (E_D) and the energy at maximum load (E_M).

The yield stress (σ_Y) was calculated from the three-point bend formula having the following expression:

$$\sigma_Y = (P_{GY} * L) / [B * (W - a)^2 * C] \quad (1)$$

where: L = distance between the specimen supports in the impact machine
 B = the width of the specimen measured parallel to the notch
 W = height of the specimen, measured perpendicularly to the notch
 a = notch depth

The constant C is dependent on the notch flank angle (ϕ), notch root radius (ρ) and the type of loading (i.e., pure bending or three-point bending). In three-point bending, for a Charpy specimen in which $\phi = 45^\circ$ and $\rho = 0.010$ inch, Equation 1 is valid with $C = 1.21$. Therefore, (for $L = 4W$),

$$\sigma_y = (P_{GY} * L) / [B * (W - a)^2 * 1.21] = (3.33 * P_{GY} * W) / [B * (W - a)^2] \quad (2)$$

For the Charpy specimen, $B = 0.394$ inch, $W = 0.394$ inch and $a = 0.079$ inch. Equation 2 then reduces to:

$$\sigma_y = 33.3 * P_{GY} \quad (3)$$

where σ_y is in units of psi and P_{GY} is in units of lbs. The flow stress was calculated from the average of the yield and maximum loads, also using the three-point bend formula.

The symbol A in columns 4, 5, and 6 of Tables 5-5 through 5-8 is the cross-section area under the notch of the Charpy specimens:

$$A = B * (W - a) = 0.1241 \text{ sq.in.} \quad (4)$$

Percent shear was determined from post-fracture photographs using the ratio-of-areas methods in compliance with ASTM Specification A370-92^[13]. The lateral expansion was measured using a dial gage rig similar to that shown in the same specification.

Tensile tests were performed on a 20,000-pound Instron, split-console test machine (Model 1115) per ASTM Specification E8-93^[14] and E21-92^[15], and RMF Procedure 8102, Revision 1. All pull rods, grips, and pins were made of Inconel 718. The upper pull rod was connected through a universal joint to improve axiality of loading. The tests were conducted at a constant crosshead speed of 0.05 inches per minute throughout the test.

Extension measurements were made with a linear variable displacement transducer extensometer. The extensometer knife edges were spring-loaded to the specimen and operated through specimen failure. The extensometer gage length was 1.00 inch. The extensometer is rated as Class B-2 per ASTM E83-93^[16].

Elevated test temperatures were obtained with a three-zone electric resistance split-tube furnace with a 9-inch hot zone. All tests were conducted in air. Because of the difficulty in remotely attaching a thermocouple directly to the specimen, the following procedure was used to monitor specimen temperatures. Chromel-Alumel thermocouples were positioned at the center and at each end of the gage section of a dummy specimen and in each tensile machine gripper. In the test configuration, with a slight load on the specimen, a plot of specimen temperature versus upper and lower tensile machine gripper and controller temperatures was developed over the range from room temperature to 550°F. During the actual testing, the grip temperatures were used to obtain desired specimen temperatures. Experiments have indicated that this method is accurate to $\pm 2^\circ\text{F}$.

The yield load, ultimate load, fracture load, total elongation, and uniform elongation were determined directly from the load-extension curve. The yield strength, ultimate strength, and fracture strength were calculated using the original cross-sectional area. The final diameter and final gage length were determined from post-fracture photographs. The fracture area used to calculate the fracture stress (true stress at fracture) and percent reduction in area was computed using the final diameter measurement.

5.2 CHARPY V-NOTCH IMPACT TEST RESULTS

The results of the Charpy V-notch impact tests performed on the various materials contained in capsule Z, which received a fluence of $5.28 \times 10^{19} \text{ n/cm}^2$ ($E > 1.0 \text{ MeV}$) in 13.24 EFPY of operation, are presented in Tables 5-1 through 5-8 and are compared with unirradiated results^[1] as shown in Figures 5-1 through 5-12.

The transition temperature increases and upper shelf energy decreases for the capsule Z materials are summarized in Table 5-9. These results led to the following conclusions:

- Irradiation of the reactor vessel intermediate shell plate B7212-1 Charpy specimens, oriented with the longitudinal axis of the specimen parallel to the major rolling direction (Longitudinal orientation), to $5.28 \times 10^{19} \text{ n/cm}^2$ ($E > 1.0 \text{ MeV}$) resulted in a 30 ft-lb transition temperature increase of 200.24°F and a 50 ft-lb transition temperature increase of 198.87°F. This results in an irradiated 30 ft-lb transition temperature of 177.59°F and an irradiated 50 ft-lb transition temperature of 208.74°F for the longitudinal oriented specimens.
- Irradiation of the reactor vessel intermediate shell plate B7212-1 Charpy specimens, oriented with the longitudinal axis of the specimen perpendicular to the major rolling direction of the plate (Transverse orientation), to $5.28 \times 10^{19} \text{ n/cm}^2$ ($E > 1.0 \text{ MeV}$) resulted in a 30 ft-lb transition temperature increase of 195.5°F and a 50 ft-lb transition temperature increase of 197.45°F. This results in an irradiated 30 ft-lb transition temperature of 188.06°F and an irradiated 50 ft-lb transition temperature of 231.12°F for transverse oriented specimens.
- Irradiation of the weld metal Charpy specimens to $5.28 \times 10^{19} \text{ n/cm}^2$ ($E > 1.0 \text{ MeV}$) resulted in a 30 ft-lb transition temperature increase of 10.0°F and a 50 ft-lb transition temperature increase of 14.2°F. This results in an irradiated 30 ft-lb transition temperature of -24.7°F and an irradiated 50 ft-lb transition temperature of -1.4°F.
- Irradiation of the weld Heat-Affected-Zone (HAZ) metal Charpy specimens to $5.28 \times 10^{19} \text{ n/cm}^2$ ($E > 1.0 \text{ MeV}$) resulted in a 30 ft-lb transition temperature increase of 142.6°F and a 50 ft-lb transition temperature increase of 113.6°F. This results in an irradiated 30 ft-lb transition temperature of -32.8°F and an irradiated 50 ft-lb transition temperature of -3.2°F.

- The average upper shelf energy of the intermediate shell plate B7212-1 (Longitudinal orientation) resulted in an average energy decrease of 36 ft-lb after irradiation to 5.28×10^{19} n/cm² ($E > 1.0$ MeV). This results in an irradiated average upper shelf energy of 94 ft-lb for the longitudinal oriented specimens.
- The average upper shelf energy of the intermediate shell plate B7212-1 (Transverse orientation) resulted in an average energy decrease of 27 ft-lb after irradiation to 5.28×10^{19} n/cm² ($E > 1.0$ MeV). Hence, this results in an irradiated average upper shelf energy of 68 ft-lb for the transverse oriented specimens.
- The average upper shelf energy of the weld metal Charpy specimens resulted an average energy decrease of 11 ft-lb after irradiation to 5.28×10^{19} n/cm² ($E > 1.0$ MeV). Hence, this results in an irradiated average upper shelf energy of 133 ft-lb for the weld metal specimens.
- The average upper shelf energy of the weld HAZ metal Charpy specimens resulted in an average energy decrease of 32 ft-lb after irradiation to 5.28×10^{19} n/cm² ($E > 1.0$ MeV). This results in an irradiated average upper shelf energy of 126 ft-lb for the weld HAZ metal.
- A comparison of the J. M. Farley Unit 2 reactor vessel beltline material test results with the Regulatory Guide 1.99, Revision 2^[5] predictions (See Table 5-10) led to the following conclusions:
 - The measured 30 ft-lb shift in transition temperature of the transverse oriented surveillance plate material contained in capsule X is in good agreement with the Regulatory Guide 1.99, Revision 2, prediction (i.e. within 5°F of the predicted 30 ft-lb shift). The measured 30 ft-lb shift in transition temperature values of all other surveillance results are less than the Regulatory Guide 1.99, Revision 2, predictions.
 - The measured percent decrease in upper shelf energy (USE) of the capsule U surveillance plate material is in good agreement with the Regulatory Guide 1.99, Revision 2, prediction (i.e. within 1 or 2 percent of the predicted USE). The measured percent decrease in upper shelf energy for all other surveillance materials is less than the Regulatory Guide 1.99, Revision 2, predictions.

The fracture appearance of each irradiated Charpy specimen from the various surveillance capsule Z materials is shown in Figures 5-13 through 5-16 and show an increasingly ductile or tougher appearance with increasing test temperature.

All beltline materials exhibit a more than adequate upper shelf energy level for continued safe plant operation and are expected to maintain an upper shelf energy of no less than 50 ft-lb throughout the life of the vessel (36 EFY) as required by 10CFR50, Appendix G^[6].

The load-time records for individual instrumented Charpy specimen tests are shown in Appendix A.

The Charpy V-notch data presented in WCAP-8956^[1], WCAP-10425^[2], WCAP-11438^[3] and WCAP-12471^[4] were based on hand-fit Charpy curves using engineering judgment. However, the results

presented in this report are based on a re-plot of all capsule data using CVGRAPH, Version 4.1, which is a hyperbolic tangent curve-fitting program. Appendix B presents a comparison of the Charpy V-Notch test results for each capsule based on hand fit vs. hyperbolic tangent fit. Appendix C presents the CVGRAPH, Version 4.1, Charpy V-notch plots and the program input data.

Appendix D of this report contains a credibility evaluation of the surveillance data from the J. M. Farley Unit 2 reactor vessel surveillance program. This evaluation indicates that the surveillance results for intermediate shell plate B7212-1 and the surveillance results for the weld metal are credible.

5.3 TENSILE TEST RESULTS

The results of the tensile tests performed on the various materials contained in capsule Z irradiated to 5.28×10^{19} n/cm² (E > 1.0 MeV) are presented in Table 5-11 and are compared with unirradiated results^[1] as shown in Figures 5-17 through 5-19.

The results of the tensile tests performed on the intermediate shell plate B7212-1 (longitudinal orientation) indicated that irradiation to 5.28×10^{19} n/cm² (E > 1.0 MeV) caused approximately a 25 ksi increase in the 0.2 percent offset yield strength and approximately a 15 to 20 ksi increase in the ultimate tensile strength when compared to unirradiated data^[1] (Figure 5-17).

The results of the tensile tests performed on the intermediate shell plate B7212-1 (transverse orientation) indicated that irradiation to 5.28×10^{19} n/cm² (E > 1.0 MeV) caused an approximate increase of 30 ksi in the 0.2 percent offset yield strength and approximately a 20 ksi increase in the ultimate tensile strength when compared to unirradiated data^[1] (Figure 5-18).

The results of the tensile tests performed on the surveillance weld metal indicated that irradiation to 5.28×10^{19} n/cm² (E > 1.0 MeV) caused approximately a 8 ksi increase in the 0.2 percent offset yield strength and approximately a 5 to 8 ksi increase in the ultimate tensile strength when compared to unirradiated data^[1] (Figure 5-19).

The fractured tensile specimens for the intermediate shell plate B7212-1 material are shown in Figures 5-20 and 5-21, while the fractured tensile specimens for the surveillance weld metal are shown in Figure 5-22. The engineering stress-strain curves for the tensile tests are shown in Figures 5-23 through 5-25.

5.4 1/2T COMPACT TENSION SPECIMEN TESTS

Per the surveillance capsule testing contract, the 1/2T Compact Tension Specimens were not tested and are being stored at the Westinghouse Science and Technology Center Hot Cell facility.

Table 5-1 Charpy V-notch Data for the J. M. Farley Unit 2 Intermediate Shell Plate B7212-1 Irradiated to a Fluence of 5.28×10^{19} n/cm² (E > 1.0 MeV) (Longitudinal Orientation)

Sample Number	Temperature		Impact Energy		Lateral Expansion		Shear
	F	C	ft-lbs	Joules	mils	mm	%
CL81	0	-18	5	7	0	0.000	2
CL80	72	22	21	28	11	0.279	5
CL90	125	52	17	23	5	0.127	10
CL79	150	66	20	27	12	0.305	20
CL77	175	79	28	38	18	0.457	25
CL84	190	88	39	53	27	0.686	35
CL85	200	93	25	34	16	0.406	30
CL86	210	99	60	81	40	1.016	60
CL78	225	107	60	81	41	1.041	60
CL83	250	121	74	100	52	1.321	80
CL89	275	135	94	127	64	1.626	90
CL87	300	149	90	122	63	1.600	100
CL82	350	177	91	123	64	1.626	100
CL76	400	204	96	130	67	1.702	100
CL88	450	232	98	133	65	1.651	100

**Table 5-2 Charpy V-notch Data for the J. M. Farley Unit 2 Intermediate Shell Plate B7212-1
Irradiated to a Fluence of 5.28×10^{19} n/cm² (E > 1.0 MeV)
(Transverse Orientation)**

Sample Number	Temperature		Impact Energy		Lateral Expansion		Shear
	F	C	ft-lbs	Joules	mils	mm	%
CT84	0	-18	6	8	2	0.051	2
CT87	72	22	4	5	0	0.000	10
CT90	125	52	17	23	7	0.178	10
CT83	150	66	22	30	15	0.381	15
CT77	175	79	28	38	22	0.559	20
CT80	190	88	31	42	22	0.559	35
CT89	200	93	18	24	14	0.356	30
CT88	200	93	25	34	19	0.483	35
CT79	210	99	44	60	30	0.762	45
CT82	225	107	61	83	44	1.118	80
CT81	250	121	56	76	45	1.143	80
CT86	275	135	64	87	43	1.092	100
CT78	300	149	76	103	55	1.397	100
CT76	350	177	69	94	52	1.321	100
CT85	400	204	62	84	50	1.270	100

Table 5-3 Charpy V-notch Data for the J. M. Farley Unit 2 Surveillance Weld Metal Irradiated to a Fluence of 5.28×10^{19} n/cm² (E > 1.0 MeV)

Sample Number	Temperature		Impact Energy		Lateral Expansion		Shear
	F	C	ft-lbs	Joules	mils	mm	%
CW81	-100	-73	4	5	0	0.000	5
CW88	-60	-51	7	9	1	0.025	10
CW76	-30	-34	10	14	7	0.178	15
CW78	-6	-21	13	18	10	0.254	20
CW89	0	-18	72	98	52	1.321	30
CW90	5	-15	86	117	58	1.473	40
CW79	15	-9	57	77	42	1.067	50
CW85	15	-9	77	104	55	1.397	45
CW83	25	-4	86	117	62	1.575	65
CW87	30	-1	91	123	63	1.600	75
CW77	50	10	88	119	61	1.549	80
CW86	100	38	105	142	78	1.981	90
CW84	150	66	123	167	84	2.134	100
CW80	195	91	151	205	81	2.057	100
CW82	250	121	124	168	85	2.159	100

Table 5-4 Charpy V-notch Data for the J. M. Farley Unit 2 Heat Affected Zone Material Irradiated to a Fluence of 5.28×10^{19} n/cm² (E> 1.0 MeV)

Sample Number	Temperature		Impact Energy		Lateral Expansion		Shear %
	F	C	ft-lbs	Joules	mils	mm	
CH90	-100	-73	8	11	2	0.051	5
CH82	-60	-51	16	22	5	0.127	20
CH77	-30	-34	20	27	9	0.229	15
CH83	-20	-29	68	92	46	1.168	40
CH86	-15	-26	68	92	40	1.016	45
CH85	-10	-23	8	11	4	0.102	25
CH76	-10	-23	42	57	26	0.660	20
CH78	0	-18	44	60	25	0.635	25
CH87	0	-18	70	95	43	1.092	50
CH80	10	-12	7	9	1	0.025	10
CH89	25	-4	130	176	90	2.286	100
CH88	50	10	68	92	40	1.016	55
CH84	100	38	122	165	87	2.210	100
CH79	150	66	115	156	88	2.235	100
CH81	195	91	140	190	79	2.007	100

Table 5-5 Instrumented Charpy Impact Test Results for the J. M. Farley Unit 2 Intermediate Shell Plate B7212-1 Irradiated to a Fluence of 5.28×10^{19} n/cm² (E>1.0 MeV)(Longitudinal Orientation)

Sample No.	Test Temp. (°F)	Charpy Energy E _D (ft-lb)	Normalized Energies (ft-lb/in ²)			Yield Load P _{GY} (lb)	Time to Yield t _{GY} (msec)	Max. Load P _M (lb)	Time to Max. T _m (msec)	Fast Fract. Load P _F (lb)	Arrest Load P _A (lb)	Yield Stress S _Y (ksi)	Flow Stress (ksi)
			Charpy E _D /A	Max. E _M /A	Prop. E _P /A								
CL81	0	5	40	22	19	2661	0.13	2669	0.14	2661	0	89	89
CL80	72	21	169	74	95	4267	0.17	4656	0.22	4551	0	142	149
CL90	125	17	137	74	62	4137	0.17	4518	0.23	4434	0	138	144
CL79	150	20	161	72	89	3920	0.17	4302	0.23	4229	0	131	137
CL77	175	28	225	156	70	3936	0.17	4453	0.38	4418	60	131	140
CL84	190	39	314	237	77	3872	0.17	4634	0.52	4617	200	129	142
CL85	200	25	201	69	132	3896	0.17	4255	0.22	4106	448	130	136
CL86	210	60	483	242	241	3799	0.17	4745	0.52	4523	1753	127	142
CL78	225	60	483	233	250	3912	0.17	4723	0.50	4535	2033	130	144
CL83	250	74	596	227	369	3663	0.17	4582	0.51	3469	1477	122	137
CL89	275	94	757	234	523	3721	0.17	4702	0.52	2871	2460	124	140
CL87	300	90	725	224	501	3839	0.17	4629	0.50	N/A	N/A	128	141
CL82	350	91	733	228	504	3778	0.17	4549	0.51	N/A	N/A	126	139
CL76	400	96	773	233	540	3659	0.17	4497	0.53	N/A	N/A	122	136
CL88	450	98	789	222	567	3697	0.17	4468	0.51	N/A	N/A	123	136

**Table 5-6 Instrumented Charpy Impact Test Results for the J. M. Farley Unit 2 Intermediate Shell Plate B7212-1
Irradiated to a Fluence of 5.28×10^{19} n/cm² (E>1.0 MeV)(Transverse Orientation)**

Sample No.	Test Temp. (°F)	Charpy Energy E _D (ft-lb)	Normalized Energies (ft-lb/in ²)			Yield Load P _{GY} (lb)	Time to Yield t _{GY} (msec)	Max. Load P _M (lb)	Time to Max. t _M (msec)	Fast Fract. Load P _F (lb)	Arrest Load P _A (lb)	Yield Stress S _Y (ksi)	Flow Stress (ksi)
			Charpy E _D /A	Max. E _M /A	Prop. E _P /A								
CT84	0	6	48	26	22	3015	0.15	3027	0.14	3015	0	100	101
CT87	72	4	32	12	21	1505	0.11	1511	0.12	1505	75	50	50
CT90	125	17	137	71	66	3990	0.17	4355	0.23	4253	0	133	139
CT83	150	22	177	70	107	3934	0.17	4283	0.23	4189	69	131	137
CT77	175	28	225	153	72	3860	0.17	4329	0.38	4310	252	129	136
CT80	190	31	250	137	113	3898	0.17	4281	0.34	4227	991	130	136
CT88	200	18	145	74	71	3780	0.17	4190	0.24	3997	974	126	133
CT89	200	25	201	55	147	3791	0.17	4052	0.20	4043	832	126	131
CT79	210	44	354	202	152	3798	0.17	4426	0.47	4241	1690	126	137
CT82	225	61	491	226	265	3940	0.17	4719	0.49	4440	2393	131	144
CT81	250	56	451	168	283	3370	0.17	4152	0.43	3291	2236	112	125
CT86	275	64	515	180	335	3884	0.17	4425	0.42	N/A	N/A	129	138
CT78	300	76	612	209	403	3802	0.17	4529	0.48	N/A	N/A	127	139
CT76	350	69	556	200	355	3699	0.17	4412	0.47	N/A	N/A	123	135
CT85	400	62	499	162	337	3682	0.17	4284	0.40	N/A	N/A	123	133

**Table 5-7 Instrumented Charpy Impact Test Results for the J. M. Farley Unit 2 Surveillance Weld Metal
Irradiated to a Fluence of 5.28×10^{19} n/cm² (E>1.0 MeV)**

Sample No.	Test Temp. (°F)	Charpy Energy E _D (ft-lb)	Normalized Energies (ft-lb/in ²)			Yield Load P _{GY} (lb)	Time to Yield t _{GY} (msec)	Max. Load P _M (lb)	Time to Max. t _M (msec)	Fast Fract. Load P _F (lb)	Arrest Load P _A (lb)	Yield Stress S _Y (ksi)	Flow Stress (ksi)
			Charpy E _D /A	Max. E _M /A	Prop. E _P /A								
CW81	-100	4	32	17	15	2153	0.12	2161	0.13	2153	0	72	72
CW88	-60	7	56	26	30	3036	0.15	3036	0.15	3036	0	101	101
CW76	-30	10	7	15	***	***	***	***	***	***	***	***	***
CW78	-6	13	105	33	72	3315	0.16	3315	0.16	3315	622	110	110
CW89	0	72	580	311	269	3560	0.17	4259	0.70	3872	139	119	130
CW90	5	86	692	311	381	3604	0.17	4300	0.70	3677	158	120	132
CW79	15	57	459	297	162	3680	0.17	4156	0.67	4045	1048	123	130
CW85	15	77	620	304	316	3563	0.17	4191	0.69	3563	788	119	129
CW83	25	86	692	302	390	3560	0.17	4181	0.69	3735	1504	119	129
CW87	30	91	733	309	424	3620	0.17	4262	0.69	3701	1059	121	131
CW77	50	88	709	302	406	3533	0.17	4166	0.70	3666	1205	118	128
CW86	100	105	845	291	555	3494	0.17	3985	0.69	2836	1788	116	125
CW84	150	123	990	348	642	3290	0.17	3880	0.84	N/A	N/A	110	119
CW80	195	151	1216	356	859	2936	0.17	3853	0.87	N/A	N/A	98	113
CW82	250	124	998	265	734	3088	0.17	3718	0.68	N/A	N/A	103	113

*** Data not recorded due to computer malfunction.

Table 5-8 Instrumented Charpy Impact Test Results for the J. M. Farley Unit 2 Heat-Affected-Zone (HAZ) Metal Irradiated to a Fluence of 5.28×10^{19} n/cm² (E>1.0 MeV)

Sample No.	Test Temp. (°F)	Charpy Energy E _D (ft-lb)	Normalized Energies (ft-lb/in ²)			Yield Load P _{GY} (lb)	Time to Yield t _{GY} (msec)	Max. Load P _M (lb)	Time to Max. t _M (msec)	Fast Fract. Load P _F (lb)	Arrest Load P _A (lb)	Yield Stress S _Y (ksi)	Flow Stress (ksi)
			Charpy E _D /A	Max. E _M /A	Prop. E _P /A								
CH90	-100	8	64	39	26	3862	0.16	3929	0.17	3862	0	129	130
CH82	-60	16	129	72	56	4417	0.17	4860	0.22	4860	0	147	154
CH77	-30	20	161	71	90	4136	0.17	4511	0.22	4336	0	138	144
CH83	-20	68	548	220	328	4262	0.17	4676	0.47	3938	148	142	149
CH86	-15	68	548	248	300	4306	0.17	4769	0.51	4433	438	143	151
CH85	-10	8	64	33	31	3457	0.16	3465	0.16	3457	0	115	115
CH76	-10	42	338	246	92	4218	0.17	4704	0.51	4597	0	140	149
CH78	0	44	354	236	119	4025	0.17	4494	0.52	4385	506	134	142
CH87	0	70	564	240	324	4185	0.17	4657	0.51	4308	761	139	147
CH80	10	7	56	29	27	3218	0.16	3228	0.15	3218	0	107	107
CH89	25	130	1047	241	806	4105	0.17	4677	0.52	N/A	N/A	137	146
CH88	50	68	548	240	307	4006	0.17	4558	0.52	4349	900	133	143
CH84	100	122	982	318	664	3858	0.17	4407	0.68	N/A	N/A	128	138
CH79	150	115	926	301	625	3661	0.17	4306	0.67	N/A	N/A	122	133
CH81	195	140	1127	310	817	3653	0.17	4347	0.68	N/A	N/A	122	133

Material	Average 30 (ft-lb) ^(a) Transition Temperature (°F)			Average 35 mil Lateral ^(b) Expansion Temperature (°F)			Average 50 ft-lb ^(a) Transition Temperature (°F)			Average Energy Absorption ^(a) at Full Shear (ft-lb)		
	Unirradiated	Irradiated	ΔT	Unirradiated	Irradiated	ΔT	Unirradiated	Irradiated	ΔT	Unirradiated	Irradiated	ΔT
Inter. Shell Plate B7212-1 (Long.)	-22.65	177.56	200.24	1.6	212.3	210.7	9.87	208.74	198.87	130	94	-36
Inter. Shell Plate B7212-1 (Trans.)	-7.44	188.06	195.5	27.2	225.6	198.4	33.66	231.12	197.45	95	68	-27
Weld Metal	-34.7	-24.7	10.0	-23.0	-0.5	22.5	-15.6	-1.4	14.2	144	133	-11
HAZ Metal	-175.4	-32.8	142.6	-111.3	5.1	116.4	-116.8	-3.2	113.6	158	126	-32

- a. "Average" is defined as the value read from the curve fit through the data points of the Charpy tests (see Figures 5-1, 5-4, 5-7 and 5-10).
- b. "Average" is defined as the value read from the curve fit through the data points of the Charpy tests (see Figures 5-2, 5-5, 5-8 and 5-11)

Material	Capsule	Fluence (x 10 ¹⁹ n/cm ²)	30 ft-lb Transition Temperature Shift		Upper Shelf Energy Decrease	
			Predicted (°F) ^(a)	Measured (°F) ^(b)	Predicted (%) ^(a)	Measured (%) ^(c)
Intermediate Shell Plate B7212-1 (Longitudinal)	U	0.644	131.1	105.79	26	28
	W	1.85	174.3	168.05	34	22
	X	3.19	195.2	164.86	38	26
	Z	5.28	210.1	200.24	43	28
Intermediate Shell Plate B7212-1 (Transverse)	U	0.644	131.1	124.01	26	27
	W	1.85	174.3	168.18	34	20
	X	3.19	195.2	200.01	38	27
	Z	5.28	210.1	195.5	43	28
Weld Metal	U	0.644	36.1	0.0 ^(d)	17	8
	W	1.85	48.0	6.7	22	0
	X	3.19	53.7	0.0 ^(d)	25	0
	Z	5.28	57.8	10.0	28	8
HAZ Metal	U	0.644	--	98.9	--	30
	W	1.85	--	147.7	--	20
	X	3.19	--	109.6	--	19
	Z	5.28	--	142.6	--	20


Notes:

- (a) Based on Regulatory Guide 1.99, Revision 2, methodology using the mean weight percent values of copper and nickel of the surveillance material.
- (b) Calculated using measured Charpy data plotted using CVGRAPH, Version 4.1 (See Appendix C)
- (c) Values are based on the definition of upper shelf energy given in ASTM E185-82.
- (d) The actual measured capsule U and capsule X ΔRT_{NDT} values are -28.7°F and -15.34°F respectively. This physically should not occur, therefore for conservatism a value of zero will be reported.

Material	Sample Number	Test Temp. (°F)	0.2% Yield Strength (ksi)	Ultimate Strength (ksi)	Fracture Load (kip)	Fracture Stress (ksi)	Fracture Strength (ksi)	Uniform Elongation (%)	Total Elongation (%)	Reduction in Area (%)
Intermediate Plate B8805-3 (Longitudinal)	CL16	200	94.2	110.3	3.76	237.7	76.7	9.9	21.4	68
	CL17	300	91.7	110.7	4.19	200.7	85.3	9.3	17.6	57
	CL18	550	85.1	105.7	4.22	135.5	85.9	8.5	12.1	37
Intermediate Plate B8805-3 (Transverse)	CT16	73	99.3	116.5	4.70	184.7	95.7	10.5	18.0	48
	CT17	250	89.1	106.5	4.00	191.7	81.5	9.3	18.1	57
	CT18	550	84.0	105.1	4.18	189.8	85.1	9.0	16.1	55
Weld Metal	CW16	25	79.5	90.5	2.66	203.7	54.2	10.8	2.6	73
	CW17	100	76.4	85.6	2.56	198.6	52.1	10.5	23.7	74
	CW18	550	62.6	82.3	2.46	194.2	50.1	9.3	21.9	74

INTERMEDIATE SHELL B7212-1 (LONGITUDINAL)

CVGRAPH 4.1 Hyperbolic Tangent Curve Printed at 13:18 on 02-22-2000



Data Set(s) Plotted

Curve	Plant	Capsule	Material	Ori.	Heat#
1	FA2	UNIRR	PLATE SA533B1	LT	B7212-1
2	FA2	U	PLATE SA533B1	LT	B7212-1
3	FA2	W	PLATE SA533B1	LT	B7212-1
4	FA2	X	PLATE SA533B1	LT	B7212-1
5	FA2	Z	PLATE SA533B1	LT	B7212-1


Figure 5-1 Charpy V-Notch Impact Energy vs. Temperature for J. M. Farley Unit 2 Reactor Vessel Intermediate Shell Plate B7212-1 (Longitudinal Orientation)

INTERMEDIATE SHELL PLATE B7212-1 (LONGITUDINAL)

CVGRAPH 4.1 Hyperbolic Tangent Curve Printed at 165255 on 12-21-1998

Results

Curve	Fluence	USE	d-USE	T @ LE35	d-T @ LE35
1	0	90.65	0	164	0
2	0	85.02	-5.63	122.15	120.51
3	0	85.83	-4.81	167.56	165.92
4	0	70.41	-20.24	183.03	181.39
5	0	66.63	-24.02	212.3	210.66



Curve Legend




Data Set(s) Plotted

Curve	Plant	Capsule	Material	Ori.	Heat#
1	FA2	UNIRR	PLATE SA533B1	LT	B7212-1
2	FA2	U	PLATE SA533B1	LT	B7212-1
3	FA2	W	PLATE SA533B1	LT	B7212-1
4	FA2	X	PLATE SA533B1	LT	B7212-1
5	FA2	Z	PLATE SA533B1	LT	B7212-1

Figure 5-2 Charpy V-Notch Lateral Expansion vs. Temperature for J. M. Farley Unit 2 Reactor Vessel Intermediate Shell Plate B7212-1 (Longitudinal Orientation)

INTERMEDIATE SHELL PLATE B7212-1(LONGITUDINAL)

CVGRAPH 4.1 Hyperbolic Tangent Curve Printed at 14:24:19 on 12-21-1998



Curve Legend

1 □ ——— 2 ○ - - - - 3 ◇ ——— 4 ▲ ——— 5 ▼ ———

Data Set(s) Plotted


Curve	Plant	Capsule	Material	Ori.	Heat#
1	FA2	UNIRR	PLATE SA533B1	LT	B7212-1
2	FA2	U	PLATE SA533B1	LT	B7212-1
3	FA2	W	PLATE SA533B1	LT	B7212-1
4	FA2	X	PLATE SA533B1	LT	B7212-1
5	FA2	Z	PLATE SA533B1	LT	B7212-1

Figure 5-3 Charpy V-Notch Percent Shear vs. Temperature for J. M. Farley Unit 2 Reactor Vessel Intermediate Shell Plate B7212-1 (Longitudinal Orientation)

INTERMEDIATE SHELL B7212-1 (TRANSVERSE)

CVGRAPH 4.1 Hyperbolic Tangent Curve Printed at 13:33:51 on 02-22-2000

Curve	Fluence	Results							
		LSE	d-LSE	USE	d-USE	T @ 30	d-T @ 30	T @ 50	d-T @ 50
1	0	2.19	0	95	0	-7.44	0	33.66	0
2	0	2.19	0	68.9	-26.09	116.56	124.01	181.83	148.17
3	0	2.19	0	75.5	-19.5	160.74	168.18	218.29	184.62
4	0	2.19	0	68.5	-26.5	192.57	200.01	222.03	188.36
5	0	2.19	0	67.8	-27.19	188.06	195.5	231.12	197.45



Curve	Plant	Capsule	Data Set(s) Plotted		Ori.	Heat#
			Material			
1	FA2	UNIRR	PLATE SA533B1		TL	B7212-1
2	FA2	U	PLATE SA533B1		TL	B7212-1
3	FA2	W	PLATE SA533B1		TL	B7212-1
4	FA2	X	PLATE SA533B1		TL	B7212-1
5	FA2	Z	PLATE SA533B1		TL	B7212-1


Figure 5-4 Charpy V-Notch Impact Energy vs. Temperature for J. M. Farley Unit 2 Reactor Vessel Intermediate Shell Plate B7212-1 (Transverse Orientation)

INTERMEDIATE SHELL PLATE B7212-1(TRANSVERSE)

CVGRAPH 4.1 Hyperbolic Tangent Curve Printed at 14:07:10 on 12-21-1981

Results

Curve	Fluence	USE	d-USE	T @ LE35	d-T @ LE35
1	0	72.35	0	27.23	0
2	0	68.48	-3.86	146.53	119.29
3	0	68.54	-3.8	182.16	154.92
4	0	62.45	-9.89	214.41	187.17
5	0	53.13	-19.21	225.59	198.35



Curve Legend

1 \square ——— 2 \circ - - - - 3 \diamond ——— 4 \triangle ——— 5 ∇ ———


Data Set(s) Plotted

Curve	Plant	Capsule	Material	Ori.	Heat#
1	FA2	UNIRR	PLATE SA533B1	TL	B7212-1
2	FA2	U	PLATE SA533B1	TL	B7212-1
3	FA2	W	PLATE SA533B1	TL	B7212-1
4	FA2	X	PLATE SA533B1	TL	B7212-1
5	FA2	Z	PLATE SA533B1	TL	B7212-1

Figure 5-5 Charpy V-Notch Lateral Expansion vs. Temperature for J. M. Farley Unit 2 Reactor Vessel Intermediate Shell Plate B7212-1 (Transverse Orientation)

INTERMEDIATE SHELL PLATE B7212-1(TRANSVERSE)

CVGRAPH 4.1 Hyperbolic Tangent Curve Printed at 14:14:51 on 12-21-1998



Curve Legend

1 \square ——— 2 \circ - - - - 3 \diamond ——— 4 \triangle ——— 5 ∇ ———


Data Set(s) Plotted

Curve	Plant	Capsule	Material	Ori.	Heat#
1	FA2	UNIRR	PLATE SA533B1	TL	B7212-1
2	FA2	U	PLATE SA533B1	TL	B7212-1
3	FA2	W	PLATE SA533B1	TL	B7212-1
4	FA2	X	PLATE SA533B1	TL	B7212-1
5	FA2	Z	PLATE SA533B1	TL	B7212-1

Figure 5-6 Charpy V-Notch Percent Shear vs. Temperature for J. M. Farley Unit 2 Reactor Vessel Intermediate Shell Plate B7212-1 (Transverse Orientation)

SURVEILLANCE PROGRAM WELD METAL

CVGRAPH 4.1 Hyperbolic Tangent Curve Printed at 13:43:31 on 12-21-1998




Data Set(s) Plotted					
Curve	Plant	Capsule	Material	Ori.	Heat#
1	FA2	UNIRR	WELD		BOLA
2	FA2	U	WELD		BOLA
3	FA2	W	WELD		BOLA
4	FA2	X	WELD		BOLA
5	FA2	Z	WELD		BOLA

Figure 5-7 Charpy V-Notch Impact Energy vs. Temperature for J. M. Farley Unit 2 Reactor Vessel Weld Metal

SURVEILLANCE PROGRAM WELD METAL

CVGRAPH 4.1 Hyperbolic Tangent Curve Printed at 17:04:10 on 12-21-1998



Curve Legend

1 \square ——— 2 \circ - - - - - 3 \diamond ——— 4 \triangle ——— 5 ∇ ———


Data Set(s) Plotted

Curve	Plant	Capsule	Material	Ori.	Heat#
1	FA2	UNIRR	WELD		BOLA
2	FA2	U	WELD		BOLA
3	FA2	W	WELD		BOLA
4	FA2	X	WELD		BOLA
5	FA2	Z	WELD		BOLA

Figure 5-8 Charpy V-Notch Lateral Expansion vs. Temperature for J. M. Farley Unit 2 Reactor Vessel Weld Metal

SURVEILLANCE PROGRAM WELD METAL

CVGRAPH 4.1 Hyperbolic Tangent Curve Printed at 17:15:15 on 12-21-1998



Curve Legend

1 □ ——— 2 ○ - - - - 3 ◇ ——— 4 ▲ ——— 5 ▼ ———


Data Set(s) Plotted

Curve	Plant	Capsule	Material	Ori.	Heat#
1	FA2	UNIRR	WELD		BOLA
2	FA2	U	WELD		BOLA
3	FA2	W	WELD		BOLA
4	FA2	X	WELD		BOLA
5	FA2	Z	WELD		BOLA

Figure 5-9 Charpy V-Notch Percent Shear vs Temperature for J. M. Farley Unit 2 Reactor Vessel Weld Metal

HEAT AFFECTED ZONE

CVGRAPH 4.1 Hyperbolic Tangent Curve Printed at 15:29:42 on 12-21-1998



Curve Legend

1 □ ——— 2 ○ - - - - - 3 ◇ ——— 4 ▲ ——— 5 ▼ ———

Data Set(s) Plotted

Curve	Plant	Capsule	Material	Ori.	Heat#
1	FA2	UNIRR	HEAT AFFD ZONE		B7212-1
2	FA2	U	HEAT AFFD ZONE		B7212-1 SIDE OF WELD
3	FA2	W	HEAT AFFD ZONE		B7212-1 SIDE OF WELD
4	FA2	X	HEAT AFFD ZONE		B7212-1 SIDE OF WELD
5	FA2	Z	HEAT AFFD ZONE		B7212-1 SIDE OF WELD


Figure 5-10 Charpy V-Notch Impact Energy vs. Temperature for J. M. Farley Unit 2 Reactor Vessel Heat-Affected-Zone Material

HEAT AFFECTED ZONE

CVGRAPH 4.1 Hyperbolic Tangent Curve Printed at 09:45:43 on 12-22-1998

Results

Curve	Fluence	USE	d-USE	T σ LE35	d-T σ LE35
1	0	87.32	0	-111.25	0
2	0	88.27	.94	-59.55	51.69
3	0	85.49	-1.83	-20.27	90.98
4	0	84.97	-2.35	-36.76	74.49
5	0	85.57	-1.75	5.1	116.36



Curve Legend

1 \square ——— 2 \circ - - - - - 3 \diamond ——— 4 \triangle ——— 5 ∇ ———


Data Set(s) Plotted

Curve	Plant	Capsule	Material	Ori.	Heat#
1	FA2	UNIRR	HEAT AFFECTED ZONE	B7212-1	SIDE OF WELD
2	FA2	U	HEAT AFFECTED ZONE	B7212-1	SIDE OF WELD
3	FA2	W	HEAT AFFECTED ZONE	B7212-1	SIDE OF WELD
4	FA2	X	HEAT AFFECTED ZONE	B7212-1	SIDE OF WELD
5	FA2	Z	HEAT AFFECTED ZONE	B7212-1	SIDE OF WELD

Figure 5-11 Charpy V-Notch Lateral Expansion vs. Temperature for J. M. Farley Unit 2 Reactor Vessel Heat-Affected-Zone Material

HEAT AFFECTED ZONE

CVGRAPH 4.1 Hyperbolic Tangent Curve Printed at 09:48:27 on 12-22-1998



Curve Legend

1 \square ——— 2 \circ - - - - 3 \diamond ——— 4 \triangle ——— 5 ∇ ———

Data Set(s) Plotted

Curve	Plant	Capsule	Material	Ori.	Heat#
1	FA2	UNIRR	HEAT AFFD ZONE	B7212-1	SIDE OF WELD
2	FA2	U	HEAT AFFD ZONE	B7212-1	SIDE OF WELD
3	FA2	W	HEAT AFFD ZONE	B7212-1	SIDE OF WELD
4	FA2	X	HEAT AFFD ZONE	B7212-1	SIDE OF WELD
5	FA2	Z	HEAT AFFD ZONE	B7212-1	SIDE OF WELD

Figure 5-12 Charpy V-Notch Percent Shear vs. Temperature for J. M. Farley Unit 2 Reactor Vessel Heat-Affected-Zone Material




Figure 5-13 Charpy Impact Specimen Fracture Surfaces for J. M. Farley Unit 2 Reactor Vessel Intermediate Shell Plate B7212-1 (Longitudinal Orientation)




Figure 5-14 Charpy Impact Specimen Fracture Surfaces for J. M. Farley Unit 2 Reactor Vessel Intermediate Shell Plate B7212-1 (Transverse Orientation)




Figure 5-15 Charpy Impact Specimen Fracture Surfaces for J. M. Farley Unit 2 Reactor Vessel Weld Metal





Figure 5-16 Charpy Impact Specimen Fracture Surfaces for J. M. Farley Unit 2 Reactor Vessel Heat-Affected-Zone Metal



LEGEND:

△○□ UNIRRADIATED

▲●■ IRRADIATED TO A FLUENCE OF $5.28 \times 10^{19} \text{ n/cm}^2$ ($E > 1.0 \text{ MeV}$) AT 550° F





Figure 5-17 Tensile Properties for J. M. Farley Unit 2 Reactor Vessel Intermediate Shell Plate B7212-1 (Longitudinal Orientation)



LEGEND:

△○□ UNIRRADIATED

▲●■ IRRADIATED TO A FLUENCE OF $5.28 \times 10^{19} \text{ n/cm}^2$ ($E > 1.0 \text{ MeV}$) AT 550 F





Figure 5-18 Tensile Properties for J. M. Farley Unit 2 Reactor Vessel Intermediate Shell Plate B7212-1 (Transverse Orientation)



LEGEND:

△○□ UNIRRADIATED

▲●■ IRRADIATED TO A FLUENCE OF $5.28 \times 10^{19} \text{ n/cm}^2$ ($E > 1.0 \text{ MeV}$) AT 550° F







Figure 5-19 Tensile Properties for J. M. Farley Unit 2 Reactor Vessel Weld Metal



Specimen CL16




Specimen CL17




Specimen CL18


Figure 5-20 Fractured Tensile Specimens from J. M. Farley Unit 2 Reactor Vessel Intermediate Shell Plate B7212-1 (Longitudinal Orientation)



Specimen CT16




Specimen CT17




Specimen CT18


Figure 5-21 Fractured Tensile Specimens from J. M. Farley Unit 2 Reactor Vessel Intermediate Shell Plate B7212-1 (Transverse Orientation)



Specimen CW16



Specimen CW17



Specimen CW18

Figure 5-22 Fractured Tensile Specimens from J. M. Farley Unit 2 Reactor Vessel Weld Metal




Figure 5-23 Engineering Stress-Strain Curves for Intermediate Shell Plate B7212-1 Tensile Specimens CL16, CL17 and CL18 (Longitudinal Orientation)






Figure 5-24 Engineering Stress-Strain Curves for Intermediate Shell Plate B7212-1 Tensile Specimens CT16, CT17 and CT18 (Transverse Orientation)




Figure 5-25 Engineering Stress-Strain Curves for Weld Metal Tensile Specimens CW16, CW17 and CW18

6 RADIATION ANALYSIS AND NEUTRON DOSIMETRY

6.1 INTRODUCTION

Knowledge of the neutron environment within the reactor vessel and surveillance capsule geometry is required as an integral part of LWR reactor vessel surveillance programs for two reasons. First, in order to interpret the neutron radiation induced material property changes observed in the test specimens, the neutron environment (energy spectrum, flux, fluence) to which the test specimens were exposed must be known. Second, in order to relate the changes observed in the test specimens to the present and future condition of the reactor vessel, a relationship must be established between the neutron environment at various positions within the reactor vessel and that experienced by the test specimens. The former requirement is normally met by employing a combination of rigorous analytical techniques and measurements obtained with passive neutron flux monitors contained in each of the surveillance capsules. The latter information is generally derived solely from analysis.

The use of fast neutron fluence ($E > 1.0$ MeV) to correlate measured material property changes to the neutron exposure of the material has traditionally been accepted for development of damage trend curves as well as for the implementation of trend curve data to assess vessel condition. In recent years, however, it has been suggested that an exposure model that accounts for differences in neutron energy spectra between surveillance capsule locations and positions within the vessel wall could lead to an improvement in the uncertainties associated with damage trend curves as well as to a more accurate evaluation of damage gradients through the reactor vessel wall.

Because of this potential shift away from a threshold fluence toward an energy dependent damage function for data correlation, ASTM Standard Practice E853, "Analysis and Interpretation of Light-Water Reactor Surveillance Results," recommends reporting displacements per iron atom (dpa) along with fluence ($E > 1.0$ MeV) to provide a data base for future reference. The energy dependent dpa function to be used for this evaluation is specified in ASTM Standard Practice E693, "Characterizing Neutron Exposures in Iron and Low Alloy Steels in Terms of Displacements per Atom." The application of the dpa parameter to the assessment of embrittlement gradients through the thickness of the reactor vessel wall has already been promulgated in Revision 2 to Regulatory Guide 1.99, "Radiation Embrittlement of Reactor Vessel Materials."

This section provides the results of the neutron dosimetry evaluations performed in conjunction with the analysis of test specimens contained in surveillance Capsules U, W, X, and Z which were withdrawn during the first, fourth, sixth, and twelfth fuel cycles, respectively. This evaluation is based on current state-of-the-art methodology and nuclear data including neutron transport and dosimetry cross-section libraries derived from the ENDF/B-VI data base. This report provides a consistent up-to-date neutron exposure data base for use in evaluating the material properties of the Farley Unit 2 reactor vessel.

In each capsule dosimetry evaluation, fast neutron exposure parameters in terms of neutron fluence ($E > 1.0$ MeV), neutron fluence ($E > 0.1$ MeV), and iron atom displacements (dpa) are established for the capsule irradiation history. The analytical formalism relating the measured capsule exposure to the exposure of the vessel wall is described and used to project the integrated exposure of the vessel wall. Also, uncertainties associated with the derived exposure parameters at the surveillance capsules and with the projected exposure of the reactor vessel are provided.

6.2 Discrete Ordinates Analysis

A plan view of the reactor geometry at the core midplane is shown in Figure 4-1. Six irradiation capsules attached to the neutron pads are included in the reactor design to constitute the reactor vessel surveillance program. The capsules are located at azimuthal angles of 107°, 110°, 287°, 290°, 340°, and 343° relative to the core cardinal axis as shown in Figure 4-1.

A plan view of a dual surveillance capsule holder attached to the neutron pad is shown in Figure 6-1. The stainless steel specimen containers are 1.182 by 1-inch and approximately 56 inches in height. The containers are positioned axially such that the test specimens are centered on the core midplane, thus spanning the central 5 feet of the 12-foot high reactor core.

From a neutronic standpoint, the surveillance capsules and associated support structures are significant. The presence of these materials has a marked effect on both the spatial distribution of neutron flux and the neutron energy spectrum in the water annulus between the neutron pad and the reactor vessel. In order to determine the neutron environment at the test specimen location, the capsules themselves must be included in the analytical model.

In performing the fast neutron exposure evaluations for the surveillance capsules and reactor vessel, two distinct sets of transport calculations were carried out. The first, a single computation in the conventional forward mode, was used primarily to obtain relative neutron energy distributions throughout the reactor geometry as well as to establish relative radial distributions of exposure parameters $\{\phi(E > 1.0 \text{ MeV}), \phi(E > 0.1 \text{ MeV}), \text{ and } \text{dpa/sec}\}$ through the vessel wall. The neutron spectral information was required for the interpretation of neutron dosimetry withdrawn from the surveillance capsule as well as for the determination of exposure parameter ratios, i.e., $[\text{dpa/sec}]/[\phi(E > 1.0 \text{ MeV})]$, within the reactor vessel geometry. The relative radial gradient information was required to permit the projection of measured exposure parameters to locations interior to the reactor vessel wall, i.e., the $\frac{1}{4}T$ and $\frac{3}{4}T$ locations.

The second set of calculations consisted of a series of adjoint analyses relating the fast neutron flux, $\phi(E > 1.0 \text{ MeV})$, at surveillance capsule positions and at several azimuthal locations on the reactor vessel inner radius to neutron source distributions within the reactor core. The source importance functions generated from these adjoint analyses provided the basis for all absolute exposure calculations and comparison with measurement. These importance functions, when combined with fuel cycle specific neutron source distributions, yielded absolute predictions of neutron exposure at the locations of interest for each cycle of irradiation. They also established the means to perform similar predictions and dosimetry evaluations for all subsequent fuel cycles. It is important to note that the cycle specific neutron source distributions utilized in these analyses included not only spatial variations of fission rates within the reactor core but also accounted for the effects of varying neutron yield per fission and fission spectrum introduced by the build-up of plutonium as the burnup of individual fuel assemblies increased.

The absolute cycle-specific data from the adjoint evaluations together with the relative neutron energy spectra and radial distribution information from the reference forward calculation provided the means to:

1. Evaluate neutron dosimetry obtained from surveillance capsules,
2. Relate dosimetry results to key locations at the inner radius and through the thickness of the reactor vessel wall,

3. Enable a direct comparison of analytical prediction with measurement, and
4. Establish a mechanism for projection of reactor vessel exposure as the design of each new fuel cycle evolves.

The forward transport calculation for the reactor model summarized in Figures 4-1 and 6-1 was carried out in r, θ geometry using the DORT two-dimensional discrete ordinates code Version 3.1^[17] and the BUGLE-96 cross-section library^[18]. The BUGLE-96 library is a 47 energy group ENDF/B-VI based data set produced specifically for light water reactor applications. In these analyses, anisotropic scattering was treated with a P_3 expansion of the scattering cross-sections and the angular discretization was modeled with an S_8 order of angular quadrature.

The core power distribution utilized in the reference forward transport calculation was derived from statistical studies of long-term operation of Westinghouse 3-loop plants. Inherent in the development of this reference core power distribution is the use of an out-in fuel management strategy, i.e., fresh fuel on the core periphery. Furthermore, for the peripheral fuel assemblies, the neutron source was increased by a 2σ margin derived from the statistical evaluation of plant-to-plant and cycle-to-cycle variations in peripheral power. Since it is unlikely that any single reactor would exhibit power levels on the core periphery at the nominal $+2\sigma$ value for a large number of fuel cycles, the use of this reference distribution is expected to yield somewhat conservative results.

All adjoint calculations were also carried out using an S_8 order of angular quadrature and the P_3 cross-section approximation from the BUGLE-96 library. Adjoint source locations were chosen at several azimuthal locations along the reactor vessel inner radius as well as at the geometric center of each surveillance capsule. Again, these calculations were run in r, θ geometry to provide neutron source distribution importance functions for the exposure parameter of interest, in this case $\phi(E > 1.0 \text{ MeV})$.

Having the importance functions and appropriate core source distributions, the response of interest could be calculated as:

$$R(r, \theta) = \int_r \int_{\theta} \int_E I(r, \theta, E) S(r, \theta, E) r dr d\theta dE$$

where:

$R(r, \theta) =$ $\phi(E > 1.0 \text{ MeV})$ at radius r and azimuthal angle θ .

$I(r, \theta, E) =$ Adjoint source importance function at radius r , azimuthal angle θ , and neutron source energy E .

$S(r, \theta, E) =$ Neutron source strength at core location r, θ , and energy E .

Although the adjoint importance functions used in this analysis were based on a response function defined by the threshold neutron flux $\phi(E > 1.0 \text{ MeV})$, prior calculations^[19] have shown that, while the implementation of low leakage loading patterns significantly impacts both the magnitude and spatial distribution of the neutron field, changes in the relative neutron energy spectrum are of second order.

Thus, for a given location, the ratio of $[dpa/sec]/[\phi(E > 1.0 \text{ MeV})]$ is insensitive to changing core source distributions. In the application of these adjoint importance functions to the Farley Unit 2 reactor, therefore, the iron atom displacement rates (dpa/sec) and the neutron flux $\phi(E > 0.1 \text{ MeV})$ were computed on a cycle-specific basis by using $[dpa/sec]/[\phi(E > 1.0 \text{ MeV})]$ and $[\phi(E > 0.1 \text{ MeV})]/[\phi(E > 1.0 \text{ MeV})]$ ratios from the forward analysis in conjunction with the cycle specific $\phi(E > 1.0 \text{ MeV})$ solutions from the individual adjoint evaluations.

The reactor core power distributions used in the plant specific adjoint calculations were taken from fuel cycle design data for the first twelve operating cycles of Farley Unit 2^[20 through 32].

Selected results from the neutron transport analyses are provided in Tables 6-1 through 6-5. The data listed in these tables establish the means for absolute comparisons of analysis and measurement for the Capsules U, W, X, and Z irradiation periods and provide the means to correlate dosimetry results with the corresponding exposure of the reactor vessel wall.

In Table 6-1, the calculated exposure parameters $[\phi(E > 1.0 \text{ MeV})]$, $[\phi(E > 0.1 \text{ MeV})]$, and $[dpa/sec]$ are given at the geometric center of the two azimuthally symmetric surveillance capsule positions (17° and 20°) for both the reference and the plant specific core power distributions. The plant-specific data, based on the adjoint transport analysis, are meant to establish the absolute comparison of measurement with analysis. The reference data derived from the forward calculation are provided as a conservative exposure evaluation against which plant specific fluence calculations can be compared. Similar data are given in Table 6-2 for the reactor vessel inner radius. Again, the three pertinent exposure parameters are listed for the reference and Cycles 1 to 12 plant specific power distributions.

It is important to note that the data for the vessel inner radius were taken at the clad/base metal interface, and, thus, represent the maximum predicted exposure levels of the vessel plates and welds.

Radial gradient information applicable to $\phi(E > 1.0 \text{ MeV})$, $\phi(E > 0.1 \text{ MeV})$, and dpa/sec is given in Tables 6-3, 6-4, and 6-5, respectively. The data, obtained from the reference forward neutron transport calculation, are presented on a relative basis for each exposure parameter at several azimuthal locations. Exposure distributions through the vessel wall may be obtained by normalizing the calculated or projected exposure at the vessel inner radius to the gradient data listed in Tables 6-3 through 6-5.

For example, the neutron flux $\phi(E > 1.0 \text{ MeV})$ at the $1/4T$ depth in the reactor vessel wall along the 0° azimuth is given by:

$$\phi_{1/4T}(0^\circ) = \phi(199.95, 0^\circ) F(204.95, 0^\circ)$$

where:

$\phi_{1/4T}(0^\circ) =$ Projected neutron flux at the $1/4T$ position on the 0° azimuth.

$\phi(199.95, 0^\circ) =$ Projected or calculated neutron flux at the vessel inner radius on the 0° azimuth.

$F(204.95, 0^\circ) =$ Ratio of the neutron flux at the $1/4T$ position to the flux at the vessel inner radius for the 0° azimuth. This data is obtained from Table 6-3.

Similar expressions apply for exposure parameters expressed in terms of $\phi(E > 0.1 \text{ MeV})$ and dpa/sec where the attenuation function F is obtained from Tables 6-4 and 6-5, respectively.

6.3 Neutron Dosimetry

The passive neutron sensors included in the Farley Unit 2 surveillance program are listed in Table 6-6. Also given in Table 6-6 are the primary nuclear reactions and associated nuclear constants that were used in the evaluation of the neutron energy spectrum within the surveillance capsules and in the subsequent determination of the various exposure parameters of interest [$\phi(E > 1.0 \text{ MeV})$, $\phi(E > 0.1 \text{ MeV})$, dpa/sec]. The relative locations of the neutron sensors within the capsules are shown in Figure 4-2. The iron, nickel, copper, and cobalt-aluminum monitors, in wire form, were placed in holes drilled in spacers at several axial levels within the capsules. The cadmium shielded uranium and neptunium fission monitors were accommodated within the dosimeter block located near the center of the capsule.

The use of passive monitors such as those listed in Table 6-6 does not yield a direct measure of the energy dependent neutron flux at the point of interest. Rather, the activation or fission process is a measure of the integrated effect that the time and energy dependent neutron flux has on the target material over the course of the irradiation period. An accurate assessment of the average neutron flux level incident on the various monitors may be derived from the activation measurements only if the irradiation parameters are well known. In particular, the following variables are of interest:

- The measured specific activity of each monitor,
- The physical characteristics of each monitor,
- The operating history of the reactor,
- The energy response of each monitor, and
- The neutron energy spectrum at the monitor location.

The specific activity of each of the neutron monitors was determined using established ASTM procedures^[34 through 47]. Following sample preparation and weighing, the activity of each monitor was determined by means of a lithium-drifted germanium, Ge(Li), gamma spectrometer. The irradiation history of the Farley Unit 2 reactor was obtained from Southern Nuclear Company personnel^[32] and data reported in NUREG-0020, "Licensed Operating Reactors Status Summary Report," for the Cycles 1 to 12 operating periods. The irradiation history applicable to the exposure of Capsules U, W, X, and Z is given in Table 6-7.

Having the measured specific activities, the physical characteristics of the sensors, and the operating history of the reactor, reaction rates referenced to full-power operation were determined from the following equation:

$$R = \frac{A}{N_0 F Y \sum \frac{P_j}{P_{ref}} C_j [1 - e^{-\lambda_j t}] [e^{-\lambda_d t}]}$$

where:

- R = Reaction rate averaged over the irradiation period and referenced to operation at a core power level of P_{ref} (rps/nucleus).
- A = Measured specific activity (dps/gm).
- N_0 = Number of target element atoms per gram of sensor.
- F = Weight fraction of the target isotope in the sensor material.
- Y = Number of product atoms produced per reaction.
- P_j = Average core power level during irradiation period j (MW).
- P_{ref} = Maximum or reference power level of the reactor (MW).
- C_j = Calculated ratio of $\phi(E > 1.0 \text{ MeV})$ during irradiation period j to the time weighted average $\phi(E > 1.0 \text{ MeV})$ over the entire irradiation period.
- λ = Decay constant of the product isotope (1/sec).
- t_j = Length of irradiation period j (sec).
- t_d = Decay time following irradiation period j (sec).

and the summation is carried out over the total number of monthly intervals comprising the irradiation period.

In the equation describing the reaction rate calculation, the ratio $[P_j]/[P_{ref}]$ accounts for month-by-month variation of reactor core power level within any given fuel cycle as well as over multiple fuel cycles. The ratio C_j , which can be calculated for each fuel cycle using the adjoint transport technology discussed in Section 6.2, accounts for the change in sensor reaction rates caused by variations in flux level induced by changes in core spatial power distributions from fuel cycle to fuel cycle. For a single cycle irradiation, C_j is normally taken to be 1.0. However, for multiple-cycle irradiations, particularly those employing low leakage fuel management, the additional C_j term should be employed. The impact of changing flux levels for constant power operation can be quite significant for sensor sets that have been irradiated for many cycles in a reactor that has transitioned from non-low leakage to low leakage fuel management or for sensor sets contained in surveillance capsules that have been moved from one capsule location to another.

For the irradiation history of Capsules U, W, X, and Z the flux level term in the reaction rate calculations was set to 1.0 for Capsule U only. Measured and saturated reaction product specific activities as well as the derived full power reaction rates are listed in Table 6-8. The reaction rates of the ^{238}U sensors provided in Table 6-8 include corrections for ^{235}U impurities, plutonium build-in, and gamma ray induced fissions. Corrections for gamma ray induced fissions were also included in the reaction rates for the ^{237}Np sensors as well.

Values of key fast neutron exposure parameters were derived from the measured reaction rates using the FERRET least squares adjustment code^[48]. The FERRET approach used the measured reaction rate data, sensor reaction cross-sections, and a calculated trial spectrum as input and proceeded to adjust the group fluxes from the trial spectrum to produce a best fit (in a least squares sense) within the constraints of the parameter uncertainties. The best estimate exposure parameters, along with the associated uncertainties, were then obtained from the best estimate spectrum.

In the FERRET evaluations, a log-normal least squares algorithm weights both the a priori values and the measured data in accordance with the assigned uncertainties and correlations. In general, the measured values, f , are linearly related to the flux, ϕ , by some response matrix, A :

$$f_i^{(s,\alpha)} = \sum_g A_{ig}^{(s)} \phi_g^{(\alpha)}$$

where i indexes the measured values belonging to a single data set s , g designates the energy group, and α delineates spectra that may be simultaneously adjusted. For example,

$$R_i = \sum_g \sigma_{ig} \phi_g$$

relates a set of measured reaction rates, R_i , to a single spectrum, ϕ_g , by the multi-group reaction cross-section, σ_{ig} . The log-normal approach automatically accounts for the physical constraint of positive fluxes, even with large assigned uncertainties.

In the least squares adjustment, the continuous quantities (i.e., neutron spectra and cross-sections) were approximated in a multi-group format consisting of 53 energy groups. The trial input spectrum was converted to the FERRET 53 group structure using the SAND-II code^[49]. This procedure was carried out by first expanding the 47 group calculated spectrum into the SAND-II 620 group structure using a SPLINE interpolation procedure in regions where group boundaries do not coincide. The 620 point spectrum was then re-collapsed into the group structure used in FERRET.

The sensor set reaction cross-sections, obtained from the ENDF/B-VI dosimetry file^[50], were also collapsed into the 53 energy group structure using the SAND-II code. In this instance, the trial spectrum, as expanded to 620 groups, was employed as a weighting function in the cross-section collapsing procedure. Reaction cross-section uncertainties in the form of a 53×53 covariance matrix for each sensor reaction were also constructed from the information contained on the ENDF/B-VI data files. These matrices included energy group to energy group uncertainty correlations for each of the individual reactions. However, correlations between cross-sections for different sensor reactions were not included. The omission of this additional uncertainty information does not significantly impact the results of the adjustment.

Due to the importance of providing a trial spectrum that exhibits a relative energy distribution close to the actual spectrum at the sensor set locations, the neutron spectrum input to the FERRET evaluation was taken from the center of the surveillance capsule modeled in the reference forward transport calculation. While the 53×53 group covariance matrices applicable to the sensor reaction cross-sections were developed from the ENDF/B-VI data files, the covariance matrix for the input trial spectrum was constructed from the following relation:

$$M_{gg'} = R_n^2 + R_g R_{g'} P_{gg'}$$

where R_n specifies an overall fractional normalization uncertainty (i.e., complete correlation) for the set of values. The fractional uncertainties, R_g , specify additional random uncertainties for group g that are correlated with a correlation matrix given by:

$$P_{gg'} = [1 - \theta] \delta_{gg'} + \theta e^{-H}$$

where:

$$H = \frac{(g - g')^2}{2 \gamma^2}$$

The first term in the correlation matrix equation specifies purely random uncertainties, while the second term describes short range correlations over a group range γ (θ specifies the strength of the latter term). The value of δ is 1 when $g = g'$ and 0 otherwise. For the trial spectrum used in the current evaluations, a short range correlation of $\gamma = 6$ groups was used. This choice implies that neighboring groups are strongly correlated when θ is close to 1. Strong long-range correlations (or anti-correlations) were justified based on information presented by R. E. Maerker^[51]. The uncertainties associated with the measured reaction rates included both statistical (counting) and systematic components. The systematic component of the overall uncertainty accounts for counter efficiency, counter calibrations, irradiation history corrections, and corrections for competing reactions in the individual sensors.

Results of the FERRET evaluation of the Capsules U, W, X, and Z dosimetry are given in Table 6-9. The data summarized in this table include fast neutron exposure evaluations in terms of $\Phi(E > 1.0 \text{ MeV})$, $\Phi(E > 0.1 \text{ MeV})$, and dpa. In general, excellent results were achieved in the fits of the best estimate spectra to the individual measured reaction rates. The measured, calculated and best estimate reaction rates for each reaction are given in Table 6-10. An examination of Table 6-10 shows that, in all cases, the reaction rates calculated with the best estimate spectra match the measured reaction rates to better than 7%. The best estimate spectra from the least squares evaluation is given in Table 6-11 in the FERRET 53 energy group structure.

In Table 6-12, absolute comparisons of the best estimate and calculated fluence at the center of Capsules U, W, X, and Z are presented. The results for the Capsules U, W, X, and Z dosimetry evaluation [BE/C ratio of 0.87 for $\Phi(E > 1.0 \text{ MeV})$] are consistent with results obtained from similar evaluations of dosimetry from other reactors using methodologies based on ENDF/B-VI cross-sections.

6.4 Projections of Reactor Vessel Exposure

The best estimate exposure of the Farley Unit 2 reactor vessel was developed using a combination of absolute plant specific transport calculations and all available plant specific measurement data. In the case of Farley Unit 2, the measurement data base contains measurements from the surveillance capsules discussed in this report.

Combining this measurement data base with the plant-specific calculations, the best estimate vessel exposure is obtained from the following relationship:

$$\Phi_{Best\ Est.} = K \Phi_{Calc.}$$

where:

$\Phi_{Best\ Est.}$ = The best estimate fast neutron exposure at the location of interest.

K = The plant specific best estimate/calculation (BE/C) bias factor derived from the surveillance capsule dosimetry data.

$\Phi_{Calc.}$ = The absolute calculated fast neutron exposure at the location of interest.

The approach defined in the above equation is based on the premise that the measurement data represent the most accurate plant-specific information available at the locations of the dosimetry; and, further that the use of the measurement data on a plant-specific basis essentially removes biases present in the analytical approach and mitigates the uncertainties that would result from the use of analysis alone.

That is, at the measurement points the uncertainty in the best estimate exposure is dominated by the uncertainties in the measurement process. At locations within the reactor vessel wall, additional uncertainty is incurred due to the analytically determined relative ratios among the various measurement points and locations within the reactor vessel wall.

For Farley Unit 2, the derived plant specific bias factors were 0.87, 0.92, 0.91 for $\Phi(E > 1.0\text{ MeV})$, $\Phi(E > 0.1\text{ MeV})$, and dpa, respectively. Bias factors of this magnitude developed with BUGLE-96 are fully consistent with experience using the ENDF/B-VI based cross-section library.

The use of the bias factors derived from the measurement data base acts to remove plant-specific biases associated with the definition of the core source, actual versus assumed reactor dimensions, and operational variations in water density within the reactor. As a result, the overall uncertainty in the best estimate exposure projections within the vessel wall depends on the individual uncertainties in the measurement process, the uncertainty in the dosimetry location, and, in the uncertainty in the calculated ratio of the neutron exposure at the point of interest to that at the measurement location.

The uncertainty in the derived neutron flux for an individual measurement is obtained directly from the results of a least squares evaluation of dosimetry data. The least squares approach combines individual uncertainty in the calculated neutron energy spectrum, the uncertainties in dosimetry cross-sections, and the uncertainties in measured foil specific activities to produce a net uncertainty in the derived neutron flux at the measurement point. The associated uncertainty in the plant specific bias factor, K , derived from the BE/C data base, in turn, depends on the total number of available measurements as well as on the uncertainty of each measurement.

In developing the overall uncertainty associated with the reactor vessel exposure, the positioning uncertainties for dosimetry are taken from parametric studies of sensor position performed as part a series of analytical sensitivity studies included in the qualification of the methodology. The uncertainties in the exposure ratios relating dosimetry results to positions within the vessel wall are again based on the analytical sensitivity studies of the vessel thickness tolerance, downcomer water density variations, and vessel inner radius tolerance. Thus, this portion of the overall uncertainty is controlled entirely by

dimensional tolerances associated with the reactor design and by the operational characteristics of the reactor.

The net uncertainty in the bias factor, K , is combined with the uncertainty from the analytical sensitivity study to define the overall fluence uncertainty at the reactor vessel wall. In the case of Farley Unit 2, the derived uncertainties in the bias factor, K , and the additional uncertainty from the analytical sensitivity studies combine to yield a net uncertainty of $\pm 12\%$

Based on this best estimate approach, neutron exposure projections at key locations on the reactor vessel inner radius are given in Table 6-13; furthermore, calculated neutron exposure projections are also provided for comparison purposes. Along with the current (13.24 EFPY) exposure, projections are also provided for exposure periods of 20 EFPY, 36 EFPY, and 54 EFPY. Projections for future operation were based on the assumption that the Cycles 9 through 12 exposure rates based on low leakage fuel management would continue to be applicable throughout plant life.

In the derivation of best estimate and calculated exposure gradients within the reactor vessel wall for the Farley Unit 2 reactor vessel, exposure projections to 20, 36, and 54 EFPY were also employed. Data based on both a $\Phi(E > 1.0 \text{ MeV})$ slope and a plant-specific dpa slope through the vessel wall are provided in Table 6-14.

In order to assess RT_{NDT} versus fluence curves, dpa equivalent fast neutron fluence levels for the $1/4T$ and $3/4T$ positions were defined by the relations:

$$\phi(1/4T) = \phi(0T) \frac{dpa(1/4T)}{dpa(0T)} \quad \text{and} \quad \phi(3/4T) = \phi(0T) \frac{dpa(3/4T)}{dpa(0T)}$$

Using this approach results in the dpa equivalent fluence values listed in Table 6-14.

In Table 6-15, updated lead factors are listed for each of the Farley Unit 2 surveillance capsules.

Figure 6-1

Plan View of a Dual Reactor Vessel Surveillance Capsule




Table 6-1
Calculated Fast Neutron Exposure Rates and Iron Atom
Displacement Rates at the Surveillance Capsule Center

<u>Cycle No.</u>	$\phi(E > 1.0 \text{ MeV}) \text{ (n/cm}^2\text{-sec)}$	
	<u>17°</u>	<u>20°</u>
Reference	2.31E+11	2.00E+11
1	1.92E+11	1.66E+11
2	2.01E+11	1.73E+11
3	1.82E+11	1.55E+11
4	1.50E+11	1.30E+11
5	1.45E+11	1.25E+11
6	1.34E+11	1.18E+11
7	1.41E+11	1.26E+11
8	1.33E+11	1.17E+11
9	1.23E+11	1.09E+11
10	1.33E+11	1.18E+11
11	1.20E+11	1.01E+11
12	1.20E+11	1.07E+11

<u>Cycle No.</u>	$\phi(E > 0.1 \text{ MeV}) \text{ (n/cm}^2\text{-sec)}$	
	<u>17°</u>	<u>20°</u>
Reference	1.13E+12	9.37E+11
1	9.40E+11	7.80E+11
2	9.81E+11	8.10E+11
3	8.89E+11	7.27E+11
4	7.34E+11	6.11E+11
5	7.09E+11	5.88E+11
6	6.54E+11	5.54E+11
7	6.89E+11	5.90E+11
8	6.49E+11	5.48E+11
9	6.02E+11	5.10E+11
10	6.52E+11	5.55E+11
11	5.85E+11	4.74E+11
12	5.89E+11	5.01E+11

Table 6-1 Cont'd
Calculated Fast Neutron Exposure Rates and Iron Atom
Displacement Rates at the Surveillance Capsule Center

<u>Cycle No.</u> Reference	Iron Atom Displacement Rate (dpa/sec)	
	<u>17°</u>	<u>20°</u>
1	4.67E-10	3.94E-10
2	3.88E-10	3.28E-10
3	4.05E-10	3.41E-10
4	3.67E-10	3.06E-10
5	3.03E-10	2.57E-10
6	2.93E-10	2.47E-10
7	2.70E-10	2.33E-10
8	2.85E-10	2.48E-10
9	2.68E-10	2.30E-10
10	2.49E-10	2.15E-10
11	2.69E-10	2.33E-10
12	2.42E-10	1.99E-10
	2.43E-10	2.11E-10

Table 6-2

Calculated Azimuthal Variation of Fast Neutron Exposure Rates
and Iron Atom Displacement Rates at the Reactor Vessel Clad/Base Metal Interface

<u>Cycle No.</u>	$\phi(E > 1.0 \text{ MeV}) \text{ (n/cm}^2\text{-sec)}$			
	<u>0°</u>	<u>15°</u>	<u>30°</u>	<u>45°</u>
Reference	6.92E+10	3.84E+10	2.81E+10	1.89E+10
1	5.80E+10	3.23E+10	2.38E+10	1.65E+10
2	6.06E+10	3.37E+10	2.47E+10	1.71E+10
3	5.54E+10	3.06E+10	2.05E+10	1.27E+10
4	4.43E+10	2.52E+10	1.80E+10	1.29E+10
5	4.09E+10	2.44E+10	1.73E+10	1.14E+10
6	3.64E+10	2.24E+10	1.73E+10	1.21E+10
7	3.93E+10	2.37E+10	1.86E+10	1.27E+10
8	3.60E+10	2.23E+10	1.71E+10	1.23E+10
9	3.35E+10	2.07E+10	1.63E+10	1.20E+10
10	3.52E+10	2.23E+10	1.73E+10	1.25E+10
11	4.27E+10	2.07E+10	1.49E+10	1.16E+10
12	2.97E+10	2.01E+10	1.50E+10	1.07E+10

<u>Cycle No.</u>	$\phi(E > 0.1 \text{ MeV}) \text{ (n/cm}^2\text{-sec)}$			
	<u>0°</u>	<u>15°</u>	<u>30°</u>	<u>45°</u>
Reference	1.81E+11	9.35E+10	6.07E+10	4.03E+10
1	1.51E+11	7.86E+10	5.13E+10	3.51E+10
2	1.58E+11	8.20E+10	5.33E+10	3.63E+10
3	1.44E+11	7.46E+10	4.41E+10	2.71E+10
4	1.16E+11	6.14E+10	3.87E+10	2.76E+10
5	1.07E+11	5.93E+10	3.73E+10	2.42E+10
6	9.51E+10	5.47E+10	3.73E+10	2.59E+10
7	1.03E+11	5.76E+10	4.00E+10	2.70E+10
8	9.39E+10	5.43E+10	3.68E+10	2.62E+10
9	8.75E+10	5.05E+10	3.52E+10	2.55E+10
10	9.18E+10	5.44E+10	3.73E+10	2.65E+10
11	1.11E+11	5.04E+10	3.20E+10	2.48E+10
12	7.76E+10	4.88E+10	3.24E+10	2.29E+10

Table 6-2 Cont'd

Calculated Azimuthal Variation of Fast Neutron Exposure Rates
and Iron Atom Displacement Rates at the Reactor Vessel Clad/Base Metal Interface

<u>Cycle No.</u>	<u>Iron Atom Displacement Rate (dpa/sec)</u>			
	<u>0°</u>	<u>15°</u>	<u>30°</u>	<u>45°</u>
<u>Reference</u>	1.10E-10	6.06E-11	4.32E-11	2.93E-11
1	9.23E-11	5.09E-11	3.65E-11	2.55E-11
2	9.64E-11	5.31E-11	3.79E-11	2.64E-11
3	8.81E-11	4.83E-11	3.14E-11	1.97E-11
4	7.04E-11	3.97E-11	2.76E-11	2.00E-11
5	6.51E-11	3.84E-11	2.65E-11	1.76E-11
6	5.80E-11	3.54E-11	2.66E-11	1.88E-11
7	6.26E-11	3.73E-11	2.85E-11	1.96E-11
8	5.73E-11	3.51E-11	2.62E-11	1.91E-11
9	5.34E-11	3.27E-11	2.51E-11	1.85E-11
10	5.60E-11	3.52E-11	2.66E-11	1.93E-11
11	6.80E-11	3.26E-11	2.28E-11	1.80E-11
12	4.73E-11	3.16E-11	2.31E-11	1.66E-11

Table 6-3

Relative Radial Distribution of $\phi(E > 1.0 \text{ MeV})$
within the Reactor Vessel Wall

RADIUS (cm)	AZIMUTHAL ANGLE			
	0°	15°	30°	45°
199.95	1.000	1.000	1.000	1.000
200.54	0.961	0.962	0.961	0.963
201.72	0.861	0.863	0.864	0.868
202.89	0.754	0.760	0.758	0.765
204.07	0.653	0.661	0.658	0.667
204.95	0.585	0.595	0.591	0.601
205.25	0.562	0.573	0.568	0.578
206.42	0.482	0.494	0.488	0.499
207.60	0.412	0.424	0.417	0.429
208.78	0.351	0.364	0.356	0.368
209.95	0.299	0.311	0.304	0.315
211.13	0.254	0.266	0.258	0.269
212.30	0.215	0.227	0.219	0.229
213.48	0.182	0.193	0.186	0.195
214.66	0.153	0.164	0.157	0.166
214.95	0.147	0.158	0.151	0.159
215.83	0.129	0.139	0.132	0.141
217.01	0.107	0.118	0.111	0.119
218.19	0.089	0.099	0.093	0.100
219.36	0.071	0.083	0.076	0.084
219.95	0.068	0.080	0.073	0.081

Note: Base Metal Inner Radius = 199.95 cm
 Base Metal $\frac{1}{4}T$ = 204.95 cm
 Base Metal $\frac{1}{2}T$ = 209.95 cm
 Base Metal $\frac{3}{4}T$ = 214.95 cm
 Base Metal Outer Radius = 219.95 cm

Table 6-4

Relative Radial Distribution of $\phi(E > 0.1 \text{ MeV})$
within the Reactor Vessel Wall

RADIUS (cm)	AZIMUTHAL ANGLE			
	0°	15°	30°	45°
199.95	1.000	1.000	1.000	1.000
200.54	1.005	1.011	1.007	1.011
201.72	0.982	0.995	0.989	0.998
202.89	0.940	0.961	0.951	0.965
204.07	0.891	0.919	0.904	0.923
204.95	0.852	0.885	0.867	0.889
205.25	0.839	0.873	0.855	0.878
206.42	0.786	0.825	0.804	0.830
207.60	0.733	0.776	0.753	0.781
208.78	0.681	0.728	0.703	0.733
209.95	0.630	0.680	0.655	0.686
211.13	0.581	0.633	0.607	0.639
212.30	0.533	0.586	0.561	0.593
213.48	0.486	0.540	0.516	0.548
214.66	0.441	0.496	0.472	0.505
214.95	0.430	0.485	0.462	0.494
215.83	0.397	0.452	0.430	0.462
217.01	0.353	0.408	0.388	0.420
218.19	0.308	0.365	0.347	0.380
219.36	0.261	0.321	0.307	0.340
219.95	0.251	0.312	0.298	0.332

Note: Base Metal Inner Radius = 199.95 cm
 Base Metal $\frac{1}{4}T$ = 204.95 cm
 Base Metal $\frac{1}{2}T$ = 209.95 cm
 Base Metal $\frac{3}{4}T$ = 214.95 cm
 Base Metal Outer Radius = 219.95 cm

Table 6-5

Relative Radial Distribution of dpa/sec
within the Reactor Vessel Wall

RADIUS (cm)	AZIMUTHAL ANGLE			
	0°	15°	30°	45°
199.95	1.000	1.000	1.000	1.000
200.54	0.968	0.971	0.967	0.969
201.72	0.889	0.897	0.885	0.889
202.89	0.805	0.821	0.798	0.804
204.07	0.725	0.747	0.715	0.724
204.95	0.670	0.695	0.659	0.668
205.25	0.651	0.678	0.640	0.650
206.42	0.584	0.615	0.572	0.583
207.60	0.524	0.558	0.511	0.523
208.78	0.470	0.506	0.456	0.469
209.95	0.421	0.458	0.408	0.421
211.13	0.376	0.414	0.364	0.377
212.30	0.336	0.374	0.325	0.338
213.48	0.299	0.337	0.290	0.303
214.66	0.265	0.303	0.258	0.271
214.95	0.258	0.295	0.251	0.264
215.83	0.234	0.272	0.229	0.242
217.01	0.205	0.242	0.203	0.216
218.19	0.177	0.214	0.178	0.191
219.36	0.149	0.188	0.156	0.170
219.95	0.143	0.183	0.151	0.166

Note: Base Metal Inner Radius = 199.95 cm
 Base Metal $\frac{1}{4}T$ = 204.95 cm
 Base Metal $\frac{1}{2}T$ = 209.95 cm
 Base Metal $\frac{3}{4}T$ = 214.95 cm
 Base Metal Outer Radius = 219.95 cm

Table 6-6

Nuclear Parameters used in the Evaluation of Neutron Sensors

<u>Monitor Material</u>	<u>Reaction of Interest</u>	<u>Target Atom Fraction</u>	<u>Response Range</u>	<u>Product Half-life</u>	<u>Fission Yield (%)</u>
Copper	$^{63}\text{Cu} (n,\alpha)$	0.6917	E > 4.7 MeV	5.271 y	
Iron	$^{54}\text{Fe} (n,p)$	0.0585	E > 1.0 MeV	312.1 d	
Nickel	$^{58}\text{Ni} (n,p)$	0.6808	E > 1.0 MeV	70.88 d	
Uranium-238	$^{238}\text{U} (n,f)$	1.0000	E > 0.4 MeV	30.07 y	6.02
Neptunium-237	$^{237}\text{Np} (n,f)$	1.0000	E > 0.08 MeV	30.07 y	6.17
Cobalt-Al	$^{59}\text{Co} (n,\gamma)$	0.0015	non-threshold	5.271 y	

Note: ^{238}U and ^{237}Np monitors are cadmium shielded.

Table 6-7

Monthly Thermal Generation During the First Twelve Fuel Cycles
of the Farley Unit 2 Reactor
(Reference Power of 2775 MWt)

<u>Year</u>	<u>Month</u>	<u>Thermal Generat. (MW-hr)</u>	<u>Year</u>	<u>Month</u>	<u>Thermal Generat. (MW-hr)</u>	<u>Year</u>	<u>Month</u>	<u>Thermal Generat. (MW-hr)</u>
1981	5	49210	1984	9	944645	1988	1	1971889
1981	6	369436	1984	10	1813687	1988	2	1806542
1981	7	118595	1984	11	1906767	1988	3	1973062
1981	8	1830227	1984	12	1771677	1988	4	1906960
1981	9	1837261	1985	1	239473	1988	5	1973062
1981	10	1948774	1985	2	0	1988	6	1904396
1981	11	1818795	1985	3	368968	1988	7	1973019
1981	12	1912506	1985	4	1861582	1988	8	1973083
1982	1	1707819	1985	5	1925137	1988	9	1767980
1982	2	10186	1985	6	1865725	1988	10	1975740
1982	3	1541170	1985	7	1769634	1988	11	1690586
1982	4	1855620	1985	8	1739953	1988	12	1938045
1982	5	1913932	1985	9	1867238	1989	1	1967158
1982	6	1836202	1985	10	1943516	1989	2	1687171
1982	7	1925451	1985	11	1874503	1989	3	1516400
1982	8	1963933	1985	12	1962073	1989	4	0
1982	9	1814278	1986	1	1798238	1989	5	172773
1982	10	1387065	1986	2	1755415	1989	6	1786822
1982	11	0	1986	3	1945120	1989	7	1864633
1982	12	1572848	1986	4	239320	1989	8	1971608
1983	1	1967195	1986	5	396193	1989	9	1456223
1983	2	1778710	1986	6	1744613	1989	10	1848890
1983	3	1969863	1986	7	1625000	1989	11	1815074
1983	4	1899797	1986	8	1865663	1989	12	1971879
1983	5	1970049	1986	9	1871967	1990	1	1970306
1983	6	1905327	1986	10	1966262	1990	2	1631313
1983	7	1960067	1986	11	1905245	1990	3	1971205
1983	8	1966925	1986	12	1970404	1990	4	1694856
1983	9	937869	1987	1	789042	1990	5	1168621
1983	10	163398	1987	2	1756640	1990	6	1907902
1983	11	1479567	1987	3	1839164	1990	7	1970982
1983	12	1917263	1987	4	1873088	1990	8	1970095
1984	1	1711893	1987	5	1972677	1990	9	1907101
1984	2	1845593	1987	6	1771494	1990	10	755300
1984	3	1895910	1987	7	1970667	1990	11	0
1984	4	1845190	1987	8	1782971	1990	12	0
1984	5	1950480	1987	9	1909196	1991	1	1459221
1984	6	1909440	1987	10	119759	1991	2	1744114
1984	7	1968023	1987	11	0	1991	3	1971550
1984	8	1951599	1987	12	240584	1991	4	1237745

Table 6-7 Cont'd

Monthly Thermal Generation During the First Twelve Fuel Cycles
of the Farley Unit 2 Reactor
(Reference Power of 2775 MWt)

<u>Year</u>	<u>Month</u>	<u>Thermal Generat. (MW-hr)</u>	<u>Year</u>	<u>Month</u>	<u>Thermal Generat. (MW-hr)</u>	<u>Year</u>	<u>Month</u>	<u>Thermal Generat. (MW-hr)</u>
1991	5	1965554	1994	9	1909440	1998	1	1972558
1991	6	1905656	1994	10	1975737	1998	2	1782144
1991	7	1966074	1994	11	1905343	1998	3	1715128
1991	8	1874009	1994	12	1709587			
1991	9	1901630	1995	1	1728025			
1991	10	1973717	1995	2	1742523			
1991	11	1784506	1995	3	555111			
1991	12	1971598	1995	4	76112			
1992	1	1853267	1995	5	493007			
1992	2	1845792	1995	6	880008			
1992	3	367169	1995	7	1896021			
1992	4	0	1995	8	1865019			
1992	5	513304	1995	9	1909440			
1992	6	1783981	1995	10	1776999			
1992	7	1877441	1995	11	1772332			
1992	8	1965981	1995	12	1939487			
1992	9	1779781	1996	1	1867751			
1992	10	1742799	1996	2	1809698			
1992	11	1890054	1996	3	1832081			
1992	12	1952058	1996	4	1895146			
1993	1	1879525	1996	5	1880613			
1993	2	1114049	1996	6	1907027			
1993	3	1936119	1996	7	1973088			
1993	4	1885890	1996	8	1972155			
1993	5	1902839	1996	9	1891141			
1993	6	1889227	1996	10	696495			
1993	7	1906713	1996	11	0			
1993	8	1952573	1996	12	749110			
1993	9	1433273	1997	1	1972929			
1993	10	0	1997	2	1688502			
1993	11	0	1997	3	1973088			
1993	12	1104196	1997	4	1906788			
1994	1	1953209	1997	5	1971338			
1994	2	1772701	1997	6	1909440			
1994	3	1962548	1997	7	1973008			
1994	4	1893222	1997	8	1971815			
1994	5	1963755	1997	9	1909440			
1994	6	1903898	1997	10	1975501			
1994	7	1973017	1997	11	1908804			
1994	8	1881896	1997	12	1951236			

Table 6-8

Measured Sensor Activities and Reaction Rates

Surveillance Capsule U

<u>Reaction</u>	<u>Location</u>	<u>Measured Activity (dps/gm)</u>	<u>Saturated Activity (dps/gm)</u>	<u>Reaction Rate (rps/atom)</u>
$^{63}\text{Cu} (n,\alpha) ^{60}\text{Co}$	Top	6.42E+04	5.50E+05	8.39E-17
	Middle	6.47E+04	5.54E+05	8.46E-17
	Bottom	6.79E+04	5.82E+05	8.87E-17
$^{54}\text{Fe} (n,p) ^{54}\text{Mn}$	Top	1.68E+06	5.68E+06	9.00E-15
	Middle	1.62E+06	5.48E+06	8.68E-15
	Bottom	1.71E+06	5.78E+06	9.17E-15
$^{58}\text{Ni} (n,p) ^{58}\text{Co}$	Top	5.17E+06	8.64E+07	1.24E-14
	Middle	4.84E+06	8.09E+07	1.16E-14
	Bottom	5.29E+06	8.84E+07	1.27E-14
$^{59}\text{Co} (n,\gamma) ^{60}\text{Co}$	Top	1.36E+07	1.17E+08	7.60E-12
	Middle	1.42E+07	1.22E+08	7.94E-12
	Bottom	1.40E+07	1.20E+08	7.83E-12
$^{59}\text{Co} (n,\gamma) ^{60}\text{Co} (\text{Cd})$	Top	7.76E+06	6.65E+07	4.34E-12
	Middle	8.09E+06	6.93E+07	4.52E-12
	Bottom	7.82E+06	6.70E+07	4.37E-12
$^{238}\text{U} (n,f) ^{137}\text{Cs} (\text{Cd})$	Middle	2.29E+05	9.65E+06	6.34E-14
	Including ^{235}U , ^{239}Pu , and γ -fission corrections			5.32E-14
$^{237}\text{Np} (n,f) ^{137}\text{Cs} (\text{Cd})$	Middle	2.15E+06	9.06E+07	5.78E-13
	Including γ -fission correction			5.74E-13

Table 6-8 Cont'd

Measured Sensor Activities and Reaction Rates

Surveillance Capsule W

<u>Reaction</u>	<u>Location</u>	<u>Measured Activity (dps/gm)</u>	<u>Saturated Activity (dps/gm)</u>	<u>Reaction Rate (rps/atom)</u>
$^{63}\text{Cu} (n,\alpha) ^{60}\text{Co}$	Top	1.53E+05	4.52E+05	6.89E-17
	Middle	1.55E+05	4.57E+05	6.98E-17
	Bottom	1.69E+05	4.99E+05	7.61E-17
$^{54}\text{Fe} (n,p) ^{54}\text{Mn}$	Top	2.11E+06	4.58E+06	7.27E-15
	Middle	2.05E+06	4.45E+06	7.06E-15
	Bottom	2.19E+06	4.76E+06	7.54E-15
$^{58}\text{Ni} (n,p) ^{58}\text{Co}$	Top	7.28E+06	7.21E+07	1.03E-14
	Middle	6.91E+06	6.84E+07	9.79E-15
	Bottom	8.04E+06	7.96E+07	1.14E-14
$^{59}\text{Co} (n,\gamma) ^{60}\text{Co}$	Top	2.77E+07	8.17E+07	5.33E-12
	Middle	2.92E+07	8.62E+07	5.62E-12
	Bottom	2.78E+07	8.20E+07	5.35E-12
$^{59}\text{Co} (n,\gamma) ^{60}\text{Co} (\text{Cd})$	Top	1.56E+07	4.60E+07	3.00E-12
	Middle	1.64E+07	4.84E+07	3.16E-12
	Bottom	1.62E+07	4.78E+07	3.12E-12
$^{238}\text{U} (n,f) ^{137}\text{Cs} (\text{Cd})$	Middle	5.70E+05	7.01E+06	4.60E-14
	Including ^{235}U , ^{239}Pu , and γ -fission corrections			3.67E-14
$^{237}\text{Np} (n,f) ^{137}\text{Cs} (\text{Cd})$	Middle	5.54E+06	6.81E+07	4.35E-13
	Including γ -fission correction			4.32E-13

Table 6-8 Cont'd

Measured Sensor Activities and Reaction Rates

Surveillance Capsule X

<u>Reaction</u>	<u>Location</u>	<u>Measured Activity (dps/gm)</u>	<u>Saturated Activity (dps/gm)</u>	<u>Reaction Rate (rps/atom)</u>
$^{63}\text{Cu} (n,\alpha) ^{60}\text{Co}$	Top	2.27E+05	4.73E+05	7.21E-17
	Middle	2.21E+05	4.60E+05	7.02E-17
	Bottom	2.33E+05	4.85E+05	7.40E-17
$^{54}\text{Fe} (n,p) ^{54}\text{Mn}$	Top	2.85E+06	4.52E+06	7.17E-15
	Middle	2.80E+06	4.44E+06	7.05E-15
	Bottom	2.95E+06	4.68E+06	7.42E-15
$^{58}\text{Ni} (n,p) ^{58}\text{Co}$	Top	3.24E+07	7.33E+07	1.05E-14
	Middle	3.07E+07	6.95E+07	9.94E-15
	Bottom	3.34E+07	7.56E+07	1.08E-14
$^{59}\text{Co} (n,\gamma) ^{60}\text{Co}$	Top	4.90E+07	1.02E+08	6.66E-12
	Middle	5.09E+07	1.06E+08	6.91E-12
	Bottom	5.06E+07	1.05E+08	6.87E-12
$^{59}\text{Co} (n,\gamma) ^{60}\text{Co} (\text{Cd})$	Top	2.90E+07	6.04E+07	3.94E-12
	Middle	2.76E+07	5.75E+07	3.75E-12
	Bottom	2.75E+07	5.73E+07	3.74E-12
	Bottom	2.67E+07	5.56E+07	3.63E-12

No fission monitors present in the capsule.

Table 6-8 Cont'd

Measured Sensor Activities and Reaction Rates

Surveillance Capsule Z

<u>Reaction</u>	<u>Location</u>	<u>Measured Activity (dps/gm)</u>	<u>Saturated Activity (dps/gm)</u>	<u>Reaction Rate (rps/atom)</u>
$^{63}\text{Cu} (n,\alpha) ^{60}\text{Co}$	Top	2.90E+05	4.78E+05	7.29E-17
	Middle	2.81E+05	4.63E+05	7.06E-17
	Bottom	3.00E+05	4.94E+05	7.54E-17
$^{54}\text{Fe} (n,p) ^{54}\text{Mn}$	Top	2.17E+06	4.82E+06	7.64E-15
	Middle	2.06E+06	4.57E+06	7.25E-15
	Bottom	2.21E+06	4.91E+06	7.78E-15
$^{58}\text{Ni} (n,p) ^{58}\text{Co}$	Top	7.13E+06	7.58E+07	1.09E-14
	Middle	6.86E+06	7.29E+07	1.04E-14
	Bottom	7.42E+06	7.89E+07	1.13E-14
$^{59}\text{Co} (n,\gamma) ^{60}\text{Co}$	Top	4.37E+07	7.20E+07	4.70E-12
	Middle	4.49E+07	7.40E+07	4.83E-12
	Bottom	4.30E+07	7.09E+07	4.62E-12
$^{59}\text{Co} (n,\gamma) ^{60}\text{Co} (\text{Cd})$	Top	2.41E+07	3.97E+07	2.59E-12
	Middle	2.52E+07	4.15E+07	2.71E-12
	Bottom	2.42E+07	3.99E+07	2.60E-12
$^{238}\text{U} (n,f) ^{137}\text{Cs} (\text{Cd})$	Middle	2.12E+06	8.62E+06	5.66E-14
	Including ^{235}U , ^{239}Pu , and γ -fission corrections			3.89E-14
$^{237}\text{Np} (n,f) ^{137}\text{Cs} (\text{Cd})$	Middle	1.12E+07	4.55E+07	2.90E-13
	Including γ -fission correction			2.89E-13

The reaction rate for $^{237}\text{Np} (n,f) ^{137}\text{Cs}$ for Capsule Z was not used in the FERRET least squares evaluation due to the inconsistency of the $^{237}\text{Np} (n,f) ^{137}\text{Cs}$ measurement relative to the 3-loop neutron pad plant data base¹.

¹ E. P. Lippincott, "Westinghouse Surveillance Capsule Neutron Fluence Reevaluation," Westinghouse Electric Company, WCAP-14044, April 1994.

Table 6-9

Summary of Neutron Dosimetry Results
Surveillance Capsules U, W, X, and Z

Best Estimate Flux and Fluence for Capsule U

<u>Quantity</u>	<u>Flux</u> <u>[n/cm²-sec]</u>	<u>Quantity</u>	<u>Fluence</u> <u>[n/cm²]</u>	<u>Uncertainty</u>
ϕ (E > 1.0 MeV)	1.66E+11	Φ (E > 1.0 MeV)	5.58E+18	7%
ϕ (E > 0.1 MeV)	8.95E+11	Φ (E > 0.1 MeV)	3.00E+19	16%
ϕ (E < 0.414 eV)	1.34E+11	Φ (E < 0.414 eV)	4.48E+18	29%
dpa/sec	3.60E-10	dpa	1.21E-02	11%

Best Estimate Flux and Fluence for Capsule W

<u>Quantity</u>	<u>Flux</u> <u>[n/cm²-sec]</u>	<u>Quantity</u>	<u>Fluence</u> <u>[n/cm²]</u>	<u>Uncertainty</u>
ϕ (E > 1.0 MeV)	1.27E+11	Φ (E > 1.0 MeV)	1.51E+19	7%
ϕ (E > 0.1 MeV)	6.47E+11	Φ (E > 0.1 MeV)	7.73E+19	16%
ϕ (E < 0.414 eV)	9.27E+10	Φ (E < 0.414 eV)	1.11E+19	29%
dpa/sec	2.66E-10	dpa	3.17E-02	11%

Best Estimate Flux and Fluence for Capsule X

<u>Quantity</u>	<u>Flux</u> <u>[n/cm²-sec]</u>	<u>Quantity</u>	<u>Fluence</u> <u>[n/cm²]</u>	<u>Uncertainty</u>
ϕ (E > 1.0 MeV)	1.29E+11	Φ (E > 1.0 MeV)	2.50E+19	12%
ϕ (E > 0.1 MeV)	6.74E+11	Φ (E > 0.1 MeV)	1.31E+20	24%
ϕ (E < 0.414 eV)	1.19E+11	Φ (E < 0.414 eV)	2.30E+19	28%
dpa/sec	2.75E-10	dpa	5.32E-02	18%

Best Estimate Flux and Fluence for Capsule Z

<u>Quantity</u>	<u>Flux</u> <u>[n/cm²-sec]</u>	<u>Quantity</u>	<u>Fluence</u> <u>[n/cm²]</u>	<u>Uncertainty</u>
ϕ (E > 1.0 MeV)	1.26E+11	Φ (E > 1.0 MeV)	5.28E+19	10%
ϕ (E > 0.1 MeV)	5.91E+11	Φ (E > 0.1 MeV)	2.47E+20	21%
ϕ (E < 0.414 eV)	8.27E+10	Φ (E < 0.414 eV)	3.45E+19	29%
dpa/sec	2.51E-10	dpa	1.05E-01	15%

Table 6-10

Comparison of Measured, Calculated, and Best Estimate
Reaction Rates at the Surveillance Capsule Center

Surveillance Capsule U						
<u>Reaction</u>	<u>Measured</u>	<u>Calculated</u>	<u>Best Estimate</u>	<u>BE / Meas</u>	<u>BE/ Calc</u>	<u>Meas/Calc</u>
$^{63}\text{Cu} (n,\alpha)$	8.57E-17	8.19E-17	8.34E-17	0.97	1.02	1.05
$^{54}\text{Fe} (n,p)$	8.95E-15	1.00E-14	9.00E-15	1.01	0.90	0.90
$^{58}\text{Ni} (n,p)$	1.22E-14	1.43E-14	1.27E-14	1.04	0.89	0.85
$^{238}\text{U} (n,f) (\text{Cd})$	5.32E-14	5.80E-14	5.02E-14	0.94	0.87	0.92
$^{237}\text{Np} (n,f) (\text{Cd})$	5.75E-13	6.21E-13	5.65E-13	0.98	0.91	0.93
$^{59}\text{Co} (n,\gamma)$	7.79E-12	6.12E-12	7.74E-12	0.99	1.26	1.27
$^{59}\text{Co} (n,\gamma) (\text{Cd})$	4.41E-12	4.71E-12	4.43E-12	1.00	0.94	0.94

Surveillance Capsule W						
<u>Reaction</u>	<u>Measured</u>	<u>Calculated</u>	<u>Best Estimate</u>	<u>BE / Meas</u>	<u>BE/ Calc</u>	<u>Meas/Calc</u>
$^{63}\text{Cu} (n,\alpha)$	7.16E-17	7.22E-17	7.04E-17	0.98	0.98	0.99
$^{54}\text{Fe} (n,p)$	7.29E-15	8.55E-15	7.42E-15	1.02	0.87	0.85
$^{58}\text{Ni} (n,p)$	1.05E-14	1.21E-14	1.04E-14	0.99	0.86	0.87
$^{238}\text{U} (n,f) (\text{Cd})$	3.67E-14	4.77E-14	3.92E-14	1.07	0.82	0.77
$^{237}\text{Np} (n,f) (\text{Cd})$	4.32E-13	4.90E-13	4.20E-13	0.97	0.86	0.88
$^{59}\text{Co} (n,\gamma)$	5.44E-12	4.51E-12	5.40E-12	0.99	1.20	1.21
$^{59}\text{Co} (n,\gamma) (\text{Cd})$	3.09E-12	3.48E-12	3.11E-12	1.01	0.89	0.89

Table 6-10 Cont'd

Comparison of Measured, Calculated, and Best Estimate
Reaction Rates at the Surveillance Capsule Center

Surveillance Capsule X						
<u>Reaction</u>	<u>Measured</u>	<u>Calculated</u>	<u>Best Estimate</u>	<u>BE / Meas</u>	<u>BE/ Calc</u>	<u>Meas/Calc</u>
⁶³ Cu (n,α)	7.21E-17	7.02E-17	7.04E-17	0.98	1.00	1.03
⁵⁴ Fe (n,p)	7.21E-15	8.61E-15	7.42E-15	1.03	0.86	0.84
⁵⁸ Ni (n,p)	1.04E-14	1.23E-14	1.04E-14	1.00	0.85	0.85
²³⁸ U (n,f) (Cd)						
²³⁷ Np (n,f) (Cd)						
⁵⁹ Co (n,γ)	6.81E-12	5.25E-12	6.76E-12	0.99	1.29	1.30
⁵⁹ Co (n,γ) (Cd)	3.76E-12	4.04E-12	3.78E-12	1.01	0.94	0.93

Surveillance Capsule Z						
<u>Reaction</u>	<u>Measured</u>	<u>Calculated</u>	<u>Best Estimate</u>	<u>BE / Meas</u>	<u>BE/ Calc</u>	<u>Meas/Calc</u>
⁶³ Cu (n,α)	7.30E-17	5.89E-17	7.19E-17	0.98	1.22	1.24
⁵⁴ Fe (n,p)	7.56E-15	6.97E-15	7.70E-15	1.02	1.10	1.08
⁵⁸ Ni (n,p)	1.09E-14	9.85E-15	1.07E-14	0.98	1.09	1.11
²³⁸ U (n,f) (Cd)	3.89E-14	3.89E-14	4.00E-14	1.03	1.03	1.00
²³⁷ Np (n,f) (Cd)						
⁵⁹ Co (n,γ)	4.72E-12	3.67E-12	4.68E-12	0.99	1.28	1.29
⁵⁹ Co (n,γ) (Cd)	2.63E-12	2.84E-12	2.65E-12	1.01	0.93	0.93

Table 6-11

Best Estimate Neutron Energy Spectrum at the
Center of Surveillance Capsules

Capsule U

<u>Group #</u>	<u>Energy (MeV)</u>	<u>Flux (n/cm²-sec)</u>	<u>Group #</u>	<u>Energy (MeV)</u>	<u>Flux (n/cm²-sec)</u>
1	1.73E+01	1.13E+07	28	9.12E-03	3.96E+10
2	1.49E+01	2.42E+07	29	5.53E-03	4.08E+10
3	1.35E+01	8.97E+07	30	3.36E-03	1.32E+10
4	1.16E+01	2.45E+08	31	2.84E-03	1.29E+10
5	1.00E+01	5.52E+08	32	2.40E-03	1.28E+10
6	8.61E+00	9.54E+08	33	2.04E-03	3.84E+10
7	7.41E+00	2.27E+09	34	1.23E-03	3.91E+10
8	6.07E+00	3.42E+09	35	7.49E-04	3.79E+10
9	4.97E+00	7.05E+09	36	4.54E-04	2.79E+10
10	3.68E+00	8.48E+09	37	2.75E-04	3.14E+10
11	2.87E+00	1.67E+10	38	1.67E-04	3.21E+10
12	2.23E+00	2.38E+10	39	1.01E-04	3.37E+10
13	1.74E+00	3.42E+10	40	6.14E-05	3.39E+10
14	1.35E+00	4.10E+10	41	3.73E-05	3.30E+10
15	1.11E+00	8.11E+10	42	2.26E-05	3.15E+10
16	8.21E-01	9.14E+10	43	1.37E-05	3.00E+10
17	6.39E-01	1.11E+11	44	8.32E-06	2.77E+10
18	4.98E-01	7.44E+10	45	5.04E-06	2.42E+10
19	3.88E-01	1.24E+11	46	3.06E-06	2.18E+10
20	3.02E-01	1.23E+11	47	1.86E-06	1.93E+10
21	1.83E-01	1.36E+11	48	1.13E-06	1.12E+10
22	1.11E-01	7.74E+10	49	6.83E-07	1.33E+10
23	6.74E-02	7.66E+10	50	4.14E-07	2.13E+10
24	4.09E-02	3.73E+10	51	2.51E-07	2.19E+10
25	2.55E-02	4.72E+10	52	1.52E-07	2.18E+10
26	1.99E-02	1.87E+10	53	9.24E-08	6.87E+10
27	1.50E-02	3.58E+10			

Note: Tabulated energy levels represent the upper energy in each group.

Table 6-11 Cont'd

Best Estimate Neutron Energy Spectrum at the
Center of Surveillance Capsules

Capsule W					
<u>Group #</u>	<u>Energy (MeV)</u>	<u>Flux (n/cm²-sec)</u>	<u>Group #</u>	<u>Energy (MeV)</u>	<u>Flux (n/cm²-sec)</u>
1	1.73E+01	9.42E+06	28	9.12E-03	2.84E+10
2	1.49E+01	2.03E+07	29	5.53E-03	2.93E+10
3	1.35E+01	7.52E+07	30	3.36E-03	9.43E+09
4	1.16E+01	2.06E+08	31	2.84E-03	9.19E+09
5	1.00E+01	4.65E+08	32	2.40E-03	9.06E+09
6	8.61E+00	8.04E+08	33	2.04E-03	2.72E+10
7	7.41E+00	1.92E+09	34	1.23E-03	2.75E+10
8	6.07E+00	2.90E+09	35	7.49E-04	2.68E+10
9	4.97E+00	5.90E+09	36	4.54E-04	1.99E+10
10	3.68E+00	6.87E+09	37	2.75E-04	2.19E+10
11	2.87E+00	1.33E+10	38	1.67E-04	2.25E+10
12	2.23E+00	1.81E+10	39	1.01E-04	2.37E+10
13	1.74E+00	2.55E+10	40	6.14E-05	2.38E+10
14	1.35E+00	3.03E+10	41	3.73E-05	2.30E+10
15	1.11E+00	5.89E+10	42	2.26E-05	2.20E+10
16	8.21E-01	6.57E+10	43	1.37E-05	2.10E+10
17	6.39E-01	7.89E+10	44	8.32E-06	1.93E+10
18	4.98E-01	5.30E+10	45	5.04E-06	1.69E+10
19	3.88E-01	8.82E+10	46	3.06E-06	1.52E+10
20	3.02E-01	8.75E+10	47	1.86E-06	1.35E+10
21	1.83E-01	9.72E+10	48	1.13E-06	7.83E+09
22	1.11E-01	5.53E+10	49	6.83E-07	9.26E+09
23	6.74E-02	5.47E+10	50	4.14E-07	1.48E+10
24	4.09E-02	2.68E+10	51	2.51E-07	1.52E+10
25	2.55E-02	3.38E+10	52	1.52E-07	1.51E+10
26	1.99E-02	1.34E+10	53	9.24E-08	4.76E+10
27	1.50E-02	2.57E+10			

Note: Tabulated energy levels represent the upper energy in each group.

Table 6-11 Cont'd

Best Estimate Neutron Energy Spectrum at the
Center of Surveillance Capsules

Capsule X

<u>Group #</u>	<u>Energy (MeV)</u>	<u>Flux (n/cm²-sec)</u>	<u>Group #</u>	<u>Energy (MeV)</u>	<u>Flux (n/cm²-sec)</u>
1	1.73E+01	9.43E+06	28	9.12E-03	3.19E+10
2	1.49E+01	2.03E+07	29	5.53E-03	3.31E+10
3	1.35E+01	7.58E+07	30	3.36E-03	1.07E+10
4	1.16E+01	2.08E+08	31	2.84E-03	1.05E+10
5	1.00E+01	4.68E+08	32	2.40E-03	1.05E+10
6	8.61E+00	8.07E+08	33	2.04E-03	3.16E+10
7	7.41E+00	1.91E+09	34	1.23E-03	3.24E+10
8	6.07E+00	2.86E+09	35	7.49E-04	3.15E+10
9	4.97E+00	5.86E+09	36	4.54E-04	2.33E+10
10	3.68E+00	6.92E+09	37	2.75E-04	2.63E+10
11	2.87E+00	1.34E+10	38	1.67E-04	2.75E+10
12	2.23E+00	1.85E+10	39	1.01E-04	2.84E+10
13	1.74E+00	2.61E+10	40	6.14E-05	2.84E+10
14	1.35E+00	3.10E+10	41	3.73E-05	2.76E+10
15	1.11E+00	6.06E+10	42	2.26E-05	2.62E+10
16	8.21E-01	6.79E+10	43	1.37E-05	2.49E+10
17	6.39E-01	8.21E+10	44	8.32E-06	2.30E+10
18	4.98E-01	5.52E+10	45	5.04E-06	2.01E+10
19	3.88E-01	9.20E+10	46	3.06E-06	1.81E+10
20	3.02E-01	9.21E+10	47	1.86E-06	1.60E+10
21	1.83E-01	1.03E+11	48	1.13E-06	9.29E+09
22	1.11E-01	5.92E+10	49	6.83E-07	1.12E+10
23	6.74E-02	5.93E+10	50	4.14E-07	1.81E+10
24	4.09E-02	2.91E+10	51	2.51E-07	1.89E+10
25	2.55E-02	3.73E+10	52	1.52E-07	1.90E+10
26	1.99E-02	1.49E+10	53	9.24E-08	6.28E+10
27	1.50E-02	2.87E+10			

Note: Tabulated energy levels represent the upper energy in each group.

Table 6-11 Cont'd

Best Estimate Neutron Energy Spectrum at the
Center of Surveillance Capsules

Capsule Z					
<u>Group #</u>	<u>Energy (MeV)</u>	<u>Flux (n/cm²-sec)</u>	<u>Group #</u>	<u>Energy (MeV)</u>	<u>Flux (n/cm²-sec)</u>
1	1.73E+01	8.91E+06	28	9.12E-03	2.49E+10
2	1.49E+01	1.94E+07	29	5.53E-03	2.58E+10
3	1.35E+01	7.34E+07	30	3.36E-03	8.31E+09
4	1.16E+01	2.04E+08	31	2.84E-03	8.10E+09
5	1.00E+01	4.68E+08	32	2.40E-03	7.98E+09
6	8.61E+00	8.22E+08	33	2.04E-03	2.39E+10
7	7.41E+00	1.99E+09	34	1.23E-03	2.41E+10
8	6.07E+00	3.02E+09	35	7.49E-04	2.34E+10
9	4.97E+00	6.17E+09	36	4.54E-04	1.73E+10
10	3.68E+00	7.17E+09	37	2.75E-04	1.89E+10
11	2.87E+00	1.37E+10	38	1.67E-04	1.91E+10
12	2.23E+00	1.85E+10	39	1.01E-04	2.04E+10
13	1.74E+00	2.55E+10	40	6.14E-05	2.05E+10
14	1.35E+00	2.95E+10	41	3.73E-05	2.00E+10
15	1.11E+00	5.59E+10	42	2.26E-05	1.92E+10
16	8.21E-01	6.09E+10	43	1.37E-05	1.84E+10
17	6.39E-01	7.17E+10	44	8.32E-06	1.70E+10
18	4.98E-01	4.74E+10	45	5.04E-06	1.49E+10
19	3.88E-01	7.77E+10	46	3.06E-06	1.34E+10
20	3.02E-01	7.64E+10	47	1.86E-06	1.19E+10
21	1.83E-01	8.43E+10	48	1.13E-06	6.95E+09
22	1.11E-01	4.78E+10	49	6.83E-07	8.23E+09
23	6.74E-02	4.73E+10	50	4.14E-07	1.31E+10
24	4.09E-02	2.32E+10	51	2.51E-07	1.36E+10
25	2.55E-02	2.94E+10	52	1.52E-07	1.35E+10
26	1.99E-02	1.17E+10	53	9.24E-08	4.25E+10
27	1.50E-02	2.25E+10			

Note: Tabulated energy levels represent the upper energy in each group.

Table 6-12

Comparison of Calculated and Best Estimate Integrated Neutron Exposure of Farley Unit 2 Surveillance Capsules U, W, X, and Z

CAPSULE U

	<u>Calculated</u>	<u>Best Estimate</u>	<u>BE/C</u>
$\Phi(E > 1.0 \text{ MeV}) \text{ [n/cm}^2\text{]}$	6.44E+18	5.58E+18	0.87
$\Phi(E > 0.1 \text{ MeV}) \text{ [n/cm}^2\text{]}$	3.15E+19	3.00E+19	0.95
dpa	1.30E-02	1.21E-02	0.93

CAPSULE W

	<u>Calculated</u>	<u>Best Estimate</u>	<u>BE/C</u>
$\Phi(E > 1.0 \text{ MeV}) \text{ [n/cm}^2\text{]}$	1.85E+19	1.51E+19	0.81
$\Phi(E > 0.1 \text{ MeV}) \text{ [n/cm}^2\text{]}$	8.70E+19	7.73E+19	0.89
dpa	3.66E-02	3.17E-02	0.87

CAPSULE X

	<u>Calculated</u>	<u>Best Estimate</u>	<u>BE/C</u>
$\Phi(E > 1.0 \text{ MeV}) \text{ [n/cm}^2\text{]}$	3.19E+19	2.50E+19	0.78
$\Phi(E > 0.1 \text{ MeV}) \text{ [n/cm}^2\text{]}$	1.56E+20	1.31E+20	0.84
dpa	6.45E-02	5.32E-02	0.83

CAPSULE Z

	<u>Calculated</u>	<u>Best Estimate</u>	<u>BE/C</u>
$\Phi(E > 1.0 \text{ MeV}) \text{ [n/cm}^2\text{]}$	5.28E+19	5.28E+19	1.00
$\Phi(E > 0.1 \text{ MeV}) \text{ [n/cm}^2\text{]}$	2.48E+20	2.47E+20	1.00
dpa	1.04E-01	1.05E-01	1.01

AVERAGE BE/C RATIOS

	<u>BE/C</u>
$\Phi(E > 1.0 \text{ MeV}) \text{ [n/cm}^2\text{]}$	0.87
$\Phi(E > 0.1 \text{ MeV}) \text{ [n/cm}^2\text{]}$	0.92
dpa	0.91

Table 6-13

Azimuthal Variations of the Neutron Exposure Projections
on the Reactor Vessel Clad/Base Metal Interface at the Core Midplane

Best Estimate

	<u>0°</u>	<u>15°^[a]</u>	<u>30°^[a]</u>	<u>45°</u>
13.24 EFPY				
E>1.0 MeV (n/cm ²)	1.51E+19	8.83E+18	6.55E+18	4.59E+18
E>0.1 MeV (n/cm ²)	4.18E+19	2.28E+19	1.50E+19	1.04E+19
dpa	2.52E-02	1.46E-02	1.05E-02	7.43E-03
20 EFPY				
E>1.0 MeV (n/cm ²)	2.16E+19	1.27E+19	9.48E+18	6.75E+18
E>0.1 MeV (n/cm ²)	5.99E+19	3.28E+19	2.17E+19	1.53E+19
dpa	3.60E-02	2.10E-02	1.52E-02	1.09E-02
36 EFPY				
E>1.0 MeV (n/cm ²)	3.71E+19	2.19E+19	1.64E+19	1.19E+19
E>0.1 MeV (n/cm ²)	1.03E+20	5.65E+19	3.75E+19	2.68E+19
dpa	6.18E-02	3.61E-02	2.64E-02	1.92E-02
54 EFPY				
E>1.0 MeV (n/cm ²)	5.44E+19	3.21E+19	2.42E+19	1.76E+19
E>0.1 MeV (n/cm ²)	1.51E+20	8.31E+19	5.54E+19	3.98E+19
dpa	9.07E-02	5.31E-02	3.89E-02	2.85E-02

Note:

- a) Maximum neutron exposure projection reported for 15° and 30° vessel location representing the octant containing the 15° neutron pad span.

Table 6-13, cont'd

Azimuthal Variations of the Neutron Exposure Projections
on the Reactor Vessel Clad/Base Metal Interface at the Core Midplane

Calculated				
	<u>0°</u>	<u>15°^[a]</u>	<u>30°^[a]</u>	<u>45°</u>
13.24 EPFY				
E>1.0 MeV (n/cm ²)	1.75E+19	1.02E+19	7.56E+18	5.30E+18
E>0.1 MeV (n/cm ²)	4.56E+19	2.48E+19	1.63E+19	1.13E+19
dpa	2.78E-02	1.61E-02	1.16E-02	8.21E-03
20 EPFY				
E>1.0 MeV (n/cm ²)	2.50E+19	1.47E+19	1.10E+19	7.80E+18
E>0.1 MeV (n/cm ²)	6.52E+19	3.57E+19	2.36E+19	1.66E+19
dpa	3.98E-02	2.31E-02	1.68E-02	1.21E-02
36 EPFY				
E>1.0 MeV (n/cm ²)	4.28E+19	2.52E+19	1.90E+19	1.37E+19
E>0.1 MeV (n/cm ²)	1.12E+20	6.15E+19	4.09E+19	2.92E+19
dpa	6.82E-02	3.98E-02	2.91E-02	2.12E-02
54 EPFY				
E>1.0 MeV (n/cm ²)	6.29E+19	3.71E+19	2.80E+19	2.04E+19
E>0.1 MeV (n/cm ²)	1.64E+20	9.05E+19	6.03E+19	4.34E+19
dpa	1.00E-01	5.86E-02	4.30E-02	3.15E-02

Note:

- a) Maximum neutron exposure projection reported for 15° and 30° vessel location representing the octant containing the 15° neutron pad span.

Table 6-14

Neutron Exposure Values within the
Farley Unit 2 Reactor Vessel

Best Estimate Fluence (n/cm²) Based on E > 1.0 MeV Slope

	<u>0°</u>	<u>15°^[a]</u>	<u>30°^[a]</u>	<u>45°</u>
20 EFPY				
Surface	2.16E+19	1.27E+19	9.48E+18	6.75E+18
1/4 T	1.27E+19	7.63E+18	5.66E+18	4.06E+18
3/4 T	6.46E+18	4.00E+18	2.95E+18	2.13E+18
36 EFPY				
Surface	3.71E+19	2.19E+19	1.64E+19	1.19E+19
1/4 T	2.17E+19	1.31E+19	9.81E+18	7.13E+18
3/4 T	1.11E+19	6.89E+18	5.11E+18	3.74E+18
54 EFPY				
Surface	5.44E+19	3.21E+19	2.42E+19	1.76E+19
1/4 T	3.18E+19	1.93E+19	1.45E+19	1.06E+19
3/4 T	1.63E+19	1.01E+19	7.54E+18	5.55E+18

Best Estimate Fluence (n/cm²) Based on dpa Slope

	<u>0°</u>	<u>15°^[a]</u>	<u>30°^[a]</u>	<u>45°</u>
20 EFPY				
Surface	2.16E+19	1.27E+19	9.48E+18	6.75E+18
1/4 T	1.45E+19	8.72E+18	6.31E+18	4.52E+18
3/4 T	9.11E+18	5.63E+18	3.95E+18	2.85E+18
36 EFPY				
Surface	3.71E+19	2.19E+19	1.64E+19	1.19E+19
1/4 T	2.48E+19	1.50E+19	1.09E+19	7.94E+18
3/4 T	1.56E+19	9.68E+18	6.84E+18	5.00E+18
54 EFPY				
Surface	5.44E+19	3.21E+19	2.42E+19	1.76E+19
1/4 T	3.64E+19	2.21E+19	1.61E+19	1.18E+19
3/4 T	2.29E+19	1.42E+19	1.01E+19	7.43E+18

Note:

- a) Maximum neutron exposure projection reported for 15° and 30° vessel location representing the octant containing the 15° neutron pad span.

Table 6-14, cont'd

Neutron Exposure Values within the
Farley Unit 2 Reactor Vessel

Calculated Fluence (n/cm^2) Based on $E > 1.0$ MeV Slope

	<u>0°</u>	<u>15°^[a]</u>	<u>30°^[a]</u>	<u>45°</u>
20 EFPY				
Surface	2.50E+19	1.47E+19	1.10E+19	7.80E+18
1/4 T	1.46E+19	8.81E+18	6.54E+18	4.69E+18
3/4 T	7.47E+18	4.63E+18	3.41E+18	2.46E+18
36 EFPY				
Surface	4.28E+19	2.52E+19	1.90E+19	1.37E+19
1/4 T	2.51E+19	1.52E+19	1.13E+19	8.23E+18
3/4 T	1.28E+19	7.96E+18	5.90E+18	4.32E+18
54 EFPY				
Surface	6.29E+19	3.71E+19	2.80E+19	2.04E+19
1/4 T	3.68E+19	2.23E+19	1.67E+19	1.22E+19
3/4 T	1.88E+19	1.17E+19	8.71E+18	6.41E+18

Calculated Fluence (n/cm^2) Based on dpa Slope

	<u>0°</u>	<u>15°^[a]</u>	<u>30°^[a]</u>	<u>45°</u>
20 EFPY				
Surface	2.50E+19	1.47E+19	1.10E+19	7.80E+18
1/4 T	1.67E+19	1.01E+19	7.29E+18	5.22E+18
3/4 T	1.05E+19	6.50E+18	4.56E+18	3.29E+18
36 EFPY				
Surface	4.28E+19	2.52E+19	1.90E+19	1.37E+19
1/4 T	2.87E+19	1.73E+19	1.26E+19	9.17E+18
3/4 T	1.80E+19	1.12E+19	7.90E+18	5.78E+18
54 EFPY				
Surface	6.29E+19	3.71E+19	2.80E+19	2.04E+19
1/4 T	4.21E+19	2.55E+19	1.86E+19	1.36E+19
3/4 T	2.65E+19	1.65E+19	1.17E+19	8.58E+18

Note:

- a) Maximum neutron exposure projection reported for 15° and 30° vessel location representing the octant containing the 15° neutron pad span.

Table 6-15

Updated Lead Factors for the J. M. Farley Unit 2
Surveillance Capsules

<u>Capsule</u>	<u>Lead Factor</u>
U ^[a]	3.31
W ^[b]	2.86
X ^[c]	3.41
Z ^[d]	3.03
V ^[e]	3.47
Y ^[e]	3.03

- [a] - Withdrawn at the end of Cycle 1.
 [b] - Withdrawn at the end of Cycle 4.
 [c] - Withdrawn at the end of Cycle 6.
 [d] - Withdrawn at the end of Cycle 12.
 [e] - Not withdrawn; on standby.

The surveillance capsule lead factor is defined by:

$$\frac{\Phi_{\text{Surveillance Capsule Calculated}}}{\Phi_{\text{Clad / Base Metal Interface Axial Peak Calculated}}}$$

where Φ is the neutron fluence ($E > 1.0$ MeV) at the time of the capsule withdrawal. In the case of the standby capsules, the neutron fluence is at the time of the latest withdrawn capsule.

7 SURVEILLANCE CAPSULE REMOVAL SCHEDULE

The following surveillance capsule removal schedule meets the requirements of ASTM E185-82 and is recommended for future capsules to be removed from the J. M. Farley Unit 2 reactor vessel. This recommended removal schedule is applicable to 36 EFPY of operation.

Capsule	Location	Lead Factor ^(a)	Removal Time (EFPY) ^(b)	Fluence (n/cm ² , E>1.0 MeV) ^(a)
U	343°	3.31	1.10	6.44 x 10 ¹⁸ (c)
W	110°	2.86	3.97	1.85 x 10 ¹⁹ (c)
X	287°	3.41	6.41	3.19 x 10 ¹⁹ (c)
Z	340°	3.03	13.24	5.28 x 10 ¹⁹ (c,d)
V	107°	3.47	Standby	(e)
Y	290°	3.03	Standby	(e)

Notes:

- (a) Updated in Capsule Z dosimetry analysis, see Section 6 of this report.
- (b) Effective Full Power Years (EFPY) from plant startup.
- (c) Plant specific evaluation.
- (d) This fluence is not less than once or greater than twice the peak end of license (36 EFPY) fluence of 4.28 x 10¹⁹ n/cm².
- (e) Capsules V and Y will reach a fluence of 6.29 x 10¹⁹ (E > 1.0 MeV), the 54 EFPY peak vessel fluence at approximately 13.8 and 16.2 EFPY, respectively. Per ASTM E185-82, these capsules may be held without testing following withdrawal.

8 REFERENCES


1. WCAP-8956, *Alabama Power Company Joseph M. Farley Nuclear Plant Unit No. 2 Reactor Vessel Radiation Surveillance Program*, J. A. Davidson, et. al., August, 1977.
2. WCAP-10425, *Analysis of Capsule U from the Alabama Power Company Joseph M. Farley Unit 2 Reactor Vessel Radiation Surveillance Program*, M. K. Kunka, et. al., October, 1983.
3. WCAP-11438, *Analysis of Capsule W from the Alabama Power Company Joseph M. Farley Unit 2 Reactor Vessel Radiation Surveillance Program*, R. P. Shogan, et. al., April, 1987.
4. WCAP-12471, *Analysis of Capsule X from the Alabama Power Company Joseph M. Farley Unit 2 Reactor Vessel Radiation Surveillance Program*, E. Terek, et. al., December, 1989.
5. Regulatory Guide 1.99, Revision 2, May 1988, *Radiation Embrittlement of Reactor Vessel Materials*.
6. Code of Federal Regulations, 10CFR50, Appendix G, *Fracture Toughness Requirements*, U.S. Nuclear Regulatory Commission, Washington, D.C.
7. ASTM E185-73, American National Standard N146, American National Standards Institute, *Standard Recommended Practice for Surveillance Tests for Nuclear Reactor Vessels*.
8. Section XI of the ASME Boiler and Pressure Vessel Code, Appendix G, *Fracture Toughness Criteria for Protection Against Failure*.
9. ASTM E208, *Standard Test Method for Conducting Drop-Weight Test to Determine Nil-Ductility Transition Temperature of Ferritic Steels*, in ASTM Standards, Section 3, American Society for Testing and Materials, Philadelphia, PA.
10. Code of Federal Regulations, 10CFR50, Appendix H, *Reactor Vessel Material Surveillance Program Requirements*, U.S. Nuclear Regulatory Commission, Washington, D.C.
11. ASTM E185-82, Annual Book of ASTM Standards, Section 12, Volume 12.02, *Standard Practice for Conducting Surveillance Tests for Light-Water Cooled Nuclear Power Reactor Vessels*.
12. ASTM E23-93a, *Standard Test Methods for Notched Bar Impact Testing of Metallic Materials*, in ASTM Standards, Section 3, American Society for Testing and Materials, Philadelphia, PA, 1993.
13. ASTM A370-92, *Standard Test Methods and Definitions for Mechanical Testing of Steel Products*, in ASTM Standards, Section 3, American Society for Testing and Materials, Philadelphia, PA, 1993.
14. ASTM E8-93, *Standard Test Methods for Tension Testing of Metallic Materials*, in ASTM Standards, Section 3, American Society for Testing and Materials, Philadelphia, PA, 1993.
15. ASTM E21-92, *Standard Test Methods for Elevated Temperature Tension Tests of Metallic Materials*, in ASTM Standards, Section 3, American Society for Testing and Materials, Philadelphia, PA, 1993.

16. ASTM E83-93, *Standard Practice for Verification and Classification of Extensometers*, in ASTM Standards, Section 3, American Society for Testing and Materials, Philadelphia, PA, 1993.
17. RSICC Computer Code Collection CCC-650, *DOORS 3.1, One, Two- and Three-Dimensional Discrete Ordinates Neutron/Photon Transport Code System*, August 1996.
18. RSICC Data Library Collection DLC-185, *BUGLE-96, Coupled 47 Neutron, 20 Gamma-Ray Group Cross Section Library Derived from ENDF/B-VI for LWR Shielding and Pressure Vessel Dosimetry Applications*, March 1996.
19. E. Maerker, et al., *Accounting for Changing Source Distributions in Light Water Reactor Surveillance Dosimetry Analysis*, Nuclear Science and Engineering, Volume 94, Pages 291-308, 1986.
20. *The Nuclear Design of the Joseph M. Farley Unit 2 Power Plant - Cycle 1*, WCAP-9710, May 1980. [W Proprietary Class 2]
21. *The Nuclear Design and Core Management of the Joseph M. Farley Unit 2 Power Plant - Cycle 2*, WCAP-10187, September 1982. [W Proprietary Class 2]
22. *The Nuclear Design and Core Management of the Joseph M. Farley Unit 2 Power Plant - Cycle 3*, WCAP-10410, September 1983. [W Proprietary Class 2]
23. *The Nuclear Design and Core Management of the Joseph M. Farley Unit 2 Power Plant - Cycle 4*, WCAP-10674, November 1984. [W Proprietary Class 2]
24. *The Nuclear Design and Core Management of the Joseph M. Farley Unit 2 Power Plant - Cycle 5*, WCAP-11150, June 1986. [W Proprietary Class 2]
25. *The Nuclear Design and Core Management of the Joseph M. Farley Unit 2 Power Plant - Cycle 7*, WCAP-11542, Rev. 1, November 1987. [W Proprietary Class 2]
26. *The Nuclear Design and Core Management of the Joseph M. Farley Unit 2 Power Plant - Cycle 7*, WCAP-12193, March 1989. [W Proprietary Class 2]
27. *The Nuclear Design and Core Management of the Joseph M. Farley Unit 2 Power Plant - Cycle 8*, WCAP-12704, Rev. 1, November 1990. [W Proprietary Class 2]
28. *The Nuclear Design and Core Management of the Joseph M. Farley Unit 2 Power Plant - Cycle 9*, WCAP-13201, March 1992. [W Proprietary Class 2]
29. *The Nuclear Design and Core Management of the Joseph M. Farley Unit 2 Power Plant - Cycle 10*, WCAP-13842, Rev. 1, December 1993. [W Proprietary Class 2]
30. *The Nuclear Design and Core Management of the Joseph M. Farley Unit 2 Power Plant - Cycle 11*, WCAP-14318, Rev. 1, May 1995. [W Proprietary Class 2]

31. *The Nuclear Design and Core Management of the Joseph M. Farley Unit 2 Power Plant - Cycle 12*, WCAP-14789, Rev. 0, December 1996. [W Proprietary Class 2]
32. *The Nuclear Design and Core Management of the Joseph M. Farley Unit 2 Power Plant - Cycle 13*, WCAP-15035, Rev. 0, April 1998. [W Proprietary Class 2]
33. Southern Nuclear Company (R. W. Clouse) transmittal to Westinghouse (J. Perock) containing selected Farley Unit 2 operating plant history data, December 15, 1998.
34. ASTM Designation E482-89 (Re-approved 1996), *Standard Guide for Application of Neutron Transport Methods for Reactor Vessel Surveillance*, in ASTM Standards, Section 12, American Society for Testing and Materials, Philadelphia, PA, 1998.
35. ASTM Designation E560-84 (Re-approved 1996), *Standard Recommended Practice for Extrapolating Reactor Vessel Surveillance Dosimetry Results*, in ASTM Standards, Section 12, American Society for Testing and Materials, Philadelphia, PA, 1998.
36. ASTM Designation E693-94, *Standard Practice for Characterizing Neutron Exposures in Iron and Low Alloy Steels in Terms of Displacements per Atom (dpa)*, in ASTM Standards, Section 12, American Society for Testing and Materials, Philadelphia, PA, 1998.
37. ASTM Designation E706-87 (Re-approved 1994), *Standard Master Matrix for Light-Water Reactor Pressure Vessel Surveillance Standard*, in ASTM Standards, Section 12, American Society for Testing and Materials, Philadelphia, PA, 1998.
38. ASTM Designation E853-87 (Re-approved 1995), *Standard Practice for Analysis and Interpretation of Light-Water Reactor Surveillance Results*, in ASTM Standards, Section 12, American Society for Testing and Materials, Philadelphia, PA, 1998.
39. ASTM Designation E261-98, *Standard Practice for Determining Neutron Fluence Rate, Fluence, and Spectra by Radioactivation Techniques*, in ASTM Standards, Section 12, American Society for Testing and Materials, Philadelphia, PA, 1997.
40. ASTM Designation E262-97, *Standard Method for Determining Thermal Neutron Reaction and Fluence Rates by Radioactivation Techniques*, in ASTM Standards, Section 12, American Society for Testing and Materials, Philadelphia, PA, 1998.
41. ASTM Designation E263-93, *Standard Method for Measuring Fast-Neutron Reaction Rates by Radioactivation of Iron*, in ASTM Standards, Section 12, American Society for Testing and Materials, Philadelphia, PA, 1998.
42. ASTM Designation E264-92 (Re-approved 1996), *Standard Method for Measuring Fast-Neutron Reaction Rates by Radioactivation of Nickel*, in ASTM Standards, Section 12, American Society for Testing and Materials, Philadelphia, PA, 1998.

-
43. ASTM Designation E481-97, *Standard Method for Measuring Neutron-Fluence Rate by Radioactivation of Cobalt and Silver*, in ASTM Standards, Section 12, American Society for Testing and Materials, Philadelphia, PA, 1998.
 44. ASTM Designation E523-92 (Re-approved 1996), *Standard Test Method for Measuring Fast-Neutron Reaction Rates by Radioactivation of Copper*, in ASTM Standards, Section 12, American Society for Testing and Materials, Philadelphia, PA, 1998.
 45. ASTM Designation E704-96, *Standard Test Method for Measuring Reaction Rates by Radioactivation of Uranium-238*, in ASTM Standards, Section 12, American Society for Testing and Materials, Philadelphia, PA, 1998.
 46. ASTM Designation E705-96, *Standard Test Method for Measuring Reaction Rates by Radioactivation of Neptunium-237*, in ASTM Standards, Section 12, American Society for Testing and Materials, Philadelphia, PA, 1998.
 47. ASTM Designation E1005-97, *Standard Test Method for Application and Analysis of Radiometric Monitors for Reactor Vessel Surveillance*, in ASTM Standards, Section 12, American Society for Testing and Materials, Philadelphia, PA, 1998.
 48. A. Schmittroth, *FERRET Data Analysis Core*, HEDL-TME 79-40, Hanford Engineering Development Laboratory, Richland, WA, September 1979.
 49. N. McElroy, S. Berg and T. Crocket, *A Computer-Automated Iterative Method of Neutron Flux Spectra Determined by Foil Activation*, AFWL-TR-7-41, Vol. I-IV, Air Force Weapons Laboratory, Kirkland AFB, NM, July 1967.
 50. RSIC Data Library Collection DLC-178, "SNLRML Recommended Dosimetry Cross-Section Compendium", July 1994.
 51. EPRI-NP-2188, *Development and Demonstration of an Advanced Methodology for LWR Dosimetry Applications*, R. E. Maerker, et al., 1981.

APPENDIX A
LOAD-TIME RECORDS FOR CHARPY
SPECIMEN TESTS



W_I = Fracture Initiation Region
 W_P = Fracture Propagation Region

t_{GY} = Time to General Yielding
 t_M = Time to Maximum Load
 t_F = Time to Fast (Brittle) Fracture Start




Figure A. 1 Specimen CL81




Figure A. 2 Specimen CL80




Figure A. 3 Specimen CL90




Figure A. 4 Specimen CL79




Figure A. 5 Specimen CL77




Figure A. 6 Specimen CL84




Figure A. 7 Specimen CL85




Figure A. 8 Specimen CL86




Figure A. 9 Specimen CL78




Figure A. 10 Specimen CL83




Figure A. 11 Specimen CL89




Figure A. 12 Specimen CL87




Figure A. 13 Specimen CL82




Figure A. 14 Specimen CL76




Figure A. 15 Specimen CL88




Figure A. 16 Specimen CT84




Figure A. 17 Specimen CT87




Figure A. 18 Specimen CT90




Figure A. 19 Specimen CT83




Figure A. 20 Specimen CT77




Figure A. 21 Specimen CT80




Figure A. 22 Specimen CT89




Figure A. 23 Specimen CT88




Figure A. 24 Specimen CT79




Figure A. 25 Specimen CT82




Figure A. 26 Specimen CT81




Figure A. 27 Specimen CT86




Figure A. 28 Specimen CT78




Figure A. 29 Specimen CT76




Figure A. 30 Specimen CT85




Figure A. 31 Specimen CW81




Figure A. 32 Specimen CW88

Data missing

Figure A. 33 Specimen CW76




Figure A. 34 Specimen CW78




Figure A. 35 Specimen CW89




Figure A. 36 Specimen CW90




Figure A. 37 Specimen CW79




Figure A. 38 Specimen CW85




Figure A. 39 Specimen CW83




Figure A. 40 Specimen CW87




Figure A. 41 Specimen CW77




Figure A. 42 Specimen CW86




Figure A. 43 Specimen CW84




Figure A. 44 Specimen CW80




Figure A. 45 Specimen CW82




Figure A. 46 Specimen CH90




Figure A. 47 Specimen CH82




Figure A. 48 Specimen CH77




Figure A. 49 Specimen CH83




Figure A. 50 Specimen CH86




Figure A. 51 Specimen CH85




Figure A. 52 Specimen CH76




Figure A. 53 Specimen CH78




Figure A. 54 Specimen CH87




Figure A. 55 Specimen CH80




Figure A. 56 Specimen CH89




Figure A. 57 Specimen CH88




Figure A. 58 Specimen CH84




Figure A. 59 Specimen CH79




Figure A. 60 Specimen CH81

APPENDIX B

CHARPY V-NOTCH SHIFT RESULTS FOR EACH CAPSULE HAND-DRAWN VS. HYPERBOLIC TANGENT CURVE-FITTING METHOD (CVGRAPH VERSION 4.1)

NOTE:

**The CVGRAPH Charpy V-notch results given in this Appendix were developed by
fixing the lower and upper shelf energy values to those given on page C-1 of
Appendix C to this report.**

TABLE B-1

Changes in Average 30 ft-lb Temperatures for Intermediate Shell
 Plate B7212-1 (Longitudinal Orientation)
 Hand Fit vs. CVGRAPH 4.1

Capsule	Unirradiated	Hand Fit	ΔT_{30}	Unirradiated	CVGRAPH Fit	ΔT_{30}
U	-23°F	120°F	133°F	- 22.65°F	83.14°F	105.79°F
W	-23°F	142°F	165°F	- 22.65°F	145.4°F	168.05°F
X	-23°F	157°F	180°F	- 22.65°F	142.21°F	164.86°F
Z	--	--	--	- 22.65°F	177.59°F	200.24°F

TABLE B-2

Changes in Average 50 ft-lb Temperatures for Intermediate Shell
 Plate B7212-1 (Longitudinal Orientation)
 Hand Fit vs. CVGRAPH 4.1

Capsule	Unirradiated	Hand Fit	ΔT_{50}	Unirradiated	CVGRAPH Fit	ΔT_{50}
U	8°F	143°F	135°F	9.87°F	140.89°F	131.02°F
W	8°F	198°F	190°F	9.87°F	185.48°F	175.61°F
X	8°F	208°F	200°F	9.87°F	186.24°F	176.37°F
Z	8°F	--	--	9.87°F	208.74°F	198.87°F

TABLE B-3

Changes in Average 35 mil Lateral Expansion Temperatures for Intermediate Shell
Plate B7212-1 (Longitudinal Orientation)
Hand Fit vs. CVGRAPH 4.1

Capsule	Unirradiated	Hand Fit	ΔT_{35}	Unirradiated	CVGRAPH Fit	ΔT_{35}
U	- 10°F	118°F	128°F	1.6°F	122.2°F	120.6°F
W	- 10°F	175°F	185°F	1.6°F	167.6°F	166.0°F
X	- 10°F	175°F	185°F	1.6°F	183.0°F	181.4°F
Z	- 10°F	--	--	1.6°F	212.3°F	210.7°F

TABLE B-4

Changes in Average Energy Absorption at Full Shear for Intermediate
Shell Plate B7212-1 (Longitudinal Orientation)
Hand Fit vs. CVGRAPH 4.1

Capsule	Unirradiated	Hand Fit	ΔE	Unirradiated	CVGRAPH Fit	ΔE
U	130 ft-lb	94 ft-lb	- 36 ft-lb	130 ft-lb	94 ft-lb	- 36 ft-lb
W	130 ft-lb	102 ft-lb	- 28 ft-lb	130 ft-lb	102 ft-lb	- 28 ft-lb
X	130 ft-lb	94 ft-lb	- 36 ft-lb	130 ft-lb	96 ft-lb	- 34 ft-lb
Z	130 ft-lb	--	--	130 ft-lb	94 ft-lb	- 36 ft-lb

TABLE B-5

Changes in Average 30 ft-lb Temperatures for Intermediate Shell
 Plate B7212-1 (Transverse Orientation)
 Hand Fit vs. CVGRAPH 4.1

Capsule	Unirradiated	Hand Fit	ΔT_{30}	Unirradiated	CVGRAPH Fit	ΔT_{30}
U	- 13°F	120°F	133°F	- 7.44°F	116.56°F	124.01°F
W	- 13°F	152°F	165°F	- 7.44°F	160.74°F	168.18°F
X	- 13°F	177°F	190°F	- 7.44°F	192.57°F	200.01°F
Z	- 13°F	--	--	- 7.44°F	188.06°F	195.5°F

TABLE B-6

Changes in Average 50 ft-lb Temperatures for Intermediate Shell
 Plate B7212-1 (Transverse Orientation)
 Hand Fit vs. CVGRAPH 4.1

Capsule	Unirradiated	Hand Fit	ΔT_{50}	Unirradiated	CVGRAPH Fit	ΔT_{50}
U	8°F	143°F	135°F	33.66°F	181.83°F	148.17°F
W	8°F	198°F	190°F	33.66°F	218.29°F	184.62°F
X	8°F	208°F	200°F	33.66°F	222.03°F	188.36°F
Z	8°F	--	--	33.66°F	231.12°F	197.45°F

TABLE B-7

Changes in Average 35 mil Lateral Expansion Temperatures for Intermediate Shell
Plate B7212-1 (Transverse Orientation)
Hand Fit vs. CVGRAPH 4.1

Capsule	Unirradiated	Hand Fit	ΔT_{35}	Unirradiated	CVGRAPH Fit	ΔT_{35}
U	32°F	160°F	128°F	27.2°F	146.5°F	119.3°F
W	32°F	190°F	158°F	27.2°F	182.2°F	155.0°F
X	32°F	222°F	190°F	27.2°F	214.4°F	187.2°F
Z	32°F	--	--	27.2°F	225.6°F	198.4°F

TABLE B-8

Changes in Average Energy Absorption at Full Shear for Intermediate Shell
Plate B7212-1 (Transverse Orientation)
Hand Fit vs. CVGRAPH 4.1

Capsule	Unirradiated	Hand Fit	ΔE	Unirradiated	CVGRAPH Fit	ΔE
U	95 ft-lb	69 ft-lb	- 26 ft-lb	95 ft-lb	69 ft-lb	- 26 ft-lb
W	95 ft-lb	76 ft-lb	- 19 ft-lb	95 ft-lb	76 ft-lb	- 19 ft-lb
X	95 ft-lb	69 ft-lb	- 26 ft-lb	95 ft-lb	69 ft-lb	- 26 ft-lb
Z	95 ft-lb	--	--	95 ft-lb	68 ft-lb	- 27 ft-lb

TABLE B-9

Changes in Average 30 ft-lb Temperatures for the Surveillance Weld Material
Hand Fit vs. CVGRAPH 4.1

Capsule	Unirradiated	Hand Fit	ΔT_{30}	Unirradiated	CVGRAPH Fit	ΔT_{30}
U	- 30°F	- 20°F	10°F	- 34.7°F	- 63.4°F	- 28.7°F
W	- 30°F	- 20°F	10°F	- 34.7°F	- 28.0°F	6.7°F
X	- 30°F	- 20°F	10°F	- 34.7°F	- 50.0°F	- 15.3°F
Z	- 30°F	--	--	- 34.7°F	- 24.7°F	10.0°F

TABLE B-10

Changes in Average 50 ft-lb Temperatures for the Surveillance Weld Material
Hand Fit vs. CVGRAPH 4.1

Capsule	Unirradiated	Hand Fit	ΔT_{50}	Unirradiated	CVGRAPH Fit	ΔT_{50}
U	- 1°F	9°F	10°F	- 15.6°F	- 26.9°F	- 11.3°F
W	- 1°F	9°F	10°F	- 15.6°F	- 3.6°F	12.0°F
X	- 1°F	9°F	10°F	- 15.6°F	- 17.8°F	- 2.2°F
Z	- 1°F	--	--	- 15.6°F	- 1.4°F	14.2°F

TABLE B-11

Changes in Average 35 mil Lateral Expansion Temperatures for the
Surveillance Weld Material
Hand Fit vs. CVGRAPH 4.1

Capsule	Unirradiated	Hand Fit	ΔT_{35}	Unirradiated	CVGRAPH Fit	ΔT_{35}
U	- 20°F	- 17°F	3°F	- 23.0°F	- 44.1°F	- 21.1°F
W	- 20°F	- 10°F	10°F	- 23.0°F	- 18.7°F	4.3°F
X	- 20°F	- 10°F	10°F	- 23.0°F	- 29.9°F	- 6.9°F
Z	- 20°F	--	--	- 23.0°F	- 0.5°F	22.5°F

TABLE B-12

Changes in Average Energy Absorption at Full Shear for the
Surveillance Weld Material
Hand Fit vs. CVGRAPH 4.1

Capsule	Unirradiated	Hand Fit	ΔE	Unirradiated	CVGRAPH Fit	ΔE
U	144 ft-lb	132 ft-lb	- 12 ft-lb	144 ft-lb	132 ft-lb	- 12 ft-lb
W	144 ft-lb	144 ft-lb	0 ft-lb	144 ft-lb	144 ft-lb	0 ft-lb
X	144 ft-lb	144 ft-lb	0 ft-lb	144 ft-lb	150 ft-lb	6 ft-lb
Z	144 ft-lb	--	--	144 ft-lb	133 ft-lb	- 11 ft-lb

TABLE B-13

Changes in Average 30 ft-lb Temperatures for the Weld Heat-Affected-Zone Material
Hand Fit vs. CVGRAPH 4.1

Capsule	Unirradiated	Hand Fit	ΔT_{30}	Unirradiated	CVGRAPH Fit	ΔT_{30}
U	- 131°F	- 73°F	58°F	- 175.4°F	- 76.5°F	98.9°F
W	- 131°F	- 22°F	109°F	- 175.4°F	- 27.7°F	147.7°F
X	- 131°F	- 21°F	110°F	- 175.4°F	- 65.8°F	109.6°F
Z	- 131°F	--	--	- 175.4°F	- 32.8°F	142.6°F

TABLE B-14

Changes in Average 50 ft-lb Temperatures for the Weld Heat-Affected-Zone Material
Hand Fit vs. CVGRAPH 4.1

Capsule	Unirradiated	Hand Fit	ΔT_{50}	Unirradiated	CVGRAPH Fit	ΔT_{50}
U	- 83°F	- 33°F	50°F	- 116.8°F	- 44.6°F	72.2°F
W	- 83°F	0°F	83°F	- 116.8°F	- 16.2°F	100.6°F
X	- 83°F	12°F	95°F	- 116.8°F	- 39.9°F	76.9°F
Z	- 83°F	--	--	- 116.8°F	- 3.2°F	113.6°F

TABLE B-15

Changes in Average 35 mil Lateral Expansion Temperatures for the Weld
Heat-Affected-Zone Material
Hand Fit vs. CVGRAPH 4.1

Capsule	Unirradiated	Hand Fit	ΔT_{35}	Unirradiated	CVGRAPH Fit	ΔT_{35}
U	- 91°F	- 38°F	53°F	- 111.3°F	- 59.6°F	51.7°F
W	- 91°F	- 5°F	86°F	- 111.3°F	- 20.3°F	91.0°F
X	- 91°F	- 5°F	86°F	- 111.3°F	- 36.8°F	74.5°F
Z	- 91°F	--	--	- 111.3°F	5.1°F	116.4°F

TABLE B-16

Changes in Average Energy Absorption at Full Shear for the Weld
Heat-Affected-Zone Material
Hand Fit vs. CVGRAPH 4.1

Capsule	Unirradiated	Hand Fit	ΔE	Unirradiated	CVGRAPH Fit	ΔE
U	158 ft-lb	111 ft-lb	- 47 ft-lb	158 ft-lb	111 ft-lb	- 47 ft-lb
W	158 ft-lb	126 ft-lb	- 32 ft-lb	158 ft-lb	126 ft-lb	- 32 ft-lb
X	158 ft-lb	126 ft-lb	- 32 ft-lb	158 ft-lb	128 ft-lb	- 30 ft-lb
Z	158 ft-lb	--	--	158 ft-lb	126 ft-lb	- 32 ft-lb

APPENDIX C

CHARPY V-NOTCH PLOTS FOR EACH CAPSULE
USING HYPERBOLIC TANGENT
CURVE-FITTING METHOD

Contained in Table C-1 are the upper shelf energy values used as input for the generation of the Charpy V-notch plots using CVGRAPH, Version 4.1. Lower shelf energy values were fixed at 2.2 ft-lb. The unirradiated and irradiated upper shelf energy values were calculated per the ASTM E185-82 definition of upper shelf energy, "the average energy value for all Charpy specimens (normally three) whose test temperature is above the upper end of the transition region. For specimens tested in sets of three at each test temperature, the set having the highest average may be regarded as defining the upper shelf energy."

Material	Unirradiated	Capsule U	Capsule W	Capsule X	Capsule Z
Inter. Shell Plate B7212-1 (Longitudinal Orientation)	130 ft-lb	94 ft-lb	102 ft-lb	96 ft-lb	94 ft-lb
Inter. Shell Plate B7212-1 (Transverse Orientation)	95 ft-lb	69 ft-lb	76 ft-lb	69 ft-lb	68 ft-lb
Weld Metal (Heat # BOLA)	144 ft-lb	132 ft-lb	144 ft-lb	150 ft-lb	133 ft-lb
HAZ Material	158 ft-lb	111 ft-lb	126 ft-lb	128 ft-lb	126 ft-lb

UNIRRADIATED

CVGRAPH 4.1 Hyperbolic Tangent Curve Printed at 09:58:53 on 02-22-2000

Page 1

Coefficients of Curve 1


A = 66.19	B = 63.99	C = 85.06	T0 = 31.87
-----------	-----------	-----------	------------

Equation is: $CVN = A + B * [\tanh((T - T0)/C)]$

Upper Shelf Energy: 130.19 Fixed Temp. at 30 ft-lbs: -22.6 Temp. at 50 ft-lbs: 9.8 Lower Shelf Energy: 2.19 Fixed

Material: PLATE SA533B1 Heat Number: B7212-1 Orientation: LT

Capsule: UNIRR Total Fluence:



Data Set(s) Plotted
 Plant: FA2 Cap: UNIRR Material: PLATE SA533B1 Ori: LT Heat #: B7212-1

Charpy V-Notch Data

Temperature	Input CVN Energy	Computed CVN Energy	Differential
-60	12	15.43	-3.43
-50	15	18.49	-3.49
-25	34	28.81	5.18
-25	19	28.81	-9.81
-10	47	37.01	9.98
0	50	43.27	6.72
20	63	57.31	5.68
50	72	79.62	-7.62
60	67	86.61	-19.61

**** Data continued on next page ****

UNIRRADIATED

Page 2

Material: PLATE SA533B1

Heat Number: B7212-1

Orientation: LT

Capsule: UNIRR

Total Fluence:

Charpy V-Notch Data (Continued)

Temperature	Input CVN Energy	Computed CVN Energy	Differential
75	103	96.11	6.88
100	110.5	108.72	1.77
125	123	117.3	5.69
150	132	122.69	9.3
210	132	128.27	3.72
210	134	128.27	5.72
210	130	128.27	1.72
			SUM of RESIDUALS = 18.42

CAPSULE U

CVGRAPH 4.1 Hyperbolic Tangent Curve Printed at 10:05:32 on 02-22-2000

Page 1

Coefficients of Curve 1


A = 48.29	B = 46.1	C = 126.37	T0 = 136.23
-----------	----------	------------	-------------

Equation is: $CVN = A + B * [\tanh((T - T_0)/C)]$

Upper Shelf Energy: 94.4 Fixed Temp. at 30 ft-lbs: 83.1 Temp. at 50 ft-lbs: 140.8 Lower Shelf Energy: 2.19 Fixed

Material: PLATE SA533B1 Heat Number: B7212-1 Orientation: LT

Capsule: U Total Fluence:



Data Set(s) Plotted
 Plant: FA2 Cap.: U Material: PLATE SA533B1 Ori: LT Heat #: B7212-1

Charpy V-Notch Data

Temperature	Input CVN Energy	Computed CVN Energy	Differential
0	13.5	11.76	1.73
50	23.5	20.96	2.53
75	33	27.56	5.43
100	40.5	35.43	5.06
125	42	44.21	-2.21
150	54	53.3	.69
150	46	53.3	-7.3
175	53	62.01	-9.01
200	73.5	69.76	3.73

**** Data continued on next page ****

CAPSULE U

Page 2

Material: PLATE SA533B1

Heat Number: B7212-1

Orientation: LT

Capsule: U Total Fluence:

Charpy V-Notch Data (Continued)

Temperature	Input CVN Energy	Computed CVN Energy	Differential
200	55	69.76	-14.76
225	88.5	76.23	12.26
250	90	81.32	8.67
300	91.5	87.97	3.52
350	98.5	91.37	7.12
400	97.5	93	4.49
			SUM of RESIDUALS = 21.98

CAPSULE W

CVGRAPH 4.1 Hyperbolic Tangent Curve Printed at 10:18:33 on 02-22-2000

Page 1

Coefficients of Curve 1


A = 52.09	B = 49.9	C = 92.4	T0 = 189.37
-----------	----------	----------	-------------

Equation is: $CVN = A + B * [\tanh((T - T_0)/C)]$

Upper Shelf Energy: 102 Fixed Temp. at 30 ft-lbs: 145.4 Temp. at 50 ft-lbs: 185.4 Lower Shelf Energy: 2.19 Fixed

Material: PLATE SA533B1 Heat Number: B7212-1 Orientation: LT

Capsule: W Total Fluence:



Data Set(s) Plotted
 Plant: FA2 Cap: W Material: PLATE SA533B1 Ori: LT Heat #: B7212-1

Charpy V-Notch Data

Temperature	Input CVN Energy	Computed CVN Energy	Differential
0	6	3.82	2.17
73	26	9.63	16.36
100	34	14.8	19.19
125	15	22.04	-7.04
150	27	32.03	-5.03
150	40	32.03	7.96
175	38	44.39	-6.39
175	40	44.39	-4.39
200	45	57.81	-12.81

**** Data continued on next page ****

CAPSULE W

Page 2

Material: PLATE SA533B1

Heat Number: B7212-1

Orientation: LT

Capsule: W Total Fluence:

Charpy V-Notch Data (Continued)

Temperature	Input CVN Energy	Computed CVN Energy	Differential
200	49	57.81	-8.81
225	82	70.43	11.56
250	93	80.83	12.16
300	103	93.65	9.34
350	100	99	.99
400	103	100.96	2.03
			SUM of RESIDUALS = 37.28

CAPSULE X

CVGRAPH 4.1 Hyperbolic Tangent Curve Printed at 10:24:09 on 02-22-2000

Page 1

Coefficients of Curve 1


A = 49.25	B = 47.05	C = 97.74	T0 = 184.68
-----------	-----------	-----------	-------------

Equation is: $CVN = A + B * [\tanh((T - T_0)/C)]$

Upper Shelf Energy: 96.3 Fixed Temp. at 30 ft-lbs: 142.2 Temp. at 50 ft-lbs: 186.2 Lower Shelf Energy: 2.19 Fixed

Material: PLATE SA533B1 Heat Number: B7212-1 Orientation: LT

Capsule: X Total Fluence:



Data Set(s) Plotted
 Plant: FA2 Cap: X Material: PLATE SA533B1 Ori: LT Heat #: B7212-1

Charpy V-Notch Data

Temperature	Input CVN Energy	Computed CVN Energy	Differential
0	2	4.3	-2.3
72	19	10.72	8.27
100	28	16.33	11.66
125	22	23.62	-1.62
125	18	23.62	-5.62
150	37	33.21	3.78
150	33	33.21	-21
175	46	44.6	1.39
200	47	56.56	-9.56

**** Data continued on next page ****

CAPSULE X

Page 2

Material: PLATE SA533B1

Heat Number: B7212-1

Orientation: LT

Capsule: X Total Fluence:

Charpy V-Notch Data (Continued)

Temperature	Input CVN Energy	Computed CVN Energy	Differential
200	42	56.56	-14.56
225	73	67.62	5.37
250	92	76.71	15.28
350	97	93.2	3.79
400	102	95.16	6.83
450	94	95.88	-1.88
			SUM of RESIDUALS = 20.6

CAPSULE Z

CVGRAPH 4.1 Hyperbolic Tangent Curve Printed at 10:29:47 on 02-22-2000

Page 1

Coefficients of Curve 1


A = 48	B = 45.8	C = 67.87	T0 = 205.78
--------	----------	-----------	-------------

Equation is: $CVN = A + B * [\tanh((T - T_0)/C)]$

Upper Shelf Energy: 93.8 Fixed Temp. at 30 ft-lbs: 177.5 Temp. at 50 ft-lbs: 208.7 Lower Shelf Energy: 2.19 Fixed

Material: PLATE SA533B1 Heat Number: B7212-1 Orientation: LT

Capsule: Z Total Fluence:



Data Set(s) Plotted
 Plant: FA2 Cap: Z Material: PLATE SA533B1 Ori: LT Heat #: B7212-1

Charpy V-Notch Data

Temperature	Input CVN Energy	Computed CVN Energy	Differential
0	5	2.41	2.58
72	21	3.94	17.05
125	17	9.95	7.04
150	20	17.03	2.96
175	28	28.54	-5.4
190	39	37.53	1.46
200	25	44.1	-19.1
210	60	50.84	9.15
225	60	60.63	-6.3

**** Data continued on next page ****

CAPSULE Z

Page 2

Material: PLATE SA533B1

Heat Number: B7212-1

Orientation: LT

Capsule: Z Total Fluence:

Charpy V-Notch Data (Continued)

Temperature	Input CVN Energy	Computed CVN Energy	Differential
250	74	74.22	-22
275	94	83.25	10.74
300	90	88.43	1.56
350	91	92.51	-1.51
400	96	93.5	2.49
450	98	93.73	4.26

SUM of RESIDUALS = 37.32

UNIRRADIATED

CVGRAPH 4.1 Hyperbolic Tangent Curve Printed at 16:52:55 on 12-21-1998

Page 1

Coefficients of Curve 1


A = 45.82	B = 44.82	C = 84.62	T0 = 22.5
-----------	-----------	-----------	-----------

Equation is: $LE = A + B * [\tanh((T - T_0)/C)]$

Upper Shelf LE: 90.65 Temperature at LE: 35 Lower Shelf LE: 1 Fixed

Material: PLATE SA533B1 Heat Number: B7212-1 Orientation: LT

Capsule: UNIRR Total Fluence:



Data Set(s) Plotted
 Plant: FA2 Cap: UNIRR Material: PLATE SA533B1 Ori: LT Heat #: B7212-1

Charpy V-Notch Data

Temperature	Input Lateral Expansion	Computed LE	Differential
-60	9	12.17	-3.17
-50	11	14.69	-3.69
-25	26	23.01	2.98
-25	16	23.01	-7.01
-10	35	29.41	5.58
0	40	34.18	5.81
20	49	44.5	4.49
50	60	59.9	.09
60	53	64.48	-11.48

*** Data continued on next page ***

UNIRRADIATED

Page 2

Material: PLATE SA533B1

Heat Number: B7212-1

Orientation: LT

Capsule: UNIRR

Total Fluence:

Charpy V-Notch Data (Continued)

Temperature	Input Lateral Expansion	Computed L.E.	Differential
75	71	70.54	.45
100	80	78.28	1.71
125	84	83.35	.64
150	91	86.45	4.54
210	89	89.6	-.6
210	87	89.6	-2.6
210	90	89.6	.39

SUM of RESIDUALS = -1.84

CAPSULE U

CVGRAPH 4.1 Hyperbolic Tangent Curve Printed at 165255 on 12-21-1998

Page 1

Coefficients of Curve 2


A = 43.01	B = 42.01	C = 130.69	T0 = 147.39
-----------	-----------	------------	-------------

Equation is: $LE = A + B * [\tanh((T - T_0)/C)]$

Upper Shelf LE: 85.02 Temperature at LE 35: 122.1 Lower Shelf LE: 1 Fixed

Material: PLATE SA533B1 Heat Number: B7212-1 Orientation: LT

Capsule: U Total Fluence:



Data Set(s) Plotted
 Plant: FA2 Cap: U Material: PLATE SA533B1 Ori: LT Heat #: B7212-1

Charpy V-Notch Data

Temperature	Input Lateral Expansion	Computed L.E.	Differential
0	8	8.97	-9.7
50	21	16.44	4.55
75	27	21.86	5.13
100	34	28.41	5.58
125	31	35.88	-4.88
150	38	43.85	-5.85
150	40	43.85	-3.85
175	40	51.75	-11.75

**** Data continued on next page ****

CAPSULE U

Page 2

Material: PLATE SA533B1

Heat Number: B7212-1

Orientation: LT

Capsule: U Total Fluence:

Charpy V-Notch Data (Continued)

Temperature	Input Lateral Expansion	Computed L.E.	Differential
200	59	59.06	-.06
200	63	59.06	3.93
225	81	65.39	15.6
250	72	70.55	1.44
300	76	77.61	-1.61
350	80	81.4	-1.4
400	80	83.3	-3.3

SUM of RESIDUALS = 2.54

CAPSULE W

CVGRAPH 4.1 Hyperbolic Tangent Curve Printed at 16:52:55 on 12-21-1998

Page 1

Coefficients of Curve 3


A = 43.41	B = 42.41	C = 155.01	T0 = 198.75
-----------	-----------	------------	-------------

Equation is: $L.E. = A + B * [\tanh((T - T_0)/C)]$

Upper Shelf L.E.: 85.83 Temperature at L.E. 35: 167.5 Lower Shelf L.E.: 1 Fixed

Material: PLATE SA533B1 Heat Number: B7212-1 Orientation: LT

Capsule: W Total Fluence:



Data Set(s) Plotted
 Plant: FA2 Cap: W Material: PLATE SA533B1 Ori: LT Heat #: B7212-1

Charpy V-Notch Data

Temperature	Input Lateral Expansion	Computed L.E.	Differential
0	7	7.06	-.06
73	19	14.98	4.01
100	30	19.54	10.45
125	18	24.63	-6.63
150	23	30.5	-7.5
150	35	30.5	4.49
175	35	36.97	-1.97
175	35	36.97	-1.97

**** Data continued on next page ****

CAPSULE W

Page 2

Material: PLATE SA533B1

Heat Number: B7212-1

Orientation: LT

Capsule: W Total Fluence:

Charpy V-Notch Data (Continued)

Temperature	Input Lateral Expansion	Computed L.E.	Differential
200	39	43.76	-4.76
200	38	43.76	-5.76
225	60	50.53	9.46
250	63	56.95	6.04
300	70	67.75	2.24
350	71	75.28	-4.28
400	80	79.95	.04

SUM of RESIDUALS = 3.81

CAPSULE X

CVGRAPH 4.1 Hyperbolic Tangent Curve Printed at 16:52:55 on 12-21-1998

Page 1

Coefficients of Curve 4


A = 35.7	B = 34.7	C = 103.9	T0 = 185.15
----------	----------	-----------	-------------

Equation is: $LE = A + B * [\tanh((T - T0)/C)]$

Upper Shelf LE: 70.41 Temperature at LE 35: 183 Lower Shelf LE: 1 Fixed

Material: PLATE SA533B1 Heat Number: B7212-1 Orientation: LT

Capsule: X Total Fluence:



Data Set(s) Plotted
 Plant: FA2 Cap: X Material: PLATE SA533B1 Ori: LT Heat #: B7212-1

Charpy V-Notch Data

Temperature	Input Lateral Expansion	Computed L.E.	Differential
0	2	2.91	-91
72	13	8.06	4.93
100	21	12.28	8.71
125	13	17.59	-4.59
125	13	17.59	-4.59
150	27	24.39	2.6
150	27	24.39	2.6

**** Data continued on next page ****

CAPSULE X

Page 2

Material: PLATE SA533B1

Heat Number: B7212-1

Orientation: LT

Capsule: X Total Fluence:

Charpy V-Notch Data (Continued)

Temperature	Input Lateral Expansion	Computed LE.	Differential
175	31	32.32	-1.32
200	33	40.63	-7.63
200	34	40.63	-6.63
225	55	48.4	6.59
250	63	54.93	8.06
350	65	67.62	-2.62
400	73	69.32	3.67
450	65	69.99	-4.99
			SUM of RESIDUALS = 3.9

CAPSULE Z

CVGRAPH 4.1 Hyperbolic Tangent Curve Printed at 16:52:55 on 12-21-1998

Page 1

Coefficients of Curve 5


A = 33.81	B = 32.81	C = 62.36	T0 = 210.05
-----------	-----------	-----------	-------------

Equation is: $LE = A + B * [\tanh((T - T_0)/C)]$

Upper Shelf LE: 66.63 Temperature at LE 35: 212.3 Lower Shelf LE: 1 Fixed

Material: PLATE SA533B1 Heat Number: B7212-1 Orientation: LT

Capsule: Z Total Fluence:



Data Set(s) Plotted
 Plant: FA2 Cap: Z Material: PLATE SA533B1 Ori: LT Heat #: B7212-1

Charpy V-Notch Data

Temperature	Input Lateral Expansion	Computed LE	Differential
0	0	1.07	-1.07
72	11	1.77	9.22
125	5	5.02	-0.2
150	12	9.34	2.65
175	18	17.09	.9
190	27	23.61	3.38

**** Data continued on next page ****

CAPSULE Z

Page 2

Material: PLATE SA533B1

Heat Number: B7212-1

Orientation: LT

Capsule: Z Total Fluence:

Charpy V-Notch Data (Continued)

Temperature	Input Lateral Expansion	Computed L.E.	Differential
200	16	28.57	-12.57
210	40	33.78	6.21
225	41	41.53	-.53
250	52	52.36	-.36
275	64	59.36	4.63
300	63	63.16	-.16
350	64	65.9	-1.9
400	67	66.48	.51
450	65	66.6	-1.6
			SUM of RESIDUALS = 9.28

UNIRRADIATED

CVGRAPH 4.1 Hyperbolic Tangent Curve Printed at 14:24:19 on 12-21-1998

Page 1

Coefficients of Curve 1

A = 50	B = 50	C = 84.43	T0 = 39.37
--------	--------	-----------	------------

Equation is: $\text{Shear}\% = A + B * [\tanh((T - T_0)/C)]$

Temperature at 50% Shear: 39.3


Material: PLATE SA533B1

Heat Number: B7212-1

Orientation: LT

Capsule: UNIRR

Total Fluence:



Data Set(s) Plotted
 Plant: FA2 Cap: UNIRR Material: PLATE SA533B1 Ori: LT Heat #: B7212-1

Charpy V-Notch Data

Temperature	Input Percent Shear	Computed Percent Shear	Differential
-60	8	8.67	-.67
-50	12	10.74	1.25
-25	18	17.87	.12
-25	22	17.87	4.12
-10	25	23.69	1.3
0	30	28.23	1.76
20	40	38.72	1.27
50	60	56.25	3.74
60	48	61.97	-13.97

**** Data continued on next page ****

UNIRRADIATED

Page 2

Material: PLATE SA533B1

Heat Number: B7212-1

Orientation: LT

Capsule: UNIRR

Total Fluence:

Charpy V-Notch Data (Continued)

Temperature	Input Percent Shear	Computed Percent Shear	Differential
75	63	69.92	-6.92
100	85	80.78	4.21
125	100	88.37	11.62
150	100	93.21	6.78
210	100	98.27	1.72
210	100	98.27	1.72
210	100	98.27	1.72

SUM of RESIDUALS = 19.81

CAPSULE U

CVGRAPH 4.1 Hyperbolic Tangent Curve Printed at 14:24:19 on 12-21-1998

Page 1

Coefficients of Curve 2

A = 50	B = 50	C = 100.7	T0 = 150.29
--------	--------	-----------	-------------

Equation is: $\text{Shear}\% = A + B * [\tanh((T - T_0)/C)]$

Temperature at 50% Shear: 150.2


Material: PLATE SA533B1

Heat Number: B7212-1

Orientation: LT

Capsule: U

Total Fluence:



Data Set(s) Plotted

Plant: FA2

Cap: U

Material: PLATE SA533B1

Ori: LT

Heat #: B7212-1

Charpy V-Notch Data

Temperature	Input Percent Shear	Computed Percent Shear	Differential
0	2	4.81	-2.81
50	17	12	4.99
75	25	18.31	6.68
100	31	26.91	4.08
125	38	37.69	3
150	44	49.85	-5.85
150	49	49.85	-85
175	56	62.02	-6.02

**** Data continued on next page ****

CAPSULE U

Page 2

Material: PLATE SA533B1

Heat Number: B7212-1

Orientation: LT

Capsule: U Total Fluence:

Charpy V-Notch Data (Continued)

Temperature	Input Percent Shear	Computed Percent Shear	Differential
200	73	72.85	.14
200	58	72.85	-14.85
225	96	81.51	14.48
250	100	87.86	12.13
300	100	95.13	4.86
350	100	98.14	1.85
400	100	99.3	.69

SUM of RESIDUALS = 19.84

CAPSULE W

CVGRAPH 4.1 Hyperbolic Tangent Curve Printed at 14:24:19 on 12-21-1998

Page 1

Coefficients of Curve 3

A = 50	B = 50	C = 74.69	T0 = 188.43
--------	--------	-----------	-------------

Equation is: $\text{Shear}\% = A + B * [\tanh((T - T_0)/C)]$

Temperature at 50% Shear: 188.4


Material: PLATE SA533B1

Heat Number: B7212-1

Orientation: LT

Capsule: W

Total Fluence:



Data Set(s) Plotted
 Plant: FA2 Cap: W Material: PLATE SA533B1 Ori: LT Heat #: B7212-1

Charpy V-Notch Data

Temperature	Input Percent Shear	Computed Percent Shear	Differential
0	2	.63	1.36
73	7	4.34	2.65
100	18	8.56	9.43
125	24	15.46	8.53
150	26	26.32	-.32
150	29	26.32	2.67
175	37	41.1	-4.1
175	37	41.1	-4.1

**** Data continued on next page ****

CAPSULE W

Page 2

Material: PLATE SA533B1

Heat Number: B7212-1

Orientation: LT

Capsule: W Total Fluence:

Charpy V-Notch Data (Continued)

Temperature	Input Percent Shear	Computed Percent Shear	Differential
200	50	57.67	-7.67
200	49	57.67	-8.67
225	82	72.69	9.3
250	95	83.86	11.13
300	100	95.19	4.8
350	100	98.69	1.3
400	100	99.65	.34

SUM of RESIDUALS = 26.66

CAPSULE X

CVGRAPH 4.1 Hyperbolic Tangent Curve Printed at 14:24:19 on 12-21-1998

Page 1

Coefficients of Curve 4

A = 50	B = 50	C = 83.64	T0 = 198.28
--------	--------	-----------	-------------

Equation is: $Shear\% = A + B * [\tanh((T - T_0)/C)]$

Temperature at 50% Shear: 198.2


Material: PLATE SA533B1

Heat Number: B7212-1

Orientation: LT

Capsule: X

Total Fluence:



Data Set(s) Plotted

Plant: FA2

Cap: X

Material: PLATE SA533B1

Ori: LT

Heat #: B7212-1

Charpy V-Notch Data

Temperature	Input Percent Shear	Computed Percent Shear	Differential
0	2	.86	1.13
72	15	4.65	10.34
100	20	8.7	11.29
125	20	14.77	5.22
125	20	14.77	5.22
150	25	23.96	1.03
150	25	23.96	1.03

**** Data continued on next page ****

CAPSULE X

Page 2

Material: PLATE SA533B1

Heat Number: B7212-1

Orientation: LT

Capsule: X Total Fluence:

Charpy V-Notch Data (Continued)

Temperature	Input Percent Shear	Computed Percent Shear	Differential
175	30	36.43	-6.43
200	40	51.02	-11.02
200	35	51.02	-16.02
225	70	65.44	4.55
250	100	77.49	22.5
350	100	97.41	2.58
400	100	99.2	.79
450	100	99.75	.24

SUM of RESIDUALS = 32.47

CAPSULE Z

CVGRAPH 4.1 Hyperbolic Tangent Curve Printed at 14:24:19 on 12-21-1998

Page 1

Coefficients of Curve 5

A = 50	B = 50	C = 63.29	T0 = 209.06
--------	--------	-----------	-------------

Equation is: $\text{Shear}\% = A + B * [\tanh((T - T_0)/C)]$

Temperature at 50% Shear: 209


Material: PLATE SA533B1

Heat Number: B7212-1

Orientation: LT

Capsule: Z

Total Fluence:



Data Set(s) Plotted
 Plant: FA2 Cap: Z Material: PLATE SA533B1 Ori: LT Heat #: B7212-1

Charpy V-Notch Data

Temperature	Input Percent Shear	Computed Percent Shear	Differential
0	2	.13	1.86
72	5	1.29	3.7
125	10	6.56	3.43
150	20	13.39	6.6
175	25	25.42	-4.2
190	35	35.38	-3.8

**** Data continued on next page ****

CAPSULE Z

Page 2

Material: PLATE SA533B1

Heat Number: B7212-1

Orientation: LT

Capsule: Z Total Fluence:

Charpy V-Notch Data (Continued)

Temperature	Input Percent Shear	Computed Percent Shear	Differential
200	30	42.89	-12.89
210	60	50.74	9.25
225	60	62.32	-2.32
250	80	78.47	1.52
275	90	88.92	1.07
300	100	94.65	5.34
350	100	98.84	1.15
400	100	99.76	.23
450	100	99.95	.04
			SUM of RESIDUALS = 18.22

UNIRRADIATED

CVGRAPH 4.1 Hyperbolic Tangent Curve Printed at 10:01:19 on 02-22-2000

Page 1

Coefficients of Curve 1


A = 48.59	B = 46.4	C = 90.37	T0 = 30.93
-----------	----------	-----------	------------

Equation is: $CVN = A + B * [\tanh((T - T_0)/C)]$

Upper Shelf Energy: 95 Fixed Temp. at 30 ft-lbs: -74 Temp. at 50 ft-lbs: 33.6 Lower Shelf Energy: 2.19 Fixed

Material: PLATE SA533B1 Heat Number: B7212-1 Orientation: TL

Capsule: UNIRR Total Fluence:



Data Set(s) Plotted
 Plant: FA2 Cap: UNIRR Material: PLATE SA533B1 Ori: TL Heat #: B7212-1

Charpy V-Notch Data

Temperature	Input CVN Energy	Computed CVN Energy	Differential
-50	19	15.46	3.53
-50	18.5	15.46	3.03
-50	15.5	15.46	.03
0	30	33.3	-3.3
0	35	33.3	1.69
0	34.5	33.3	1.19
30	52	48.11	3.88
30	43	48.11	-5.11
30	48	48.11	-.11

**** Data continued on next page ****

UNIRRADIATED

Page 2

Material: PLATE SA533B1

Heat Number: B7212-1

Orientation: TL

Capsule: UNIRR

Total Fluence:

Charpy V-Notch Data (Continued)

Temperature	Input CVN Energy	Computed CVN Energy	Differential
100	70	78.45	-8.45
100	76.5	78.45	-1.95
100	74	78.45	-4.45
150	106	88.78	17.21
150	95	88.78	6.21
150	98	88.78	9.21
210	88	93.26	-5.26
210	89	93.26	-4.26
210	94	93.26	.73
			SUM of RESIDUALS = 13.77

CAPSULE U

CVGRAPH 4.1 Hyperbolic Tangent Curve Printed at 10:08:13 on 02-22-2000

Page 1

Coefficients of Curve 1


A = 35.54	B = 33.35	C = 103.29	T0 = 133.91
-----------	-----------	------------	-------------

Equation is: $CVN = A + B * [\tanh((T - T_0)/C)]$

Upper Shelf Energy: 68.9 Fixed Temp. at 30 ft-lbs: 116.5 Temp. at 50 ft-lbs: 181.8 Lower Shelf Energy: 2.19 Fixed

Material: PLATE SA533B1 Heat Number: B7212-1 Orientation: TL

Capsule: U Total Fluence:



Data Set(s) Plotted
 Plant: FA2 Cap.: U Material: PLATE SA533B1 Ori: TL Heat #: B7212-1

Charpy V-Notch Data

Temperature	Input CVN Energy	Computed CVN Energy	Differential
50	15	13.17	1.82
75	22.5	18.35	4.14
100	21.5	24.97	-3.47
110	32.5	27.96	4.53
125	33.5	32.67	.82
150	37	40.7	-3.7
175	42.5	48.15	-5.65
175	46	48.15	-2.15
200	49.5	54.38	-4.88

**** Data continued on next page ****

CAPSULE U

Page 2

Material: PLATE SA533B1

Heat Number: B7212-1

Orientation: TL

Capsule: U

Total Fluence:

Charpy V-Notch Data (Continued)

Temperature	Input CVN Energy	Computed CVN Energy	Differential
225	69	59.13	9.86
250	67.5	62.52	4.97
275	68	64.82	3.17
300	67	66.32	.67
350	69	67.89	1.1
400	73	68.51	4.48
			SUM of RESIDUALS = 15.72

CAPSULE W

CVGRAPH 4.1 Hyperbolic Tangent Curve Printed at 10:20:47 on 02-22-2000

Page 1

Coefficients of Curve 1


A = 38.84	B = 36.65	C = 102.67	T0 = 186.03
-----------	-----------	------------	-------------

Equation is: $CVN = A + B * [\tanh((T - T_0)/C)]$

Upper Shelf Energy: 75.5 Fixed Temp. at 30 ft-lbs: 160.7 Temp. at 50 ft-lbs: 218.2 Lower Shelf Energy: 2.19 Fixed

Material: PLATE SA533B1 Heat Number: B7212-1 Orientation: TL

Capsule: W Total Fluence:



Data Set(s) Plotted
 Plant: FA2 Cap: W Material: PLATE SA533B1 Ori: TL Heat #: B7212-1

Charpy V-Notch Data

Temperature	Input CVN Energy	Computed CVN Energy	Differential
25	6	5.25	.74
76	16	9.89	6.1
125	29	19.31	9.68
150	30	26.49	3.5
150	30	26.49	3.5
175	27	34.92	-7.92
175	37	34.92	2.07
200	33	43.8	-10.8
200	30	43.8	-13.8

**** Data continued on next page ****

CAPSULE W

Page 2

Material: PLATE SA533B1

Heat Number: B7212-1

Orientation: TL

Capsule: W Total Fluence:

Charpy V-Notch Data (Continued)

Temperature	Input CVN Energy	Computed CVN Energy	Differential
210	35	47.25	-12.25
225	68	52.12	15.87
250	72	59.12	12.87
300	78	68.31	9.68
350	68	72.61	-4.61
400	84	74.38	9.61
			SUM of RESIDUALS = 24.28

CAPSULE X

CVGRAPH 4.1 Hyperbolic Tangent Curve Printed at 10:25:35 on 02-22-2000

Page 1

Coefficients of Curve 1


A = 35.34	B = 33.15	C = 46.21	T0 = 200.09
-----------	-----------	-----------	-------------

Equation is: $CVN = A + B * [\tanh((T - T_0)/C)]$

Upper Shelf Energy: 68.5 Fixed Temp. at 30 ft-lbs: 192.5 Temp. at 50 ft-lbs: 222 Lower Shelf Energy: 2.19 Fixed

Material: PLATE SA533B1 Heat Number: B7212-1 Orientation: TL

Capsule: X Total Fluence:



Data Set(s) Plotted
 Plant: FA2 Cap: X Material: PLATE SA533B1 Ori: TL Heat #: B7212-1

Charpy V-Notch Data

Temperature	Input CVN Energy	Computed CVN Energy	Differential
0	3	2.21	.78
72	19	2.45	16.54
150	24	9	14.99
175	23	18.93	4.06
175	18	18.93	-.93
190	30	28.22	1.77
200	26	35.27	-9.27
200	23	35.27	-12.27
210	45	42.34	2.65

**** Data continued on next page ****

CAPSULE X

Page 2

Material: PLATE SA533B1

Heat Number: B7212-1

Orientation: TL

Capsule: X Total Fluence:

Charpy V-Notch Data (Continued)

Temperature	Input CVN Energy	Computed CVN Energy	Differential
210	38	42.34	-4.34
225	63	51.66	11.33
225	55	51.66	3.33
250	69	61.64	7.35
350	67	68.39	-1.39
450	75	68.49	6.5
			SUM of RESIDUALS = 41.12

CAPSULE Z

CVGRAPH 4.1 Hyperbolic Tangent Curve Printed at 10:31:13 on 02-22-2000

Page 1

Coefficients of Curve 1


A = 35	B = 32.8	C = 66.49	T0 = 198.28
--------	----------	-----------	-------------

Equation is: $CVN = A + B * [\tanh((T - T_0)/C)]$

Upper Shelf Energy: 67.8 Fixed Temp. at 30 ft-lbs: 188 Temp. at 50 ft-lbs: 231.1 Lower Shelf Energy: 2.19 Fixed

Material: PLATE SA533B1 Heat Number: B7212-1 Orientation: TL

Capsule: Z Total Fluence:



Data Set(s) Plotted
 Plant: FA2 Cap: Z Material: PLATE SA533B1 Ori: TL Heat #: B7212-1

Charpy V-Notch Data

Temperature	Input CVN Energy	Computed CVN Energy	Differential
0	6	2.36	3.63
72	4	3.63	.36
125	17	8.71	8.28
150	22	14.64	7.35
175	28	23.96	4.03
190	31	30.93	.06
200	25	35.84	-10.84
200	18	35.84	-17.84
210	44	40.72	3.27

**** Data continued on next page ****

CAPSULE Z

Page 2

Material: PLATE SA533B1

Heat Number: B7212-1

Orientation: TL

Capsule: Z Total Fluence:

Charpy V-Notch Data (Continued)

Temperature	Input CVN Energy	Computed CVN Energy	Differential
225	61	47.51	13.48
250	56	56.36	-36
275	64	61.86	2.13
300	76	64.86	11.13
350	69	67.12	1.87
400	62	67.64	-5.64
			SUM of RESIDUALS = 20.94

UNIRRADIATED

CVGRAPH 4.1 Hyperbolic Tangent Curve Printed at 14:07:18 on 12-21-1998

Page 1

Coefficients of Curve 1


A = 36.67	B = 35.67	C = 98.64	T0 = 31.87
-----------	-----------	-----------	------------

Equation is: $LE = A + B * [\tanh((T - T_0)/C)]$

Upper Shelf LE: 72.35 Temperature at LE 35: 272 Lower Shelf LE: 1 Fixed

Material: PLATE SA533B1 Heat Number: B7212-1 Orientation: TL

Capsule: UNIRR Total Fluence:



Data Set(s) Plotted

Plant: FA2 Cap: UNIRR Material: PLATE SA533B1 Ori: TL Heat #: B7212-1

Charpy V-Notch Data

Temperature	Input Lateral Expansion	Computed L.E.	Differential
-50	11	12.4	-14
-50	11	12.4	-14
-50	11	12.4	-14
0	27	25.53	1.46
0	27	25.53	1.46
0	27	25.53	1.46
30	39	35.99	3
30	35	35.99	-99
30	36	35.99	0

**** Data continued on next page ****

UNIRRADIATED

Page 2

Material: PLATE SA533B1

Heat Number: B7212-1

Orientation: TL

Capsule: UNIRR

Total Fluence:

Charpy V-Notch Data (Continued)

Temperature	Input Lateral Expansion	Computed L.E.	Differential
100	56	58.02	-2.02
100	54	58.02	-4.02
100	55	58.02	-3.02
150	68	66.38	1.61
150	67	66.38	.61
150	76	66.38	9.61
210	69	70.47	-1.47
210	70	70.47	-.47
210	68	70.47	-2.47

SUM of RESIDUALS = .54

CAPSULE U

CVGRAPH 4.1 Hyperbolic Tangent Curve Printed at 14:07:18 on 12-21-1998

Page 1

Coefficients of Curve 2


A = 34.74	B = 33.74	C = 98.97	T0 = 145.78
-----------	-----------	-----------	-------------

Equation is: $LE = A + B * [\tanh((T - T_0)/C)]$

Upper Shelf LE: 68.48 Temperature at LE 35: 146.5 Lower Shelf LE: 1 Fixed

Material: PLATE SA533B1 Heat Number: B7212-1 Orientation: TL

Capsule: U Total Fluence:



Data Set(s) Plotted
 Plant: FA2 Cap: U Material: PLATE SA533B1 Ori: TL Heat #: B7212-1

Charpy V-Notch Data

Temperature	Input Lateral Expansion	Computed L.E.	Differential
50	11	951	1.48
75	16	14.02	1.97
100	20	20.16	-16
110	27	23.04	3.95
125	30	27.76	2.23
150	30	36.18	-6.18
175	40	44.42	-4.42
175	40	44.42	-4.42

**** Data continued on next page ****

CAPSULE U

Page 2

Material: PLATE SA533B1

Heat Number: B7212-1

Orientation: TL

Capsule: U

Total Fluence:

Charpy V-Notch Data (Continued)

Temperature	Input Lateral Expansion	Computed L.E.	Differential
200	50	51.57	-1.57
225	70	57.15	12.84
250	63	61.16	1.83
275	67	63.86	3.13
300	64	65.62	-1.62
350	60	67.41	-7.41
400	69	68.09	.9
			SUM of RESIDUALS = 2.57

CAPSULE W

CVGRAPH 4.1 Hyperbolic Tangent Curve Printed at 14:07:18 on 12-21-1998

Page 1

Coefficients of Curve 3


A = 34.77	B = 33.77	C = 138.16	T0 = 181.23
-----------	-----------	------------	-------------

Equation is: $LE = A + B * [\tanh((T - T0)/C)]$

Upper Shelf LE: 68.54 Temperature at LE. 35: 182.1 Lower Shelf LE: 1 Fixed

Material: PLATE SA533B1 Heat Number: B7212-1 Orientation: TL

Capsule: W Total Fluence:



Data Set(s) Plotted
 Plant: FA2 Cap: W Material: PLATE SA533B1 Ori: TL Heat #: B7212-1

Charpy V-Notch Data

Temperature	Input Lateral Expansion	Computed L.E.	Differential
25	7	7.37	-37
76	15	13.08	1.91
125	25	21.73	3.26
150	27	27.26	-26
150	30	27.26	2.73
175	38	33.24	4.75
175	28	33.24	-5.24
200	31	39.33	-8.33

**** Data continued on next page ****

CAPSULE W

Page 2

Material: PLATE SA533B1

Heat Number: B7212-1

Orientation: TL

Capsule: W Total Fluence:

Charpy V-Notch Data (Continued)

Temperature	Input Lateral Expansion	Computed L.E.	Differential
200	31	39.33	-8.33
210	37	41.7	-4.7
225	54	45.12	8.87
250	59	50.31	8.68
300	60	58.27	1.72
350	61	63.14	-2.14
400	64	65.81	-1.81

SUM of RESIDUALS = .71

CAPSULE X

CVGRAPH 4.1 Hyperbolic Tangent Curve Printed at 14:07:18 on 12-21-1998

Page 1

Coefficients of Curve 4


A = 31.72	B = 30.72	C = 117.52	T0 = 201.85
-----------	-----------	------------	-------------

Equation is: $LE = A + B * [\tanh((T - T_0)/C)]$

Upper Shelf L.E.: 62.45 Temperature at L.E. 35: 214.4 Lower Shelf L.E.: 1 Fixed

Material: PLATE SA533B1 Heat Number: B7212-1 Orientation: TL

Capsule: X Total Fluence:



Data Set(s) Plotted
 Plant: FA2 Cap: X Material: PLATE SA533B1 Ori: TL Heat #: B7212-1

Charpy V-Notch Data

Temperature	Input Lateral Expansion	Computed L.E.	Differential
0	4	2.91	1.08
72	12	7.07	4.92
150	23	18.98	4.01
175	23	24.82	-1.82
175	21	24.82	-3.82
190	36	28.63	7.36
200	27	31.24	-4.24

**** Data continued on next page ****

CAPSULE X

Page 2

Material: PLATE SA533B1

Heat Number: B7212-1

Orientation: TL

Capsule: X Total Fluence:

Charpy V-Notch Data (Continued)

Temperature	Input Lateral Expansion	Computed L.E.	Differential
200	23	31.24	-8.24
210	28	33.85	-5.85
210	30	33.85	-3.85
225	44	37.7	6.29
225	40	37.7	2.29
250	53	43.65	9.34
350	54	57.88	-3.88
450	62	61.57	.42
			SUM of RESIDUALS = 3.99

CAPSULE Z

CVGRAPH 4.1 Hyperbolic Tangent Curve Printed at 14:07:18 on 12-21-1998

Page 1

Coefficients of Curve 5


A = 27.06	B = 26.06	C = 69.02	T0 = 203.9
-----------	-----------	-----------	------------

Equation is: $LE = A + B * [\tanh((T - T0)/C)]$

Upper Shelf LE: 53.13 Temperature at LE 35: 225.5 Lower Shelf LE: 1 Fixed

Material: PLATE SA533B1 Heat Number: B7212-1 Orientation: TL

Capsule: Z Total Fluence:



Data Set(s) Plotted
 Plant: FA2 Cap: Z Material: PLATE SA533B1 Ori: TL Heat #: B7212-1

Charpy V-Notch Data

Temperature	Input Lateral Expansion	Computed LE	Differential
0	2	1.14	.85
72	0	2.11	-2.11
125	7	5.81	1.18
150	15	10.03	4.96
175	22	16.74	5.25
190	22	21.88	.11

**** Data continued on next page ****

CAPSULE Z

Page 2

Material: PLATE SA533B1

Heat Number: B7212-1

Orientation: TL

Capsule: Z Total Fluence:

Charpy V-Notch Data (Continued)

Temperature	Input Lateral Expansion	Computed L.E.	Differential
200	19	25.59	-6.59
200	14	25.59	-11.59
210	30	29.36	.63
225	44	34.79	9.2
250	45	42.28	2.71
275	43	47.24	-4.24
300	55	50.1	4.89
350	52	52.39	-3.9
400	50	52.96	-2.96

SUM of RESIDUALS = 1.92

UNIRRADIATED

CVGRAPH 4.1 Hyperbolic Tangent Curve Printed at 14:14:51 on 12-21-1998

Page 1

Coefficients of Curve 1


A = 50	B = 50	C = 85.4	T0 = 49.68
--------	--------	----------	------------

Equation is: $\text{Shear}\% = A + B * [\tanh((T - T_0)/C)]$

Temperature at 50% Shear: 49.6

Material: PLATE SA533B1 Heat Number: B7212-1 Orientation: TL

Capsule: UNIRR Total Fluence:



Data Set(s) Plotted
 Plant: FA2 Cap: UNIRR Material: PLATE SA533B1 Ori: TL Heat #: B7212-1

Charpy V-Notch Data

Temperature	Input Percent Shear	Computed Percent Shear	Differential
-50	12	8.83	3.16
-50	12	8.83	3.16
-50	12	8.83	3.16
0	25	23.8	1.19
0	25	23.8	1.19
0	27	23.8	3.19
30	43	38.67	4.32
30	32	38.67	-6.67
30	35	38.67	-3.67

**** Data continued on next page ****

UNIRRADIATED

Page 2

Material: PLATE SA533B1

Heat Number: B7212-1

Orientation: TL

Capsule: UNIRR

Total Fluence:

Charpy V-Notch Data (Continued)

Temperature	Input Percent Shear	Computed Percent Shear	Differential
100	73	76.46	-3.46
100	69	76.46	-7.46
100	73	76.46	-3.46
150	100	91.28	8.71
150	100	91.28	8.71
150	100	91.28	8.71
210	100	97.71	2.28
210	100	97.71	2.28
210	100	97.71	2.28
			SUM of RESIDUALS = 27.69

CAPSULE U

CVGRAPH 4.1 Hyperbolic Tangent Curve Printed at 14:14:51 on 12-21-1998

Page 1

Coefficients of Curve 2

A = 50	B = 50	C = 95.05	T0 = 159.64
--------	--------	-----------	-------------

Equation is: $\text{Shear}\% = A + B * [\tanh((T - T_0)/C)]$

Temperature at 50% Shear: 159.6


Material: PLATE SA533B1

Heat Number: B7212-1

Orientation: TL

Capsule: U

Total Fluence:



Data Set(s) Plotted

Plant: FA2

Cap: U

Material: PLATE SA533B1

Ori: TL

Heat #: B7212-1

Charpy V-Notch Data

Temperature	Input Percent Shear	Computed Percent Shear	Differential
50	16	9.05	6.94
75	23	14.41	8.58
100	27	22.18	4.81
110	31	26.02	4.97
125	37	32.54	4.45
150	37	44.94	-7.94
175	48	58	-10
175	46	58	-12

**** Data continued on next page ****

CAPSULE U

Page 2

Material: PLATE SA533B1

Heat Number: B7212-1

Orientation: TL

Capsule: U

Total Fluence:

Charpy V-Notch Data (Continued)

Temperature	Input Percent Shear	Computed Percent Shear	Differential
200	57	70.03	-13.03
225	100	79.81	20.18
250	100	87	12.99
275	100	91.88	8.11
300	100	95.04	4.95
350	100	98.21	1.78
400	100	99.36	.63
			SUM of RESIDUALS = 35.46

CAPSULE W

CVGRAPH 4.1 Hyperbolic Tangent Curve Printed at 14:14:51 on 12-21-1998

Page 1

Coefficients of Curve 3

A = 50	B = 50	C = 61.11	T0 = 199.68
--------	--------	-----------	-------------

Equation is: $\text{Shear}\% = A + B * [\tanh((T - T_0)/C)]$

Temperature at 50% Shear: 199.6


Material: PLATE SA533B1

Heat Number: B7212-1

Orientation: TL

Capsule: W

Total Fluence:



Data Set(s) Plotted
 Plant: FA2 Cap: W Material: PLATE SA533B1 Ori: TL Heat #: B7212-1

Charpy V-Notch Data

Temperature	Input Percent Shear	Computed Percent Shear	Differential
25	2	.32	1.67
76	11	1.71	9.28
125	20	7.98	12.01
150	24	16.43	7.56
150	27	16.43	10.56
175	32	30.83	1.16
175	28	30.83	-2.83
200	34	50.25	-16.25

**** Data continued on next page ****

CAPSULE W

Page 2

Material: PLATE SA533B1

Heat Number: B7212-1

Orientation: TL

Capsule: W Total Fluence:

Charpy V-Notch Data (Continued)

Temperature	Input Percent Shear	Computed Percent Shear	Differential
200	36	50.25	-14.25
210	49	58.35	-9.35
225	90	69.6	20.39
250	100	83.84	16.15
300	100	96.38	3.61
350	100	99.27	.72
400	100	99.85	.14
			SUM of RESIDUALS = 40.6

CAPSULE X

CVGRAPH 4.1 Hyperbolic Tangent Curve Printed at 14:14:51 on 12-21-1998

Page 1

Coefficients of Curve 4

A = 50	B = 50	C = 35.05	T0 = 202.96
--------	--------	-----------	-------------

Equation is: $\text{Shear}\% = A + B * [\tanh((T - T_0)/C)]$

Temperature at 50% Shear: 202.9


Material: PLATE SA533B1

Heat Number: B7212-1

Orientation: TL

Capsule: X

Total Fluence:



Data Set(s) Plotted

Plant: FA2

Cap: X

Material: PLATE SA533B1

Ori: TL

Heat #: B7212-1

Charpy V-Notch Data

Temperature	Input Percent Shear	Computed Percent Shear	Differential
0	2	0	1.99
72	10	.05	9.94
150	20	4.64	15.35
175	25	16.85	8.14
175	30	16.85	13.14
190	35	32.3	2.69
200	40	45.77	-5.77

**** Data continued on next page ****

CAPSULE X

Page 2

Material: PLATE SA533B1

Heat Number: B7212-1

Orientation: TL

Capsule: X Total Fluence:

Charpy V-Notch Data (Continued)

Temperature	Input Percent Shear	Computed Percent Shear	Differential
200	35	45.77	-10.77
210	45	59.89	-14.89
210	45	59.89	-14.89
225	100	77.85	22.14
225	95	77.85	17.14
250	100	93.6	6.39
350	100	99.97	.02
450	100	99.99	0

SUM of RESIDUALS = 50.65

CAPSULE Z

CVGRAPH 4.1 Hyperbolic Tangent Curve Printed at 14:14:51 on 12-21-1998

Page 1

Coefficients of Curve 5

A = 50	B = 50	C = 46.55	T0 = 209.53
--------	--------	-----------	-------------

Equation is: $\text{Shear}\% = A + B * [\tanh((T - T_0)/C)]$

Temperature at 50% Shear: 209.5


Material: PLATE SA533B1

Heat Number: B7212-1

Orientation: TL

Capsule: Z

Total Fluence:



Data Set(s) Plotted
 Plant: FA2 Cap: Z Material: PLATE SA533B1 Ori: TL Heat #: B7212-1

Charpy V-Notch Data

Temperature	Input Percent Shear	Computed Percent Shear	Differential
0	2	.01	1.98
72	10	.27	9.72
125	10	2.57	7.42
150	15	7.19	7.8
175	20	18.49	1.5
190	35	30.17	4.82

**** Data continued on next page ****

CAPSULE Z

Page 2

Material: PLATE SA533B1

Heat Number: B7212-1

Orientation: TL

Capsule: Z

Total Fluence:

Charpy V-Notch Data (Continued)

Temperature	Input Percent Shear	Computed Percent Shear	Differential
200	35	39.9	-4.9
200	30	39.9	-9.9
210	45	50.5	-5.5
225	80	66.02	13.97
250	80	85.04	-5.04
275	100	94.33	5.66
300	100	97.98	2.01
350	100	99.76	.23
400	100	99.97	.02

SUM of RESIDUALS = 29.83

UNIRRADIATED

CVGRAPH 4.1 Hyperbolic Tangent Curve Printed at 13:43:31 on 12-21-1998

Page 1

Coefficients of Curve 1

A = 73.09	B = 70.9	C = 52.07	T0 = 2.05
-----------	----------	-----------	-----------

Equation is: $CVN = A + B * [\tanh((T - T0)/C)]$

Upper Shelf Energy: 144 Fixed Temp. at 30 ft-lbs: -34.6 Temp. at 50 ft-lbs: -15.5 Lower Shelf Energy: 2.19 Fixed


Material: WELD

Heat Number: BOLA

Orientation:

Capsule: UNIRR

Total Fluence:



Data Set(s) Plotted
 Plant: FA2 Cap: UNIRR Material: WELD Ori: Heat #: BOLA

Charpy V-Notch Data

Temperature	Input CVN Energy	Computed CVN Energy	Differential
-100	8	4.96	3.03
-50	16	19.11	-3.11
-25	42	39.26	2.73
-10	50	56.97	-6.97
10	109	83.83	25.16
25	68	102.46	-34.46
40	124	117.22	6.77
50	133	124.59	8.4
75	144	135.88	8.11

**** Data continued on next page ****

UNIRRADIATED

Page 2

Material: WELD

Heat Number: BOLA

Orientation:

Capsule: UNIRR

Total Fluence:

Charpy V-Notch Data (Continued)

Temperature	Input CVN Energy	Computed CVN Energy	Differential
100	132	140.77	-8.77
150	131	143.51	-12.51
150	150	143.51	6.48
175	155	143.81	11.18
210	137	143.95	-6.95
210	153	143.95	9.04
210	154	143.95	10.04
			SUM of RESIDUALS = 18.18

CAPSULE U

CVGRAPH 4.1 Hyperbolic Tangent Curve Printed at 13:43:31 on 12-21-1998

Page 1

Coefficients of Curve 2

A = 67.09	B = 64.9	C = 96.1	T0 = -.93
-----------	----------	----------	-----------

Equation is: $CVN = A + B * [\tanh((T - T_0)/C)]$

Upper Shelf Energy: 132 Fixed Temp. at 30 ft-lbs: -63.4 Temp. at 50 ft-lbs: -26.8 Lower Shelf Energy: 2.19 Fixed


Material: WELD

Heat Number: BOLA

Orientation:

Capsule: U

Total Fluence:



Data Set(s) Plotted
 Plant: FA2 Cap: U Material: WELD Ori: Heat #: BOLA

Charpy V-Notch Data

Temperature	Input CVN Energy	Computed CVN Energy	Difference
-50	13	36.57	-23.57
-25	79	51.18	27.81
0	37	67.73	-30.73
0	95	67.73	27.26
25	90	84.2	5.79
50	85	98.6	-13.6
50	96	98.6	-2.6
75	113	109.83	3.16

**** Data continued on next page ****

CAPSULE U

Page 2

Material: WELD

Heat Number: BOLA

Orientation:

Capsule: U

Total Fluence:

Charpy V-Notch Data (Continued)

Temperature	Input CVN Energy	Computed CVN Energy	Differential
100	108	117.84	-9.84
125	140	123.19	16.8
150	133	126.62	6.37
175	122	128.74	-6.74
200	114	130.04	-16.04
250	155	131.3	23.69
300	128	131.75	-3.75
			SUM of RESIDUALS = 4.01

CAPSULE W

CVGRAPH 4.1 Hyperbolic Tangent Curve Printed at 13:43:31 on 12-21-1998

Page 1

Coefficients of Curve 3

A = 73.09	B = 70.9	C = 66.49	T0 = 18.91
-----------	----------	-----------	------------

Equation is: $CVN = A + B * [\tanh((T - T_0)/C)]$

Upper Shelf Energy: 144 Fixed Temp. at 30 ft-lbs: -27.9 Temp. at 50 ft-lbs: -3.5 Lower Shelf Energy: 2.19 Fixed


Material: WELD

Heat Number: BOLA

Orientation:

Capsule: W

Total Fluence:



Data Set(s) Plotted
 Plant: FA2 Cap: W Material: WELD Ori: Heat #: BOLA

Charpy V-Notch Data

Temperature	Input CVN Energy	Computed CVN Energy	Differential
-100	5	6.05	-1.05
-50	14	18.04	-4.04
-50	33	18.04	14.95
-25	47	32.07	14.92
0	45	53.45	-8.45
0	28	53.45	-25.45
25	98	79.56	18.43
25	72	79.56	-7.56

**** Data continued on next page ****

CAPSULE W

Page 2

Material: WELD

Heat Number: BOLA

Orientation:

Capsule: W

Total Fluence:

Charpy V-Notch Data (Continued)

Temperature	Input CVN Energy	Computed CVN Energy	Differential
50	108	104.02	3.97
76	132	122.4	9.59
125	123	138.39	-15.39
200	127	143.39	-16.39
250	155	143.86	11.13
350	159	143.99	15
350	154	143.99	10

SUM of RESIDUALS = 19.66

CAPSULE X

CVGRAPH 4.1 Hyperbolic Tangent Curve Printed at 13:43:31 on 12-21-1998

Page 1

Coefficients of Curve 4

A = 76.09	B = 73.9	C = 88.94	T0 = 15
-----------	----------	-----------	---------

Equation is: $CVN = A + B * [\tanh((T - T0)/C)]$

Upper Shelf Energy: 150 Fixed Temp. at 30 ft-lbs: -50 Temp. at 50 ft-lbs: -17.8 Lower Shelf Energy: 2.19 Fixed


Material: WELD

Heat Number: BOLA

Orientation:

Capsule: X

Total Fluence:



Plant: FA2 Cap: X Data Set(s) Plotted Material: WELD Ori: Heat #: BOLA

Charpy V-Notch Data

Temperature	Input CVN Energy	Computed CVN Energy	Differential!
-100	4	12.55	-8.55
-50	40	30.01	9.98
-50	25	30.01	-5.01
-40	25	35.45	-10.45
-25	43	44.93	-1.93
-25	58	44.93	13.06
0	62	63.75	-1.75

**** Data continued on next page ****

CAPSULE X

Page 2

Material: WELD

Heat Number: BOLA

Orientation:

Capsule: X

Total Fluence:

Charpy V-Notch Data (Continued)

Temperature	Input CVN Energy	Computed CVN Energy	Differential
0	74	63.75	10.24
25	69	84.37	-15.37
50	107	103.76	3.23
100	138	130.95	7.04
200	128	147.72	-19.72
350	181	149.92	31.07
450	153	149.99	3
			SUM of RESIDUALS = 14.83

CAPSULE Z

CVGRAPH 4.1 Hyperbolic Tangent Curve Printed at 13:43:31 on 12-21-1998

Page 1

Coefficients of Curve 5

A = 67.59	B = 65.4	C = 61.26	T0 = 15.46
-----------	----------	-----------	------------

Equation is: $CVN = A + B * [\tanh((T - T_0)/C)]$


Upper Shelf Energy: 133 Fixed Temp. at 30 ft-lbs: -24.6 Temp. at 50 ft-lbs: -1.4 Lower Shelf Energy: 2.19 Fixed

Material: WELD

Heat Number: BOLA

Orientation:

Capsule: Z Total Fluence:



Data Set(s) Plotted
 Plant: FA2 Cap: Z Material: WELD Ori: Heat #: BOLA

Charpy V-Notch Data

Temperature	Input CVN Energy	Computed CVN Energy	Differential
-100	4	5.14	-1.14
-60	7	12.46	-5.46
-30	10	26.36	-16.36
0	72	51.43	20.56
0	13	51.43	-38.43
5	86	56.53	29.46

**** Data continued on next page ****

CAPSULE Z

Page 2

Material: WELD

Heat Number: BOLA

Orientation:

Capsule: Z

Total Fluence:

Charpy V-Notch Data (Continued)

Temperature	Input CVN Energy	Computed CVN Energy	Differential
15	77	67.09	9.9
15	57	67.09	-10.09
25	86	77.69	8.3
30	91	82.82	8.17
50	88	100.99	-12.99
100	105	125.2	-20.2
150	123	131.4	-8.4
195	151	132.62	18.37
250	124	132.93	-8.93

SUM of RESIDUALS = -27.26

UNIRRADIATED

CVGRAPH 4.1 Hyperbolic Tangent Curve Printed at 17:04:10 on 12-21-1998

Page 1

Coefficients of Curve 1

A = 46.67	B = 45.67	C = 52.29	T0 = -93.7
-----------	-----------	-----------	------------

Equation is: $LE = A + B * [\tanh((T - T_0)/C)]$

Upper Shelf LE: 92.34

Temperature at LE 35: -23

Lower Shelf LE: 1 Fixed


Material: WELD

Heat Number: BOLA

Orientation:

Capsule: UNIRR

Total Fluence:



Data Set(s) Plotted
 Plant: FA2 Cap: UNIRR Material: WELD Ori: Heat #: BOLA

Charpy V-Notch Data

Temperature	Input Lateral Expansion	Computed LE	Differential
-100	7	3.76	3.23
-50	15	16.94	-1.94
-25	35	33.41	1.58
-10	44	46.12	-2.12
10	73	62.85	10.14
25	60	73	-13
40	80	80.33	-3.33
50	89	83.79	5.2
75	92	88.85	3.14

**** Data continued on next page ****

UNIRRADIATED

Page 2

Material: WELD

Heat Number: BOLA

Orientation:

Capsule: UNIRR

Total Fluence:

Charpy V-Notch Data (Continued)

Temperature	Input Lateral Expansion	Computed L.E.	Differential
100	91	90.96	.03
150	92	92.13	-.13
150	91	92.13	-1.13
175	90	92.26	-2.26
210	92	92.32	-.32
210	93	92.32	.67
210	91	92.32	-1.32

SUM of RESIDUALS = 1.42

CAPSULE U (WELD)

CVGRAPH 4.1 Hyperbolic Tangent Curve Printed at 17:04:10 on 12-21-1998

Page 1

Coefficients of Curve 2

A = 46.23	B = 45.23	C = 83.1	T0 = -22.96
-----------	-----------	----------	-------------

Equation is: $LE = A + B * [\tanh((T - T0)/C)]$

Upper Shelf LE: 91.47

Temperature at LE 35: -44

Lower Shelf LE: 1 Fixed


Material: WELD

Heat Number: BOLA

Orientation:

Capsule: U

Total Fluence:



Data Set(s) Plotted
 Plant: FA2 Cap: U Material: WELD Ori: Heat #: BOLA

Charpy V-Notch Data

Temperature	Input Lateral Expansion	Computed L.E.	Differential
-50	16	32.02	-16.02
-25	68	45.13	22.86
0	32	58.43	-26.43
0	77	58.43	18.56
25	74	69.78	4.21
50	70	78.14	-8.14
50	78	78.14	-14
75	85	83.65	1.34

**** Data continued on next page ****

CAPSULE U (WELD)

Page 2

Material: WELD

Heat Number: BOLA

Orientation:

Capsule: U

Total Fluence:

Charpy V-Notch Data (Continued)

Temperature	Input Lateral Expansion	Computed L.E.	Differential
100	81	87.01	-6.01
125	92	88.97	3.02
150	92	90.08	1.91
175	91	90.7	.29
200	91	91.05	-.05
250	90	91.34	-1.34
300	96	91.43	4.56
			SUM of RESIDUALS = -1.36

CAPSULE W (WELD)

CVGRAPH 4.1 Hyperbolic Tangent Curve Printed at 17:04:10 on 12-21-1998

Page 1

Coefficients of Curve 3


A = 43.37	B = 42.37	C = 67.52	T0 = -5.15
-----------	-----------	-----------	------------

Equation is: $LE = A + B * [\tanh((T - T0)/C)]$

Upper Shelf LE: 85.75 Temperature at LE 35: -18.6 Lower Shelf LE: 1 Fixed

Material: WELD Heat Number: BOLA Orientation:

Capsule: W Total Fluence:



Data Set(s) Plotted
 Plant: FA2 Cap: W Material: WELD Ori: Heat #: BOLA

Charpy V-Notch Data

Temperature	Input Lateral Expansion	Computed LE	Differential
-100	5	5.81	-81
-50	15	18.75	-3.75
-50	29	18.75	10.24
-25	41	31.27	9.72
0	42	46.6	-4.6
0	29	46.6	-17.6
25	71	61.13	9.86
25	55	61.13	-6.13

**** Data continued on next page ****

CAPSULE W (WELD)

Page 2

Material: WELD

Heat Number: BOLA

Orientation:

Capsule: W

Total Fluence:

Charpy V-Notch Data (Continued)

Temperature	Input Lateral Expansion	Computed L.E.	Differential
50	81	71.91	9.08
76	79	78.73	.26
125	92	83.99	8
200	83	85.56	-2.56
250	93	85.71	7.28
350	83	85.75	-2.75
350	71	85.75	-14.75
			SUM of RESIDUALS = 1.5

CAPSULE X (WELD)

CVGRAPH 4.1 Hyperbolic Tangent Curve Printed at 17:04:10 on 12-21-1998

Page 1

Coefficients of Curve 4

A = 42.38	B = 41.38	C = 70.53	T0 = -17.18
-----------	-----------	-----------	-------------

Equation is: $LE = A + B * [\tanh((T - T0)/C)]$

Upper Shelf LE: 83.77

Temperature at LE 35: -29.9

Lower Shelf LE: 1 Fixed


Material: WELD

Heat Number: BOLA

Orientation:

Capsule: X

Total Fluence:



Plant: FA2 Cap: X Data Set(s) Plotted: Material: WELD Ori: Heat #: BOLA

Charpy V-Notch Data

Temperature	Input Lateral Expansion	Computed L.E.	Differential
-100	4	8.21	-4.21
-50	33	24.4	8.59
-50	24	24.4	-4
-40	22	29.44	-7.44
-25	40	37.81	2.18
-25	43	37.81	5.18
0	50	52.27	-2.27

**** Data continued on next page ****

CAPSULE X (WELD)

Page 2

Material: WELD

Heat Number: BOLA

Orientation:

Capsule: X

Total Fluence:

Charpy V-Notch Data (Continued)

Temperature	Input Lateral Expansion	Computed L.E.	Differential
0	52	52.27	-27
25	53	64.55	-11.55
50	80	73.04	6.95
100	92	80.89	11.1
200	85	83.59	1.4
350	80	83.76	-3.76
450	78	83.77	-5.77
			SUM of RESIDUALS = -2.8

CAPSULE Z (WELD)

CVGRAPH 4.1 Hyperbolic Tangent Curve Printed at 17:04:10 on 12-21-1998

Page 1

Coefficients of Curve 5


A = 40.8	B = 39.8	C = 39.93	T0 = 5.39
----------	----------	-----------	-----------

Equation is: $LE = A + B * [\tanh((T - T_0)/C)]$

Upper Shelf LE: 80.6 Temperature at LE 35: -4 Lower Shelf LE: 1 Fixed

Material: WELD Heat Number: BOLA Orientation:

Capsule: Z Total Fluence:



Plant: FA2 Cap: Z Data Set(s) Plotted: Material: WELD Ori: Heat #: BOLA

Charpy V-Notch Data

Temperature	Input Lateral Expansion	Computed LE	Differential
-100	0	14	-14
-60	1	3.9	-2.9
-30	7	12.56	-5.56
0	52	35.46	16.53
0	10	35.46	-25.46
5	58	40.41	17.58

**** Data continued on next page ****

CAPSULE Z (WELD)

Page 2

Material: WELD

Heat Number: BOLA

Orientation:

Capsule: Z

Total Fluence:

Charpy V-Notch Data (Continued)

Temperature	Input Lateral Expansion	Computed L.E.	Differential
15	55	50.19	4.8
15	42	50.19	-8.19
25	62	58.91	3.08
30	63	62.63	.36
50	61	72.9	-11.9
100	78	79.91	-1.91
150	84	80.54	3.45
195	81	80.59	.4
250	85	80.6	4.39
			SUM of RESIDUALS = -6.71

UNIRRADIATED (WELD)

CVGRAPH 4.1 Hyperbolic Tangent Curve Printed at 17:15:15 on 12-21-1998

Page 1

Coefficients of Curve 1

A = 50	B = 50	C = 62.37	T0 = -15
--------	--------	-----------	----------

Equation is: $\text{Shear}\% = A + B * [\tanh((T - T_0)/C)]$

Temperature at 50% Shear: -15


Material: WELD

Heat Number: BOLA

Orientation:

Capsule: UNIRR

Total Fluence:



Data Set(s) Plotted
 Plant: FA2 Cap: UNIRR Material: WELD Ori: Heat #: BOLA

Charpy V-Notch Data

Temperature	Input Percent Shear	Computed Percent Shear	Differential
-100	12	6.14	5.85
-50	30	24.56	5.43
-25	40	42.05	-2.05
-10	43	53.99	-10.99
10	80	69.03	10.96
25	72	78.28	-6.28
40	85	85.36	-3.36
50	94	88.93	5.06
75	100	94.71	5.28

**** Data continued on next page ****

UNIRRADIATED (WELD)

Page 2

Material: WELD

Heat Number: BOLA

Orientation:

Capsule: UNIRR

Total Fluence:

Charpy V-Notch Data (Continued)

Temperature	Input Percent Shear	Computed Percent Shear	Differential
100	100	97.55	2.44
150	100	99.49	.5
150	100	99.49	.5
175	100	99.77	.22
210	100	99.92	.07
210	100	99.92	.07
210	100	99.92	.07

SUM of RESIDUALS = 16.8

CAPSULE U (WELD)

CVGRAPH 4.1 Hyperbolic Tangent Curve Printed at 17:15:15 on 12-21-1998

Page 1

Coefficients of Curve 2

A = 50	B = 50	C = 76.93	T0 = -11.25
--------	--------	-----------	-------------

Equation is: $\text{Shear}\% = A + B * [\tanh((T - T0)/C)]$

Temperature at 50% Shear: -11.2


Material: WELD

Heat Number: BOLA

Orientation:

Capsule: U

Total Fluence:



Data Set(s) Plotted
 Plant: FA2 Cap: U Material: WELD Ori: Heat #: BOLA

Charpy V-Notch Data

Temperature	Input Percent Shear	Computed Percent Shear	Differential
-50	24	26.74	-2.74
-25	53	41.15	11.84
0	42	57.25	-15.25
0	64	57.25	6.74
25	67	71.95	-4.95
50	73	83.09	-10.09
50	91	83.09	7.9
75	99	90.39	8.6

**** Data continued on next page ****

CAPSULE U (WELD)

Page 2

Material: WELD

Heat Number: BOLA

Orientation:

Capsule: U

Total Fluence:

Charpy V-Notch Data (Continued)

Temperature	Input Percent Shear	Computed Percent Shear	Differential
100	98	94.74	3.25
125	100	97.18	2.81
150	100	98.51	1.48
175	100	99.21	.78
200	100	99.58	.41
250	100	99.88	.11
300	100	99.96	.03
			SUM of RESIDUALS = 10.92

CAPSULE W (WELD)

CVGRAPH 4.1 Hyperbolic Tangent Curve Printed at 17:15:15 on 12-21-1998

Page 1

Coefficients of Curve 3

A = 50	B = 50	C = 53.01	T0 = 1.87
--------	--------	-----------	-----------

Equation is: $\text{Shear}\% = A + B * [\tanh((T - T_0)/C)]$

Temperature at 50% Shear: 1.8


Material: WELD

Heat Number: BOLA

Orientation:

Capsule: W

Total Fluence:



Data Set(s) Plotted
 Plant: FA2 Cap: W Material: WELD Ori: Heat #: BOLA

Charpy V-Notch Data

Temperature	Input Percent Shear	Computed Percent Shear	Differential
-100	6	2.09	3.9
-50	13	12.37	.62
-50	21	12.37	8.62
-25	28	26.62	1.37
0	49	48.23	.76
0	37	48.23	-11.23
25	87	70.52	16.47
25	55	70.52	-15.52

**** Data continued on next page ****

CAPSULE W (WELD)

Page 2

Material: WELD

Heat Number: BOLA

Orientation:

Capsule: W

Total Fluence:

Charpy V-Notch Data (Continued)

Temperature	Input Percent Shear	Computed Percent Shear	Differential
50	94	86	7.99
76	97	94.24	2.75
125	100	99.04	.95
200	100	99.94	.05
250	100	99.99	0
350	100	99.99	0
350	100	99.99	0

SUM of RESIDUALS = 16.77

CAPSULE X (WELD)

CVGRAPH 4.1 Hyperbolic Tangent Curve Printed at 17:15:15 on 12-21-1998

Page 1

Coefficients of Curve 4

A = 50	B = 50	C = 64.71	T0 = -8.9
--------	--------	-----------	-----------

Equation is: $\text{Shear}\% = A + B * [\tanh((T - T_0)/C)]$

Temperature at 50% Shear: -8.9


Material: WELD

Heat Number: BOLA

Orientation:

Capsule: X

Total Fluence:



Data Set(s) Plotted
 Plant: FA2 Cap: X Material: WELD Ori: Heat #: BOLA

Charpy V-Notch Data

Temperature	Input Percent Shear	Computed Percent Shear	Differential
-100	4	5.64	-1.64
-50	30	21.92	8.07
-50	20	21.92	-1.92
-40	25	27.66	-2.66
-25	30	37.81	-7.81
-25	45	37.81	7.18
0	50	56.83	-6.83

**** Data continued on next page ****

CAPSULE X (WELD)

Page 2

Material: WELD

Heat Number: BOLA

Orientation:

Capsule: X

Total Fluence:

Charpy V-Notch Data (Continued)

Temperature	Input Percent Shear	Computed Percent Shear	Differential
0	65	56.83	8.16
25	65	74.03	-9.03
50	95	86.06	8.93
100	100	96.66	3.33
200	100	99.84	.15
350	100	99.99	0
450	100	99.99	0

SUM of RESIDUALS = 5.92

CAPSULE Z (WELD)

CVGRAPH 4.1 Hyperbolic Tangent Curve Printed at 17:15:15 on 12-21-1998

Page 1

Coefficients of Curve 5

A = 50	B = 50	C = 40.03	T0 = 15.93
--------	--------	-----------	------------

Equation is: $\text{Shear}\% = A + B * [\tanh((T - T_0)/C)]$

Temperature at 50% Shear: 15.9


Material: WELD

Heat Number: BOLA

Orientation:

Capsule: Z

Total Fluence:



Plant: FA2 Cap: Z Data Set(s) Plotted: Material: WELD Ori: Heat #: BOLA

Charpy V-Notch Data

Temperature	Input Percent Shear	Computed Percent Shear	Differential
-100	5	3	4.69
-60	10	2.2	7.79
-30	15	9.15	5.84
0	30	31.08	-1.08
0	20	31.08	-11.08
5	40	36.67	3.32

**** Data continued on next page ****

CAPSULE Z (WELD)

Page 2

Material: WELD

Heat Number: BOLA

Orientation:

Capsule: Z Total Fluence:

Charpy V-Notch Data (Continued)

Temperature	Input Percent Shear	Computed Percent Shear	Differential
15	45	48.82	-3.82
15	50	48.82	1.17
25	65	61.12	3.87
30	75	66.87	8.12
50	80	84.57	-4.57
100	90	98.52	-8.52
150	100	99.87	.12
195	100	99.98	.01
250	100	99.99	0
			SUM of RESIDUALS = 5.87

UNIRRADIATED (HEAT AFFECTED ZONE)

CVGRAPH 4.1 Hyperbolic Tangent Curve Printed at 14:52:36 on 12-21-1998

Page 1

Coefficients of Curve 1


A = 80.09	B = 77.9	C = 164.51	T0 = -49.76
-----------	----------	------------	-------------

Equation is: $CVN = A + B * [\tanh((T - T_0)/C)]$

Upper Shelf Energy: 158 Fixed Temp. at 30 ft-lbs: -175.3 Temp. at 50 ft-lbs: -116.8 Lower Shelf Energy: 2.19 Fixed

Material: HEAT AFFECTED ZONE Heat Number: B7212-1 Orientation:

Capsule: UNIRR Total Fluence:



Data Set(s) Plotted
 Plant: FA2 Cap: UNIRR Material: HEAT AFFECTED ZONE Ori: Heat #: B7212-1

Charpy V-Notch Data

Temperature	Input CVN Energy	Computed CVN Energy	Differential
-200	11	23.8	-12.8
-100	98	57.02	40.97
-100	40	57.02	-17.02
-50	98	79.98	18.01
-50	71	79.98	-8.98
20	44	111.28	-67.28
25	114	113.25	.74
50	136	122.29	13.7
75	123	129.96	-6.96

**** Data continued on next page ****

UNIRRADIATED (HEAT AFFECTED ZONE)

Page 2

Material: HEAT AFFECTED ZONE

Heat Number: B7212-1

Orientation:

Capsule: UNIRR

Total Fluence:

Charpy V-Notch Data (Continued)

Temperature	Input CVN Energy	Computed CVN Energy	Differential
100	191	136.28	54.71
150	159	145.37	13.62
210	86	151.64	-65.64
210	189	151.64	37.35
210	151	151.64	-64
			SUM of RESIDUALS = -22

CAPSULE U

CVGRAPH 4.1 Hyperbolic Tangent Curve Printed at 13:55:16 on 12-21-1998

Page 1

Coefficients of Curve 2

A = 56.59	B = 54.4	C = 77.23	T0 = -35.15
-----------	----------	-----------	-------------

Equation is: $CVN = A + B * [\tanh((T - T_0)/C)]$

Upper Shelf Energy: 111 Fixed Temp. at 30 ft-lbs: -76.4 Temp. at 50 ft-lbs: -44.5 Lower Shelf Energy: 2.19 Fixed


Material: HEAT AFFECTED ZONE

Heat Number: B7212-1 SIDE OF WELD

Orientation:

Capsule: U

Total Fluence:



Data Set(s) Plotted

Plant: FA2

Cap: U

Material: HEAT AFFECTED ZONE

Ori:

Heat #: B7212-1 SIDE OF WELD

Charpy V-Notch Data

Temperature	Input CVN Energy	Computed CVN Energy	Differential
-100	21	19.3	1.69
-50	30	46.27	-16.27
-25	76	63.71	12.28
0	68	79.78	-11.78
0	102	79.78	22.21
50	104	100.19	3.8
50	98	100.19	-2.19
75	58	105.06	-47.06

**** Data continued on next page ****

CAPSULE U

Page 2

Material: HEAT AFFECTED ZONE

Heat Number: B7212-1 SIDE OF WELD

Orientation:

Capsule: U Total Fluence:

Charpy V-Notch Data (Continued)

Temperature	Input CVN Energy	Computed CVN Energy	Differential
75	119	105.06	13.93
100	106	107.8	-1.8
125	125	109.3	15.69
175	108	110.53	-2.53
200	114	110.75	3.24
250	97	110.93	-13.93
300	108	110.98	-2.98
			SUM of RESIDUALS = -25.68

CAPSULE W (HAZ)

CVGRAPH 4.1 Hyperbolic Tangent Curve Printed at 16:41:00 on 12-21-1998

Page 1

Coefficients of Curve 1

A = 64.09	B = 61.9	C = 29.54	T0 = -9.37
-----------	----------	-----------	------------

Equation is: $CVN = A + B * [\tanh((T - T_0)/C)]$

Upper Shelf Energy: 126 Fixed Temp. at 30 ft-lbs: -27.6 Temp. at 50 ft-lbs: -16.2 Lower Shelf Energy: 2.19 Fixed


Material: HEAT AFFECTED ZONE

Heat Number: B7212-1 SIDE OF WELD

Orientation:

Capsule: W

Total Fluence:



Data Set(s) Plotted

Plant: FA2

Cap: W

Material: HEAT AFFECTED ZONE

Ori:

Heat #: B7212-1 SIDE OF WELD

Charpy V-Notch Data

Temperature	Input CVN Energy	Computed CVN Energy	Differential
-100	29	2.46	26.53
-100	20	2.46	17.53
-50	13	9.63	3.36
-50	5	9.63	-4.63
-25	79	34.1	44.89
-25	9	34.1	-25.1
-20	19	42.75	-23.75
0	119	83.1	35.89
0	53	83.1	-30.1

**** Data continued on next page ****

CAPSULE W (HAZ)

Page 2

Material: HEAT AFFECTED ZONE

Heat Number: B7212-1 SIDE OF WELD

Orientation:

Capsule: W Total Fluence:

Charpy V-Notch Data (Continued)

Temperature	Input CVN Energy	Computed CVN Energy	Differential
50	122	123.81	-1.81
76	132	125.61	6.38
125	120	125.98	-5.98
250	139	126	13
250	89	126	-37
350	155	126	29
			SUM of RESIDUALS = 48.18

CAPSULE X

CVGRAPH 4.1 Hyperbolic Tangent Curve Printed at 13:55:16 on 12-21-1998

Page 1

Coefficients of Curve 4


A = 65.09	B = 62.9	C = 67.24	T0 = -23.43
-----------	----------	-----------	-------------

Equation is: $CVN = A + B * [\tanh((T - T_0)/C)]$

Upper Shelf Energy: 128 Fixed Temp. at 30 ft-lbs: -65.7 Temp. at 50 ft-lbs: -39.9 Lower Shelf Energy: 2.19 Fixed

Material: HEAT AFF'D ZONE Heat Number: B7212-1 SIDE OF WELD Orientation:

Capsule: X Total Fluence:



Data Set(s) Plotted

Plant: FA2 Cap: X Material: HEAT AFF'D ZONE Ori: Heat #: B7212-1 SIDE OF WELD

Charpy V-Notch Data

Temperature	Input CVN Energy	Computed CVN Energy	Differential
-100	13	13.9	-9
-70	8	27.38	-19.38
-50	66	41.46	24.53
-50	38	41.46	-3.46
-40	59	49.91	9.08
-20	36	68.31	-32.31
0	110	86.17	23.82

**** Data continued on next page ****

CAPSULE X

Page 2

Material: HEAT AFFECTED ZONE

Heat Number: B7212-1 SIDE OF WELD

Orientation:

Capsule: X Total Fluence:

Charpy V-Notch Data (Continued)

Temperature	Input CVN Energy	Computed CVN Energy	Differential
0	135	86.17	48.82
0	27	86.17	-59.17
20	127	100.88	26.11
50	91	115.27	-24.27
125	92	126.49	-34.49
200	118	127.83	-9.83
250	126	127.96	-1.96
350	140	127.99	12
			SUM of RESIDUALS = -41.44

CAPSULE Z

CVGRAPH 4.1 Hyperbolic Tangent Curve Printed at 13:55:16 on 12-21-1998


Page 1

Coefficients of Curve 5

A = 64.09	B = 61.9	C = 76.31	T0 = 14.53
-----------	----------	-----------	------------

Equation is: $CVN = A + B * [\tanh((T - T_0)/C)]$

Upper Shelf Energy: 126 Fixed Temp. at 30 ft-lbs: -32.7 Temp. at 50 ft-lbs: -3.1 Lower Shelf Energy: 2.19 Fixed
 Material: HEAT AFFD ZONE Heat Number: B7212-1 SIDE OF WELD Orientation:
 Capsule: Z Total Fluence:



Data Set(s) Plotted

Plant: FA2 Cap: Z Material: HEAT AFFD ZONE Ori: Heat #: B7212-1 SIDE OF WELD

Charpy V-Notch Data

Temperature	Input CVN Energy	Computed CVN Energy	Differential
-100	8	8.06	-0.06
-60	16	17.57	-1.57
-30	20	31.59	-11.59
-20	68	37.85	30.14
-15	68	41.27	26.72
-10	42	44.86	-2.86

**** Data continued on next page ****

CAPSULE Z

Page 2

Material: HEAT AFFF ZONE

Heat Number: B7212-1 SIDE OF WELD

Orientation:

Capsule: Z Total Fluence:

Charpy V-Notch Data (Continued)

Temperature	Input CVN Energy	Computed CVN Energy	Differential
-10	8	44.86	-36.86
0	70	52.45	17.54
0	44	52.45	-8.45
10	7	60.42	-53.42
25	130	72.53	57.46
50	68	90.96	-22.96
100	122	114.08	7.91
150	115	122.54	-7.54
195	140	124.91	15.08
			SUM of RESIDUALS = 9.52

UNIRRADIATED (HAZ)

CVGRAPH 4.1 Hyperbolic Tangent Curve Printed at 09:35:32 on 12-22-1998

Page 1

Coefficients of Curve 1


A = 44.16	B = 43.16	C = 107.3	T0 = -88.12
-----------	-----------	-----------	-------------

Equation is: $LE = A + B * [\tanh((T - T_0)/C)]$

Upper Shelf LE: 87.32 Temperature at LE 35: -111.2 Lower Shelf LE: 1 Fixed

Material: HEAT AFFD ZONE Heat Number: B7212-1 SIDE OF WELD Orientation:

Capsule: UNIRR Total Fluence:



Data Set(s) Plotted

Plant: FA2 Cap: UNIRR Material: HEAT AFFD ZONE Ori: Heat #: B7212-1 SIDE OF WELD

Charpy V-Notch Data

Temperature	Input Lateral Expansion	Computed L.E.	Differential
-200	5	10.54	-5.54
-100	33	39.4	-6.4
-100	57	39.4	17.59
-50	46	58.88	-12.88
-50	60	58.88	1.11
20	73	77.17	-4.17
25	79	77.98	1.01
50	91	81.21	9.78
75	87	83.38	3.61

**** Data continued on next page ****

UNIRRADIATED (HAZ)

Page 2

Material: HEAT AFFECTED ZONE

Heat Number: B7212-1 SIDE OF WELD

Orientation:

Capsule: UNIRR

Total Fluence:

Charpy V-Notch Data (Continued)

Temperature	Input Lateral Expansion	Computed L.E.	Differential
100	81	84.81	-3.81
150	95	86.32	8.67
210	73	86.99	-13.99
210	91	86.99	4
210	87	86.99	0

SUM of RESIDUALS = -1.01

CAPSULE U (HAZ)

CVGRAPH 4.1 Hyperbolic Tangent Curve Printed at 17:23:24 on 12-21-1998

Page 1

Coefficients of Curve 2


A = 44.63	B = 43.63	C = 90.03	T0 = -39.37
-----------	-----------	-----------	-------------

Equation is: $LE = A + B * [\tanh((T - T_0)/C)]$

Upper Shelf LE: 88.27 Temperature at LE 35: -59.5 Lower Shelf LE: 1 Fixed

Material: HEAT AFFD ZONE Heat Number: B7212-1 SIDE OF WELD Orientation:

Capsule: U Total Fluence:



Data Set(s) Plotted

Plant: FA2 Cap: U Material: HEAT AFFD ZONE Ori: Heat #: B7212-1 SIDE OF WELD

Charpy V-Notch Data

Temperature	Input Lateral Expansion	Computed LE	Differential
-100	17	19.01	-2.01
-50	29	39.51	-10.51
-25	63	51.54	11.45
0	58	62.59	-4.59
0	75	62.59	12.4
50	83	77.73	5.26
50	70	77.73	-7.73
75	50	81.9	-31.9

**** Data continued on next page ****

CAPSULE U (HAZ)

Page 2

Material: HEAT AFFECTED ZONE

Heat Number: B7212-1 SIDE OF WELD

Orientation:

Capsule: U Total Fluence:

Charpy V-Notch Data (Continued)

Temperature	Input Lateral Expansion	Computed L.E.	Differential
75	89	81.9	7.09
100	89	84.5	4.49
125	93	86.07	6.92
175	89	87.53	1.46
200	90	87.85	2.14
250	88	88.13	-1.3
300	92	88.23	3.76
			SUM of RESIDUALS = -1.88

CAPSULE W (HAZ)

CVGRAPH 4.1 Hyperbolic Tangent Curve Printed at 17:23:24 on 12-21-1998

Page 1

Coefficients of Curve 3


A = 43.24	B = 42.24	C = 38.53	T0 = -12.65
-----------	-----------	-----------	-------------

Equation is: $LE = A + B * [\tanh((T - T_0)/C)]$

Upper Shelf LE: 85.49 Temperature at LE 35: -20.2 Lower Shelf LE: 1 Fixed

Material: HEAT AFFECTED ZONE Heat Number: B7212-1 SIDE OF WELD Orientation:

Capsule: W Total Fluence:



Data Set(s) Plotted

Plant: FA2 Cap: W Material: HEAT AFFECTED ZONE Ori: Heat #: B7212-1 SIDE OF WELD

Charpy V-Notch Data

Temperature	Input Lateral Expansion	Computed L.E.	Differential
-100	15	1.89	13.1
-100	17	1.89	15.1
-50	23	11.63	11.36
-50	10	11.63	-1.63
-25	57	30.15	26.84
-25	10	30.15	-20.15
-20	15	35.29	-20.29
0	80	56.64	23.35

**** Data continued on next page ****

CAPSULE W (HAZ)

Page 2

Material: HEAT AFFECTED ZONE

Heat Number: B7212-1 SIDE OF WELD

Orientation:

Capsule: W Total Fluence:

Charpy V-Notch Data (Continued)

Temperature	Input Lateral Expansion	Computed L.E.	Differential
0	41	56.64	-15.64
50	90	82.34	7.65
76	93	84.65	8.34
125	98	85.42	12.57
250	98	85.49	12.5
250	71	85.49	-14.49
350	99.5	85.49	14

SUM of RESIDUALS = 72.63

CAPSULE X (HAZ)

CVGRAPH 4.1 Hyperbolic Tangent Curve Printed at 17:23:24 on 12-21-1998

Page 1

Coefficients of Curve 4


A = 42.98	B = 41.98	C = 59.47	T0 = -25.31
-----------	-----------	-----------	-------------

Equation is: $LE = A + B * [\tanh((T - T_0)/C)]$

Upper Shelf LE: 84.97 Temperature at LE. 35: -36.7 Lower Shelf LE: 1 Fixed

Material: HEAT AFFD ZONE Heat Number: B7212-1 SIDE OF WELD Orientation:

Capsule: X Total Fluence:



Data Set(s) Plotted

Plant: FA2 Cap: X Material: HEAT AFFD ZONE Ori: Heat #: B7212-1 SIDE OF WELD

Charpy V-Notch Data

Temperature	Input Lateral Expansion	Computed LE	Differential
-100	9	73	169
-70	7	16.23	-9.28
-50	40	26.49	13.5
-50	23	26.49	-3.49
-40	40	32.82	7.17
-20	32	46.72	-14.72
0	15	59.84	-44.84

**** Data continued on next page ****

CAPSULE X (HAZ)

Page 2

Material: HEAT AFFECTED ZONE

Heat Number: B7212-1 SIDE OF WELD

Orientation:

Capsule: X Total Fluence:

Charpy V-Notch Data (Continued)

Temperature	Input Lateral Expansion	Computed L.E.	Differential
0	68	59.84	8.15
0	91	59.84	31.15
20	92	69.94	22.05
50	65	78.79	-13.79
125	76	84.44	-8.44
200	82	84.93	-2.93
250	90	84.96	5.03
350	94	84.97	9.02
			SUM of RESIDUALS = 27

CAPSULE Z (HAZ)

CVGRAPH 4.1 Hyperbolic Tangent Curve Printed at 18:06:04 on 12-21-1998

Page 1

Coefficients of Curve 5


A = 43.28	B = 42.28	C = 68.72	T0 = 18.75
-----------	-----------	-----------	------------

Equation is: $LE = A + B * [\tanh((T - T_0)/C)]$

Upper Shelf LE: 85.57 Temperature at LE 35: 5.1 Lower Shelf LE: 1 Fixed

Material: HEAT AFFD ZONE Heat Number: B7212-1 SIDE OF WELD Orientation:

Capsule: Z Total Fluence:



Data Set(s) Plotted

Plant: FA2 Cap: Z Material: HEAT AFFD ZONE Ori: Heat #: B7212-1 SIDE OF WELD

Charpy V-Notch Data

Temperature	Input Lateral Expansion	Computed LE	Differential
-100	2	3.58	-1.58
-60	5	8.76	-3.76
-30	9	17.48	-8.48
-20	46	21.68	24.31
-15	40	24.04	15.95
-10	26	26.56	-5.6

**** Data continued on next page ****

CAPSULE Z (HAZ)

Page 2

Material: HEAT AFFECTED ZONE

Heat Number: B7212-1 SIDE OF WELD

Orientation:

Capsule: Z Total Fluence:

Charpy V-Notch Data (Continued)

Temperature	Input Lateral Expansion	Computed LE	Differential
-10	26	26.49	-49
0	43	31.99	11
0	25	31.99	-6.99
10	1	37.93	-36.93
25	90	47.21	42.78
50	40	61.52	-21.52
100	87	78.69	8.3
150	88	84.16	3.83
195	79	85.47	-6.47
			SUM of RESIDUALS = -2.16

UNIRRADIATED (HAZ)

CVGRAPH 4.1 Hyperbolic Tangent Curve Printed at 09:33:55 on 12-22-1998

Page 1

Coefficients of Curve 1

A = 50	B = 50	C = 111.34	T0 = -67.03
--------	--------	------------	-------------

Equation is: $\text{Shear}\% = A + B * [\tanh((T - T_0)/C)]$

Temperature at 50% Shear: -67


Material: HEAT AFFD ZONE

Heat Number: B7212-1 SIDE OF WELD

Orientation:

Capsule: UNIRR

Total Fluence:



Data Set(s) Plotted

Plant: FA2

Cap: UNIRR

Material: HEAT AFFD ZONE

Ori:

Heat #: B7212-1 SIDE OF WELD

Charpy V-Notch Data

Temperature	Input Percent Shear	Computed Percent Shear	Differential
-200	8	8.4	-4
-100	42	35.61	6.38
-100	45	35.61	9.38
-50	34	57.58	-23.58
-50	60	57.58	2.41
20	82	82.68	-68
25	83	83.92	-92
50	100	89.11	10.88
75	100	92.76	7.23

**** Data continued on next page ****

UNIRRADIATED (HAZ)

Page 2

Material: HEAT AFFECTED ZONE

Heat Number: B7212-1 SIDE OF WELD

Orientation:

Capsule: UNIRR

Total Fluence:

Charpy V-Notch Data (Continued)

Temperature	Input Percent Shear	Computed Percent Shear	Differential
100	100	95.25	4.74
150	100	98.01	1.98
210	93	99.31	-6.31
210	100	99.31	.68
210	100	99.31	.68

SUM of RESIDUALS = 12.48

CAPSULE U (HAZ)

CVGRAPH 4.1 Hyperbolic Tangent Curve Printed at 18:26:40 on 12-21-1998

Page 1

Coefficients of Curve 2

A = 50	B = 50	C = 76.33	T0 = -28.12
--------	--------	-----------	-------------

Equation is: $\text{Shear}\% = A + B * [\tanh((T - T0)/C)]$

Temperature at 50% Shear: -28.1


Material: HEAT AFFECTED ZONE

Heat Number: B7212-1 SIDE OF WELD

Orientation:

Capsule: U

Total Fluence:



Data Set(s) Plotted

Plant: FA2 Cap: U Material: HEAT AFFECTED ZONE Ori: Heat #: B7212-1 SIDE OF WELD

Charpy V-Notch Data

Temperature	Input Percent Shear	Computed Percent Shear	Differential
-100	5	13.2	-8.2
-50	35	36.05	-1.05
-25	52	52.04	-0.4
0	62	67.63	-5.63
0	87	67.63	19.36
50	82	88.56	-6.56
50	84	88.56	-4.56
75	73	93.71	-20.71

*** Data continued on next page ***

CAPSULE U (HAZ)

Page 2

Material: HEAT AFFECTED ZONE

Heat Number: B7212-1 SIDE OF WELD

Orientation:

Capsule: U Total Fluence:

Charpy V-Notch Data (Continued)

Temperature	Input Percent Shear	Computed Percent Shear	Differential
75	100	93.71	6.28
100	100	96.63	3.36
125	100	98.22	1.77
175	100	99.51	.48
200	100	99.74	.25
250	100	99.93	.06
300	100	99.98	.01
			SUM of RESIDUALS = -15.15

CAPSULE W (HAZ)

CVGRAPH 4.1 Hyperbolic Tangent Curve Printed at 18:26:40 on 12-21-1998

Page 1

Coefficients of Curve 3

A = 50	B = 50	C = 27.31	T0 = -11.25
--------	--------	-----------	-------------

Equation is: $\text{Shear}\% = A + B * [\tanh((T - T_0)/C)]$

Temperature at 50% Shear: -11.2


Material: HEAT AFFECTED ZONE

Heat Number: B7212-1 SIDE OF WELD

Orientation:

Capsule: W

Total Fluence:



Data Set(s) Plotted

Plant: FA2 Cap: W Material: HEAT AFFECTED ZONE Ori: Heat #: B7212-1 SIDE OF WELD

Charpy V-Notch Data

Temperature	Input Percent Shear	Computed Percent Shear	Differential
-100	9	.15	8.84
-100	10	.15	9.84
-50	13	5.53	7.46
-50	9	5.53	3.46
-25	16	26.76	-10.76
-25	31	26.76	4.23
-20	35	34.51	.48
0	94	69.5	24.4°

**** Data continued on next page ****

CAPSULE W (HAZ)

Page 2

Material: HEAT AFFECTED ZONE

Heat Number: B7212-1 SIDE OF WELD

Orientation:

Capsule: W Total Fluence:

Charpy V-Notch Data (Continued)

Temperature	Input Percent Shear	Computed Percent Shear	Differential
0	49	69.5	-20.5
50	96	98.88	-2.88
76	97	99.83	-2.83
125	100	99.99	0
250	95	100	-5
250	100	100	0
350	100	100	0

SUM of RESIDUALS = 16.87

CAPSULE X (HAZ)

CVGRAPH 4.1 Hyperbolic Tangent Curve Printed at 18:26:40 on 12-21-1998

Page 1

Coefficients of Curve 4

A = 50	B = 50	C = 63.2	T0 = -15
--------	--------	----------	----------

Equation is: $\text{Shear}\% = A + B * [\tanh((T - T_0)/C)]$

Temperature at 50% Shear: -15


Material: HEAT AFFECTED ZONE

Heat Number: B7212-1 SIDE OF WELD

Orientation:

Capsule: X

Total Fluence:



Data Set(s) Plotted

Plant: FA2

Cap: X

Material: HEAT AFFECTED ZONE

Ori:

Heat #: B7212-1 SIDE OF WELD

Charpy V-Notch Data

Temperature	Input Percent Shear	Computed Percent Shear	Differential
-100	5	6.35	-1.35
-70	5	14.92	-9.92
-50	35	24.83	10.16
-50	20	24.83	-4.83
-40	35	31.19	3.8
-20	35	46.05	-11.05
0	25	61.64	-36.64

**** Data continued on next page ****

CAPSULE X (HAZ)

Page 2

Material: HEAT AFFECTED ZONE

Heat Number: B7212-1 SIDE OF WELD

Orientation:

Capsule: X Total Fluence:

Charpy V-Notch Data (Continued)

Temperature	Input Percent Shear	Computed Percent Shear	Differential
0	65	61.64	3.35
0	95	61.64	33.35
20	100	75.16	24.83
50	65	88.66	-23.66
125	75	98.82	-23.82
200	100	99.88	.11
250	100	99.97	.02
350	100	99.99	0
			SUM of RESIDUALS = -35.66

CAPSULE Z (HAZ)

CVGRAPH 4.1 Hyperbolic Tangent Curve Printed at 18:26:40 on 12-21-1998

Page 1

Coefficients of Curve 5

A = 50	B = 50	C = 71.04	T0 = 15.93
--------	--------	-----------	------------

Equation is: $Shear\% = A + B * [\tanh((T - T_0)/C)]$

Temperature at 50% Shear: 15.9


Material: HEAT AFFECTED ZONE

Heat Number: B7212-1 SIDE OF WELD

Orientation:

Capsule: Z

Total Fluence:



Data Set(s) Plotted

Plant: FA2

Cap: Z

Material: HEAT AFFECTED ZONE

Ori:

Heat #: B7212-1 SIDE OF WELD

Charpy V-Notch Data

Temperature	Input Percent Shear	Computed Percent Shear	Differential
-100	5	3.68	1.31
-60	20	10.54	9.45
-30	15	21.53	-6.53
-20	40	26.66	13.33
-15	45	29.5	15.49
-10	20	32.51	-12.51

**** Data continued on next page ****

CAPSULE Z (HAZ)

Page 2

Material: HEAT AFFECTED ZONE

Heat Number: B7212-1 SIDE OF WELD

Orientation:

Capsule: Z Total Fluence:

Charpy V-Notch Data (Continued)

Temperature	Input Percent Shear	Computed Percent Shear	Differential
-10	25	32.51	-7.51
0	50	38.96	11.03
0	25	38.96	-13.96
10	10	45.83	-35.83
25	100	56.34	43.65
50	55	72.29	-17.29
100	100	91.42	8.57
150	100	97.75	2.24
195	100	99.35	.64

SUM of RESIDUALS = 12.09

APPENDIX D

J. M. FARLEY UNIT 2 SURVEILLANCE PROGRAM
CREDIBILITY ANALYSIS

INTRODUCTION:

Regulatory Guide 1.99, Revision 2, and 10 CFR Part 50.61 describes general procedures acceptable to the NRC staff for calculating the effects of neutron radiation embrittlement of the low-alloy steels currently used for light-water-cooled reactor vessels. Position C.2 of Regulatory Guide 1.99, Revision 2, describes the method for calculating the adjusted reference temperature and Charpy upper-shelf energy of reactor vessel beltline materials using surveillance capsule data. The methods of Position C.2 can only be applied when two or more credible surveillance data sets become available from the reactor in question.

To date there has been four surveillance capsules removed from the J. M. Farley Unit 2 reactor vessel. To use these surveillance data sets, they must be shown to be credible. In accordance with the discussion of Regulatory Guide 1.99, Revision 2, and 10 CFR Part 50.61 there are five requirements that must be met for the surveillance data to be judged credible.

The purpose of this evaluation is to apply the credibility requirements of Regulatory Guide 1.99, Revision 2, and 10 CFR Part 50.61 to the J. M. Farley Unit 2 reactor vessel surveillance data and determine if the J. M. Farley Unit 2 surveillance data is credible.

EVALUATION

Criterion 1: Materials in the capsules should be those judged most likely to be controlling with regard to radiation embrittlement.

The beltline region of the reactor vessel is defined in Appendix G to 10 CFR Part 50, "Fracture Toughness Requirements", as follows:

"the reactor vessel (shell material including welds, heat affected zones, and plates or forgings) that directly surrounds the effective height of the active core and adjacent regions of the reactor vessel that are predicted to experience sufficient neutron radiation damage to be considered in the selection of the most limiting material with regard to radiation damage."

The J. M. Farley Unit 2 reactor vessel consists of the following beltline region materials:

- Intermediate shell plate B7203-1,
- Intermediate shell plate B7212-1,
- Lower shell plate B7210-2,
- Lower shell plate B7210-2,
- Intermediate shell longitudinal weld seam 19-923A (Heat # HODA)
- Intermediate shell longitudinal weld seam 19-923B (Heat # BOLA)
- Intermediate to lower shell circumferential weld seam 11-923 (Heat # 5P5622)
- Lower shell longitudinal weld seams 20-923 A & B (Heat # 83640)

Per WCAP-8956, the Farley Unit 2 surveillance program was based on ASTM E185-73, "Standard Recommended Practice for Surveillance Tests for Nuclear Reactor Vessels". Per Section 4.1 of ASTM E185-73, *"The base metal and weld metal to be included in the program should represent the material that may limit the operation of the reactor during its lifetime. The test material should be selected on the basis of initial transition temperature, upper shelf energy level, and estimated increase in transition temperature considering chemical composition (copper (Cu) and phosphorus (P)) and neutron fluence."*

At the time the Farley Unit 2 surveillance capsule program was developed, intermediate shell plate B7212-1 was judged to be most limiting and was therefore utilized in the surveillance program.

The Farley Unit 2 surveillance program weld was fabricated using the shielded metal arc welding process and E8018 stick electrodes, in a manner similar to that used to fabricate middle shell axial seams 19-923A (heat HODA) and B (heat BOLA). These electrodes were not copper-coated and do not exhibit the chemical variability found in copper-coated submerged arc weld wire. Although the surveillance weld material does not represent the limiting reactor vessel beltline weld, the results of mechanical property tests performed on the surveillance weld are considered to be representative of the property changes expected in the reactor vessel beltline seams. The NRC explicitly approved the selection of the Farley Unit 2 surveillance weld material on the basis that the limiting beltline material (i.e., intermediate plate B7212-1) was included in the surveillance program and conservative methods of analysis contained in Regulatory Guide 1.99 were available to predict the radiation characteristics of the limiting beltline weld. The NRC incorporated an exemption to the requirements of Appendix H to 10 CFR Part 50 in the Farley Unit 2 Operating License, thereby approving the selected surveillance weld material based on the NRC evaluation provided in Section 5.2.1 of NUREG-0117.

Although the Farley Unit 2 surveillance weld material does not meet the requirements of Criterion 1, conservative methods of analysis are available to predict the radiation characteristics of the limiting beltline weld. The limiting beltline plate material is intermediate plate B7212-1 which is more limiting than any of the reactor vessel beltline welds and is included in the reactor vessel material surveillance program. Therefore, the Farley Unit 2 reactor vessel material surveillance program provides assurance that the radiation damage to the vessel can be adequately determined and the integrity of the Farley Unit 2 reactor vessel will be ensured during normal plant operations and anticipated operational occurrences. Therefore, the Farley Unit 2 surveillance program meets this criteria.

Criterion 2: Scatter in the plots of Charpy energy versus temperature for the irradiated and unirradiated conditions should be small enough to permit the determination of the 30 ft-lb temperature and upper shelf energy unambiguously.

Plots of Charpy energy versus temperature for the unirradiated and irradiated condition are presented Section 5 of this report.

Based on engineering judgment, the scatter in the data presented in these plots is small enough to permit the determination of the 30 ft-lb temperature and the upper shelf energy of the J. M. Farley Unit 2 surveillance materials unambiguously. Hence, the J. M. Farley Unit 2 surveillance program meets this criterion.

Criterion 3: When there are two or more sets of surveillance data from one reactor, the scatter of ΔRT_{NDT} values about a best-fit line drawn as described in Regulatory Position 2.1 normally should be less than 28°F for welds and 17°F for base metal. Even if the fluence range is large (two or more orders of magnitude), the scatter should not exceed twice those values. Even if the data fail this criterion for use in shift calculations, they may be credible for determining decrease in upper shelf energy if the upper shelf can be clearly determined, following the definition given in ASTM E185-82.

The functional form of the least squares method as described in Regulatory Position 2.1 will be utilized to determine a best-fit line for this data and to determine if the scatter of these ΔRT_{NDT} values about this line is less than 28°F for welds and less than 17°F for the plate.

Following is the calculation of the best fit line as described in Regulatory Position 2.1 of Regulatory Guide 1.99, Revision 2.

TABLE D-1:
Calculation of the J. M. Farley Unit 2 Chemistry Factor Values
Based on Surveillance Capsule Data

Material	Capsule	Capsule $f^{(a)}$	FF ^(b)	$\Delta RT_{NDT}^{(c)}$	FF* ΔRT_{NDT}	FF ²	
Inter. Shell Plate B7212-1 (Longitudinal)	U	0.644	0.88	105.8	93.1	0.77	
	W	1.85	1.17	168.06	196.6	1.37	
	X	3.19	1.31	164.86	216.0	1.72	
	Z	5.28	1.41	200.24	282.3	1.99	
Inter. Shell Plate B7212-1 (Transverse)	U	0.644	0.88	124.01	109.1	0.77	
	W	1.85	1.17	168.18	196.9	1.37	
	X	3.19	1.31	200.01	262.0	1.72	
	Z	5.28	1.41	195.5	275.7	1.99	
	SUM:					1631.6	11.7
$CF_{B8628-1} = \sum(FF * RT_{NDT}) \div \sum(FF^2) = (1631.6) \div (11.7) = 139.5^{\circ}F$							
Surveillance Weld Material ^(d)	U ^(e)	0.644	0.88	0.0	0.0	0.77	
	W	1.85	1.17	6.7	7.8	1.37	
	X ^(e)	3.19	1.31	0.0	0.0	1.72	
	Z	5.28	1.41	10.0	14.1	1.99	
	SUM:					21.9	5.85
	$CF_{Surv. Weld} = \sum(FF * RT_{NDT}) \div \sum(FF^2) = (21.9) \div (5.85) = 3.7^{\circ}F$						

Notes:

- (a) f = Measured fluence from capsule Z dosimetry analysis results (See Section 6 of this report).
- (b) FF = fluence factor = $f^{(0.28 - 0.1 \cdot \log f)}$.
- (c) ΔRT_{NDT} values are the measured 30 ft-lb shift values (See Section 5 of this report).
- (d) These measured ΔRT_{NDT} values do not include the adjustment ratio procedure of Reg. Guide 1.99 Revision 2, Position 2.1, since this calculation is based on the actual surveillance weld metal measured shift values and based on the copper and nickel content the ratio would be 1 (i.e. 41/41 = 1). In addition, the only surveillance data available is from the J. M. Farley Unit 2 reactor vessel, therefore, no temperature adjustment is required.
- (e) The measured ΔRT_{NDT} values for capsules U and X are -28.7°F and -15.3°F, respectively. These values are assumed to be 0°F in this analysis since using the negative numbers will give a negative chemistry factor value and this should physically not happen. In addition, using 0°F will result in a higher chemistry factor for other calculations (i.e. PTS, P-T curves, etc.).

The scatter of ΔRT_{NDT} values about the functional form of a best-fit line drawn as described in Regulatory Position 2.1 is presented in Table D-2.

TABLE D-2

Best Fit Evaluation for J. M. Farley Unit 2 Surveillance Materials

Base Material	CF (°F)	FF	Measured ΔRT_{NDT} (30 ft-lb) (°F)	Best Fit ^(a) ΔRT_{NDT} (°F)	Scatter of ΔRT_{NDT} (°F)	< 17°F (Base Metals) < 28°F (Weld Metal)
Inter. Shell Plate B7212-1 (Longitudinal)	139.2	0.88	105.8	122.8	17	Yes
	139.2	1.17	168.06	163.2	-4.9	Yes
	139.2	1.31	164.86	182.7	17.8	No
	139.2	1.41	200.24	196.7	-3.5	Yes
Inter. Shell Plate B7212-1 (Transverse)	139.2	0.88	124.01	122.8	-1.2	Yes
	139.2	1.17	168.18	163.2	-5.0	Yes
	139.2	1.31	200.01	182.7	-17.3	No
	139.2	1.41	195.5	196.7	1.2	Yes
Surveillance Weld Metal	3.7	0.88	0.0	3.3	-3.3	Yes
	3.7	1.17	6.7	4.3	-2.4	Yes
	3.7	1.31	0.0	4.8	-4.8	Yes
	3.7	1.41	10.0	5.2	-4.8	Yes

NOTES:

(a) Best Fit Line Per Equation 2 of Reg. Guide 1.99 Rev. 2 Position 1.1.

Table D-2 indicates all the scatter is within the acceptable range for credible surveillance weld data. Therefore, the weld data meets this criteria.

Table D-2 indicates that one of the measured plate ΔRT_{NDT} values is below the lower bound 1σ of $17^\circ F$ by less than $1^\circ F$. This indicates that the best fit line would slightly over predict this measured ΔRT_{NDT} value. Table 2 also indicates that one of the measured ΔRT_{NDT} values is above the upper bound 1σ of $17^\circ F$ by less than $1^\circ F$. From a statistical point of view, $\pm 1\sigma$ ($17^\circ F$) would be expected to encompass 68% of the data. It is still statistically acceptable to have two of the data points fall outside the $\pm 1\sigma$ bounds. The fact that two of the measured ΔRT_{NDT} values are less than $1^\circ F$ outside of the 1σ bound of $17^\circ F$ can be attributed to several factors, such as 1) the inherent uncertainty in Charpy test data, 2) the use of a symmetric hyperbolic tangent Charpy curve fitting program versus an asymmetric hyperbolic tangent Charpy curve fitting program versus a hand drawn curve using engineering judgement, and/or 3) rounding errors.

Looking at the data given in Table 2, all measured ΔRT_{NDT} values are below or within the upper bound 1σ of $17^\circ F$ except one. The one data point that is above 1σ is only above by $.8^\circ F$. Hence, based on the above evaluation, the plate data meets the intent of this criteria.

The best fit surveillance data is shown graphically in Figures D-1 and D-1 which follow.

Figure D-1

Farley Unit 2 Intermediate Shell Plate B7212-1





Figure D-2

Farley Unit 2 Weld Metal Data



Criterion 4: The irradiation temperature of the Charpy specimens in the capsule should match the vessel wall temperature at the cladding/base metal interface within +/- 25°F.

The capsule specimens are located in the reactor between the core barrel and the vessel wall and are positioned opposite the center of the core. The test capsules are in baskets attached to the neutron pads. The location of the specimens with respect to the reactor vessel beltline provides assurance that the reactor vessel wall and the specimens experience equivalent operating conditions such that the temperatures will not differ by more than 25°F. Hence, this criteria is met.

Criterion 5: The surveillance data for the correlation monitor material in the capsule should fall within the scatter band of the data base for that material.

The J. M. Farley Unit 2 surveillance program does not contain correlation monitor material. Therefore, this criterion is not applicable to the J. M. Farley Unit 2 surveillance program.

CONCLUSION:

Based on the preceding responses to all five criteria of Regulatory Guide 1.99, Revision 2, Section B and 10 CFR 50.61, the J. M. Farley Unit 2 surveillance data is credible.