

***Preliminary Options for  
Risk-Informing 10 CFR 50.46  
and Large-Break LOCA DBA***

---

F. Eric Haskin  
ERI Consulting

Meeting with Westinghouse Owner's Group  
March 17, 2000

# References:

---

- Framework for Risk-Informing Regulations
    - ▶ Presented at Feb 24-25 public workshop
    - ▶ Available for review on NRC website
    - ▶ Proposes quantitative goals for four high-level defense in depth strategies
  
  - NUREG/CR-5750, “Rates of Initiating Events at U.S. Nuclear Power Plants: 1987 -1995”
    - ▶ Includes data and updated estimates of pipe break LOCA frequencies
-

# Relevant Data (NUREG/CR-5750)

---

- No reported medium or large NSSS pipe breaks in about 8000 worldwide reactor calendar years of operation
  - Throughwall cracks
    - ▶ PWRs
      - Dominant mechanism is thermal fatigue
      - One large (8" pipe), four medium (2" to 6" pipes)
    - ▶ BWRs
      - Dominant mechanism is intergranular stress corrosion cracking (IGSCC)
      - Most in recirculation bypass lines and riser pipe welds
      - 34 in large U.S. pipes
      - One since IGSCC mitigation efforts began in mid-1980s
  - Only 3 U.S. throughwall cracks discovered by leak detection systems while operating at power
-

# Estimating Large-Pipe-Break LOCA Frequencies (NUREG/CR-5750)

---

- Estimate through-wall crack frequency based on data
  - Adjust downward for IGSCC mitigation (BWRs)
  - Multiply by conservative estimate of probability of rupture given a through-wall crack based on
    - ▶ Technical review of information on fracture mechanics
    - ▶ Data on high-energy pipe failures and cracks
    - ▶ Assessments of pipe-break frequencies by others
    - ▶  $P_{R-TW} = \max(2.5/\text{diam}(\text{mm}), 0.01)$
-

# Estimated Large-Break LOCA Mean Frequencies

---

	BWR	PWR
■ WASH-1400	3e-4/yr	3e-4/yr
■ NUREG-1150	1e-4/yr	5e-4/yr
■ NUREG/CR-5750	2e-5/yr	4e-6/yr
■ Bayesian	—	2e-6/yr

---


# **NUREG/CR-5750**

## **Large-Break LOCA Frequencies**

---

- “Reasonable but conservative adjustment to previous estimates of pipe-break LOCA frequencies”
  - Seismic-induced LOCAs not discussed
  - NUREG/CR-5750 (page 39) suggests “an expert elicitation process could likely produce more definitive estimates” considering
    - ▶ Data
    - ▶ Fracture mechanics analyses
    - ▶ Pipe fracture experiments
    - ▶ Current operating, surveillance and maintenance practices
-

# NUREG/CR-5750 Figure 3-2



# **Preliminary Options: 50.46 and Large Break LOCA (sheet 1 of 3)**

---

- Relax Appendix K conservatisms, e.g.
    - ▶ Use current ANS decay-heat standard
    - ▶ Replace Baker-Just oxidation model
    - ▶ Etc.
    - ▶ Revised models would have to be approved
  
  - Modify acceptance criteria
    - ▶ Replace high-temperature and oxidation limits with embrittlement criterion
    - ▶ Note: high-burnup fuel has more pre-existing oxidation
-



# **Preliminary Options: 50.46 and Large Break LOCA (sheet 2 of 3)**

---

- **Make best-estimate analysis with uncertainty propagation less burdensome**
    - ▶ Hybrid approaches (e.g. SECY-83-472)
    - ▶ Automate audit analyses
    - ▶ Use more efficient uncertainty analysis schemes
  - **Treat break size and location probabilistically**
    - ▶ Propagate this uncertainty with others
  - **Relax simultaneous failure assumptions**
    - ▶ Double-ended large break
    - ▶ Loss of offsite power
    - ▶ Failure of one emergency AC power train
-

# Preliminary Options: 50.46 and Large Break LOCA (sheet 3 of 3)

---

- Eliminate very large breaks as DBA initiators
    - ▶ Framework currently implies frequency would have to be demonstrably less than  $1e-6/\text{yr}$
    - ▶ Might still retain as design basis event for containment
  - Risk-based definitions of AOOs and DBAs, for example (very preliminary)
    - ▶ Sequences with mean frequencies  $> f_1$  should not cause significant fuel failures (AOOs)
    - ▶ Sequences with mean frequencies between  $f_1$  and  $f_2$  should not cause risk-significant core damage or containment failure (DBAs)
    - ▶ Sequences with mean frequencies between  $f_2$  and  $f_3$  should not cause a large early release
-

# Questions for WOG

---

- Feedback on preliminary options for risk-informing 50.46 and large-LOCA DBA?
  - What changes would be proposed if
    - ▶ All large pipe breaks eliminated as DBA initiators?
    - ▶ Cold and hot leg breaks eliminated as DBA initiators?
    - ▶ All breaks  $>2 \text{ ft}^2$  eliminated as DBA initiators?
  - If the changes were implemented and a large LOCA occurred, what would be the probability of
    - ▶ Core melting?
    - ▶ Bottom head meltthrough?
    - ▶ Containment failure?
-