

**FLORIDA POWER CORPORATION
CRYSTAL RIVER UNIT 3
DOCKET NUMBER 50-302/LICENSE NUMBER DPR-72**

ATTACHMENT B

MONTHLY OPERATING REPORT

JANUARY 2000

REVISED APPENDIX A - OPERATING DATA REPORT

APPENDIX A OPERATING DATA REPORT

DOCKET NO. 50-302
UNIT NAME FLCRP-3
DATE February 3, 2000
COMPLETED BY L. J. Barbieri
TELEPHONE (352) 795-6486 x3761

REPORTING PERIOD (Month/Year): January 2000

	MONTH	YEAR TO DATE	CUMULATIVE
1 DESIGN ELECTRICAL RATING (MWe-Net)	825		
2 MAXIMUM DEPENDABLE CAPACITY (MWe-Net)	843		
3 NUMBER OF HOURS REACTOR WAS CRITICAL	744.0	744.0	133,760
4 NUMBER OF HOURS THE GENERATOR WAS ON LINE	744.0	744.0	131,527
5 UNIT RESERVE SHUTDOWN HOURS	0.0	0.0	0
6 NET ELECTRICAL ENERGY GENERATED (MWH)	634,149	634,149	100,891,490

NOTE:

Item 2, Maximum Dependable Capacity (MWe-Net) was increased from 818 to 843 due to changes/modifications that increased the plant output.