

Perry Nuclear Power Plant 10 Center Road Perry, Ohio 44081

John K. Wood Vice President, Nuclear 440-280-5224 Fax: 440-280-8029

January 18, 2000 PY-CEI/NRR-2459L

United States Nuclear Regulatory Commission Document Control Desk Washington, D.C. 20555

Perry Nuclear Power Plant Dockets Nos. 50-440 Submission of Exercise Scenario

Ladies and Gentlemen:

In keeping with the schedule established in Inspection Manual Procedure 82302, the scenario package for the March 21, 2000 Evaluated Exercise at the Perry Nuclear Power Plant (PNPP) is being submitted for approval review. Due to the confidential nature of the scenario package, copies of the scenario package have only been provided to the parties listed on the enclosed distribution list to ensure controlled access prior to the exercise.

The scenario package is not intended to drive any Nuclear Regulatory Commission (NRC) exercise activities. Therefore, no specific objectives are included for demonstration by NRC staff.

Comments from the NRC and Federal Emergency Management Agency (FEMA) on the proposed scenario package are requested by no later than February 21, 2000.

If you have any questions or require additional information, please contact David L. Bauguess, Emergency Planning Unit at (440) 280-5589.

Very truly yours,

Dlb/tls

Enclosure

cc: NRC Project Manager

NRC Resident Inspector

NRC Region III, Incident Response Center

JAH 2 - 2000

Enclosure PY-CEI/NRR-2459L January 20, 2000

<u>Distribution of Scenario Package for the March 21, 2000 Evaluated Exercise</u> at the Perry Nuclear Power Plant (PNPP)

Mr. Robert Jickling Emergency Preparedness Analyst U.S. Nuclear Regulatory Commission Region III 801 Warrenville Road Lisle, IL 60532-4351 (1 Copies) Mr. Jim Williams
Executive Director
Ohio Department of Public Safety
Ohio Emergency Management Agency
2855 West Dublin Granville Road
Columbus, OH 43235-2206
(3 Copies – for submittal to FEMA)

FIRST ENERGY CORPORATION PERRY NUCLEAR POWER PLANT

2000 EMERGENCY PREPAREDNESS EXERCISE

INTRODUCTION

To evaluate the state of emergency preparedness and to satisfy the requirements outlined in 10CFR50 Appendix E (Section IV.F.2.b-d), a full participation exercise will be conducted on March 21, 2000. This Exercise will be conducted jointly with the State of Ohio and Ashtabula, Geauga and Lake Counties. The conduct and evaluation of the Exercise also provides training for emergency response organization personnel and a means to further enhance First Energy Corporation's emergency response capability.

The enclosed Exercise Manual has been developed to provide the basis for the conduct of a simulated accident at the Perry Nuclear Power Plant Unit 1 facility, located in North Perry Village, Ohio. As such, the manual is to be utilized by the exercise controllers to initiate, control, and evaluate the activities of the participants in the exercise. Included in this manual are a general description and overview of the emergency exercise, the scenario, relevant data and time schedule of simulated plant conditions.

The Exercise Manual is subject to a limited, controlled distribution. <u>Exercise "players" will not</u> have prior knowledge of the nature of the simulated incident or any parts thereof.

As exercise efforts progress, changes may be required to the Exercise Manual. Any changes made to the Exercise Manual since the 60-day submittal will be identified during pre-exercise meetings.

PERRY NUCLEAR POWER PLANT 2000 EMERGENCY PREPAREDNESS EXERCISE

TABLE OF CONTENTS

INTRODUCTION TABLE OF CONTENTS

1.0 EXERCISE OBJECTIVES

- 1.1 Perry Plant Objectives
- 1.2 State of Ohio Objectives
- 1.3 Ashtabula County Objectives
- 1.4 Lake County Objectives
- 1.5 Geauga County Objectives

2.0 EXERCISE INFORMATION

- 2.1 Off-Site Action Locations
- 2.2 Onsite Exercise Organization
- 2.3 Onsite Emergency Response Facilities

3.0 GENERAL INFORMATION

- 3.1 Travel Information
- 3.2 Accommodations
- 3.3 Abbreviations
- 3.4 Definitions

4.0 CONTROLLER AND EVALUATOR INFORMATION

- 4.1 Controller Organization
- 4.2 Controller Telephone Numbers
- 4.3 Controller Briefing Materials
- 4.4 Plant Self Assessment Plan

5.0 SCHEDULE OF EVENTS

- 5.1 On-Site Perry Plant Schedule of Events
- 5.2 Off-Site State/Local County Schedule of Events

PERRY NUCLEAR POWER PLANT 1996 EMERGENCY PREPAREDNESS EXERCISE

TABLE OF CONTENTS

(Continued)

6.0 SCENARIO

- 6.1 Initial Conditions/Turnover Documents
- 6.2 (Perry Plant) Onsite Sequence of Events
- 6.3 Offsite Sequence of Events
- 6.4 Use of Simulator and ICS

7.0 MESSAGES/PLANT DATA

- 7.1 Player/Controller Message Summary
- 7.2 Plant Data Database (ICS)
- 7.3 EP INFO Line Database

8.0 RADIOLOGICAL DATA

- 8.1 In-Plant Radiation Data
- 8.2 Chemistry/Effluent Sample Data
- 8.3 Meteorological Data
- 8.4 On-Site Radiation Data
- 8.5 Dose Projection Data
- 8.6 Plume Maps/Field Team Data

9.0 PLANT MINI-SCENARIOS

10.0 PUBLIC INFORMATION MESSAGES

- 10.1 Public Information Questions
- 10.2 Media Monitor Scripts
- 10.3 County Public Access/Rumor Control Problems

11.0 OFF-SITE SCENARIOS

- 11.1 Potassium Iodide (KI) Demonstration
- 11.2 Off-Site Monitoring/Decontamination Centers and Stations
- 11.3 Lake County Medical Services Drill
- 11.4 Data for Evacuation Estimate

SECTION 1.0

EXERCISE OBJECTIVES

The following is contained in this section:

- Section 1.1 Perry Plant (On-Site) Objectives
- Section 1.2 State of Ohio Objectives
- Section 1.3 Ashtabula County Objectives
- Section 1.4 Lake County Objectives
- Section 1.5 Geauga County Objectives

PERRY NUCLEAR POWER PLANT FULL PARTICIPATION EXERCISE

OBJECTIVES

Section 1.1
Perry Plant Onsite Objectives

March 21, 2000

AFFECTED AREA	ITEM <u>NO.</u>	<u>OBJECTIVE</u>
Group A	Objectives:	EVENT CLASSIFICATION
CR	A.1	Demonstrate ability to effectively assess postulated plant indications, alarms and reports, and correctly classify an emergency event in a timely manner.
CR, TSC EOF	A.2	Demonstrate ability to correctly identify a series of postulated emergency events which escalate to a Site Area or General Emergency classification.
EOF	A.3	Demonstrate ability to correctly terminate from the emergency phase.
	Manag	ng Condition: A separate Recovery Director and Plant Recovery ger will be mobilized in support of Recovery planning. TSC and taffing used to support Emergency Phase response will establish the

framework of a Recovery Organization as outlined in EPI-A10.

AFFECTED AREA	ITEM <u>NO.</u>	OBJECTIVE
Group B Obje	ectives: ERO	NOTIFICATIONS/RESPONSE
CR, TSC SAS	B.1	Demonstrate ability to notify on-call ERO personnel in a timely manner upon (re)classification of an emergency event.
TSC, OSC EOF, PIRT JPIC	B.2	Demonstrate ability to adequately staff and activate facilities promptly in support of postulated emergency conditions.
TSC, OSC	B.3	Demonstrate ability to augment staffing in support of postulated emergency conditions.
CR, TSC EOF	B.4	Demonstrate ability to effectively direct the activation of emergency facilities in a timely manner when required by procedure or warranted based on postulated events.
EOF. TSC	B.9	Demonstrate the ability to coordinate with and support NRC regional site team activities.

AFFECTEI <u>AREA</u>	O ITEM NO.	<u>OBJECTIVE</u>
Group C Ob	ojectives: OFF	SITE NOTIFICATIONS
CR, TSC, EOF	C.1	Demonstrate ability to notify the State of Ohio and local counties within 15 minutes of initially declaring and reclassifying an emergency event.
CR, TSC, EOF	C.2	Demonstrate ability to notify the NRC within one hour of initially declaring or reclassifying an emergency event.
CR, TSC, EOF	C.3	Demonstrate ability to periodically update Federal, State and local county officials, and agencies on the status of emergency based on available information.
CR, TSC, EOF	C.4	Demonstrate ability to maintain an open line over the ENS and "5-way" circuits and respond to inquiries promptly.
	conta	ting Condition: "5-Way" Circuit or alternate methods will be used to act actual State and local county points of contact. A phone cell will ed to simulate communications and interactions with the NRC.
CR, TSC EOF	C.6	Demonstrate ability to effectively transfer responsibility for ENS and "5-way" circuits between facilities.
TSC, EOF	C.7	Demonstrate ability to notify and periodically update utility support organizations (e.g., INPO, NEIL) as required.
	<u>Limit</u> 1. 2.	No specific timeframe is established at the Alert classification for the notification of NEIL and INPO. Therefore, initial contact with these organizations is expected to be turned over to the TSC from the Control Room Simulator. Actual calls will be placed to the INPO Incident Response Center. However, notifications to NEIL will be via a control cell with telephone numbers pre-established with participants as an initial condition.
EOF	C.8	Demonstrate mechanism for recommending protective actions to State and local county authorities.

Group D Objectives: EMERGENCY COMMUNICATIONS

AFFECTED AREA	ITEM NO.	<u>OBJECTIVE</u>
CR, TSC OSC, EOF PIRT, JPIC	D.1	Demonstrate ability to communicate clearly and effectively between onsite facilities.
CR, SAS OSC	D.2	Demonstrate ability to communicate clearly and effectively with shift and OSC repair/assessment team personnel dispatched in-plant.
TSC, EOF	D.3	Demonstrate ability to communicate clearly and effectively with Radiation Monitoring Teams (RMTs).
CR, CAS	D.4	Demonstrate ability to effectively warn or advise Plant personnel or individuals onsite or in adjacent areas controlled by CEI utilizing the Plant Public Address (PA), and Exclusion Area Page Systems.
CR, TSC	D.6	Demonstrate ability to keep Corporate management informed of the emergency status EOF and coordinate Corporate support.

<u>Limiting Condition:</u> Corporate response activities will be limited to notifications of plant status and requests for Corporate support.

AFFECTED AREA	ITEM <u>NO.</u>	<u>OBJECTIVE</u>
Group E Obje	ctives:	COMMAND AND CONTROL
CR	E.1	Demonstrate ability of Shift Supervisor to promptly assume and carry out duties of the Emergency Coordinator upon the initial classification of an emergency event.
CR, TSC EOF	E.2	Demonstrate effective and orderly transfer of Emergency Coordinator duties between facilities.
CR, OSC, TSC, EOF	E.3	Demonstrate ability of key ERO personnel to coordinate, emergency assessment and response activities.
CR, TSC	E.4	Demonstrate ability to establish/revise in-plant ERO priorities and effectively utilize ERO personnel to address priorities.
CR, TSC, OSC, EOF PIRT, JPIC	E.5	Demonstrate ability to effectively coordinate facility activities and to update facility staff on event status, priorities, and expected actions.
OSC	E.6	Demonstrate ability to coordinate the assembly, effective briefing/debriefing, and timely dispatching of OSC teams.
OSC	E.7	Demonstrate ability to promptly access spare/replacement parts and deliver to OSC or in-plant repair teams.
		<u>Limiting Conditions:</u> No spare parts or equipment will be withdrawn from the warehouse inventory. Objective will be limited to communications with Material Handlers, searching of warehouse data bases, and delivery of simulated part to OSC or work area.
OSC, SECURITY	E.8	Demonstrate effective coordination of on-shift personnel (PPOs, Security Officers, etc.) and their integration with the ERO when mobilized.

AFFECTED ITEM

AREA NO. **OBJECTIVE**

Group E Objectives: COMMAND AND CONTROL (cont'd.)

TSC, EOF E.9 **RMT**

Demonstrate ability to effectively transfer dose assessment

responsibility and control of RMTs between facilities.

EOF, RMT E.10 Demonstrate ability to effectively control RMT movement in

relation to the release plume.

TSC, EOF E.11

Demonstrate ability of Plant, and State and local county

governments to work effectively and in a coordinated manner as

specified in the Plant Emergency Plan.

AFFECTED ITEM

AREA NO.

OBJECTIVE

Group F Objectives: ACCIDENT ASSESSMENT/RESPONSE

CR F. 1

Demonstrate timely and effective use of Plant Emergency Instructions (PEIs), Off-Normal Instructions (ONIs), and other operations procedures to respond to postulated indications,

alarms and reports.

Limiting Conditions: The exercise scenario was developed based on an anticipated operator response in accordance with plant procedures. Deviations from postulated response actions will be allowed by the controller organization if this action does not prevent the demonstration of objectives.

The purpose of the exercise is not to evaluate the adequacy of license operator training. Any concerns or questions regarding operator response to a postulated scenario event or casualty will be referred to Operations Training Unit (OTU) for resolution.

CR, TSC F.2 Demonstrate ability of the ERO to assess postulated equipment or component failures in a timely manner and effectively develop

corrective actions to mitigate events.

AFFECTED AREA	ITEM <u>NO.</u>	OBJECTIVE
Group F Obje	ctives: ACC	IDENT ASSESSMENT/RESPONSE (Contd.)
TSC, EOF	F.3	Demonstrate ability to identify the source of an actual or potential radiological release and postulated magnitude based on plant system parameters and effluent monitors.
TSC, EOF RMT	F.5	Demonstrate ability to mobilize and deploy RMTs in a timely manner.
RMT	F.6	Demonstrate appropriate equipment and procedures for determining ambient radiation levels.
RMT	F.7	Demonstrate appropriate equipment and procedures for measuring airborne radioactive concentrations as low as $10^{-7} \mu\text{Ci/cc}$ under field conditions in the presence of noble gases.
EOF	F.8	Demonstrate ability to project exposures based on plant effluent monitor readings and field data for various meteorological conditions.
EOF	F.9	Demonstrate ability to determine appropriate protective action recommendations for the general public based on NUREG-0654, Appendix 1 and EPA Protective Action Guidelines (PAGs).
EOF	F.10	Demonstrate ability for determining the source term for releases of radiological material within plant systems (i.e. relationship between containment radiation monitor readings and radioactive material available for release from containment).
EOF, RMT	F.12	Demonstrate ability to effectively track airborne radioactive plume using RMTs.

2000 EVEX

AFFECTED AREA	ITEM <u>NO.</u>	<u>OBJECTIVE</u>
Group F Obje	ectives:	ACCIDENT ASSESSMENT/RESPONSE (Contd.)
CR, TSC, OSC, EOF	F.16	Demonstrate onsite capability and resources to provide initial values and continuing assessment throughout the course of an accident, to include: Post Accident Sampling capability Radiation and effluent monitors In-plant radiation monitoring instrumentation Containment radiation monitoring
AFFECTED AREA	ITEM <u>NO.</u>	OBJECTIVE
Group G Obje	ctives: I	FACILITIES AND EQUIPMENT
CR, TSC,	G.1	Demonstrate effective operation and adequacy of facilities in the assessment and OSC, EOF, mitigation of a postulated emergency event.
CR, TSC OSC, EOF PIRT, JPIC	G.2	Demonstrate ability of key ERO personnel to perform the staffing responsibilities outlined in Table 8-1 of the Emergency Plan for the event postulated.
CR, TSC, PIRT, JPIC	G.5 ·	Demonstrate ability of facility staff to update/maintain status boards and other OSC, EOF, displays in an accurate and timely manner.
CR, TSC, EOF	G.6	Demonstrate ability of ERO staff to effectively use the Integrated Computer System (ICS) to monitor and assess plant conditions.
TSC, EOF	G.9	Demonstrate ability of TSC and EOF staff to place facility HVAC in emergency isolation mode.
TSC, EOF	G.10	Demonstrate ability of the TSC and EOF HVAC systems to adequately maintain facility temperature control within established limits.
AFFECTED	ITEM	

AREA

NO.

OBJECTIVE

Group G Objectives: FACILITIES AND EQUIPMENT (Contd.)

ALL

G.11

Demonstrate availability of equipment (including dosimetry and sampling devices) to effectively support facility operations, OSC teams, and RMTs.

Group H Objectives: ACCOUNTABILITY

SECURITY H.1

Demonstrate ability to account for all individuals within the Protected Area upon initiation of personnel accountability by ascertaining the names of missing individuals within 30 minutes and accounting for Protected Area personnel continuously thereafter

Limiting Condition: Personnel accountability will be demonstrated through the temporary evacuation of non-essential personnel from the Protected Area. Access back into the Protected Area will be allowed once accountability is accomplished.

Personnel required to support plant operation or exercise control and evaluation activities will be exempted from accountability. Exempted personnel will be identified to Site Protection prior to the exercise.

SECURITY H.6

Demonstrate ability to radiologically monitor individuals evacuating the Protected Area.

Group I Objectives:

EXPOSURE CONTROL

OSC

1.1

Demonstrate ability to effectively monitor and control emergency worker exposures per Plant procedures.

OSC, TSC, I.3

EOF

Demonstrate ability to assign personal dosimetry, effectively monitor exposure at appropriate frequencies, and maintain accurate dose records for Plant emergency workers.

Limiting Condition: Issuance of dosimetry to OSC staff at a Site Area Emergency per EPI-B11, OSC staff will be issued a TLD and low range dosimeter upon declaration of a Site Area Emergency. However, OSC staff requiring RRA access will continue to follow normal plant dosimetry requirements.

AFFECTED AREA	ITEM <u>NO.</u>	OBJECTIVE
Group I Object	ctives:	EXPOSURE CONTROL
OSC, HP	I.4	Demonstrate adequate equipment and procedures for decontamination of Plant emergency workers and equipment, and for waste disposal.
НР	I.5	Demonstrate onsite contamination control measures, including area access control, drinking water and food supplies, and criteria for permitting return of areas and items to normal use.
Group J Object	ctives:	MEDICAL RESPONSE
FAT	J.1	Demonstrate ability of onsite first aid responders to effectively assess a medical emergency and render appropriate medical care within their training in a timely manner.
FAT, HP	J.2	Demonstrate adequacy of health physics support in determining the radiological status of a victim and advising first aid responders on radiological concerns.
FAT	J.3	Demonstrate adequacy of facilities and equipment to support first aid responders.
FAT, SAS	J.4	Demonstrate ability to promptly notify and request offsite ambulance support for transportation of a victim.
SECURITY. FAT	J.5	Demonstrate organizational ability and procedures for Plant first aid responders, health physics, and security officers to effectively coordinate: ingress and egress to and from the Protected Area of an offsite ambulance; dress-out and radiological monitoring of the ambulance and crew, and transfer of a victim.
		imiting Conditions: Postulated injury will not justify ambulance areas

<u>Limiting Conditions:</u> Postulated injury will not justify ambulance crew access into the plant RRA. Therefore, transfer of victim from the FAT to Perry Township Fire Department will occur at the RRA Access Point.

AFFECTEI <u>AREA</u>	NO.	OBJECTIVE
Group J Obj	ectives:	MEDICAL RESPONSE (Cont'd.)
SAS	J.6	Demonstrate ability to notify and coordinate with a local medical facility for the care, handling and treatment of a contaminated and injured victim.
		<u>Limiting Condition:</u> Objective is limited to the notification of Lake East Hospital in Painesville, OH. Interface of plant Health Physics support with hospital staff will be evaluated under Lake County objectives per FEMA-REP-15.
Group K Ob	jectives:	PUBLIC INFORMATION/RUMOR CONTROL
JPIC	K.1	Demonstrate points of contact and physical locations for use by news media during an emergency.
JPIC	K.3	Demonstrate organizational ability and procedures to designate a spokesperson having access to necessary information, and arrange for a timely exchange of information among designated spokespersons.
JPIC	K.4	Demonstrate ability to brief media representatives in a clear, accurate and timely manner.
JPIC	K.5	Demonstrate ability to monitor the media to detect and correct errors.
PIRT, JPIC	K.6	Demonstrate ability of Company telephone attendants and personnel to reroute incoming inquiries regarding the emergency to the PIRT/JPIC.
		<u>Limiting Condition</u> : This objective is met by a controller calling directly into an ERO Facility and being directed to an appropriate facility/personnel.
JPIC	K.7	Demonstrate ability to establish and operate rumor control in a coordinated fashion.

AFFECTED ITEM

AREA NO. OBJECTIVE

Group I Objectives: EXPOSURE CONTROL

PIRT, JPIC K.8 Demonstrate ability of the PIRT/JPIC to disseminate information

to Company employees.

Group L Objectives: RECOVERY

TSC, EOF L.2 Demonstrate ability to formulate a Recovery Plan and identify a

Recovery Organization.

<u>Limiting Condition:</u> No additional callouts, with the exception of the Recovery Director and Plant Recovery Manager, will be made to support Recovery discussions. ERO personnel staffing the TSC and EOF during the Emergency Phase will be integrated into a Recovery Organization to

assist in the development of a preliminary Recovery Plan.

EOF L.3 Demonstrate ability to establish a method of periodically updating State and local county officials on plant recovery activities.

END OF LISTING

PERRY NUCLEAR POWER PLANT FULL PARTICIPATION EXERCISE

OBJECTIVES

Section 1.2 State of Ohio Objectives

March 21, 2000

GROUP A OBJECTIVES - CORE OBJECTIVES

OBJECTIVE 1: MOBILIZATION OF EMERGENCY PERSONNEL Demonstrate the ability to alert and fully mobilize personnel for both emergency facilities and field operations. Demonstrate the capability to activate and staff emergency facilities for emergency operations.

Objective Selected: Yes

Offsite Response Organizations:

American Red Cross Attorney General's Office Ohio Department of Agriculture Ohio Department of Health Ohio National Guard Ohio Department of Human Services

Ohio Department of Public Safety/Highway Patrol

Ohio Emergency Management Agency Ohio Department of Mental Health Ohio Department of Natural Resources Ohio Department of Transportation Ohio Environmental Protection Agency Public Utilities Commission of Ohio

Extent of Play:

The State will notify and mobilize all response agencies who have responsibilities in the State EOC (listed below). The field activities will be prepositioned. The following response functions will be staffed:

State EOC:

Executive Room Operations Room Assessment Room **Public Information** Rumor Control Communications

Security

Field Activities: Emergency Operations Facility

Joint Public Information Center

Field Monitoring Teams Field Sample Screening Point

Communications Van

OBJECTIVE 2: FACILITIES - EQUIPMENT, DISPLAYS, AND WORK ENVIRONMENT Demonstrate the adequacy of facilities, equipment, displays, and other materials to support emergency operations.

Objective Selected: Yes

Offsite Response Organization:

Ohio Emergency Management Agency

Extent of Play:

All facilities, equipment and displays at the locations listed in Objective 1 will be demonstrated. Backup power will be demonstrated in the EOC at a time mutually agreed upon by FEMA evaluators and Ohio EMA's communications section.

OBJECTIVE 3: DIRECTION AND CONTROL Demonstrate the ability to direct and control emergency operations.

Objective Selected: Yes

Offsite Response Organizations:

Ohio Department of Health

Ohio Emergency Management Agency

Extent of Play:

Overall direction and control of state activities will be demonstrated in the State EOC. The Executive Director of Ohio EMA will be positioned in the Executive Room and will coordinate decisions on behalf of the Governor's office. The Ohio Department of Health is responsible for operational functions in the Assessment Room.

<u>OBJECTIVE 4: COMMUNICATIONS</u> Demonstrate the capability to communicate with all appropriate emergency personnel at facilities and in the field.

Objective Selected: Yes

Offsite Response Organization:

Ohio Emergency Management Agency

Extent of Play:

The primary means of communications between the State EOC, County EOCs, Joint Public Information Center, and Emergency Operations Facility is telephone. The primary means of communications between the State EOC, Field Monitoring Teams and Field Sample Screening point is two-way radio. The state communications van will be located at Ledgemont Elementary School. Backup communications will be available during the exercise and will be demonstrated upon request or in case primary communications fail.

<u>OBJECTIVE 5: EMERGENCY WORKER EXPOSURE CONTROL</u> Demonstrate the capability to continuously monitor and control radiation exposure to emergency workers.

Objective Selected: Yes

Offsite Response Organizations:

Ohio Department of Health

Ohio Emergency Management Agency

Ohio Environmental Protection Agency

Extent of Play:

The State Assessment Room will monitor the exposure of the Field Monitoring Teams and the Sample Screening Point.

Previous ARCA: 47-96-A-05-03

Ensure that all group dosimetry kits contain a CDV-750 dosimeter charger and that the dosimeters are zeroed at the time of issuance and initial readings recorded.

Previous ARCA: 47-96-A-05-03

Ensure that all emergency workers are provided training in radiological exposure control.

<u>OBJECTIVE 6: FIELD RADIOLOGICAL MONITORING - AMBIENT RADIATION MONITORING</u> Demonstrate the appropriate use of equipment and procedures for determining field radiation measurements.

Objective Selected: Yes

Offsite Response Organization:

Ohio Emergency Management Agency

Ohio Department of Health

Extent of Play:

Two field radiological monitoring teams will participate in the exercise. The teams will be prepositioned at the Lake County EOC at the ALERT stage. The teams will function from that point in accordance with their SOPs.

<u>OBJECTIVE 7: PLUME DOSE PROJECTIONS</u> Demonstrate the capability to develop dose projections and protective action recommendations regarding evacuation and sheltering.

Objective Selected: Yes

Offsite Response Organizations:

Ohio Department of Health

Ohio Emergency Management Agency

Ohio Environmental Protection Agency

Extent of Play:

The State Assessment Room will be activated at the ALERT stage. Plume projections will be done on a computer using a dose assessment program specifically for the Perry Nuclear Power Plant. The backup is a battery operated laptop computer and will be demonstrated if requested.

Recommendations will then be forwarded to the Executive Group.

2000 EVEX Section 1.2 Page 3 of 9

OBJECTIVE 8: FIELD RADIOLOGICAL MONITORING - AIRBORNE RADIOIODINE AND PARTICULATE ACTIVITY MONITORING Demonstrate the appropriate use of equipment and procedures for the measurement of airborne radioiodine concentrations as low as 10^{-7} (0.0000001) microcuries per cubic centimeter in the presence of noble gases and obtain samples of particulate activity in the airborne plume.

Objective Selected: Yes

Offsite Response Organizations:

Ohio Department of Health

Ohio Emergency Management Agency

Ohio Environmental Protection Agency

Extent of Play:

As stated in Objective 6, the radiological monitoring teams will function in accordance with their procedures. However, charcoal cartridges will be used in the air samplers instead of the more costly silver zeolite filters.

Samples will be taken to the field sample screening point (located at Ledgemont Elementary School), but will not be transported to the lab in Columbus.

OBJECTIVE 9: PLUME PROTECTIVE ACTION DECISION MAKING Demonstrate the capability to make timely and appropriate protective action decisions (PAD).

Objective Selected: Yes

Offsite Response Organizations:

Ohio Department of Health

Ohio Emergency Management Agency

Ohio Environmental Protection Agency

Extent of Play:

The decision making process will take place in accordance with the State Plan. Protective Action Recommendations, animal advisories and emergency worker protective recommendations, including KI use, will be processed in the Assessment Room and forwarded to the Executive Room. Coordination will take place between the executive groups in the Ashtabula County, Geauga County, Lake County and State of Ohio EOCs. The recommendations will then be forwarded to the counties over the dedicated phone in the Assessment Room.

OBJECTIVE 10: ALERT AND NOTIFICATION Demonstrate the capability to promptly alert and notify the public within the 10-mile plume pathway emergency planning zone (EPZ) and disseminate instructional messages to the public on the basis of decisions by appropriate State or local officials.

Objective Selected: Yes

Offsite Response Organizations:

Ohio Emergency Management Agency

Extent of Play:

The State will consult with the county EOCs to determine the best immediate protective action for the populace. Once a decision is reached that requires the activation of the alert and notification system, Lake County will simulate the initiation of the sirens and the appropriate EAS message. (See Lake County Objective 10.)

OBJECTIVE 11: PUBLIC INSTRUCTIONS AND EMERGENCY INFORMATION Demonstrate the capability to coordinate the formulation and dissemination of accurate information and instructions to the public.

Objective Selected: Yes

Offsite Response Organizations:

Ohio Emergency Management Agency

Extent of Play:

Same as Objective 10.

<u>OBJECTIVE 12: EMERGENCY INFORMATION - MEDIA</u> Demonstrate the capability to coordinate the development and dissemination of clear, accurate, and timely information to the news media.

Objective Selected: Yes

Offsite Response Organizations:

Department of Public Safety Ohio Department of Health

Ohio Emergency Management Agency

Extent of Play:

The Ohio EMA PIO and a Health Department representative will be present at the JPIC (Lakeland Community College) to address protective actions being implemented and the activities taking place at the State level. Coordination will take place between state, county and utility PIOs. Public information representatives will be present in the State EOC to communicate with the JPIC.

OBJECTIVE 13: EMERGENCY INFORMATION - RUMOR CONTROL Demonstrate the capability to establish and operate rumor control in a coordinated and timely manner.

Objective Selected: Yes

Offsite Response Organization:

Ohio Emergency Management Agency

Extent of Play:

In accordance with the REP plan and SOPs, rumor control will be accomplished by establishing and publicizing a rumor control telephone number for the State EOC.

One Rumor Control Operator will be demonstrated during the exercise. A minimum of 12 rumor control messages will be inserted. The Rumor Control Operator will receive an average of 6 calls per hour for a two-hour period.

The Rumor Control Officer will be responsible for identifying trends. This information will be forwarded to the PIO at the JPIC.

GROUP B OBJECTIVES - SCENARIO DEPENDENT

OBJECTIVE 14: IMPLEMENTATION OF PROTECTIVE ACTION - USE OF POTASSIUM IODIDE (KI) FOR EMERGENCY WORKERS, INSTITUTIONALIZED PERSONS, AND THE GENERAL PUBLIC Demonstrate the capability and resources to implement potassium iodide (KI) protective actions for emergency workers, institutionalized individuals and, if the State plan specifies, the general public.

Objective Selected: Yes

Offsite Response Organization:

Ohio Emergency Management Agency

Ohio Department of Health

Extent of Play:

The Field Monitoring Teams will simulate the use of KI if recommended by ODH. The State plan does not specify the use of KI by the general public. All emergency workers have pre-distributed KI.

OBJECTIVE 15: IMPLEMENTATION OF PROTECTIVE ACTIONS - SPECIAL POPULATIONS

Demonstrate the capability and resources necessary to implement appropriate protective actions for special populations.

Objective Selected: No - This is a county function.

OBJECTIVE 16: IMPLEMENTATION OF PROTECTIVE ACTIONS - SCHOOLS Demonstrate the capability and resources necessary to implement protective actions for school children within the plume pathway emergency planning zone (EPZ).

Objective Selected: No - This is a county function.

OBJECTIVE 17: TRAFFIC AND ACCESS CONTROL Demonstrate the organizational capability and resources necessary to control evacuation traffic flow and to control access to evacuated and sheltered areas.

Objective Selected: No - This is a county function.

<u>OBJECTIVE 18: RECEPTION CENTER - MONITORING, DECONTAMINATION, AND REGISTRATION</u> Demonstrate the adequacy of procedures, facilities, equipment, and personnel for the radiological monitoring, decontamination, and registration of evacuees.

Objective Selected: No - This is a county function.

<u>OBJECTIVE 19: CONGREGATE CARE</u> Demonstrate the adequacy of facilities, equipment, supplies, personnel, and procedures for congregate care of evacuees.

Objective Selected: No - This is a county function.

OBJECTIVE 20: MEDICAL SERVICES - TRANSPORTATION Demonstrate the adequacy of vehicles, equipment, procedures, and personnel for transporting contaminated, injured, or radiologically exposed individuals.

Objective Selected: No - This is a county function.

OBJECTIVE 21: MEDICAL SERVICES - FACILITIES Demonstrate the adequacy of the equipment, procedures, supplies, and personnel of medical facilities responsible for treatment of contaminated, injured, or radiologically exposed individuals.

Objective Selected: No - This is a county function.

OBJECTIVE 22: EMERGENCY WORKERS, EQUIPMENT, AND VEHICLES - MONITORING AND DECONTAMINATION Demonstrate the adequacy of procedures for the monitoring and decontamination of emergency workers, equipment and vehicles.

Objective Selected: No - This is a county function.

GROUP C OBJECTIVES - SIX YEAR CYCLE

<u>OBJECTIVE 23: SUPPLEMENTARY ASSISTANCE (FEDERAL/OTHER)</u> Demonstrate the capability to identify the need for external assistance and to request such assistance from Federal or other support organizations.

Objective Selected: No - Last Demonstrated September 1996

OBJECTIVE 24: POST-EMERGENCY SAMPLING Demonstrate the use of equipment and procedures for collection and transportation of samples from areas that received deposition from the airborne plume.

Objective Selected: No - Last Demonstrated September 1996

<u>OBJECTIVE 25: LABORATORY OPERATIONS</u> Demonstrate laboratory operations and procedures for measuring and analyzing samples.

Objective Selected: No - Last Demonstrated September 1996

OBJECTIVE 26: INGESTION EXPOSURE PATHWAY - DOSE PROJECTION AND PROTECTIVE ACTION DECISION MAKING Demonstrate the capability to project dose to the public for ingestion exposure pathway and recommend protective actions.

Objective Selected: No - Last Demonstrated September 1996

OBJECTIVE 27: INGESTION EXPOSURE PATHWAY - PROTECTIVE ACTION IMPLEMENTATION Demonstrate the capability to implement protective actions for the ingestion exposure pathway.

Objective Selected: No - Last Demonstrated September 1996

OBJECTIVE 28: RELOCATION, RE-ENTRY, AND RETURN - DECISION MAKING Demonstrate the capability to develop decisions on relocation, re-entry, and return.

Objective Selected: No - Last Demonstrated September 1996

OBJECTIVE 29: RELOCATION, RE-ENTRY, AND RETURN - IMPLEMENTATION Demonstrate the capability to implement appropriate measures for relocation, re-entry and return.

Objective Selected: No - Last Demonstrated September 1996

OBJECTIVE 30: CONTINUOUS 24-HOUR STAFFING Demonstrate the capability to maintain staffing on a continuous, 24-hour basis through an actual shift change.

Objective Selected: No - Last Demonstrated June 1998

OBJECTIVE 31: OFFSITE SUPPORT FOR THE EVACUATION OF ONSITE PERSONNEL Demonstrate the capability to provide offsite support for the evacuation of onsite personnel.

Objective Selected: No - This is a county function.

OBJECTIVE 32: UNANNOUNCED EXERCISE OR DRILL Demonstrate the capability to carry out emergency response functions in an unannounced exercise or drill.

Objective Selected: No - Last Demonstrated June 1998

OBJECTIVE 33: OFF-HOURS EXERCISE OR DRILL response functions during an off-hours exercise or drill.

Objective Selected: No - Last Demonstrated June 1998

Ashtabula County, Ohio

Radiological Emergency Preparedness Exercise Objectives

Perry Nuclear Power Plant Evaluated Exercise March 2000

For the March 2000 Evaluated Exercise

Preparation Date: December 14, 1999

Group A Objectives, numbered 1-13. These are core objectives that should be demonstrated in every biennial exercise by all Offsite Response Organizations (OROs) that have responsibility for them.

Objective 1. MOBILIZATION OF EMERGENCY PERSONNEL

Demonstrate the capability to alert and fully mobilize personnel for both emergency facilities and field operations. Demonstrate the capability to activate and staff emergency facilities for emergency operations.

Objective selected: Yes
Offsite Response Organizations:

Ashtabula County Emergency Management Agency and Emergency Operations Center (EOC) Staff

Field Activity Participants:

American Red Cross
Amateur Radio
Conneaut Fire Department
Conneaut Police Department
Ohio State Highway Patrol
Geneva-on-the-Lake Fire Department

Extent of Play:

Ashtabula County EOC Staff will mobilize upon notification from the Ashtabula County Sheriff's Dispatch Center and EMA Staff. Full field notifications utilizing primary means of communications will be completed one time at the Site Area Emergency classification. All subsequent notifications will be simulated. All field agency demonstrations will be conducted out-of-sequence and participants will be pre-positioned.

Objective 2. FACILITIES - EQUIPMENT, DISPLAYS, AND WORK ENVIRONMENT

Demonstrate the adequacy of facilities, equipment, displays and other materials to support emergency operations.

Objective Selected: Yes
Offsite Response Organizations:

Ashtabula County Emergency Operations Center (EOC)

Extent of Play:

The Ashtabula County Emergency Operations Center (EOC) will demonstrate this objective. The Emergency Management Agency Director or designee at the EOC will show back-up power via a walk-down.

Objective 3. DIRECTION AND CONTROL

Demonstrate the capability to direct and control emergency operations.

Objective Selected: Yes
Offsite Response Organizations:

Ashtabula County EOC
American Red Cross
Conneaut Fire Department
Conneaut Police Department
Ohio State Highway Patrol
Geneva-on-the-Lake Fire Department

Extent of Play:

Direction and control of emergency operations will be demonstrated in accordance with the exercise scenario, the Ashtabula County Radiological Emergency Response Plan and as appropriate per out-of-sequence field demonstrations.

Objective 4. COMMUNICATIO NS

Demonstrate the capability to communicate with all appropriate emergency personnel at facilities and in the field.

Objective Selected: Yes
Offsite Response Organizations:

Ashtabula County EOC
Ashtabula County Sheriff's Department
American Red Cross
Amateur Radio
Conneaut Fire Department
Conneaut Police Department
Ohio State Highway Patrol
Geneva-on-the-Lake Fire Department

Extent of Play:

Primary (telephone) and secondary (radio/pagers) means of communications will be demonstrated at the EOC and as appropriate per out-of-sequence field demonstrations. Full notification of field agencies from the EOC will be conducted at the Site Area Emergency classification only. Exercise Controllers will drive out-of-sequence field play.

Objective 5. EMERGENCY WORKER EXPOSURE CONTROL

Demonstrate the capability to continuously monitor and control radiation exposure to emergency workers.

Objective Selected: Yes
Offsite Response Organizations:

Ashtabula County EOC Staff
Conneaut Fire Department
Conneaut Police Department
Ohio State Highway Patrol
Geneva-on-the-Lake Fire Department

Extent of Play:

The Ashtabula County EOC Radiological Officer will demonstrate radiation exposure control capabilities and issue dosimetry to the Public Information Officer. Dosimetry and exposure control procedures will be demonstrated by the above agencies during out-of-sequence exercise activities.

2000 EVEX

Objective 6. FIELD RADIOLOGICAL MONITORING - AMBIENT RADIATION MONITORING

Demonstrate the appropriate use of equipment and procedures for determining field radiation measurements.

Objective Selected: N/A

Objective 7. DOSE PROJECTION

Demonstrate the capability to develop dose projections and protective action recommendations regarding evacuation and sheltering.

Objective Selected: N/A

Objective 8. FIELD RADIOLOGICAL MONITORING - AIRBORNE RADIOIODINE AND PARTICULATE ACTIVITY MONITORING

Demonstrate the appropriate use of equipment and procedures for the measurement of airborne radioiodine concentrations as low as 10-7 (.0000001) micro-curies per cubic centimeter in the presence of noble gases and obtain samples of particulate activity in the airborne plume.

Objective Selected: N/A

Objective 9. PLUME PROTECTIVE ACTION DECISION MAKING

Demonstrate the capability to make timely and appropriate protective action decisions.

Objective Selected: Yes
Offsite Response Organizations:

Ashtabula County EOC Executive Group

Extent of Play:

Ashtabula County EOC Executive Group will demonstrate this objective in coordination with Lake and Geauga counties' Executive Groups and the State of Ohio.

Objective 10. ALERT AND NOTIFICATION

Demonstrate the capability to promptly alert and notify the public within the 10-mile plume pathway Emergency Planning Zone (EPZ) and disseminate instructional messages to the public on the basis of decisions by appropriate State or local officials.

Objective Selected: Yes
Offsite Response Organizations:

Ashtabula County EOC Staff Geneva-on-the-Lake Fire Department

Extent of Play:

Upon a protective action decision (PAD) by the combined Executive Groups of Ashtabula, Geauga, and Lake counties (start of the 15-minute clock), the Lake County EOC staff will prepare the appropriate Emergency Alert System (EAS) message and simulate sounding the sirens and sending the message over the EAS system. Lake County EOC will demonstrate a silent siren test in lieu of an actual siren sounding. A representative of the #1 Local Primary Station will be available for interview.

Simulation of sending the EAS message(s) will be conducted as follows:

The procedure for the EAS encoder will be followed to deliver the message to WTAM, the #1 Local Primary Station, with the exception that the telephone number to the station will not be dialed. By not connecting WTAM, there will be no possibility of accidentally broadcasting the message over one or more of the participating EAS stations. The "send" button on the Lake County EAS encoder will be depressed, and this action will activate the outgoing alert light and playback of the recorded message. Also, a data sheet will automatically be printed by the encoder and the time recorded on this data sheet shall be used as the official end of the 15-minute clock.

Lake County will FAX a copy of the EAS message(s) to the Joint Public Information Center (JPIC) where Public Information Officers (PIOs) may distribute hard copies to the news media representatives and may, if time and circumstances allow, make an announcement regarding the message. Otherwise, the EAS message can be announced at the next scheduled press briefing or in response to news media inquiries about the PAD message. In delivering information about the EAS message just released, the counties' PIOs may indicate that a corresponding Special News Bulletin (SNB) will be issued soon.

The Geneva-on-the-Lake Fire Department will demonstrate back-up route alerting as an out-of-sequence, pre-positioned field activity. One pre-determined siren located in Geneva-on-the-Lake Village (A-1) will be out-of-service (simulated) and back up route alerting will be conducted in the siren coverage area. Use of the mobile Public Address (PA) system will be simulated.

2000 EVEX Section 1.3 Page 5 of 14

Objective 11. PUBLIC INSTRUCTIONS AND EMERGENCY INFORMATION

Demonstrate the capability to coordinate the formulation and dissemination of accurate information and instructions to the public.

Objective Selected: Yes
Offsite Response Organizations:

Ashtabula County EOC Staff

Extent of Play:

Based upon the combined Protective Action Decisions (PADs) of the Executive Groups of Ashtabula, Geauga and Lake counties, the Lake County EOC staff will prepare and issue the appropriate EAS message(s) (See Objective 10; Extent of Play) and the corresponding Special News Bulletin(s) (SNB). Special News Bulletins are the very same message as their corresponding EAS message except that the SNBs are longer due to greater detail. Lake County will FAX the SNB(s) to the Joint Public Information Center (JPIC) where one of the PIOs from Ashtabula, Geauga, or Lake counties will represent the three counties by proceeding to the briefing room and reading the content of the message to the assembly of news media representatives and answer their questions pertaining to the message. This briefing should commence no sooner than 15-minutes after transmission of the EAS message from Lake County EOC to the Local Primary EAS Station. Hard copies of the SNB(s) will be distributed to the news media representatives.

Ashtabula, Geauga and Lake Counties will also coordinate release of other informational and instructional messages as necessary. Such messages may include Special Information Bulletins (SIB), which are a third category of prepared messages contained in the counties' "SOP for EAS Messages, Special News Bulletins, and Special Information Bulletins pertaining to the Perry Nuclear Power Plant". These SIBs are considered routine, meaning that they are to be delivered by one or more of the counties' PIOs at the next scheduled press briefing.

Previous Area Requiring Corrective Action (ARCA): Yes, Issue No.: 47-98-A-11-03.

Description: Ashtabula County modified a pre-scripted Special News Bulletin to include townships out to 16-miles from the Perry Nuclear Power Plant, but failed to include Hartsgrove Township, which was included in the precautionary action decision.

Corrective Action: Ashtabula County EOC Staff will check all information for the public against the "County Protective Action Decisions" form to ensure accuracy.

2000 EVEX Section 1.3 Page 6 of 14

Objective 12. EMERGENCY INFORMATION - MEDIA

Demonstrate the capability to coordinate the development and dissemination of clear, accurate, and timely information to the news media.

Objective Selected: Yes
Offsite Response Organizations:

Ashtabula County Public Information Officer (PIO) at the JPIC Ashtabula County PIO Liaison at the Ashtabula County EOC

Extent of Play:

The Ashtabula County Public Information Officer (PIO) will demonstrate this objective at the Joint Public Information Center (JPIC) in coordination with Lake and Geauga counties, the State of Ohio and the utility spokespersons. The JPIC is located at Lakeland Community College. Special News Bulletins (SNBs) will be issued by the Lake County EOC and presented to the news media by one of the counties' PIOs at the JPIC.

Previous ARCA: Yes, Issue No.: 47-98-A-12-04

Description: The Emergency Preparedness Information in the telephone directory was incomplete and did not include the required "educational information on radiation," and "protective measures, e.g., evacuation routes and relocation centers." Moreover, the Emergency Public Information brochure identified two congregate care centers (Braden Junior High School and Kent State University) on the list of centers, while the map of evacuation routes indicates, but does not name, the location of three other care centers (Rowe Middle School, Edgewood Senior High School, and Pymatuning Valley Middle School).

Corrective Action: Ashtabula County EMA has coordinated with the Perry Nuclear Power Plant, State of Ohio, and Lake and Geauga counties to ensure accurate and complete information is submitted to the public. Ashtabula County EMA has reviewed the Emergency Preparedness Information brochure and emergency information in local telephone directories prior to publication to ensure information is accurate and complete and in compliance with the provisions of NUREG-0654, G.1.

2000 EVEX

Objective 13. EMERGENCY INFORMATION - RUMOR CONTROL

Demonstrate the capability to establish and operate rumor control in a coordinated and timely manner.

Objective Selected: Yes
Offsite Response Organizations:

Ashtabula County EOC Staff

Extent of Play:

Ashtabula County Rumor Control operations are conducted from the Ashtabula County EOC. Appropriate EOC staff will respond to calls from an exercise-controller operated control cell for one hour, receiving approximately six calls. Additional calls outside the one-hour time frame may also be received.

Ashtabula County Rumor Control staff will identify any trends, reporting them to the Executive Group. Appropriate announcements will be developed in response to identified County specific trends. The PIO Liaison will forward this information to the Ashtabula County PIO at the JPIC.

Radio and television monitoring capabilities will be shown but not utilized, as no actual emergency public information messages will be broadcast.

GROUP B Objectives numbered 14-22. These objectives should be demonstrated in every biennial exercise by some organizations. OROs with responsibility for these objectives should demonstrate at least once every six years.

Objective 14.

IMPLEMENTATION OF PROTECTIVE ACTIONS - USE OF KI FOR EMERGENCY WORKERS, INSTITUTIONALIZED INDIVIDUALS, AND THE GENERAL PUBLIC

Demonstrate the capability to implement potassium iodide (KI) protective actions for emergency workers, institutionalized individuals, and if the State plan specifies the general public.

Objective Selected: Yes
Offsite Response Organizations:

Ashtabula County EOC Staff Conneaut Fire Department Ohio State Highway Patrol Geneva-on-the-Lake Fire Department

Extent of Play:

Ohio Department of Health (ODH) will make recommendations regarding the use of KI. Ashtabula County's preparedness measures for KI include pre-distribution to emergency response agencies. At the time of the emergency, the agencies distribute the KI and dosimetry to their individual emergency workers. If the ODH recommendation for use of KI excludes the Ashtabula County portion of the Emergency Planning Zone, demonstration of this objective may be facilitated by discussion with the Ashtabula County Radiological Officer at the EOC. For field agency demonstrations, KI procedures will be demonstrated by interview with exercise participants or, if necessary, by exercise controller inject.

Objective 15. IMPLEMENTATION OF PROTECTIVE ACTIONS - SPECIAL POPULATIONS

Demonstrate the capability and resources necessary to implement appropriate protective actions for special populations.

Objective Selected: Yes Offsite Response Organizations:

Ashtabula County EOC Staff

Extent of Play:

Notification to individuals with special needs within the Ashtabula County portion of the Emergency Planning Zone (EPZ) will be simulated. The Ashtabula County Emergency Management Agency maintains a list of special needs residents within the Ashtabula County portion of the EPZ. The Fire/EMS Officer and Human Services Officer at the EOC will coordinate special needs notification activities and upon request, will present the confidential list for review by the FEMA Evaluator.

Objective 16. IMPLEMENTATION OF PROTECTIVE ACTIONS - SCHOOLS

Demonstrate the capability and resources necessary to implement protective actions for school children within the plume pathway Emergency Planning Zone (EPZ).

Objective Selected: No

Objective 17. TRAFFIC AND ACCESS CONTROL

Demonstrate the organizational capability and resources necessary to control evacuation traffic flow and to control access to evacuated and sheltered areas.

Objective Selected: Yes
Offsite Response Organizations:

Ohio State Highway Patrol

Extent of Play:

An Access Control Point (ACP) located at State Routes 90 and 534 will be demonstrated out-of-sequence, pre-positioned by the Ohio State Highway Patrol. Traffic and access control procedures will be simulated.

2000 EVEX

Objective 18. RECEPTION CENTER MONITORING, DECONTAMINATION, AND REGISTRATION

Demonstrate the adequacy of procedures, facilities, equipment and personnel for the radiological monitoring, decontamination, and registration of evacuees.

Objective Selected: Yes
Offsite Response Organizations:

Conneaut Fire Department American Red Cross

Extent of Play:

Conneaut Fire Department will demonstrate this objective out-of-sequence, pre-positioned at the Conneaut Rowe Middle School care center. The demonstration will be initiated by exercise controller inject. One locker room will be fully set-up and demonstrated. A walk-through of the remaining locker room will be conducted upon request. A representative from the American Red Cross will describe registration procedures. Six monitoring demonstrations will be conducted using a portal monitor. One individual with simulated contamination will be walked through the monitoring/decontamination process, which includes a whole body monitoring using a CDV-700 survey meter retrofitted with a frisker probe. A controller will provide contamination levels. Decontamination will be simulated. Vehicle monitoring and decontamination procedures will be demonstrated by interview with representatives from the Conneaut Fire Department. No vehicle will be monitored or washed.

Objective 19. CONGREGATE CARE

Demonstrate the adequacy of facilities, equipment, supplies, personnel, and procedures for congregate care of evacuees.

Objective Selected: Yes
Offsite Response Organizations;

American Red Cross

Extent of Play:

Congregate care capabilities will be demonstrated out-of-sequence, by interview with representatives from the local American Red Cross Chapter at Conneaut Rowe Middle School Care Center. The American Red Cross personnel will provide a walk-through of the facility with description of congregate care capabilities.

2000 EVEX Section 1.3 Page 11 of 14

Objective 20. MEDICAL SERVICES - TRANSPORTATION

Demonstrate the adequacy of vehicles, equipment, procedures and personnel for transporting contaminated, injured, or exposed individuals.

Objective Selected: N/A

Objective 21. MEDICAL SERVICES - FACILITIES

Demonstrate the adequacy of the equipment, procedures, supplies, and personnel of medical facilities responsible for treatment of contaminated, injured, or exposed individuals.

Objective Selected: N/A

Objective 22. EMERGENCY WORKERS, EQUIPMENT, AND VEHICLES - MONITORING AND DECONTAMINATION

Demonstrate the adequacy of procedures for the monitoring and decontamination of emergency worker, equipment, and vehicles.

Objective Selected: No

Group C Objectives, numbered 23-33. These objectives should be demonstrated once every six years by each organization with responsibility for them.

Objective 23. SUPPLEMENTARY ASSISTANCE (FEDERAL/OTHER)

Demonstrate the capability to identify the need for external assistance and to request such assistance from Federal or other support organizations.

Objective Selected: N/A

Objective 24. POST-EMERGENCY SAMPLING

Demonstrate the use of equipment and procedures for the collection and transportation of samples from areas that received deposition from the airborne plume.

Objective Selected: N/A

2000 EVEX Section 1.3 Page 12 of 14

Objective 25. **LABORATORY OPERATIONS**

Demonstrate laboratory operations and procedures for measuring and analyzing samples.

Objective Selected: N/A

Objective 26. INGESTION EXPOSURE PATHWAY - DOSE PROJECTION AND PROTECTIVE ACTION DECISION MAKING

Demonstrate the capability to project dose to the public for the ingestion exposure pathway and to recommend protective actions.

Objective Selected: N/A

Objective 27. **INGESTION EXPOSURE PATHWAY - PROTECTIVE ACTION IMPLEMENTATION**

Demonstrate the capability to implement protective actions for the ingestion exposure pathway.

Objective Selected: N/A

Objective 28. RELOCATION, RE-ENTRY AND RETURN - DECISION MAKING

Demonstrate the capability to develop decisions on relocation, re-entry, and return.

Objective Selected: No

Objective 29. RELOCATION, RE-ENTRY AND RETURN - IMPLEMENTATION

Demonstrate the capability to implement appropriate measures for relocation, re-entry. and return.

Objective Selected: No

2000 EVEX Section 1.3 Page 13 of 14

Objective 30. CONTINUOUS, 24-HOUR STAFFING

Demonstrate the capability to maintain staffing on a continuous, 24-hour basis through an actual shift change.

Objective Selected: No

Objective 31. OFFSITE SUPPORT FOR THE EVACUATION OF ONSITE PERSONNEL

Demonstrate the capability to provide offsite support for the evacuation of onsite personnel.

Objective Selected: N/A

Objective 32. UNANNOUNCED EXERCISE OR DRILL

Demonstrate the capability to carry out emergency response functions in an unannounced exercise or drill.

Objective Selected: No

Objective 33. OFF-HOURS EXERCISE OR DRILL

Demonstrate the capability to carry out emergency response functions during an off-hours exercise or drill.

Objective Selected: No

2000 EVEX Section 1.3 Page 14 of 14

Lake County, Ohio

Radiological Emergency Preparedness Exercise Objectives

Perry Nuclear Power Plant Evaluated Exercise March 2000

OFF-SITE EXERCISE OBJECTIVES

March 2000 Evaluated Exercise Reference: FEMA Reps 14 and 15, September 1991

ORO Lake County

Preparation Date: 12-09-99

Group A Objectives, numbered 1-13. These are <u>core objectives</u> that should be demonstrated in every biennial exercise by all Offsite Response Organizations (OROs) that have responsibility for them.

Objective 1. MOBILIZATION OF EMERGENCY PERSONNEL

Demonstrate the capability to alert and fully mobilize personnel for both emergency facilities and field operations. Demonstrate the capability to activate and staff emergency facilities for emergency operations.

Objective selected: Yes

Offsite Response Organizations:

Lake County Emergency Management Agency (EMA) and Lake County Emergency Operation Center (EOC) Staff

Field Activity Participants:

American Red Cross
Kirtland City Fire Department
Leroy Twp. Fire Department
Perry Twp. Fire Department
Mentor City Fire Department

Painesville City School District
Painesville Twp. School District
Lake County Sheriff's Department
Lake East Hospital
Lake County Field Monitoring Teams

Extent of Play:

Lake County EOC Staff will mobilize upon notification from the Lake County Sheriff's Department Central Communication Center.

Full field notification utilizing primary means of communication will be completed one time, at <u>Site Area Emergency only</u>. All subsequent notifications will be simulated.

Field agencies involved in exercise play will demonstrate out-of-sequence and pre-positioned with three exceptions; Lake County Field Monitoring Team, Perry Township Fire Department, and Lake East Hospital will be mobilized.

Objective 2. FACILITIES - EQUIPMENT, DISPLAYS, AND WORK ENVIRONMENT

Demonstrate the adequacy of facilities, equipment, displays and other materials to support emergency operations.

Objective Selected: Yes

Offsite Response Organizations:

Lake County Emergency Operation Center

Extent of Play:

The Lake County Emergency Operations Center (EOC) will demonstrate this objective. Activation of back-up power and uninterrupted power supply (UPS) will be demonstrated..

Objective 3. DIRECTION AND CONTROL

Demonstrate the capability to direct and control emergency operations.

Objectives Selected: Yes

Offsite Response Organizations:

Lake County Emergency Operations Center

Field Activity Participants:

American Red Cross Kirtland City Fire Department Leroy Twp. Fire Department Mentor City Fire Department Perry Twp. Fire Department

Painesville Twp. School District Lake County Sheriff's Department Lake East Hospital Lake County Field Monitoring Teams

Painesville City School District Extent of Play:

This objective will be demonstrated according to the exercise scenario, the County RERP and, as appropriate, per out-of-sequence field demonstrations.

Objective 4. COMMUNICATIONS

Demonstrate the capability to communicate with all appropriate emergency personnel at facilities and in the field.

Objective Selected: Yes

Offsite Response Organizations:

Lake County Emergency Management Agency Lake County Emergency Operations Center

Field Activity Participants:

American Red Cross
Kirtland City Fire Department
Leroy Twp. Fire Department
Perry Twp. Fire Department
Mentor City Fire Department

Painesville City School District
Painesville Twp. School District
Lake County Sheriff's Department

Lake East Hospital

Lake County Field Monitoring Team

Page 3 of

Extent of Play:

Primary (telephone) and secondary (radio/pagers) means of communications will be demonstrated at the EOC and as appropriate per out-of-sequence field demonstrations.

Controllers will drive out-of-sequence field play.

Full notification from the EOC at Site Area Emergency only.

The American Red Cross will discuss back-up communication capabilities at the Kirtland High School Care Center.

2000 EVEX Section 1.4

Objective 5. EMERGENCY WORKER EXPOSURE CONTROL

Demonstrate the capability to continuously monitor and control radiation exposure to emergency workers.

Objective Selected: Yes

Offsite Response Organizations:

Lake County EOC Staff (as

applicable)

Kirtland City Fire Department

Leroy Twp. Fire Department

Perry Twp. Fire Department

Mentor City Fire Department

Painesville City School District Transportation Dept.

Painesville Twp. School District Transportation Dept.

Lake County Sheriff's Department

Lake East Hospital

Lake County Field Monitoring Team

Extent of Play:

The Lake County EOC Radiological Officer will demonstrate radiation exposure control capabilities.

Dosimetry and exposure control procedures will be demonstrated by the above field agencies during out-of-sequence field activities.

Previous Area Requiring Corrective Action (ARCA): Yes, Issue No.: 47-98-05-A-01

<u>Description</u> The Lake County Radiological Officer did not instruct the EOF Liaison to report to an Emergency Worker Monitoring and Decontamination Station after completion of his assignment as called for in the Personnel Dosimetry Instructions. Because of the close proximity of the EOF to the Perry Nuclear Power Plant, the EOF Liaison's vehicle would have likely been radiologically contaminated. (NUREG-0654;K.3,K.5)

Recommendation: The Lake County Radiological Officer will expressly refer to the Personnel Dosimetry Instructions in the Dosimetry briefing and cover each of the 13 items on the checklist in this briefing.

2000 EVEX Section 1.4 Page 4 of

Objective 6. FIELD RADIOLOGICAL MONITORING - AMBIENT RADIATION MONITORING

Demonstrate the appropriate use of equipment and procedures for determining field radiation measurements.

Objective Selected: Yes

Offsite Response Organizations:

Lake County Field Monitoring Teams

Extent of Play:

Lake County Health District will demonstrate the use of two Field Monitoring Teams (FMTs), in sequence.

Prior to the exercise, a FEMA evaluator will review contents of the FMT vehicles; an equipment inventory list will be provided to the evaluator to verify availability of supplies and equipment. At the conclusion of the equipment review, all seals will be replaced in order to indicate that all required supplies and equipment are contained within.

Objective 7. PLUME DOSE PROJECTION

Demonstrate the capability to develop dose projections and protective action recommendations regarding evacuation and sheltering.

Objective Selected: NA

Offsite Response Organizations:

Objective 8. FIELD RADIOLOGICAL MONITORING - AIRBORNE RADIOIODINE AND PARTICULATE ACTIVITY MONITORING

Demonstrate the appropriate use of equipment and procedures for the measurement of airborne radioiodine concentrations as low as 10-7 (.0000001) micro-curies per cubic centimeter in the presence of noble gases and obtain samples of particulate activity in the airborne plume.

Objective Selected: Yes

Offsite Response Organizations:

Lake County Health District Field Monitoring Teams (FMTs)

Extent of Play:

For the exercise, expired silver zeolite cartridges will be used; new cartridges will be available for the FEMA evaluator's observation.

Objective 9. PLUME PROTECTIVE ACTION DECISION MAKING

Demonstrate the capability to make timely and appropriate protective action decisions.

Objective Selected: Yes

Offsite Response Organization:

Lake County EOC Executive Group

Extent of Play:

This will be demonstrated by the Lake County EOC Executive Group in coordination with Ashtabula and Geauga counties' Executive Groups and the State of Ohio.

2000 EVEX Section 1.4 Page 6 of 20

Objective 10. ALERT AND NOTIFICATION

Demonstrate the capability to promptly alert and notify the public within the 10-mile plume pathway Emergency Planning Zone (EPZ) and disseminate instructional messages to the public on the basis of decisions by appropriate State or local officials.

Objective Selected: Yes

Offsite Response Organizations:

Lake County EOC Staff
Leroy Twp. Fire Department

Extent of Play:

Upon a protective action decision(s) (PAD) by the combined Executive Groups of Ashtabula, Geauga, and Lake counties (start of the 15 minute clock), the Lake County EOC staff will prepare the appropriate Emergency Alert System (EAS) message and simulate sounding the siren and sending the message over the EAS system. A silent siren test will be demonstrated in lieu of an actual siren sounding. A representative of the #1 Local Primary Station will be available for interview by an evaluator.

Simulation of sending the EAS message(s) will be conducted as follows:

The procedure for the EAS encoder will be followed to deliver the message to WTAM, the #1 Local Primary Station, with the exception that the telephone number to the station will not be dialed. By not connecting WTAM, there will be no possibility of accidentally broadcasting the message over one or more of the participating EAS stations. The "send" button on the Lake County EAS encoder will be depressed, and this action will activate the outgoing alert light and playback of the recorded message. Also, a data sheet will automatically be printed by the encoder and the time recorded on this data sheet shall be used as the official end of the 15-minute clock.

Lake County will FAX a copy of the EAS message(s) to the Joint Public Information Center (JPIC) where Public Information Officers (PIOs) may distribute hard copies to the news media representatives and may, if time and circumstances allow, make an announcement regarding the message. Otherwise, the EAS message can be announced at the next scheduled press briefing or in response to news media inquiries about the PAD and message. In delivering information about the EAS message just released, the counties' PIO's may indicate that a corresponding Special News Bulletin (SNB) will be issued soon.

One predetermined siren located in Leroy Township (L-22) will not sound (simulated) and back-up route alerting will be demonstrated. Back-up Route Alerting will be

2000 EVEX Section 1.4 Page 7 of 20

demonstrated out-of-sequence and pre-positioned; the mobile PA system will not be used. Agency demonstration will be initiated by exercise controller.

Notifications to individuals with special needs will be simulated by the Human Services Coordinator in the EOC in accordance with their SOP. A special needs list is maintained by the Lake County Human Services Department. The Human Services Coordinator will present the confidential list for review by the FEMA evaluator, upon request.

Objective 11. PUBLIC INSTRUCTIONS AND EMERGENCY INFORMATION

Demonstrate the capability to coordinate the formulation and dissemination of accurate information and instructions to the public.

Objective Selected: Yes

Offsite Response Organization:

Lake County EOC staff

Extent of Play:

Based upon the combined PAD(s) of the Executive Groups of Ashtabula, Geauga, and Lake counties, the Lake County EOC staff will prepare and issue the appropriate EAS message(s) (See Objective 10; Extent of Play) and the corresponding Special News Bulletin(s) (SNB). SNBs are the very same message as their corresponding EAS messages except that the SNBs are longer due to greater detail. Lake County will FAX the SNB(s) to the Joint Public Information Center (JPIC) where one of the PIOs from Ashtabula, Geauga, or Lake County will represent the three counties by proceeding to the briefing room and reading the content of the message to the assembly of news media representatives and answer their questions pertaining to the message. This briefing should commence no sooner than 15 minutes after transmission of the EAS message from the Lake County EOC to the Local Primary EAS Station. Hard copies of the SNB(s) will be distributed to the news media representatives.

Ashtabula, Geauga, and Lake counties will also coordinate release of other informational and instructional messages as they deem appropriate. Such messages may include Special Information Bulletins (SIB), which are a third category of prepared messages contained in the counties' "SOP for EAS Messages, Special News Bulletins, and Special Information Bulletins pertaining to the Perry Nuclear Power Plant." These SIBs are considered routine, meaning that they are to be delivered by one or more of the counties' PIO's at the next scheduled press briefing.

Page 8 of 20 Section 1.4 **2000 EVEX**

Objective 12. EMERGENCY INFORMATION - MEDIA

Demonstrate the capability to coordinate the development and dissemination of clear, accurate, and timely information to the news media.

Objective Selected: Yes

Offsite Response Organization:

Lake County Public Information Officer (PIO) at the JPIC Lake County PIO Liaison at the EOC

Extent of Play:

The Lake County Public Information Officer (PIO) will demonstrate this objective at the Joint Public Information Center (JPIC) in coordination with Geauga and Ashtabula counties' PIOs, the State of Ohio and the utility spokespersons. The JPIC is located at Lakeland Community College.

Special News Bulletins (SNBs) will be issued by the Lake County EOC and presented to the news media by one of the counties' PIOs at the JPIC.

Previous Area Requiring Corrective Action (ARCA): Yes, Issue No.: 47-98-A-12-02

Description: Press release 5 issued by Lake County incorrectly included on a list of "Care Centers Currently Open" two schools not designated in the Ashtabula County Emergency Management Plan as congregate care centers.

Corrective Action: Lake County EOC Staff will check all information for the public against the "County Protective Action Decisions" form to ensure accuracy.

Section 1.4 2000 EVEX Page 9 of 20

Objective 13. EMERGENCY INFORMATION - RUMOR CONTROL

Demonstrate the capability to establish and operate rumor control in a coordinated and timely manner.

Objective Selected: Yes

Offsite Response Organizations:

Lake County EOC Staff

Extent of Play:

Lake County Rumor Control operations are conducted from the Lake County EOC. Appropriate EOC staff will respond to telephone calls from an exercise controller-operated control cell for one hour; fielding approximately six calls. Additional calls outside the one-hour time frame may also be received. Rumor Control Staff will identify any trends and report them to the Executive Group. Appropriate announcements will be developed in response to identified County specific trends. The PIO Liaison will forward this information to the PIO at the JPIC.

Radio and television monitoring capability will be shown but not utilized, as no actual messages will be broadcast.

2000 EVEX Section 1.4 Page 10 of 20

GROUP B Objectives, numbered 14-22. These objectives should be demonstrated in every biennial exercise by some organizations. OROs with responsibility for these objectives should demonstrate at least once every six years.

Objective 14. IMPLEMENTATION OF PROTECTIVE ACTIONS - USE OF KI FOR EMERGENCY WORKERS, INSTITUTIONALIZED INDIVIDUALS, AND THE GENERAL PUBLIC

Demonstrate the capability to implement potassium iodide (KI) protective actions for emergency workers, institutionalized individuals, and if the State plan specifies, the general public.

Objective Selected: Yes Offsite Response Organization:

Lake County EOC Staff (as applicable)
Kirtland City Fire Department
Leroy Twp. Fire Department
Perry Twp. Fire Department
Mentor City Fire Department
Painesville City School District Transportation Department
Painesville Twp. School District Transportation Department
Lake County Sheriff's Department
Lake East Hospital
Lake County Field Monitoring Teams

Extent of Play:

Ohio Department of Health (ODH) will make recommendations regarding the use of KI. The county's preparedness measures for KI include pre-distribution to field response agencies so appropriate agencies routinely have KI on hand. At the time of an emergency, the agencies distribute the KI and dosimetry to their individual workers. For field agency demonstrations, KI procedures will be demonstrated by interview with exercise participants or by exercise controller inject.

2000 EVEX Section 1.4 Page 11 of 20

Objective 15.IMPLEMENTATION OF PROTECTIVE ACTIONS - SPECIAL POPULATIONS

Demonstrate the capability and resources necessary to implement appropriate protective actions for special populations.

Objective Selected: Yes

Offsite Response Organization:

Lake County EOC Staff

Extent of Play:

Notification to individuals with special needs within the Lake County portion of the EPZ will be simulated. A special needs list is maintained by the Lake County Human Services Department. The Human Services Coordinator will present the confidential list for review by the FEMA evaluator, upon request.

Objective 16. IMPLEMENTATION OF PROTECTIVE ACTIONS - SCHOOL

Demonstrate the capability and resources necessary to implement protective actions for school children within the plume pathway Emergency Planning Zone (EPZ).

Objective Selected: Yes

Offsite Response Organization:

Painesville City School District Painesville Twp. School District

Extent of Play:

The school districts will demonstrate this objective out-of-sequence, by interview with the superintendent, high school principal, transportation department; to include a bus operator. The use of dosimetry and KI will be discussed with transportation personnel only.

No movement of students or vehicles will occur.

2000 EVEX Section 1.4 Page 12 of 20

Objective 17. TRAFFIC AND ACCESS CONTROL

Demonstrate the organizational capability and resources necessary to control evacuation traffic flow and to control access to evacuated and sheltered areas.

Objective Selected: Yes

Offsite Response Organization:

Lake County Sheriff's Department

Extent of Play:

One pre-positioned Traffic Control Point (TCP) will be demonstrated with the Lake County Sheriff's Department at Rt.20 and Fairgrounds Road.

TCP will be demonstrated out-of-sequence.

No actual controlling of traffic will be demonstrated.

2000 EVEX Section 1.4 Page 13 of 20

Objective 18. RECEPTION CENTER MONITORING, DECONTAMINATION, AND REGISTRATION

Demonstrate the adequacy of procedures, facilities, equipment and personnel for the radiological monitoring, decontamination, and registration of evacuees.

Objective Selected: Yes

Offsite Response Organization:

American Red Cross Kirtland City Fire Department

Extent of Play:

Kirtland City Fire Department will demonstrate this objective out-of-sequence and pre-positioned at the Kirtland High School Care Center. The demonstration will be initiated by exercise controller inject. One locker room will be fully set up; a walk-through of the second locker room will be conducted, if requested. A representative from the American Red Cross will describe registration procedures.

Six monitoring demonstrations will be conducted using portable portal monitoring equipment. One individual with simulated contamination will be walked through the monitoring/decontamination process, which includes whole body monitoring using a CDV-700 survey meter, retrofitted with a frisker probe. Contamination levels will be provided by a controller. Decontamination will be simulated.

Vehicle monitoring and decontamination procedures will be demonstrated by interview with representatives from the Kirtland City Fire Department. No vehicle will be monitored or washed.

Objective 19. CONGREGATE CARE

Demonstrate the adequacy of facilities, equipment, supplies, personnel, and procedures for congregate care of evacuees.

Objective Selected: Yes

Offsite Response Organization:

American Red Cross

Extent of Play:

Congregate care capabilities will be demonstrated out-of-sequence by interview with an American Red Cross representative at the Kirtland High School Care Center. American Red Cross personnel will provide a walk-through of the facility with description of congregate care capabilities. No set-up of care center equipment or supplies will be demonstrated.

Objective 20. MEDICAL SERVICES - TRANSPORTATION

Demonstrate the adequacy of vehicles, equipment, procedures and personnel for transporting contaminated, injured, or exposed individuals.

Objective Selected: Yes

Offsite Response Organization:

Perry Twp. Fire Department

Extent of Play:

Will be demonstrated by the Perry Twp. Fire Department in-sequence with the on-site scenario. A simulated contaminated/injured victim from the Perry Power Plant will be transported to Lake East Hospital. No emergency lights and/or sirens will be used.

Dosimetry and survey instruments owned by the Perry Fire Department may be used in addition to that issued by the State of Ohio and the Utility.

2000 EVEX Section 1.4 Page 15 of 20

Objective 21. MEDICAL SERVICES - FACILITIES

Demonstrate the adequacy of the equipment, procedures, supplies, and personnel of medical facilities responsible for treatment of contaminated, injured, or exposed individuals.

Objective Selected: Yes

Offsite Response Organization:

Lake East Hospital

Extent of Play:

Hospital owned dosimetry may be used in addition to that issued by the State of Ohio.

Simulated radiation levels will be provided by a controller using a body map specifying contamination and post-decontamination levels.

Objective 22. EMERGENCY WORKERS, EQUIPMENT, AND VEHICLES - MONITORING AND DECONTAMINATION

Demonstrate the adequacy of procedures for the monitoring and decontamination of emergency worker, equipment, and vehicles.

Objective Selected: Yes

Offsite Response Organization:

Mentor City Fire Department

Extent of Play:

Mentor Fire Department will demonstrate this objective out-of-sequence, pre-positioned at the Mentor High School Football Stadium. One locker room will be fully set-up. A walk-through of the second locker room will be conducted, if requested. Brown craft paper will be used as a floor covering.

Two monitoring demonstrations will be conducted using portal monitoring equipment. Individuals with simulated contamination will then be monitored using the CDV-700 survey meter, retrofitted with a frisker pancake probe to determine the exact location of contamination and radiation levels. Decontamination of emergency workers will be simulated.

2000 EVEX Section 1.4 Page 16 of 20

Vehicle monitoring and decontamination procedures will be demonstrated by interview; no vehicle will be monitored or washed.

2000 EVEX Section 1.4 Page 17 of 20

Group C Objectives, numbered 23-33. These objectives should be demonstrated once every six years by each organization with responsibility for them.

Objective 23. SUPPLEMENTARY ASSISTANCE (FEDERAL/OTHER)

Demonstrate the capability to identify the need for external assistance and to request such assistance from Federal or other support organizations.

Objective Selected: N/A

Offsite Response Organization:

Extent of Play:

Objective 24. POST-EMERGENCY SAMPLING

Demonstrate the use of equipment and procedures for the collection and transportation of samples from areas that received deposition from the airborne plume.

Objective Selected: N/A

Offsite Response Organization:

Extent of Play:

Objective 25. LABORATORY OPERATIONS

Demonstrate laboratory operations and procedures for measuring and analyzing samples.

Objective Selected: N/A

Offsite Response Organization:

Objective 26. INGESTION EXPOSURE PATHWAY - DOSE PROJECTION AND PROTECTIVE ACTION DECISION MAKING

Demonstrate the capability to project dose to the public for the ingestion exposure pathway and to recommend protective actions.

Objective Selected: N/A

Offsite Response Organization:

Extent of Play:

Objective 27. INGESTION EXPOSURE PATHWAY - PROTECTIVE ACTION IMPLEMENTATION

Demonstrate the capability to implement protective actions for the ingestion exposure pathway.

Objective Selected: N/A

Offsite Response Organization:

Extent of Play:

Objective 28. RELOCATION, RE-ENTRY AND RETURN - DECISION MAKING

Demonstrate the capability to develop decisions on relocation, re-entry, and return.

Objective Selected: No

Offsite Response Organization:

Extent of Play:

Objective 29. RELOCATION, RE-ENTRY AND RETURN - IMPLEMENTATION

Demonstrate the capability to implement appropriate measures for relocation, re-entry, and return.

Objective Selected: No

Offsite Response Organization:

Objective 30. CONTINUOUS, 24-HOUR STAFFING

Demonstrate the capability to maintain staffing on a continuous, 24-hour basis through an actual shift change.

Objective Selected: No

Offsite Response Organization:

Extent of Play:

Objective 31. OFFSITE SUPPORT FOR THE EVACUATION OF ONSITE PERSONNEL

Demonstrate the capability to provide off-site support for the evacuation of on-site personnel.

Objective Selected: No

Offsite Response Organization:

Extent of Play:

Objective 32. UNANNOUNCED EXERCISE OR DRILL

Demonstrate the capability to carry out emergency response functions in an unannounced exercise or drill.

Objective Selected: No

Offsite Response Organization:

Extent of Play:

Objective 33. OFF-HOURS EXERCISE OR DRILL

Demonstrate the capability to carry out emergency response functions during an off-hours exercise or drill.

Objective Selected: No

Offsite Response Organization:

GEAUGA COUNTY OHIO

Objectives

For the
Perry Nuclear Power Plant
Evaluated Exercise

March 2000

GEAUGA COUNTY EXERCISE OBJECTIVES For the March 2000 Evaluated Exercise

Preparation Date: November 12, 1999

Group A Objectives, numbered 1-13. These are core objectives that should be demonstrated in every biennial exercise by all Offsite Response Organizations (OROs) that have responsibility for them.

Objective 1. MOBILIZATION OF EMERGENCY PERSONNEL

Demonstrate the capability to alert and fully mobilize personnel for both emergency facilities and field operations. Demonstrate the capability to activate and staff emergency facilities for emergency operations.

Objective selected: Yes
Offsite Response Organizations:

Geauga County Department of Emergency Services (DES) and Emergency Operations Center (EOC) Staff

Field Activity Participants:

Middlefield Volunteer Fire Department Ledgemont School District Geauga County Sheriff's Office Middlefield Police Department American Red Cross

Extent of Play:

Geauga County EOC Staff will mobilize upon notification from the Geauga County Sheriff's Dispatch Center.

Full field notification utilizing primary means of communication will be completed one only, at Site Area Emergency. All other notifications will be simulated.

All field agency demonstrations will be conducted out-of-sequence and participants will be pre-positioned.

2000 EVEX Section 1.5 Page 1 of

Objective 2. FACILITIES - EQUIPMENT, DISPLAYS, AND WORK ENVIRONMENT

Demonstrate the adequacy of facilities, equipment, displays and other materials to support emergency operations.

Objective Selected: Yes Offsite Response Organizations:

Geauga County EOC

Extent of Play:

The Geauga County Emergency Operations Center (EOC) will demonstrate this objective. Back-up power will be shown via a walk-down by the Emergency Services Director or designee at the EOC.

Objective 3. DIRECTION AND CONTROL

Demonstrate the capability to direct and control emergency operations.

Objective Selected: Yes Offsite Response Organizations:

Geauga County EOC Staff
Middlefield Volunteer Fire Department
Ledgemont School District
Geauga County Sheriff's Office
American Red Cross
Middlefield Police Department

Extent of Play:

Direction and control of emergency operations will be demonstrated in accordance with the exercise scenario, the Geauga County Radiological Emergency Response Plan and as appropriate per out-of-sequence field demonstrations.

2000 EVEX Section 1.5 Page 2 of 13

Objective 4. COMMUNICATIONS

Demonstrate the capability to communicate with all appropriate emergency personnel at facilities and in the field.

Objective Selected: Yes Offsite Response Organizations:

> Geauga County EOC Staff Middlefield Volunteer Fire Department Geauga County Sheriff's Office Geauga Amateur Radio Association

Extent of Play:

Primary (telephone) and secondary (radio/pagers) means of communications will demonstrated at the EOC and as appropriate per out-of-sequence field demonstrations.

Full notification from the EOC to field agencies will be conducted at <u>Site Area Emergency</u> only.

Controllers will drive out-of-sequence field play.

Objective 5. EMERGENCY WORKER EXPOSURE CONTROL

Demonstrate the capability to continuously monitor and control radiation exposure to emergency workers.

Objective Selected: Yes Offsite Response Organizations:

Geauga County EOC Staff
Middlefield Volunteer Fire Department
Ledgemont School District – Transportation Department
Geauga County Sheriff's Office
Middlefield Police Department

Extent of Play:

The Geauga County EOC Radiological Officer will demonstrate radiation exposure control capabilities and issue dosimetry to the Public Information Officer. Dosimetry and exposure control procedures will be demonstrated by the above agencies during out-of-sequence exercise activities.

Objective 6. FIELD RADIOLOGICAL MONITORING - AMBIENT RADIATION MONITORING

Demonstrate the appropriate use of equipment and procedures for determining field radiation measurements.

Objective Selected: N/A

Objective 7. DOSE PROJECTION

Demonstrate the capability to develop dose projections and protective action recommendations regarding evacuation and sheltering.

Objective Selected: N/A

Objective 8. FIELD RADIOLOGICAL MONITORING - AIRBORNE RADIOIODINE AND PARTICULATE ACTIVITY MONITORING

Demonstrate the appropriate use of equipment and procedures for the measurement of airborne radioiodine concentrations as low as 10-7 (.0000001) micro-curies per cubic centimeter in the presence of noble gases and obtain samples of particulate activity in the airborne plume.

Objective Selected: N/A

Objective 9. PLUME PROTECTIVE ACTION DECISION MAKING

Demonstrate the capability to make timely and appropriate protective action decisions.

Objective Selected: Yes

Offsite Response Organizations:

Geauga County EOC Executive Group

Extent of Play:

Geauga County EOC Executive Group will demonstrate this objective in coordination with Lake and Ashtabula counties' Executive Groups and the State of Ohio.

Objective 10. ALERT AND NOTIFICATION

Demonstrate the capability to promptly alert and notify the public within the 10-mile plume pathway Emergency Planning Zone (EPZ) and disseminate instructional messages to the public on the basis of decisions by appropriate State or local officials.

Objective Selected: Yes Offsite Response Organizations:

Geauga County EOC Staff

Extent of Play:

Upon a protective action decision (PAD) by the combined Executive Groups of Ashtabula, Geauga, and Lake counties (start of the 15-minute clock), the Lake County EOC staff will prepare the appropriate Emergency Alert System (EAS) message and simulate sounding the sirens and sending the message over the EAS system. A silent siren test will be demonstrated by Lake County EOC in lieu of an actual siren sounding. A representative of the #1 Local Primary Station will be available for interview by an evaluator.

Simulation of sending the EAS message(s) will be conducted as follows:

The procedure for the EAS encoder will be followed to deliver the message to WTAM, the #1 Local Primary Station, with the exception that the telephone number to the station will not be dialed. By not connecting to WTAM, there will be no possibility of accidentally broadcasting the message over one or more of the participating EAS stations. The "send" button on the Lake County EAS encoder will be depressed, and this action will activate the outgoing alert light and playback of the recorded message. Also, a data sheet will automatically be printed by the encoder and the time recorded on this data sheet shall be used as the official end of the 15-minute clock.

Lake County will FAX a copy of the EAS message(s) to the Joint Public Information Center (JPIC) where Public Information Officers (PIOs) may distribute hard copies to the news media representatives and may, if time and circumstances allow, make an announcement regarding the message. Otherwise, the EAS message can be announced at the next scheduled press briefing or in response to news media inquiries about the PAD message. In delivering information about the EAS message just released, the counties' PIOs may indicate that a corresponding Special News Bulletin (SNB) will be issued soon.

2000 EVEX Section 1.5 Page 5 of 13

Objective 11. PUBLIC INSTRUCTIONS AND EMERGENCY INFORMATION

Demonstrate the capability to coordinate the formulation and dissemination of accurate information and instructions to the public.

Objective Selected: Yes Offsite Response Organizations:

Geauga County EOC Staff

Extent of Play:

Based upon the combined PAD(s) of the Executive Groups of Ashtabula, Geauga and Lake counties, the Lake County EOC staff will prepare and issue the appropriate EAS message(s) (See Objective 10; Extent of Play) and the corresponding Special News Bulletin(s) (SNB). SNB's are the very same message as their corresponding EAS messages except that the SNBs are longer due to greater detail. Lake County will FAX the SNB(s) to the Joint Public Information Center (JPIC) where one of the PIOs from Ashtabula, Geauga, or Lake counties will represent the three counties by proceeding to the briefing room and reading the content of the message to the assembly of news media representatives and answer their questions pertaining to the message. This briefing should commence no sooner than 15 minutes after transmission of the EAS message from Lake County EOC to the Local Primary EAS Station. Hard copies of the SNB(s) will be distributed to the news media representatives.

Ashtabula, Geauga and Lake counties will also coordinate release of other informational and instructional messages as necessary. Such messages may include Special Information Bulletins (SIB), which are a third category of prepared messages contained in the counties' "SOP for EAS Messages, Special News Bulletins, and Special Information Bulletins pertaining to the Perry Nuclear Power Plant." These SIBs are considered routine, meaning that they are to be delivered by one or more of the counties' PIOs at the next scheduled press briefing.

2000 EVEX Section 1.5 Page 6 of 13

Objective 12. EMERGENCY INFORMATION - MEDIA

Demonstrate the capability to coordinate the development and dissemination of clear, accurate, and timely information to the news media.

Objective Selected: Yes Offsite Response Organizations:

Geauga County PIO at the JPIC
Geauga County PIO Liaison at the Geauga County EOC

Extent of Play:

The Geauga County Public Information Officer (PIO) will demonstrate this objective at the Joint Public Information Center (JPIC) in coordination with Lake and Ashtabula counties PIOs, the State of Ohio and the utility spokespersons. The JPIC is located at Lakeland Community College. Special News Bulletins (SNBs) will be issued by the Lake County EOC and presented to the news media by one of the counties' PIOs at the JPIC.

Objective 13. EMERGENCY INFORMATION - RUMOR CONTROL

Demonstrate the capability to establish and operate rumor control in a coordinated and timely manner.

Objective Selected: Yes Offsite Response Organizations:

Geauga County EOC Staff

Extent of Play:

Geauga County Rumor Control operations are conducted from the Geauga County EOC. Appropriate EOC staff will respond to calls from an exercise-controller operated control cell for one hour, receiving approximately six calls. Additional calls outside the one-hour time frame may also be received.

Geauga County Rumor Control staff will identify any trends and report them to the Executive Group. Appropriate announcements will be developed in response to identified County specific trends. The PIO Liaison will forward this information to the County PIO at the JPIC.

Radio and television monitoring capabilities will be shown but not utilized as no actual emergency public information messages will be broadcast.

2000 EVEX Section 1.5 Page 7 of 13

2000 PERRY PLANT EVALUATED EXERCISE 1.5 GEAUGA COUNTY OBJECTIVES

GROUP B Objectives, numbered 14-22. These objectives should be demonstrated in every biennial exercise by some organizations. OROs with responsibility for these objectives should demonstrate at least once every six years.

Objective 14. IMPLEMENTATION OF PROTECTIVE ACTIONS - USE OF KI FOR EMERGENCY WORKERS, INSTITUTIONALIZED INDIVIDUALS, AND THE GENERAL PUBLIC

Demonstrate the capability to implement potassium iodide (KI) protective actions for emergency workers, institutionalized individuals, and if the State plan specifies, the general public.

Objective Selected: Yes Offsite Response Organizations:

> Geauga County EOC Staff – Radiological Officer Middlefield Volunteer Fire Department Geauga County Sheriff's Office Ledgemont School District

Extent of Play:

Ohio Department of Health (ODH) will make recommendations regarding the use of KI. Geauga County's preparedness measures for KI include pre-distribution to emergency response agencies. At the time of the emergency, the agencies distribute the KI and dosimetry to their individual emergency workers. If the ODH recommendation for use of KI excludes the Geauga County portion of the Emergency Planning Zone (EPZ), demonstration of this objective may be facilitated by discussion with the Geauga County Radiological Officer at the EOC. For field agency demonstrations, KI procedures will be demonstrated by interview with exercise participants or, if necessary, by exercise controller inject.

2000 EVEX Section 1.5 Page 8 of 13

2000 PERRY PLANT EVALUATED EXERCISE 1.5 GEAUGA COUNTY OBJECTIVES

Objective 15. IMPLEMENTATION OF PROTECTIVE ACTIONS - SPECIAL POPULATIONS

Demonstrate the capability and resources necessary to implement appropriate protective actions for special populations.

Objective Selected: Yes Offsite Response Organizations:

Geauga County EOC Staff

Extent of Play:

Notification to individuals with special needs within the Geauga County portion of the Emergency Planning Zone (EPZ) will be simulated. A list of special needs residents within the Geauga County portion of the EPZ is maintained by the Geauga County Department of Emergency Services (DES). The Fire/EMS Officer at the EOC will coordinate special needs notification activities and upon request will present the confidential list for review by the FEMA Evaluator.

Objective 16. IMPLEMENTATION OF PROTECTIVE ACTIONS - SCHOOLS

Demonstrate the capability and resources necessary to implement protective actions for school children within the plume pathway Emergency Planning Zone (EPZ).

Objective Selected: Yes
Offsite Response Organizations:

Ledgemont School District

Extent of Play:

2000 EVEX

Ledgemont School District will demonstrate this objective out-of-sequence, by interview with the superintendent, high school principal, transportation supervisor/bus driver. The use of dosimetry and KI will be discussed with transportation personnel only.

No movement of students or vehicles will occur.

Section 1.5 Page 9 of 13

2000 PERRY PLANT EVALUATED EXERCISE 1.5 GEAUGA COUNTY OBJECTIVES

Objective 17. TRAFFIC AND ACCESS CONTROL

Demonstrate the organizational capability and resources necessary to control evacuation traffic flow and to control access to evacuated and areas.

Objective Selected: Yes Offsite Response Organizations:

Geauga County Sheriff's Office

Extent of Play:

A Traffic Control Point (TCP) located at State Route 608 and U.S. Route 6 will be demonstrated out-of-sequence, pre-positioned by the Geauga County Sheriff's Office. Traffic control procedures will be simulated.

Objective 18. RECEPTION CENTER MONITORING, DECONTAMINATION, AND REGISTRATION

Demonstrate the adequacy of procedures, facilities, equipment and personnel for the radiological monitoring, decontamination, and registration of evacuees.

Objective Selected: Yes Offsite Response Organizations:

> Middlefield Volunteer Fire Department American Red Cross

Extent of Play:

Middlefield Volunteer Fire Department will demonstrate this objective out-of-sequence at Cardinal High School, 14785 Thompson Avenue, Middlefield Village. One locker room will be fully set-up and demonstrated. A walk-through of the remaining locker room will be conducted upon request. An American Red Cross representative will describe registration procedures.

Six (6) monitoring demonstrations will be conducted using a portal monitor. One individual with simulated contamination will be walked through the monitoring/decontamination process, which includes whole body monitoring using a CDV-700 survey meter, retrofitted with a frisker probe. Contamination levels will be provided by a controller. Decontamination will be simulated.

Vehicle monitoring and decontamination procedures will be demonstrated by interview with representatives from the Middlefield Volunteer Fire Department. No vehicle will be monitored or washed

2000 EVEX Section 1.5 Page 10 of 13

2000 PERRY PLANT EVALUATED EXERCISE 1.5 GEAUGA COUNTY OBJECTIVES

Objective 19. CONGREGATE CARE

Demonstrate the adequacy of facilities, equipment, supplies, personnel, and procedures for congregate care of evacuees.

Objective Selected: Yes
Offsite Response Organizations:

American Red Cross

Extent of Play:

Congregate care capabilities will be demonstrated out-of-sequence at the Cardinal High School Care Center, by interview with representatives from the local American Red Cross Chapter. The American Red Cross personnel will provide a walk-through of the facility with description of congregate care capabilities. No set-up of care center equipment or supplies will be demonstrated.

Objective 20. MEDICAL SERVICES - TRANSPORTATION

Demonstrate the adequacy of vehicles, equipment, procedures and personnel for transporting contaminated, injured, or exposed individuals.

Objective Selected: N/A

Objective 21. MEDICAL SERVICES - FACILITIES

Demonstrate the adequacy of the equipment, procedures, supplies, and personnel of medical facilities responsible for treatment of contaminated, injured, or exposed individuals.

Objective Selected: N/A

Objective 22. EMERGENCY WORKERS, EQUIPMENT, AND VEHICLES - MONITORING AND DECONTAMINATION

Demonstrate the adequacy of procedures for the monitoring and decontamination of emergency worker, equipment, and vehicles.

Objective Selected: No

2000 EVEX

Section 1.5 Page 11 of 13

2000 PERRY PLANT EVALUATED EXERCISE 1.5 GEAUGA COUNTY OBJECTIVES

Group C Objectives, numbered 23-33. These objectives should be demonstrated once every six years by each organization with responsibility for them.

Objective 23. SUPPLEMENTARY ASSISTANCE (FEDERAL/OTHER)

Demonstrate the capability to identify the need for external assistance and to request such assistance from Federal or other support organizations.

Objective Selected: N/A

Objective 24. POST-EMERGENCY SAMPLING

Demonstrate the use of equipment and procedures for the collection and transportation of samples from areas that received deposition from the airborne plume.

Objective Selected: N/A

Objective 25. LABORATORY OPERATIONS

Demonstrate laboratory operations and procedures for measuring and analyzing samples.

Objective Selected: N/A

Objective 26. INGESTION EXPOSURE PATHWAY - DOSE PROJECTION AND PROTECTIVE ACTION DECISION MAKING

Demonstrate the capability to project dose to the public for the ingestion exposure pathway and to recommend protective actions.

Objective Selected: N/A

Objective 27. INGESTION EXPOSURE PATHWAY - PROTECTIVE ACTION IMPLEMENTATION

Demonstrate the capability to implement protective actions for the ingestion exposure pathway.

Objective Selected: N/A

Page 12 of 13

2000 PERRY PLANT EVALUATED EXERCISE 1.5 GEAUGA COUNTY OBJECTIVES

Objective 28. RELOCATION, RE-ENTRY AND RETURN - DECISION MAKING

Demonstrate the capability to develop decisions on relocation, re-entry, and return.

Objective Selected: No

Objective 29. RELOCATION, RE-ENTRY AND RETURN - IMPLEMENTATION

Demonstrate the capability to implement appropriate measures for relocation, re-entry, and return.

Objective Selected: No

Objective 30. CONTINUOUS, 24-HOUR STAFFING

Demonstrate the capability to maintain staffing on a continuous, 24-hour basis through an actual shift change.

Objective Selected: No

Objective 31. OFFSITE SUPPORT FOR THE EVACUATION OF ONSITE PERSONNEL

Demonstrate the capability to provide offsite support for the evacuation of onsite personnel.

Objective Selected: N/A

Objective 32. UNANNOUNCED EXERCISE OR DRILL

Demonstrate the capability to carry out emergency response functions in an unannounced exercise or drill.

Objective Selected: No

Objective 33. OFF-HOURS EXERCISE OR DRILL

Demonstrate the capability to carry out emergency response functions during an off-hours exercise or drill.

Objective Selected: No

ACTION LOCATIONS MARCH 20-22, 2000

SECTION 2.0

EXERCISE INFORMATION This section contains:

Section 2.1 - Off-site Action Locations

Section 2.2 - Onsite Exercise Organization

Section 2.3 - Onsite Emergency Response Facilities

ACTION LOCATIONS MARCH 20-22, 2000

This document lists participating agencies, dates, times, locations with directions, and contact names and telephone numbers for respective demonstrations. Exercise controller and evaluator assignments are also identified.

STATE OF OHIO

Demonstrating Agency/
Location

Date/
Time

Exercise Controller/
[Exercise Evaluator]

Initial Notification Point
Ohio Emergency Management Agency
2855 Dublin Granville Road
Columbus, OH

Contact Carol O'Claire (614) 799-3915

rections: The State EOC is located on State Route-161, (2855 W. Dublin Granville Road), between Sawmill Road and SR-315. Roadway entrance is to the south side of SR-161 (at the ODOT and Med-Flight signs). Stay straight on roadway to the second driveway and park. The EOC building entrance is at the top of the stairway. Upon entry request the guard notify your contact.

State Emergency Operations Center

3/21/00

Ohio Emergency Management Agency

08:00 - 15:00 hours

2855 Dublin Granville Road Columbus, OH

Contact Carol O'Claire (614) 799-3915

State Assessment Room

3/21/00

Ohio Emergency Management Agency

08:00 - 15:00 hours

2855 Dublin-Granville Road

Columbus OH

Contact Carol O'Claire (614) 799-3915

ACTION LOCATIONS MARCH 20-22, 2000

STATE OF OHIO (continued)

Demonstrating Agency/ Location	Date/ Time	Exercise Controller/ [Exercise Evaluator]
Emergency Operations Facility (EOF)	3/21/00	Dan Cleavenger

Perry Nuclear Power Plant

08:00 - 15:00 hours

Dan Cleavenger

10 North Center Road Perry, OH

Contact Sonia Eischen, State of Ohio EOF Liaison (440) 280-5746

Directions: The EOF is located at the Perry Nuclear Power Plant (10 North Center Road, Perry, Ohio) on the first floor of the Training and Education Center (TEC Building) which is the two story, brick and cement building off to the left of the road upon entering the PNPP grounds. Take State Route 2 to its end and continue straight ahead on U.S. Route 20 to Center Road (traffic light). Turn left (north) on Center Road and enter the JPP grounds from Center Road; take the first road on the left (across from the large sign, which is on the right side) and proceed a few feet to the parking lot in front of the TEC Building.

~10:00 - 15:00 Hours

Joint Public Information Center

3/21/00

Cheryl Jenkins

Lakeland Community College

Performing Arts Center 7700 Clocktower Drive

Mentor, OH

Contact:

Dick Kimmins, State of Ohio Public Information Officer (PIO)

Phone: (440) 269-7107 or

(440) 269-7122/7115/7116

Directions: The main entrance (Clocktower Drive) is from Route 306, just south of Interstate 90. (Also, there is a back entrance from Garfield Road not far from the Lake County EOC.) The Performing Arts Center is to the immediate left of the clock tower. Enter the doors directly under the overhead walkway. If the security personnel will not admit you, ask for an Exercise Controller or the Government Liaison person.

Parking: Secured parking is available in the lot directly across from the clock. The parking code to enter will be given at the pre-exercise briefing. The gate lifts automatically when exiting. Parking is also available in the student parking lots.

ACTION LOCATIONS MARCH 20-22, 2000

STATE OF OHIO (continued)

Demonstrating Agency/

Date/

Exercise Controller/

Location

Time

[Exercise Evaluator]

State of Ohio Field Monitoring Teams

3/21/00

Lake County

~09:30 hours

Emergency Operations Center

8505 Garfield Road

Mentor, Ohio

Contact Dan Redman (440) 953-5396

Directions: The Lake County EOC is located at the end of Garfield Road. The EOC is accessible from (1) Rt. 84 (Mentor) or (2) Lakeland Community College Campus (the location of the Joint Public Information Center).

ate of Ohio Communications Van

3/21/00

Ledgemont Elementary School

~09:30 hours

16200 Burrows Road

Thompson, OH

Contact Larry Confer or Rick Ponder (614) 799-3642 or (614) 799-3641

Directions: From Interstate Route 90 take State Route 528 south to Burrows Road (approximately 4 miles south of the Thompson Square). Turn right (west) on Burrows Road and proceed to the Ledgemont Elementary School.

State of Ohio Sample Screening Point

3/21/00

Ledgemont Elementary School

~09:30 hours

16200 Burrows Road

Thompson, OH

Contact George Cicotte or S. Jayaraman

(614) 203-6359 (cellular) or (614) 728-0872 (pre-exercise)

Directions: See above.

(2000 EVEX)

SECT. 2.1-17

ACTION LOCATIONS MARCH 20-22, 2000

LAKE COUNTY

Mentor, Ohio

Kirtland, OH

Demonstrating Agency/Date/Exercise Controller/LocationTime[Exercise Evaluator]

Lake County Field Monitoring Teams 3/20/00
Lake County 18:00 hours
Emergency Operations Center
8505 Garfield Road

Contact John Wills, Regional Radiological Analyst, Ohio EMA (440) 953-5393

Directions: Inventory of the Lake County Health District field monitoring team kits will be conducted on Monday, March 20, 2000 at 18:00 hours at the Lake County EOC, which is located at the end of Garfield Road. The EOC is accessible from (1) Rt. 84 (Mentor) or (2) Lakeland Community College Campus.

rvote: The Lake County Field Monitoring Teams will conduct their demonstration in sequence with the evaluated exercise on Tuesday, March 21, 2000 beginning from the Lake County EOC.

Monitoring/Decontamination Public 3/20/00 Jerome Barclay Kirtland High School 18:30 hours 9152 Chillicothe Road

Demonstrating Agency: Kirtland Fire Department Contact Lt. Doug Boode (440) 256-8979

Directions: Take Interstate 90 to State Route 306. Go south on Route 306 approximately two miles to Kirtland High School. Turn right into the school parking lot and proceed to rear entrance of the building.

ACTION LOCATIONS MARCH 20-22, 2000

LAKE COUNTY (continued)

Demonstrating Agency/	Date/	Exercise Controller/
Location	Time	[Exercise Evaluator]
Congregate Care Center/Registration	3/20/00	Jerome Barclay
Kirtland High School	18:30 hours	ŕ
9152 Chillicothe Road		

Demonstrating Agency: American Red Cross Contact Rick McPeak

(440) 352-3171

Kirtland, OH

Directions: Take Interstate 90 to State Route 306. Go south on Route 306 approximately two miles to Kirtland High School. Turn right into the school parking lot and proceed to rear entrance of the building.

Dack-Up Route Alerting

3/20/00

Leroy Township Fire Department

19:00 hours

13028 Leroy Center Road Leroy Township, OH

Contact James McDonald

(440) 254-4124

Directions: Take Interstate Route 90 to Vrooman Road exit. Go south on Vrooman Road to Leroy Center Road. Turn left (east) on Leroy Center Road. The Fire Department is located on the right (south) side of the road.

ACTION LOCATIONS MARCH 20-22, 2000

LAKE COUNTY (continued)

Demonstrating Agency/
Location

Date/
Time

Exercise Controller/
[Exercise Evaluator]

Initial Notification Point

Lake County

Central Communications Center

8505 Garfield Road

Mentor, OH

Date/
Exercise Controller/

[Exercise Evaluator]

Contact Robert Archer, Director (440) 953-5393 or (440) 256-1415/1416

Directions: The Central Communications Center is co-located with the Lake County EOC, which is located at the end of Garfield Road. The EOC is accessible from (1) Rt. 84 (Mentor) or (2) Lakeland Community College impus.

Emergency Operations Center
Lake County EOC

3/21/00

ake County EOC

08:00 - 1500 hours

8505 Garfield Road Mentor, OH

Contact Robert Archer, Director (440) 953-5393 or (440) 256-1415/1416

Directions: The Lake County EOC is located at the end of Garfield Road (see above).

ACTION LOCATIONS MARCH 20-22, 2000

LAKE COUNTY (continued)

Demonstrating Agency/

Date/

Exercise Controller/

Location

Time

[Exercise Evaluator]

Medical Services - Transportation

3/21/00

Perry Nuclear Power Plant

07:30 hours

Unit #1, Controlled Access Area 10 North Center Road Perry, OH

The demonstrating agency is: Perry Township Fire Department 3742 Center Road Perry, OH

Contact Chief Robert Bates

40) 259-2880

Directions and Notes: The Medical Services demonstration will be conducted in sequence with the evaluated exercise. Contact the Exercise Controller who will be waiting outside the Primary Access Control Point at the Perry Power Plant. The Perry Township Fire Department will respond to the Perry Nuclear Power Plant, enter through the Primary Access Control Point (PACP) vehicle lock, and travel to the transfer point from the Radiological Restricted Area. Special access and dosimetry is required for all participants, including the evaluator. An Exercise Controller will escort the FEMA Evaluator inside the plant's controlled area.

Medical Services – Facilities

Lake East Hospital

3/21/00

10 East Washington Street Painesville, OH

08:00 hours

1 miles (111)

Contact Pat Casella or Ron Howard (440) 354-1685

Directions: Take State Route 2 to the Painesville Fairport Harbor exit. Take Richmond Street south to the corner of East Washington and Liberty streets. The Hospital Emergency Room Entrance is on High Street.

(2000 EVEX)

SECT. 2.1-17

ACTION LOCATIONS MARCH 20-22, 2000

LAKE COUNTY (continued)

Demonstrating Agency/ Location	Date/ Time	Exercise Controller/ [Exercise Evaluator]
Joint Public Information Center Lakeland Community College 7700 Clocktower Drive Mentor, OH	3/21/00 ~10:00 - 15:00 hours	Cheryl Jenkins

Contact Ken Gauntner, Lake County Public Information Officer (PIO) (440) 269-7107 or (440) 269-7122/7115/7116

Directions: Directions: The main entrance (Clocktower Drive) is from Route 306, just south of Interstate 90. (Also, there is a back entrance from Garfield Road not far from the Lake County EOC.) The Performing Arts Center is to the immediate left of the clock tower. Enter the doors directly under the overhead walkway. If the security personnel will not admit you, ask for an Exercise Controller or the Government Liaison person.

rarking: Secured parking is available in the lot directly across from the clock. The parking code to enter will be given at the pre-exercise briefing. The gate lifts automatically when exiting. Parking is also available in the student parking lots

Emergency Alert System Radio Station

3/21/00

Jay Carter

WGAR 99.5 FM 12:00 hours

5005 Rockside Road Suite 530 Cleveland OH

Contact John Makley, Technical Director (216) 328-9950

Directions:

Take Interstate Route 90 to Route 271. Take Route 271 South to Route 480 West. Take Route 480 West to Interstate Route 77 South to the Rockside Road exit. Turn right at the exit and turn right at the first drive on the right-hand side. WGAR is located on the 5th floor of the Crown Center Building.

ACTION LOCATIONS MARCH 20-22, 2000

LAKE COUNTY (continued)

Demonstrating Agency/

Date/

Exercise Controller/

Location

Time

[Exercise Evaluator]

Emergency Worker Monitoring/Decontamination

Mentor High School Football Stadium

3/21/00 Jerome Barclay

6477 Center Road (Route 615) 19:00 hours

Mentor, OH

Demonstrating Agency: Mentor Fire Department

Contact Lee Silvi (440) 974-5765

Directions: Take State Route 2 to Route 615 (Center Road). Take Route 615 south to Civic Boulevard. Follow Civic Boulevard to the Mentor High School Football Stadium.

school District

Painesville Township School District erintendent's Office 09:30 hours

3/22/00 Jerome Barclay

Superintendent's Office Board of Education

board of Education

585 Riverside Drive

Painesville, OH

Contact Superintendent Keith Thimons (440) 352-0068

,

Directions: Take State Route 2 to State Route 44 south. Take State Route 44 to Painesville/Mentor State Route 84 exit. Take Route 84 east to Painesville Riverside High School. The Administration office is located west of the high school building.

ACTION LOCATIONS MARCH 20-22, 2000

LAKE COUNTY (continued)

Demonstrating Agency/

Date/

Exercise Controller/

Location

Time

[Exercise Evaluator]

School District

Painesville City School District

3/22/00 Jerome Barclay

Superintendent's Office

11:00 hours

Board of Education 58 Jefferson Street

Painesville, OH

Contact Superintendent Mike Hanlon (440) 639-7000

Directions: Take Route 2 to Painesville Fairport Harbor exit. Take Richmond Street south to Jackson Street. Take Jackson Street west to Jefferson Street. Turn south (left) on Jefferson Street. The Board of Education ilding is on the left.

Traffic/Access Control

3/22/00

Jerome Barclay

Lake County Sheriff's Department

13:00 hours

Demonstration location:

Intersection of State Route 20 and Fairgrounds Road

Painesville Township, OH

Contact Deputy Thomas Cotter

(440) 350-5514

Directions: Take State Route 2 to State Route 44 south. Take State Route 44 to the Jackson Street exit. Proceed straight off of the exit ramp to State Route 20 Mentor Avenue. Turn right (west) and proceed to the Fairgrounds Road/State Route 20 intersection.

ACTION LOCATIONS MARCH 20-22, 2000

ASHTABULA COUNTY

Date/ Exercise Controller/ Demonstrating Agency/ Location Time [Exercise Evaluator]

Initial Notification Point

3/21/00

Ashtabula County

Sheriff's Department Dispatch Center 25 West Jefferson Street Jefferson, OH

Contact Ed Somppi, Director (440) 576-9148

Directions: Take Interstate 90 to State Route 45. Take State Route 45 south to State Route 307. Take State Route 307 east to State Route 46 (Chestnut Street). Take State Route 46 south (right) to the intersection with Jefferson Street. The Sheriff' Department is located with the county courthouse on the right. The Dispatch enter is located in the basement area adjacent to the County EOC.

Emergency Operations Center

3/21/00

Ashtabula County Courthouse

25 West Jefferson Street

Jefferson, OH

Contact Ed Somppi, Director

(440) 576-9148

Directions: See above.

Joint Public Information Center

3/21/00

~10:00 - 15:00 hours

Cheryl Jenkins

08:00 hours

08:00 - 15:00 hours

Lakeland Community College

7700 Clocktower Drive

Mentor, OH

Contact Byron Landolfi, Ashtabula County Public Information Officer (PIO) (440) 269-7107 or (440) 269-7122/7115/7116

ASHTABULA COUNTY (continued)

(2000 EVEX)

SECT. 2.1-17

ACTION LOCATIONS MARCH 20-22, 2000

Demonstrating Agency/

Date/

Exercise Controller/

Location

Time

[Exercise Evaluator]

Monitoring/Decontamination - Public

3/21/00

Michael Ginn

Conneaut Rowe Middle School

19:00 hours

360 Rowe Street

Conneaut, OH

Demonstrating Agency: Conneaut Fire Department

Contact Chief Bimm Orrenmaa

(440) 593-7460

Directions: Take Interstate Route 90 to the Conneaut (State Route 7) exit. Take Route 7 north to State Route 20 (Main Street). Turn right (east) on Route 20 and travel across the Main Street Bridge to Rowe Street. Turn north (left) on Rowe Street and proceed to the Middle School on the right.

Congregate Care Center/Registration

3/21/00

Michael Ginn

Conneaut Rowe Middle School

19:00 hours

360 Rowe Street

Conneaut, OH

Demonstrating Agency: American Red Cross

Contact Randy Dramis

(440) 998-1020

Directions: See above.

ACTION LOCATIONS MARCH 20-22, 2000

ASHTABULA COUNTY (continued)

Demonstrating Agency/	Date/	Exercise Controller/
Location	Time	[Exercise Evaluator]

Traffic/Access Control

3/22/00

Michael Ginn

Ohio State Highway Patrol

13:00 hours

Demonstration location:

Intersection of Interstate Route 90 and State Route 534

Harpersfield Township, OH

Contact Lt. George Williams, Post Commander Ohio State Highway Patrol Ashtabula Post #4 (440) 969-1155

Directions: The Ohio State Highway Patrol Trooper will meet the evaluator at the BP gas station on the orthwest corner of the exit ramp.

Back-Up Route Alerting

3/22/00

19:00 hours

Michael Ginn

Geneva-on-the-Lake Fire Department

4931 South Warner Drive Geneva-on-the-Lake, OH

Contact Chief James Bartlett (440) 466-8765

Directions: From Interstate Route 90 or State Route 20 go south on State Route 534. Take Route 534 to State Route 531 (State Route 534 ends at State Route 531). Take State Route 531 east to South Warner Drive.

ACTION LOCATIONS MARCH 20-22, 2000

GEAUGA COUNTY

Demonstrating Agency/
Location

Date/
Time

Exercise Controller/
[Exercise Evaluator]

Initial Notification Point
Geauga County
08:00 hours

Sheriff's Dispatch Center
12518 Merritt Road
Chardon, OH

Contact Dale Wedge, Director Geauga County Department of Emergency Services (DES) (440) 285-9200

Directions: The Sheriff's Dispatch Center is located at the Geauga County EOC. Take State Route 44 to Merritt Road. Turn left (east) on Merritt Road (about 2 miles south of Route 322). Proceed to the first iveway on the left.

Emergency Operations Center 12518 Merritt Road

3/21/00

Chardon, OH

08:00 - 15:00 hours

Contact Dale Wedge, Director (440) 285-9200

Directions: See above.

Joint Public Information Center

3/21/00

Cheryl Jenkins

Lakeland Community College

~10:00 - 15:00 hours

7700 Clocktower Drive

Mentor, OH

Contact, Sue Negron, Geauga County Public Information Officer (PIO) (440) 269-7107 or (440) 269-7122/7115/7116

JEAUGA COUNTY (continued)

(2000 EVEX)

SECT. 2.1-17

ACTION LOCATIONS MARCH 20-22, 2000

Demonstrating Agency/

Date/

Exercise Controller/

Location

Time

[Exercise Evaluator]

School District

3/22/00

Barbara Pizzi

Ledgemont School District

09:00 hours

16200 Burrows Road Thompson, OH

Contact Dr. William Zwick, Superintendent (440) 298-3341

Directions: The Ledgemont School District Superintendent's Office is located in the Ledgemont Elementary School. Take State Route 528 south to Burrows Road (approximately 4 miles south of the Thompson Square). Turn right (west) on Burrows Road and proceed to the Ledgemont Elementary School.

Traffic/Access Control

3/22/00

Geauga County Sheriff's Office

13:00 hours

Demonstration location:

tersection of State Route 608 and U.S. Route 6

.ambden Township, OH

Contact Lt. Dan McClelland

(440) 286-1234

Monitoring/Decontamination - Public

3/22/00

Barbara Pizzi

19:00 hours

Cardinal High School

14785 Thompson Road

Middlefield, OH

Demonstrating Agency: Middlefield Fire Department

Contact Chief Stuart Anderson

(440) 632-1907

Directions: Take State Route 87 to Thompson Street. The High School is at the end of Thompson Street.

ACTION LOCATIONS MARCH 20-22, 2000

GEAUGA COUNTY (continued)

Demonstrating Agency/	Date/	Exercise Controller/
Location	Time	[Exercise Evaluator]

Congregate Care Center/Registration
Cardinal High School

3/22/00 Barbara Pizzi

19:00 hours

14785 Thompson Road Middlefield, OH

Demonstrating Agency: American Red Cross

Contact Jay Becker (440) 285-4911

Directions: Take State Route 87 to Thompson Street. The High School is at the end of Thompson Street.

2000 PERRY PLANT EVALUATED EXERCISE 2.2 ONSITE EXERCISE ORGANIZATION

2.2 ONSITE EXFRCISE ORGANIZATION

The organization for this Exercise will consist of the Exercise Coordinator, Lead Facility Controllers, other Exercise controllers, players, and observers. The role of each of these is discussed in this section.

- 2.2.1 The Exercise Coordinator will coordinate all preparations for the conduct of the exercise, including the development of the scenario and exercise manual. He will interface, as required, with the Lead Facility Controllers, to resolve any inter-facility questions concerning the exercise scenario, and shall determine the amount of "free play" that will be permissible on the part of the players (particularly by the players in the Control Room). He shall have sole authority to terminate the Exercise if, in his judgment, events have occurred which require that the Exercise be suspended to direct appropriate resources to resolution of an actual problem or emergency. Upon receiving verification from all Lead Facility Controllers that the objectives have been satisfactorily demonstrated, he shall authorize distribution of the exercise termination message. After the exercise has been completed, he will chair the controller/ evaluator de-briefing sessions, and coordinate the compilation of a consolidated critique report delineating strengths and weaknesses identified by these individuals. He will also chair the post-exercise critique meeting. He will coordinate the preparation of an itemized list of corrective actions and improvement items identified during the conduct of the exercise, in accordance with the Perry Plant Emergency Plan and PSI-0017.
- 2.2.2 Controllers are qualified personnel selected to perform functions as follows:
 - 1. A <u>Lead Facility Controller</u> is assigned to each emergency response facility or key activity (i.e., Fire Brigade/FAT or RMTS). The Lead Facility Controller is responsible for all Controllers, Evaluators, and Observer activities for that facility and, if appropriate, its associated teams. Controllers for teams or subareas of a facility report to the Lead Facility Controller.

Lead Facility Controllers are responsible for:

- (1) conducting facility/activity critiques with players immediately following exercise termination, and
- (2) evaluating performance based on the objective acceptance criteria outlined in Self-Assessment Plan (Section 4.4)
- 2. The Controllers will deliver Exercise messages to designated players at specified times and places during the Exercise per Section 7. 1, "Player/Controller Message Summary". As deemed necessary, additional contingency messages may be delivered to keep Exercise action moving according to the scenario sequence of events.

2000 PERRY PLANT EVALUATED EXERCISE 2.2 ONSITE EXERCISE ORGANIZATION

Controllers submit written recommendations to the Lead Facility Controller, who in turn summarizes all comments for submittal to the Exercise Coordinator prior to the scheduled critique.

- 3. Persons designated as Controllers for a given function may also be assigned as Evaluators of that function when feasible. Evaluators will record their observations using the evaluation form provided and make recommendations to the Lead Controller. They will evaluate player performance based on requirements contained in the Emergency Plan and appropriate Implementing Instructions. Each Evaluator shall keep an on-going record (chronology) of significant events as they occur.
- 4. The Exercise Coordinator will coordinate the development and conduct of a formal post-exercise critique per PSI-0017, based on the comments and recommendations received from Lead Controllers and designated Evaluators.

Controllers/Evaluators will be identified by RED armbands with white lettering.

Federal agency evaluators will be identified by YELLOW armbands with black lettering denoting "NRC" or "FEMA" as appropriate.

- 2.2.3 <u>Players</u> include Perry Plant and other First Energy Corp. personnel assigned to perform emergency functions, as described in the Emergency Plan and Implementing Instructions. Players from off-site organizations and agencies are participants in the Exercise as described in their respective Emergency Plans and Standard Operating Procedures.
- 2.2.4 Observers from First Energy Corporation and other organizations may be authorized, on a limited basis, to participate in the Exercise solely for the purpose of observing Exercise activity for personal education. Observers will report initially to the Perry Plant Emergency Planning Supervisor for credential review and authorized admittance. They will be provided with orientation information and appropriate exercise publications.

Observers will be identified by GRFEN armbands with white lettering stating "Observer".

2.3 ONSITE EMERGENCY RESPONSE FACILITIES

During the Exercise, special facilities will be activated to manage, assess, and support emergency response. Figure 2.3.1 identifies the location of key Perry Plant buildings.

2.3.1 On-Site Facilities

The Perry Nuclear Power Plant Emergency Response Facilities are:

1. Control Room Simulator

The Unit 1 Control Room will not be used due to potential interference with plant activities. For the Exercise, the PNPP Simulator, located on the first floor of the PNPP Training and Education Center (TEC), will be utilized. Control Room emergency response measures will be exercised from the Simulator under the direction of the Shift Supervisor, acting as the Emergency Coordinator, until relieved by the TSC Operations Manager.

2. <u>Technical Support Center (TSC)</u>

When emergency conditions escalate to an Alert status or higher, coordination of the emergency response will shift from the Control Room [Simulator] to the TSC, located in the 603' 6" level of the Service Building (see Figure 2.3.2). The Operations Manager relieves the Shift Supervisor as acting Emergency Coordinator and directs activities from the TSC until relieved by the Emergency Coordinator in the EOF. The TSC is the location from which technical management personnel support actions being performed in the Control Room. The TSC serves as the primary communications source to the NRC. The TSC will perform event classification, offsite notifications to Federal, State, and local county agencies, and offsite dose assessment until the EOF is operational.

3. Operations Support Center (OSC)

The OSC. located on the 599' elevation of the Control Complex (see Figure 2.3.3), provides a location where emergency response teams can be assembled and coordinated during an emergency. The OSC will be activated for emergency conditions classified as an Alert or higher, and may be activated for an Unusual Event at the discretion of the Emergency Coordinator.

4. Emergency Operations Facility (EOF)

The EOF, located in the Training and Education Center (see Figure 2.3.4), will be activated for emergency conditions classified as a Site Area Emergency or General Emergency (optional for the Alert status). The Emergency Coordinator relieves the TSC Operations Manager as active Emergency Coordinator and directs activities from the EOF. The EOF is the "command post" for coordination of response measures with offsite organizations, assessment of radiological and environmental conditions, and development of protective action recommendations for the general public.




Figure 2.3.1

TECHNICAL SUPPORT CENTER (TSC) SERVICE BUILDING ELEV. 603'6"




Figure 2.3.2

OPERATIONS SUPPORT CENTER (OSC) LAYOUT 599'Level Control Complex Building (Main Floor)




Figure 2.3.3

EMERGENCY OPERATIONS FACILITY (EOF) LAYOUT




Figure 2.3.4

SECTION 3.0 GENERAL INFORMATION

This sections contains the following:

- Section 3.1 Travel Information
- Section 3.2 Accommodations
- Section 3.3 Abbreviations
- Section 3.4 Definitions

3.1 TRAVEL INFORMATION

This section of the Exercise manual provides travel information to those individuals from First Energy Corporation, other utilities, local/State/Federal government, and /or other organizations who will participate in the Exercise as Observers.

Permission to observe the Exercise must be obtained from the Emergency Planning Supervisor, Perry Plant, A240, 10 Center Road, Perry, Ohio 44081. (440-280-5294)

DIRECTIONS TO THE PERRY PLANT

The Perry Plant is located on the southeastern shoreline of Lake Erie in Lake County, Ohio, approximately seven miles northeast of Painesville, Ohio, and about 35 miles northeast of downtown Cleveland.

a. Air

Several airlines provide passenger service to Cleveland Hopkins International Airport.

b. <u>Car</u>

- 1. Several car rental agencies are available at Cleveland Hopkins International Airport to provide rental vehicles for ground transportation to the Perry Plant.
- 2. Persons traveling from Hopkins International Airport via auto should take the following route:
 - State Road 237 North to Interstate 480 East (Youngstown).
 - Follow I-480 to Interstate 271 North; follow I-271 North to Interstate 90 (Erie).
 - Take I-90 East to State Route 44; follow SR 44 North (Painesville) to State Route 2 (East).
 - Take State Route 2 East (which becomes State Route 20) to Center Road (traffic light). Turn left (North) onto Center Road and proceed to the Perry Plant site.

Total distance is approximately 50 miles (see Figure 3.1).

2000 EVEX

3.2 <u>ACCOMMODATIONS</u>

Hotel/motel accommodations may be obtained at the following locations:

Lake & Geauga Counties:

Courtyard by Marriott, Willoughby, I-90 & Route 91	(440) 530-1100
Days Inn Cleveland, Willoughby, I-90 & Route 306	(440) 946-0500
Holiday Inn Express, Mentor, I-90 & Heisley Road	(440) 357-0384
Quail Hollow Resort in Concord Twp., 1-90 at Route 44	(440) 352-6201
Ramada Inn, Cleveland E, Willoughby, I-90 & Route 91	(440) 944-4300
Radisson Hotel, Eastlake, Route 2 & Route 91	(440) 953-8000
Red Roof Inn in Mentor, 1-90 at Route 306	(440) 946-9872
Super 8 Motel in Mentor, Route 2 at Route 306	(440) 951-8558
Travel Lodge, Willoughby, I-90 & Route 91	(440) 585-1900

Ashtabula County:

Travel Lodge in Austinburg, 1-90 at Route 45	(440) 275-2011
Holiday Inn Express in Austinburg, 1-90 at Route 45	(440) 275-2020
Hampton Inn in Austinburg, I-90 at Rout 45	(440) 275-2000
Comfort Inn in Austinburg, I-90 at Rout 45	(440) 275-2711

2000 EVEX SECT. **3.0** Page 2 of 11

3.3 <u>LIST OF ABBREVIATIONS</u>

ACP - Access Control Point

AEGTS - Annulus Exhaust Gas Treatment System

ARC - American Red Cross

AB - Auxiliary Building

ADS - Automatic Depressurization System

ARI - Alarm Response Instruction

ATWAS - Anticipated Transient Without a SCRAM

CADAP - Computer-Aided Dose Assessment Program (CADAP)

CAS - Control Alarm Station

CDEct - Committed Dose Equivalent - Child Thyroid

CEDE - Committed Effective Dose Equivalent

CEI - The Cleveland Electric Illuminating Company

CNTMT - Containment

CFR - Code of Federal Regulations

· CR - Control Room

CRD - Control Rod Drive

DG - Diesel Generator

DOE - Department of Energy

EAL - Emergency Action Level

EAS - Emergency Alert System

ECC - Emergency Communications Center

3.3 <u>LIST OF ABBREVIATIONS</u> (Cont'd)

LOCA

		(cont u)
EMA	-	Emergency Management Agency
ENS	- ·	Emergency Notification System
EOC	-	Emergency Operations Center
EOF	-	Emergency Operations Facility
EPA	-	Environmental Protection Agency
EPI	-	Emergency Plan Implementing Instruction
EPZ	-	Emergency Planning Zone
ERDS	-	Emergency Response Data System
ERF	-	Emergency Response Facility
ERIS	-	Emergency Response Information System
ERO	-	Emergency Response Organization
FEMA	-	Federal Emergency Management Agency
FHA	-	Fuel Handling Accident
FHB	-	Fuel Handling Building
HB	-	Heater Bay
HPCS	-	High Pressure Core Spray
HPN	-	Health Physics Network
IB	-	Intermediate Building
ICS		Integrated Computer System
INPO	-	Institute of Nuclear Power Operations
JPIC	-	Joint Public Information Center

2000 EVEX SECT. 3.0 Page 4 of 11

Loss of Coolant Accident

3.3 <u>LIST OF ABBREVIATIONS</u> (Cont'd)

LCO - Limiting Condition of Operation

LPCI - Low Pressure Coolant Injection

LPCS - Low Pressure Core Spray

MSIV - Main Steam Isolation Valve

NRC - Nuclear Regulatory Commission

ODCM - Offsite Dose Calculation Manual

ODH - Ohio Department of Health

OEMA - Ohio Emergency Management Agency

ONG - Ohio National Guard

ONI - Off-Normal Instruction

OSC - Operations Support Center

PACP - Primary Access Control Point

PAG - Protective Action Guideline

PAR - Protective Action Recommendation

PASS - Post Accident Sampling System

PEI - Plant Emergency Instruction

PIRT - Public Information Response Team

PNPP - Perry Nuclear Power Plant

PTI - Plant Test Instruction

RCIC - Reactor Core Isolation Cooling

REP - Radiological Emergency Preparedness

2000 PERRY PLANT EVALUATED EXERCISE 3.0 General Information

3.3 General Information LIST OF ABBREVIATIONS (Cont'd)

RHR - Residual Heat Removal

RMT - Radiation Monitoring Team

RPV - Reactor Pressure Vessel

RWCU - Reactor Water Clean-up System

SAS - Secondary Alarm Station

SDV - Scram Discharge Volume

SLC - Standby Liquid Control (boron injection)

SOI - System Operating Instruction

SPDS - Safety Parameter Display System (i.e., ICS)

SR - State Route

SRV - Safety Relief Valve

SVI - Surveillance Instruction

TB - Turbine Building

TEDE - Total Effective Dose Equivalent

TPC - Turbine Power Complex

TCP - Traffic Control Point

TS - Technical Specifications

TSC - Technical Support Center

USAR - Updated Safety Analysis Report

X/Q - Wind Dispersion Factor (Chi/Q)

2000 PERRY PLANT EVALUATED EXERCISE 3.0 General Information

3.4 <u>DEFINITIONS</u>

ALERT: The occurrence of an event or events that involve an actual or potentially substantial degradation of the level of safety of the plant. The consideration is to prepare to cope with potentially more serious emergencies. Any radioactive releases are expected to be limited to a small fraction of the EPA Protective Action Levels.

<u>COMMITTED DOSE EQUIVALENT (CDE)</u>: The dose equivalent to organs or tissues of reference that will be received from an intake of radioactive material by an individual during the 50 year period following the intake. For dose assessment purposes, CDE for child thyroid is calculated.

<u>COMMITTED EFFECTIVE DOSE EQUIVALENT (CEDE)</u>: The sum of the products of the weighting factors applicable to each of the body organs or tissues and the committed dose equivalent to these organ or tissues. CEDE is the internal dose component of TEDE.

<u>COMPUTER-AIDED DOSE ASSESSMENT PROGRAM (CADAP)</u>: The automated computer program used by the PNPP for the projection of emergency offsite doses to the general public and for development of protective action recommendations.

<u>CONTROL ROOM (CR)</u>: The principal on-site location from which the reactor is controlled and from which effective emergency control direction is given. The CR is located on the 654' elevation of the Control Complex.

<u>CONTROL ROOM SIMULATOR:</u> The on-site location, which is physically set up to reflect the actual unit control room. The simulator, located in the PNPP Training and Education Center, will be used as the control room for the purposes of the Exercise.

<u>DOSE ASSESSMENT:</u> The process of estimating the amount of radiation a person will potentially receive as a result of a radiological release.

<u>EMERGENCY ACTION LEVELS (EALs)</u>: Levels which consist of specific sets of plant parameters (i.e., instrument indications, system status, radiological doses and dose rates) that shall be used for emergency classification. EALs are used specifically to provide early readiness status of emergency response personnel and organizations.

EMERGENCY OPERATIONS CENTER (EOC): An off-site location utilized by State, County and other government agencies and organizations to perform assessments of radiological conditions and to coordinate off-site activities (access, evacuation, etc.).

2000 EVEX SECT. 3.0 Page 7 of 11

2000 PERRY PLANT EVALUATED EXERCISE 3.0 General Information

3.4 <u>DEFINITIONS</u> (Cont'd)

EMERGENCY OPERATIONS FACILITY (EOF): A specifically designated location for the utility management of overall emergency response activities, the coordination of radiological assessments, and the control of off-site emergency support activities. The PNPP EOF is located within the Owner-Controlled Area on the lower floor of the Training Center Building, approximately one-half mile from the plant.

EMERGENCY PLANNING ZONES (EPZ): Two zones that the EPA recommends be established around all nuclear power stations. One zone with a radius of approximately 10 miles for airborne exposure, and the other with a radius of approximately 50 miles for contaminated food. In these zones, predetermined protective action plans are needed.

EMERGENCY RESPONSE DATA SYSTEM (ERDS): A computerized data link between the PNPP and NRC for the transmission of plant system/operations data and vent flow/radiation monitoring data. ERDS is activated by the PNPP at an Alert.

EMERGENCY RESPONSE FACILITY: Any of several on-site and off-site centers which are activated to coordinate emergency actions. Included in this category are the Control Room, Technical Support Center, Operations Support Center, Emergency Operations Facility, Joint Public Information Center, and State and local Emergency Operations Centers.

<u>EP INFO LINE</u>: PC/modem based system in which the State of Ohio and local counties can dial directly into plant computer system to access limited data on site meteorological conditions, plant vent flow rates and radiation monitor readings, and specific operational parameters.

<u>EXCLUSION AREA:</u> The area surrounding the Perry Plant in which First Energy Corp. has the authority to determine all activities including exclusion or removal of persons and property from the area during accident conditions.

<u>GENERAL EMERGENCY:</u> The most severe level of emergency classification which indicates that events are in progress or have occurred which involve actual or imminent substantial core degradation or melting with potential for loss of containment integrity. Release of radioactive material can be reasonably expected to exceed PAG exposure levels off-site.

<u>INGESTION EXPOSURE PATHWAY:</u> The principal exposure from this pathway would be from ingestion of contaminated water or foods, such as milk or fresh vegetables. The time of potential exposure could range in length from hours to months.

2000 EVEX SECT. 3.0 Page 8 of 11

2000 PERRY PLANT EVALUATED EXERCISE 3.0 General Information

3.4 DEFINITIONS

JOINT PUBLIC INFORMATION CENTER (JPIC): An off-site emergency response facility, located at the Lakeland Community College, in Kirtland, Ohio, which is staffed by First Energy, local, State, NRC and FEMA officials. The JPIC provides a forum and point of contact for a coordinated release of news and information to the news media, general public, First Energy Corporation employees and special interest groups.

OFF-SITE: Any area outside the Owner-Controlled Area fence surrounding the Perry plant.

ON-SITE: The area within the Owner-Controlled Area fence surrounding the Perry Plant.

OPERATIONS SUPPORT CENTER (OSC): The on-site location in close proximity to the Control Room and Technical Support Center to which plant support personnel and other Emergency Response team personnel report and await instructions. The OSC is located on the 599' and 574' levels of the Control Complex adjacent to the Radiological Restricted Area and the Health Physics/Chemistry areas.

<u>OWNER-CONTROLLED AREA:</u> The area continuous to the Protected Area designated by the owner organization to be controlled for security purposes.

<u>PLUME EXPOSURE PATHWAY:</u> The means by which a radioactive cloud (plume) can expose the population at risk and/or on-site personnel to radiation. The principal exposure sources for this pathway are (1) whole body external exposure to gamma radiation from the plume and from deposited material and (2) inhalation exposure from the passing radioactive plume. The time of potential exposure could range from hours to days.

POPULATION AT RISK: Those persons for whom protective actions are or would be taken.

<u>PROJECT SUPPORT AREA</u>: The area within the Site Boundary encompassed by a security fence which encloses the warehouse building, project organization office areas, and contractor support areas, and to which access is controlled for security purposes.

<u>PROTECTED AREA:</u> The area encompassing the Vital Areas requiring a double perimeter barrier fence and the Primary Access Control Point.

<u>PROTECTIVE ACTION:</u> Those emergency measures taken after an accident or an uncontrolled release of radioactive materials has occurred, for the purpose of preventing or minimizing radiological exposures to personnel that would likely occur if the actions were not taken.

2000 EVEX SECT. 3.0 Page 9 of 11

2000 PERRY PLANT EVALUATED EXERCISE 3.0 General Information

3.4 <u>DEFINITIONS</u> (Cont'd)

<u>PROTECTIVE ACTION GUIDES (PAGs):</u> Projected radiological dose to individuals in the general population that warrant protective action following a release of radioactive material. Protective actions would be warranted provided the reduction in individual dose is not offset by excessive risks to individual safety in taking the protective action. The PAG does not include the dose that has unavoidably occurred prior to the assessment.

<u>PUBLIC INFORMATION RESPONSE TEAM (PIRT):</u> A facility, located in the EOF NRC Office and staffed by First Energy Corporation personnel, which may be activated to handle increased media interest that does not warrant JPIC activation.

<u>RADIOLOGICAL CONTROL AREA (RCA):</u> An area off-site where access is controlled for radiological protection purposes.

<u>RADIATION MONITORING TEAMS (RMTs):</u> Two-person teams responsible for monitoring radiation levels in the environment and (in some cases) for collecting soil, air, and water samples for laboratory analysis.

<u>RADIOLOGICALLY RESTRICTED AREA (RRA)</u>: An area in-plant where access is controlled for radiological protection purposes.

<u>RECOVERY ACTIONS</u>: Those actions taken after an emergency to restore the plant as nearly as possible to pre-emergency conditions.

<u>RE-ENTRY ACTIONS</u>: The return to an evacuated area, in either the plant or site, for such actions as search and rescue, first aid, fire fighting, manipulation or repair of critical equipment or systems, and assess conditions in preparation for recovery operations.

SECONDARY ALARM STATION (SAS): The continuously manned security stations where all initial off-site and Emergency Response personnel notifications are conducted. The SAS is located in the Unit 1 Control Room.

SITE AREA EMERGENCY: The occurrence of an event or events which involve actual or likely major failures of plant functions needed for the protection of the public. The potential for a situation hazardous to the general public is the major concern of the Site Area Emergency classification. Radioactive releases are not expected to exceed the EPA Protective Action Guideline levels except within the Site Boundary.

<u>SYSTEM CONTROL CENTER (SCC)</u>: The off-site facility located in Brecksville, Ohio which controls and coordinates the generation and transmission within the First Energy Corporation system and with neighboring utilities.

2000 EVEX SECT. 3.0 Page 10 of 11

2000 PERRY PLANT EVALUATED EXERCISE 3.0 General Information

3.4 <u>DEFINITIONS</u>

<u>TECHNICAL SUPPORT CENTER (TSC)</u>: The on-site location which will serve as the focal point for gathering information on current and projected plant status and for the orderly implementation of emergency procedures in support of reactor command and control functions. The TSC is located on the 602'6" level of the Service Building.

<u>TOTAL EFFECTIVE DOSE EQUIVALENT (TEDE)</u>: The sum of whole body (external dose) and CEDE (internal dose).

<u>UNUSUAL EVENT</u>: The occurrence of an event or events, which indicate a potential degradation of the level of safety of the plant. Unusual event emergencies involve minor situations that have the potential to escalate to more serious emergencies. No releases of radioactive material requiring off-site response or monitoring are expected unless further degradation of safety systems occurs. (The unusual event classification corresponds to the Notification of Unusual Event classification specified in federal guidance.)

2000 EVEX

SECTION 4.0

CONTROLLER AND EVALUATOR INFORMATION

This section contains:

Section 4.1 - Controller Organizations

Section 4.2 - Controller Telephone Numbers

Section 4.3 - Controller Briefing Materials

Section 4.4 - Plant Self-Assessment Plan

SECTION 4.1

CONTROLLER ORGANIZATION

This section contains:

Section 4.1.1 - Perry Plant (Onsite) Controller Roster

Section 4.1.2 - Offsite Controller Roster

SECTION 4.2 CONTROLLER TELEPHONE NUMBERS

2000 PERRY EVALUATED EXERCISE

4.2 CONTROLLER TELEPHONE NUMBERS

1. The following telephone numbers will be used to contact Controllers in each of the designated Emergency Response Facilities. Instruments for "CONTROLLER USE ONLY" are colored <u>YELLOW</u>.

Facility	Telephone No. (280-XXXX)
Control Room (Simulator)	Ext. 5702
Operations Support Center (OSC)	Ext. 5541
Technical Support Center (TSC)	Ext. 5733
Emergency Operations Facility (EOF)	
- CEI Room - Display Room (Dose Assessment)	Ext. 5797 Ext. 7171
Public Information Response Team (PIRT)	Ext. 5219
Joint Public Information Center (JPIC)	269-7108
State of Ohio Emergency Operations Center (EOC)	614/799-3910
Ashtabula County EOC	440-576-9148
Geauga County EOC	440-285-9200 x7670
Lake County EOC	440-256-1415
Company Telephone Bridge	Ext. 7100

Any changes in scenario will be discussed with lead Controllers in the Simulator Room, TSC, and OSC <u>prior to implementation</u>. The TSC will be responsible for communicating scenario changes or concerns to the EOF.

2.

(open line between Simulator - OSC - TSC)

2000 PERRY EVALUATED EXERCISE

3. OSC / In-Plant Communications:

Field controllers will communicate to the Simulator Instructor's Console through the Lead OSC Controller, both prior to and after OSC activation.

The Lead OSC Controller will notify both the Simulator 'driver' and TSC of equipment restoration or delays affecting the scenario.

4. Extension Numbers for Simulated Off-Site Agencies:

Organization	Telephone No.
Nuclear Regulatory Commission:	
- Emergency Notification System (ENS)	ENS Mockup (use first no.listed)
- ENS Backup	Ext. 6018
- Health Physics Network (HPN)	HPN Mockup (use first no.listed)
- HPN Backup	Ext. 6043
Non-Mandatory Notifications:	
- NEIL	5680
Simulator Nos.:	
- STA	Ext. 5899
- SAS	Ext. 5931
- Communicator/CRA	259-2365 or Ext. 5694

SECTION 4.3

CONTROLLER BRIEFING MATERIALS

This section contains:

- Section 4.3.1 Onsite Controller Briefing Handout
- Section 4.3.2 Offsite Controller Briefing

SECTION 4.3.1 ONSITE CONTROLLER BRIEFING HANDOUT

SECTION 4.3.2 OFF-SITE CONTROLLER BRIEFING

2000 EVALUATED EXERCISE 4.3.2 OFF-SITE CONTROLLER BRIEFING

A. ROLE OF THE OFFSITE EXERCISE CONTROLLER

- 1. Ensure that the FEMA evaluator has access to facilities, people, and materials and can see what she/he wants to see.
- 2. Insert selected messages/data; and in some field demonstrations (such as ambulance or hospital play), organize/initiate exercise play with the FEMA evaluator.
- 3. Terminate exercise play with the approval of the FEMA evaluator.
- 4. Ensure that the exercise does not interfere with response to actual emergencies. Exercise play can be temporarily suspended so that emergency response agencies can respond to actual events, however, discretion should be practiced so that exercise play is not unjustifiably interrupted.
- 5. If exercise play becomes grossly misdirected, the Exercise Controller, with the concurrence of the FEMA evaluator, can redirect play to keep the overall response in accordance with the scenario. Examples:
 - a. County EOC believes it has received GENERAL EMERGENCY notification when the classification is an ALERT.
 - b. County EOC initiates evacuation upon declaration of a "State of Emergency" by the Governor.
 - c. County EOC actually activates field units that have not been designated as exercise participants.

B. EXERCISE SAFETY MEASURES

1. Should, at any time during the course of this exercise, an actual emergency situation arise, all activities and communications related to the exercise will be suspended. It will be the responsibility of any Exercise Controller that becomes aware of an actual emergency to suspend exercise response in his/her immediate area and to inform the Lead Exercise Controllers of the situation. Upon notification of an actual emergency, the Lead Controllers will notify all other Controllers to suspend all exercise activities.

2000 EVALUATED EXERCISE 4.3.2 OFF-SITE CONTROLLER BRIEFING

- 2. Should, at any time during the course of this exercise, an Exercise Controller witness an exercise participant undertake any action which would, in the opinion of the Controller, place either an individual or component in an unsafe condition, the Controller is responsible for intervening in the individual's actions and terminating that portion of the exercise and then contacting the Lead Exercise Controller and informing him of the situation.
- 3. No discharging of fire extinguishers or initiation of any fire suppression systems will be required for the Scenario.
- 4. Any motor vehicle response to this exercise, whether it be ambulance, fire fighting equipment, police/security vehicles or field monitoring teams, should observe all normal motor vehicle operating laws including posted speed limits, stop lights/signs, one way streets, etc. Emergency lights and sirens on vehicles are not to be used.
- 5. All telephone communications, radio transmissions and public address announcements related to the exercise must begin and end with the statement, "This is an exercise (or drill)." Should a Controller witness an exercise participant not observing this practice, it is the Controllers responsibility to remind the individual of the need to follow this procedure.
- 6. Exercise participants are to inject as much realism into the exercise as is consistent with its safe performance; however, caution must be used to prevent overreaction.
- 7. Care must be taken to ensure that any non-participating individuals who may observe exercise activities or overhear exercise communications are not misled into believing that an actual emergency exists. Any Exercise Controller or Observer who is aware of an individual or group of individuals in the immediate vicinity who may have become alarmed or confused about the situation, should approach that individual or group and explain the nature of the exercise and its intent.

C. EXERCISE CONTROLLER CONDUCT

- 1. Each Exercise Controller should be familiar with the following:
 - a. The basic objectives of the exercise.
 - b. Exercise safety.
 - c. The exercise scenario, including the initiating events and the expected course of action to be taken.

2000 EVEX Section 4.3.2 Page 2 of 3

2000 EVALUATED EXERCISE 4.3.2 OFF-SITE CONTROLLER BRIEFING

- d. The various locations that will be involved and the specific items to be observed when at those locations.
- 2. A summary and description of the Controllers' assigned locations, including an onsite exercise controllers organization chart is provided within this packet.
- 3. Controllers are assigned to various locations and are to be at their initial locations as per direction of the County Lead Controller.
- 4. If Controllers are to provide information via written message or oral response (e.g., initiating events, instrument readings, monitoring results, etc.) to the exercise participants, the information must be provided exactly as when prescribed. Failure to provide information appropriately may invalidate the results of the exercise.
- 5. Controllers should offer no information, advice, or assistance to the exercise participants. Any such requests should be respectfully declined. Controllers should only interpose themselves if the participants are taking an action that will cause the exercise to go far afield of the anticipated time schedule and/or outcome (see A-5 above).
- 6. Deficiencies and strong performance points should be noted for presentation in the critique with county representatives.

SECTION 4.4 PLANT SELF-ASSESSMENT PLAN

SECTION 5.0 SCHEDULE OF EVENTS

This Section contains:

Table 5.1 - (On-Site) Perry Plant Schedule of Events

Table 5.2 - (Off-Site) State/Local County Schedule of Events

2000 EVALUATED EXERCISE 5.1 ONSITE SCHEDULE OF EVENTS

SCHEDULE OF EVENTS

DATE	<u>TIME</u>	<u>EVENT</u>	LOCATION
Thursday, March 16	1000 to 1100	Players' Briefing	PC201 ¹
Monday, March 20	0900 to 1100	Controllers' Briefing	PC101
	1330 to 1400	Phone Cell Controllers' Briefing (ENS, HPN, "5-Way", INPO, etc.)	TEC 110/111
	1500 to 1630	NRC Entrance Meeting & Briefing	TEC Auditorium
	1630 to 1730	NRC Plant Tour, Badging, etc.	
Tuesday, March 21	0630 to 0700	OSC/In-Plant Supervisors Turnover Briefing	PACP 2nd Floor Conference Room
	0630 to 0700	Control Room Crew Turnover Briefing	TEC Simulator Room
	0700 to 1600 ²	Exercise	
	1600 to 1700	In-Facility Critiques	
	1700 to 1800	Lead Controller Debriefing	TEC 110/111
Wednesday, March 22	1400 to 1530	Lead Controllers Meeting	TEC 110/111
	1600 to 1630	Meeting with NRC Team Leader (if requested)	TEC-EOF NRC/ PIRT Room
Thursday, March 23	0900 to 1030	Post-Exercise Criteria	TEC Auditorium (On- Site/JPIC)
	1030 to 1100	NRC Exit Meeting	TEC Auditorium
Friday, March 24	11:00-12:00	NRC and FEMA Briefing of the Public	Lake County EOC

PC refers to the In-Processing Center located outside the Protected Area behind the P&R Building.

²Control Room, Technical Support Center (TSC), and Operations Support Center (OSC) staffs will be allowed to de-mobilize at the lead facility controller's direction prior to exercise termination based on the scenario time-line. A critique will be held in each facility with players immediately following staff demobilization.

2000 EVALUATED EXERCISE 5.2 OFF-SITE SCHEDULE OF EVENTS

SCHEDULE OF EVENTS

DATE	TIME	EVENT	LOCATION
Monday, March 20, 2000	11:00-12:00	Off-Site Exercise Controllers Briefing	Perry Power Plant Administration Building
	14:00-16:00	Federal Emergency Management Agency (FEMA) Pre-Exercise Briefing	To Be Announced (TBA)
	18:00-21:30	Off-Site Out-of-Sequence Exercise Demonstrations	Lake County
Tuesday, March 21, 2000	08:00-16:00	In-Sequence Exercise Demonstrations	Lake, Geauga and Ashtabula counties
	18:00-22:00	Off-Site Out-of-Sequence Exercise Demonstrations	Lake, Geauga and Ashtabula counties
Wednesday, March 22, 2000	09:00-22:00	Off-Site Out-of-Sequence Exercise Demonstrations	Lake, Geauga and Ashtabula counties
Thursday, March 23, 2000	08:00-12:00	Off-Site Lead Exercise Controllers Brief Ohio EMA	TBA
Friday, March 24, 2000	09:00-10:30	FEMA Briefing of Key Exercise Participants	Lake County Emergency Operations Center (EOC)
	11:00-12:00	Nuclear Regulatory Commission (NRC) and FEMA Briefing of the Public	Lake County EOC

Note: See "Off-site Action Locations" document for detailed times and locations of off-site exercise demonstrations.

SECTION 6.1

INITIAL CONDITIONS/TURNOVER DOCUMENTS

This section contains:

Section 6.1.1 - Initial Conditions Summary

Section 6.1.2 - Control Room Turnover Documents (turnover sheets, current tagouts, active LCOs, etc.)

2000 EVALUATED EXERCISE 6.1.1 ONSITE INITIAL CONDITIONS SUMMARY

The Perry Plant is at 100% power following completion of a refueling outage. The following is a listing of the status of plant systems and significant evolutions in progress:

Mini-Scenario Reference

- 1. A malfunction occurred early third shift on March 20th with the Reactor Feed Pump Turbine (RFPT) 'A' Level Controller, 1C34-R601, such that the gain changer, 1C34-K602, does not recognize when RFPT 'A' is in AUTO. To support I&C troubleshooting efforts, RFPT 'A' has been Transferred to the manual speed control dial and RFPT 'B' placed on the Startup Level Controller.
- 2. Header 'B' of the Safety-Related Instrument Air System (P57) was isolated at 0500 hours and the header depressurized as part of a planned outage. Work activities include the repair of a severe packing leak on Containment Isolation Valve, 1P57-F015B. A temporary air supply has been installed in the containment upstream of Drywell Isolation Valve, 1P57-F020B, per a temporary modification as make-up for normal header leakage. Header 'B' is expected to be returned to service by 0930 hours. [12 hour LCO per TS 3.5.1]

MS No. 2

MS No. 1

- Standby Liquid Control (SLC) 'A' Pump, 1C41-C001A, was taken out of service for preventive maintenance (Repetitive Task R85-4753) on third shift. Upon inspection, water was discovered in the oil drained from the SLC 'A' Pump. An oil sample has been delivered to Chemistry for analysis. [7 day LCO per TS 3.1.7]
- 4. Residual Heat Removal (RHR) 'A' Pump, 1E12-C001A, was returned to service at 0600 hours following an oil replacement due to high particulates in the upper oil reservoir.
- 5. Annulus Exhaust Gas Treatment (AEGTS) Fan 'A', 1M15-C001A, was taken out of service on March 19th for a fan bearing replacement. Repairs should be completed by second shift tomorrow. [7 day LCO per TS 3.6.4.3]

SECTION 6.1.2

CONTROL ROOM TURNOVER DOCUMENTS

This section contains:

- Crew turnover briefing sheets
- Current tagouts
- Active LCOs

SECTION 6.2 PERRY PLANT ONSITE SEQUENCE OF EVENTS

Approximate Time	Key Events	Reference
0700	Initial conditions established in Control Room Simulator. The 2000 Evaluated Exercise commences.	
0720	Control Room has indication of the inadvertent opening of Safety Relief Valve (SRV) 1B21-F051D. Actions taken per Off-Normal Instruction (ONI) B21-1, "SRV Inadvertent Opening/Stuck Open", are not successful in closing the SRV. Suppression Pool temperature starts to rise. The Control Room will initially decrease Rx power to ≤90% per ONI-B21-1, then should consider commencing a controlled reduction in power per Integrated Operating Instruction (IOI)-3, "Power Changes", in preparation for plant shutdown.	
0725	Control Room Operators should place both loops of Residual Heat Removal (RHR) into Suppression Pool Cooling mode. During the realignment of RHR 'B' loop per System Operating Instruction (SOI) E12, the RHR 'B' Pump Minimum Flow Valve, 1E12-F064B, fails to close, thereby reducing flow to the RHR 'B' Heat Exchanger. Suppression Pool temperature stabilizes.	MS No. 3
0750	Alarms are received at the Secondary Alarm Station (SAS) indicating a potential fire in the RHR 'A' Pump Room. A Perry Plant Operator (PPO) and Fire Brigade First Responder are dispatched to the scene of the fire. The RHR 'A' Pump, 1E12-C001A, should be removed from service by the Control Room.	MS No. 4
0753	If not yet secured, the RHR 'A' Pump will trip. Perry Township Fire Department is notified by the Secondary Alarm Station (SAS) and responds to the Perry Plant site.	
0755	The System Engineer trips and falls in the RHR 'A' Pump Room. The Engineer suffers a sprained ankle and a radiologically contaminated laceration to his left forearm. The Engineer is able to exit the RHR 'A' Pump Room without assistance.	MS No. 5

Approximate Time	Key Events	Reference
0800	An ALERT should be declared per Initiating Condition FA1, "Fire affecting the operability of plant safety systems required to establish or maintain safe shutdown".	
	The Technical Support Center (TSC), Operations Support Center (OSC), and Public Information Response Team (PIRT), if not yet mobilized at the Shift Supervisor's discretion, are activated per Emergency Plan Implementing Instruction (EPI) -A6, "TSC Activation", and -A7, "OSC Activation".	
~0815	Injured worker is relocated by the First Aid Team to the Radiological Restricted Area (RRA) Control Point, located on the 599' elevation of the Control Complex Building, and transferred to Perry Township Fire Department personnel. The victim is subsequently transported to Lake East Hospital (Painesville, OH).	
0830	A Rod Control and Information System (RC&IS) failure occurs prohibiting the manual insertion of control rods.	MS No. 6
~0915	The plant receives a phone call pointing to sabotage as the cause of the fire in the RHR "A" pump. Site Security investigates.	
0920	Control Room annunciators are lost due to a failure in Breaker D1A06. Operators enter ONI-R61, "Loss of Control Room Annunciators (Unit 1)", and take actions to stabilize the plant and augmented Control Room staffing to monitor plant indications.	MS No. 7
0935	Control Room receives call from SNSO of act of sabotage in RHR A/B Pump rooms. A SITE AREA EMERGENCY should be declared per Initiating Condition NS1, "Security Event in a plant Vital	MS No. 5A
	Area." The Emergency Operations Facility (EOF) and Joint Public Information Center (JPIC) are activated per EPI-A8, "EOF Activation".	
~0950	Repairs to the RHR 'B' Pump Minimum Flow Valve are completed, and the valve is closed.	
~1005	RC&IS is returned to service. Operators should commence a controlled shutdown of the plant.	

Approximate Time	Key Events	Reference
1015	A weld failure occurs on a test-connection reducing tee downstream of 1P57-F020A, depressurizing the Safety-Related Instrument Air System 'A' Header in Containment. Safety-Related Instrument Air is now unavailable to accumulators for all eight Automatic Depressurization System (ADS) SRVs.	
	[NOTE: Operators may not immediately observe the loss of air pressure in P57 'A' Header due to the loss of Control Room annunciators.]	
	Repairs to Containment Isolation Valve, 1P57-F015B, should be expedited to support restoration of the 'B' Header.	
1030	Control Room annunciators are restored.	
1045	A leak occurs in Containment on the Instrument Air System (P52). Air pressure on the parallel header in Containment decreases rapidly. Operators enter ONI-P52, "Loss of Service and/or Instrument Air".	
	If Operator attempts to isolate the break by closing Instrument Air Containment Isolation Valve, 1P52-F200, parallel header air pressure will decrease rapidly.	
1048	One Scram Discharge Volume (SDV) drain valve fails closed due to low instrument air pressure. The SDV starts to fill.	
1049	INST VOL NOT DRAINED annunciator is received in the Control Room. Per ONI-P52, Operators commence a fast reactor shutdown.	

Approximate Time	Key Events	Reference
1051	Following a manual runback in reactor recirculation flow, a manual scram is initiated but control rods do not fully insert due to insufficient SDV capacity. Due to the loss of instrument air, the inboard Main Steam Isolation Valves (MSIVs) fail closed and SDV Vent Valves, 1C11-F010 and -F180, and Drain Valves, 1C11-F011 and -F181, cannot be repositioned to drain the SDV. Operators enter Plant Emergency Instructions (PEIs)-B13, "RPV Control (ATWS)", and -T23, "Containment Control".	
	Reactor Core Isolation Cooling (RCIC) and High Pressure Core Spray (HPCS) automatically initiate at Level 2 (130") to assist the Motor Feed Pump (MFP) in restoring RPV level. HPCS is secured by the Control Room Operators per PEI-B13(ATWS).	
1053	SRVs cycle to control Reactor Pressure Vessel (RPV) pressure, bleeding off pressure in SRV accumulators. Once pressure is lost in the accumulators, the ability to emergency depressurize the RPV is lost.	
1055	Per PEI-B13 (ATWS), Operators should take the following actions to reduce reactor power:	
	Initiate boron injection. However, Standby Liquid Control (SLC) 'B' Pump fails to start. Operators should enter PEI-SPI (Special Plant Instruction) 1.8, "Alternate Boron Injection".	MS No. 8
	Attempt to insert control rods per PEI-SPI 1.3, "Manual Rod Insertion". Control rods do not insert due to a loss of drive pressure when Control Rod Drive Flow Control Valve, 1C11-F002A, fails closed on a loss of instrument air.	•
	Lower RPV level as a means of Reactor power control.	

Approximate Time	Key Events	Reference
1105	A weld failure occurs on the upstream (RPV) side of RCIC Steam Supply Outboard Isolation Valve, 1E51-F064. Position indication is lost for the 1E51-F064 valve due to an electrical short at the valve caused by the release of steam. [NOTE: Since the weld failure occurs upstream of 1E51-F064, the actual position of the valve does NOT impact the scenario.]	
	Steam Tunnel temperatures increase dramatically above isolation setpoints. Elevated radiation levels are indicated in the Steam Tunnel and at the Turbine Building/Heater Bay (TB/HB) Vent monitor.	
1110	A RCIC isolation signal is received due to high steam line differential pressure. However, the RCIC Steam Supply Inboard Isolation Valve, 1E51-F063, fails to close when commanded. An unisolable release pathway to the environment now exists from the RCIC System into the Steam Tunnel and out the TB/HB Vent.	MS No. 9 Figure 8.5.2
1125	A GENERAL EMERGENCY is declared based on Initiating Condition CG1, "Failure to initiate or complete a successful shutdown, AND indication of an extreme challenge to the ability to cool the core". Classification is based on a scram occurring, the Rx is NOT shutdown, Suppression Pool temperature is >110°F, and entry into the UNSAFE region on the Heat Capacity Limit (HCL) curve.	
	Dose projections based on the postulated offsite release do not justify exceeding the default EVACUATE protective action recommendation (PAR) for a General Emergency.	
1225	Motor Feed Pump (MFP), 1N27-C004, trips on low lube oil pressure. RPV levels starts to decrease. CRD pumps now serve as the only means of high-pressure make-up to the RPV. Operators are unable to emergency depressurize per PEI-B13 (ATWS).	MS No. 10
~1230	RPV level drops below the top of active fuel (TAF), 0".	
	Per PEI-B13 (ATWS), Operators will initiate HPCS if it is determined that RPV level can NOT be maintained greater than -25" AND <2 SRVs are open.	

Approximate		
Time	Key Events	Reference
1235	Containment and TB/HB Vent radiation monitors increase drastically as a result of HPCS injection or when RPV level approaches -25". [NOTE: Per PEIs, adequate core cooling can NOT be ensured under ATWS conditions if RPV level decreases below -25".]	
1250	Offsite protective action recommendation (PAR) is revised based on actual vent radiation monitor readings.	
1320	The SLC 'B' Pump is restored. Boron injection into the RPV is initiated to bring the Reactor subcritical.	
1335	Safety-Related Instrument Air Header 'B' is returned to service, and ADS capability is restored to 4 SRVs.	
	Per PEI-B13 (ATWS), HPCS is secured and emergency depressurization of the RPV is initiated. The driving force for the offsite release into the Steam Tunnel via RCIC is eliminated.	
~1340	Repairs to the MCC EF1D07 completed. The RCIC Steam Supply Inboard Isolation Valve is successfully closed isolating the RCIC System.	
1415 - ~1500	Emergency Phase terminated onsite. Commence onsite Recovery discussions.	

SECTION 6.3

OFF-SITE SEQUENCE OF EVENTS

Date Time	PNPP Key Events and Actions	Ohio Response	County and Local Agencies Response
3/20/00 1800			(L) Out-of-sequence demonstration. Lake County FMTs inventory of equipment supplies - Lake EOC Parking lot.
1830			(L) Out-of-sequence demonstration. Monitoring/Decontamination (M/D) of the public is demonstrated by Kirtland FD at Kirtland High School.
			(L) Out-of-sequence demonstration. Congregate Care Center operations are demonstrated by the Red Cross at Kirtland High School.
1900			(L) Out-of-sequence demonstration. Back-up Route Alerting is demonstrated by Leroy Township FD.
3/21/00 0700	Initial conditions are established. In-sequence exercise commences.	1	
0720	Safety relief valve sticks open. RHR "B" loop minimum flow valve fails to close.		
0750	Fire in RHR "A" Pump Room. Perry Twp. Fire Department notified.		(L) Perry Twp. Fire Department responds to PNPP.

Date	PNPP Key Events and Actions	Ohio Response	County and Local Agencies Response
7ime 0753	A Plant worker falls and sprains his ankle and suffers a radiologically contaminated laceration of the arm.		(L) Perry Twp. Fire Department responds with ambulance to PNPP.
0800	An ALERT is declared due to a fire potentially affecting safe shutdown. Notifications to the State and counties are made. The Technical Support Center and the Operations Support Center are activated. The PIRT (Public Information Response Team), an activity co-located with the EOF, will be activated at this time. The PIRT will function until the JPIC becomes operational.	The Ohio State Highway Patrol receives the notification and notifies selected State agencies and personnel. Ohio EMA partially activates the State EOC in Columbus. ODH dispatches assessment personnel to the State EOC. Dispatch of Field Monitoring Teams is simulated (FMTs are prepositioned). Inspection and inventory of FMTs equipment and supplies commence in the parking lot of the Lake County EOC.	The Sheriff's Departments, or the counties' EMAs, of Ashtabula, Geauga, and Lake Counties receive the notification and activate or notify stand-by agencies and individuals per their respective procedures. Counties utilize telephones, radios, and pagers per procedures. (L) Two Lake County field-monitoring teams are assembled at the Lake County EOC and when ready may be dispatched to field locations.

Date Time	PNPP Key Events and Actions	Ohio Response	County and Local Agencies Response
0815		Ohio EMA simulates dispatch of Ohio National Guard helicopter to deliver state assessment personnel to the EOF and PI personnel to the JPIC.	Per procedures, selected EOC staff personnel report to their respective EOCs and commence assigned duties.
		(These personnel are prepositioned.) Ohio EMA notifies ONG, who then dispatch personnel to the three county	(L) Lake County will place a call to the Common Program Control Station (WGAR) and place them on stand-by status.
		EOCs.	(L) Perry Township FD personnel at PNPP receive from PNPP fire brigade personnel a
		Ohio EMA simulates dispatch of representatives to the counties' EOCs. (These personnel are prepositioned.)	contaminated and injured patient and demonstrate handling, care, and transport of the patient.
		Ohio EOC simulates dispatch of the Communication Van (OEMA), and the Sample Screening Print (ODH).	
		All of these people are prepositioned.	

Date Time	PNPP Key Events and Actions	Ohio Response	County and Local Agencies Response
0845		If the JPIC is activated, the State PIO begins coordinating releases of information to news media at the JPIC with PIOs of participating agencies upon their arrival at the JPIC.	(L) The Perry Township FD personnel transport the patient to the Lake East Hospital ER personnel, who demonstrate decontamination and care of the patient.
			If the EOF is activated the counties may send a representative there.
			If the JPIC is activated the counties may send their PIOs to commence with public information duties there.

Date Time	PNPP Key Events and Actions	Ohio Response	County and Local Agencies Response
0920	Loss of Control Room annunciators. Actions are taken to stabilize the plant and augment staff to monitor plant indicators.		
0935	A SITE AREA EMERGENCY (SAE) is declared due to sabotage inside a plant Vital Area. If not already activated, the Emergency Operations Facility (EOF) and the Joint Public Information Center (JPIC) are activated. The Technical Support Center (TSC) Security Coordinator calls the Lake County EOC and requests traffic control to assist with evacuation of non-essential personnel from the PNPP Site. Evacuation of non-essential personnel is simulated.	Ohio EOC receives notification of the SAE declaration over the 5-way dedicated phone link in the assessment room. Notification begins to agencies not yet activated to respond to the State EOC for the duration of the emergency. The Office of the Governor declares that a "State of Emergency" exists, and directs full activation of the State EOC and Ohio National Guard. Ohio EMA requests from the Federal Emergency Management Agency (FEMA) for support from the DOE and the Coast Guard to include: 1. Field monitoring for noble gas and iodine.	Lake, Ashtabula and Geauga Counties receive notification of the SAE declaration over the 5-way dedicated phone. EOC personnel not yet in the EOC are notified and asked to report for duty. The counties' EOC Executive Groups ensure that a "State of Emergency" is declared and that planned state assistance is activated. Ashtabula, Geauga, and Lake counties each demonstrate actual notifications to all of their respective response agencies. (Police and Fire Department, School Districts, Hospitals, county agencies, and selected others). NOTE: This is the only full notification demonstrated by the counties.
	·	2. Field sampling, including analysis to determine particulate depositions.	Field response agencies assemble personnel and equipment (Simulated; also, see out-of-sequence play).

Date Time	PNPP Key Events and Actions	Ohio Response	County and Local Agencies Response
0935		3. Logistic support for Federal response.	Traffic Control points are planned and coordinated in EOCs.
		4. Notification support for Lake Erie.	·
		ODH and Ohio Dept. of Agriculture makes an initial recommendation on livestock and poultry.	(L) Lake County Field Monitoring Teams, if not already in field locations, are dispatched to appropriate field locations.
		Consolidated Railways (CONRAIL) and Norfolk & Southern Railways are notified to restrict rail traffic in the 10-mile EPZ. (Simulated)	Monitoring/decontamination station (center) teams, once assembled and ready may move to assigned locations (Simulated, see out-of-sequence play).
		Federal Aviation Administration (FAA) is notified to restrict air traffic in the 10-mile EPZ. (Simulated)	EOCs demonstrate the ability and the availability of the resources necessary to effect evacuation of people with special needs.
		Communication links are established among the State EOC, the EOF (State's liaison), and the JPIC (State's PIO);	Public Information Hotlines (rumor control) in the EOCs begin receiving calls.
		back-up means are provided by the Communication Van.	Care Center personnel report to assigned care centers (simulated; see out-of-sequence play).

Date Time	PNPP Key Events and Actions	Ohio Response	County and Local Agencies Response
0935		The State's two Field Monitoring Teams will begin demonstration of procedures related to field movements. The State Representative in the Lake County EOC will direct the teams to appropriate locations. The starting point will be the Lake County EOC. Rumor Control begins receiving calls.	
1125	A GENERAL EMERGENCY is declared due to failure to initiate or complete a successful shutdown, AND indication of an extreme challenge to the ability to cool the core. The State and counties are notified. Notification includes protective action recommendations.	State Assessment team receives notification of the GENERAL EMERGENCY and takes the utility's recommendations under advisement. The team formulates the State's recommended protective actions, obtains Governor's (or designated representative in EOC) approval and informs the counties of the Governor's recommendations via the Executive Discussion Line. Appropriate officials/agencies/ media are informed of change in status.	Counties' Executive Groups are informed of the plant's change in status and the utility's recommendations for protective actions. Counties Executive Groups commence deliberation via the Executive Discussion Line (EDL). Counties simulate notifications to all field agencies.
		ODH Sample Screening Point personnel, at Ledgemont Elementary School, Thompson Twp., will simulate handling of environmental samples.	Care centers are fully activated. (Simulated; see out-of-sequence play.) Monitoring /decontamination stations for emergency workers and
		State Assessment Team begins continuous monitoring of emergency workers exposure.	monitoring/decon centers for public are activated, if not already activated. (Simulated, see out-of-sequence play).

Date Time	PNPP Key Events and Actions	Ohio Response	County and Local Agencies Response
1145			A three county coordinated Protective Action Decision with the State is made via the EDL.
			(L) Lake County assembles an EAS message, simulates the sounding of sirens, and delivers the message to WGAR radio station. WGAR simulates broadcast over the air.
			(L) Lake County transmits a copy of the EAS message to the JPIC, State EOC, EOF, and the other two counties.

Date Time	PNPP Key Events and Actions	Ohio Response	County and Local Agencies Response
1250	PNPP makes a second Protective Action Recommendation based on drastically increased vent radiation monitor readings.	The State Dose Assessment Group conducts dose assessment based on the increased vent monitor readings and then delivers a new Protective Action Recommendation to the counties via the Executive Discussion Line. ODA and ODH make additional recommendations on livestock and poultry.	The three counties receive the new Protective Action Recommendations from PNPP and the State and arrive at a second Protective Action Decision. (L) Lake County assembles a second EAS message, simulates siren sounding and orally delivers the EAS message to WGAR radio station where it is recorded but not broadcast. WGAR personnel describe the procedure for broadcast of the message over the air. (L) Lake County transmits a copy of the EAS message to the State EOC, JPIC, EOF, and the other two counties.
1320	Boron is injected into the Reactor Pressure Vessel (RPV).		
1335	RPV is depressurized.		
~1400	The release plume has dissipated. PNPP terminates Emergency Phase. On-site recovery discussions begin.		

Date	PNPP Key Events and Actions	Ohio Response	County and Local Agencies Response
Time			
1430		State of Ohio terminates exercise demonstration.	Ashtabula, Geauga, and Lake counties terminate exercise demonstration.
1900			(L) Out of-sequence demonstration.
	÷		M/D of Emergency Workers (EW) is demonstrated by the Mentor FD at the Mentor H.S. Football Stadium.
1900			(A) Out-of-sequence demonstration. Congregate Care Center operations are demonstrated by the ARC at the Rowe Middle School in Conneaut.
			(A) Out-of-sequence demonstration. M/D of the public is demonstrated by the Conneaut FD at the Rowe Middle School.
<u>3/22/00</u> 0900		-	(G) Out-of-sequence demonstration. Interview of the Ledgemont SD Superintendent, High School Principal, Transportation Supervisor, and bus driver at the Ledgemont Elementary School.

Date Time	PNPP Key Events and Actions	Ohio Response	County and Local Agencies Response
0930			(L) Out-of-sequence demonstration. Interview of Painesville Twp. SD Superintendent, High School Principal, Transportation Supervisor, and Bus Driver at Board of Education Office.
1100			(L) Out-of-sequence demonstration. Interview of Painesville City SD Superintendent, High School Principal, Transportation Supervisor, and Bus Driver at Board of Education Office.
1300			 (G) Out-of-sequence demonstration. Traffic/Access Control Point is demonstrated at SR 608 and US 6 in Hambden by the Geauga County Sheriff's Office. (L) Out-of-sequence demonstration. A Traffic/Access Control Point is demonstrated at US Route 20 and Fairgrounds Road by Lake County Sheriffs
			Dept. (A) Out-of-sequence demonstration A Traffic/Access Control Point is demonstrated at I-90 and SR 534 by Ohio Highway Patrol.

Date Time	PNPP Key Events and Actions	Ohio Response	County and Local Agencies Response
1900			(G) Out-of-sequence demonstration. Congregate Care Center operations are demonstrated by the ARC at the Cardinal H.S.
			(G) Out-of-sequence demonstration. M/D of the public is demonstrated by the Middlefield FD at the Cardinal H.S.
			(A) Out-of-sequence demonstration. Geneva-on-the-Lake FD demonstrates Back-up Route Alerting.

SECTION 6.4 USE OF SIMULATOR AND ICS

USE OF SIMULATOR AND ICS

During the 2000 Evaluated Exercise, the Perry Plant Simulator will be programmed to provide real time data to the Simulator panels and designated Integrated Computer System (ICS) terminals located in certain Perry Plant Emergency Response Facilities. Table 6.4 outlines the operational guidelines, which will be utilized by the Controller Organization to program the exercise events into the Simulator computer.

A networking arrangement will connect designated ICS "drill" terminals in the Technical Support Center (TSC), Operations Support Center (OSC), and the Emergency Operations Facility (EOF) to the Simulator's ICS computer. Exercise participants in these facilities will utilize ICS, which is their normal data acquisition method, to access scenario operations and radiation data.

In the event of failure of the Simulator ICS computer or networking arrangement, the TSC and EOF will establish an alternate telephone loop with the Control Room Simulator to acquire plant operational data. The Control Room staff will continue to assess plant conditions using the instrumentation and annunciators located on the Simulator panels.

If a "non-fatal" simulator error occurs, controllers may be able to reprogram the simulator to the time just prior to the error. This will result in the exercise being suspended for about 2 minutes. This action should not affect exercise conduct. When a failure or malfunction occurs in the Simulator processing computer, data sheets described in Section 7.1 of the Exercise Manual will be utilized in the Simulator, TSC and EOF.

SCENARIO SETUP

NOTE:

Files on TGIS (FILE\\DATABOOK\BATCH\EPLANHCD)

Tie in the MSL Rad. Monitors & Cntmt Vent Exh. Rad Monitors

Reload RT Executive 40,2 from user EPLAN

NOTE:

For ICS & simulator to be in sync with respect to time, DO NOT put

simulator in FREEZE after going to RUN.

1. Reset to IC 78, verify/establish the following conditions:

- a) RFPT 'B' on SULC, RFPT 'A' on Manual Speed Control Dial.
- b) SLC 'A' Out-of-Service Switch in "INOP"
- c) AEGTS Train 'B' in service
- d) AEGTS Train 'A' switch in "INOP"
- 2. Close 1P57-F015B and 1P57-F020B BEFORE executing the Batch File.
- 3. Execute batch file "EPLANHCD". Verify items in Attachment 1 of this section.
- 4. Hang red tags on:
- · a) M15A Fan and Heater Control Switches
 - b) SLC Pump 'A' Keylock Switch
 - c) P57-F015B Control Switch
 - d) P57-F020B Control Switch
- 4. Perform the following actions at instructor area back terminal:
 - a) Push F6
 - b) Owner name: "LOAD" RETURN RETURN
 - c) TSM: "ISD V" RETURN
 - d) Path: "HCD"
- <u>RETURN</u>
- e) EXECUTIVE: "RTEX30,3" RETURN
- f) ISD: "DCM"
- **RETURN**
- g) ISD: "PAGE 1"
- RETURN
- h) ISD: "D ADKSRVMINPRESS" RETURN
- 5. Verify info tag file inserted

SCENARIO OPERATIONAL GUIDANCE

TIME	ACTION	NOTES
0700	Place Simulator in "RUN" Activate CAEP EPLAN_METDATA	Scenario start time
0720	Initiate trigger E1 (SRV F051D Leakage)	Adjust leakage severity to 10%, When 1E12F064B fails to close, adjust severity to 5%
0751	Initiate trigger E2	High RHR Room temperature alarms, two minutes later RHR 'A' pump trips
~0753-0759	Initiate trigger E3	Removes RHR Room high temperature alarms. To be initiated upon report that fire is out.
0830	Initiate trigger E4	RC&IS lockup, loss of control rod movement.
0920	Initiate trigger E5	Loss of D1A06 (annunciators), after 55 minute delay P57 'A' Hdr. Pressure decreases to '0' psig
~0950	Delete malfunction MV05:1E12F0064B	Remove malfunction when repairs to valve have been completed, or Override the RED and GREEN lights off, and remove the malfunction if the valve is manually isolated.
~1005	Initiate trigger E17	Deletes RC&IS failure, initiation of this trigger needs to be coordinated with in-field controller
1015	None	P57 'A' header depressurizes with 5 minute ramp to 0 psig
~1030	Delete malfunction ED17D	Remove malfunction when repairs to D1A06 are completed.

TIME	<u>ACTION</u>	NOTES
1045	Initiate trigger E6	Instrument air leak in containment causes a scram and MSIV isolation. 5 seconds after the parallel header reaches 50#, the INST VOL NOT DRAINED annunciator will alarm
1046-1053	At back simulator terminal type "S 1 300"	Perform this action within 1-2 minutes after MSIV isolation. This prevents all SRV actuation with exception of the Safety Mode. (SRVs will cycle a few times first)
~1053	None	SLC Pump 'B' fails upon start signal.
1105	Initiate trigger E8 (RCIC Steam in Stm Tunnel)	E51-F064 fails and radiation monitors start to ramp up.
1110	Initiate trigger E14	Causes RCIC isolation signal but E51-F063 fails to close.
1225	Initiate trigger E9 <u>and</u> adjust severity of malfunction RV02:1B21F0051D to 50%	Motor Feed Pump trips on low lube oil pressure and SRV F051D opens, causing level to decrease.
1230-1235	At 0" RPV level or if HPCS is initiated, initiate trigger E15	Containment and TB/HB radiation monitors increase drastically. If necessary, adjust SRV F051D leakage.
~1320	Toggle RF SL12 to CLOSE	Closes breaker for SLC pump "B"
1330	Adjust malfunction RV02:1B21F0051D to stabilize RPV pressure less than 1050#	Important to be less that safety relief setpoints prior to next step.
~1330	Read Override File (ror) P57Lights	When tags are cleared on P57 valves.
1334	Initiate trigger E7	Fails all SRVs closed except F051D.
1335	At back simulator terminal type "S 1 75"	Allows operation of 4 SRVs after next step.

2000 EVEX

Section 6.4

Page 4 of 5

<u>TIME</u>	ACTION	NOTES
1335	Initiate trigger E13	ADS 'B' Header SRVs returned to operation.
1337-1340	Initiate trigger E16	Radiation monitors start to ramp down.
1340	Delete malfunctions MV06:1E51F0063 BS02:1E31N0683A BS02:1E31N0683B	Remove malfunction when repairs to E51-F063 are completed.
1415-1530	Place simulator in freeze	End of scenario Ensure all Lead Controllers have determined that objectives have been evaluated.
1530-1630	Restore normal simulator training load. Restore simulator communications switch to the training mode, notify the control room unit supervisor.	

SECTION 7.0

MESSAGES/PLANT DATA

Contents of this Subsection:

Section 7.1 - Player/Controller Message Summary

Section 7.2 - Plant Data Database (ICS)

Section 7.3 - EP INFO Line Database

This subsection contains a listing of messages that may be used by controllers to interject information, prompt play actions, or control the progress of the scenario. The individual message forms are to be handed out in accordance with the instructions in the Controllers Notes on Table 7.1. An example of the message format used is contained on Figure 7.1.

The various types of messages used to coordinate exercise play are as follows:

- O Contingency messages are noted with a number followed by the letter "C" (e.g., 10C). Contingency messages are delivered only if certain predetermined conditions identified in the "Controller Notes" have been met.
- o Simulator Messages are noted with a number followed by the letter "S" (e.g., 12S). Simulator messages are delivered to the Simulator operators only if the Simulator is not operable.
- Other messages are handed out per the instructions listed in the "Controllers Notes" portion on Table 7.1 or are for information for the Exercise Controllers.
- Other information which may be given to a Participant <u>only if earned</u> is provided in the individual Mini-scenarios.
- o Messages to Controllers are for information only. Message forms are not printed for these.

* * THIS IS A DRILL * *

Time: _0915

Message No: 14

2000 PERRY EVALUATED EXERCISE

EXAMPLE MESSAGE FORM

Message For: SAS

Message: The following alarm is received on the Fire Alarm Computer.

710.03 AL FIR SO/HD's: 574' I.B; ACCESS AREA.SDP H51-P927 599CC C-5

* * THIS IS A DRILL * *

Figure 7.1

MESSAGE No:	TIME	MESSAGE FOR	MESSAGE	CONTROLLERS	ACTIONS EXPECTED
1	0630	Simulator Controllers	Verify the following: I. The Simulator communication switch is in "E-Plan" Mode 2. Contact the Control Room to have them unplug: - 3-Way Circuit - STA Ringdown - Auto-Dialer	NOTES	
2.		Control Room Staff .	Refer to sheets for turnover briefing: • Unit 1 Daily Status Report • Shift Turnover Sheets • LCO Tracking Logs • Tag Out Sheets	1. The most recent chemistry analyses are located in Section 8.2, Provide the data if participants request additional chemistry information. 2. If participants request meteorological information and describe how they would access it, provide the information from Section 8.3. 3. See the appropriate miniscenarios for details on the following equipment which is out of service: a. Repairs to Safety-related Instrument Air Header 'B' Header Isolation Valve 1P57-F015B. Miniscenario No. 1. b. Standby Liquid Control Pump, 1C41-C001A: Miniscenario No. 2. 4. If the simulator is not in operation for the exercise, see	1. Review initial conditions and ensure all understand them.
38	0700	Control Room	See Attached Sheets for Initial Plant Conditions: •Control Room Annunciators •Plant Technical Data Screen •Plant Overview Screen •Radiation Data Summary Screen	Message No. 3S. The referenced data sheets are to be given to the control room staff only if the Simulator is not operable for the exercise.	

4	0700	Simulator Shift Supervisor	1. Notify the Control Room Shift Supervisor of the commencement of the Exercise. 2. Make the following PA announcement: "Attention, attention all personnel; we are now commencing the 2000 Emergency Preparedness Exercise. All announcements prefaced by 'This is a drill' are for designated participants only. Plant PA Channel 4 and Plant Radio Channel 2 should be used for all in-plant communications being directed to the Simulator Control Room. Minimize use of these channels for non-drill activities." Repeat the announcement.	 Controller to verify that the Simulator Shift Supervisor notifies the on-shift Control Room Shift Supervisor of the commencement of the Exercise. Verify that the PA announcement is made. If Radio Channel 2 and/or PA Channel 4 are used frequently by non-exercise participants, repeat the message as needed.
5	0750	Simulator SAS	The following alarm is received on the Fire Alarm Computer: 911.01 AL FIR 9 - SD'S: FOR E. RHR RMS ALL LVLS AUX-1 SDP P929 IB620 D-2	I. If the SAS Operator goes to the VAX to pull up alarm descriptions, hand out message Number 6X.
6X	0750+	Simulator SAS	The following information is available on the VAX. Smoke Detector Panel: Address Number 911.01 Device Type SD MPL Number Drawing Number Location IB Elevation 620	Deliver this message only if the SAS Operator goes to the VAX for additional alarm indications.
7X	0810	Shift Supervisor	Declare an ALERT (EPI-A1, Initiating Condition FA1, "Fire affecting the operability of plant safety systems required to establish or maintain safe shutdown".	Deliver this message only if the Shift Supervisor has not declared an ALERT by now or if discussions regarding classification will not draw to the appropriate conclusion soon. The Shift Supervisor / Emergency Coordinator should: 1. Implement EPI-A6, "TSC Activation", and -A7, "OSC Activation"and PIRT should be directed to be activated. 2. Make notifications as required. 3. Monitor the situation.

8	0820	ENS Ckt. Phoner	Read the following message over the Drill ENS Circuit: "This is a Drill. You are directed to maintain an open line over the ENS Circuit at this time This is a drill."	This message is to be transmitted over the ENS Circuit upon waiting a finite period after the NRC/ENS Controller receives an initial notification of the Alert. This delay is utilized to duplicate the time period in which the NRC Operations Officer would be required to complete internal NRC notifications.	If responsibility for the ENS circuit has not yet been transferred to the TSC, the communicator in the Control Room shall maintain an open line over the ENS circuit at this time. Responsibility for the
9x	0900	"5-Way"	This is a drill. Representatives from	This massage is to be since to be	ENS circuit will then be transferred to the TSC, and an open line will be maintained by the TSC throughout the remainder of the drill.
		Communicators	the Ohio Emergency Management Agency and Ohio Department of Health have been dispatched to the Perry Plant site via Ohio National Guard Helicopter. Estimated time of arrival is 1000 hours. This is a drill. NOTE: response via helicopter will only be simulated.	This message is to be given to the "5-Way" Communicator only if notice has not yet been provided by the OEMA over the "5-Way" Circuit.	The TSC Security Coordinator should simulate Site Protection response to the helicopter's arrival; this may include dispatching a Security Officer and a Fire Brigade member to the heliport outside of the EOF
10	0915	Maintenance Coordinator	"Place the TSC Ventilation System on Emergency Recirculation."	1. Deliver this message when time permits to the TSC Maintenance Coordinator. This is being done for exercise demonstration purposes only. Projected radiation levels in the vicinity of the TSC would not result in an automatic realignment of the TSC HVAC to the emergency recirculation mode.	EUE
				 Do not interfere with the TSC Maintenance Coordinator duties. 	

11	0920	HPN Ckt.	Pond the following		
	0320	Phoner	Read the following message over the Drill ENS Circuit; "This is a drill. You are directed to initiate an open line over the Health Physics Network. Keep the HPN line open and manned until further notice. This is a drill."	The HPN Controller is to maintain the HPN line opened to the TSC, and EOF once operational, for the remainder of the exercise.	I. The ENS Communicator in the TSC receiving this message should notify the Administrative Assistant of the NRC Request. The Administrative Assistant should in turn advise the TSC Radiation Protection Coordinator (RPC).
					The RPC will assign an HP Technician from the OSC to HPN, or request that an I&C Technician be used as a Communicator. 2. Once the EOF is
12	0025				operational, the RPC should inform the EOF Offsite Radiation Advisor that the HPN be open for the transfer of dose assessment information to the NRC.
12	0935+	Drill Shift Supervisor / Central Alarm Station	The following message (for Exclusion Area Page/Plant PA/) shall be read in place of the pre-recorded site accountability message: "This is a Drill." Attention all site personnel. Accountability is now in effect within the Unit 1 Protected Area only. Personnel performing a plant operating or emergency plan function must report their location to the Control Room or appropriate emergency facility. All other personnel must exit the Protected Area using normal exiting procedures. This is a Drill."	I. Under no circumstances shall the pre-recorded accountability message on the Exclusion Area Paging System be activated. 2. Delay handing out message until a Site Area Emergency has been declared and communicated to the Shift Supervisor.	I. TSC Operations Manager should initiate personnel accountability by directing the Drill Shift Supervisor and the Central Alarm Station (CAS) to make the designated announcement over the Exclusion Area Paging System. 2. This message shall be repeated by the Simulator and CAS every 5 minutes over the Exclusion Area Page System until accountability is complete.

·				·	3. Plant personnel evacuating the Protected Area will be detained in PACP Parking lot until accountability is complete.
13X	0950	TSC Operations Manager	Declare a SITE AREA EMERGENCY (EPI-A1, Initiating Condition NS1, "Security Event in a plant Vital Area."	Deliver this message to the TSC Operations Manager only if a SITE AREA EMERGENCY has not been classified by now or if discussions will not draw to the appropriate conclusion soon. Message No. 12 concerning the drill accountability message for the Exclusion Area Paging must also be implemented.	
14	1000	ENS Ckt. Phoner	This is a drill. "Please inform Perry Nuclear Power Plant Management that the NRC Region III Site Team has been dispatched to your site. Please make appropriate arrangements for our staff. Expected arrival time is 1400. This is a drill.	1. Deliver this message via the ENS telephone at approximately this time. 2. Deployment of a "mock" NRC Site Team will be simulated. However, if asked, NRC is planning to dispatch the following Site Team members: Title Will Locate At	Plant Management should make appropriate arrangements.
				Team Leader EOF Protective Measures Coordinator EOF Reactor Safety Coordinator EOF Governmental Liaison Coordinator EOF Operations Coordinator TSC Radiation Safety Coordinator TSC Security / Safeguards Coordinator TSC	
				 A Controller should inform any Site NRC personnel participating in the exercise about this message. 	

1.5	1030	LEOE Manager	[WD] bl. DOD		
1. J	1030	EOF Manager	"Place the EOF Ventilation System in Emergency Isolation Mode."	1. Deliver this message when time permits to the EOF Manager. This is being done for exercise purposes. Radiation levels do not require placing the Ventilation System on Recirculation mode.	
1.6				2. Do not interfere with the EOF Manager's duties.	Ì
16	1140	Corporate Liaison	The JPIC is receiving a number of telephone inquiries from shareholders. These are some of their concerns:	, ductes.	
			"What are employees being advised regarding their stock? "How many employees own stock? How much? What percent of total outstanding stock is that? "Is NYSE still trading our stock? "How much is our stock valued at now? What was it this morning? "Who's in touch with the NYSE?		
			You are requested to formulate a strategy to deal with shareholder concerns.		
17x	1140	Emergency Coordinator	Declare a GENERAL EMERGENCY (EPI-A1, Initiating Condition CG1, "Failure to initiate or complete a successful shutdown, AND indication of an extreme challenge to the ability to cool the core".	Deliver this message to the Emergency Coordinator only if the Emergency Coordinator has not declared a GENERAL EMERGENCY by now or if discussions will not draw to the appropriate conclusion soon.	The Emergency Coordinator should: 1. Escalate to a "GENERAL EMERGENCY" per EPI-A2. 2. Make Notifications
18	1200	Emergency Coordinator	"This is John Stetz. I want you to know that we at FENOC will do all we can to support you. What do you need? How can we help? Can you briefly describe what happened?"	 Controller is to act as Mr. Stetz. Controller can free play additional questions as appropriate. 	3. Recommend default protective actions

19	1200	Corporate	Human Resources Department has been	T	
1 1 2	1200		receiving several phone calls from		
	1	Liaison	employees or their spouses about the	İ	
			following;		1
ł					
			How will I know if I should show up		
			for work at the Plant?		
İ			Will I be paid if I am told not to		1
			show up?		
			If the plant does not start up		
			again, will I still be employed?		1
			• Will the Company use this as a method		
			of getting rid of		
	1		Are employees eligible for		
			unemployment if the area of the		İ
			plant they work is not accessible?		
20	1230	CEI Telephone	Can you help us address this situation? "I heard that you are setting up a	A controller is to call in this	
		Operator (622-	press center for the news media. I	message acting as a Boston Globe	
		9800)	want to talk with them. What is their number?"	reporter.	
21	1315	OSC	"Develop a relief shift roster. This	Deliver this message between	Relief shift rosters
		Coordinator,	is being implemented now for exercise	1430-1515 so as not to interfere	should be developed.
		TSC Admin	purposes."	with facility operations.	, , , , , , , , , , , , , , , , , , , ,
		Assistant			
	ł	EOF Manager]
		JPIC Manger			
22	1330	EOF Manager	You have just received the following	An EOF Controller should leave this	Determine responses and
			FAX from Pete Burg. He is holding an	message on the EOF FAX machine.	FAX by 1500.
] ,	}		emergency briefing of the First Energy		
			Board. In preparation for this		
	<u> </u>	İ	meeting, he needs the following:		
	j		mercany, he needs the following:		
			1. A brief synopsis of the accident.		
			2. Problems encountered; resolutions.		
	1		3. Status of plant; prognosis. When will		
[]			the plant be returned to service?		
				į	
1			4. Status of off-site actions and		
			response; prognosis.		
	L	l	5. Amount of radiation released: total		

amount and amount vs. time. Health
effects of same.
6. Status of plant employees. Any
injuries or deaths?
7. Status of media response and
coverage.
a.Summary of types of media
questions.
b.What media are covering this. How
many? Are any media at the
site?
c.What state, local and federal
agencies are at media center?
d.How is it going? How do we look?
8. List of key facilities, managers and
key staff. What Non-CEI personnel
are on CEI property.
9. What does Perry need? Support,
personnel, equipment.
0. Other pertinent information for the
board.
The Board meeting is scheduled for
1530. Please submit written notes by
FAX (280-8009) by 1500.

23	1400	TSC Administrative Assistant	Return the TSC Ventilation to its normal lineup.	Deliver this message to the TSC Administrative Assistant at this time. Do not let this message interfere with the TSC Administrative Assistant's other actions; however, Controller must ensure that the system is realigned prior to the termination of the exercise.	
24	1400	Simulator Controllers	Verify the following: 1. The Simulator communications switch is in the "Training" mode. 2. Contact the Control Room to have them plug in:	Notify lead controllers in the TSC, OSC, and EOF that the Simulator Control Room has terminated play.	
25	1430	EOF Manager	Return the EOF Ventilation to its normal lineup.	Deliver this message to the EOF Manager. Do not let this message interfere with the EOF Manager's other actions; however, the Controller must ensure that the system is re-aligned prior to the termination of the exercise.	

SECTION 7.2

PLANT DATA DATABASE (ICS)

The following is the Plant Data Database used to generate the Plant Data Sheets as a function of time to be used in the event of a Simulator failure. This data was acquired utilizing the Perry Plant Simulator.

This section contains:

Table 7.2.1 - Plant Technical Data Trends

Table 7.2.2 - Plant Overview Data Trends

Table 7.2.3 - Radiation Data Summary Trends

Table 7.2.4 - Key Control Room Annunciator Summary

Table 7.2.1

PLANT TECHNICAL DATA TRENDS

(All technical data trends are shown with the plant overview data in Table 7.2.2)

Table 7.2.2

PLANT OVERVIEW DATA TRENDS

2000 PERRY EVA ATED EXERCISE TABLE 7.2.2

	LPCI A STATUS	LPCI B STATUS	LPCI C STATUS	SHTDN CLG A	SHTDN CLG B	CNTMT SPRAY A	CNTMT SPRAY B	SUPR PL CLG A
TIME	E12EK003	E12EK004	E12EK005	E12EK009	E12EK010	E12EK011	E12EK012	E12EK013
6:54:59	0	0	0	0	0	0	0	0
6:59:59	0	0	0	0	0	0	0	0
7:04:59	0	· 0	0	0	0	0	0	0
7:09:59	0	0	0 .	0	0	0	0	0
7:14:59	0	0	0	0	0	0	0	0
7:19:59	0	. 0	0	0	0	0	0	0
7:24:59	0	0	0	0	0	0	0	1
7:29:59	0	0	0	0	0	. 0	0	1
7:34:59	0	0	0	0	0	0	0	1
7:39:59	0	0 🗸	0	0	0	0	0	1
7:44:59	0	0	0	0	0	0	0	1
7:49:58	0	0	0	0	0	0	0	1
7:54:58	0	0	0	0	0	0	0	0
7:59:58	0	0	0	0	0	0	0	0
8:04:58	0	0	0	0	0	0	0	0
8:09:58	0	0	0	0	. 0	0	0	0
8:14:58	0	0	0	0	0	0	0	0
8:19:58	0	0	0	. 0	0	0	0	0
8:24:58	0	0	0	0	0	0	0	0
8:29:58	0	0	0	0	0	0	0	0
8:34:58	0	0	0	0	0	0	0	0
8:39:58	0	0	0	0	0	0	0	0
8:44:58	0	0	0	0	0	0	0	. 0
8:49:58	0	0	0	0	0	0	0	0
8:54:58	0	0	0	0	0	0	0	0
8:59:58	0	0	0	0	0	0	0	0
9:04:58	0	0	0	0	0	0	0	0
9:09:58	0	0	0	0	0	0	0	0
9:14:58	0	0	. 0	0	0	0	0	0
9:19:58	0	0	0	0	0	0	0	0
9:24:58	0	0	0	0	0	0	0	0
9:29:57	0	0	0	0	0	0	0	0
9:34:57	0	0	0	0	· 0	0	0	0
9:39:57	0	0	0	0	0	0	0	0
9:44:57	0	0	0	0	0	0	0	0
9:49:57	0	0	0	0	0	0	0	Ö

2000 PERRY EVA .TED EXERCISE TABLE 7.2.2

TIME		LPCI A STATUS		LPCI C STATUS	SHTDN CLG A	SHTDN CLG B	CNTMT SPRAY A	CNTMT SPRAY B	SUPR PL CLG A
9.54.57				E12EK005	E12EK009	E12EK010			
9:99:57 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0				0	0	0	0	0	
10.09.57		-	0	0	0	0	0	0	
10:14:57		•	0	0	0	0	0	0	0
10:19:57		0 .	0	0	0	0	0	0	0
10:24:57		0	0	0	0	0	0	0	Ô
10.29:57			0	0	0	0	0	0	0
10:39:57		0	0 ·	0	0	0	0	0	0
10:39:57		=	0	0	0	0	0		0
10:49:48	10:34:57	0	0	0	0	0	0	-	ō
10:54:48		0	. 0	0	0	0	0	0	0
10:59:48		0	0	0	.0	0	0	0	Ô
11:04:48		0	0	0	0	0	0	0	n
11:09:48		0	0	0 .	0	0	0	0	n
11:14:48 0<		0	0	0	0	0 .	0	0	0
11:19:48 0<		0	0	0	0	0	0	0	0
11:24:48 0<		0	0	0	0	0	0	Ô	0
11:29:48 0<		0	0	0	0	0	o o	0	0
11:34:48 0<		0	0	0.	0	0	0	0	0
11:39:48 0<		0	0	0	0	0	0	n	0
11:44:48 0<		0	0	0	0	0	0	0	0
11:44:48 0<		0	0	0	0	0	0	0	0
11:49:48 0<		0	0	0	0	0	0	=	0
11:54:48 0<		0	0	. 0	0	0	0	<u>-</u>	0
12:04:48 0<	11:54:48	0	0	0	0	0	0	0	0
12:09:48 0<		0	0	0	0	0	0	0	0
12:09:48 0<		0	0	0	0	0	0	'n	0
12:14:48 0<	12:09:48	0	0	0	0	0	0	n o	•
12:19:48 0<	12:14:48	0	0	0 .	0	0	0	n	. 0
12:24:47 0 0 0 0 0 0 0 12:29:48 0 0 0 0 0 0 0 12:34:47 0 0 0 0 0 0 0 12:39:47 0 0 0 0 0 0 0 12:44:47 0 0 0 0 0 0 0 12:49:47 0 0 0 0 0 0 0	12:19:48	0	0	0	0	0	-	0	0
12:29:48 0 0 0 0 0 0 12:34:47 0 0 0 0 0 0 0 12:39:47 0 0 0 0 0 0 0 12:44:47 0 0 0 0 0 0 0 12:49:47 0 0 0 0 0 0 0	12:24:47	0	0	0	0	0	-	0	0 .
12:34:47	12:29:48	0	0	0	0	0	-	· ·	0
12:39:47	12:34:47	0	0	0	0	. 0		•	Ó
12:44:47	12:39:47	0	0	0	0	0	•	v	0
12:49:47	12:44:47	0	0	0	0		-	ŭ	•
	12:49:47	0	0	0	0	ū		-	· ·

2000 PERRY EVA TED EXERCISE TABLE 7.2.2

TIME	LPCI A STATUS E12EK003	LPCI B STATUS E12EK004	LPCI C STATUS E12EK005	SHTDN CLG A E12EK009	SHTDN CLG B E12EK010	CNTMT SPRAY A E12EK011	CNTMT SPRAY B	
12:54:47	0	0	0	0	. 0	EIZEKUII	E12EK012	E12EK013
12:59:47	0	0	n	0	. 0	0	0	0
13:04:47	0	0	Ô	0	. 0	0	0	0
13:09:47	0	0	n	0	0	0	0	0
13:14:47	0	0	. 0	0	0	0	0	0
13:19:47	0	n	0	0	0	0	0	0
13:24:47	0	n	0	0	0	0	0	0
13:29:47	0	0	0	0	. 0	0	0	0
13:34:47	0	0	0	0	0	0	0	0
13:39:47	n	0	0	0	0	0	0	0
13:44:47	0	0	0	0	0	0	0	0
13:49:47	0	0	0	0	0	0	0	0
13:54:47	0	0	U	0	0	0	0	0
13:59:47	0	0	0	0	0	0	0	0
14:04:47	0	0	0	0	0	0	0	0
14:04:47	0	U	0	0	0	0	0	0
	0	0	0	0	0	0	0	0
14:14:46	0	0	0	0	0	0	0	0
14:19:46	0	0	0	0	0	0	0	0 -
14:24:46	0	. 0	0	0	0	0	0	0
14:29:46	0	0	0	0	0	0	0	0
14:31:29	0	0	0	0	0	0	0	ō

2000 PERRY EVA ATED EXERCISE TABLE 7.2.2

	SUPR CLG B	HPCS STATUS	LPCS STATUS	RCIC STATUS	SLC STATUS	FDW STATUS	CRD STATUS	ESW A PUMP STATUS
TIME	E12EK014	E22EK002	E21EK001	E51EK002	C41EK003	N27EK001	C11EK001	P45EC001
6:54:59	0	0	0	0	0	1	1	0
6:59:59	0	0	0	0	0	1	1	0
7:04:59	0	· 0	0	0	0	1	1	0
7:09:59	0	0	0	0	0	1	1	0
7:14:59	0	. 0	0	0	0		1	0
7:19:59	0	0	0	0	0	1	1	0
7:24:59	0	0	0	0	0	1	. 1	1
7:29:59	0	0	0	0	0	1	1	1
7:34:59	- 1	0	0	0	0	1	1	1
7:39:59	1	0	0	0	0	1	1	1
7:44:59	1	0	0	0	0	1	1	1
7:49:58	1	0	0	0	0	1	1	1
7:54:58	1	0	0	0	0	1	1	1
7:59:58	1	0	0	0	0	1	1	1
8:04:58	1	0	0	0	0	1	1	1
8:09:58	1	0	0	0	0	1	1	1
8:14:58	1	0	0	0	0	1	1	1
8:19:58	1	0	0	0	0	1	Ì	1
8:24:58	1	0	0	0	0	1	1	1
8:29:58	1	0	0	0	0	1	1	1
8:34:58	1	0	0	0	0	1	1	1
8:39:58	1	0	0	0	0	1	1	1
8:44:58	1	0	0	0	0	1	1	1
8:49:58	1	0	0	0	0	1	· 1	1
8:54:58	1	0	0	0	0	1	1	1
8:59:58	1	0	0	0	0	1	1	1
9:04:58	1	0	0	0	0	1	1	1
9:09:58	1	0	0	0	0	1	1	1
9:14:58	1	0	0	0	0	1	1	1
9:19:58	1	0 .	0	0	0	1	1	1
9:24:58	1	0	0	0	0	1	1	1
9:29:57	1	0	0	0	0	1	1	1
9:34:57	1	0	0	0	0	1	1	1
9:39:57	1	0	0	0	0	1	1	1
9:44:57	1	0	0	0	0	1	1	1
9:49:57	1	0	0	0	Ö	1	1	1
								•

2000 PERRY EVA ATED EXERCISE TABLE 7.2.2

TIME	SUPR CLG B E12EK014	HPCS STATUS E22EK002	LPCS STATUS E21EK001	RCIC STATUS E51EK002	SLC STATUS	FDW STATUS	CRD STATUS	ESW A PUMP STATUS
9:54:57	1	0	0	0	C41EK003	N27EK001	C11EK001	P45EC001
9:59:57		0	0	0	0	1	1	1
10:04:57	1	0	0		0	1	1	1
10:09:57		0	0	0	0	1	1	1
10:14:57	1	0	0	0	0	1	1	1
10:19:57	1	0	0	0	0	1	1	1
10:19:57	<u>,</u>	0	•	0	0	1	1	· 1
10:29:57	1	0	0 0	0	0	1	1	1
10:34:57	1	0	_	0	0	1	1 .	1
	•	U	0	0	0	1	1	1
10:39:57	1	0	0	0	0	1	1	1
10:49:48	1	0	0	÷1	0	BAD DATA	0	1
10:54:48	0	0	0	0	0	BAD DATA	0	1
10:59:48	0	0	0	0	0	BAD DATA	0	1
11:04:48	0	0	0	0	0	BAD DATA	0	1
11:09:48	0	. 0	0	0	0 .	BAD DATA	0	1
11:14:48	0	0	0	0	0	BAD DATA	0	1
11:19:48	0	0	0	0	0	BAD DATA	0	1
11:24:48	0	0	0	0	0	BAD DATA	0	1
11:29:48	0	0	. 0	0	0	BAD DATA	0	1
11:34:48	0	0	0	0	0	BAD DATA	0	1
11:39:48	0	0	0	0	0	BAD DATA	0	1
11:44:48	0	0	0	0	0	BAD DATA	0	1
11:49:48	0	0	0	0	0	BAD DATA	0	1
11:54:48	0	0	0	0	0	BAD DATA	0	1
11:59:48	0	0	0	0	0	BAD DATA	0	1
12:04:48	0	0	0	0	0	BAD DATA	0	1
12:09:48	0	0	0	0	0	BAD DATA	0	1 .
12:14:48	0	0	0	0	0	BAD DATA	Ö	1
12:19:48	0	0	0	0	0	BAD DATA	0	1
12:24:47	0	0	0	0	0	BAD DATA	Ö	1
12:29:48	0	0	. 0	0	0	0	0	1
12:34:47	0	0	0	0	0	0	0	1
12:39:47	0	0	0	0	0	Õ	0	1
12:44:47	0	0	0	0	0.	o o	0	1
12:49:47	0	. 0	0	0	0	0	0	1
			-	•	•	U	U	1

2000 PERRY EVA .TED EXERCISE TABLE 7.2.2

				•				
TIME	SUPR CLG B E12EK014	HPCS STATUS E22EK002	LPCS STATUS E21EK001	RCIC STATUS E51EK002	SLC STATUS C41EK003	FDW STATUS N27EK001	CRD STATUS C11EK001	ESW A PUMP STATUS P45EC001
12:54:47	0	1	0	0	0	0	0	1
12:59:47	0	1	0	0	0	0	0	4
13:04:47	0	0	0	0	0	n	0	,
13:09:47	0	0	. 0	0	0	n	n	1
13:14:47	0	0	. 0	0	0	Ô	0	4
13:19:47	0	0	0	0	0	n	0	1
13:24:47	0	0	0	0	0	0	0	4
13:29:47	0	0	0	0	1	n	0	1
13:34:47	0	0	0	0	1	n	0	1
13:39:47	0	0	0	0	1	0	0	1
13:44:47	0	0	0	0	1	n	0	1
13:49:47	0	0	0	0 .	1	0	0	1
13:54:47	0	0	0	0	1	1	0	1
13:59:47	0	0	0	0	1	'n	0	1
14:04:47	0	0	0	0	1	n	0	1
14:09:46	0	O	0	0	1	n	0	1
14:14:46	0	0	0	0	1	Ô	0	1
14:19:46	0	0	0	0	1	ñ	0	1
14:24:46	0	0	0	0	1	0	0	1
14:29:46	0	0	0	0	1	n	0	1
14:31:29	. 0	0	0	0	1	0	0	T 4
				-	•	Ū	U	1

2000 PERRY EVA TED EXERCISE TABLE 7.2.2

	ESW B PUMP STATUS	ESW C PUMP	NCC A PUMP	NCC B PUMP	NCC C PUMP	SLC TANK	CST VOLUME (K	CNTMT
TIME	P45EC002	STATUS	STATUS	STATUS	STATUS	VOLUME (GAL)	GAL)	HYDROGEN (%)
		P45EC003	P43EC011	P43EC012	P43EC013	C41ED001	P11BE001	M51EE001
6:54:59	0	0	1	1	0	4799.859	331.916	BAD DATA
6:59:59	0	0	1	1	0	4799.859	331.917	BAD DATA
7:04:59	0	0	1	1	0	4799.859	331.917	BAD DATA
7:09:59	0	0	1.	1	0	4799.859	331.917	BAD DATA
7:14:59	0	0	1	1	0	4799.859	331.918	BAD DATA
7:19:59	0	0	1	1	0	4799.859	331.789	BAD DATA
7:24:59	0	0	1	1	0	4799.859	- 337.819	BAD DATA
7:29:59	0	0	1	1	0	4799.859	339.555	BAD DATA
7:34:59	1	0	1	1	0 -	4799.859	339.826	BAD DATA
7:39:59	1	0	1	1	0	4799.859	339.579	BAD DATA
7:44:59	1	0	1	1 ,	0	4799.859	339.355	BAD DATA
7:49:58	1	0	1	1	0	4799.859	339.111	BAD DATA
7:54:58	1	0 .	1	1	0	4799.859	338.864	BAD DATA
7:59:58	1	0	1	1	0	4799.859	338.72	BAD DATA
8:04:58	1	0	1	1	0	4799.859	338.577	BAD DATA
8:09:58	1	0	1	1	0	4799.859	338.433	BAD DATA
8:14:58	1	0	· 1	1	0	4799.859	338.22	BAD DATA
8:19:58	1	0	1	1	0	4799.859	338.074	BAD DATA
8:24:58	1	0	1	1	0	4799.859	337.936	BAD DATA
8:29:58	1	0	1	1	0	4799.859	337.793	BAD DATA
8:34:58	1	0	1	1	0	4799.859	337.678	BAD DATA
8:39:58	1	0	1	1	0	4799.859	337.544	BAD DATA
8:44:58	1	0	1	1	0	4799.859	337.4	BAD DATA
8:49:58	1	0	1	1	0	4799.859	337.259	BAD DATA
8:54:58	1	0	1	1	0	4799.859	337.115	BAD DATA
8:59:58	1	0	1	1	0	4799.859	336.974	BAD DATA
9:04:58	1	0	1	1	0	4799.859	336.833	BAD DATA
9:09:58	1	0	1	1	0	4799.859	336.696	BAD DATA
9:14:58	1	0	1	1	0	4799.859	336.56	BAD DATA
9:19:58	1	0	1	1	0	4799.859	339.875	BAD DATA
9:24:58	1	0	1	1	0	4799.859	339.696	BAD DATA
9:29:57	1	0	1	1	0	4799.859	339.924	BAD DATA
9:34:57	1	0	1	1	0	4799.859	339.875	BAD DATA
9:39:57	1	0	· 1	1	0	4799.859	339.794	BAD DATA
9:44:57	1	0	1	1	0	4799.859	339.657	BAD DATA
9:49:57	1	0	1	1	Ō	4799.859	339.514	
		•	•	•	•	41 33.033	339.014	BAD DATA

	ESW B PUMP STATUS	ESW C PUMP STATUS	NCC A PUMP STATUS	NCC B PUMP STATUS	NCC C PUMP STATUS	SLC TANK VOLUME (GAL)	CST VOLUME (K	CNTMT
TIME	P45EC002	P45EC003	P43EC011	P43EC012	P43EC013	C41ED001	GAL)	HYDROGEN (%)
9:54:57	1	0	1	1	0	4799.859	P11BE001	M51EE001
9:59:57	1	0	1	1	0		339.371	BAD DATA
10:04:57	1	0	1	1	. 0	4799.859	339.227	BAD DATA
10:09:57	1	0	1	1	0	4799.859	339.084	BAD DATA
10:14:57	1	0	1	1	•	4799.859	338.941	BAD DATA
10:19:57	1	o ·	1	1	0	4799.859	338.797	BAD DATA
10:24:57	1	Ö	1	1	0	4799.859	338.654	BAD DATA
10:29:57	1	Ö	1	1	0	4799.859	338.509	BAD DATA
10:34:57	1	0	1	. 1	0	4799.859	337.922	BAD DATA
	•	•	Ī	1	0	4799.859	333.267	BAD DATA
10:39:57	1	0 ′	1	1	0	4799.859	334.48	BAD DATA
10:49:48	1	1	0	1	0	4799.859	338.554	0.01
10:54:48	1	1	1	1	0	4799.859	349.012	0.01
10:59:48	1	1	1	1	0	4799.859	349.666	0.01
11:04:48	. 1	1	1	1	0	4799.859	349.427	0.01
11:09:48	1	1	1	1	0	4799.859	348.898	0.011
11:14:48	1	1	1	1	0	4799.859	347.802	0.011
11:19:48	1	1 '	1	1	0	4799.859	346.713	0.011
11:24:48	1	1	1	1	0	4799.859	345.787	0.012
11:29:48	1	1	1	1	0	4799.859	344.814	0.012
11:34:48	1	1	1	1	0	4799.859	343.802	0.012
11:39:48	1	1	1	1	0	4799.859	342.161	0.013
11:44:48	1	1	1	1	0	4799.859	340.788	0.013
11:49:48	1	1	1	1	0	4799.859	339.389	0.014
11:54:48	1	1	1	1	0	4799.859	338.147	0.014
11:59:48	1	1	1	1	0	4799.859	337.162	0.015
12:04:48	1	1	1	1	0	4799.859	336.101	0.015
12:09:48	1	1	1	1	0	4799.859	335.093	0.016
12:14:48	1	. 1	1	1	0	4799.859	334.091	0.016
12:19:48	1	1	· 1	· 1	0	4799.859	333.084	0.017
12:24:47	1	1 .	1	1	0	4799.859	332.078	0.017
12:29:48	1	1	1	1	0	4799.859	331.082	0.017
12:34:47	1	1	1	1	0	4799.859	330.059	
12:39:47	1	1	1	1	0	4799.859	329.056	0.018
12:44:47	1	1	1	1	n o	4799.859	329.056 327.051	0.019
12:49:47	1	1	1	1	0	4799.859		0.019
			•	•		4133.003	306.09	0.02

	ESW B PUMP STATUS	ESW C PUMP STATUS	NCC A PUMP STATUS	NCC B PUMP STATUS	NCC C PUMP STATUS	SLC TANK VOLUME (GAL)	CST VOLUME (K	CNTMT
TIME	P45EC002	P45EC003	P43EC011	P43EC012	P43EC013	C41ED001	GAL) P11BE001	HYDROGEN (%)
12:54:47	1	1	1	1	0	4799.859	281.159	M51EE001
12:59:47	1	1	1	1	0	4799.859	256.373	0.02
13:04:47	1	1	1	1	o O	4799.859	227.087	0.021
13:09:47	1	1	1	1	o O	4799.859		0.021
13:14:47	1	1	1	1	0		197.625	0.022
13:19:47	1	1		1	0 .	4799.859	193.85	0.022
13:24:47	1	•	,	<u>'</u>	0 .	4799.009	196.14	0.022
		1		1	0	4799.859	198.458	0.023
13:29:47	1	1	1	1	0	4603.754	200.735	0.023
13:34:47	1	1	1	1	0	4388.523	203.017	0.024
13:39:47	1	· 1	1	1	0	4174.719	205.292	0.024
13:44:47	1	1	1	1	0	3961.634	207.565	0.025
13:49:47	1	· 1	1	1	0	3747.117	209.829	0.026
13:54:47	1	1	1	1	0	3532.6	212.064	0.026
13:59:47	1	1	1	1	0	3318.798	214.293	0.027
14:04:47	1	1	. 1	1	0	3104.281	216.513	0.028
14:09:46	1	1	1	1	0	2890.479	218.716	0.029
14:14:46	1	1	1	1	0	2676.678	220.904	0.029
14:19:46	1	1	1	1	0	2461.446	223.097	0.03
14:24:46	· 1	1	1	1	0	2247.644	225.282	0.031
14:29:46	1	1	1	1	0	2033.127	227.491	0.031
14:31:29	1	1	1	1	0	1960.191	228.22	0.033

	CNDR		•		RPV PRESS-		
	PRESSURE (IN	RPV LEVEL	RPV LEVEL-VALIDATD		VALIDATED	SUPP POOL	SUPP POOL LEVEL-
	HGA)	(INCHES)	STATUS	RPV PRESS (PSI)	STATUS	LEVEL (FT)	VALIDATED STATUS
TIME	N21EE003	B21ED001	B21ED002	B21ED003	B21ED004	G43ED001	G43ED002
6:54:59	2.936	202.255	4	1020.67	4	18.268	4
6:59:59	2.936	202.228	4	1020.732	4	18.269	4
7:04:59	2.937	202.238	4	1020.712	4	18.269	4
7:09:59	2.937	202.265	. 4	1020.703	4	18.269	4
7:14:59	2.937	202.239	4	1020.715	4	18.269	4
7:19:59	2.744	205.683	4	1008.109	4	18.273	4 ·
7:24:59	2.722	201.218	4	1007.397	4	18.29	4
7:29:59	2.703	201.158	4	1007.236	4	18.306	4
7:34:59	2.688	201.114	4	1006.776	4	18.334	4
7:39:59	2.702	201.167	4	1006.99	4	18.347	4
7:44:59	2.697	201.16	4	1006.732	4	18.356	4
7:49:58	2.693	201.108	4	1006.575	4	18.367	4
7:54:58	2.691	201.127	4	1006.464	4	18.377	4
7:59:58	2.688	201.074	4	1006.249	4	18.384	4
8:04:58	2.685	201.059	4	1006.129	4	18.391	4
8:09:58	2.682	201.046	4	1005.98	4	18.398	4
8:14:58	2.679	201.085	4	1005.838	4	18.406	4
8:19:58	2.677	201.064	4	1005.742	4	18.413	4
8:24:58	2.675	201.045	4	1005.592	4	18.418	4
8:29:58	2.672	201.015	4	1005.446	4	18.423	4
8:34:58	2.669	201.024	4	1005.344	4	18.428	4
8:39:58	2.667	201.008	4	1005.233	4	18.433	4
8:44:58	2.664	201.021	4	1005.123	4	18.438	4
8:49:58	2.662	200.995	4	1005.013	4	18.443	4
8:54:58	2.66	200.988	· 4	1004.893	4	18.448	4
8:59:58	2.658	200.947	4	1004.817	4	18.453	4
9:04:58	2.657	200.985	4	1004.745	4	18.458	4
9:09:58	2.655	200.941	4	1004.667	4	18.463	4
9:14:58	2.653	200.958	4	1004.555	4	18.468	4
9:19:58	2.692	200.984	4	1004.523	4	18.473	4
9:24:58	2.641	200.881	4	1004.355	4	18.478	4
9:29:57	2.652	200.903	4	1004.331	4	18.483	4
9:34:57	2.647	200.915	4	1004.257	4	18.488	4
9:39:57	2.646	200.892	4	1004.265	4	18.493	4
9:44:57	2.645	200.888	4	1004.094	4	18.498	4
9:49:57	2.643	200.885 -	4	1004.106	4	18.503	4

	CNDR PRESSURE (IN	DDV I EVE			RPV PRESS-		
	HGA)	RPV LEVEL (INCHES)	RPV LEVEL-VALIDATD STATUS	RPV PRESS (PSI)	VALIDATED	SUPP POOL	SUPP POOL LEVEL-
TIME	N21EE003	B21ED001	B21ED002	B21ED003	STATUS B21ED004	LEVEL (FT)	VALIDATED STATUS
9:54:57	2.643	200.866	4	1004.007		G43ED001	G43ED002
9:59:57	2.641	200.855	4	1003.965	4	18.508	4
10:04:57	2.641	200.848	. 4	1003.985	4	18.512	4
10:09:57	2.64	200.813	4	1003.931	4	18.517	4
10:14:57	2.641	200.893	. 4	1003.794	4	18.522	4
10:19:57	2.638	200.872	4	1003.794	4	18.527	4
10:24:57	2.639	200.815	4	1003.773	4	18.532	4
10:29:57	2.605	200.82	4		4	18.537	4
10:34:57	2.644	200.934	4	1003.685	4	18.542	4
			4	1003.602	4	18.547	4
10:39:57	2.634	200.847	4	1003.64	4	18.552	4
10:49:48	1.115	146.359	4	950.579	4	18.543	4
10:54:48	1.103	78.59	4	1060.819	4	18.692	4
10:59:48	1.098	58.005	4	1111.385	4	18.765	4
11:04:48	1.128	47.73	4	1036.345	4	18.841	4
11:09:48	1.717	32.63	4	1093.834	4	18.883	4
11:14:48	2.883	17.046	4	1009.332	4	18.923	4
11:19:48	4.296	38.335	4	988.875	4	18.929	4
11:24:48	5.788	33.263	4	1057.073	4	18.935 🖫	4
11:29:48	7.263	20.234	4	962.061	4	18.974	4
11:34:48	8.671	29.247	4	1101.026	4	18.985	4
11:39:48	9.924	11.409	4	1027.537	4	19.025	4
11:44:48	11.045	15.994	4	1126.84	4	23.62	4
11:49:48	12.054	51.868	4	1025.43	4	23.917	4
11:54:48	12.967	2.689	4	1126.104	4	23.824	4
11:59:48	13.797	41.951	4	1023.732	4	23.71	4
12:04:48	14.555	44.478	4	1098.073	4	23.675	4
12:09:48	15.252	44.761	4	1139.513	4	23.675	4
12:14:48	15.892	41.029	4	1137.953	4	23.675	4
12:19:48	16.485	37.041	. 4	1126.893	4	23.674	4
12:24:47	17.032	33.48	4	1116.308	4	23.674	4
12:29:48	17.548	7.329	4	854.821	4	23.68	4
12:34:47	18.021	9.692	4	, 821.592	4	23.673	4
12:39:47	18.463	0.23	4	841.1	4	23.674	4 .
12:44:47	18.876	-2.43	4	854.798	4	23.679	4
12:49:47	19.264	6.331	4	831.167	4.	23.783	4

	CNDR				RPV PRESS-		
	PRESSURE (IN	RPV LEVEL	RPV LEVEL-VALIDATD		VALIDATED	SUPP POOL	SUPP POOL LEVEL-
	HGA)	(INCHES)	STATUS	RPV PRESS (PSI)	STATUS	LEVEL (FT)	VALIDATED STATUS
TIME	N21EE003	B21ED001	B21ED002	B21ED003	B21ED004	G43ED001	G43ED002
12:54:47	19.629	16.313	4	755.188	4	23.831	4
12:59:47	19.971	32.734	4	532.59	4	23.76	4
13:04:47	20.293	47.081	4	606.65	4	23.89	4
13:09:47	20.6	56.205	4	842.871	4	23.997	4
13:14:47	20.889	65.47	4	1089.124	4	23.834	4
13:19:47	21.164	66.752	4	1158.139	4	23.681	4.
13:24:47	21.427	53.934	4	1045.061	4	23.673	4
13:29:47	21.674	52.868	4	1050.49	4	23.673	4
13:34:47	21.909	45.554	4	950.905	4	23.673	4
13:39:47	22.133	40.194	4	961.231	4	23.671	4
13:44:47	22.345	7.133	4	849.769	4	23.691	4
13:49:47	22.55	-1.459	4	244.77	4	23.696	4
13:54:47	22.744	14.415	4	97.131	4	23.548	4
13:59:47	22.93	24.605	4	57.57	4	23.407	4
14:04:47	23.108	45.03	4	44.879	4	23.323	4
14:09:46	23.279	74.657	4	37.072	4	23.211	4
14:14:46	23.442	104.921	4	31.712	4	23.091	4
14:19:46	23.601	136.33	4	26.847	4	22.983	4
14:24:46	23.753	170.096	4	23.029	4	22.862	4
14:29:46	23.899	201.458	4	20.142	4	22.742	4
14:31:29	23.946	212.618	4	19.49	4	22.708	4

		DW PRESS-		•		CNTMT TEMP-		DW PRESS-
	SUPP POOL	VALIDATED	CNTMT PRESS	CNTMT PRESS-		VALIDATED	DW PRESS	VALIDATED
	TEMP (F)	STATUS	(PSIG)	VALIDATED STATUS	CNTMT TEMP (F)	STATUS	(PSIG)	STATUS
TIME	D23ED005	D23ED006	D23ED003	D23ED004	D23ED009	D23ED010	D23ED001	D23ED002
6:54:59	80.186	4	0.007	4	82.093	4	0.065	4
6:59:59	80.186	4	0.006	4	82.057	4	0.064	4
7:04:59	80.186	4	0.005	4	82.022	4	0.063	4
7:09:59	80.186	4	0.004	4	81.988	4	0.063	4
7:14:59	80.186	4	0:003	4	81.954	4	0.062	4
7:19:59	80.509	4	0.003	4	81.921	4	0.061	4
7:24:59	81.551	4	0.004	4	81.887	4	0.061	4
7:29:59	82.258	4	0.005	4	81.856	4	0.063	4
7:34:59	83.589	4	0.007	4	81.83	4	0.066	4
7:39:59	83.53	4	0.009	4	81.806	4	0.07	4
7:44:59	83.266	4	0.01	4	81.789	4	0.074	4
7:49:58	83.065	4	0.011	4 .	81.774	4	0.076	4
7:54:58	83.002	4	0.012	4	81.756	4	0.076	4
7:59:58	83.137	4	0.013	4	81.739	4	0.075	4
8:04:58	83.268	4	0.013	4	81.723	4	0.073	4
8:09:58	83.397	4	0.014	4	81.706	4	0.07	4
8:14:58	83.524	4	0.014	4	81.69	4	0.066	4
8:19:58	83.621	4	0.015	4	81.674	4	0.062	4
8:24:58	83.638	4	0.015	4	81.658	4	0.057	4
8:29:58	83.653	4	0.016	4	81.641	4	0.051	4
8:34:58	83.669	4	0.016	4	81.625	4	0.046	4
8:39:58	83.681	4	0.016	4	81.611	4	0.041	4
8:44:58	83.692	4	0.017	4	81.597	4	0.035	4
8:49:58	83.704	4	0.017	4	81.582	4	0.03	4
8:54:58	83.716	4	0.017	4	81.567	4	0.024	4
8:59:58	83.727	4	0.018	4	81.554	4	0.019	4
9:04:58	83.737	4	0.018	4	81.543	4	0.013	4
9:09:58	83.748	4	0.018	4	81.532	4	0.008	4
9:14:58	83.759	4	0.019	4	81.522	4	0.002	4
9:19:58	83.771	4	0.019	4	81.513	4	-0.003	4
9:24:58	83.783	4	0.02	4	81.504	4	-0.009	4
9:29:57	83.793	4	0.02	4	81.497	4	-0.015	. 4
9:34:57	83.802	4	0.02	4	81.489	4	-0.02	4
9:39:57	83.812	4	0.021	4	81.485	4	-0.026	4
9:44:57	83.821	4	0.021	4	81.48	4	-0.031	4
9:49:57	83.827	4	0.022	4	81.476	4	-0.037	4

		DW PRESS-				CNTMT TEMP-		DW PRESS-
	SUPP POOL	VALIDATED	CNTMT PRESS	CNTMT PRESS-		VALIDATED	DW PRESS	VALIDATED
TIME	TEMP (F)	STATUS	(PSIG)	VALIDATED STATUS		STATUS	(PSIG)	STATUS
TIME	D23ED005	D23ED006	D23ED003	D23ED004	D23ED009	D23ED010	D23ED001	D23ED002
9:54:57	83.822	4	0.022	4	81.473	4	-0.042	4
9:59:57	83.822	4	0.023	4	81.47	4	-0.048	4
10:04:57	83.821	4	0.023	4	81.468	4	-0.054	4
10:09:57	83.82	4	0.024	4	81.466	4	-0.059	4
10:14:57	83.819	4	0.024	4	81.464	4	-0.065	4
10:19:57	83.817	4	0.025	4	81.462	4	-0.071	- 4
10:24:57	83.816	4	0.025	4	81.461	4	-0.076	4
10:29:57	83.815	4	0.026	4	81.459	4	-0.082	4
10:34:57	83.814	4	0.026	4	81.458	4	-0.088	, 4
10:39:57	83.813	4	0.027	4	81.456	4	-0.094	4
10:49:48	89.962	4	0.22	4	82.542	4	0.129	4
10:54:48	100.938	4	0.281	4	83.805	4	0.107	4
10:59:48	105.972	4	0.312	4	84.712	4	0.106	4
11:04:48	110.784	4	0.356	4	85.567	4	0.154	4
11:09:48	113.374	4	0.4	4	86.381	4	0.198	4
11:14:48	115.945	4	0.441	4	87.167	4	0.237	4
11:19:48	116.334	4	0.476	4	87.916	4	0.27	4
11:24:48	116.748	4	0.506	4	88.63	4	0.298	4
11:29:48	118.857	4	0.537	4	89.345	4	0.325	4
11:34:48	119.912	4	0.567	4	90.419	4	0.357	4
11:39:48	122.448	4 .	0.598	4	91.527	4	0.387	4
11:44:48	115.359	4	0.619	4	92.459	4	0.407	4
11:49:48	116.568	4	0.627	4	93.189	4	0.516	4
11:54:48	116.935	4	0.649	4	93.966	4	0.497	4
11:59:48	118.691	4	0.67	4	94.749	4	0.468	4
12:04:48	119.044	4	0.679	4	95.496	4	0.464	4
12:09:48	119.417	4	0.684	4	96.225	4	0.469	4
12:14:48	119.8	4	0.687	4	96.945	4	0.473	4
12:19:48	120.193	4	0.689	4	97.633	4	0.474	4
12:24:47	120.569	4	0.691	4	98.301	4	0.476	4
12:29:48	122.869	4	0.698	4	98.978	4	0.484	4
12:34:47	124.377	4	0.704	4	99.732	4	0.488	4
12:39:47	124.675	4	0.707	4	100.443	4	0.492	4
12:44:47	124.837	. 4	0.709	4	101.112	4	0.496	, , 4
12:49:47	124.098	4	0.739	4	101.754	4	0.543	4
		•	****	•	101.704	7	0.040	4

TIME	SUPP POOL TEMP (F) D23ED005	DW PRESS- VALIDATED STATUS D23ED006	CNTMT PRESS (PSIG) D23ED003	CNTMT PRESS- VALIDATED STATUS D23ED004		CNTMT TEMP- VALIDATED STATUS	DW PRESS (PSIG)	DW PRESS- VALIDATED STATUS
12:54:47	123,239	4	0.772		D23ED009	D23ED010	D23ED001	D23ED002
12:59:47	122.763	4	0.772	4	102.351	4	0.599	4
13:04:47	121.388	4		4	102.903	4	0.603	4
13:09:47		4	0.829	4	103.419	4	0.661	4
	119.997	4	0.862	4	103.874	4	0.742	4
13:14:47	119.894	4	0.868	4	104.301	4	0.716	4
13:19:47	120.366	4	0.871	. 4	104.733	4	0.659	4
13:24:47	122.164	4	0.869	4	105.174	4	0.654	4
13:29:47	122.796	4	0.862	4	105.609	4	0.647	4
13:34:47	124.254	4	0.857	4	106.073	4	0.642	4
13:39:47	124.885	4. ,	0.851	4	106.542	4	0.635	4
13:44:47	126.282	4	0.847	4	107.003	4		4
13:49:47	140.647	4	0.875	4	107.899	4	0.631	4
13:54:47	145.742	4	0.88	4	109.068	4	0.663	4
13:59:47	147.955	4	0.877	4		4	0.661	4
14:04:47	149.509	A	0.875	4	110.146	4	0.655	4
14:09:46	150.819	7	- · · · · ·	4	111.198	4	0.654	4
14:14:46		4	0.872	4	112.24	4	0.651	4
	151.924	4	0.868	4	113.283	4	0.647	4
14:19:46	152.804	4	0.865	4	114.297	4	0.643	4
14:24:46	153.553	4	0.86	4	115.274	4	0.639	4
14:29:46	154.165	4	0.855	4	116.221	4	0.634	4
14:31:29	154.326	4	0.854	4	116.531	4	0.633	4

	DW TEMP (F)	DW TEMP- VALIDATED STATUS	POWER (%)	RX POWER- VALIDATED STATUS	SCRAM STATUS	SDVG ODEN		
TIME	D23ED007	D23ED008	C51ED001	C51ED002	C71ED003	SRVS OPEN	SRV STATUS	MSIV STATUS
6:54:59	124.687	4	100.208	4	5	B21ED051	B21ED050	B21ED072
6:59:59	124.657	4	100.144	4	5 5	0	5	5
7:04:59	124.628	4	99.537	4		0	5	5
7:09:59	124.6	4	100.479	4	5	0	5	5
7:14:59	124.573	4	100.479	4	5	0	5	5
7:19:59	124.544	4	89.125	4	5	0	5	5
7:24:59	124.475	4	90.819	4	5	1	2	-5
7:29:59	124.418	4	91.117	4	5	1	2	5
7:34:59	124.37	4	90.287	4	5	1	2	5
7:39:59	124.326	. 4	90.545	4	5	1	2	5
7:44:59	124.289	4	90.509	4	5	1	2	5
7:49:58	124.26	4	90.264	4	5	1	2	5
7:54:58	124.23	4	89.12	4	5 5	1	2	5
7:59:58	124.201	4	89.413	4		1	2	5
8:04:58	124.171	4	89.771	4	5	1	2	5
8:09:58	124.142	4	88.841	4	5 5	1	2	. 5
8:14:58	124.114	4	90.008	4	5 5	1	2	5
8:19:58	124.09	4	89.352	4	5	1	2	5 .
8:24:58	124.069	4	89.205	4	5 5	1	2	5
8:29:58	124.049	4	89.017	4	5 ·	1	2	5
8:34:58	124.03	4	88.914	4	5	1	2	5
8:39:58	124.011	4	88.941	4	5	1	2	5
8:44:58	123.993	4	88.497	4	5	1	2	5
8:49:58	123.975	4	88.718	4	5		2	5
8:54:58	123.957	4	88.523	4	5		2	5
8:59:58	123.94	4	88.848	4	5	1	2	5
9:04:58	123.922	4	88.999	4	5	1	2	5
9:09:58	123.906	4	87.77	4	5	1	2	5
9:14:58	123.89	4	88.203	4	5	1	2	5
9:19:58	123.873	4	87.928	л	5	4	2	5
9:24:58	123.858	4	88.62	4	5		2	5
9:29:57	123.845	4	88.542	4	5	1	2	5
9:34:57	123.833	4	88.387	4	5 5	1	2	5
9:39:57	123.822	4	88.448	4	5	1	2	5
9:44:57	123.813	4	88.239	4	5 5	1	2	5
9:49:57	123.805	4	87.573	4	5 5	1	2	5
	· · 	•	07.010	4	IJ	ī	2	5

		DW TEMP-		RX POWER-				•
		VALIDATED		VALIDATED				
	DW TEMP (F)	STATUS	POWER (%)	STATUS	SCRAM STATUS	SRVS OPEN	SRV STATUS	MSIV STATUS
TIME	D23ED007	D23ED008	C51ED001	C51ED002	C71ED003	B21ED051	B21ED050	B21ED072
9:54:57	123.796	4	88.101	4	5	1	2	5
9:59:57	123.787	4	87.769	4	5	1	2	5
10:04:57	123.778	4	88.037	4	5	1	2	5
10:09:57	123.769	4	87.316	4	5	1	2	5
10:14:57	123.76	4	88.124	4	5	1	2	5
10:19:57	123.751	4	87.61	4	5	1	2	5
10:24:57	123.741	4	87.6	4	5	1	· 2	5
10:29:57	123.733	4	88.01	4	5	1	2	5
10:34:57	123.723	4	87.669	4	5	1	2	5
10:39:57	123.714	4	87.557	4	5	1	2	5
10:49:48	129.68	4	2.327	4	3	1	2	1
10:54:48	126.746	4	1.164	4	3	1	2	1
10:59:48	122.719	4	0.694	4	3	1	2	1
11:04:48	122.094	4	0.414	4	3	1	2	1
11:09:48	121.732	4	0.519	4	3	1	2	1
11:14:48	121.501	4	0.292	4	3	1	2	1
11:19:48	121.256	4	0.504	4	3	1	2	1
11:24:48	121.072	4	0.605	4	3	1	2	1
11:29:48	120.957	4	0.13	4	3	8	2	1
11:34:48	120.829	4	0.568	4	3	1	2	1
11:39:48	120.749	4 -	0.478	4	3	1	2	1
11:44:48	120.681	4	0.471	4	3	1	2	1
11:49:48	121.424	4	0.273	4	3	1	2	1
11:54:48	122.043	4	0.413	4	3	1	. 2	1
11:59:48	122.383	4	0.209	4	3	1	2	1
12:04:48	122.649	4	0.198	4	3	1	2	1
12:09:48	122.877	4	0.076	4	3	1	2	1
12:14:48	123.056	4	0.004	4	3	1	2	1
12:19:48	123.198	4	0	4	3	1	2	1
12:24:47	123.324	4	0	4	3	1	2	1
12:29:48	123.424	4	0	4	3	1	2	1
12:34:47	123.424	- 4	0	4	3	1	2	1
12:39:47	123.502	4	0	4	3	1	2	1
12:44:47	123.603	4	0	4	3	1	2	1
12:49:47	123.729	4	0	4	3	1	2	1

	DW TEMP (F)	DW TEMP- VALIDATED STATUS	POWER (%)	RX POWER- VALIDATED STATUS	SCRAM STATUS	SRVS OPEN	SRV STATUS	MCD/ CTATUO
TIME	D23ED007	D23ED008	C51ED001	C51ED002	C71ED003	B21ED051	B21ED050	MSIV STATUS B21ED072
12:54:47	123.912	4	0	4	3	1	2	1
12:59:47	123.855	4	0	4	3	N	5	1
13:04:47	123.564	4	0	4	3	0	5	•
13:09:47	123.515	4	0.249	4	3	0	5	1
13:14:47	123.607	4	0.327	4	3	1	2	1
13:19:47	123.739	4	0.299	4	3	1	2	1
13:24:47	123.884	4	0.143	4	3		. 2	1
13:29:47	124.05	4	0.033	4	3	1 .	2	1
13:34:47	124.18	4	0	4	3	. '	2	1
13:39:47	124.298	4	0	4	3	1	2	1
13:44:47	124.43	. /4	0	4	3	5	2	1
13:49:47	124.085	4	. 0	4	3	4	2	1
13:54:47	123.378	4	0	4	3	BAD DATA	Z DAD DATA	1
13:59:47	122.549	4	Ô	4	3	BAD DATA	BAD DATA	1
14:04:47	121.858	4	. 0	4	3	BAD DATA	BAD DATA	1
14:09:46	121.255	4	0	4	3	BAD DATA	BAD DATA	1
14:14:46	120.725	4	n	4	3	BAD DATA	BAD DATA	1
14:19:46	120.261	4	Ô	4	3	BAD DATA	BAD DATA	1
14:24:46	119.832	4	0	4	3		BAD DATA	1
14:29:46	119.455	4	n	A	3	BAD DATA	BAD DATA	1
14:31:29	119.337	4	0	4	3	BAD DATA	BAD DATA	1
		•	•	4	3	BAD DATA	BAD DATA	1

	GROUP ISOLATED STATUS	NON-SPDS RAD STATUS	RAD	DG 1 STATUS	DG 2 STATUS	DG 3 STATUS	GEN OUTPUT (MWe)	TURBINE SPEED (RPM)
TIME	B21ED073	D21ED001	D17ED001	R43ED002	R43ED003	R43ED004	N41BD001	N31BA013
6:54:59	1	1	1	5	5	5	1228.595	1800.001
6:59:59	1	1	1	5	5	5	1229.005	1800.001
7:04:59	1	1	1	5	5	5	1229.005	1800.001
7:09:59	1	1	1	5	5	5	1229.005	1800.001
7:14:59	1	1	1	5	5	5	1229.005	1800.001
7:19:59	1	1	1 .	5	5	5	1226.4	1799.998
7:24:59	1	2	1	5	5	5	1226.4	1800
7:29:59	1	2	1	5	5	5	1105.843	1800.001
7:34:59	1	2	1	5	5	5	1105.843	1800.001
7:39:59	1	2	1	5	5	5	1107.692	1800.001
7:44:59	. 1	2	1	5.	5	5	1107.692	1800.001
7:49:58	1	2	1	5	5	5	1089.6	1800.001
7:54:58	1	2	. 1	5	5	5 .	1089.6	1800
7:59:58	1	2	1 ,	5	5	5	1082.466	1800.001
8:04:58	1	2	1	5	5	. 5	1082.466	1800.001
8:09:58	1	2	1	5	5	5	1059.532	1800.001
8:14:58	1	2	1	5	5	5	1059.532	1800
8:19:58	1	2	1	5	5	5	1057.763	1800.001
8:24:58	1	2	1	5	5	5	1057.763	1800.001
8:29:58	1	2	1	5	5	5	1076.934	1800.001
8:34:58	1	2	1	5	5	5	1076.934	1800.001
8:39:58	1	2	1	5	5	5	1057.763	1800.001
8:44:58	1	2	1	5	5	5	1057.763	1800.001
8:49:58	1	2	1	5	5	5	1057.763	1800.001
8:54:58	1	2	1	5	5	5	1057.763	1800
8:59:58	1	2	1	5	5	5	1057.763	1800.001
9:04:58	1	2	1	5	5	5	1057.763	1800.001
9:09:58	1	2	1	5	5	5	1070.835	1800.001
9:14:58	1	2	1 .	5	5	5	1070.835	1800.001
9:19:58	1	2	BAD DATA	5	5	5	1059.532	1800
9:24:58	1	2	BAD DATA	5	5	5	1059.532	1800
9:29:57	1	2	BAD DATA	5	5	5	1059.532	1800.001
9:34:57	1	2	BAD DATA	5	5	5	1059.532	1800
9:39:57	1	2	BAD DATA	5	5 ·	5	1061.137	1800.001
9:44:57	1	2	BAD DATA	5	5	5	1061.137	1800.001
9:49:57	1	2	BAD DATA	5	5	5	1065.6	1800.001

	GROUP	NON-SPDS RAD		•			GEN OUTPUT	TURBINE SPEED
	ISOLATED STATUS	STATUS	RAD	DG 1 STATUS	DG 2 STATUS	DG 3 STATUS	(MWe)	(RPM)
TIME	B21ED073	D21ED001	D17ED001	R43ED002	R43ED003	R43ED004	N41BD001	N31BA013
9:54:57	1	2	BAD DATA	5	5	5	1065.6	1800.001
9:59:57	1	2	BAD DATA	5	5	5	1011.371	1800.001
10:04:57	1	2	BAD DATA	5	5	5	1011.371	1800.001
10:09:57	1	2	BAD DATA	5	5	5	1060.94	1800.001
10:14:57	1	2	BAD DATA	. 5	5	5	1060.94	1800.001
10:19:57	1	2	BAD DATA	5	5	5	1060.94	1800.001
10:24:57	1	2	BAD DATA	5	5	5	1060.94	1800.001
10:29:57	1	2	3	5	5	5	1059.532	1800.001
10:34:57	1	2	2	5	5	5	1059.532	1800.001
10:39:57	1	2	1	5	5	5	1055.805	1800.001
10:49:48	3	2	1	3	3	3	BAD DATA	1723.147
10:54:48	3	2	1	3	3	3	BAD DATA	1538.69
10:59:48	3	2	1	3	3	3	BAD DATA	1341.732
11:04:48	3	2	1	3	3	3	-2342.176	1151.472
11:09:48	3	3	2	3	3	3	-2342.176	960.086
11:14:48	3	3	2	3	3	3	0	748.49
11:19:48	3	3	3	3	3	3	0	524.994
11:24:48	3	3	3	3	3	3	0	307.664
11:29:48	3	3	3	3	3	3	0	120.783
11:34:48	. 3	3	3	3	3	3	0	1.5
11:39:48	3	3	3	3	3	3	0	1.5
11:44:48	3	3	3	3	3	3	0	1.5
11:49:48	3	3	3	3	3	3	0	1.5
11:54:48	3	3	3	3	3	3	0	1.5
11:59:48	3	3	3	3	3	3	0	1.5
12:04:48	3	3 .	3	3	3	3	0	1.5
12:09:48	3	3	3	3	. 3	3	0	1.5
12:14:48	3	3	3	3	3	3	0	1.5
12:19:48	3	3	3	3	3	3	0	1.5
12:24:47	3	3	3	3	3	3	0	1.5
12:29:48	3	3	3	3	3	3	. 0	1.5
12:34:47	3	3	3	3	. 3	. 3	0	1.5
12:39:47	3	3	3	3	3	3	0	1,5
12:44:47	3	3	3	3	3	3	0	1.5
12:49:47	3	3	3	3	3	3	0	1.5

Section 7.2.2

	GROUP ISOLATED STATUS	NON-SPDS RAD STATUS	RAD	DG 1 STATUS	DG 2 STATUS	DG 3 STATUS	GEN OUTPUT (MWe)	TURBINE SPEED (RPM)
TIME	B21ED073	D21ED001	D17ED001	R43ED002	R43ED003	R43ED004	N41BD001	N31BA013
12:54:47	3	3	3	3	. 3	3	0	1.5
12:59:47	3	3	3	3	3	3	0	1.5
13:04:47	3	3	3	3	3	3	0	1.5
13:09:47	3	3	3	3	3	3	0	1.5
13:14:47	3	3	3	3	3	3	0	1.5
13:19:47	3	3	3	3	3	3	0	1.5
13:24:47	3	3	3	3	3	3	0	1.5
13:29:47	3	3	3	3	3	3	0	1.5
13:34:47	3	3	3	3	3 .	3	0	1.5
13:39:47	3	3	3	· 3	3	3	0	1.5
13:44:47	3	· / 3	3	3	3	3	0	1.5
13:49:47	3	3	3	3	3	3	0	1.5
13:54:47	3	3	3	3	3	3	0	1.5
13:59:47	3	3	3	3	3	3	0	1.5
14:04:47	3	3	. 3	3	3	3	0	1.5
14:09:46	3	3	3	3	3	3	0	1.5
14:14:46	· 3	3	3	3	3	3	0	1.5
14:19:46	3	.3	3	3	3	3	0	1.5
14:24:46	3	3	3	3	3	3	0	1.5
14:29:46	3	3	3	3	3	3	0	1.5
14:31:29	3	3	3	3	3	3	0	1.5

TIME 6:56:11 7:01:11 7:06:11 7:11:10 7:16:10 7:21:11 7:26:10 7:31:10 7:36:10 7:41:10 7:46:10 7:51:10 7:56:10 8:01:10 8:06:10 8:11:10 8:16:10 8:21:10 8:26:10 8:31:10 8:36:10 8:41:10 8:46:10 8:51:10 8:56:09 9:01:09 9:06:09 9:11:09 9:16:09 9:21:09 9:26:09 9:31:09 9:36:09 9:41:09 9:46:09 9:51:09

	FEEDWATER	STEAM FLOW		CONT VALVE	STOP VALVE
	FLOW (Mlbm)	(Mlbm)	BYP VALVE POS	POS	POS
TIME	N27BD001	N11BD001	C85EA011	N32EA010	N32EA001
6:54:59	15.325	15.354	0	82.192	100
6:59:59	15.325	15.354	0	82.193	100
7:04:59	15.324	15.354	0	82.213	100
7:09:59	15.324	15.353	0	82.204	100
7:14:59	15.324	15.353	0	82.21	100
7:19:59	15.324	15.353	0	74.371	100
7:24:59	13.708	13.737	0	73.47	100
7:29:59	13.685	13.714	0	73.226	100
7:34:59	13.66	13.689	0	72.68	100
7:39:59	13.64	13.669	0	73.015	100
7:44:59	13.618	13.651	0	72,793	100
7:49:58	13.597	13.631	0	72.605	100
7:54:58	13.577	13.606	0	72.488	100
7:59:58	13.564	13.589	0	72.319	100
8:04:58	13.545	13.575	0	72.189	100
8:09:58	13.528	13.557	0	72.042	100
8:14:58	13.51	13.539	. 0	71.898	100
8:19:58	13.493	13.522	0	71.818	100
8:24:58	13.478	13.507	0	71.711	100
8:29:58	13.463	13.492	0	71.608	100
8:34:58	13.447	13.476	0	71.521	100
8:39:58	13.433	13.463	0	71.415	100
8:44:58	13.42	13.449	0	71.309	100
8:49:58	13.406	13.435	0	71.21	100
8:54:58	13.391	13.422	0	71.124	100
8:59:58	13.381	13.408	0	71.043	100
9:04:58	13.37	13.396	0	70.979	100
9:09:58	13.359	13.388	0	70.875	100
9:14:58	13.348	13.377	. 0	70.818	100
9:19:58	13.338	13.368	. 0	70.759	100
9:24:58	BAD DATA	BAD DATA	0	70.684	100
9:29:57	BAD DATA	BAD DATA	. 0	70.639	100
9:34:57	BAD DATA	BAD DATA	0	70.59	100
9:39:57	BAD DATA	BAD DATA	0	70.549	100
9:44:57	BAD DATA	BAD DATA	0	70.486	100
9:49:57	BAD DATA	BAD DATA	0	70.444	100
	•		•	19.777	100

	FEEDWATER	STEAM FLOW		CONT VALVE	STOP VALVE	
	FLOW (Mlbm)	(Mlbm)	BYP VALVE POS	POS	POS	
TIME	N27BD001	N11BD001	C85EA011	N32EA010	N32EA001	TIME
9:54:57	BAD DATA	BAD DATA	0	70.406	100	9:56:09
9:59:57	BAD DATA	BAD DATA	0	70.377	100	10:01:09
10:04:57	BAD DATA	BAD DATA	0	70.338	100	10:06:09
10:09:57	BAD DATA	BAD DATA	0	70.307	100	10:11:09
10:14:57	BAD DATA	BAD DATA	, 0	70.27	100	10:16:09
10:19:57	BAD DATA	BAD DATA	0	70.247	100	10:21:09
10:24:57	BAD DATA	BAD DATA	0	70.217	100	10:26:09
10:29:57	BAD DATA	BAD DATA	0	70.183	100	10:31:09
10:34:57	13.232	13.261	0	70.141	100	10:36:09
10:39:57	13.225	13.254	0	70.14	100	10:41:08
10:49:48	12.434	BAD DATA	0	0	0	13:15:58
10:54:48	0.04	BAD DATA	0	0	0	13:20:58
10:59:48	0.101	BAD DATA	0	0	0	13:25:58
11:04:48	0.138	BAD DATA	0	0	0	13:30:58
11:09:48	0.076	BAD DATA	0	0	0	13:35:58
11:14:48	0.055	BAD DATA	0	0	0	13:40:58
11:19:48	0.463	BAD DATA	0	0	0	13:45:58
11:24:48	0.104	BAD DATA	0.	0	0	13:50:58
11:29:48	0.092	BAD DATA	0	0	0	13:55:58
11:34:48	0.073	BAD DATA	0	0	0	. 14:00:58
11:39:48	0.04	BAD DATA	. 0	0	0	14:05:57
11:44:48	0.052	BAD DATA	0	0	0	14:10:58
11:49:48	0.043	BAD DATA	0	0	0	14:15:57
11:54:48	0.01	BAD DATA	0	0	0	14:20:57
11:59:48	0.005	BAD DATA	0	0	0	14:25:57
12:04:48	0.005	BAD DATA	0	0	0	14:30:57
12:09:48	0.005	BAD DATA	0	0	0	14:35:57
12:14:48	0.005	BAD DATA	0	0	0	14:40:57
12:19:48	0.005	BAD DATA	0	0	0	14:45:57
12:24:47	0.005	BAD DATA	0	0	0	14:50:57
12:29:48	0	BAD DATA	0	0	, 0	14:55:57
12:34:47	0.001	BAD DATA	0	0	0	15:00:56
12:39:47	0.001	BAD DATA	0	0	0	15:05:57
12:44:47	0.001	BAD DATA	0	0	0	15:10:57
12:49:47	0.001	BAD DATA	0	0	0	15:15:57

	FEEDWATER	STEAM FLOW		CONT VALVE	STOP VALVE	
	FLOW (Mlbm)	(Mlbm)	BYP VALVE POS	POS	POS	
TIME	N27BD001	N11BD001	C85EA011	N32EA010	N32EA001	TIME
12:54:47	0.001	BAD DATA	0	0	0	15:20:57
12:59:47	0.001	BAD DATA	0	0	0	15:25:57
13:04:47	0.001	BAD DATA	0	0	0	15:30:57
13:09:47	0.001	BAD DATA	0	0	0	15:35:57
13:14:47	0.001	BAD DATA	. 0	0	0	15:40:57
13:19:47	0.001	BAD DATA	0	0	0	15:45:57
13:24:47	0.001	BAD DATA	0	0	0	15:50:57
13:29:47	0.001	BAD DATA	0	0	0	15:55:57
13:34:47	0.001	BAD DATA	0	0	0	16:00:57
13:39:47	0.001	BAD DATA	0	О	0	16:05:56
13:44:47	0.001	BAD DATA	0	0	0	16:10:56
13:49:47	0.001	BAD DATA	0	0	0	16:15:56
13:54:47	BAD DATA	BAD DATA	, 0	0	0	16:20:56
13:59:47	BAD DATA	BAD DATA	0	0	0	16:25:56
14:04:47	BAD DATA	BAD DATA	0	0	0	16:30:56
14:09:46	BAD DATA	BAD DATA	0	0	0	16:35:56
14:14:46	BAD DATA	BAD DATA	0	0	0	16:40:55
14:19:46	BAD DATA	BAD DATA	0	0	0	16:45:56
14:24:46	BAD DATA	BAD DATA	0	0	0	16:50:56
14:29:46	BAD DATA	BAD DATA	0	0	0	16:55:56
14:31:29	BAD DATA	BAD DATA	0	0	0	16:57:38
						10.57.58

Table 7.2.3

RADIATION DATA SUMMARY TRENDS

	Plant Vent 1 1D17- K786 CPM	Plant Vent 11D19- N300 uCi/cc	Plant Vent 1 1D19-340 uCi/cc	Plant Vent 1 Flow 1M33-N125A KCFM	Plant Vent 2 2D17- K786 CPM	Plant Vent 2 2D19-	Plant Vent 2 2D19-	Plant Vent 2 Flow 1M33-N125B
TIME	D17EA030	D19EA003	D19EA004	M33EA001	D17EA530	N300 uCi/cc	N340 uCi/cc	KCFF
6 54 59	100	0 001	1.02	88.496	88	D19EA503	D19EA504	M33EA002
6:59:59	100	0 001	1.02	88.496	88	0.001	. 1.02	54 545
7:04 59	100	0.001	1.02	88.496	88	0.001	1.02	54.544
7:09:59	100	0 001	1.02	88.496	88		1.02	54.545
7 14 59	100	0 001	1.02	88.496	88	0.001	1.02	54.545
7:19:59	100	0.001	1.02	88 496	88	0.001	1.02	54 544
7.24.58	100	0.001	1.02	88 496	88 .	0.001	1.02	54 544
7 29 58	100	0 001	1.02	88 496	88	0.001	1.02	54 546
7 34 58	100	0 001	1.02	88 496	88	0 001	1.02	54.546
7:39:58	100	0.001	1.02	88.496	88	0.001	1.02	54 544
7:44 58	100	0.001	1.02	88 496	88	0.001	1.02	54 544
7:49:58	100	0.001	1.02	88.496	88	0.001	1.02	54 544
7:51:58	100	0.001	1,02	88 496	88	0.001	1.02	54 544
7:59 58	100	0 001	1.02	88 496	88	0.001	1.02	. 54.544
8 04.58	100	0.001	1.02	88.496	88	0.001	1.02	54.544
8:09 58	100	0 001	1.02	88.496	88	0.001	1.02	54 544
8 14 58	100	0 001	1.02	88.496	88	0.001	1.02	54.544
8.19.58	100	0.001	1.02	88 496	88	0.001	1.02	54 543
8.24.58	100	0.001	1.02	88.496	88	0.001 0.001	1.02	54.544
8 29 58	100	0.001	1.02	88.496	88	0.001	1.02	54.543
8 34 58	100	0.001	1.02	88 496	88	0.001	1.02	54 545
8:39.58	100	0.001	1.02	88 496	88	0.001	1.02	54.543
8 44 5B	100	0 001	1.02	88.496	88	0.001	1.02	54.545
8:49:58	100	0.001	1.02	88.496	88	- 0.001	1.02	54 546
8:54:58	100	0.001	1.02	88.496	88	0.001	1.02	54 544
8:59.58	100	0.001	1.02	88.496	88	0.001	1.02	54.544
9.04.58	100	0.001	1.02	88.496	88	0.001	1.02	54.544
9 09 58	100	0.001	1.02	88 496	88	0.001	1.02 1.02	54.546
9:14:57	100	0.001	1.02	88.496	88	0.001	1.02	54 544
9,19.57	100	0.001	1.02	88.496	88	0.001	1.02	54 544
9.24:57	100	0.001	1.02	88 496	88	0.001	1.02	54.544
9 29 57	100	0 001	1.02	88 496	88	0.001	1.02	54.544
9:34.57	100	0.001	1.02	88 496	88	0 001	1.02	54 545
9:39 57	100	0 001	1 02	88.496	88	0 001	1.02	54,544
9.44:57	100	0.001	1.02	88.496	88	0.001	1.02	54.544 54.544
9 49:57	100	0.001	1.02	88.496	88	0 001	1.02	54.544
9:54:57	100	0.001	1.02	88.496	88	0 001	1.02	54.544
9.59:57	100	0.001	1.02	88.496	88	0.001	1.02	54.545
10 04 57	100	0.001	1.02	88.496	88	0 001	1.02	54.545 54.545
10:09:57	100	0.001	1.02	88 496	88	0.001	1.02	54.545 54.544
10:14:57	100	0 001	1.02	88.496	88	0.001	1.02	54.544 54.544
10:19:57	100	0.001	1.02	88.496	88	0.001	1.02	54.544
10:24:56	100	0.001	1.02	88.496	88	0.001	1.02	54.544
10:29:57	100	0.001	1.02	88.496	88	0.001	1.02	54.544
10:34:57	100	0.001	1.02 .	88.496	88	0.001	1.02	54.544 54.545
10:39:57	100	0.001	1.02	88.496	88	0.001	1.02	54.545
10.49.51	100	0.001	1.02	88.496	88	0.001	1.02	54.545 54.545
10:54:51	100	0.001	1.02	88.496	88	0.001	1.02	54.546
10:59,51	100	0.001	1.02	88.496	88	0.001	1.02	54.546
11:04:51	100	0.001	1.02	88.496	88	0.001	1.02	54.546 54.547
11:09:51	340.051	1.166	1.166	88.496	88	0.001	1.02	54.547 54.547
							1.02	34.347

	Plant Vent 1 1D17-	Plant Vent 11D19-	Plant Vent 1 1D19-340	Plant Vent 1 Flow 1M33-N125A	Plant Vent 2 2D17-	Plant Vent 2 2D19-	Plant Vent 2 2D19-	Plant Vent 2 Flow 1M33-N125B
	K786 CPM	N300 uCi/cc	uCi/cc	KCFM	K786 CPM	N300 uCi/cc	N340 uCi/cc	KCFF
TIME	D17EA030	D19EA003	D19EA004	M33EA001	D17EA530	D19EA503	D19EA504	M33EA002
11.14.51	709 955	1.205	1.205	88.496	88	0.001	1 02	54.547
11:19:51	1081.303	1.211	1 211	88 496	88	0.001	1 02	54.548
11:24:51	1209 988	1 295	1 295	88.496	88	0.001	1.02	54.548
11:29:51	1209.988	1.159	1 159	88.496	88	0.001	1.02	54.548
11:34:51	1209.988	1.033	1 033	88.496	88	0.001	1.02	54.548
11:39:50	1209 988	0.886	1 02	88.496	88	0.001	1 02	54.549
11:44:51	1209.988	0.938	1 02	88.496	88	0.001	1 02	54.547
11:49:50	1209.988	0.824	1 02	88.496	88	0.001	1.02	54.55
11:54:50	1209.988	0.896	1 02	88.496	88	0.001	1 02	54.55
11:59:50	1209.988	0.735	1 02	88.496	88	0.001	1 02	54.55
12 04:50	1209 988	0.723	1 02	88.496	88	0.001	1.02	54.549
12:09.50	1209 988	0.672	1 02	88.496	88	0.001	1 02	54.55
12:14:50	1209.988	0.605	1 02	88.496	88	0.001	1 02	54.55 54.55
12:19:50	1209 988	0 607	1.02	88.496	88	0.001	1.02	54.55
12.24:50	1209 988	0.578	1.02	88.496	88	0.001	1 02	54.55
12:29:50	1209.988	0.527	1:02	88.496	88	0.001	1 02	54.549
12:34:50	2128 154	0.525	1 02	88.496	88	0.001	1 02	54.549
12.39:50	5009.949	0.501	1 02	88.496	88	0.001	1.02	54.549
12:44:50	5009,949	0.487	1.02	88.496	88	0.001	1.02	54.551
12:49:50	5009.949	0 463	1 02	88.496	88	0.001	1 02	54.55
12:54:50	5009.949	0 484	1 02	88.496	88	0.001	1.02	54.55
12:59:50	5009.949	0.604	1 02	88.496	88	0.001	1.02	54.55
13:04:50	5009 949	0.354	1 02	88 496	88	0.001	1.02	54.55
13:09:50	5009.949	0.315	1 02	88.496	88 .	0.001	1.02	54.55
13:14:50	5009.949	0.96	1.02	88.496	88	0.001	1.02	54.55
13:19:50	5009.949	1.138	1.138	88.496	88	0.001	1 02	54.551
13:24:50	5009.949	0.981	1.02	88.496	88	0.001	1.02	54.549
13:29:49	5009 949	0.864	1 02	88.496	88	0 001	1 02	54.551
13:34:50	5009.949	0.785	1 02	88.496	88	0.001	1 02	54.548
13:39:49	5009.949	0.703	1.02	88.496	88	0.001	1.02	54.549
13:44:49	4275 477	0.731	1.02	88.496	88	0.001	1.02	54.549
13:49:49	2672.329	0 014	1 02	88.496	88	0.001	1 02	54.55
13:54:49	1059 268	0.001	1 02	88.496	88	0.001	1 02	54,549
13:59:49	209.998	0.001	1.02	88.496	88	0.001	1.02	54.549
14:04:49	209.998	0.001	1 02	88.496	88	0 001	1.02	54.55
14:09.49	209.998	0.001	1 02	88.496	. 88	0.001	1.02	54.55
14:14:49	209.998	0.001	1 02	88.496	88	0.001	1.02	54.55
14:19:49	209.998	0.001	1.02	88.496	88	0.001	1 02	54.551
14:24:49	209 998	0.001	1.02	88.496	88	0.001	1.02	54.55
14:29:49	209.998	0.001	1 02	88.496	88	0.001	1.02	54.551
14:31:29	209.998	0.001	1.02	88 496	88	0.001	1.02	54.551

	Offgas Vent D17-K836 CPM	Offgas Vent D19-N400	Offges Vent D-N440 uCi/cc	Offgas Vent Flow M36-N090 KCFM	TB&HB Vent D17-K856 CPM	TB&HB Vent D19-	TB&HB Vent D19-	TB&HB Vent Flow M41-N260
TIME	D17EA033	D19EA005	D19EA006	M36EA001	D17EA036	N500 uCi/cc	N540 uCi/cc	KCFM
6 54 59	50	0 001	1.02	17 578	50	D19EA007	D19EA008	M41EA001
6 59 59	50	0 001	1.02	17 578	50 50	0.001	1.02	170.41
7 04 59	50	0.001	1.02	17 578	50 50	0.001	1.02	170.41
7 09 59	50	0.001	1.02	17 578	50 50	0.001	1.02	170.41
7 14 59	50	0 001	1.02	17 578	50 50	0 001	1.02	170 41
7 19 59	50	0 001	1.02	17 578	50 50	0.001	1.02	170 41
7 24 58	50	0 001	1.02	17 578	50 50	0 001	1.02	170 41
7 29 58	50	0 001	1.02	17 578	50 50	0.001	1.02	170.41
7 34:58	50	0 001	1.02	17 578	50	0.001	1.02	170 41
7 39 58	50	0 001	1.02	17 579	50	0 001	1.02	170 41
7 44 58	50	0 001	1.02	17 579	50	0 001 0 001	1.02	170 41
7 49 58	50	0.001	1.02	17 579	50 50	0.001	1.02	170 41
7 54:58	50	0 001	1.02	17 578	50		1.02	170 41
7 59 58	50	0 001	1.02	17 579	50	0.001 0.001	1.02	170.41
8 04 58	50	0.001	1.02	17 579	50	0.001	1.02	170 41
8 09 58	50	0.001	1.02	17.578	50	0.001	1.02	170.41
8 14 58	50	0 001	1.02	17 579	50	0.001	1.02	170.41
8 19 58	50	0 001	1.02	17 579	50	0.001	1.02 1.02	170.41
8 24 58	50	0 001	1.02	17 579	50	0 001	1.02	170 41
8 29 58	50	0 001	1.02	17 579	50	0.001	1.02	170.41
8 34.58	50	0 001	1.02	17 579	50	0.001	1.02	170 41
8 39.58	50	0 001	1.02	17.579	50	0.001	1.02	170.41
8 44:58	50	0.001	1.02	17 579	50	0.001	1.02	170.41
8 49 58	50	0 001	1.02	17 579	50	0.001	1.02	170 41
8 54 58	50	0.001	1.02	17 579	50	0.001	1.02	170 41
8 59 58	50	0.001	1.02	17 579	50	0 001	1.02	170.41 170.41
9.04.58	50	0 001	1.02	17.579	50	0.001	1.02	170.41
9 09 58	50	0 001	1.02	17 579	50	0.001	1.02	170.41
9 14 57	50	0 001	1.02	17 579	50	0.001	1.02	170 41
9 19.57 9.24.57	50	0.001	1.02	17 56	50	0.001	1.02	170.41
9:29:57	50	0.001	1.02	17 56	50	0.001	1.02	170.41
9 34 57	50 50	0 001	1.02	17 56	50	0.001	1.02	170 41
9 39 57	50 50	0 001	1.02	17 56	50	0.001	1.02	170 41
9 44 57	50	0.001 0.001	1.02	17 56	50	0.001	1.02	170 41
9 49 57	50	0 001	1.02	17.56	50	0 001	1.02	170 41
9 54 57	50	0 001	1.02	17 56	50	0.001	1.02	170 41
9 59.57	50	0 001	1.02 1.02	17.56	50	0 001	1.02	170 41
10 04 57	50	0 001	1.02	17 56	50	0.001	1.02	170.41
10 09 57	50	0.001	1.02	17 56	50	0.001	1 02	170.41
10:14:57	50	0.001	1.02	17.56	50	0.001	1.02	170.41
10 19.57	50	0.001	1.02	17 56 17 56	50	0.001	1.02	170 41
10:24:56	50	0.001	1.02	17.56	50	0.001	1.02	170 41
10 29:57	50	0.001	1.02		50	0.001	1.02	170.41
10:34:57	50	0.001	1.02	17.94 17.585	50	0.001	1.02	170.41
10:39.57	50	0.001	1.02	17.57	50	0.001	1.02	170 41
10.49:51	50	0.001	1.02	17.589	50	0.001	1.02	170.41
10 54 51	50	0.001	1.02	17.589	50	0.001	1.02	170.41
10 59 51	50	0.001	1.02	17.547	50	0.001	1.02	170.41
11 04:51	50	0 001	1.02	17 428	50	0.001	1.02	170.41
11:09 51	50	0 052	1.02	17.288	50	0.001	1.02	170 41
		**		17.200	1121.663	0.118	1.02	170 41

	•					***************************************	**********	T041016 - 171 - 1144 11000
				Offgas Vent Flow M36-N090		TB&HB Vent D19-	TB&HB Vent D19-	TB&HB Vent Flow M41-N260 KCFM
	CPM	uCi/cc	uCi/cc	KCFM	CPM	N500 uCi/cc	N540 uCi/cc D19EA008	M41EA001
TIME	D17EA033	D19EA005	D19EA006	M36EA001 17.288	D17EA036 2773.6	D19EA007 0.123	1.02	170.41
11:14:51	50	0.054	1.02	17.288	4433.207	0.123	1.02	170.41
11,19:51	50	0.055	1.02		5009 949	0.124	1.02	170.41
11:24:51	50	0.058	1.02	17.288	5009.949	0.133	1.02	170.41
11:29.51	50	0.052	1 02	17.289	5009.949	0.106	1.02	170.41
11:34.51	50	0.046	1 02	17.289	5009.949	0.106	1 02	170.41
11:39.50	50	0.04	1 02	17.288 17.287	5009.949	0.09	1 02	170.41
11:44:51	50	0.041	1 02 1 02	17.287	5009.949	0.085	1 02	170.41
11:49:50	50	0.035		17.287	5009.949	0.092	1 02	170.41
11:54:50	50	0.039	1.02		5009.949	0.092	1 02	170.41
11:59:50	50	0.032	1.02	17.288 17.288	5009.949	0.074	1 02	170.41
12:04:50	50	0.033	1.02	17.288	5009.949	0.069	1 02	170.41
12:09.50	50	0.029	1 02		5009.949	0.063	1 02	170.41
12:14:50	50	0.028	1.02	17.288	5009 949	0.063	1 02	170.41
12:19:50	50	0.026	1.02	17.288	5009.949	0.059	1.02	170.41
12:24:50	50	0.026	1.02	17.288 17.288	5009.949	0.055	1 02	170.41
12:29.50	50	0.024	1 02	17.288	52042.789	0.054	1 02	170.41
12:34:50	50	0.023	1.02	17.288	200008	0.052	1.02	170.41
12:39:50	50	0.022 0.021	1.02	17.288	200008	0.05	1.02	170.41
12:44.50	50	0.021	1 02	17.288	200008	0.048	1 02	170.41
12:49:50	50 50	0.021	1.02	17.288	200008	0.05	1 02	170.41
12:54:50		0.027	1.02	17.289	200008	0.062	1.02	170.41
12:59:50	50	0.027	1 02	17.289	200008	0.037	1.02	170.41
13:04:50	50 50	0.013	1.02	17.289	200008	0.033	1.02	170.41
13:09:50	50	0.04	1 02	17.289	200008	0.098	1.02	170.41
13:14:50 13:19:50	50	0.05	1.02	17.289	200008	0,116	1.02	170.41
13:19:50	5 0	0.043	1.02	. 17.289	200008	0.101	1.02	170.41
13:24:50	50	0.039	1.02	17.289	200008	0,088	1 02	170.41
13:34:50	. 50	0.034	1 02	17.289	200008	0.08	1 02	170.41
13:39:49	50	0.032	1.02	17.289	200008	0.072	1.02	170.41
13:44:49	50	0.032	1.02	17.289	169472.625	0.075	1.02	170.41
13:49:49	50	0.001	1 02	17.289	102729.875	0.002	1 02	170.41
13.54.49	50	0.001	1.02	17.289	35570.266	0.001	1 02	170.41
13:59:49	50	0.001	1 02	17.289	259 997	0.001	1.02	170.41
14:04:49	50	0.001	1.02	17.289	259.997	0.001	1.02	170.41
14:09:49	50	0.001	1.02	17.289	259.997	0.001	1.02	170.41
14:14:49	50	0.001	1.02	17.289	259.997	0.001	1 02	170.41
14:14:49	50	0.001	1.02	17.289	259 997	0.001	1.02	170.41
14:19:49	50	0.001	1.02	17.289	259.997	0.001	1.02	170.41
14.29.49	50	0.001	1.02	17.289	259.997	0.001	1.02	170.41
14:29:49	50	0.001	1.02	17.289	259.997	0.001	1.02	170.41
14.31.29	30	5.501		200	200.000			

	CNTMT ATM MON D19-N200A R/HR	DW ATM MON D19-N100A R/HR	CNTMT ATM MON N200B R/HR	D19-	DW ATM MON D19-N100B	620' AB MSL B	D17-	574 AB Wesl D21-K122	599' CNTMT, AIRLK
TIME	D19EA020	D19EA021	D19EA001		R/HR D19EA002	K6108 MR/H	R	MR/HR	D21-K033 MR/HR
6 54.59	2 225	2 225	2 225		2 225	D17EA012		D21EA009	D21EA007
6 59 59	2.225	2 225	2 225		2 225	324 999		0 705	1
7 04 59	2.225	2 225	2 225		2 225	325 181		0.704	1
7 09 59	2.225	2 225	2 225			325.172		0.705	1
7 14 59	2 225	2 225	2 225		2.225 2.225	325 188		0.705	1
7 19 59	2 136	2.136	2.136			324.991		0 704	1
7 24 58	2.132	2 132	2.132		2.136	296.928		0.678	1
7 29 58	2.131	2.131	2.132		2.132	295.479		0.677	1
7 34 58	2.13	2.13	2 13		2.131	295 262		0.676	1
7 39 58	2.128	2.128	2.128		2 13	294 942		0.676	1
7 44 58	2.127	2.127	2.128		2.128	294.443		0.676	1
7 49 58	2.126	2.126			2 127	293 865		0.675	1
7 54 58	2.124	2 124	2.126		2 126	293.721		0.675	1
7 59 58	2.123	2.123	2.124 2.123		2.124	293.129		0.674	1
8 04 58	2.122	2.123			2.123	292.652		0.674	1
8.09.58	2.121	2 121	2.122		2.122	292.396		0.674	1
8 14 58	2.12	2.12	2.121		2.121	292 103		0.673	1
8 19 58	2.119	2.12	2 12		2.12	291.71		0.673	1
8.24 58	2.118	2.118	2 119		2.119	291.375		0.673	1
8.29.58	2 117	2.110	2 118		2.118	291 266		0.673	1
8 34 58	2.117		2 117		2.117	290.718		0.672	1
8:39 58	2.115	2.116 2.115	2 117		2 116	290.557		0.672	1
8.44 58	2.115	2.115	2.115		2 115	290 266		0.672	1
8:49:58	2 115	2.114	2 115		2.115	290 229		0.671	1
8:54:58	2.114	2.114	2.115		2.114	289.912		0.671	1
8 59 58	2.113	2.113	2 114		2.113	289.502		0.671	1
9.04.58	2.112		2.113		2.113	289.448		0.671	1
9.09.58	2 111	2.112 2.111	2.112		2.112	289.218		0.671	1
9 14:57	2.11	2.11	2 111		2.111	289 059		0.67	1
9 19 57	2.11	2.109	2.11		2.11	288.713		0.67	1
9 24.57	2.109	2.109	2.11		2.109	288.282		0.67	1
9 29 57	2.109	2 109	2 109		2.109	288.278		0.67	1
9:34 57	2.108	2 108	2 109		2.109	288 161		0.67	1
9.39.57	2.108	2 108	2.108		2.108	288.126		0.67	1
9.44:57	2.108		2 108		2.108	287.89		0.669	1
9:49:57	2.107	2 108 2 107	2 108		2.108	287.945		0.669	1
9.54:57	2.106	2.107	2 107		2.107	287.507		0.669	1
9:59.57	2.106		2 106		2 106	287.437		0 669	1
10 04:57	2.105	2.106 2.105	2 106		2.106	287.212		0.669	1
10.09.57	2.105	2.105	2 105		2.105	287.155		0.669	1
10 14.57	2 104		2.105		2.105	286.939		0.668	1
10 19:57	2.105	2.104 2.105	2.104		2.104	286.862		0.668	1
10.24:56	2.104		2.105		2.105	286.947		0 668	1
10.29:57	2.104	2.104	2 104		2.104	286.704		0.668	1
10.29.57	2.104	2.104	2 104		2.104	286.807		0.668	1
10:39:57	2.104	2.104	2.104		2.104	286.745		0 668	1
10:39:57		2.104	2.104		2.104	286.639		0.668	1
10:54:51	1.268	1.272	1.268		1.272	3.5		0 419	1
	1.243	1.243	1.243		1 243	3.5		0.41	i ,
10 59 51	1.235	1.235	1.235		1 235	3.5		0.408	i
11:04:51	1.232	1.232	1.232		1.232	3.5		0.407	i
11:09.51	1.232	1.232	1.232 ⁻		1.232	389.114		1 45	i
									•

	CNTMT ATM MON D19-N200A R/HR	DW ATM MON D19-N100A R/HR	CNTMT ATM MON D1 N200B R/HR	9- DW ATM MON D19-N100B R/HR	620' AB MSL B D17- K610B MR/HR	574 AB West D21-K122 MR/HR	599' CNTMT, AIRLK D21-K033 MR/HR
TIME	D19EA020	D19EA021	D19EA001	D19EA002	D17EA012	D21EA009	D21EA007
11:14.51	1.228	1.228	1.228	1.228	556.337	1.742	1
11 19:51	1.23	1.23	1.23	1.23	724.776	1.479	
11 24.51	1.23	1.23	1.23	1.23	784	1.784	1
11:29:51	1 225	1 225	1 225	1 225	784	1 315	•
11:34:51	1 229	1.229	1 229	1.229	784	1.324	1
11.39:50	1 228	1 228	1.228	1 228	784	1.151	1
11,44:51	1 227	1.227	1.227	1 227	784	1 514	1
11 49 50	1 225	1.225	1.225	1 225	784	1,307	•
11:54:50	1 226	1 226	1.226	1 226	784	1.294	1
11:59 50	1 224	1.224	1.224	1 224	784	1.088	1
12:04:50	1 223	1.223	1.223	1.223	784	1.043	1
12 09 50	1 222	1.222	1.222	1 222	784	1.174	1
12:14:50	1 221	1 221	1.221	1 221	784	0.916	1
12.19.50	1 221	1.221	1.221	1 221	784	1.057	1
12:24:50	1 221	1.221	1.221	1 221	784	0.894	1
12 29:50	1 221	1.221	1.221	1 221	784	0 855	1
12:34:50	122008.875	123482	1227.096	1240 802	2944.994	0 947	2461.988
12:39:50	500000.75	500000.75	5000.898	5000.898	9799.996	1.013	9998.441
12:44:50	500000.75	500000.75	5000 898	5000 898	9799.996	0.984	9998.441
12:49.50	500000.75	500000.75	5000.898	5000.898	9799.996	0.829	9998.441
12:54:50	500000.75	500000 75	5000.898	5000.898	9799.996	0.832	9998.441
12:59:50	500000.75	500000.75	5000.898	5000.898	9799.996	0.865	9998.441
13:04:50	500000 75	500000.75	5000.898	5000 898	9799.996	0.882	9998.441
13:09:50	500000.75	500000.75	5000.898	5000.898	9799.996	0.694	9998.441
13 14 50	500000.75	500000.75	5000 898	5000.898	9799.996	1.696	9998.441
13:19:50	500000.75	500000.75	5000.898	5000.898	9799.996	1.482	9998.441
13:24:50	500000 75	500000.75	5000.898	5000.898	9799.996	1.345	9998.441
13:29:49	500000 75	500000.75	5000.898	5000 898	9799.996	1.178	9998.441
13:34:50	500000.75	500000.75	5000.898	5000.898	9799.996	1.219	9998.441
13:39:49	500000.75	500000.75	5000.898	5000.898	9799.996	0.977	9998.441
13:44:49	500000 75	500000.75	5000.898	5000 898	8605.461	1.085	9998.441
13:49:49	500000.75	500000 75	5000.898	5000.898	5976,168	0.413	9998.441
13:54:49	500000 75	500000.75	5000,898	5000 898	3356.511	0 404	9998.441
13:59.49	500000 75	500000.75	5000.898	5000.898	1960	0.404	9998.441
14:04.49	500000.75	500000.75	5000.898	5000.898	1960	. 0.404	9998.441
14.09:49	500000 75	500000.75	5000,898	5000.898	1960	0.404	9998 441
14:14:49	500000.75	500000.75	5000.898	5000.898	1960	0.404	9998.441
14:19.49	500000 75	500000.75	5000.898	5000 898	1960	0.403	9998.441
14:24.49	500000.75	500000.75	5000.898	5000.898	1960	0.403	9998.441
14.29:49	500000.75	500000.75	5000.898	5000.898	1960	0.403	9998.441
14:31:29	500000 75	500000.75	5000.898	5000.898	1960	0.403	9998.441

2000 EVEX Section 7.2.4

	620' CNTMT CRD HCU West D21-K042 MR/HR	642' CNTMT RWCU FL DRN D21-K052 MR/HR	690' CNTMT UP POOLS D21-K072 MR/HR	690' CNTMT, UP POOLS D21-K083 MR/HR	577' TB, HTWL PMP AREA D21-K182 MR/HR	605' TB, K21-K172 MR/HR	647' TB, West D21- K162 MR/HR	548' TPC, SUMP D21-K192 MR/HR
TIME	D21EA002	D21EA004	D21EA003	D21EA006	D21EA014	D21EA016	D21EA013	D21EA015
6 54 59	2 223	5 045	3	1 923	0.3	0.2	0.4	101.7
6 59 59	2 222	5 044	3	1 923	0.3	0.2	0.4	101.673
7.04:59	2.223	5 046	3	1.923	0.3	0.2	0.4	101.81
7 09-59	2 223	5 046	3	1.923	0.3	02	0.4	101 733
7 14 59	2 222	5 044	3	1.923	0.3	0.2	0.4	101 621
7 19.59	2 363	4 778	3	1.886	0.3	0.2	0.4	92 82
7 24 58	2.804	4 767	3	1 884	0.3	0.2	0.4	92 447
7 29 58	3.1	4 763	3	1 884	0.3	0.2	0.4	92 347
7 34:58	3.1	4.763	3	1 884	0.3	0.2	0.4	92 266
7.39.58	3.1	4 755	3	1.883	0.3	0.2	0.4	92.08
7 44:58	3.1	4 75	3	1 882	0.3	02	0.4	91 952
7 49 58	3.1	4 746	3	1 881	03	0.2	0.4	91.714
7.54:58	3 1	4.743	3	1 881	0.3	0.2	0.4	91.614
7 59 58	3.1	4 738	3	1.88	0.3	0.2	0.4	91 417
8 04 58	3.1	4.736	3	1.88	0.3	0.2	0.4	91.338
8 09.58	3.1	4 733	3	1.88	0.3	0.2	0.4	91 227
8 14:58	3.1	4.729 /	3	1 879	0.3	02	0.4	91 132
8:19:58	3 1	4.726	3	1 879	0.3	0.2	0.4	91 013
8:24:58	3.1	4 725	3	1 878	0.3	0.2	0.4	91.1
8.29.58	3.1	4 72	3	1 878	0.3	02	0.4	90 854
8:34:58	3.1	4.72	3	1.878	0.3	02	0.4	90 88
8 39:58	3.1	4.716	3	1.877	0.3	0.2	0.4	90.701
8:44:58	3.1	4.714	. 3.	1.877	0.3	02	0.4	90.647
8.49.58	3.1	4.712	3	1.877	0.3	0.2	0.4	90.632
8:54:58	3.1	4.712	3	1.877	0.3	0.2	0.4	90.612
8:59:58	3.1	4.708	3	1.876	0.3	0.2	0.4	90 379
9:04:58	3.1	4.706	3	1.876	0.3	0.2	0.4	90.444
9:09:58	31	4 703	3	1 875	0.3	02	04	90.37
914:57	3.1	4 701	3	1.875	0.3	0.2	0.4	90 272
9 19:57	3.1	4.697	3	1.875	0.3	0.2	0.4	90.159
9.24.57	3.1	4.697	3	1 875	0.3	0.2	0.4	90.113
9 29 57	3.1	4.696	3	1.874	0.3	02	0.4	90 095
9 34 57	3.1	4.695	3	1 874	0.3	0.2	0.4	89.966
9:39:57	3.1	4 694	3	1.874	0.3	02	0.4	90 029
9:44.57	3.1	4.694	3	1 874	0.3	02	0.4	90 037
9:49:57	3.1	4.69	3	1.874	03	0.2	0.4	89 804
9:54:57	3.1	4.689	3	1.873	0.3	0.2	0.4	89 896
9.59.57	3.1	4.687	3	1.873	0.3	0.2	0.4	89.81
10:04:57	3.1	4 686	3	1.873	0.3	0.2	0.4	89.713
10.09.57	3.1	4.684	3	1.873	0.3	0.2	0.4	89 597
10 14:57	3.1 3.1	4.683	3	1.873	0.3	0.2	0.4	89.711
10.19.57	3.1	4.684 4.682	3 3	1 873	0.3	0.2	0.4	89.708
10:24:56	3.1	4.683		1 872	0.3	0.2	0.4	89.618
10:29:57	3.1	4.682	3 3	1.873	0.3	0.2	0.4	89.718
10:34:57 10:39:57	3.1 3.1	4.681	3	1.873	0.3	0.2	0.4	89.554
	3.1 3.1	2 186	3	1.872	0.3	0.2	0.4	89.503
10.49:51				1.526	0.3	0.2	0.4	6.382
10.54:51	3.1	2.099	3	1.514	0.3	0.2	0.4	3.567
10.59.51	3.1 3.1	2.076 2.065	3 3	1.511	0.3	0.2	0.4	2 733
11:04:51	3.1 3.1	2.065 3.109	3	1.509	0.3	0.2	04	2.302
11:09:51	3.1	3, 109	3	1.509	21.702	43.127	43.326	91.797

	COO' CHITME ODD HOU	0.00 0.000		690' CNTMT, UP	577' TB, HTWL PMP			
	620' CNTMT CRD HCU West D21-K042 MR/HR	642' CNTMT RWCU FL DRN		POOLS D21-KO83	AREA D21-K182	605' TB, K21-K172	647' TB, West D21-	548' TPC, SUMP
TIME	D21EA002	D21-K052 MR/HR	D21-K072 MR/HR	MR/HR	MR/HR	MR/HR	K162 MR/HR	D21-K192 MR/HR
11 14:51	31	D21EA004 3.392	D21EA003	D21EA006	D21EA014	D21EA016	D21EA013	D21EA015
11:19.51	31	3.392	3	1.508	54.998	109.806	109.883	95.282
11 24:51	31		3	1.508	88.411	176.745	176.699	98.781
11:29:51	31	3.439	3	1 508	100.099	200.098	200.098	100.099
11:34.51	31	2.955	3	1.506	100.099	200.098	200 098	100 099
11:39:50	31	2.976	3	1.508	100.099	200.098	200.098	100.099
11:44:51	31	2.799	3	1.507	100.099	200.098	200.098	100.099
11:49.50	31	3.16	3	1.772	100 099	200.098	200.098	100.099
11:54:50	3.1	2.948	3	1 986	100.099	200.098	200.098	100.099
11:59:50	3.1 3.1	2.937	3	2.016	100 099	200.098	200.098	100.099
12.04 50		2 726	3	1.94	100 099	200.098	200.098	100.099
12.09.50	31	2.68	3	1 929	100.099	200.098	200 098	100.099
12:14:50	3 1	2.806	3 .	1 884	100.099	200.098	200.098	100.099
12:19:50	31	2.546	3	1 856	100.099	200.098	200 098	100.099
12:24:50	3 1	2.686	3	1.849	100.099	200.098	200.098	100.099
12:29:50	3.1 3.1	2.523	3	1.843	100.099	200.098	200.098	100.099
12:34:50	3 1 2394 826	2.484	3	1.838	100.099	200.098	200.098	100.099
12:39.50		2462 441	2424.927	2421.964	2442.838	2523.334	2527.811	2438.59
12:44:50	BAD DATA	BAD DATA	BAD DATA	BAD DATA	BAD DATA	BAD DATA	BAD DATA	BAD DATA
12:49:50	BAD DATA	BAD DATA	BAD DATA	BAD DATĄ	BAD DATA	BAD DATA	BAD DATA	BAD DATA
12:54:50	BAD DATA	BAD DATA	BAD DATA	BAD DATA	BAD DATA	BAD DATA	BAD DATA	BAD DATA
12:59:50	BAD DATA	BAD DATA	BAD DATA	BAD DATA	BAD DATA	BAD DATA	BAD DATA	BAD DATA
13:04:50	BAD DATA	BAD DATA	BAD DATA	BAD DATA	BAD DATA	BAD DATA	BAD DATA	BAD DATA
13:09:50	BAD DATA	BAD DATA	BAD DATA	BAD DATA	BAD DATA	BAD DATA	BAD DATA	BAD DATA
13:14:50	BAD DATA	BAD DATA	BAD DATA	BAD DATA	BAD DATA	BAD DATA	BAD DATA	BAD DATA
13:19.50	BAD DATA	BAD DATA	BAD DATA	BAD DATA	BAD DATA	BAD DATA	BAD DATA	BAD DATA
13:24:50	BAD DATA	BAD DATA	BAD DATA	BAD DATA	BAD DATA	BAD DATA	BAD DATA	BAD DATA
13.24.50	BAD DATA	BAD DATA	BAD DATA	BAD DATA	BAD DATA	BAD DATA	BAD DATA	BAD DATA
13:34:50	BAD DATA	BAD DATA	BAD DATA	BAD DATA	BAD DATA	BAD DATA	BAD DATA	BAD DATA
13:39:49	BAD DATA	BAD DATA	BAD DATA	BAD DATA	BAD DATA	BAD DATA	BAD DATA	BAD DATA
13:44:49	BAD DATA	BAD DATA	BAD DATA	BAD DATA	BAD DATA	BAD DATA	BAD DATA	BAD DATA
13:49:49	BAD DATA	BAD DATA	BAD DATA	BAD DATA	8784.078	8783.332	8782.586	8790.48
13:49:49	BAD DATA	BAD DATA	BAD DATA	BAD DATA	6110.09	6109.348	6108.602	6114.176
13:54:49	BAD DATA	BAD DATA	BAD DATA	BAD DATA	3418.968	3418.222	3417.478	3420.721
	BAD DATA	BAD DATA	BAD DATA	BAD DATA	2000.08	2000.08	2000.08	2000.08
14:04:49	BAD DATA	BAD DATA	BAD DATA	BAD DATA	2000.08	2000.08	2000.08	
14:09:49	BAD DATA	BAD DATA	BAD DATA	BAD DATA	2000.08	2000.08	2000 08	2000.08
14:14:49	BAD DATA	BAD DATA	BAD DATA	BAD DATA	2000.08	2000.08	2000.08	2000.08
14:19.49	BAD DATA	BAD DATA	BAD DATA	BAD DATA	2000.08	2000.08	2000.08	2000.08
14 24:49	BAD DATA	BAD DATA	BAD DATA	BAD DATA	2000.08	2000.08	2000.08	2000.08
14:29:49	BAD DATA	BAD DATA	BAD DATA	BAD DATA	2000.08	2000.08	2000.08	2000.08
14:31.29	BAD DATA	BAD DATA	BAD DATA	BAD DATA	2000.08	2000.08	2000.08	2000.08
						,	2000.08	2000 08

2000 PERRY EVA ATED EXERCISE

Table 7.2.4

	568' TPC, CNDS FLTR		602' OG, AFT FLTR		647' HB, FD PMP		620' FHB, SPNT FUEL
	PMP D21-K192 MR/HR	584' OG, D21-K202 MR/HR	AREA D21-K222	600' HB, HP FW HTR AREA	AREA D21-K242	599'IB, FPCC FL DRN	STG PL D21-K332
TIME	D21EA017	D21EA019	MR/HR D21EA020	D21-K232 MR/HR	MR/HR	D21-K312 MR/HR	MR/HR
6 54 59	0 521	021EA019 0 479	0.481	D21EA010	D21EA011	D21EA027	D21EA029
6 59 59	0 458	0 584		2.404	0.778	0.416	2 889
7 04 59	0 599	0.511	0.473	2.393	0.794	0.416	2.938
7 09 59	0 405	0.511	0.438	2.53	0.852	0.396	3.053
7 14.59	0.592	0 549	0.595 0.602	2.446	0.86	0.394	2.978
7 19 59	0.43	0 502	0.802	2.415	0.862	0.378	3 041
7 24 58	0.574	0 444	0.372	2.319	0.84	0.395	2.895
7 29 58	0.425	0 482	0.372	2 201 2 333	0.838	0.407	2.854
7 34.58	0.504	0 532	0.565		0.797	0.397	3.07
7.39.58	0.514	0.507	0.502	2.328	0.733	0.404	3.097
7 44 58	0.447	0.422	0.496	2.273 2.137	0.82	0.386	2.905
7:49:58	0.448	0.517	0.53	2.226	0.8	0.394	3.053
7 54.58	0.551	0.421	0.529	2.256	0.658	0.4	2.983
7 59 58	0.523	0 429	0.426	2.256	0.848	0.396	3.054
8 04 58	0.564	0 412	0.432	2.194	0.836 0.827	0.405	2.918
8 09 58	0.548	0.486	0.494	2.152	0.804	0.424	2.896
8 14:58	0.475	0.51	0.434	2 167	0.721	0.407 0.418	3.129
8 19 58	0.389	0.368	0.375	2.119	0.748	0.418	3.064
8.24.58	0.505	0.394	0.509	22	0.793	0.415	2.891
8:29.58	0.406	0 468	0.397	2 245	0.793	0.407	3.039
8.34.58	0.53	0 367	0.551	2 203	0.68	0 385	2.991
8:39:58	0.392	0.441	0.409	2.183	0.67	0.404	2.913 2.934
8 44 58	0.425	0.483	0.364	2.111	0.712	0.402	2.934 3.14
8 49.58	0.408	0.519	0.51	2.27	0.764	0.407	2.966
8 54 58	0.394	0.474	0.516	2 228	0.674	0.403	2.962
8 59 58	0.576	0.462	0.413	2.219	0.744	0.4	3.027
9 04:58	0.537	0.405	0.507	2.251	0.705	0.4	3.25
9.09:58	0.527	0.48	0.516	2.238	0.829	0.401	2.854
9:14:57	0.511	0.466	0.527	2.197	0.809	0.384	2.968
9 19 57	0.466	0.523	0.442	2.184	0.738	0.41	2.848
9 24 57	0.49	0.55	0.384	2.24	0.729	0.415	2.793
9 29:57	0.394	0.507	0.408	2.229	0.802	0.395	3.178
9 34 57	0.442	0.545	0.517	2.2	0.792	0.412	3.016
9.39:57	0.393	0 455	0.557	2.169	0.695	0.388	2.941
9:44:57	0.558	0 407	0.455	2.263	0.741	0.399	3.172
9:49:57	0.448	0.507	0.541	2.22	0.748	0.41	3.057
9.54.57	0.477	0.548	0.493	2.189	0.826	0.407	3.014
9.59.57	0.565	0 361	0.481	2.184	0.767	0.407	2.927
10:04:57	0.499	0.466	0.469	2.229	0.658	0.39	3.049
10.09:57	0.523	0.476	0.501	2.209	0.82	0.393	2.974
10:14:57	0.396	0.386	0 485	2.133	0.694	0.407	2.82
10 19 57	0.465	0.412	0.434	2.226	0.687	0.402	3.044
10:24:56	0.409	0.51	0.538	2.259	0.767	0.383	3.206
10.29:57	0.48	0.488	0.363	2.147	0.701	0.392	2.851
10.34:57	0.442	0.546	0.428	2.217	0.777	0.408	3.103
10.39:57 10.49.51	0.392	0.394	0.545	2.158	0.745	0.384	3.119
	0 247	0.142	0.123	0.451	0.22	0.394	2.914
10:54.51 10:59:51	0.216	0.129	BAD DATA	0.534	0.257	0.396	2.882
	0.315	BAD DATA	0.176	0.441	0 246	0.386	3.138
11:04:51 11:09:51	0.306 0.337	0.168	0 169	0.439	0.2	0.393	3 125
11.09.01	0 331	0.144	0.109	0.441	0.254	0.39	3.149

Table 7.2.4

KEY CONTROL ROOM ANNUNCIATOR SUMMARY

NEWLY RECEIVED

LOCKED IN

P601

-SLC A OUT OF SERVICE-

P800

-ANNUL EXH SYS TRAIN A OUT OF SERVICE-

2000 PERRY EVAL ATED EXERCISE 7.2.4 SIGNIFICANTSCONTROL ROOM ANNUNCIATORS

NEWLY RECEIVED

ACKNOWLEDGED/CLEARED

LOCKED IN

P680

<u>P601</u>

- SRV LEAKAGE P614 -

-SLC A OUT OF SERVICE-

P601

- SRV OPEN -

P800

-ANNUL EXH SYS TRAIN A OUT OF SERVICE-

2000 PERRY EVA ATED EXERCISE 7.2.4 SIGNIFICANTSCONTROL ROOM ANNUNCIATORS

NEWLY RECEIVED

ACKNOWLEDGED/CLEARED

LOCKED IN

P601

- RHR B OUT OF SERVICE -

and/or

- RHR A OUT OF SERVICE -

(depending on which pumps are aligned to SP

Cooling)

ADS A PERMISSIVE LPCS/RHR A RUN

ADS B PERMISSIVE RHR B/C RUN

P680

- SRV LEAKAGE P614 -

P601

-SLC A OUT OF SERVICE-

- SRV OPEN -

P800

-ANNUL EXH SYS TRAIN A OUT OF SERVICE-

LOCKED IN

P601

- RHR PUMP A TRIP -

- RHR PUMP A DISCHARGE PRESSURE HI/LO -

- AMB TEMP HIGH P632-

-RHR EQUIP AREA DIFF TEMP HIGH P632-

ADS B PERMISSIVE RHR B/C RUN

P680

- SRV LEAKAGE P614 -

P601

-SLC A OUT OF SERVICE-

- SRV OPEN -

- RHR A/B OUT OF SERVICE -

P800

-ANNUL EXH SYS TRAIN A OUT OF SERVICE-

LOCKED IN

P680

- INHIBIT ROD MOTION RCIS OOS -

-AMB TEMP HIGH P632-

- SRV LEAKAGE P614 -

P680

-RHR EQUIP AREA DIFF TEMP HIGH P632-

P601

-SLC A OUT OF SERVICE-

- SRV OPEN -

- RHR PUMP A TRIP -

- RHR A/B OUT OF SERVICE -

- RHR PUMP A DISCHARGE PRESSURE HI/LO -

P800

-ANNUL EXH SYS TRAIN A OUT OF SERVICE-

LOCKED IN

P680

P680

- SRV LEAKAGE P614 -

- INHIBIT ROD MOTION RCIS OOS -

P601

P601

- SRV OPEN -

-SLC A OUT OF SERVICE-

- RHR PUMP A TRIP -

- RHR A/B OUT OF SERVICE -

- RHR PUMP A DISCHARGE PRESSURE HI/LO -

P800

-ANNUL EXH SYS TRAIN A OUT OF SERVICE-

LOCKED IN

P680

- SRV LEAKAGE P614 -

P680

- INHIBIT ROD MOTION RCIS OOS -

<u>P601</u>

- SRV OPEN -

P601

-SLC A OUT OF SERVICE-

- RHR PUMP A TRIP -

- RHR A/B OUT OF SERVICE -

- RHR PUMP A DISCHARGE PRESSURE HI/LO -

P800

-ANNUL EXH SYS TRAIN A OUT OF SERVICE-

P680

- ANN PWR SUPPLY FAIL -

TIME: 0920

LOCKED IN

2000 PERRY EVA. ATED EXERCISE 7.2.4 SIGNIFICANTSCONTROL ROOM ANNUNCIATORS

NEWLY RECEIVED ACKNOWLEDGED/CLEARED

LOCKED IN

P601

- ANN PWR SUPPLY FAIL -

P601

- ADS A AIR STRG TANK PRES HI/LO -

P680

-SLC A OUT OF SERVICE-

- SRV LEAKAGE P614 -

- RHR PUMP A TRIP -

P870

- RHR PUMP A DISCHARGE PRESSURE HI/LO -

-BUS LIT BREAKER TRIP

- RHR B OUT OF SERVICE -

P800

BUS L12 BREAKER TRIP

P601

-ANNUL EXH SYS TRAIN A OUT OF SERVICE-

P680

- SRV OPEN -

TIME: 1030

COM AREA & PRCS RAD P906

2000 PERRY EVAL ATED EXERCISE 7.2.4 SIGNIFICANTSCONTROL ROOM ANNUNCIATORS

NEWLY RECEIVED

ACKNOWLEDGED/CLEARED

LOCKED IN

P870

- PARALLEL IA HEADER PRESSURE LOW -

P680

- SCRAM VLV AIR HEADER PRESS LO -

P601

-SLC A OUT OF SERVICE-

- ADS A AIR STRG TANK PRES HI/LO -

- RHR PUMP A TRIP -

- RHR PUMP A DISCHARGE PRESSURE HI/LO -

P800

-ANNUL EXH SYS TRAIN A OUT OF SERVICE-

TIME: 1046

P680

P680

LOCKED IN

[Status light for SDV Drain Valve, 1C11-F011, indicates closed.]

- SCRAM VLV AIR HEADER PRESS LO -

P601

-SLC A OUT OF SERVICE-

- ADS A AIR STRG TANK PRES HI/LO -

- RHR PUMP A TRIP -

- RHR PUMP A DISCHARGE PRESSURE HI/LO -

P870

- PARALLEL IA HEADER PRESSURE LOW -

- SERVICE AIR HEADER PRESSURE LOW -

P800

-ANNUL EXH SYS TRAIN A OUT OF SERVICE-

TIME: 1048

2000 PERRY EVA. ATED EXERCISE 7.2.4 SIGNIFICANTSCONTROL ROOM ANNUNCIATORS

NEWLY RECEIVED

ACKNOWLEDGED/CLEARED

LOCKED IN

P680

- INST VOL NOT DRAINED -

[Status lights for SDV Drain Valves, 1C11-F011 & -F181, and SDV Vent Valves, 1C11-F010 & -F180, indicate closed.]

P680

- SCRAM VLV AIR HEADER PRESS LO -

P601

-SLC A OUT OF SERVICE-

- ADS A AIR STRG TANK PRES HI/LO -

- RHR PUMP A TRIP -

- RHR PUMP A DISCHARGE PRESSURE HI/LO -

P870

- PARALLEL IA HEADER PRESSURE LOW -

- SERVICE AIR HEADER PRESSURE LOW -

P800

-ANNUL EXH SYS TRAIN A OUT OF SERVICE-

TIME: 1049 >

LOCKED IN

P680

P870

P680

-RPS MANUAL SCRAM-

-PARALLEL IA HEADER PRESSURE LOW-

-SCRAM VLV AIR HEADER PRESS LO-

-RRCS MANUAL ARI-

-SERVICE AIR HEADER PRESSURE LOW-

-INST VOL NOT DRAINED-

P601

-RPS RX PRESS HI-

-RPS RX LEVEL LO L3-

-SLC A OUT OF SERVICE-

-FULL SCRAM-

-ADS A AIR STRG TANK PRES HI/LO-

-ADS B AIR STRG TANK PRESS HI/LO-

P601

-MSIV CLOSE SIGNAL RECEIVED-

-SRV OPEN SIGNAL RECEIVED-

-SRV OPEN-

-ADS A PERMISSIVE RX LEVEL 3-

-ADS B PERMISSIVE RX LEVEL 3-

-RHR PUMP A DISCHARGE PRESSURE HI/LO-

-RHR PUMP A TRIP-

P800

-ANNUL EXH SYS TRAIN A OUT OF SERVICE-

TIME: 1051

NEWLY RECEIVED

ACKNOWLEDGED/CLEARED LOCKED IN

P680

- RRCS RX LEVEL LO L2 -

P870

- PARALLEL IA HEADER PRESSURE LOW -

- RPS MANUAL SCRAM --RRCS MANUAL ARI -

P601

- SERVICE AIR HEADER PRESSURE LOW -

- RPS RX PRESS HI -

P680

- BOP ISOL RX LEVEL L0 L2 -

- HPCS RX LEVEL LO L2 -

- HPCS PUMP START SIGNAL RECEIVED -

- RCIC START SIGNAL RECEIVED -

-RPS RX LEVEL LO L3 -

- ADS A PERMISSIVE RX LEVEL 3 -

- ADS B PERMISSIVE RX LEVEL 3 -

- SCRAM VLV AIR HEADER PRESS LO -

- INST VOL NOT DRAINED -

P601

-MSIV CLOSE SIGNAL RECEIVED -

-SRV OPEN SIGNAL RECEIVED -

- SRV OPEN -

-SLC A OUT OF SERVICE-

TIME: 1053 (SHEET 1 0F 2)

LOCKED IN

P601 (Cont'd)

- ADS A AIR STRG TANK PRES HI/LO -

- RHR PUMP A TRIP -

- RHR PUMP A DISCHARGE PRESSURE HI/LO -

P800

-ANNUL EXH SYS TRAIN A OUT OF SERVICE-

TIME: 1053

LOCKED IN

n	•	n

- SLC B OUT OF SERVICE -

[Status lights: o SQUIB B OR PWR LOSS

o PUMP OR MOV OVLD OR PWR

LOSS

o Pump breaker lights for 1C41-C001B extinguished]

Continuity light for C42-C004B extinguished

P680

- RPS RX PRESS HI -

-RPS RX LEVEL LO L3 -

- ADS A PERMISSIVE RX LEVEL 3 -

- ADS B PERMISSIVE RX LEVEL 3 -

- RRCS RX LEVEL LO L2 -

P680

- RPS MANUAL SCRAM -

-RRCS MANUAL ARI -

- SCRAM VLV AIR HEADER PRESS LO -

- INST VOL NOT DRAINED -

P601

- RCIC START SIGNAL RECEIVED -

-MSIV CLOSE SIGNAL RECEIVED -

-SLC A OUT OF SERVICE-

- ADS A AIR STRG TANK PRES HI/LO -

- RHR PUMP A TRIP -

- RHR PUMP A DISCHARGE PRESSURE HI/LO -

P800

-ANNUL EXH SYS TRAIN A OUT OF SERVICE-

TIME: 1055

P601

- BOP ISOL RX LEVEL L0 L2 -

- HPCS RX LEVEL LO L2 -

- HPCS PUMP START SIGNAL RECEIVED -

-SRV OPEN SIGNAL RECEIVED -

SRV OPEN -

P870

- PARALLEL IA HEADER PRESSURE LOW -

- SERVICE AIR HEADER PRESSURE LOW -

2000 PERRY EVALUATED EXERCISE 7.2.4 SIGNIFICANTSCONTROL ROOM ANNUNCIATORS ACKNOWLEDGE OF THE PROPERTY OF THE P

NEWLY RECEIVED

ACKNOWLEDGED/CLEARED

LOCKED IN

P680

- RPS RX PRESS HI -

P680

- RPS MANUAL SCRAM -

-RRCS MANUAL ARI -

- SCRAM VLV AIR HEADER PRESS LO -

- INST VOL NOT DRAINED -

P601

-SRV OPEN SIGNAL RECEIVED -

-SRV LOGIC RX PRESSURE HIGH

P601

- RCIC START SIGNAL RECEIVED -

-MSIV CLOSE SIGNAL RECEIVED -

-SLC A OUT OF SERVICE-

- SLC B OUT OF SERVICE -

- ADS A AIR STRG TANK PRES HI/LO -

- RHR PUMP A TRIP -

- RHR PUMP A DISCHARGE PRESSURE HI/LO -

P800

-ANNUL EXH SYS TRAIN A OUT OF SERVICE-TIME: 1058

NEWLY RECEIVED

LOCKED IN

P680

- RRCS RX LEVEL LO L2 -

P601

- SRV OPEN -

- BOP ISOL RX LEVEL LO L2 -

- HPCS RX LEVEL LO L2 -

P680

- RPS RX PRESS HI -

- RPS MANUAL SCRAM -

-RRCS MANUAL ARI -

- SCRAM VLV AIR HEADER PRESS LO -

· - INST VOL NOT DRAINED -

P601

-SRV OPEN SIGNAL RECEIVED -

- RCIC START SIGNAL RECEIVED -

-MSIV CLOSE SIGNAL RECEIVED -

-SLC A OUT OF SERVICE-

- SLC B OUT OF SERVICE -

- ADS A AIR STRG TANK PRES HI/LO -

TIME: 1100 (SHEET 1 OF 2)

LOCKED IN

P601 (Cont'd)

- RHR PUMP A TRIP -

- RHR PUMP A DISCHARGE PRESSURE HI/LO -

P800

-ANNUL EXH SYS TRAIN A OUT OF SERVICE-

TIME: 1100 (SHEET 2 OF 2)

NEWLY RECEIVED

LOCKED IN

P680

P680

P680

- EMG ROOM TEMP TRBL -

- RPS RX PRESS HI -

- RRCS RX LEVEL LO L2 -

- RPS MANUAL SCRAM -

-RRCS MANUAL ARI -

- SCRAM VLV AIR HEADER PRESS LO -

- INST VOL NOT DRAINED -

P601

- BOP ISOL RX LEVEL I.O L2 -

- HPCS RX LEVEL LO L2 -

- RCIC START SIGNAL RECEIVED -

-MSIV CLOSE SIGNAL RECEIVED -

-SLC A OUT OF SERVICE-

- SLC B OUT OF SERVICE -

- ADS A AIR STRG TANK PRES HI/LO -

TIME: 1105 (SHEET 1 OF 2)

LOCKED IN

P601 (Cont'd)

- RHR PUMP A TRIP -

- RHR PUMP A DISCHARGE PRESSURE HI/LO -

P800

-ANNUL EXH SYS TRAIN A OUT OF SERVICE-

TIME: 1105 (SHEET 2 OF 2)

2000 PERRY EVALUATED EXERCISE 7.2.4 SIGNIFICANTSCONTROL ROOM ANNUNCIATORS

NEWLY RECEIVED

ACKNOWLEDGED/CLEARED

LOCKED IN

P680

- RPS RX PRESS HI -

- AIRBORNE RAD P804 -

P601

-SRV OPEN SIGNAL RECEIVED -

- STEAM TUNNEL LD AMB TEMP P632 -

- STEAM TUNNEL LD DIFF TEMP P632 -

-TURBINE POWER COMPLEX TEMP HIGH -

[Position indication lights on 1E51-F064 are extinguished.]

RCIC ISOL TIMER RUNNING ST TNL TEMP HI

P680

- EMG ROOM TEMP TRBL -

- RRCS RX LEVEL LO L2 -

- RPS MANUAL SCRAM -

-RRCS MANUAL ARI -

- SCRAM VLV AIR HEADER PRESS LO -

- INST VOL NOT DRAINED -

P601

- BOP ISOL RX LEVEL LO L2 -

- HPCS RX LEVEL LO L2 -

- RCIC START SIGNAL RECEIVED -

-MSIV CLOSE SIGNAL RECEIVED -

-SLC A OUT OF SERVICE-

- SLC B OUT OF SERVICE -

TIME: 1108 (SHEET 1 OF 2)

LOCKED IN

P601 (Cont'd)
- ADS A AIR STRG TANK PRES HI/LO -

- RHR PUMP A TRIP -

- RHR PUMP A DISCHARGE PRESSURE HI/LO -

P800

-ANNUL EXH SYS TRAIN A OUT OF SERVICE-

TIME: 1108 (SHEET 2 OF 2)

NEWLY RECEIVED

LOCKED IN

P601

- SRV OPEN -

-RCIC ISOL STEAM TUNNEL HIGH -

[Position indication lights on 1E51-F063 & -F064 are extinguished.]

P680

- RPS RX PRESS HI -

-RRCS RX LEVEL LO L2 -

- EMG ROOM TEMP TRBL -

. - RPS MANUAL SCRAM -.

-RRCS MANUAL ARI -

- SCRAM VLV AIR HEADER PRESS LO-

- INST VOL NOT DRAINED -

- AIRBORNE RAD P804 -

P601

-SRV OPEN SIGNAL RECEIVED -

- STEAM TUNNEL LD AMB TEMP P632 -

- STEAM TUNNEL LD DIFF TEMP P632 -

-TURBINE POWER COMPLEX TEMP HIGH -

TIME: 1110 (SHEET 1 OF 2)

LOCKED IN

P601 (Cont'd)

- BOP ISOL RX LEVEL LO L2 -

- HPCS RX LEVEL LO L2 -

-MSIV CLOSE SIGNAL RECEIVED -

-SLC A OUT OF SERVICE-

- SLC B OUT OF SERVICE -

- ADS A AIR STRG TANK PRES HI/LO -

- RHR PUMP A TRIP -

- RHR PUMP A DISCHARGE PRESSURE HI/LO -

P800

-ANNUL EXH SYS TRAIN A OUT OF SERVICE-

TIME: 1110 (SHEET 2 OF 2)

2000 PERRY EVALUATED EXERCISE 7.2.4 SIGNIFICANTSCONTROL ROOM ANNUNCIATORS <u>ACKNOWLEDGED/CLEARED</u>

NEWLY RECEIVED

LOCKED IN

P680

- MFP TRIP -

-MFP DC OIL PUMP START PRESS LO-

P680

- EMG ROOM TEMP TRBL -

- RRCS RX LEVEL LO L2 -

- RPS MANUAL SCRAM -

-RRCS MANUAL ARI -

- SCRAM VLV AIR HEADER PRESS LO -

- INST VOL NOT DRAINED -

- AIRBORNE RAD P804 -

P601

- RCIC ISOL STEAM FLOW HIGH -

-RCIC ISOL STEAM TUNNEL HIGH -

- NS4 INBD ISOLATION OUT OF SERVICE -

- STEAM TUNNEL LD AMB TEMP P632 -

- STEAM TUNNEL LD DIFF TEMP P632 -

TIME: 1225 (SHEET 1 OF 2)

LOCKED IN

P601 (Cont'd)

-TURBINE POWER COMPLEX TEMP HIGH -

- BOP ISOL RX LEVEL LO L2 -

- HPCS RX LEVEL LO L2 -

-MSIV CLOSE SIGNAL RECEIVED -

-SLC A OUT OF SERVICE-

- SLC B OUT OF SERVICE -

- ADS A AIR STRG TANK PRES HI/LO -

- RHR PUMP A TRIP -

- RHR PUMP A DISCHARGE PRESSURE HI/LO -

P800

-ANNUL EXH SYS TRAIN A OUT OF SERVICE-TIME: 1225 (SHEET 2 OF 2)

2000 PERRY EVALUATED EXERCISE 7.2.4 SIGNIFICANTSCONTROL ROOM ANNUNCIATORS

NEWLY RECEIVED

ACKNOWLEDGED/CLEARED

P601

- MSL ISOL RX LEVEL LO L1 -

- ADS B OPEN SIGNAL RECEIVED -
- LPCI A START SIGNAL RECEIVED -
- LPCI B&C START SIGNAL RECEIVED -

LOCKED IN

P680

- MFP TRIP -

-MFP DC OIL PUMP START PRESS LO-

- EMG ROOM TEMP TRBL -

- RRCS RX LEVEL LO L2 -

- RPS MANUAL SCRAM -

-RRCS MANUAL ARI -

- SCRAM VLV AIR HEADER PRESS LO -

- INST VOL NOT DRAINED -

- AIRBORNE RAD P804 -

P601

- RCIC ISOL STEAM FLOW HIGH -

-RCIC ISOL STEAM TUNNEL HIGH -

- NS4 INBD ISOLATION OUT OF SERVICE -

- STEAM TUNNEL LD AMB TEMP P632 -

TIME: 1230 (SHEET 1 OF 3)

NEWLY RECEIVED

LOCKED IN

P601 (Cont'd)

- STEAM TUNNEL LD DIFF TEMP P632 -

-TURBINE POWER COMPLEX TEMP HIGH -

- BOP ISOL RX LEVEL LO L2 -

- HPCS RX LEVEL LO L2 -

-MSIV CLOSE SIGNAL RECEIVED -

-SLC A OUT OF SERVICE-

- SLC B OUT OF SERVICE -

- ADS A AIR STRG TANK PRES HI/LO -

- RHR PUMP A TRIP -

- RHR PUMP A DISCHARGE PRESSURE HI/LO -

P800

-ANNUL EXH SYS TRAIN A OUT OF SERVICE-

TIME: 1230 (SHEET 2 OF 3)

LOCKED IN

P680

- -MFP DC OIL PUMP START PRESS LO-
 - EMG ROOM TEMP TRBL -
 - RRCS RX LEVEL LO L2 -
 - RPS MANUAL SCRAM -
 - -RRCS MANUAL ARI -
- SCRAM VLV AIR HEADER PRESS LO -
 - INST VOL NOT DRAINED -
 - AIRBORNE RAD P804 -

P601

- MSL ISOL RX LEVEL LO L1 -
- ADS B OPEN SIGNAL RECEIVED -
- LPCI A START SIGNAL RECEIVED -
- LPCI B&C START SIGNAL RECEIVED -

TIME: 1235 (SHEET 1 OF 3)

LOCKED IN

P601 (Cont'd)

- RCIC ISOL STEAM FLOW HIGH -
- -RCIC ISOL STEAM TUNNEL HIGH -
- NS4 INBD ISOLATION OUT OF SERVICE -
- STEAM TUNNEL LD AMB TEMP P632 -
- STEAM TUNNEL LD DIFF TEMP P632 -
- -TURBINE POWER COMPLEX TEMP HIGH -
 - BOP ISOL RX LEVEL LO L2 -
 - HPCS RX LEVEL LO L2 -
 - -MSIV CLOSE SIGNAL RECEIVED -
 - -SLC A OUT OF SERVICE-
 - SLC B OUT OF SERVICE -
 - ADS A AIR STRG TANK PRES HI/LO -
- RHR PUMP A DISCHARGE PRESSURE HI/LO -

P800

-ANNUL EXH SYS TRAIN A OUT OF SERVICE-TIME: 1235 (SHEET 2 OF 3)

NEWLY RECEIVED

LOCKED IN

P601

<u>P601</u>

P680

- HPCS PUMP START SIGNAL RECEIVED -
- MSL ISOL RX LEVEL LO L1 -

-MFP DC OIL PUMP START PRESS LO-

- HPCS MAN INITIATION SWITCH ARMED -

- EMG ROOM TEMP TRBL -

-HPCS SUPR POOL SUCT VLV OPEN CST/SUPR PL LVL -

- RRCS RX LEVEL LO L2 - RPS MANUAL SCRAM -
 - -RRCS MANUAL ARI -
- SCRAM VLV AIR HEADER PRESS LO -
 - INST VOL NOT DRAINED -
 - AIRBORNE RAD P804 -

P601

- ADS B OPEN SIGNAL RECEIVED -
- LPCI A START SIGNAL RECEIVED -
- LPCI B&C START SIGNAL RECEIVED -
 - RCIC ISOL STEAM FLOW HIGH -

TIME: 1240 (SHEET 1 OF 3)

LOCKED IN

P601 (Cont'd)

- HPCS RX LEVEL LO L2 -

-RCIC ISOL STEAM TUNNEL HIGH -

- NS4 INBD ISOLATION OUT OF SERVICE -

- STEAM TUNNEL LD AMB TEMP P632 -

- STEAM TUNNEL LD DIFF TEMP P632 -

-TURBINE POWER COMPLEX TEMP HIGH -

- BOP ISOL RX LEVEL LO L2 -

- HPCS RX LEVEL LO L2 -

-MSIV CLOSE SIGNAL RECEIVED -

-SLC A OUT OF SERVICE-

- SLC B OUT OF SERVICE -

- ADS A AIR STRG TANK PRES HI/LO -

- RHR PUMP A DISCHARGE PRESSURE HI/LO -

P800

-ANNUL EXH SYS TRAIN A OUT OF SERVICE-

TIME: 1240 (SHEET 2 OF 3)

LOCKED IN

P601

<u>P680</u>

- SLC B OUT OF SERVICE -

-MFP DC OIL PUMP START PRESS LO-

- HPCS MAN INITIATION SWITCH ARMED -

- EMG ROOM TEMP TRBL -

-HPCS SUPR POOL SUCT VLV OPEN CST/SUPR PL LVL -

- RRCS RX LEVEL LO L2 -

LVL-

- RPS MANUAL SCRAM -

-RRCS MANUAL ARI -

- SCRAM VLV AIR HEADER PRESS LO-

- INST VOL NOT DRAINED -

- AIRBORNE RAD P804 -

P601

- HPCS PUMP START SIGNAL RECEIVED -

- ADS B OPEN SIGNAL RECEIVED -

- LPCI A START SIGNAL RECEIVED -

- LPCI B&C START SIGNAL RECEIVED -

TIME: 1320 (SHEET 1 OF 3)

LOCKED IN

P601 (Cont'd)

- RCIC ISOL STEAM FLOW HIGH -
 - HPCS RX LEVEL LO L2 -
- -RCIC ISOL STEAM TUNNEL HIGH -
- NS4 INBD ISOLATION OUT OF SERVICE -
- STEAM TUNNEL LD AMB TEMP P632 -
- STEAM TUNNEL LD DIFF TEMP P632 -
- -TURBINE POWER COMPLEX TEMP HIGH -
 - BOP ISOL RX LEVEL LO L2 -
 - HPCS RX LEVEL LO L2 -
 - -MSIV CLOSE SIGNAL RECEIVED -
 - -SLC A OUT OF SERVICE-
 - ADS A AIR STRG TANK PRES HI/LO -
- RHR PUMP A DISCHARGE PRESSURE HI/LO -

P800

-ANNUL EXH SYS TRAIN A OUT OF SERVICE-TIME: 1320 (SHEET 2 OF 3)

2000 PERRY EVALUATED EXERCISE 7.2.4 SIGNIFICANTSCONTROL ROOM ANNUNCIATORS

NEWLY RECEIVED

ACKNOWLEDGED/CLEARED

LOCKED IN

P601

-SRV OPEN -

P680

-MFP DC OIL PUMP START PRESS LO-

- EMG ROOM TEMP TRBL -

- RRCS RX LEVEL LO L2 -

- RPS MANUAL SCRAM -

-RRCS MANUAL ARI -

- SCRAM VLV AIR HEADER PRESS LO -

- INST VOL NOT DRAINED -

- AIRBORNE RAD P804 -

P601

- HPCS PUMP START SIGNAL RECEIVED -

- ADS B OPEN SIGNAL RECEIVED -

- LPCI A START SIGNAL RECEIVED -

- LPCI B&C START SIGNAL RECEIVED -

TIME: 1340 (SHEET 1 OF 3)

LOCKED IN

P601 (Cont'd)

- RCIC ISOL STEAM FLOW HIGH -
 - HPCS RX LEVEL LO L2 -
- -RCIC ISOL STEAM TUNNEL HIGH -
- NS4 INBD ISOLATION OUT OF SERVICE -
- STEAM TUNNEL LD AMB TEMP P632 -
- STEAM TUNNEL LD DIFF TEMP P632 -
- -TURBINE POWER COMPLEX TEMP HIGH -
 - BOP ISOL RX LEVEL LO L2 -
 - HPCS RX LEVEL LO L2 -
 - -MSIV CLOSE SIGNAL RECEIVED -
 - -SLC A OUT OF SERVICE-
 - ADS A AIR STRG TANK PRES HI/LO -
- RHR PUMP A DISCHARGE PRESSURE HI/LO -

P800

-ANNUL EXH SYS TRAIN A OUT OF SERVICE-

TIME: 1340 (SHEET 2 OF 3)

LOCKED IN

P680

- EMG ROOM TEMP TRBL -

- RRCS RX LEVEL LO L2 -

P601

-RCIC ISOL STEAM TUNNEL HIGH -

- NS4 INBD ISOLATION OUT OF SERVICE -

- STEAM TUNNEL LD AMB TEMP P632 -

- STEAM TUNNEL LD DIFF TEMP P632 -

-TURBINE POWER COMPLEX TEMP HIGH -

- RPS MANUAL SCRAM -

-MFP DC OIL PUMP START PRESS LO-

P680

-RRCS MANUAL ARI -

- SCRAM VLV AIR HEADER PRESS LO -

- INST VOL NOT DRAINED -

- AIRBORNE RAD P804 -

P601

-SRV OPEN -

- HPCS PUMP START SIGNAL RECEIVED -

- ADS B OPEN SIGNAL RECEIVED -

- LPCI A START SIGNAL RECEIVED -

- LPCI B&C START SIGNAL RECEIVED -

TIME: 1350 (SHEET 1 OF 2)

LOCKED IN

P601 (Cont'd)

- HPCS RX LEVEL LO L2 -

- BOP ISOL RX LEVEL LO L2 -

- HPCS RX LEVEL LO L2 -

-MSIV CLOSE SIGNAL RECEIVED -

-SLC A OUT OF SERVICE-

- ADS A AIR STRG TANK PRES HI/LO -

- RHR PUMP A DISCHARGE PRESSURE HI/LO -

P800

-ANNUL EXH SYS TRAIN A OUT OF SERVICE-

TIME: 1350 (SHEET 2 OF 2)

NEWLY RECEIVED

LOCKED IN

P680

P680

- AIRBORNE RAD P804 -

-MFP DC OIL PUMP START PRESS LO-

- RRCS RX LEVEL LO L2 -

- RPS MANUAL SCRAM -

-RRCS MANUAL ARI -

- SCRAM VLV AIR HEADER PRESS LO -

- INST VOL NOT DRAINED -

P601

- SRV OPEN -

- HPCS PUMP START SIGNAL RECEIVED -

- ADS B OPEN SIGNAL RECEIVED -

- LPCI A START SIGNAL RECEIVED -

- LPCI B&C START SIGNAL RECEIVED -

- HPCS RX LEVEL LO L2 -

TIME: 1400 (SHEET 1 OF 2)

LOCKED IN

P601 (Cont'd)

- BOP ISOL RX LEVEL LO L2 -

- HPCS RX LEVEL LO L2 -

-MSIV CLOSE SIGNAL RECEIVED -

-SLC A OUT OF SERVICE-

- ADS A AIR STRG TANK PRES HI/LO -

- RHR PUMP A DISCHARGE PRESSURE HI/LO -

P800

-ANNUL EXH SYS TRAIN A OUT OF SERVICE-

TIME: 1400 (SHEET 2 OF 2)

SECTION 7.3

EP INFO LINE DATABASE

2000 PERRY EVALUATED EXERCISE 7.3 EP INFO LINE DATABASE

TABLE 7.3

PLANT, METEOROLOGICAL AND VENT DATA FOR EP INFO LINE

DATE		WIND SPD-MPH	DELTA TEMP	WIND <u>DIR (FROM)</u>	STAB CLASS	UNIT I	VENT <u>CFM</u>	UNIT 2	VENT <u>CFM</u>	OG VEN	T <u>CFM</u>	TB <u>ACT</u>	VENT <u>CFM</u>	<u>(%)</u>	PWR <u>LVL</u>	RPV PRESS	RPV CNTM	MT
3/21/00	730	3.0	2.0	295	F	6.8E+01 L-NCPM	9.0E+04	6.0E+01 L-NCPM	6.0E+04	6.2E+01 L-NCPM	1.5E+04	9.5E+01 L-NCPM	1.7E+05	89	198	1007	0.0	
3/21/00	745	4.0	2.1	294	F	6.8E+01 L-NCPM	9.0E+04	6.0E+01 L-NCPM	6.0E+04	6.2E+01 L-NCPM	1.5E+04	9.5E+01 L-NCPM	1.7E+05	89	198	1007	0.0	
3/21/00	800	4.5	2.1	292	F	6.8E+01 L-NCPM	9.0E+04	6.0E+01 L-NCPM	6.0E+04	6.2E+01 L-NCPM	1.5E+04	9.5E+01 L-NCPM	1.7E+05	88	198	1007	0.0	
3/21/00	815	7.0	2.1	291	F	6.8E+01 L-NCPM	9.0E+04	6.0E+01 L-NCPM	6.0E+04	6.2E+01 L-NCPM	1.5E+04	9.5E+01 L-NCPM	1.7E+05	88	198	1007	0.0	
3/21/00	830	6.0	1.9	294	F	6.8E+01 L-NCPM	9.0E+04	6.0E+01 L-NCPM	6.0E+04	6.2E+01 L-NCPM	1.5E+04	9.5E+01 L-NCPM	1.7E+05	88	198	1007	0.0	
3/21/00	845	7.5	2.1	291	F	6.8E+01 L-NCPM	9.0E+04	6.0E+01 L-NCPM	6.0E+04	6.2E+01 L-NCPM	1.5E+04	9.5E+01 L-NCPM	1.7E+05	88	198	1006	0.0	
3/21/00	900	5.0	2.1	293	F	6.8E+01 L-NCPM	9.0E+04	6.0E+01 L-NCPM	6.0E+04	6.2E+01 L-NCPM	1.5E+04	9.5E+01 L-NCPM	1.7E+05	87	198	1006	0.0	
3/21/00	915	5.5	2.0	294	F	6.8E+01 L-NCPM	9.0E+04	6.0E+01 L-NCPM	6.0E+04	6.2E+01 L-NCPM	1.5E+04	9.5E+01 L-NCPM	1.7E+05	87	198	1006	0.0	
3/21/00	930	5.0	2.2	293	F	6.8E+01 L-NCPM	9.0E+04	6.0E+01 L-NCPM	6.0E+04	6.2E+01 L-NCPM	1.5E+04	9.5E+01 L-NCPM	1.7E+05	87	198	1005	0.0	
3/21/00	945	6.0	2.0	294	F	6.8E+01 L-NCPM	9.0E+04	6.0E+01 L-NCPM	6.0E+04	6.2E+01 . L-NCPM	1.5E+04	9.5E+01 L-NCPM	1.7E+05	87	198	1005	0.0	

2000 EVEX Section 7.3 Page 1 of 3

2000 PERRY EVALUATED EXERCISE 7.3 EP INFO LINE DATABASE

DATE	TIME WIND	DELTA WIND		VENT	UNIT 2 VENT	OG VENT	TB VENT	PWR		RPV CNTMT_
	SPD-MPH	TEMP DIR (FROM)	CLASS ACT	<u>CFM</u>	ACT CFM	<u>ACT</u> <u>CFM</u>	ACT CFM	(%) <u>LVL</u>	PRESS	PRESS
3/21/00	1000 6.5	2.0 291	F 6.8E+01 L-NCPM	9.0E+04	6.0E+01 6.0E+04 L-NCPM	6.2E+01 1.5E+04 L-NCPM	9.5E+01 1.7E+05 L-NCPM	87 198	1005	0.0
3/21/00	1015 5.5	1.8 295	F 6.8E+01 L-NCPM		6.0E+01 6.0E+04 L-NCPM	6.2E+01 1.5E+04 L-NCPM	9.5E+01 1.7E+05 L-NCPM	87 198	1005	0.0
3/21/00	1030 3.0	1.9 296	F 6.8E+01 L-NCPM	9.0E+04	6.0E+01 6.0E+04 L-NCPM	6.2E+01 1.5E+04 L-NCPM	9.5E+01 1.7E+05 L-NCPM	87 198	1005	0.0
3/21/00	1045 4.0	2.0 295	F 6.8E+01 L-NCPM	9.0E+04	6.0E+01 6.0E+04 L-NCPM	6.2E+01 1.5E+04 L-NCPM	9.5E+01 1.7E+05 L-NCPM	75 198	1005	0.0
3/21/00	1100 3.5	1.9 294	F 6.8E+01 L-NCPM	9.0E+04	6.0E+01 6.0E+04 L-NCPM	6.2E+01 1.5E+04 L-NCPM	9.5E+01 1.7E+05 L-NCPM	17 183	1070	0.5
3/21/00	1115 4.0	1.8 292	F 1.2E+03 L-NCPM	9.0E+04	6.0E+01 6.0E+04 L-NCPM	6.2E+01 1.5E+04 L-NCPM	5.0E+03 1.7E+05 L-NCPM	3 29	1152	0.7
3/21/00	1130 4.0	1.9 295	F 1.2E+03 L-NCPM	9.0E+04	6.0E+01 6.0E+04 L-NCPM	6.2E+01 1.5E+04 L-NCPM	5.0E+03 1.7E+05 L-NCPM	1 17	958	0.9
3/21/00	1145 5.5	1.8 294	F 1.2E+03 L-NCPM	9.0E+04	6.0E+01 6.0E+04 L-NCPM	6.2E+01 1.5E+04 L-NCPM	5.0E+03 1.7E+05 L-NCPM	1 13	950	0.9
3/21/00	1200 5.5	2.2 295	F 1.2E+03 L-NCPM	9.0E+04	6.0E+01 6.0E+04 L-NCPM	6.2E+01 1.5E+04 L-NCPM	5.0E+03 1.7E+05 L-NCPM	1 9	941	0.9
3/21/00	1215 5.0	2.2 293	F 1.2E+03 L-NCPM	9.0E+04	6.0E+01 6.0E+04 L-NCPM	6.2E+01 1.5E+04 L-NCPM	5.0E+03 1.7E+05 L-NCPM	1 4	932	1.0

2000 PERRY EVALUATED EXERCISE 7.3 EP INFO LINE DATABASE

TABLE 7.3 (Cont.)

PLANT, METEOROLOGICAL AND VENT DATA FOR EP INFO LINE

DATE	TIME	WIND SPD-MPH	DELTA TEMP D	WIND VIR (FROM)	STAB CLASS	UNIT I <u>ACT</u>	VENT <u>CFM</u>	UNIT 2 V <u>ACT</u>	VENT <u>CFM</u>	OG VEN <u>ACT</u>	T <u>CFM</u>	TB <u>ACT</u>	VENT <u>CFM</u>	<u>(%)</u>	PWR <u>LVL</u>	RPV <u>PRESS</u>	RPV CNTMT_ PRESS	
3/21/00	1230	4.5	2.1	294	F	1.2E+03 L-NCPM	9.0E+04	6.0E+01 L-NCPM	6.0E+04	6.2E+01 L-NCPM	1.5E+04	5.0E+03 L-NCPM	1.7E+05	0	-1	923	1.0	
3/21/00	1245	5.0	2.0	291	F	5.0E+03 L-NCPM	9.0E+04	6.0E+01 L-NCPM	6.0E+04	6.2E+01 L-NCPM	1.5E+04	2.0E+05 L-NCPM	1.7E+05	. 0	21	681	1.2	
3/21/00	1300	5.5	2.0	291	F	5.0E+03 L-NCPM	9.0E+04	6.0E+01 L-NCPM	6.0E+04	6.2E+01 L-NCPM	1.5E+04	2.0E+05 L-NCPM	1.7E+05	0	32	736	1.2	
3/21/00	1315	8.0	2.1	289	F	5.0E+03 L-NPCM	9.0E+04	6.0E+01 L-NCPM	6.0E+04	6.2E+01 1NCPM	1.5E±04	2.5E+04 L-NCPM	1.7E+05	0	32	736	1.2	
3/21/00	1330	9.0	2.0	292	F	5.0E+03 L-NPCM	9.0E+04	6.0E+01 L-NCPM	6.0E+04	6.2E+01 L-NCPM	1.5E+04	2.5E+04 L-NCPM	1.7E+05	2	43	791	1.2	
3/21/00	1345	9.0	2.1	288	F	2.5E+03 L-NCPM	9.0E+04	6.0E+01 L-NCPM	6.0E+04	6.2E+01 L-NCPM	1.5E+04	5.0E+03 L-NCPM	1.7E+05	0	21	208	1.4	
3/21/00	1400	8.0	2.0	290	F	1.0E+03 L-NCPM	9.0E+04	6.0E+01 L-NCPM	6.0E+04	6.2E+01 L-NCPM	1.5E+04	5.0E+03 L-NCPM	1.7E+05	0	25	170	1.4	
3/21/00	1415	9.0	2.1	291	F	6.8E+02 L-NCPM	9.0E+04	6.0E+01 L-NCPM	6.0E+04	6.2E+01 L-NCPM	1.5E+04	5.0E+03 L-NCPM	1.7E+05	0	25	170	1.4	
3/21/00	1430	11.0	2.0	291	F	1.0E+02 L-NCPM	9.0E+04	6.0E+01 L-NCPM	6.0E+04	6.2E+01 L-NCPM	1.5E+04	2.0E+02 L-NCPM	1.7E+05	0	25	170	1.4	

SECTION 8.0

RADIOLOGICAL DATA

8.0 RADIOLOGICAL DATA

This section provides all relevant on-site radiological and radiochemistry data necessary for exercise participants.

Section 8.1 details in-plant radiation data. Tables 8.1.1 through 8.1.4 list the process radiation monitor trend data. The monitors are grouped by ICS screen number 158.

ICS Screen No. 158 "Radiation Data Summary Trends" is also provided as a function of time in the Message/Plant Data forms, Section 7.2.

Tables 8.1.5 to 8.1.21 detail in tabular and graphical form, area radiation readings including ambient, contamination and airborne levels.

Section 8.2 denotes Plant Chemistry and Effluent sample data. Pre-accident and post-accident data are provided for the reactor coolant system (Tables 8.2.1 & 2), suppression pool (Tables 8.2.3 & 4), drywell atmosphere (Table 8.2.5 and 6) and containment atmosphere (Table 8.2.7 and 8). Also listed, as Tables 8.2.9 and 8.2.10 are the grab sample results for the release point. Table 8.2.11 gives information to calculate iodine activity on the D-17 cartridges on the Turbine Building vent.

Meteorological data is outlined in Section 8.3. Table 8.3.1 lists meteorological tower data as a function of time. The day's forecast is found in Table 8.3.2.

On-site out of plant dose rate readings are included as Tables 8.4.1 (Whole Body), 8.4.2 (Thyroid), and 8.4.3 (Air Sample Results).

Dose projection input data, i.e., gaseous effluent radiation and flow monitor data is presented in Section 8.5. Table 8.5.1 lists this information. Dose projection results are provided in Tables 8.5.2, 8.5.3. Noble gas and iodine release rates, as well as release pathways out of the plant are graphically depicted in Figures 8.5.1 and 8.5.2 respectively.

Section 8.6 provides the necessary tables to support offsite radiation field monitoring team activities.

Section 8.7 provides the necessary figures and tables to drive Ingestion Pathway exercise activities.

SECTION 8.1 IN PLANT RADIATION DATA

TABLES 8.1.1 TO 8.1.4 PROCESS RADIATION MONITOR TREND DATA

(See Table 8.5.1 for Process Radiation Monitor Trends)

TABLES 8.1.5 TO 8.1.21

IN-PLANT AREA RADIATION LEVELS

LOCATION	TABLE
STM TNL 615	8.1.5
STM TNL 630	8.1.6
TB577	8.1.7
TB605	8.1.8
TB620	8.1.9
TB647	8.1.10
IB574 East	8.1.11
IB574 West	8.1.12
IB599 East	8.1.13
IB599 West	8.1.14
IB620	8.1.15
IB654	8.1.16
IB682	8.1.17
AB599	8.1.18
AB574	8.1.19
AB620	8.1.20
C 599	8.1.21

<u>TABLE 8.1.5</u>

STEAM TUNNEL ELEV. 615'

TIME:	0700 0800	0800 0900	0900 0930	0930 1000	1000 1030	1030 1115	1115 1130	1130 1200	1200 1230	1230 1300	1300 1330	1330 1400	1400 END	
Ambient Radiation Level (mr/hr)		. ,												
General Area	AS FO	OUND -				>	840	840	840	2400	2.2E4	2.2E4	2200	
Contamination Level dpm/100cm² General Areas AS FOUND> 25K 25K 25K 250K 250K 250K 250K														
General Areas	А	S FOUI	ND			>	25K	25K	25K	250K	250K	250K	250K	
<u>Airborne Levels cpm</u> (μCi/cc)														
General Areas	A	S FOUI	۰ ظ		>:	REFE	R TO T	ABLE	8.2.5					
Air Sample Volume = 35ft ³														

STEAM TUNNEL ELEV. 630'

TIME:	0700 0800	0800 0900	0900 0930	0930 1000	1000 1030	1030 1115	1115 1130	1130 1200	1200 1230	1230 1300	1300 1330	1330 1400	1400 END	
Ambient Radiation Level (mr/hr)														
General Area	AS FO	UND -				>	820	820	820	2200	2.2E4	2.2E4	2200	
Contamination Level dpm/100cm														
General Areas	A	S FOUI	۷D -			>	20K	20K	20K	200K	200K	200K	200K	
<u>Airborne</u> <u>Levels cpm</u> (μCi/cc)											·			
General Areas	A	s foui	VD		>	REFE	R TO T	ABLE	8.2.5					
Air Sample Volume = 35 ft ³														

TURBINE BUILDING 577'

TIME:	0700 0800	0800 0900	0900 0930	0930 1000	1000 1030	1030 1115	1115 1130	1130 1200	1200 1230	1230 1300	1300 1330	1330 1400	1400 END	
Ambient Radiation Level (mr/hr)														
General Area	AS FC	UND				>	1000	1000	1000	1000	1.0E4	1.0E4	1000	
Contamination Level dpm/100cm ²														
General Areas	Α	S FOUN	۷D			>	10000	10000	10000	100K	100K	100K	100K	
Airborne Levels cpm (μCi/cc)														
General Areas	A		ND	**********	,	>	3.1E6 6.0E-6						3.1E7 6.0E-5	
Notes: If net counts per m Assumes total air s					is off-so	cale hig	gh							

TURBINE BUILDING ELEV. 605'

	TIME:	0700 0800	0800 0900	0900 0930	0930 1000	1000 1030	1030 1115			1200 1230	1230 1300	1300 1330	1330 1400	1400 END
Ambient R (mr/hr)	adiation Level		AS F0	OUND -			·>	800	800	800	1000	1.0E4	1.0E4	1000
Contamina General A	ntion Level dpm/1		A	S FOU	ND		>	10000	10000	10000	100K	100K	100K	100K
Airborne L	<u>.evels cpm</u> (μCi/cc)													
General A	reas		A	S FOU	ND	**	>	3.2E6 6.0E-6			3.1E7 6.0E-5			3.1E-7 6.0E-5
	f net counts per m Assumes total air s				frisker	is off-sc	ale hi	gh						

TURBINE BUILDING ELEV. 620'

TIME:	0700 0800	0800 0900	0900 0930	0930 1000	1000 1030	1030 1115	1115 1130	1130 1200	1200 1230	1230 1300	1300 1330	1330 1400	1400 END	
Ambient Radiation Level (mr/hr) General Area		AS F	OUND			>	800	800	800	1000	1.0E4	1.0E4	1000	
Contamination Level dpm/100cm General Areas														
<u>Airborne Levels cpm</u> (μCi/cc)														
General Areas		AS FO	UND			>			3.1E6 6.0E-6				2.1E7 4.0E-5	
Notes: If net counts per n Assumes total air					is off-so	cale hig	h ·							

TURBINE BUILDING ELEV. 647'

TIME:	0700 0800	0800 0900	0900 0930	0930 1000	1000 1030	1030 1115	1115 1130	1130 1200	1200 1230	1230 1300	1300 1330	1330 1400	1400 END	
Ambient Radiation Level (mr/hr)		,												
General Area		AS F	OUND			>	800	800	800	1000	1.0E4	1.0E4	1000	
Contamination Level dpm/100cm ²														
General Areas		AS FO	U ND -		•	>	10000	10000	10000	10000	100K	100K	100K	
<u>Airborne Levels cpm</u> (μCi/cc)														
General Areas 2.3E-5		AS FO	U ND -			>		3.9E6 1.3E-5					2.1E7 4.0E-5	
Notes: If net counts per n Assumes total air					is off-so	cale hig	h							

<u>TABLE 8.1.11</u>

Intermediate Building Elevation 574' East

1300

1400

	TIME:	0800	0900	1000	1100	1200	1230	1300	1330	1400	END			
Ambient Rad (mr/hr) General Area			AS F	OUND			>		gure 8.		>			
Contamination Level dpm/100cm														
General Area	S		<i>[</i>	AS FOU	ND				<u></u>		>			
Airborne Lev	<u>rels cpm</u> (μCi/cc)													
General Area	s		A	AS FOU	МD -						>			
				•										
Air Sample V	Volume = 35ft^3													

2000 EVEX

Section 8.1

Intermediate Building Elevation 574' West

1000 1100 1200 1230 1300 1330

-	TIME:	0800	0900	1000	1100	1200	1230	1300	1330	1400	END			
Ambient Ra	adiation Level		•					See Ei	gure 8.	1 12				
General Ar	ea		AS F	DUND	********		>				>			
•														
Contamination Level dpm/100cm														
General Ar	eas		A	AS FOU	ND						>			
Airborne L	<u>evels cpm</u> (μCi/cc)													
General Are	eas		A	S FOU	ND						>			
Air Sample	Volume = 35 ft ³													

Intermediate Building Elevation 599' East

0800 0900 1000 1100 1200 1230 1300 1330 1400

	TIME:	0800	0900	1000	1100	1200	1230	1300	1330	1400	END			
Ambient F (mr/hr) General A	Radiation Level		AS F				>		gure 8.		>			
Contamination Level dpm/100cm														
General A	reas		<i>[</i>	AS FOU	ND						>			
Airborne I	<u>-evels cpm</u> (μCi/cc)													
General A	reas		. A	S FOU	ND						>			
Air Sample	e Volume = 35ft³													

Intermediate Building Elevation 599' West

TIME:	0700 0800	0800 0900	0900 1000	1000 1100	1100 1200	1200 1230	1230 1300	1300 1330	1330 1400	1400 END
Ambient Radiation Level (mr/hr) General Areas		<i>F</i>	AS FOU	ND				gure 8.		>
Contamination Level dpm/1 General Areas		A	AS FOU	ND	••••					>
<u>Airborne Levels cpm</u> (μCi/cc)										
General Areas		Д	S FOU	ND					********	>
Air Sample Volume = 35ft ³										

Intermediate Building Elevation 620'

1000 1100 1200 1230 1300 1330 1400

TIME:	0800	0900 1000	1100	1200	1230	1300	1330	1400	END
adiation Level									
		AS FOUND			>				>
tion Level dpm/1	<u>00cm</u>								
		AS FOUND		·					>
<u>evels</u> <u>cpm</u> (μCi/cc)									
		AS FOUND							->
Volume = 35ft^3									
	adiation Level tion Level dpm/1	adiation Level tion Level dpm/100cm evels cpm (µCi/cc)	adiation Level AS FOUND tion Level dpm/100cm AS FOUND evels cpm (µCi/cc) AS FOUND	adiation Level AS FOUND tion Level dpm/100cm AS FOUND evels cpm (μCi/cc) AS FOUND	adiation Level AS FOUND tion Level dpm/100cm AS FOUND evels cpm (μCi/cc) AS FOUND	adiation Level AS FOUND tion Level dpm/100cm AS FOUND evels cpm (μCi/cc) AS FOUND	See Fi AS FOUND tion Level dpm/100cm AS FOUND evels cpm (μCi/cc) AS FOUND	See Figure 8 AS FOUND	See Figure 8.1.15 AS FOUND tion Level dpm/100cm AS FOUND evels cpm (μCi/cc) AS FOUND

Intermediate Building Elevation 654'

	TIME:	0700 0800	0800	0900 1000	1000 1100	1100 1200	1200 1230	1230 1300	1300 1330	1330 1400	1400 ENE
Ambient Rad (mr/hr)	iation Level							See Fi	gure 8.	1.16	
			AS F	OUND			>				>
Contaminatio	n <u>Level</u> <u>dpm/1</u>		AS F	OUND			·				>
Airborne Lev	<u>els cpm</u> (μCi/cc)				,						
			AS F	OUND							>
Air Sample V	$volume = 35 ft^3$										

<u>TABLE 8.1.17</u>

Intermediate Building Elevation 682'

TIME:	0800	0900	1000	1100	1200	1230	1300	1330	1400	END
Ambient Radiation Level (mr/hr) General Areas	_	<i>A</i>	AS FOU	ND				gure 8.		>
Contamination Level dpm/1 General Areas		[AS FOU	JND						>
Airborne Levels cpm (μCi/cc)				DJD.						
General Areas Air Sample Volume = 35ft ³		/	45 FUC)ND						>

<u>TABLE 8.1.18</u>

Auxiliary Building Elevation 599'

TIME:	0800	0900	1000	1100	1200	1230	1300	1330	1400	END
Ambient Radiation Level (mr/hr) General Areas		<i>[</i>	AS FOU	IND				gure 8.1		>
Contamination Level dpm/ General Areas	-	A	.s Fou	IND						>
Airborne Levels cpm (μCi/cc) General Areas		·	S FOU	'ND		·				>
Air Sample Volume = 35ft ³	ı									

<u>TABLE 8.1.19</u>

Auxiliary Building Elevation 574'

1000 1100 1200 1230 1300 1330 1400

production to	TIME:	0800	0900	1000 1100	1200	1230	1300	1330	1400	END
Ambient I (mr/hr) General A	Radiation Level		· ,	AS FOUND				gure 8.		>
Contamin General A	ation Level dpm/		<i>[</i>	AS FOUND						>
Airborne	<u>Levels cpm</u> (μCi/cc)									
General A	reas		<i>F</i>	AS FOUND						>
Air Samp	le Volume = 35ft	3	٠			٠				

Auxiliary Building Elevation 620'

1400

	TIME:	0800	0900	1000	1100	1200	1230	1300	1330	1400	END
Ambient (mr/hr) General A	Radiation Level		<i>[</i> -	AS FOU	ND				gure 8.		>
Contamin	ation Level dpm/	100cm									
General A	Areas		A	AS FOU	ND					·	>
Airborne	<u>Levels cpm</u> (μCi/cc)										
General A	Areas		A	AS FOU	ND	-					>
Air Samp	le Volume = 35ft	3									

0900

0700

Control Complex Elevation 599'

TIME:	0700 0800	0800 0900	0900 1000	1000 1100	1100 1200	1200 1230	1230 1300	1300 1330	1330 1400	1400 END
Ambient Radiation Level (mr/hr) General Areas		, }	AS FOU	ND				gure 8.		>
Contamination Level dpm/1 General Areas		·	AS FOU	IND		·				>
<u>Airborne</u> <u>Levels cpm</u> (μCi/cc)										
General Areas		<i>[</i>	AS FOU	JND						>
Air Sample Volume = $35 ft^3$		•	•		•					

SECTION 8.2 CHEMISTRY/EFFLUENT SAMPLE DATA

CHEMISTRY/EFFLUENT SAMPLE DATA

LOCATION	TABLE
Reactor Coolant	8.2.1 & 2
Suppression Pool	8.2.3 & 4
Drywell Atmosphere	8.2.5 & 6
Containment Atmosphere	8.2.7 & 8
Steam Tunnel Atmosphere	8.2.9
Turbine Building/Heater Bay Vent	8.2.10
D-17 Cartridge	8.2.11

TABLE 8.2.1 STANDARD REACTOR COOLANT ISOTOPIC ANALYSIS 0700 - 1235

<u>IODINES</u>	μCi/cc	DEI	Noble Gases	<u>μCi/ml</u>
I-131 I-132 I-133 I-134 I-135	2.00E-4 5.65E-3 3.35E-3 1.95E-2 7.25E-3	2.00E-4 2.04E-4 9.05E-4 3.30E-4 <u>6.08E-4</u> 2.28E-3	XE-133	2.62E-4
<u>PARTICULATES</u>	<u>μCi/ml</u>		<u>PARTICULATES</u>	<u>μCi/ml</u>
Na-24 Cr-51 Mn-54 Fe-59 Cs-137 Nb-95 Cs-138 Np-239 Tc-101 Sr-92 Sr-91 Tc-104 Te-132 Mn-56 Co-58 Co-60 Zn-65 Ni-65 As-76 Mo-99 Tc-99m	7.79E-4 1.74E-3 1.11E-5 5.2E-4 <2.9E-4 8.5E-4 5.89E-3 6.43E-4 6.55E-2 1.54E-2 5.13E-3 5.05E-2 1.1E-4 3.54E-4 8.94E-5 1.33E-4 9.15E-4 1.4E-3 7.78E-5 1.49E-3 8.32E-3		La-142 Ba-139 Ru-105 2n 69m SR 93 Y92 Y93 Ag110m	2.5E-3 2.05E-2 1.50E-3 2.66E-4 2.00E-2 2.19E-2 4.79E-4 8.37E-6
Cs-134 Y-91m Nb-95m	2.7E-4 1.8E-3 1.7E-3			
NON PADIOCUENTO				

NON-RADIOCHEMICAL

Cl ⁻ (ppm)	0.008
Conductivity (µmho/cm)	0.10
pН	6.5
Dissolved O ₂ (ppm)	0.2

TABLE 8.2.2

POST-ACCIDENT REACTOR COOLANT ISOTOPIC ANALYSIS

1235 - END

<u>IODINES</u>	<u>μCi/ml</u>	DEI	Noble Gases	μCi/ml
I-131	50.5	50.5	Xe-131m	6.5E-4
I-132	. 6.4	2.3E-1	Xe-133	2.0E-1
I-133	34.6	9.34	Xe-135	1.8E-1
I-134	7.6	1.3E-1.	Xe-135m	7.9E-3
I-135	18.6	1.56	Xe-137	1.6E-1
		61.76	Xe-138	1.9E-1
			Kr-83m	3.0E-3
	PARTICU	LATES µCi/ml	Kr-85m	4.8E-3
			Kr-85	1.0E-3
	Cs-134	2.0E-1	Kr-87	6.1E-3
	Cs-137	8.66	Kr-88	9.1E-3
	Cs-138	13.2	Kr-89	1.5E-1
	Te-132	11.2		
	Mo-99	12.8		
	Ru-105	9.7		
	Sr-91	8.6		
	Sr-92	7.9		
	Ba-140	9.1		
	Y-92	8.2		
	La-140	9.9		
	Ce-144	10.1		
	Zr-95	12.2		
	Zr-97	12.9		
NON-RADIOCHEN	<u>MICAL</u>	•		
Cl (ppm)		0.19		
Conductivity (µmho	/cm)	0.82		
pН		7.2		
Boron (ppm)		1200 ppm at 1430		
Dissolved O ₂ (ppm)		0.2		
Total Gases (cc/kg)		32		

TABLE 8.2.3

STANDARD SUPPRESSION POOL ISOTOPIC ANALYSIS
0700 - 1235

<u>ISOTOPE</u>	<u>μCi/ml</u>
Co-60	5.55E-7
Zn-65	3.26E-7
I-133	1.57E-7
Xe-133	4.00E-7
Xe-135	3.00E-7

TABLE 8.2.4

POST-ACCIDENT SUPPRESSION POOL ISOTOPIC ANALYSIS
1235 - END

<u>IODINES</u>	<u>μCi/ml</u>	DEI	Noble Gases	<u>μCi/ml</u>
I-131	40	40	Xe-131m	4.3E-5
I-132	3.93	1.4E-1	Xe-133	1.3E-2
I-133	21.2	5.72	Xe-135	1.2E-2
I-134	4.7	8.0E-2	Xe-135m	5.5E-4
I-135	11.4	9.6E-1	Xe-137	1.1E-2
		46.9	Xe-138	1.3E-2
			Kr-83m	2.0E-4
			Kr-85m-	3.2E-4
			Kr-85	6.6E-5
•			Kr-87	4.1E-4
			Kr-88	6.0E-4
			Kr-89	9.9E-3
	DADTICI II AT	FG G:/ 1		
G 10.4	PARTICULAT			
C s-134	2.0E-1	Sr-92	5.5	
Cs-137	5.3	Ba-140	4.8	
Cs-138	4.97	Y-92	4.8	

La-140

Ce-144

Zr-95

Zr-97

Te-132

Mo-99

Ru-105

Sr-91

8.0

8.7

6.4

5.2

4.63

4.8

6.1

2.0

TABLE 8.2.5

STANDARD DRYWELL ATMOSPHERE ISOTOPIC ANALYSIS 0700 - 1235

Gross Activity
Particulate Activity

<2.0E-9 μCi/cc 8.4E-11 μCi/cc

TABLE 8.2.6

POST-ACCIDENT DRYWELL ATMOSPHERE 1251 - END

<u>IODINES</u>	μCi/ml	DEI	Noble Gases	<u>μCi/ml</u>
I-131 I-132 I-133 I-134 I-135	2.56 3.2E-1 1.75 3.9E-1 9.4E-1	2.56 1.2E-2 4.7E-1 6.6E-3 7.9E-2 3.13	Xe-131m Xe-133 Xe-135 Xe-135m Xe-137 Xe-138 Kr-83m Kr-85m Kr-85 Kr-85	6.3E-5 1.9E-2 1.7E-2 7.6E-4 1.5E-2 1.8E-2 2.9E-4 4.8E-4 9.6E-5 5.9E-4 8.7E-4
		••	Kr-89	1.4E-2

PARTICULATES

None

TABLE 8.2.7

STANDARD CONTAINMENT ATMOSPHERE 0720 - 1235

Gross Activity
Particulate Activity

1.04E-3 μCi/cc* 7.6E-10 μCi/cc

TABLE 8.2.8

POST-ACCIDENT CONTAINMENT ATMOSPHERE ISOTOPIC ANALYSIS
1235 - END

<u>IODINES</u>	μCi/ml	DEI	Noble Gases	μCi/ml
I-131	13.1	13.1	Xe-131m	5.5E - 4
· I-132	1.66	6.0E-2	Xe-133	1.7E-1
I-133	8.97	2.42	Xe-135	1.5E-1
I-134	1.97	3.3E-2	Xe-135m	6.6E-3
I-135	4.82	4.0E-1	Xe-137	1.3E-1
•		16.01	Xe-138	1.6E-1
			Kr-83m	2.5E-3
			Kr-85m	4.0E-3
			Kr-85	8.4E-4
			Kr-87	5.1E-3
			Kr-88	7.6E-3
			Kr-89	1.3E-1
	PARTICULATES	(μCi/ml)		
Cs-134	1.7E-2	Sr-92	6.6E-1	
Cs-137	7.2E-1	Ba-140	7.6E-1	
Cs-138	1.1	Y-92	6.8E-1	
Te-132	9.3E-1	La-140	8.3E-1	
Mo-99	1.06	Ce-144	8.4E-1	
Ru-105	8.1E-1	Zr-95	1.02	
Sr-91	7.2E-1	Zr-97	1.08	

^{*} This is activity due to stuck open SRV

TABLE 8.2.9
STEAM TUNNEL ISOTOPIC ANALYSIS

$(\mu \text{Ci/cc})$ 1115 1245 1300 1315 1330 1345	1400 - END
Kr-85 0.0E+0 8.62E-1 2.11E+0 2.11E+0 8.62E-1 1.841	0.000
Kr-87 0.0E+0 8.77E-1 2.14E+0 2.14E+0 8.77E-1 1.87	
Kr-88 0.0E+0 1.85E+0 4.52E+0 1.85E+0 3.95	E-5 0.0E+0
Xe-133 0.0E+0 3.75E+1 9.15E+1 9.15E+1 3.75E+1 8.001	E-4 0.0E+0
Xe-135 1.50E-8 7.74E+0 1.89E+1 1.89E+1 7.74E+0 1.651	E-4 1.50E-8
Total N.G 1.50E-8 4.87E+1 1.19E+2 1.19E+2 4.87E+1 1.041	E-3 1.50E-8 ,
I-131 1.67E-9 3.99E-2 1.0E-1 1.0E-1 3.99E-2 8.45I	E-7 1.67E-9
I-132 0.0E+0 5.07E-3 1.27E-2 1.27E-2 5.07E-3 1.07I	E-7 0.0E+0
I-133 7.26E-9 2.73E-2 6.85E-2 6.85E-2 2.73E-2 5.79I	E-7 7.26E-9
I-134 0.0E+0 6.18E-3 1.55E-2 1.55E-2 6.18E-3 1.31I	E-7 0.0E+0
I-135 0.0E+0 1.45E-2 3.63E-2 3.63E-2 1.45E-2 3.07I	
Total	
Iodine 8.93E-9 9.30E-2 2.33E-1 2.33E-1 9.30E-2 1.97I	E-6 8.93E-9

For TB/HB Isotopic Analysis, divide activities by 10.

TABLE 8.2.10

TURBINE BUILDING VENT ISOTOPIC ANALYSIS

ISOTOPE (μCi/cc)	1115	1245	1300	1315	1330	1345	1400 - END
Kr85M	1.81E-8	1.56E-2	1.63E-2	1.63E-2	1.86E-2	3.46E-7	1.81E-8
Kr85	0.0E+0	3.60E-3	3.76E-3	3.76E-3	3.60E-3	8.01E-8	0.0E+0
Kr87	2.82E-8	1.58E-2	1.65E-2	1.65E-2	1.58E-2	3.51E-7	2.82E-8
Kr88	3.94E-9	3.38E-2	3.49E-2	3.49E-2	3.38E-2	7.42E-7	3.94E-9
Xe-133	1.12E-9	6.75E-1	7.06E-1	7.06E-1	6.75E-1	1.50E-5	1.12E-9
Xe-135	1.67E-8	1.39E-1	1.46E-1	1.46E-1	1.39E-1	3.11E-6	1.67E-8
Total N.G	6.81E-8	8.78E-1	9.19E-1	9.19E-1	8.78E-1	1.96E-5	6.81E-8
l-131	1.67E-9	1.26E-3	1.43E-3	1.43E-3	1.26E-3	3.09E-8	1.67E-9
I-132	0.0E+0	1.60E-4	1.82E-4	1.82E-4	1.60E-4	3.92E-9	0.0E+0
I-133	7.26E-9	8.64E-4	9.82E-4	9.82E-4	8.64E-4	2.11E-8	7.26E-9
I-134	0.0E+0	1.95E-4	2.21E-4	2.21E-4	1.95E-4	4.77E-9	0.0E+0
I-135	0.0E+0	4.57E-4	5.20E-4	5.20E-4	4.57E-4	5.12E-9	0.0E+0
Total Iodine	8.93E-9	2.93E-3	3.43E-3	3.43E-3	2.93E-3	7.73E-8	8.93E-9
iodino	0.7527	2.752 5	, , , , , ,	5.4515.5	2.7312-3	7.752-0	0.73L-7
VENT							
FLOW (CFM)	1.70E+5	1.70E+5	1.70E+5	1.70E+5	1.70E+5	1.70E+5	1.70E+5
RELEASE							
RATES							
(μCi/sec)							
NOBLE GAS	5.54	7.14E+7	7.48E+7	7.48E+7	7.14E+7	1.6E+3	5.54
IODINE	7.3E-1	2.38E+5	2.79E+5	2.79E+5	2.38E+5	6.29E+0	7.3E-1

For Unit 1 Vent Isotopic Analysis, divide noble gas by 10 and iodine by 104.

TABLE 8.2.11

IODINE ACTIVITY ON D-17 CARTRIDGES

The following information will be used to calculate iodine activity on the cartridges, if samples are pulled from the Turbine Building Vent.

Scenario Time	Rate(Ci/sec)	Flow (cfm)
1215-1230 1230-1245	Negligible Negligible	1.7E+5 1.7E+5
1245-1300 1300-1315	.238 .279	1.7E+5 1.7E+5
1315-1330 1330-1345 1345-1400	.279 .238 Negligible	1.7E+5 1.7E+5
. 1400-1415 1415-1430	Negligible Negligible Negligible	1.7E+5 1.7E+5 1.7E+5

Total curies on cartridge equals the sum of:

Time elapsed x release rate x cartridge flow ÷ vent flow for each interval. (seconds) (ci/sec) (cfm) (cfm)

(Cartridge flow = 1 cfm for the low-range monitor, 1D17K856)

For example, say the 1D17K856 iodine cartridge is pulled at 1335. Determine the number of curies of iodine absorbed on the cartridge.

1245-1300 (900 sec)(.238 Ci/sec)(1.0 cfm)/(1.7E5 cfm) = 1.36E-3
1300-1315 (900 sec)(.279 Ci/sec)(1.0 cfm)/(1.7E5 cfm) = 1.48E-3
1315-1330 (900 sec)(.279 Ci/sec)(1.0 cfm)/(1.7E5 cfm) = 1.48E-3
Total activity =
$$(1.26E-3) + (1.48E-3) + (1.48E-3) = 4.22E-3$$
 Ci = 4.22 millicuries

Contact doses from these cartridges can be determined using this formula:

1 millicurie = 40 mR/hr

For the example above, the contact dose rate on the cartridge would be 168.8 mR/hr

SECTION 8.3 METEOROLOGICAL DATA

2000 PERRY EVALUATED EXERCISE 8.3.1 METEOROLOGICAL DATA

(PRIMARY SENSORS, 10 METER SENSORS)

TIME	SPEED (MPH)	DIRECTION (DEGREES FROM)	DELTA-T (DEGREES F)
0730	3.0	295	2.0
0745	4.0	294	2.1
0800	4.5	292	2.1
0815	7.0	291	2.1
0830	6.0	294	1.9
0845	7.5	291	2.1
0900	5.0	293	2.1
0915	5.5	294	2.0
0930	5.0	293	2.2
0945	6.0	294	2.0
1000	6.5	292	2.0
1015	5.5	295	1.8
1030	3.0	296	1.9
1045	4.0	295	2.0
1100	3.5	294	1.9
. 1115	4.0	292	1.8
1130	4.0	295	1.9
1145	5.5	294	1.8
1200	5.5	295	2.2
1215	5.0	293	2.2
1230	4.5	294	2.1
1245	5.0	291	2.0
1300	5.5	291	2.0
1315	8.0	289	2.1
1330	9.0	292	2.0
1345	9.0	288	2.1
1400	8.0	290	2.0
1415	9.0	291	2.1
1,430	11.0	291	2.0
1445	12.0	290	2.0
1500	11.0	290	2.1
1515	14.0	286	2.1
1530	13.5	295	2.1
1545	16.0	292	2.0
1600	15.5	284	2.0

2000 PERRY EVALUATED EXERCISE 8.3.2 METEOROLOGICAL FORECAST

Morning:

Expect partly cloudy skies this morning with light winds out of

the northeast. Temperatures are expected to be in the middle to

upper 40's.

Afternoon: Clear and seasonably cool with temperatures in the mid 60's. Clouds

developing later with winds increasing to 5-15 mph from the northwest. An increased chance of precipitation of 50% towards

evening.

Evening:

Becoming cloudy this evening, with winds increasing as a storm front enters the area from the north. Winds of 10 to 20 mph are expected with gusts up to 35 mph. Warm temperatures will persist with a 75% chance of rain as the storm front passes

through the area.

SECTION 8.4 ON SITE RADIOLOGICAL DATA

This section contains:


Figure 8.4 - Onsite Plume Location

Figure 8.4.1 - Onsite Whole Body Dose Rates

Figure 8.4.2 - Child Thyroid Dose Rates

Figure 8.4.3 - Onsite Plume Air Sample Results

Figure 8.4
ONSITE PLUME LOCATION



2000 PERRY EVALUATED EXERCISE FIGURE 8.4.1 ONSITE PLUME LOCATION

TABLE 8.4.1
ON-SITE WHOLE BODY DOSE RATES (mRem/hr)

		DC	WNWIND	DISTANCE	(meters)		
TIME	100	200	400	600	800	1000	1200
1235	*	*	*	*	*	*	*
1245	19 (48)	19 (48)	*	*	*	*	*
1300	24 (61)	24 (61)	17 (43)	1.5 (3.8)	1.5 (3.8)	13 (3.3)	11 (2.8)
1315	19 (48)	19 (48)	200 (52)	17 (43)	17 (43)	13 (33)	11 (24)
1330	19 (48)	19 (48)	17 (43)	15 (38)	15 (38)	13 (33)	11 (2.8)
1345	*	*	*	*	*	*	*

<u>NOTES</u>: All values are calculated at plume centerline.

For measurements taken off-centerline, interpolate between the centerline and the edge of the plume. Assume value at plume edge equals 10% of centerline.

Closed window readings. Numbers in parenthesis indicate open window reading.

Background levels (less than .02 mR/hr) are indicated by *.

2000 PERRY EVALUATED EXERCISE FIGURE 8.4.1 ONSITE PLUME LOCATION

TABLE 8.4.2
CHILD THYROID DOSE RATES (mRem/hr)

			DOWNW	VIND DISTA	ANCE (meter	rs)	
TIME	100	200	400	600	800	1000	1200
1235	360	360	*	*	*	*	*
1245	3600	3600	340	320	300	280	260
1300	3600	3600	3400	3200	3000	2800	2600
1315	3600	3600	3400	3200	3000	2800	2600
1330	360	360	3400	3200	3000	2800	2600
1345	*	*	340	320	300	280	260

NOTES: All values are calculated at plume centerline.

For measurements taken off-centerline, interpolate between the centerline and the edge of the plume. Assume value at plume edge equals 10% of centerline.

Concentrations that are less than detectable are represented by *.

2000 PERRY EVALUATED EXERCISE FIGURE 8.4.1 ONSITE PLUME LOCATION

TABLE 8.4.3

ON-SITE PLUME AIR SAMPLE RESULTS (uCi/cc) (For time period 1245-1315 hours)*

Isotope	Concentration	MPC	%MPC
KR 85m	6.68E-6	6E-6	1.11E+2
KR 85	1.33E-7	1E-5	1.33E+0
KR 87	6.01E-6	1E-6	6.01E+2
KR 88	1.27E-5	1E-6	1.27E+3
XE 133	2.57E-4	1E-5	2.57E+3
XE 135	5.30E-5	4E-6	1.33E+3
I 131	2.80E-7	9E-9	3.11E+3
I 132	3.34E-8	2E-7	1.67E+1
I 133	1.67E-7	3E-8	5.57E+2
I 134	4.34E-8	5E-7	8.68E+0
I 135	1.00E-7	1E-7	1.00E+2
Total	3.34E-4	444	9.68E+3

Contact Dose Rates on filter media (assuming a 40 cubic feet sample):

Particulate Filter = 2 mr/hr Charcoal Cartridge = 30 mr/hr Marinelli Beaker = 5 mr/hr


^{*}All other time periods Air Samples will be as read.

SECTION 8.5

DOSE PROJECTION DATA

This section contains:

- Figure 8.5.1 Plant Release Pathways
- Figure 8.5.2 Noble Gas and Iodine Release Rates
- Table 8.5.1 Gaseous Effluent Radiation Monitor And Flow Monitor Data
- Table 8.5.2 Computer-Aided Dose Assessment Program
 (CADAP) Offsite Dose Results for RCIC Steam Leak
- Table 8.5.3 Computer-Aided Dose Assessment Program (CADAP) Offsite Dose Results for Fuel Failure



PLANT RELEASE PATHWAYS
(Primary via "Unfiltered" Turbine Building/Heater Bay Vent)

574'/568'

RHR C ROOM

RCIC ROOM

AUXILIARY BUILDING

PLANT RELEASE PATHWAYS (Secondary via "Filtered" Unit 1 Vent)

INTERMEDIATE BUILDING

CONTROL

2000 PNPP EVALUATED EXERCISE NOBLE GAS RELEASE RATE (uCi/sec)




Figure 8.5.2

2000 PNPP EVALUATED EXERCISE IODINE RELEASE RATE (uCi/sec)




Figure 8.5.2 (Cont.)

	Plant Vent 1 1D17-	Plant Vent 11D19-		Plant Vent 1 Flow 1M33-N125A	Plant Vent 2 2D17-	Plant Vent 2 2D19-	Plant Vent 2 2D19-	Plant Vent 2 Flow 1M33-N1258
THAT	K786 CPM	N300 uCi/cc	uCi/cc `	KCFM	K786 CPM	N300 uCi/cc	N340 uCi/cc	KCFF
TIME	D17EA030	D19EA003	D19EA004	M33EA001	D17EA530	D19EA503	D19EA504	M33EA002
6:54:59	100	0.001	1.02	88.496	88	0.001	1.02	54.545
6.59.59	100	0.001	1.02	88.496	88	0.001	1.02	54.544
7.04:59	100	0.001	1.02	88.496	88	0.001	1.02	54.545
7:09.59	100	0.001	1.02	88 496	88	0.001	1.02	54.545
7:14:59	100	0.001	1.02	88.496	88	0.001	1.02	54.544
7:19:59	100	0.001	1.02	88.496	88	0.001	1.02	54.544
7:24:58	100	0.001	1.02	88.496	68	0.001	1.02	54.546
7:29:58	100	0.001	1.02	88.496	88	0.001	1.02	54.546
7:34:58	100	0.001	1.02	- 88.496	88	0.001	1.02	54.544
7:39:58	100	0.001	1.02	88.496	88	0.001	1.02	54.544
7:44:58	100	0.001	1.02	88.496	88	0.001	1.02	54 544
7 49 58	100	0.001	1.02	88.496	88	0.001	1.02	54.544
7:54:58	100	0.001	1.02	88,496	88	0.001	1.02	54.544
7:59:58	100	0.001	1.02	88.496	. 88	0.001	1.02	54.544
8:04:58	100	0.001	1.02	88.496	88	0.001	1.02	54.544
8:09:58	100	0.001	1.02	88.496	88	0.001	1.02	54.544
8.14:58	100	0.001	1.02	88.496	88	0.001	1.02	54 543
8:19:58	100	0.001	1.02	88.496	88	0.001	1.02	54.544
8.24:58	100	0.001	1.02	88.496	88	0.001	1.02	54.543
8:29:58	100	0.001	1.02	88.496	88	0.001	1.02	54 545
8:34:58	100	0.001	1.02	88.496	88	0.001	1.02	54.543
8:39:58	100	0.001	1.02	88.496	88	0.001	1.02	54.545
8.44:58	100	0.001	1.02	88.496	88	0.001	1.02	54 546
8:49:58	100	0.001	1.02	88.496	88	0.001	1.02	54.544
8:54:58	100	0.001	1.02	88.496	88	0.001	1.02	54 544
8:59:58	100	0.001	1.02	. 88.496	. 88	0.001	1.02	54.544
9:04:58	100	0.001	1.02	88.496	88	0,001	1.02	54.546
9:09:58	100	0.001	1.02	88 496	88	0.001	1.02	54.544
9:14:57	100	0.001	1.02	88.496	88	0.001	1.02	54.544
9:19:57	100	0.001	1.02	88.496	88	0.001	1.02	54.544
9:24:57	100	0.001	1.02	88.496	88	0.001	1.02	54.544
9:29:57	100	0.001	1.02	88.496	88	0.001	1.02	54.545
9:34:57	100	0.001	1.02	88.496	88	0.001	1.02	54.544
9:39:57	100	0.001	1.02	88.496	88	0.001	1.02	54.544
9:44:57	100	0.001	1.02	88.496	88	0.001	1.02	54.544
9:49:57	100	0.001	1.02	88.496	88	0.001	1.02	54.544
9:54:57	100	0.001	1.02	88.496	88	0.001	1.02	54.544
9:59:57	100	0.001	1.02	88.496	88	0.001	1.02	54.545
10:04:57	100	0.001	1.02	88.496	88	0.001	1.02	54 545
10:09:57	100	0,001	1.02	88.496	88	0.001	1.02	54.544
10:14:57	100	0.001	1.02	88.496	88	0.001	1.02	54.544
10:19:57	100	0.001	1.02	88.496	88	0.001	1.02	54.544
10:24:56	100	0.001	1.02	88.496	88	0.001	1.02	54.544
10:29:57	100	0.001	1.02	88.496	88	0.001	1.02	54.544
10:34:57	100	0.001	1.02	88.496	88	0.001	1.02	54.545
10:39:57	100	0.001	1.02	88.496	88	0.001	1.02	54.545 54.545
10:49:51	100	0.001	1.02	88.496	88	0.001	1.02	54.545 54.545
10:54:51	100	0.001	1.02	88.496	88	0.001	1.02	54.545 54.546
10:59:51	100	0.001	1.02	88.496	88	0.001	1.02	54.546
11:04:51	100	0.001	1.02	88.496	88	0.001	1.02	54.547
11:09:51	340.051	1,166	1.166	88.496	88	0.001	1.02	
		., 100		55.480	55	0.001	1.02	54.547

	Plant Vent 1 1D17-	Plant Vent 11D19-	Plant Vent 1 1D19-340	Plant Vent 1 Flow 1M33-N125A	Plant Vent 2 2D17-	Plant Vent 2 2D19-	Plant Vent 2 2D19-	Plant Vent 2 Flow 1M33-N125B
	K786 CPM	N300 uCi/cc	uC/cc	KCFM	K786 CPM	N300 uCi/cc	N340 uCi/cc	KCFF
TIME	D17EA030	D19EA003	D19EA004	M33EA001	D17EA530	D19EA503	D19EA504	M33EA002
11:14:51	709.955	1.205	1 205	88.496	88	0.001	1 02	54.547
11:19:51	1081.303	1.211	1.211	88.496	88	0.001	1.02	54.548
11:24:51	1209.988	1.295	1 295	88.496	88	0.001	1.02	54.548
11:29:51	1209.988	1.159	1.159	88.496	88	0.001	1.02	54.548
11:34:51	1209.988	1.033	1 033	88.496	88	0.001	1 02	54.548
11:39.50	1209.988	0.886	1.02	88.496	88	0.001	1.02	54.549
11:44:51	1209.988	0.938	1.02	88.496	88	0.001	1.02	54.547
11:49:50	1209.988	0.824	1.02	88.496	88	0.001	1.02	54.55
11:54:50	1209.988	0.896	1 02	88.496	88	0.001	1.02	54.55
11:59:50	1209.988	0.735	1 02	88.496	88	0.001	1.02	54.55
12:04:50	1209.988	0.723	1.02	88.496	88	0.001	1.02	54.549
12:09:50	1209 988	0.672	1.02	88.496	88	0.001	1.02	54.55
12:14:50	1209.988	0.605	1.02	88 496	88	0.001	1 02	54,55
12:19:50	1209.988	0.607	1.02	88.496	88	0.001	1.02	54.55
12:24:50	1209.988	0.578	1.02	88.496	88	0.001	1.02	54.55
12:29:50	1209.988	0.527	1 02	88.496	88	0.001	1.02	54.549
12:34:50	2128 154	0.525	1 02	88.496	88	0.001	1.02	54.549
12:39:50	5009.949	0.501	1.02	88.496	88	0.001	1.02	54.549
12:44:50	5009.949	0.487	1.02	88.496	88	0.001	1.02	54.551
12:49:50	5009.949	0.463	1.02	88.496	88	0.001	1 02	54.55
12:54:50	5009.949	0.484	1 02	88.496	88	0.001	1 02	54.55
12:59:50	5009.949	0.604	1.02	88.496	88	0.001	1.02	54.55
13:04.50	5009.949	0.354	1.02	88.496	88	0.001	1.02	54.55
13:09:50	5009.949	0.315	1.02	88.496	88	0.001	1.02	54.55
13:14:50	5009.949	0.96	1.02	88.496	88	0.001	1.02	54.55
13:19:50	5009.949	1.138	1.138	88.496	88	0.001	1.02	54.551
13:24:50	5009.949	0.981	1.02	88.496	88	0.001	1.02	54.549
13:29:49	5009.949	0.864	1.02	. 88.496	88	0.001	1 02	54.551
13.34:50	5009.949	0.785	1.02	88.496	88	0.001	1.02	54.548
13:39:49	5009.949	0.703	1.02	88.496	88	0.001	1.02	54.549
13:44:49	4275.477	0.731	1.02	⁻ 88.496	88	0.001	1.02	54.549
13:49:49	2672 329	0.014	1.02	88.496	88	0.001	1.02	54.55
13:54:49	1059.268	0.001	1 02	88.496	88	0.001	1 02	54.549
13:59:49	209.998	0.001	1.02	88.496	88	0.001	1 02	54.549
14:04:49	209.998	0.001	1.02	88.496	88	0.001	1.02	54.55
14:09:49	209.998	0.001	1.02	88.496	88	0.001	1.02	54.55
14:14:49	209.998	0.001	1.02	88.496	88	0.001	1.02	54.55
14:19:49	209.998	0.001	1.02	88.496	. 88	0.001	1.02	54.551
14:24:49	209 998	0.001	1.02	88.496	88	0.001	1 02	54.55
14:29:49	209.998	0.001	1.02	88.496	88	0.001	1.02	54.551
14:31:29	209.998	0.001	1.02	88.496	88	0.001	1.02	54.551

2000 EVEX

	Offgas Vent D17-K836 CPM	Offgas Vent D19-N400 uCi/cc	Offgas Vent D-N440 uCi/cc	Offgas Vent Flow M36-N090		TB&HB Vent D19-	TB&HB Vent D19-	TB&HB Vent Flow M41-N260
TIME	D17EA033	D19EA005	D19EA006	KCFM	СРМ	N500 uCi/cc	N540 uCi/cc	KCFM
6:54:59	50	0.001	1.02	M36EA001	D17EA036	D19EA007	D19EA008	M41EA001
6:59:59	50	0.001	1.02	17.578	50	0.001	1.02	170.41
7:04:59	50	0.001	1.02	17.578	50	0.001	1.02	170.41
7:09:59	50	0.001		17.578	50	0 001	1.02	170.41
7:14.59	· 50	0 001	1.02	17.578	50	0 001	1.02	170.41
7:19:59	50	0 001	1.02	17.578	50	0.001	1.02	170.41
7:24:58	50	0.001	1.02	17.578	50	0 001	1.02	170.41
7:29:58	50	0.001	1.02	17.578	50	0.001	1.02	170.41
7:34:58	50		1.02	17.578	50	0.001	1.02	170.41
7:39:58	50	0.001	1.02	17.578	50	0.001	1.02	170.41
7:44:58	50	0.001	1.02	17.579	50	0.001	1.02	170.41
7:49:58	50	0.001	1.02	17.579	50	0.001	1.02	170.41
7:54:58	50	0.001	1.02	17 579	50	0.001	1.02	170.41
7:59:58	50 50	0.001	1.02	17.578	50	0.001	1.02	170.41
8:04:58	50 50	0.001	1.02	17.579	50	0.001	1.02	170.41
8:09:58	50	0.001	1.02	17 579	50	0 001	1.02	170.41
8:14:58		0.001	1.02	17.578	50	0 001	1.02	170.41
8:19:58	50 50	0.001	1.02	17.579	50	0.001	1.02	170.41
8:24:58	50 50	0.001	1.02	17.579 .	50	0.001	1.02	170.41
8:29:58	50 50	0.001	1.02	17.579	50	0.001	1.02	170.41
8:34:58	50 50	0.001	1.02	17.579	50	0.001	1.02	170.41
8:39:58	50 50	0.001	1.02	17 579	50	0.001	1.02	170 41
8:44:58		0.001	1.02	17.579	50	0.001	1.02	170.41
8:49:58	50 50	0.001	1.02	17 579	50	0.001	1.02	170.41
8:54:58	50 50	0.001	1.02	17.579	50	0.001	1.02	170.41
8:59:58		0.001	1.02	17.579	50	0.001	1.02	170.41
9:04:58	50 50	0.001	1.02	17.579	50	0.001	1.02	170.41
9:09:58	50	0.001	1.02	17.579	50	0.001	1.02	170.41
9:14:57	50	0.001	1.02	17 579	50	0.001	1.02	170.41
9:19:57	50	0.001	1.02	17.579	50	0.001	1.02	170.41
9:24:57	50	0.001	1.02	17.56	50	0.001	1.02	170.41
9:29:57	50	0.001 0.001	1.02	17.56	50	0 001	1.02	170.41
9:34:57	50		1.02	17.56	50	0.001	1.02	170.41
9:39:57	50	0.001 0.001	1.02	17.56	50	0.001	1.02	170.41
9:44:57	50	0.001	1.02	17.56	50	0.001	1.02	170.41
9:49:57	50	0.001	1.02	17.56	50	0.001	1.02	170.41
9:54:57	50	0.001	1.02	17.56	50	0 001	1.02	170.41
9:59:57	50	0.001	1.02	17.56	50	0.001	1.02	170.41
10:04:57	50	0.001	1.02	17.56	50	0.001	1.02	170.41
10:09:57	50	0.001	1.02	17.56	50	0.001	1.02	170.41
10:14:57	50	0.001	1.02	17.56	50	0.001	1.02	170.41
10:19:57	50		1.02	17.56	50	0.001	1.02	170.41
10:24:56	50	0.001	1.02	17.56	50	0.001	1.02	170.41
10:29:57	50	0.001	1.02	17.56	50	0.001	1.02	170.41
10:34:57	50 50	0.001	1.02	17.94	50	0.001	1.02	170.41
10:39:57	50 50	0.001	1.02	17.585	50	0.001	1.02	170.41
		0.001	1.02	17.57	50	0.001	. 1.02	170 41
10:49:51 10:54:51	50	0.001	1.02	17.589	50	0.001	1.02	170.41
	50	0 001	1.02	17.532	50	0.001	1.02	170.41
10:59:51	50	0.001	1.02	17.547	50	0.001	1.02	170,41
11:04:51	50	0.001	1.02	17.428	50	0.001	1.02	170.41
11:09:51	50	0.052	1.02	17.288	1121.663	0.118	1.02	170.41

	Offgas Vent D17-K836 CPM	Offgas Vent D19-N400	Offgas Vent D-N440			TB&HB Vent D19-	TB&HB Vent D19-	TB&HB Vent Flow M41-N260
TIME	D17EA033	uCi/cc D19EA005	uCi/cc	KCFM	СРМ	N500 uCi/cc	N540 uCi/cc	KCFM
11:14:51	50		D19EA006	M36EA001	D17EA036	D19EA007	D19EA008	M41EA001
11:19:51		0.054	1 02	17.288	2773 6	0.123	1.02	170.41
	50	0.055	1.02	17.288	4433.207	0.124	1.02	170.41
11:24:51	50	0.058	1.02	17.288	5009.949	0.133	1.02	170.41
11:29:51	50	0.052	1.02	17.289	5009 949	0.118	1 02	170.41
11:34:51	50	0.046	1.02	17 289	. 5009.949	0.106	1 02	170 41
11:39:50	50	0.04	1.02	17.288	5009.949	0.09	1.02	170 41
11:44:51	50	0.041	1 02	17.287	5009.949	0.097	1 02	170 41
11:49:50	50	0.035	1.02	17.287	5009.949	0.085	1 02	170.41
11:54:50	50	0.039	1.02	17.287	5009.949	0.092	1 02	170 41
11:59:50	50	0.032	1.02	17.288	5009.949	0.075	1 02	170.41
12:04:50	50	0.033	1.02	17.288	5009.949	0.074	1.02	170 41
12:09:50	50	0.029	1 02	17.288	5009.949	0.069	1 02	170.41
12:14:50	50	0.028	1.02	17.288	5009.949	0.063	1 02	170.41
12:19:50	50	0.026	1 02	17.288	5009.949	0.063	1.02	170.41
12:24:50	50	0.026	1.02	17.288	5009 949	0.059	1.02	170.41
12:29:50	50	0.024	1.02	17.288	5009.949	0 055	1 02	170.41
12:34:50	50	0.023	1.02	17.288	52042.789	0.054	1 02	170.41
12:39:50	50	0.022	1.02	17.288	200008	0.052	1 02	170.41
12.44:50	50	0.021	1.02	17.288	200008	0.05	1.02	170.41
12:49:50	50	0.021	1.02	17.288	200008	0.048	1 02	170.41
12:54:50	50	0.022	1.02	17.288	200008	0.05	1.02	170.41
12:59:50	50	0.027	1.02	17.289	200008	0.062	1 02	170.41
13:04:50	50	0.013	1 02	17.289	200008	0.037	1.02	170.41
13:09:50	50	0.012	1.02	17.289	200008	0.033	1 02	170.41
13:14:50	50	0.04	1.02	17.289	200008	0.098	1.02	170.41
13:19:50	50	0.05	1.02	17.289	200008	0.116	1 02	170.41
13:24:50	50	0.043	1.02	17.289	200008	0.101	1 02	170.41
13:29:49	50	0.039	1.02	17.289	200008	0.088	1.02	170.41
13:34:50	50	0.034	1.02	17.289	200008	0.08	1.02	170.41
13:39:49	50	0.032	1 02	17.289	200008	0.072	1 02	170.41
13:44:49	50	0.032	1.02	17.289	169472 625	0.075	1.02	170.41
13:49:49	50	0 001	1.02	17.289	102729.875	0.002	1 02	170.41
13:54:49	50	0.001	1.02	17.289	35570.266	0.001	1.02	170.41
13:59:49	50	0.001	1.02	17.289	259,997	0.001	1 02	170.41
14:04:49	50	0.001	1.02	17.289	259.997	0.001	1.02	170,41
14:09:49	50	0.001	1.02	17.289	259 997	0.001	1.02	170.41
14:14:49	50	0.001	1.02	17.289	259.997	0.001	1.02	170.41
14:19:49	50	0.001	1.02	17.289	259 997	0.001	1.02	170.41
14:24:49	50	0 001	1.02	17.289	259.997	0.001	1.02	170.41
14:29:49	50	0.001	1.02	17.289	259.997	0.001	1.02	170.41
14:31:29	50	0.001	1.02	17.289	259.997	0.001	1.02	170.41
						0.001	1.02	170.41

<u>Table 8.5.2</u>

Computer-Aided Dose Assessment Program (CADAP)
Offsite Dose Results for RCIC Steam Leak

Time: 19:46:30			Date	Jan 18, 2000
Distance	×/0	Whole Body	TEDE	Child Thyroid
SB 1 MILE 2 MILES 3 MILES 4 MILES 5 MILES 6 MILES 7 MILES 8 MILES 9 MILES	1.30E-04 7.10E-05 3.57E-05 2.35E-05 1.73E-05 1.36E-05 1.11E-05 9.42E-06 8.14E-06 7.15E-06 6.37E-06	Dose Rate (R/hr) 9.67E-05 5.17E-05 2.47E-05 1.55E-05 1.09E-05 8.15E-06 6.39E-06 5.17E-06 4.28E-06 3.60E-06 3.08E-06	Dose (R) 1.21E-03 6.48E-04 3.13E-04 1.97E-04 1.40E-04 1.06E-04 8.38E-05 6.84E-05 5.72E-05 4.86E-05 4.20E-05	Dose (R) 1.63E-02 8.83E-03 4.37E-03 2.82E-03 2.04E-03 1.57E-03 1.27E-03 1.06E-03 8.98E-04 7.78E-04 6.82E-04
М	ETEOROLOGICAL DA	ATA	* = Dose Exce	eds PAR Limits
Wind Speed: Wind Direction: Stability Class:	4.0 mph 290 deg F		RELEASE DU	RATION Hours
PRELIMINARY EM	IERGENCY CLASSIFI	CATION PROT	ECTIVE ACTION REC	COMMENDATION
· Pr	NONE based on ojected Doses	base	ed on General Emerger EVACUATE Subare	

Time Since Reactor Power < 4%: 2.00 Hours
No Damage Spectrum Used
Primary System Plateout
Filtration On
Unit 1 Vent: Low Range = 7.56E+02 cpm, Flow Rate = 8.85E+01 kcfm
Time Since Reactor Power < 4%: 2.00 Hours
No Damage Spectrum Used

Primary System Plateout No Filtration TB/HB Vent: Low Range = 2.98E+03 cpm, Flow Rate = 1.70E+02 kcfm	
Prepared by:	
Approved by:	

9. Meteorological Data:	14. Sour	ce Term used	for Calculation,	based on Core	Condition:	
(a) Wind Speed: 4.0 mph (b) Wind Direction from: 290 degrees	•	No Damage	C Clad Dama	ge 🦰 Fuel M	elt 🧲 Iso. Sa	mple
(c) Stability Class: F		-	luction factors:	:		
(d) Precipitation: C Yes © No			on Pool Temp < on Pool Temp >		(h) Unfiltered	nd
10. Recommended Protective Actions: (a) Evacuation of people as follows:	4000000000	(c) 0.5 · 24 H		- 4.14.	C () FHBVS	
Subareas 1,2,3		(d) > 24 Hour		<u>_</u>	······································	
Other		(e) Containme (f) Fuel Pool 9	ent Spray Scrubbing			
(b) Sheltering of people as follows:	V	(g) Primary Sy	stem Plateout			
Subareas	16. Proje	ected offsite d	ose at 19:46:3	Dased on a	6.00 hour re	lease duration:
Other]	Α	В	С	D	E
(c) Other:	DIST.	SECTOR(S)	TEDE RATE (REM/HR)	TEDE (REM)	C.T. RATE (REM/HR)	C.T. DOSE (REM)
11. Recommended protective actions based on: (EPI-B8)	SB	E,F&G	2.01E-04	1.21E-03	2.71E-03	1.63E-02
(a) A General Emergency has been declared.	2 miles	E,F&G	5.21E-05	3.13E-04	7.28E-04	4.37E-03
C (b) Calculations based on elevated radiation	5 miles	E.F&G	1.76E-05	1.06E-04	2.62E-04	1.57E-03
levels out plant vents.	10 miles	E,F&G	7.00E-06	4.20E-05	1.14E-04	6.82E-04
C (c) Actual field monitoring team levels		Survey Data:	***************************************	A		g k
C (d) Potential release calculations		lot Applicable	(no abnormal re	lease has occu	red).	
12 Offsite Belease Information	А	В		ם ב)	Ε
[a] Airborne release [iii (b) Liquid release	TIM # TAKI		CCITI	GAM DOSE (REM.	RATE DOSE	D THYROID REM) BASED HRS IMMER.
[c] Actual start time: hours [d] Estimated start time: hours	1 7	- -				
(e) Release duration: 6.00 hours	2					
[7] Time of Reactor Power < 4%: hours 13. Release Rates:	3					
VENT MONITOR READING RANGE FLOW RATE (kc/m) (a) UNIT 1 7.56E+02 LOW 8.850E+01		I I	irface contamina	inition:		
	1 I	-			vals at this time.	
(b) UNIT 2 8.80E+01 LOW 5.454E+01		. (ы				
(c) TB/HB 2.99E+03 LOW 1.704E+02	19. DRC	to TEDE co	nversion factor i	s: 2.07		
(d) OFFGAS 4.50E+01 LOW 11.755E+01	20. l rep	,		This is an act	ual ememencu	
	20. 1 lep	eer >:- [11				

<u>Table 8.5.3</u>

Computer-Aided Dose Assessment Program (CADAP)
Offsite Dose Results for Fuel Failure

	V 10	Whole Body	TEDE	Child Thyroic
Distance	X/Q .	Dose Rate (R/hr)	Dose (R)	Dose (R)
SB 1 MILE 2 MILES 3 MILES 4 MILES	1.16E-04 6.35E-05 3.19E-05 2.09E-05 1.54E-05	3.41E-02 1.83E-02 8.77E-03 5.47E-03 3.82E-03	2.75E+00 * 1.50E+00 * 7.45E-01 4.84E-01 3.53E-01	5.05E+01 * 2.53E+01 * 1.65E+01 * 1.21E+01 *
5 MILES 6 MILES 7 MILES 8 MILES 9 MILES	1.21E-05 9.93E-06 8.39E-06 7.25E-06 6.37E-06	2.86E-03 2.23E-03 1.80E-03 1.48E-03 1.24E-03	2.74E-01 2.23E-01 1.87E-01 1.60E-01 1.40E-01	9.46E+00 * 7.73E+00 * 6.50E+00 * 5.60E+00 * 4.90E+00
10 MILES	5.67E-06 ETEOROLOGICAL DA	1.06E-03	1.23E-01 * = Dose Eyce	4.35E+00 eds PAR Limits
Wind Speed: Wind Direction:	4.5 mph deg	710	RELEASE DU	
Stability Class:	F		A	
PRELIMINARY EM	ERGENCY CLASSIFI	CATION PROT	ECTIVE ACTION REC	COMMENDATION
GENER	AL EMERGENCY		based on projected/a	ctual doses:

Time Since Reactor Power < 4%: 2.00 Hours
Clad Damage Spectrum Used
Suppression Pool Temp < 212 F
24 Hour Holdup
Filtration On
Unit 1 Vent: Low Range = 5.01E+03 cpm, Flow Rate = 8.85E+01 kcfm
Time Since Reactor Power < 4%: 2.00 Hours

Clad Damage Spectrum Used Primary System Plateout
No Filtration FB/HB Vent: Low Range = 2.00E+05 cpm, Flow Rate = 1.70E+02 kcfm
Prepared by:
Approved by:

9. Meteorological Data: (a) Wind Speed: 4.5 mph (b) Wind Direction from: 294 degrees				based on Core	Condition: elt C: Iso. Sa	mple
(c) Stability Class: F (d) Precipitation: C Yes No	(€) (a) 9	uppression	etion factors:		(h) Unfiltera	od
10. Recommended Protective Actions: (a) Evacuation of people as follows:	C (c) (Suppression 1.5 - 24 Hou 24 Hour H		· 212 F	C (i) Filtered C (i) FHBVS	
Subareas 1, 2, 3, 4, 5 Other	(e) (f) (f)	Containmen uel Pool Sc	nt Spray crubbing			
(b) Sheltering of people as follows:			tem Plateout			
Subareas	16. Projecte	i offsite dos	se at 20:00:14	based on a	6.00 hourre	lease duration:
Other		A	В	С	D	E
(c) Other.	DIST. SEC		TEDE RATE (REM/HR)	TEDE (REM)	C.T. RATE (REM/HR)	C.T. DOSE (REM)
11. Recommended protective actions based on: (EPI-B8)	SB E.	F&G	4.58E · 01	2.75E+00	1.54E+01	9.24E+01
ে (a) A General Emergency has been declared.	2 miles E.	F & G	1.24E-01	7.45E-01	4.21E+00	2.53E+01
 (b) Calculations based on elevated radiation levels out plant vents. 	5 miles E. 10 miles E.	t G	4.57E-02 2.06E-02	2.74E-01 1.23E-01	1.58E+00 7.25E-01	9.46E+00 4.35E+00
C (c) Actual field monitoring team levels	} : * *	I	2002-02	1.236-01	7.23E-UI	14.30E+00
C (d) Potential release calculations	17. Field Sur Not A	•	no abnormal rel	ease has occur	ed).	
12. Offsite Release Information	Α	В	С	D		E
(a) Airborne release (b) Liquid release	TIME # TAKEN	DISTAN (miles)	# CCCTC	GAMI DOSE F (REM/	RATE DOSE) THYRDID REM) BASED HRS IMMER.
(c) Actual start time: hours	-	(//////////		(ITEM)	nnj 511.	THE STREET
(d) Estimated start time: hours (e) Release duration: 6.00 hours						
(f) Time of Reactor Power <4%: hours	2					
13. Release Rates:	3					
VENT MONITOR READING RANGE FLOW RATE (kc/m)	4					
(a) UNIT 1 5.01E+03 (LOW 8.850E+01	18. Estimate	ofanv surfa	ace contamina	tion:		***************************************
(b) UNIT 2 8.80E+01 LOW 5.455E+01	1	-		ere at normal lev	vals at this time.	
	₽ (6			-		
(e) TB/HB 2.00E+05 LOW 1.704E+02 (d) OFFGAS 4.50E+01 LOW 1,729E+01	19. DRD to 1	EDE conv	rersion factor is	13.22		······································
<u> </u>	20, I repeat:	∏his	isaDn ii C	This is an actu	al emergency	

SECTION 8.6 PLUME MAPS/FIELD TEAM DATA

8.6 FIELD TEAM DATA/PLUME MAPS

The following tables include data to be used by field Radiation Monitoring Teams (and their Controllers) to help track the plume and evaluate the severity of the radiological release. These data will also be used by radiological assessment personnel to correlate environmental findings to the values calculated using effluent isotopic and meteorological values.

This section contains the following:

<u>Reference</u>	<u>Title</u>	Page No.
Figure 8.6.1	thru 8.6.10 Plume Position Maps	8.6-2
Table 8.6.1	Release Rate (Time vs. Distance)	8.6-13
Table 8.6.2	Plume Position (Time vs. Distance)	8.6-15
Table 8.6.3	Closed Window Whole Body Dose Rates (Time vs. Distance)	8.6-17
Table 8.6.4	Open Window Whole Body Dose Rates (Time vs. Distance	8.6-19
Table 8.6.5	Child Thyroid Dose Rates (Time vs. Distance)	8.6-21
Table 8.6.6	Iodine Concentrations (Time vs. Distance)	8.6-23
Table 8.6.7	Silver Zeolite Cartridge Readings for PRM6/GM1 (Time vs. Distance)	8.6-25
Table 8.6.8	Lake County Field Team Data for Silver Zeolite Cartridge (Time vs. Distance)	8.6-27
Table 8.6.9	State of Ohio Field Team Data for Silver Zeolite Cartridge (Time vs. Distance)	8.6-29

PLUME POSITION MAPS

Figure No.	Time Period	Page No.
8.6.1	1235 - 1245	8.6-3
8.6.2	1245 - 1300	8.6-4
8.6.3	1300 - 1315	8.6-5
8.6.4	1315 - 1330	8.6-6
8.6.5	1330 - 1345	8.6-7
8.6.6	1345 - 1400	8.6-8
8.6.7	1400 - 1415	8.6-9
8.6.8	1415 - 1430	8.6-10
8.6.9	1430 - 1445	8.6-11
8.6.10	1445 - END	8.6-12

2000 EVEX Section 8.6 Page 2 of 30




Figure 8.5.1: 1235 to 1245




Figure 8.5.2: 1245 to 1300




Figure 8.5.3: 1300 to 1315




Figure 8.5.4 1315 to 1330




Figure 8.5.5: 1330 to 1345




Figure 8.5.6: 1345 to 1400




Figure 8.5.7: 1400 to 1415




Figure 8.5.8: 1415 to 1430




Figure 8.5.9: 1430 to 1445




Table 8.6.1

Release Rate Times

DOWNWIND DISTANCE (Miles)

TIME	S.B.	1.0	1.5	2.0	2.5	3.0	3.5	4.0	4.5	5.0
1235						•				
1245	1235	1235	. ,							
1300	1245	1245	1235	1235	1235					
1315	1300	1300	1300	1245	1245	1245	1235	1235	1235	
1330	1315	1315	1315	1315	1300	1300	1300	1245	1245	1245
1345	1330	1330	1330	1330	1315	1315	1315	1315	1300	1300
1400					1330	1330	1330	1330	1315	1315
1415		•							1330	1330
1430										
1445	•									

Table 8.6.1 (Cont.)

Release Rate Times

DOWNWIND DISTANCE (Miles)

					······································					
TIME	5.5	6.0	6.5	7.0	7.5	8.0	8.5	9.0	9.5	10.0
1235						•				
1245										
1300										
1315										
1330	1235	1235	1235							
1345	1300	1300	1245	1245	1245	1235	1235			
1400	1315	1315	1315	1300	1300	1300	1245	1245	1245	1235
1415	1330	1330	1330	1315	1315	1315	1315	1300	1300	1300
1430				1330	1330	1330	1330	1330	1315	1315
1445										1330

Table 8.6.2

Plume Position

DOWNWIND DISTANCE (Miles)

							·····			
TIME	S.B.	1.0	1.5	2.0	2.5	3.0	3.5	4.0	4.5	5.0
1235			·							
1245	XXXX	XXXX								
1300	XXXX	XXXX	XXXX	XXXX	XXXX					
1315	XXXX	XXXX	XXXX	XXXX	XXXX	xxxx	xxxx	xxxx	xxxx	
1330	XXXX	XXXX	XXXX	XXXX	XXXX	XXXX	XXXX	XXXX	XXXX	xxxx
1345	XXXX	XXXX	XXXX	XXXX	XXXX	XXXX	XXXX	XXXX	XXXX	XXXX
1400					XXXX	XXXX	XXXX	XXXX	XXXX	XXXX
1415									XXXX	XXXX
1430										мих
1445										

Table 8.6.2 (Cont.)

Plume Position

DOWNWIND DISTANCE (Miles)

TIME	5.5	6.0	6.5	7.0	7.5	8.0	8.5	9.0	9.5	10.0
1235										
1245										*
1300										
1315										
1330	XXXX	XXXX	XXXX							
1345	XXXX	XXXX	XXXX	XXXX	XXXX	XXXX	XXXX			
1400	XXXX	XXXX	XXXX	XXXX	XXXX	XXXX	XXXX	XXXX	XXXX	XXXX
1415	XXXX	XXXX	XXXX	XXXX	XXXX	XXXX	XXXX	XXXX	XXXX	XXXX
1430				XXXX	XXXX	XXXX	XXXX	XXXX	XXXX	XXXX
1445										XXXX

Page 16 of 30

Table 8.6.3

Closed Window Whole Body Dose Rates (mR/hr)

DOWNWIND DISTANCE (Miles)

TIME	S.B.	1.0	1.5	2.0	2.5	3.0	3.5	4.0	4.5	5.0
1235										
1245	BKGD	BKGD								
1300	11	10	BKGD	BKGD	BKGD					
1315	. 11	10	9.5	7.6	6.8	6.0	BKGD	BKGD	BKGD	
1330	11	10	9.5	8.6	6.9	6.0	5.2	3.8	3.0	2.4
1345	BKGD	BKGD	BKGD	BKGD	7.4	6.5	5.6	4.7	3.5	2.6
1400					BKGD	BKGD	BKGD	BKGD	4.0	3.1
1415									BKGD	BKGD
1430										
1445										
INT*	8.9E+00	8.3E+00	5.2E+00	4.4E+00	5.6E+00	4.8E+00	3.0E+00	2.3E+00	2.8E+00	2.1E+00
DOSE										
MAX** DOSE	6.7E+01	6.3E+01	5.7E+01	5.2E+01	4.6E+01	4.0E+01	3.5E+01	2.9E+01	2.4E+01	1.8E+01

^{*}INT Dose is the actual dose received if exposed at centerline for the entire release.

^{**}MAX Dose is the projected dose based on the default duration for centerline values.

¹⁾ All values represent plume centerline readings.

²⁾ For measurements taken off-centerline, interpolate between the centerline value and the edge of the plume.

³⁾ The value at the plume edge equals 1% of the centerline readings.

Table 8.6.3 (Cont.)

Closed Window Whole Body Dose Rates (mR/hr)

DOWNWIND DISTANCE (Miles)

TIME	5.5	6.0	6.5	7.0	7.5	8.0	8.5	9.0	9.5	10.0
1235				,						
1245										
1300										
1315										
1330	BKGD	BKGD	BKGD						•	
1345	2.5	2.3	1.8	1.7	1.5	BKGD	BKGD			
1400	2.8	2.6	2.4	1.9	1.7	1.6	1.2	BKGD	BKGD	BKGD
1415	BKGD	BKGD	1.3	2.2	2.0	1.8	1.6	1.2		BKGD
1430				BKGD	BKGD	BKGD	BKGD	BKGD	1.2	BKGD
1445										BKGD
										27.02
INT*	1.4E+00	1.3E+00	1.4E+00	1.5E+00	1.4E+00	9.5E-01	8.0E-01	7.6E-01	7.8E-01	5.5E-01
DOSE				1102,00).5E 01	O.OL-O1	7.0L-01	7.8E-01	J.JE-01
MAX**	1.7E+01	1.6E+01	1.4E+01	1.3E+01	1.2E+01	1.1E+01	9.6E+00	8.4E+00	7.2E+00	6.0E+00
DOSE									,,,,,,,,,,,	0.00.00

^{*}INT Dose is the actual dose received if exposed at centerline for the entire release.

^{**}MAX Dose is the projected dose based on the default duration for centerline values.

¹⁾ All values represent plume centerline readings.

²⁾ For measurements taken off-centerline, interpolate between the centerline value and the edge of the plume.

³⁾ The value at the plume edge equals 1% of the centerline readings.

Table 8.6.4
*Open Window Whole Body Dose Rates (mR/hr)

DOWNWIND DISTANCE (Miles)

TIME	S.B.	1.0	1.5	2.0	2.5	3.0	3.5	4.0	4.5	5.0
1235										
1245	2.4	2.2					·			
1300	26	24	1.9	1.7	1.5			*		
1315	26	24	22	17	16	14	BKGD	BKGD	BKGD	
1330	26	24	22	20	16	14	12	8.6	6.9	5.5
1345	2.4	2.2	2.0	. 1.8	17	15	13	11	8.0	6.1
1400					1.7	1.5	1.3	1.1	9.3	7.2
1415									BKGD	BKGD
1430										

NOTES:

1445

- 1) All values represent plume centerline readings.
- 2) For measurements taken off-centerline, interpolate between the centerline value and the edge of the plume.
- 3) The value at the plume edge equals 1% of the centerline readings.

Table 8.6.4 (Cont.)

Open Window Whole Body Dose Rates (mR/hr)

DOWNWIND DISTANCE (Miles)

TIME	5.5	6.0	6.5	7.0	7.5	8.0	8.5	9.0	9.5	10.0
1235										
1245										
1300			*							
1315										
1330	BKGD	BKGD	BKGD							
1345	5.7	5.3	4.2	3.8	3.5	BKGD	BKGD			
1400	6.4	6.0	5.5	4.4	4.0	3.6	2.7	2.4	2.0	BKGD
1415	BKGD	BKGD	3.0	5.1	4.6	4.2	3.7	2.8	2.4	
1430				BKGD	BKGD	BKGD				2.0
1445				DKOD	DKOD	מטאמ	BKGD	1.8	2.7	2.3
1443										BKGD

¹⁾ All values represent plume centerline readings.

²⁾ For measurements taken off-centerline, interpolate between the centerline value and the edge of the plume.

³⁾ The value at the plume edge equals 1% of the centerline readings.

Table 8.6.5
Child Thyroid Dose Rates (mRem/hr)

DOWNWIND DISTANCE (Miles)

TIME	S.B.	1.0	1.5	2.0	2.5	3.0	3.5	4.0	4.5	5.0
1235										
1245	260	240								
1300	2600	2400	200	190	170					
1315	2600	2400	2200	1800	1600	1400	120	100		
1330	2600	2400	2200	2000	1600	1400	1300	930	770	640
1345	260	240	220	200	1700	1600	1400	1200	880	700
1400					190	160	140	120	1000	820
1415									110	
1430										
1445				•						
INT* DOSE	2.0E+03	1.9E+03	1.2E+03	1.0E+03	1.3E+03	1.1E+03	7.2E+02	5.8E+02	7.2E+02	5.6E+02
MAX** DOSE	1.5E+04	1.4E+04	1.3E+04	1.2E+04	1.1E+04	9.6E+03	8.4E+03	7.2E+03	6.0E+03	4.8E+03

NOTES:

- 1) All values represent plume centerline readings.
- 2) For measurements taken off-centerline, interpolate between the centerline value and the edge of the plume.
- 3) The value at the plume edge equals 1% of the centerline readings.

Section 8.6

^{*}INT Dose is the actual dose received if exposed at centerline for the entire release.

^{**}MAX Dose is the projected dose based on the default duration for centerline values.

Table 8.6.5 (Cont.)

Child Thyroid Dose Rates (mRem/hr)

DOWNWIND DISTANCE (Miles)

									
5.5	6.0	6.5	7.0	- 7.5	8.0	8.5	9.0	9.5	10.0
670	630		480	450					
750	710	670	560	520	490	380	350	320	
		370	640	600	560				350
									390
3.9E+02	3.7E+02	4.0E+02	4.4E+02	4.1E+02	2.9E+02	2.5E+02	2.6E+02	2.8E+02	2.0E+02
4.6E+03	4.3E+03	4.1E+03	3.8E±03	3 6E±03	3 4E+03	3 1F+03	2 9F+03	2 6E±03	2.4E+03
			2.52.00	2,023.03	55.05	3.12103	2.72.103	2.015+05	2.4L1Q3
	670 750	670 630 750 710 3.9E+02 3.7E+02	670 630 510 750 710 670 370 3.9E+02 3.7E+02 4.0E+02	670 630 510 480 750 710 670 560 370 640 3.9E+02 3.7E+02 4.0E+02 4.4E+02	670 630 510 480 450 750 710 670 560 520 370 640 600 3.9E+02 3.7E+02 4.0E+02 4.4E+02 4.1E+02	670 630 510 480 450 750 710 670 560 520 490 370 640 600 560 3.9E+02 3.7E+02 4.0E+02 4.4E+02 4.1E+02 2.9E+02	670 630 510 480 450 750 710 670 560 520 490 380 370 640 600 560 520 3.9E+02 3.7E+02 4.0E+02 4.4E+02 4.1E+02 2.9E+02 2.5E+02	670 630 510 480 450 750 710 670 560 520 490 380 350 370 640 600 560 520 420 250 3.9E+02 3.7E+02 4.0E+02 4.4E+02 4.1E+02 2.9E+02 2.5E+02 2.6E+02	670 630 510 480 450 750 710 670 560 520 490 380 350 320 370 640 600 560 520 420 380 250 430 3.9E+02 3.7E+02 4.0E+02 4.4E+02 4.1E+02 2.9E+02 2.5E+02 2.6E+02 2.8E+02

^{*}INT Dose is the actual dose received if exposed at centerline for the entire release.

- 1) All values represent plume centerline readings.
- 2) For measurements taken off-centerline, interpolate between the centerline value and the edge of the plume.
- 3) The value at the plume edge equals 1% of the centerline readings.

^{**}MAX Dose is the projected dose based on the default duration for centerline values.

Table 8.6.6

Iodine Concentrations in uCi/cc

DOWNWIND DISTANCE (Miles)

-										
TIME	S.B.	1.0	1.5	2.0	2.5	3.0	3.5	4.0	4.5	5.0
1235										
1245	1.3E-07	1.2E-07								
1300	1.3E-06	1.2E-06	1.0E-07	9.3E-08	8.4E-08					
1315	1.3E-06	1.2E-06	1.1E-06	8.8E-07	8.0E-07	7.1E-07	5.9E-08	5.1E-08		
1330	1.3E-06	1.2E-06	1.1E-06	1.0E-06	8.1E-07	7.2E-07	6.3E-07	4.7E-07	3.9E-07	3.2E-07
1345	1.3E-07	1.2E-07	1.1E-07	1.0E-07	8.7E-07	7.8E-07	6.8E-07	5.8E-07	4.4E-07	3.5E-07
1400					9.3E-08	8.2E-08	7.2E-08	6.2E-08	5.1E-07	4.1E-07
1415									5.4E-08	
1430									***************************************	
1445								•		

- 1) All values represent plume centerline readings.
- 2) For measurements taken off-centerline, interpolate between the centerline value and the edge of the plume.
- 3) The value at the plume edge equals 1% of the centerline readings.

Table 8.6.6 (Cont.)

Iodine Concentrations in uCi/cc

DOWNWIND DISTANCE (Miles)

TIME	5.5	6.0	6.5	7.0	7.5	8.0	8.5	9.0	9.5	10.0
1235										
1245		,								
1300										
1315					•					
1330										
1345	3.3E-07	3.2E-07	2.6E-07	2.4E-07	2.3E-07					
1400	3.8E-07	3.6E-07	3.4E-07	2.8E-07	2.6E-07	2.4E-07	1.9E-07	1.8E-07	1.6E-07	
1415		•	1.9E-07	3.2E-07	3.0E-07	2.8E-07	2.6E-07	2.1E-07	1.9E-07	1.7E-07
1430								1.3E-07	2.1E-07	1.9E-07
1445										
NOTES:	1)	All values represent	plume centerline re	eadings.						
	2)	For measurements to	ken off-centerline,	interpolate between	en the centerline v	alue and the edge of	of the plume.			

The value at the plume edge equals 1% of the centerline readings.

Table 8.6.7 SILVER ZEOLITE CARTRIDGE READINGS PRM6/GM-1 PRM - 6/GM-1 CPM NET

DOWNWIND DISTANCE (Miles)

TIME	S.B.	1.0	1.5	2.0	2.5	3.0	3.5	4.0	4.5	5.0
	0.2.						•			
1235										
1245	2.6E+05	2.4E+05		,			*			
1300	2.6E+06	2.4E+06	2.0E+05	1.9E+05	1.7E+05					
1315	2.6E+06	2.4E+06	2.2E+06	1.8E+06	1.6E+06	1.4E+06	1.2E+05	1.0E+05		
1330	2.6E+06	2.4E+06	2.2E+06	2.0E+06	1.6E+06	1.4E+06	1.3E+06	9.3E+05	7.7E+05	6.4E+05
1345	2.6E+05	2.4E+05	2.2E+05	2.0E+05	1.7E+06	1.6E+06	1.4E+06	1.2E+06	8.8E+05	7.0E±05
1400					1.9E+05	1.6E+05	1.4E+05	1.2E+05	1.0E+06	8.2E+05
1415									1.1E+05	
1430			•							

NOTES:

1445

- 1) All values represent plume centerline readings.
- 2) For measurements taken off centerline, interpolate between the centerline value and the edge of the plume.
- 3) The value at the plume edge equals 1% of the centerline readings.
- 4) The valve is for both the filter adsorber and the bare adsorber.

Table 8.6.7 (Cont.)

PRM - 6/GM-1 CPM (NET)

DOWNWIND DISTANCE (Miles)

TIME	5.5	6.0	6.5	7.0	7.5	8.0	8.5	9.0	9.5	10.0
1235										
1245										
1300										
1315										
1330										
1345	6.7E+05	6.3E+05	5.1E+05	4.8E+05	4.5E+05					
1400	7.5E+05	7.1E+05	6.7E+05	5.6E+05	5.2E+05	4.9E+05	3.8E+05	3.5E+05	3.2E+05	
1415			3.7E+05	6.4E+05	6.0E+05	5.6E+05	5.2E+05	4.2E+05	3.8E+05	3.5E+05
1430								2.5E+05	4.3E+05	3.9E+05
1445										

- 1) All values represent plume centerline readings.
- 2) For measurements taken off centerline, interpolate between the centerline value and the edge of the plume.
- 3) The value at the plume edge equals 1% of the centerline readings.
- 4) The valve is for both the filter adsorber and the bare adsorber.

Table 8.6.8

Lake County Field Team Data Silver Zeolite Cartridge -Net Counts for 1 Minute (1-131)

DOWNWIND DISTANCE (Miles)

TI 15	~ -									
TIME	S.B.	1.0	1.5	2.0	2.5	3.0	3.5	4.0	4.5	5.0
1235					•					
1245	7.72E+03	7.13E+03						•		
1300	7.72E+04	7.13E+04	5.94E+03	5.52E+03	4.99E+03					
1315	7.72E+04	7.13E+04	6.53E+04	5.23E+04	4.75E+04	4.22E+04	3.50E+03	3.03E+03		
1330	7.72E+04	7.13E+04	6.53E+04	5.94E+04	4.81E+04	4.28E+04	3.74E+04	2.79E+04	2.32E+04	1.90E+04
1345	7.72E+03	7.13E+03	6.53E+03	5.94E+03	5.17E+04	4.63E+04	4.04E+04	3.45E+04	2.61E+04	2.08E+04
1400					5.52E+03	4.87E+03	4.28E+03	3.68E+03	3.03E+04	2.44E+04
1415									3.21E+03	2.442.04
1430								•	3.2113.03	
1445			*							

- 1) All values represent plume centerline readings.
- 2) For measurements taken off-centerline, interpolate between the centerline value and the edge of the plume.
- 3) The value at the plume edge equals 1% of the centerline readings.
- 4) Air sample volume 90,000 cc = sample flow rate: 60L/min; sample time.
- 5) Silver Zeolite Cartridge Efficiency: 90%.
- 6) Ag2 Efficiency (used to measure Ag2 for I-131): 5.8%.
- 7) Maximum meter range 1.0E7 counts.
- 8) Assume filter activity approximately zero (no particulates).
- 9) Concentrations from Table 8.6.6 multiplied by a conversion factor of 5.94E10 to determine counts per minute (cpm).

Table 8.6.8 (Cont.)

Lake County Field Team Data Silver Zeolite Cartridge -Net Counts for 1 Minute (I-131)

DOWNWIND DISTANCE (Miles)

TIME	5.5	6.0	6.5	7.0	7.5	8.0	8.5	9.0	9.5	10.0
1235 1245 1300 1315										
1330 1345	1.96E+04	1.90E+04	1.54E+04	1.43E+04	1.37E+04					
1400 1415	2.26E+04	2.14E+04	2.02E+04 1.13E+04	1.66E+04 1.90E+04	1.54E+04 1.78E+04	1.43E+04 1.66E+04	1.13E+04 1.54E+04	1.07E+04 1.25E+04	9.50E+03 1.13E+04	1.01E+04
1430 1445	**.							7.72E+03	1.25E+04	1.13E+04

- 1) All values represent plume centerline readings.
- 2) For measurements taken off-centerline, interpolate between the centerline value and the edge of the plume.
- 3) The value at the plume edge equals 1% of the centerline readings.
- 4) Air sample volume 90,000 cc = sample flow rate: 60L/min; sample time.
- 5) Silver Zeolite Cartridge Efficiency: 90%.
- 6) Ag2 Efficiency (used to measure Ag2 for I-131): 5.8%.
- 7) Maximum meter range 1.0E7 counts.
- 8) Assume filter activity approximately zero (no particulates).
- 9) Concentrations from Table 8.6.6 multiplied by a conversion factor of 5.94E10 to determine counts per minute (cpm).

Table 8.6.9

State of Ohio Field Team Data Silver Zeolite Cartridge -Net Counts for 1 Minute (1-131)

DOWNWIND DISTANCE (Miles)

TIME	S.B.	1.0	1.5	2.0	2.5	3.0	3.5	4.0	4.5	5.0
1235										
1245	7.72E+03	7.13E+03								
1300	7.72E+04	7.13E+04	5.94E+03	5.52E+03	4.99E+03		•			
1315	7.72E+04	7.13E+04	6.53E+04	5.23E+04	4.75E+04	4.22E+04	3.50E+03	3.03E+03		
1330	7.72E+04	7.13E+04	6.53E+04	5.94E+04	4.81E+04	4.28E+04	3.74E+04	2.79E+04	2.32E+04	1.90E+04
1345	7.72E+03	7.13E+03	6.53E+03	5.94E+03	5.17E+04	4.63E+04	4.04E+04	3.45E+04	2.61E+04	2.08E+04
1400					5.52E+03	4.87E+03	4.28E+03	3.68E+03	3.03E+04	2.44E+04
1415									3.21E+03	
1430										

NOTES:

1445

- 1) All values represent plume centerline readings.
- 2) For measurements taken off-centerline, interpolate between the centerline value and the edge of the plume.
- 3) The value at the plume edge equals 1% of the centerline readings.
- 4) If no data is provided, assume BKGD levels.
- 5) Iodine Cartridge Data:
 - Air sample flow rate = 60L/min
 - Probe efficiency = 10%
 - Sample run time = 5 minutes
- 6) Concentrations from Table 8.6.6 multiplied by a conversion factor of 5.94E10 to determine counts per minute (cpm).

Table 8.6.9 (Cont.)

State of Ohio Field Team Data Silver Zeolite Cartridge -Net Counts for 1 Minute (I-131)

DOWNWIND DISTANCE (Miles)

TIME	5.5	6.0	6.5	7.0	7.5	8.0	8.5	9.0	9.5	10.0
1235		•								
1245										
1300										
1315						,				
1330										
1345	1.96E+04	1.90E+04	1.54E+04	1.43E+04	1.37E+04					
1400	2.26E+04	2.14E+04	2.02E+04	1.66E+04	1.54E+04	1.43E+04	1.13E+04	1.07E+04	9.50E+03	
1415			1.13E+04	1.90E+04	1.78E+04	1.66E+04	1.54E+04	1.25E+04	1.13E+04	1.01E+04
1430			•					7.72E+03	1.25E+04	. 1.13E+-4
1445										• • • • • • •

- 1) All values represent plume centerline readings.
- 2) For measurements taken off-centerline, interpolate between the centerline value and the edge of the plume.
- 3) The value at the plume edge equals 1% of the centerline readings.
- 4) If no data is provided, assume BKGD levels.
- 5) Iodine Cartridge Data:
 - Air sample flow rate = 60L/min
 - Probe efficiency = 10%
 - Sample run time = 5 minutes
- 6) Concentrations from Table 8.6.6 multiplied by a conversion factor of 5.94E10 to determine counts per minute (cpm).

9.0 MINI-SCENARIOS

This section contains summaries for following system and equipment casualties. Each scenario outlines the indications, cause, and postulated response for each casualty postulated in the Initial Conditions (Section 6.1) and Perry Plant Sequence of Events (Section 6.2).

	Mini-Scenario Title	Page No.
1.	Repairs to Safety-Related Instrument Air Header 'B'Isolation Valve, 1P57-F015B (Initial Condition)	9.0-1
2.	Preventive Maintenance on Standby Liquid Control (SLC) 'A' Pump, 1C41-C001A [Initial Condition]	9.0-7
3.	Failure of Residual Heat Removal (RHR) 'B' Pump Minimum Flow Valve, 1E12-F064B	9.0-12
4.	Fire in RHR 'A' Pump Room, 1E12-C001A	9.0-16
5.	Radiologically Contaminated Injury	9.0-22
5A.	Sabotage in a Plant Vital Area	9.0-28
6.	Rod Control and Information System (RC&IS) Rod Block	9.0-30
7.	Loss of power to Control Room Annunciators	9.0-34
8.	Failure of SLC 'B' Pump, 1C41-C001B, to Start	9.0-36
9.	Failure of Reactor Core Isolation Cooling (RCIC) Steam Supply Inboard Valve, 1E51-F063, to Close	9.0-39
10.	Motor Feed Pump (MFP), 1N27-C004, Trip	9.0-44

Each mini-scenario contains the following sections as applicable:

- Approximate Time(s)
- Location(s)
- Required Set-up
- Event Summary
- Postulated Sequence of Events
- References
- Attachments

While designed to allow for free play by participants, each mini-scenario is also an integral part of the overall sequence of exercise events. Therefore, controllers may make adjustments as noted to ensure the exercise scope and time line remain within established parameters.

Mini-Scenario No. 1

Repairs to Safety-Related Instrument Air Header 'B' Isolation Valve, 1P57-F015B

APPROXIMATE TIME: Initial Condition

LOCATION:

Actual -

620' elevation, Auxiliary Building (AXC/08-620)

REQUIRED SET-UP:

- 1. Valve mockup pre-positioned.
- 2. Work Order Package
- 3. Clearance Package
- 4. Active LCO (12 hour LCO per TS 3.5.1)
- 5. Active LCO (12 hour LCO per TS 3.3.6.1)
- 6. Potential LCO (TS 3.4.4)

EVENT SUMMARY: Header 'B' of the Safety-Related Instrument Air System (P57) was isolated and tagged out at 0500 hours today as part of a planned system outage to effect repairs to Containment Penetration valve, 1P57-F015B, which has a severe packing leak. Valve inspection revealed a leaking diaphragm and packing. Design Engineering is dispositioning a use-as-is NCC-CR due by 0900 to tighten packing to reduce the leak.

A temporary air supply has been installed in Containment on test connection valve 1P57-F526B, per temporary modification #XXXX, as a reserve to make-up for expected header leakage. The valve 1P57-F0015B is tagged out as an initial condition. The header is expected to be returned to service by 1000 hours.

NOTE: The purpose of the P57 System is to supply compressed air to the Automatic Depressurization System (ADS) safety relief valve accumulators and non-ADS SRV B21-F051D. Of the eight ADS SRVs, four SRVs are supplied from the 'A' Header, including non-ADS SRV 1B21-F051D, and four SRVs from the 'B' Header.

Refer to Attachment 1 for a simplified drawing of the Safety-Related Instrument Air (P57) System. A more detailed layout is available on plant drawing D-302-271.

POSTULATED SEQUENCE OF EVENTS

- 1. The Design Engineer dispositioned the CR by recommending that the packing be tightened and no MOVATS testing be done due to large margin, and that further inspection be performed as part of Refueling Outage (RFO) No. 8. Valve repairs should commence on a risk basis while the CR is being routed for disposition. An Operability determination / 10CFR 50.59 Engineering Management approval is required
- 2. SVI-P57-T9119 has been revised to allow performance of the LLRT in Modes 1, 2 &3.
- 3. At 1015 hours, the 'A' Header is depressurized due to a weld failure in Containment. ADS capability is now limited to the pressure available in the SRV accumulators.
 - NOTE: These accumulators ensure an adequate air supply in the event of a P57 system failure. The accumulator capacity is sufficient to provide two valve actuations during Loss of Coolant Accident (LOCA) conditions.
- 4. Efforts to reassemble 1P57-F015B valve and restore the 'B' Header should be expedited. Consideration should be given toward supplying air pressure to the ADS/SRV accumulators via one of the test connections in Containment. However, at approximately 1050 hours, access to Containment will be restricted due to a low power Anticipated Transient Without a Scram (ATWS).

Tighten Packing. On opening valve electronically, it trips on overload relay and/or fuses due to over-torque of packing gland, causing stem binding. Controller to adjust scenario as required to fit the timeline. Repair MCC bucket, readjust packing to loosen it up. Manual operation of valve not possible, due to MOV jamming stem in place or broken shaft key.

5. At approximately 1315 hours, reassembly of the 1P57-F015B valve is completed.

Controllers must allow sufficient time to clear tagout and realign the system. The status of repairs activities must also be clearly communicated to the Simulator Driver by OSC controllers.


6. At 1335 hours, the 'B' Header is returned to service and ADS is initiated to depressurize the Reactor Pressure Vessel (RPV) per Plant Emergency Instruction (PEI) B13, RPV Control (ATWS).

REFERENCES:

- System Design Manual (SDM) P57, "Safety-Related Instrument Air System"
- Plant Drawing D-302-271 (system piping diagram)
- Plant Drawing 4549-40-1048 (Sheet 3)


ATTACHMENTS:

- 1. SDM-P57 System Diagram
- 2. CR documenting 1P57-F015B packing leak
- 3. 1P57-F015B Valve Assembly



90-4

Mini-Scenario No. 1 Attachment 2



1P57-F015B VALVE ASSEMBLY

Mini-Scenario No. 1 Attachment 3

Preventive Maintenance on Standby Liquid Control (SLC) 'A' Pump, 1C41-C001A

APPROXIMATE TIME: Initial Condition

LOCATION:

Actual -

642' elevation, Containment (C 0/642)

REQUIRED SET-UP:

- 1. Prestaged oil sample with water.
- 2. Work Order Package
- 3. Tagout (MPL #: 1C41-C0001A)
- 4. Active LCO (7 day LCO per TS 3.1.7)

EVENT SUMMARY: During third shift, Repetitive Task No. 1C41C0001A File 1 (Attachment 1) was initiated to replace the crankcase and gearbox oil and lubricate SLC 'A' Pump. Upon draining pump oil, the sample taken for Chemistry analysis appears to contain water. A CR (Attachment 2) was written and forwarded to the Control Room during shift turnover.

At the start of the exercise, the SLC 'A' Pump is tagged out and work has been suspended awaiting engineering evaluation. No oil is present in the pump crankcase or gearbox. The work area has been cleared due to material accountability concerns inside Containment.

SLC 'B' Pump, 1C41-C001B, is operable.

POSTULATED SEQUENCE OF EVENTS:

- 1. Upon receiving the CR during crew turnover, the Control Room Shift Supervisor will complete the Control Room portion of the CR form per PAP-1608, "Corrective Action Program", and contact the RSE or designated engineering support to identify the source of the water in leakage into the pump crankcase.
- 2. Any initial efforts following turnover to inspect the SLC 'A' Pump or to flush the pump and replace the oil should be suspended at 0720 hours when personnel are directed to exit Containment due to a stuck open SRV.

3. Further efforts to evaluate and restore the SLC 'A' Pump should be suspended due to changing plant priorities until an ATWS and subsequent failure of SLC 'B' Pump to start (Mini-Scenario No. 8) occurs at approximately 1050. With the loss of both SLC pumps, Operators should line up for alternate boron injection per PEI: Special Plant Instruction (SPI) 1.8.

NOTE: Alternate boron injection into the RPV is performed via the High Pressure Core Spray (HPCS) flush connection 1E22-F031 using the SLC Transfer System and the Alternate Boron Injection Pump. The estimated time to line-up and initiate alternate boron injection is approximately 4 hours.

Players will be allowed to perform PEI SPI-1.8 actions to line-up for alternate boron injection. However, efforts can NOT be successful until after the SLC 'B' Pump is restored to service at approximately 1320 hours since the Simulator does NOT model alternate boron injection. If required, controllers will interject a problem with installing the ABI connection assembly end of the high-pressure hose to the HPCS flush connection.

4. If after evaluation of ALARA concerns, a decision is made to enter Containment to replace the oil in SLC 'A' Pump, the pump will start but mechanically seize after approximately 5 minutes. (Ensure this is communicated to the Simulator Controller)

No further action to enter Containment should be considered following the Motor Feed Pump (MFP) trip (Mini-Scenario No. 10) and subsequent RPV level inventory loss at 1225 hours.

REFERENCES:

- PEI:SPI-1.8, "Alternate Boron Injection"
- Plant Drawing D-302-692, "SLC Transfer System"
- Plant Drawing D-302-701, "HPCS"

ATTACHMENTS:

- 1. Repetitive Task No. 1C41C0001A File 1
- 2. CR Form (documenting sample contamination)

Mini-Scenario No. 2 Attachment 1 (Sheet 1 of 2)

Mini-Scenario No. 2 Attachment 1 (Sheet 2 of 2)

Mini-Scenario No. 2 Attachment 2

Residual Heat Removal (RHR) Minimum Flow Valve, 1E12-F064B

APPROXIMATE TIME: Approximately 0725 hours

LOCATION: Actual - 574' elevation, Auxiliary Building (AXC/03-574)

REQUIRED SET-UP:

1. Mockup pre-positioned simulating a 4" motor-operated gate valve.

NOTE: Ensure mock-up is set up in area of low background radiation.

EVENT SUMMARY: RHR 'B' Minimum Flow Valve, 1E12-F064B, fails to fully closed when the RHR 'B' Loop is placed in Suppression Pool Cooling Mode in response to an SRV inadvertently opening. Flow is reduced to the RHR 'B' Heat Exchanger, which in turn reduces cooling for the Suppression Pool (Attachment 1).

POSTULATED SEQUENCE OF EVENTS:

- 1. When an Operator attempts to realign the RHR 'B' Loop into Suppression Pool Cooling Mode per System Operating Instruction (SOI) E12, the OPEN position indicator light on panel 1H13-P680 for the 1E12-F064B valve will extinguish, but the CLOSED position light does NOT illuminate.
- 2. A Perry Plant Operator (PPO) should be dispatched to the 1E12-F064B valve, and upon close inspection, will observe that the packing gland is cocked, thus mechanically binding the valve and preventing valve stem movement.

This will cause the torque switch to interrupt the control circuitry as if the valve were closed (Attachment 2).

3. The Control Room may direct PPO to close manual isolation valve 1E12-F018B, thus increasing flow to the RHR 'B' Heat Exchanger.

Operator action to close the 1E12-F018B valve would result in a loss of minimum flow protection.

If 1E12-F018B is closed, controller <u>must</u> report action immediately to Simulator Driver.

4. An OSC team will be dispatched to relax the gland nuts and realign the packing gland on the 1E12-F064B valve. However, upon further inspection the team members note that the packing gland has gouged into the stem causing a visible burr on the stem.

This can be corrected with a file and emery cloth after the packing gland is straightened and tightened. The 1E12-F064B valve can then be stroked closed either manually or with the normal control circuitry.

The 1E12-F064B valve should be restored at 0950, but can be closed as early as 0930 hours.


If it is necessary to slow the progress of this evolution, workers will observe fluid leaking around the packing gland. This should result in increased radiological controls being imposed at the work site.

REFERENCES:

- SOI-E12, "Residual Heat Removal System (Unit 1)"
- Plant Drawing D-208-055 (Sheet A39)
- Plant Drawing D-302-643
- System Design Manual (SDM) E12, "Residual Heat Removal System"


ATTACHMENTS:

- 1. Suppression Pool Cooling Flowpath (SDM Figure E12-4)
- 2. RHR Pump Minimum Flow Valve Control Circuitry (SDM Figure E12-23)



SUPPRESSION POOL COOLING FLOWPATH

Mini-Scenario No. 3
Attachment 1



RHR PUMP MINIMUM FLOW VALVE CONTROL CIRCUITRY

Mini-Scenario No. 3
Attachment 2

Fire in RHR 'A' Pump Room, 1E12-C001A

APPROXIMATE TIME: 0750 hours

LOCATION:

Actual -

574' elevation, Auxiliary Building -

RHR 'A' Pump Room (Room 3)

REQUIRED SET-UP:

1. Materials prestaged in RHR 'A' Pump Room.

EVENT SUMMARY: The Control Room receives a call from a Maintenance Planner who discovered an injured individual outside of RHR "A" pump room. He states that the individual is a System Engineer who has lacerated his left forearm on scaffolding erected inside the RHR "A" pump room, and he also smells a strong odor of smoke in the area. This is immediately followed by SAS receiving multiple smoke detector alarms from Smoke Detector Panel 1H51-P0929, SAS Address 911.01. SAS notifies the Control Room of the probable fire event and the Control Room requests SAS to tone out the first-aid team / fire brigade and notify Perry Township Fire Dept. per PAP-1911and EPI-B004. SAS Tones out the first-aid team / fire brigade, dispatches a first responder, and notifies Central Communications (911) to request Perry Township Fire Department. Upon arrival of the first responder on scene, he observes the injured individual at the north/west portion of AUX 574' holding his arm. When the first responder arrives at the RHR "A" pump room, he observes heavy smoke conditions inside the pump room and paint blistering on the inner water tight door. The first responder relays his findings to the SAS / Control Room.

The System Engineer is contaminated and injured (Mini-Scenario No. 5) but is able to exit the room with out assistance.

POSTULATED SEQUENCE OF EVENTS:

1. The Secondary Alarm Station (SAS) receives the following smoke detector alarms:

"911.01 AL FIR 9-SD'S: FOR E. RHR RMS. ALL LVLS AUX-1 SDP P929 IB620 D-2"

A first responder is dispatched by SAS to investigate, and the Fire Brigade/First-Aid Team are "toned out" per PAP-1911and EPI-B004.

2. Operators received and acknowledge the following annunciators on panel 1H13-P601:

AMB TEMP HIGH P632 (greater than 120°F)
RHR EQUIP AREA DIFF TEMP HIGH P632 (▲T greater than 20°F)

Recorder/meter E31-N610AT indicates a room temperature of 145F.

RHR 'A' Room ambient and differential temperatures will remain below 153°F and 49°F respectively to preclude an automatic RHR and RCIC isolation.

3. The Control Room receives a call from a Maintenance Planner who discovered an injured individual outside of RHR "A" pump room. He states that the individual is a System Engineer who lacerated his right arm on scaffolding erected inside RHR "A" pump room, and he also smells a strong odor of smoke in the area.

If NOT secured by 0753 hours, the RHR 'A" Pump will trip.

- 4. When the first responder arrives at the RHR "A" pump room, he observes heavy smoke conditions inside the pump room and paint blistering on the inner water tight door. The first responder relays his findings to the SAS / Control Room.
- 5. Perry Township Fire Department (PTFD) is notified per PAP-1911 by the SAS. Upon arrival at the Primary Access Control Point (PACP), PTFD vehicles and personnel will be processed into the Protected Area per Security Posting Instruction (SPI) 0010 and issued dosimetry per Emergency Plan Implementing Instruction (EPI) B11.

PTFD personnel will be allowed in limited numbers to respond to the fire scene.

6. The Fire Brigade will mobilize and combat the fire per PAP-1911. While combating the fire, the RHR 'A'' Pump and surrounding area will be hosed down.

CAUTION

Drill play within the RHR 'A' Pump Room will be strictly controlled and limited to spaces well outside of posted radiologically contaminated areas.

7. During the post-fire damage assessment, no physical damage to the RHR 'A' Pump will be observed. However, pump motor internals are wet, as a result of hose spray.

8. The TSC, once operational, should coordinate efforts to dry and megger the pump motor.

Efforts to restore the RHR 'A' Pump can be successful after 0945 hours. Any attempt to start the RHR 'A' Pump prior to 0945 hours will result in a pump trip.

REFERENCES:

- PAP-1911, "Fire Emergencies"
- Prefire Plan Instruction (FPI) 1AB, "Auxiliary Building Unit 1"
- SPI-0010, "Vehicle Access"
- EPI-B11, "Emergency Dosimetry Issue"
- EPI-B004 First-Aid and Medical Care

ATTACHMENTS:

- 1. FPI-1AB: Unit 1 RHR 'A' System, 574' elevation
- 2. Radiological Survey Report

Mini-Scenario No. 4

PNPP No. 8282-7

UNIT 1 - RHR A SYSTEM 574' - 10" ELEVATION

FIRE ZONE IABIB

OM17B: FPI-LAB PAGE : 3 REV. : n

SAFE SHUTDOWN EQUIPMENT/CIRCUITS

THIS FIRE ZONE CONTAINS COMPONENTS AND CIRCUITS FOR METHOD A SYSTEMS AND ONLY CIRCUITS FOR METHOD B SYSTEMS. FOR A FIRE IN THIS ZONE SAFE SHUTDOWN COULD BE ACHIEVED UTILIZING METHOD B SYSTEMS AND EQUIPMENT. METHOD B CONDUITS HAVE BEEN WRAPPED WITH A 1 HOUR RATED FIRE BARRIER.

METHOD AZ COMPONENTS FOR LPCS LOCATED IN THIS FIRE ZONE. COMPONENTS

1E21-F005 INJECTION VALVE (OUTBOARD ISOLATION)

MINIMUM RETURN FLOW VALVE TO SUPPRESSION POOL 1E21-F011

1E21-F012 FULL FLOW BYPASS TEST VALVE

METHOD A2 CIRCUITS FOR LPCS ADS

1E21C4A 1E21F2A 1E21F5A

CONTAINED IN CONDUITS AND TRAYS:

1R33F84A 1R33F56A 1R33F55A IR33F189A 691

FIRE DAMAGE OR DAMAGE RESULTING FROM SUPPRESSION ACTIVITIES TO CIRCUITS FOR METHOD B WOULD NOT PREVENT SAFE SHUTDOWN. CIRCUITS FOR RHR VALVES 1E12-F040 AND IB21-F065B ARE ONLY NEEDED FOR SHUTDOWN COOLING OPERATION OF RHR AND COULD BE MANUALLY OPERATED. PLANT PROCEDURE ONI-P54 DESCRIBES OPERATION. REMAINING CIRCUIT FOR METHOD B SYSTEMS SERVING THE AIR SYSTEM VALVE 1P57-F015B, LOCATED IN CONDUITS 1P57F2B AND 1R33F1051B IS WRAPPED IN A ONE-HOUR FIRE RATED ENCLOSURE THROUGHOUT THE ZONE.

HAZARDS

FLAMMABLE-COMBUSTIBLE GASSES/LIQUIDS

LUBRICATING OIL 50 GAL. VALVE OPERATING GREASE 21 LBS.

ELECTRICAL

480 VOLT POWER AND CONTROL CABLE **4160 VOLT POWER**

ORDINARY COMBUSTIBLE

MOTOR WINDING INSULATION CABLE INSULATION

RADIOLOGICAL

RADIATION AREA CONTAMINATED AREA UNDER FLOOR GRATING

SUPPRESSION

SUPPRESSION EQUIPMENT

	MPL	LOCATION
2 · ABC EXTING.	1P54-D7107M	AXB-04
	1P54-D7108M	AXC-09
2 - MANUAL WATER	1P54-D719	AXC-09
HOSE REELS	1P54-D5263	AXA-07
	IP54-D5264	AXA-03
	1P54-D722	AXC-01

RECOMMENDED DOOR ACCESS

PRIMARY - 599° CC TO IB DOWN STAIRWAY TO 574' IB THROUGH IB-101 ENTER AX-207 ALTERNATE - AX-406 TO STAIRWAY DOWN TO 568
AX THROUGH AX-101 ENTER

DETECTION

SMOKE DETECTORS 1H51-P929, PANEL LOCATED 1B-620

COMMUNICATION

MPL LOCATION GAITRONICS 1R51-H091 80-AXA 1R51-H092 AXB-08 1R51-H094 AXB-05 1851.8250 AXD-08

RECOMMENDED COMMAND POST

IB-620 **DOOR IB-301**

RESTRICTED RADIO AREA

AREA OF 574' WEST SIDE WITHIN 15 FT, OF PANEL

VENTILATION

RECOMMENDED MUSTER POINT

IB-620 **DOOR IB-301**

ij

IM38-C001 A & B - SUPPLY ACTIVATION OF DUCT MOUNTED SMOKE DETECTOR WILL SHUT DOWN M38 SUPPLY FAN. EXHAUST FANS WILL STILL BE OPERABLE. 1M38-C002 A & B · EXHAUST 1M39-B001A - PUMP ROOM COOLER

The second of th

CAUTION

STEEL GRATED FLOORS

UNPROTECTED OPENING ON THE EAST WALL AT 620' ELEV. EXPOSES AREA 1AB-3A TO THE FIRE

Mini-Scenario No. Attachment 1 (Sheet 1 of


(2000 EVEX)


CECT 00-19

PNPP No. 8282-7 PAP-1922

UNIT 1 - RHR A SYSTEM 574' - 10" ELEVATION

OM17B: FPI-IAB Page : 4 Rev. : 0





Mini-Scenario No. 4 Attachment 1 (Sheet 2 of 2)

'NPP No. 7247 Rev. 9/93 NSTRUMENT		——————————————————————————————————————		HPI-	12				
N31KUMEN I	MPL .	CAL DUE	RWP 1	Na			DATE	7	пме
NSTRUMENT	MPL #	CAL DUE	AREA						
NSTRUMENT				'A' RHR	PU	MP ROOM			
431ROMENT	MPL /	CAL DUE	PURPO	OSE ·					
STRUMENT	MPL /	CAL DUE		-					
EACTOR POWER	L ATT SALE			·•••					
		PLE No. 1 #Ci/cc C	Ci/on	AIR.SAMPL	E Na		_		
CAECA BI OCA IN CIN			picira:	P			c		
CHECK BLOCK IF SUF	RVEY OF A SPILL AREA]			AINATIOI I dpm/100		LIS
				}		·			
AA	A : .				No.	SMEAR		BTA- MMA	ALPH
(4)					1	عصاك		K	1
7		•	•		3		$\overline{}$	<u>K</u>	
U				F	4			<u>K</u>	
			•	<u> </u>	5	 		K	-
N	Je.			T-	6			K	-
	(10)	ES V		· -	7			K	
	1			-	8		4		
		(g)		Γ	9	J	4		
N/		(8)			10	floor	6	K	
		.: 15	j		11	SOP	1 2	IK	
Q .				Ŀ	12				
		1 (7)		L	13				
		20 6		L	14				
•	4 (-	15				
_	* * * *	بلبل		ļ	16				
		Posted		}	17				
:		H. ROP, DEM (C)		<u>. </u>	18	·	_		
	(3)	in Bo	X	L	20	<u> </u>			
	. کار	. 015 0		}	21		- -		
	(o :	<u>۱۳۰۸-۲</u>		-	2			-	
	<u>a</u> d	18861.10	Ť		3			\dashv	
Doct	1 0 25	H, Dem			4		1		-:
, R	INP PAD	Rup		. 2	25				
	2220			2	6		1	1	
				2	7		1	1	
		•	•	2	8				
^	•			2	9				
Ull ger	neral are	a doserate	s as	_ 3	0				
i i	1		-						•
reac	ያ • _	_							
PRODUCTION OF THE PROPERTY OF	(Dose rates are	in mrem/hr at approx. S' above	the floor unles	otherwise note	d)				

Mini-Scenario No. 4 Attachment 2

Mini-Scenario No. 5

Radiologically Contaminated Injury

APPROXIMATE TIME: 0750 hours

LOCATION:

Actual -

574' elevation, Auxiliary Building -

RHR 'A' Pump Room (Room 3)

REQUIRED SET-UP:

1. Moulage to simulate postulated injuries.

EVENT SUMMARY: The Control Room receives a call from a Maintenance Planner who discovered an injured individual outside RHR "A" pump room. He states that the individual is a System Engineer who has lacerated his left forearm on scaffolding erected inside RHR "A" pump room, The System Engineer suffers a 4" laceration to the back of his left forearm while attempting to impede his fall and a bruise to his left knee (Attachment 1).

The System Engineer is able to exit the RHR 'A' Pump Room and secure the water tight door without assistance.

POSTULATED SEQUENCE OF EVENTS:

1. The Maintenance Planner discovers the injured System Engineer in the 574' AX Hallway outside the RHR 'A' Pump Room. The Maintenance Planner should assist the injured victim to the 574' AX west side access area and request the Control Room to dispatch the First Aid Team (FAT).

The victim may be moved at the discretion of the FAT to prevent from interfering with fire response.

Per EPI-B4, the SAS should perform the following:

- Notify the Radiologically Restricted Area (RRA) Control Point to verify that a Health Physics Technician has been dispatched to the injury scene.
- Notify Lake East Hospital and advise them of an injury requiring offsite medical treatment, and the victim's radiological status when known.

2. Upon arrival, the FAT should ascertain the condition of the victim and will determine or observe the following:

A 4" full thickness laceration to the left forearm,

• Vital signs: Pulse 102

Skin warm and dry Pupils equal and reactive

B/P 130/82

Respirations 28 and regular

3. The FAT should immediately cut away the torn clothing from the victim's left forearm and apply a dressing to the laceration to stop the bleeding.

Continuous pressure on the laceration is needed to stop the bleeding.

Clothing should be torn or cut away from the laceration before applying a dressing to prevent contamination from being introduced into the wound.

4. Health Physics technicians at the scene should determine the extent of contamination to the victim and the immediate vicinity. (Refer to Attachment 1 for Personnel Contamination Survey results.)

NO contamination will have been spread by foot outside the RHR 'A' Pump Room. However, anything the victim touches with his hands is potentially contaminated.

- 5. Health Physics may attempt to partially decontaminate the victim by removing his clothing. However, due to the severity of the forearm laceration transportation of the victim to Lake East Hospital and later decontamination of the wound will be required.
- 6. The FAT should transport the victim to the RRA Control Point where he will be transferred to PTFD ambulance personnel. Available Health Physics Technicians should assist in the dress out of the PTFD ambulance and personnel per EPI-B4.

Since the injury is NOT potentially life threatening and in response to the fire emergency, PTFD will be held up at the RRA access point.

7. A Health Physics Technician will accompany the victim to Lake East Hospital in Painesville, OH to monitor for potential contamination spread and to assist, if requested, in decontaminating the victim. A second Health Physics Technician or Supervisor will be dispatched to Lake East Hospital per EPI-B4 to assist in monitoring and releasing the PTFD ambulance vehicle and personnel, Emergency Room treatment area and equipment, and Emergency Room staff.

Refer to Section 11.2 for further details under the Lake County Medical Services Drill.

REFERENCES:

EPI-B4, "First Aid and Medical Care"

ATTACHMENTS:

1. Personnel Survey Report

Mini-Scenario No. 5 Attachment 1

PERSONNEL CONTAMINATION SURVEY

PNPP No. 6838 Rev. 3/1/99 HPI-E0007												
EVENT DETAILS (Normally, this form is utilized for contaminations ≥6000 ccpm)							Control Point Location:					
Affected Individual:(Last, First, MI) Social Security #					Follow Up Survey #: N/A (attach copy)							
									`			
Supervisor/Mail Zon	e/Phone #:			D	ept:	ept: Compa		Section:	Unit:	Unit:		
				<u>_</u>		<u> </u>	1		<u></u>			
Work Location: AREA: Contam Clean RWP# Work Description:							☐ TRRA Anticipated ☐ Unplanned					
Contamination Type: Particle General MCA Attached												
Contamination Loca			Clothing [□Ме	odesty					
Individuals Account	of Occurrence	ce, (inclu	de method	of disc	overy):							
						(-						
Signature:						Dat	e:					
RP Technician Revi	ew of Occurr	ence, (fo	llow up acti	ions):								
Drobable Cause Ca	do / bl			··· •	I CD No.			······································				
Probable Cause Co	de (see back	or page		·	CR Nu	mber:				□N/A		
RPT (print)				RPT (sign)				Date	e:		
DECON/INITIAL D	OSE EVAL	LUATIO	N 📗 N/A					dow	(mrad/h)			
				اليا			Window		em/h)			
Body Locati	ion				Pre-Decon Shiel (ccpm)* ccpr			Post-Decon (ccpm)	Decon	# of Decon		
,	0.20		(cable	(,,	Method	Attempts			
Left Forearm Appro			c. 4" long 600				□N/A	300/150/<100		3		
Clothing on right le	eg (calf)		300)]N/A					
Skin under clothin	g (calf)			<100)	[□N/A					
Instrument MPL #L70-		Cal Du	Cal Due Date Instrur			nent MPL #L70-			Cal Due Date			
Date/Time of Contamination Date/Time of Decontamination: Estimated Residency Duration (hrs): Deposition:												
Initial Skin Dose Evaluation: (shielded) ccpm x hours = ccpm-hours												
RPS Supv. Notified (≥30,000 ccpm-hours) ☐ Yes ☐ No Whole Body Count Performed ☐ Yes ☐ No												
RPT (Print): RPT(Sign): Date:												
RPS Supervisor Review and Recommendations:												
RPS Supv.(Print):												
SDE Complete Yes N/A Trending Yes No RP Trending Personnel Initial:												

* Assume that a corrected open window reading of 1 mrad/h equals 100,000 ccpm.

Distribution: Original-Dosimetry File Copy-Individuals Supervisor

PNPP No. 6838 Rev. 3/1/99


HPI-E0007

CAUSE CODE

^	Dorn	onnol Free	EXAMPLE				
Α.	Pers	onnel Error	,				
	A1.	Inattention to Detail	Poor technique of the affected individual.				
	A2.	Inadequate Communication	Failure of affected individual to heed Radiation Protection instruction.				
	A3.	Failure to Follow Procedure	Failure of affected individual to follow RWP. Failure of affected individual to heed Radiation Protection posting.				
	A4.	Inadequate Knowledge/Training	Inadequate knowledge/training of affected individual.				
	A5.	Other Personnel Error	Affected individuals. Contamination caused by other personnel error.				
	A6.	Inadequate HP Practices	Affected individuals. Contamination caused				
В.	Prog	ram/Procedure Deficiency	by Radiation Protection error.				
	B1.	Inadequate or Unclear	Cause of contamination resulted from program/procedure inadequacy.				
	B2.	Not Covered By Procedure/ Program	Cause of contamination resulted from information not contained in program/procedure.				
C.	B3. Equij	Other pment Malfunction	Low Level Contamination Build-up.				
	C1.	Maintenance	Contaminated Protective Clothing.				
	C2.	Design	Inherent design of the equipment resulted in the contamination.				
	C3.	Installation	Equipment was installed improperly and				
	C4.	Component Failure	resulted in contamination when used. Equipment Failure.				
	C5.	Other	Protective clothing/contamination migration.				
D.	Othe	r Causes Specific To Health Physics					
	D1. D2. D3.	(Deleted) Non-Contaminated Injury (Deleted)	Non-Contaminated injury.				
	D4.	Discrete Particle	Discrete particle.				
	D5.	Planned	Planned in accordance with <hpi-c0005>.</hpi-c0005>				
E.	Unkr	nown	Unknown Source of Contamination.				
D.	Not o	covered by A, B, C, D, N above	Other - Indeterminable Cause. Mini-Scenario No. 5 Attachment 1				

Mini-Scenario No. 5Attachment 1

Directions: Indicate levels of contamination on the corresponding body part.



Sabotage in a Plant Vital Area

APPROXIMATE TIME: 0925

LOCATION:

Lake East Hospital (Simulated Location)

REQUIRED SET-UP:

1. Incendiary device mock-up pre-positioned in RHR 'B' Pump Room.

EVENT SUMMARY:

At approximately 0930 a controller will call the main badging area (280-5401) and relay information from an engineer that had been injured in an accident and is being treated at Lake Hospitals. At approximately the same time, a second controller will contact (280-5819) wishing to talk to the onduty Supervisor, Nuclear Security Operations (SNSO). The second controller will identify himself as a member of the Perry Township Fire Department.

POSTULATED SEQUENCE OF EVENTS:

1. Caller: Controller: #1

THIS IS A DRILL:

"This is the HP Tech that went to the hospital with that systems engineer this morning.

Name: -----"

"The injured engineer told me something that really concerns me! He ADMITTED to setting the fire in the Pump room, AND that he had placed another incendiary device in the RHR "B" room. He went so far as to tell me the device is located on the cable tray in RHR "B" room."

2. Second Caller: Controller #2

THIS IS A DRILL:

Makes contact with the on-duty SNSO. Identifies himself as a member of the Perry Fire Brigade. The callers says; "We are treating the fire in RHR "A" as "suspicious", due to the significant amount of damage in the room. This amount of damage is not consistent with a normal electrical fire or oil fire in the pump. We're still investigating but I thought you should know."

- 3. Using the information gathered from both telephone calls, the on-duty SNSO should determine that this is a credible threat.
- 4. The SNSO shall dispatch an Officer to RHR "B" to investigate. A second device shall be located.
- 5. SNSO response to this incident should be in accordance with Security Contingency Instruction 0033 (Sabotage Device Found in a Vital Area.)
- **6.** The SNSO should notify the Control Room, the TSC Security Coordinator, and Local Law Enforcement of the events and discovery of the device.
- 7. The SNSO's actions should include isolating the area, and running area accountability.
- 8. Control Room Shift Supervisor, based on this information, should enter EAL NS-1 (Confirmed Act of Sabotage Within a Vital Area)

The SNSO should begin and end each of these conversations with THIS IS A DRILL.

PARTICIPANTS:

- Security
- Control Room
- Off-Site Departments
 - 1. FBI (Simulated)
 - 2. Lake County Sheriff
 - 3. Perry Township FD. (Simulated)

REFERENCES:

- EPI-A1, Emergency Action Levels
- SCI-0033, Security Contingency Instruction, Confirmed Act of Sabotage Within a Vital Area

ATTACHMENTS:

None

Rod Control and Information System (RC&IS) Rod Block

APPROXIMATE TIME: 0830 hours

LOCATION:

Actual -

Unit 1 Control Room

REQUIRED SET-UP:

EVENT SUMMARY: While performing a power due a safety relief valve (SRV) inadvertently opening, manual insertion of control rods is prohibited due to a failed input isolator card at panel 1H13-P651 causing analyzer to lockup.

POSTULATED SEQUENCE OF EVENTS:

1. Inward rod movement stops with the following indication present at 1H13-P680:

INHIBIT ROD MOTION RCIS OOS annunciator (P680-5A-D8)

TEST DISPLAY LAMP on the Operator Control Panel Blinking

- 2. Operators should enter Off-Normal Instruction (ONI) C11-1 for inability to move control rods, and contact the Technical Support Center (TSC) to request I&C support to troubleshoot the failure.
- 3. Upon initiation of troubleshooting activities in the Control Room, I&C technicians should discover the following at panel 1H13-P653:
 - No faults on the Fault Map
 - DIV 1 COMMAND WORD on the Analyzer Section will be blanked out
 - COMMANDS DISAGREE LED illuminated

4. Attempts to reset RC&IS will cause the CLOCK and ADDRESS to increment while the RESET button is held. However, the CLOCK and ADDRESS will again freeze when the RESET button is released.

These conditions are caused by the loss of the 5 VDC Monitoring Circuit on the Input Isolator Card, thus preventing any DIV 1 COMMAND WORDS from being sent.

5. LEDs on the DIV 1 Activity Page in 1H13-P651 indicate normal, but LEDs CR10, CR20, and CR100 on the Input Isolator Card are NOT illuminated. (Not Simulated)

Failure of LEDs to be illuminated indicates a problem with the 5 VDC supply.

6. Inward rod motion using RC&IS will be restored once a replacement Input Isolator Card is obtained and installed.

RC&IS should be restored at 1005 hours, but NO LATER THAN 1030 hours.


As a contingency to delay the restoration of RC&IS, adjustments will be required to be made to the Input Isolator Card.

REFERENCES:

- ARI-H13-P680-5, "Reactor Control (Left)"
- ONI-C11-1, "Inability to Move Control Rods"
- Vendor Manual 209G Tab 7 GEK File Drawing RPIS Control File Input Isolator Layout Card 159C4685AA
- Vendor Manual 209G Tab 7 GEK File Drawing RPIS Control File Input Isolator Schematic Card 851E902AA


ATTACHMENTS:

- 1. Optical Isolator Card Layout Drawing
- 2. Optical Isolator Card Schematic



Optical Isolator Card Layout Drawing

Mini-Scenario No. 6 Attachment 1



Vendor Manual 209G 851E902AA Optical Isolator Card Schematic

Mini-Scenario No. 6 Attachment 2

Loss of Power to Control Room Annunciators

APPROXIMATE TIME: 0920 hours

LOCATION: Actual - 620' elevation, Turbine Power Complex (TPC), Unit 1

REQUIRED SET-UP:

1. Prestage mockup of breaker in accessible area. (Manual operated DC Breaker req'd. for mock-up.)

EVENT SUMMARY: Breaker D1A06 opens on a spurious trip signal interrupting power to the Control Room annunciators. The failure of Breaker D1A06 will also result in an Off-Gas System isolation and loss of RFPT control on the Master Level Controller (refer to Initial Condition Summary, Item #1).

A complete listing of components/equipment powered from Breaker D1A06 is contained in Plant . Data Book (PDB) H004.

POSTULATED SEQUENCE OF EVENTS:

1. All 125 VDC annunciators in the Control Room are lost with the exception of the following AC-powered annunciator:

ANN PWR SUPPLY FAIL

- 2. Per ONI-C61, Operators will perform the following:
 - Maintain plant conditions as steady state as possible, i.e. suspend or do NOT commence any
 evolution which may result in a transient to the plant.
 - Augment Control Room staff with other plant licensed and non-licensed personnel to increase the ability to monitor plant parameters.

For the purposes of this exercise, the Simulator will be allowed to contact Operator Training Unit (OTU) to determine the availability of additional licensed personnel.

- 4. Based on the extent of the annunciator loss, Operators should dispatch a PPO directly to Breaker D1A06. Upon arrival the PPO will be unable to close the breaker. An OSC team should then be dispatched to rack out and troubleshoot Breaker D1A06.
- 5. Closer inspection of Breaker D1A06 once racked out reveals a loose spring on the closing latch mechanism. Repair team personnel should reattach the spring, then rack in and close the breaker to restore annunciators at approximately 1030.

If troubleshooting and repair activities progress too rapidly, controllers can direct repair team personnel that the breaker spring is broke. However, <u>annunciators MUST</u> be returned between 1025 and 1035 hours.

REFERENCES:

- ARI-H13-P680-7, "Steam Control (Unit 1)", page 133
- ONI-R61, "Loss of Control Room Annunciators (Unit 1)"
- ONI-R42-4, "Loss of DC Bus D-1-A"
- PDB-H004, "125 VDC Bus D-1-A"

ATTACHMENTS: None

Failure of SLC 'B' Pump, 1C41-C001B, to Start

APPROXIMATE TIME: Approximately 1055 hours

LOCATION: Actual (MCC EF1C08) - 620' elevation, Control Complex

REQUIRED SET-UP:

Prestage mockup MCC and penetration fuse box in accessible area.

EVENT SUMMARY: SLC 'B' Pump fails to start when initiated per PEI-B13 (ATWS) in response to an ATWS condition resulting from the loss of instrument air to the Control Rod Drive Hydraulic (CRDH), C11, System. Due to the unavailability of the SLC 'A' Pump as an initial condition (Mini-Scenario No. 2), Operators should line-up for alternate boron injection per PEI SPI-1.8.

NOTE: Alternate boron injection into the RPV is performed via the High Pressure Core Spray (HPCS) flush connection 1E22-F031 using the SLC Transfer System and the Alternate Boron Injection Pump. The estimated time to line-up and initiate alternate boron injection is approximately 4 hours.

Players will be allowed to perform PEI SPI-1.8 actions to line-up for alternate boron injection. However, efforts can NOT be successful until after the SLC 'B' Pump is restored to service. If required, controllers will interject a problem with installing the ABI connection assembly end of the high-pressure hose to the HPCS flush connection.

POSTULATED SEQUENCE OF EVENTS:

1. Upon inspection, an OSC repair team will observe that the 'A' and 'C' phase fuses in MCC EF1C08 Compartment D are blown.

If repair team personnel attempt to replace the fuses without identifying and correcting the problem (as described below), the 'A' and 'C' replacement fuses will also blow.

- 2. Repair team personnel upon evaluating the source of the blown fuses should discover a defective fuse holder located in 1R24S026 section 19-F12, which is adjacent to MCC EF1C08 Compartment D. The defective fuse holder caused a high resistance condition on the 'B' phase power supply to the SLC 'B' Pump motor. This condition in turn caused the 'A' and 'C' phase mainline fuses to blow on overcurrent, thus loosing power to the control power transformer and preventing pump operation.
- 3. A replacement fuse holder should be obtained from the Warehouse. Once installed and the main line fuses replaced, the SLC 'B' Pump can be restored to service and boron injection initiated.

SLC 'B' Pump can be restored to service as early as 1300 hours, but by no later than 1320 hours.


Controllers must remember to allow sufficient time for the tagout to be cleared.

REFERENCES:

- PEI-B13, "RPV Control (ATWS)"
- PEI:SPI-1.8, "Alternate Boron Injection"
- Plant Drawing B-208-030 (Sheet A06), "Standby Liquid Control Pump (C001B)"
- Plant Drawing D-209-208 (Sheet 289), "(1R24-S024) 480 V MCC EF1C08, Compartments D, E, and J"

ATTACHMENTS:

1. Diagram of Penetration Fuse Box (from B-208-030, Sheet A06)



<u>Diagram of Penetration Fuse Box</u> (from Plant Drawing B-208-030, Sheet A06)

Mini-Scenario No. 8 Attachment 1

Failure of the Reactor Core Isolation Cooling (RCIC) Steam Supply Inboard Valve, 1E51-F063, to Close

APPROXIMATE TIME: 1110 hours

LOCATION:

Actual (Valve)

Drywell (Unit 1)

(MCC EF1D07) -

620' elevation, Control Complex

REQUIRED SET-UP:

1. Prestage mockup MCC in accessible area.

EVENT SUMMARY: A weld failure occurs at 1105 hours in the Steam Tunnel upstream of the RCIC Steam Supply Outboard Isolation Valve, 1E51-F064. Position indication at panel 1H13-P601 for the 1E51-F064 valve is lost due to an electrical short at the valve as a result of the valve's proximity to the weld failure.

At 1110 hours, a RCIC isolation signal is received due to high RCIC steam line differential pressure. However, the RCIC Steam Supply Inboard Isolation Valve, 1E51-F063, fails to close when commanded. An unisolable release pathway to the environment now exists from the RCIC System into the Steam Tunnel and out the Turbine Building/Heater Bay (TB/HB) Vent. (Refer to Attachment 2 and Figure 8.5.2.)

POSTULATED SEQUENCE OF EVENTS:

- 1. The Control Room receives the following indication of an unisolated steam line break in the Steam Tunnel:
 - RCIC ISOL STEAM TUNNEL TEMP HIGH annunciator on panel 1H13-P601
 - Loss of position indication for both the 1E51-F063 & -F064 valves on 1H13-P601
- 2. With both the 1E51-F063 (in Drywell) & -F064 (in the Steam Tunnel) inaccessible, OSC repair teams should be dispatched to the breakers and MCCs for each respective valve to attempt to determine if an electrical source for these failures exists.

3. Attempts to identify the actual position of the 1E51-F064 valve are unsuccessful.

Any attempt to use the Steam Tunnel cameras to identify the location of the RCIC line break will be unsuccessful.

Since the weld failure occurred upstream of the 1E51-F064 valve, the actual position of the valve does NOT impact the ability to isolate the break.

- 4. Mainline fuses are discovered blown at MCC for the 1E51-F064 valve. When replaced, fuses will repeatedly fail. Response efforts should now focus on troubleshooting and closing the 1E51-F063 valve.
- 5. Upon inspection of fuse box R24-S026 (Section 19-F9) which is adjacent to MCC EF1D07 Compartment XN, repair team personnel will observe that mainline fuses 1T1 and 1T2 have blown. (Refer to Attachment 1.)

If repair team personnel attempt to replace these fuses without identifying and correcting the problem source (as described below), the '1T1' and '1T2' replacement fuses will also blow.

- 6. Repair team personnel upon evaluating the source of the blown fuses should discover a failed control power transformer.
- 7. A replacement control power transformer should be obtained from the Warehouse and installed, and the mainline fuses for '1T1' and '1T2' replaced.

The 1E51-F063 valve must be closed at exactly 1340 hours to coincide with radiation monitor data loaded in the Computer-Aided Dose Assessment Program (CADAP) "drill" file.

Restoration of the 1E51-F063 must be closely coordinated between the Simulator Driver and OSC controller.


SECT. 9.0-40

REFERENCES:


- ARI-H13-P601-21, "RCIC & LPCS (Unit 1)"
- ONI-N11, "Pipe Break Outside Containment (Unit 1)"
- PEI-N11, "Containment Leakage Control"
- Plant Drawing B-208-075 (Sheet A24), RCIC Steam Supply Line Isolation Inboard to RHR Condensing Heat Exchanger F063"

ATTACHMENTS:

- 1. Diagram of Penetration Fuse Box (from B-208-075, Sheet A24)
- 2. RCIC System (SDM Figure E51-1)



Attachment 1



Motor Feed Pump (MFP), 1N27-C004, Trip

APPROXIMATE TIME: 1225 hours

LOCATION: Actual - 620' elevation, Heater Building (Unit 1)

REQUIRED SET-UP:

EVENT SUMMARY: The MFP trips on low lube oil pressure (less than 5 psig) when a relief valve at the discharge of the AC oil pump inadvertently opens recycling oil back to lube oil sump (Attachment 1). The MFP DC oil pump starts due to low lube oil pressure (less than 8 psig), but can NOT prevent pressure from dropping to trip setpoint.

With the loss of the MFP, no other system is available to feed the RPV; therefore, RPV level starts to decrease. While available, per PEI-B13 (ATWS), HPCS can NOT be used to feed the RPV until RPV level can NOT be maintained greater than -25 inches.

[NOTE: top of active fuel (TAF) = 0 inches.]

POSTULATED SEQUENCE OF EVENTS:

- 1. A PPO dispatched to the MFP will hear flow noise in the piping from the failed relief valve. The failed relief valve and associated piping will be warm to the touch. He will also observe that the DC oil pump is running.
- 2. Attempts to manually override the relief valve by turning the adjusting screw (Piece 'C' on Attachment 2) will NOT work due to binding caused by a broken control spring (Piece 'G'). Retainer (Piece 'D') will NOT turn inward if attempted to close relief valve.
- 3. The MFP lube oil system should be secured and the relief valve removed for repairs or placement.


Efforts to replace or repair the relief valve can be successful after 1315 hours.

REFERENCES:

- ARI-H13-P680-3, "Feedwater (Unit 1)" (pages 3 and 69)
- ONI-N27, "Feedwater Pump Trip (Unit 1)"
- PEI-B13, "RPV Control (ATWS")

ATTACHMENTS:


- 1. Vendor Manual Drawing C-76-E-55 Exerpt(illustrating lube oil system configuration)
- 2. Vendor Manual Figure (illustrating FULFLO relief valve assembly)



Vendor Manual Drawing C-76-E-55 Exerpt (illustrating lube oil system configuration)

Mini-Scenario No. 10 Attachment 1

INSTALLATION AND MAINTENANCE INSTRUCTIONS FOR FULFLO VALVES



<u>Vendor Manual Figure</u> (illustrating FULFLO relief valve assembly)

> Mini-Scenario No. 10 Attachment 2

END OF SECTION 9.0, "MINI-SCENARIOS"

SECTION 10.0

PUBLIC INFORMATION MESSAGES

Contents of this Section:

Section 10.1 - Public Information Questions

Section 10.2 - Media Monitor Scripts

Section 10.3 - County Public Access/Rumor Control Messages

2000 PERRY EVALUATED EXERCISE 10.0 PUBLIC INFORMATION MESSAGES

A significant aspect of emergency response is the ability to provide area citizens and the news media with accurate and timely information about the incident. Public perception and reaction are influenced by the information relayed to them. To ensure that the Perry Nuclear Power Plant (PNPP) Emergency Response Organization is prepared to deal with inquiries during an incident at PNPP, this exercise provides certain elements that test Public Information activities and response. During the course of this exercise, both the PNPP Public Information Response Team (PIRT) and the Joint Public Information Center (JPIC) will be activated and exercised.

Special Exercise Controllers have been selected and trained to test the Rumor Control and Media Response staffs. Controllers will act as concerned citizens, employees, government officials, and as members of the media, posing questions to the staff. Controllers should use pseudonyms when making calls.

The following pages denote questions that can be used by the controllers. Questions are grouped by time in relation to the events specified in the exercise scenario. Controllers are allowed to use questions from earlier times, but may <u>not</u> jump ahead. The lead PIRT Controller shall verify that the exercise is adhering to schedule, and will make any necessary timing adjustments. Space is provided for controllers to make notes on the response. Controllers also should use special critique forms as discussed in their training. Free play, based on available information, is encouraged. Controllers may also ask more than one question per call, if appropriate.

<u>Controllers must always precede questions with "This is a drill."</u> If playing a reporter, controllers can free play questions based on the information given. Additionally, controllers should ask questions about FirstEnergy, The Illuminating Company, the state or counties, background on PNPP, radiation, the state/county/utility interface, protective actions, etc.

SECTION 10.1 PUBLIC INFORMATION QUESTIONS

2000 PERRY EVALUATED EXERCISE 10.1 PUBLIC INFORMATION QUESTIONS

TIME

QUESTION

0900

THIS IS A DRILL

This is (make up a last name) from Radio Station WKAP. We understand that there's been some kind of an emergency at Perry. What's going on?

THIS IS A DRILL

This is the <u>NEWS Today Newspaper</u>. What is the status of the fire? Should the public be concerned?

THIS IS A DRILL

This is Radio Station WRAT. We heard there's something happening at the plant. We want to send a local reporter out to cover it. Who should she ask for?

THIS IS A DRILL

I live on Center Rd. I have seen a lot of fire trucks go by. What is happening with the plant?

THIS IS A DRILL

This is Channel 81. We heard there are problems again at the plant. Can we speak to the Plant Manager? We'd like to get him on tape discussing this problem for a 10:00 a.m. news broadcast.

THIS IS A DRILL

I heard someone was hurt at the Perry Plant. My son works at the plant and I can't reach him.

THIS IS A DRILL

This is Gloria Buckingham with the <u>Courier Journal</u>. I heard there was an emergency declared at the plant. What is your company doing to correct the problem? Is this the result of human error again?

THIS IS A DRILL

Why isn't your Joint Public Information Center activated?

THIS IS A DRILL

Has the State and Counties been notified of the emergency? What is the Governor doing?

2000 PERRY EVALUATED EXERCISE 10.1 PUBLIC INFORMATION QUESTIONS

(0900 Continued)

THIS IS A DRILL

I'm new to this area. I've never lived around a nuclear plant, but an alert at a chemical plant I lived close to meant serious consequences. What is a Nuclear Alert?

THIS IS A DRILL

I heard there is a fire inside the plant. How bad is it? Do I have to leave my home?

1000

THIS IS A DRILL

My kids are with a neighbor down at Perry Park. I can't leave to go get them. Who's going to let them know what's happening?

THIS IS A DRILL

I'm with the Reporter. We sent a reporter out to get a personal interview with someone? Could you see if she has arrived yet? Are there any other media at the site?

THIS IS A DRILL

Is there any danger to the public?

THIS IS A DRILL

Have you given any recommendations to the County Commissioners?

THIS IS A DRILL (Elisa)

Are you evacuating people? Do I need to leave?

THIS IS A DRILL

This is (<u>make up a last name</u>) from WXIN radio station. Our reporters attempted to interview some plant employees earlier today about the Perry Plant. Those employees said they couldn't talk about Perry or any situation there. Do you stop employees from talking to the Press? Who talks to the press for your company? Can I talk to that person?

THIS IS A DRILL

Does the fire have anything to do with the low level waste disposal site out there?

THIS IS A DRILL

I'd like to talk to the individual contacting public officials. I need to know if the governor has declared a state of emergency. People are calling my office. I'm a local trustee from Willoughby.

2000 PERRY EVALUATED EXERCISE 10.1 PUBLIC INFORMATION QUESTIONS

THIS IS A DRILL

Has anyone been injured because of this incident?

THIS IS A DRILL

This is Gloria Star from WLWS Channel 82. I've heard that you declared a Site Area Emergency. What should our viewing audience be doing now? Do you have an update for us?

THIS IS A DRILL

Has the Perry Plant recommended any protection actions to citizens? Has any outside help been brought in?

THIS IS A DRILL

I live in Madison. Should I be doing anything to get ready for an evacuation? Are there any preliminary messages?

THIS IS A DRILL

I represent Radio Station WDON. You are live on the air. We heard about the problems out there. This is kind of like the Titanic, isn't it? People said it would never sink and it did. For years nuclear people have been saying that this plant won't blow, but it's obviously going to. Would you comment on the similarities between these two tragedies, please?

THIS IS A DRILL

Is the fire at the plant under control?

THIS IS A DRILL

Weren't you just shut down for a long outage? Didn't you fix everything then?

1100

THIS IS A DRILL

Is the NRC coming to the Site?

THIS IS A DRILL

This is (make up a last name) from WWOG Radio. We received a report that people are leaving the Perry area. Are they being told to go? If so, who's telling them, and where are they being told to go to?

THIS IS A DRILL

Who should I call for further information about Lake County?

2000 PERRY EVALUATED EXERCISE 10.1 PUBLIC INFORMATION QUESTIONS

THIS IS A DRILL

This is Gloria Foster from CLN. I understand there are major problems there on the shores of Lake Erie at that Nuclear Plant, and things are moving from bad to worse. Where's the person in charge? I'd like to talk to him.

THIS IS A DRILL

This is (make up a last name). Can you update me on the status of the reactor? I've tried getting through to the EMA and all lines are busy.

THIS IS A DRILL (Elisa)

What class of emergency are we presently in? What does that mean?

THIS IS A DRILL

This is the Akron Analyzer. We understand Perry employees evacuating the area are being told not to speak with any one. Are your employees being sent to special care areas? If so where is the nearest one where we could find someone to talk to?

THIS IS A DRILL (Name)

We are getting a lot of calls this morning about the emergency at Perry. We don't want them calling us. What number should we tell our listeners to call to get information about the plant?

THIS IS A DRILL

What should I do? I live in Madison Township?

1200 THIS IS A DRILL

Do you have enough water to cool that place down? Where do you get it from - Lake Erie? Are you dumping contaminated water back into the lake?

THIS IS A DRILL

This is Conneaut Radio Station WWWW. We'd like to come out to the plant site to get some photographs and interviews with individuals working to alleviate this emergency.

THIS IS A DRILL

Are there any county representatives in that facility? I'm a Mentor councilman and I'd like to get a first-hand report of how things are going.

THIS IS A DRILL

My husband is going fishing on Lake Erie. Should he still go? Is it safe? Should he take a portable radio? What radio station should he listen to?

(2000 EVEX) SECT. 10.1 Page 4 of 7

2000 PERRY EVALUATED EXERCISE 10.1 PUBLIC INFORMATION QUESTIONS

(1200 continued)

THIS IS A DRILL

This is Elisa Donaldson from the <u>Lake County Courier</u>. What's the real reason you folks are having so many problems with that plant? Is any of this the result of your terminating employees? Are your employees depressed from all the layoffs and cuts, and not performing satisfactorily?

THIS IS A DRILL

Is the Media Center open yet?

THIS IS A DRILL

Have the State and Counties been notified of the emergency? What is the Governor doing?

THIS IS A DRILL

I cannot find my Emergency Information Brochure. What should I do?

THIS IS A DRILL

This is the Mayor of Erie. Can you see that we get a personal telephone call and update on any changes in the emergency. Believe it or not, we are getting calls from citizens in this area about what's happening at Perry.

THIS IS A DRILL

What actions are being done to stop this emergency?

1300

THIS IS A DRILL

I'm so tired of that Plant. When are the people in this area going to be able to rely on that place to run? Can't you people fix that reactor right?

THIS IS A DRILL

This is WCYX, Channel 31. Boy, do you folks have big problems. Is there anyone there who can verify whether a spontaneous evacuation is occurring?

THIS IS A DRILL

Do those sirens mean I should leave? Or, do I just need to stay tuned to my radio and television?

THIS IS A DRILL

This is radio station WISK. Is this the first General Emergency you guys have declared? We need some answers for our viewers, who are saying that you just had a big emergency in March. Is that true? What other nuclear plants have had emergencies?

2000 PERRY EVALUATED EXERCISE 10.1 PUBLIC INFORMATION QUESTIONS

(1300 continued)

THIS IS A DRILL

This is (Name) from the Stock Market Today. When is the next press briefing? How many media are at your Media Center?

THIS IS A DRILL

How many times and for how long do those sirens sound?

THIS IS A DRILL

How serious is a Site Area Emergency? Why are people leaving the site?

THIS IS A DRILL

This is Gloria Brown on Main Street in Perry. I'm not leaving my home! I don't care how many sirens you guys sound. I'm not leaving!

THIS IS A DRILL

Elisa Richardson on Radio Station WINW. I know your plant has had fuel after fuel leak, why didn't they fix this problem in the last outage?

1400

THIS IS A DRILL

Do you plan to reimburse residents for any damages due to this emergency?

THIS IS A DRILL

Do you issue more than one EAS message?

THIS IS A DRILL

How much radiation are you releasing to the environment?

THIS IS A DRILL

Will you ever be able to operate the plant again?

THIS IS A DRILL

Has the radiation stopped? How much was released?

THIS IS A DRILL

This is radio station WCPN Public Radio. I have you live on the air. I would like for you to give us an update as to what is happening out there. (WAIT FOR AN ANSWER) Will your Emergency Manager debate Bob Pollard of the Union of Concerned Scientists? We will set it up by telephone.

THIS IS A DRILL

Who will pay for this?

2000 PERRY EVALUATED EXERCISE 10.1 PUBLIC INFORMATION QUESTIONS

(1400 continued)

THIS IS A DRILL

Will my taxes go up to pay for damages caused by the accident at the Perry Plant?

THIS IS A DRILL

You just issued a General Emergency. That's more serious then a Site Area Emergency? Is there any danger to the public?

THIS IS A DRILL

Elisa Jacobs of the <u>Boston Globe</u> I'd like to talk to members of the crew who were in the Control Room when the emergency first started. Are any of those individuals available?

THIS IS A DRILL

What is the status with the fire at the plant? What kind of damage did it cause?

THIS IS A DRILL

Will the NRC be responsible for the Plant from now on? Will they be more aware of public safety?

NOTE TO CONTROLLERS: The exercise is terminated.

SECTION 10.2 MEDIA MONITOR SCRIPTS

Another aspect of JPIC response is the ability to monitor media broadcasts of the nuclear plant emergency. By doing this, JPIC responders can verify the accuracy of the information being released to the public. Faulty information should be corrected by JPIC staff.

A controller will give each script to the Media Monitor Staff person at the time designated on the script. For exercise purposes, the script simulates transcription of a television news broadcast.

Note: Reference (Players/Controllers Message Summary) Section 7.1 for messages directed to Corporate Liaison and CEI Telephone Operator.

THIS IS A DRILL SEGMENT #1

TIME: 1100

"This is Barbara Starr for WCHP News.

We have just received word of a problem at the Perry Nuclear Power Plant. There has been a report that there is a fire at the Plant. There has also been a report that an injured person has been transported to the hospital.

Officials at the plant have classified the condition an ALERT category. An Alert is the second lowest of four emergency classifications used to describe situations that can get progressively worse at nuclear plants.

Stay tuned to this station for updated information, as it becomes available.

For WCHP, this is Barbara Starr."

THIS IS A DRILL

2000 EVEX Section 10.2 Page 2 of 6

THIS IS A DRILL SEGMENT #2

TIME: 1120

"This is Barbara Starr for WCHP News.

The emergency situation at the Perry Nuclear Power Plant located about 35 miles east of Cleveland has been changed to a SITE AREA EMERGENCY. It seems that all the warning alarms in the Control Room are broken. The status of the plant is unknown.

Although the emergency was declared, a plant spokesperson stresses that there is no immediate danger to the public. However, people living near the plant have continued to report that plant personnel are evacuating the area as quickly as they can.

The Illuminating Company, State and County officials are setting up an emergency news center near the plant called the Joint Public Information Center. We will continue to provide you with the latest information as it becomes available.

Barbara Starr, WCHP News."

THIS IS A DRILL SEGMENT #3

TIME: 1230

"This is Barbara Starr for WCHP News.

Conditions at the Perry Nuclear Power Plant are deteriorating. WCHP just recently learned that the emergency situation has been upgraded to a General Emergency. A General Emergency is the highest classification for emergencies at Nuclear Power Plants.

County Commissioners in all three counties have ordered that everyone within a 25 mile radius of the plant evacuate to a safer place. At this time we don't know how much radiation has been released.

Stay tuned to this station for further updates on the status of this nuclear disaster, which appears to be quickly becoming the worst nuclear disaster in history.

For WCHP, this is Barbara Starr."

THIS IS A DRILL SEGMENT #4

TIME: 1300

"This is Barbara Starr for WCHP News.

Reporting on the ongoing nuclear disaster at the Perry Nuclear Power Plant. I spoke with several residents from around Perry about the continuing emergency.

- Citizen 1: Airline companies know that sooner or later one of their airplanes will crash.

 Regardless of how careful they are with maintenance, training, and using good quality parts, eventually some factor such as human error, terrorist bomb, sabotage, or simple mechanical failure will cause an accident. The same is true for nuclear power plants. So why build them in the first place?
- Citizen 2: I heard that some county government officials who are holed up in an underground bunker somewhere in the woods in Lake County are the people who are calling the shots. What do they know about running a nuclear power plant? That's why we're in the mess we're in!
- Citizen 3: This is a bad accident and I'm afraid that a lot of us are going to lose our property, just like what happened in Russia and Three Mile Island. It wouldn't have been so bad if they'd allowed us to buy insurance for this type of catastrophe!
- Citizen 4: It's a shame that some people do not take pets with them when they leave. They just let them loose to forage for themselves. Now, there are roving packs of dogs, probably mad with radiation poisoning, attacking any other animal or human in sight.

This is Barbara Starr, WCHP. Stay tuned for further information."

THIS IS A DRILL SEGMENT #5

TIME: 1340

"This is Barbara Starr for WCHP News.

The situation at the Perry Nuclear Plant is improving. The nuclear reactor has been shut down. CEI, State and County officials are now discussing what after effects are to be seen in the areas around the plant.

Who is at fault, how long the effects of this disaster will last, and who will pay for the repairs and lost electricity remains to be seen. For the citizens of Ohio, the real emergency may only be beginning.

Reporting for WCHP, this is Barbara Starr."

SECTION 10.3

County Public Access/Rumor Control Problems

An exercise control cell, referred to as "Rumor Mongers", will make telephone calls to Ashtabula, Geauga, and Lake counties' emergency operation centers (EOCs) where the public access/rumor control functions are located. These calls will imitate calls from the public that may be received during an actual emergency.

The "problems" presented by the Rumor Mongers are outlined on the following pages. These problems are organized into two packages: one that contains problems for Lake County (Labeled "Lake-#") and the other which contains problems for each of the three counties (Labeled "AGL-#). Lake County will receive twice the number of problems as the other two counties. The two packages of problems are different from one another. Also, within the "AGL" package that pertains to all three counties, three of the problems (AGL-3a, 3b, 3c; AGL-7a, 7b, 7c; AGL-18a, 18b, 18c) differ so that no single entity will receive exactly the same set of problems as any other.

Messages that intentionally have a common theme (rumors) are: messages 9, 10, and 11 in the package pertaining to all three counties.

The messages will be initiated by the Rumor Mongers at the approximate time indicated on each. If there is a delay in the scenario proceeding, an Exercise Controller will telephone the control cell and arrange a corresponding delay in the calls being made to the Public access and Rumor control functions in the EOCs.

If the counties' rumor control personnel have to return a call to the caller (Rumor Monger), the exercise control cell will be organized to accept such call backs and maintain continuity.

PUBLIC ACCESS AND RUMOR CONTROL PROBLEMS FOR ASHTABULA, GEAUGA, AND LAKE COUNTIES March 21, 2000

SAE

Message #:

AGL-1

Counties: Emergency Classification:

ASHTABULA - 440-576-3419

GEAUGA - LAKE -	440-285-2210 440-953-5469 440-953-5470	Approximate Time: Exercise Rumor Monger ID:	1000
DIRECTIONS :	FOR THE EXER	CISE RUMOR MONGER:	
"have an exercise below. Answer a is reasonably corproblem; DO NO	e message." Then range questions and consistent with the state of confound matter	number listed above and tell the persuant the Rumor Problem aloud, assurtherwise interact with the Rumor Cated problem. Accept reasonable and by inserting outlandish or extraneously phone number and assumed in	ontroller in a manner that swers (solutions) to the ous information. If a call
Assumed Identity	Y :	Rumor Problem:	
Nancy (Melvin) 345 Engineer Pla		"This is an exercise. My broth confused as to what's happening explain just exactly what's wror	g at Perry. Can you please
Ashtabula: Gene Geauga: Thomp Lake: Fairport H	son	This is an exercise."	
RUMOR MON	GER NOTES:	· · · · · · · · · · · · · · · · · · ·	

2000 EVEX SECT. 10.3 Page 2 of 43

PUBLIC ACCESS AND RUMOR CONTROL PROBLEMS FOR ASHTABULA, GEAUGA, AND LAKE COUNTIES March 21, 2000

SAE

Counties: Emergency Classification:

ASHTABULA GEAUGA - LAKE -	- 440-576-3419 440-285-2210 440-953-5469 440-953-5470	Message #: Approximate Time: Exercise Rumor Monger ID:	AGL-2 1015
DIRECTIONS F	OR THE EXERCI	SE RUMOR MONGER:	
"have an exercise below. Answer as is reasonably cons problem; DO NO	message." Then reany questions and othe sistent with the states of confound matters to the states of	nber listed above and tell the pend the Rumor Problem aloud, as erwise interact with the Rumor diproblem. Accept reasonable a by inserting outlandish or extrapoack phone number and assume	suming the identity shown Controller in a manner that answers (solutions) to the neous information. If a call
Assumed Identity	;	Rumor Pr	roblem:
Laurel (Steve) We 5699 Fruitful Lan		bell pepp	an exercise. I've got tomatoes, ers, rhubarb, leaf lettuce, iceberg nd romaine growing out back.
Ashtabula: Genev	va-on-the-Lake	The state of the s	I do to protect them if the Perry
Geauga: Munson			ases radiation?
Lake: Painesville		This is an	n exercise."
RUMOR MONG	SER NOTES:		
		•	

PUBLIC ACCESS AND RUMOR CONTROL PROBLEMS FOR ASHTABULA, GEAUGA, AND LAKE COUNTIES March 21, 2000

Counties: Emergency Classification: ASHTABULA – 440-576-3419 GEAUGA - 440-285-2210 LAKE - 440-953-5469 440-953-5470	SAE Message #: Approximate Time: Exercise Rumor Monger ID:	AGL-3a 1030
DIRECTIONS FOR THE EXERCIS	E RUMOR MONGER:	
Call the Rumor Control telephone num "have an exercise message." Then read below. Answer any questions and othe reasonably consistent with the stated pr DO NOT confound matters by inserting indicated give the call-back phone num	I the Rumor Problem aloud, assuming the Rumor Common Common Common Accept reasonable answig outlandish or extraneous inform	ontroller in a manner that is vers (solutions) to the problem;
Assumed Identity:	Rumor Problem:	
Rochelle (Chip) Fox 5282 Blue Mountain Blvd. Sheffield	"This is an exercise. Is it safe outside? This is an exercise."	for my children to play
RUMOR MONGER NOTES:		

PUBLIC ACCESS AND RUMOR CONTROL PROBLEMS FOR ASHTABULA, GEAUGA, AND LAKE COUNTIES March 21, 2000

SAE

ASHTABULA	A – 440-576-3419	Message #:	AGL-3b
GEAUGA -	440-285-2210	Approximate Time:	1030
LAKE -	440-953-5469	Exercise Rumor Monger ID:	
	440-953-5470		
DIRECTIONS 1	FOR THE EXER	CISE RUMOR MONGER:	
Call the Rumor (Control talanhona n	number listed above and tell the pers	
halam Amanan	message. Then i	read the Rumor Problem aloud, assu	iming the identity snown
		otherwise interact with the Rumor C	
		ted problem. Accept reasonable an	
		s by inserting outlandish or extrane	
back to you is inc	dicated give the cal	l-back phone number and assumed	identity.
Assumed Identity	λ:	Rumor Problem:	
Susan (Dean) Mo	:Cabe	"This is an exercise. I was go	ing to go on a picnic today
578 Maple Tree	Lane	Should I cancel my plans? Thi	
Burton		· •	
RUMOR MONO	GER NOTES:		-

Counties: Emergency Classification:

Counties: Emergency Class ASHTABULA - 440-576- GEAUGA - 440-285- LAKE - 440-953- 440-953	3419 Message #: 2210 Approximate Tit 5469 Exercise Rumor	AGL-3c me: 1030 Monger ID:
DIRECTIONS FOR TH	E EXERCISE RUMOR MON	NGER:
"have an exercise message below. Answer any quest is reasonably consistent w	e." Then read the Rumor Proble ions and otherwise interact with ith the stated problem. Accept	em aloud, assuming the identity shown the Rumor Controller in a manner that reasonable answers (solutions) to the dish or extraneous information. If a call and assumed identity.
Assumed Identity:	Rumor Problem:	
Carol (Luke) O'Grady 4910 Lakewood Circle Lakeline	"This is an exer already been kill This is an exerc	cise. Is it true that hundreds of people have led in the accident out at Perry?
RUMOR MONGER NO	OTES:	

PUBLIC ACCESS AND RUMOR CONTROL PROBLEMS FOR ASHTABULA, GEAUGA, AND LAKE COUNTIES March 21, 2000

Counties: Emergency Classification: ASHTABULA - 440-576-3419 GEAUGA - 440-285-2210 LAKE - 440-953-5469 440-953-5470	SAE Message #: Approximate Time: Exercise Rumor Monger ID:	AGL-4 1100
DIRECTIONS FOR THE EXERCISE	E RUMOR MONGER:	
Call the Rumor Control telephone number "have an exercise message." Then read below. Answer any questions and other is reasonably consistent with the stated problem; DO NOT confound matters by back to you is indicated give the call-back.	the Rumor Problem aloud, a rwise interact with the Rumo problem. Accept reasonable v inserting outlandish or extra	r Controller in a manner that answers (solutions) to the aneous information. If a call
Assumed Identity:	Rumor Problem:	
Rhonda (Tim) Wollensak 8763 Applewood Dr.	"This is an exercise. What This is an exercise."	's happening at the Perry Plant?
Ashtabula: Jefferson Geauga: Middlefield Lake: Mentor		
RUMOR MONGER NOTES:		

PUBLIC ACCESS AND RUMOR CONTROL PROBLEMS FOR ASHTABULA, GEAUGA, AND LAKE COUNTIES March 21, 2000

Counties: Emerg	gency Classification:	SAE	
ASHTABUL	A - 440-576-3419	Message #:	AGL-5
GEAUGA -	440-285-2210	Approximate Time:	1110
LAKE -	440-953-5469	Exercise Rumor Monger ID:	<u> </u>
	440-953-5470		
DIRECTIONS	FOR THE EXERCIS	SE RUMOR MONGER:	
Call the Rumor	Control telephone num	aber listed above and tell the pers	son who answers that you
	-	d the Rumor Problem aloud, assu	
	_	erwise interact with the Rumor C	-
	· •		
•		l problem. Accept reasonable an	· · · · · · · · · · · · · · · · · · ·
		by inserting outlandish or extrane	
back to you is in	idicated give the call-b	back phone number and assumed	identity.
Assumed Identit	<u>y</u> :	Rumor Problem:	•
Sharon (Edward) Smart	"This is an exercise. My father	er who is a college physics professor
3388 Crescent D	•		Beiger counter a couple of years ago.
		<u> </u>	n. Is it safe to assume, then, that it's
Ashtabula: Gen	A1/2	alright to go outside? This is a	
		arright to go outside: This is a	m Caci cisc.
Geauga: Thomp	oson		•
Lake: Mentor		·	· •
	• • • • • • • • • • • • • • • • • • • •	· •	
RUMOR MON	GER NOTES:		
	· · · · · · · · · · · · · · · · · · ·		

Page 8 of 43 **SECT. 10.3**

2000 EVEX

Counties: Emergency Classification: ASHTABULA - 440-576-3419 GEAUGA - 440-285-2210 LAKE - 440-953-5469 440-953-5470	SAE Message #: Approximate Time: Exercise Rumor Monger ID:	AGL-6 1120
DIRECTIONS FOR THE EXERCIS	SE RUMOR MONGER:	
Call the Rumor Control telephone num "have an exercise message." Then read below. Answer any questions and other is reasonably consistent with the stated problem; DO NOT confound matters by back to you is indicated give the call-back.	I the Rumor Problem aloud, assurting the Rumor Control of the Rumor Control of the Rumor Control of the Rumor Control of the Rumor Control of the Rumor Rumo	ming the identity shown ontroller in a manner that swers (solutions) to the ous information. If a call
Assumed Identity:	Rumor Problem:	
Maria (Mario) Leone 66 Liberty St.	"This is an exercise. I never go the mail and don't know which i neighbor, John Wagner, and I w	
Ashtabula: Andover Geauga: Parkman Lake: Wickliffe	Which way should we go to avo This is an exercise."	
RUMOR MONGER NOTES:		

PUBLIC ACCESS AND RUMOR CONTROL PROBLEMS FOR ASHTABULA, GEAUGA, AND LAKE COUNTIES March 21, 2000

Counties: Emerger	ncy Classification:	GE	
ASHTABULA GEAUGA -	- 440-576-3419 440-285 - 2210	Message #: Approximate Time:	AGL-7a 1130
LAKE -	440-953-5469 440-953-5470	Exercise Rumor Monger ID:	
DIRECTIONS F	OR THE EXERCI	SE RUMOR MONGER:	
"have an exercise abelow. Answer are is reasonably consproblem; DO NO?	message." Then really questions and othe state of the st	mber listed above and tell the person of the Rumor Problem aloud, assurerwise interact with the Rumor Cod problem. Accept reasonable and by inserting outlandish or extraneous pack phone number and assumed in	ming the identity shown ontroller in a manner that swers (solutions) to the ous information. If a call
Assumed Identity:		Rumor Problem:	
Beth (Brian) McC 333 Wyandot Trai Ashtabula		we'll have in this area all our liv	n all along, and that it's something yes and we'll have to live with. more this accident will add, and
RUMOR MONG	ER NOTES:	· · · · · · · · · · · · · · · · · · ·	

2000 EVEX SECT. 10.3 Page 10 of 43

PUBLIC ACCESS AND RUMOR CONTROL PROBLEMS FOR ASHTABULA, GEAUGA, AND LAKE COUNTIES March 21, 2000

Counties: Emergency Classification: ASHTABULA - 440-576-3419 GEAUGA - 440-285-2210 LAKE - 440-953-5469 440-953-5470	GE Message #: Approximate Time: Exercise Rumor Monger ID:	AGL-7b 1130
DIRECTIONS FOR THE EXERCI	SE RUMOR MONGER:	
Call the Rumor Control telephone nur "have an exercise message." Then rea below. Answer any questions and oth is reasonably consistent with the state problem; DO NOT confound matters back to you is indicated give the call-	nd the Rumor Problem aloud, assumerwise interact with the Rumor C d problem. Accept reasonable and by inserting outlandish or extrane	oming the identity shown controller in a manner that swers (solutions) to the cous information. If a call
Assumed Identity:	Rumor Problem:	
Peggy (Henry) DeBoer 55 Shore Dr. Auburn	"This is an exercise. I heard to radiation into Lake Erie. This vaccident to last thousands of yed do that? This is an exercise."	
RUMOR MONGER NOTES:		

Page 11 of 43 **SECT. 10.3 2000 EVEX**

PUBLIC ACCESS AND RUMOR CONTROL PROBLEMS FOR ASHTABULA, GEAUGA, AND LAKE COUNTIES March 21, 2000

GE

Counties: Emergency Classification:

ASHTABULA - 440-576-3419 GEAUGA - 440-285-2210 LAKE - 440-953-5469 440-953-5470	Message #: Approximate Time: Exercise Rumor Monger ID:	AGL-7c 1130
DIRECTIONS FOR THE EXERCI	SE RUMOR MONGER:	
Call the Rumor Control telephone nur "have an exercise message." Then rea below. Answer any questions and oth is reasonably consistent with the state problem; DO NOT confound matters back to you is indicated give the call-	nerwise interact with the Rumor C and problem. Accept reasonable and the inserting outlandish or extrane	ontroller in a manner that swers (solutions) to the ous information. If a call
. Assumed Identity:	Rumor Problem:	
Kimberly (Marcus) Quinton 100 Lilly Pond Dr. Willoughby	"This is an exercise. Could the into Lake Erie and then into our know for sure? This is an exe	ne Perry Plant radioactivity get or drinking water? How will we reise."
RUMOR MONGER NOTES:		
		,

AGL-7c

Counties: Emerge	ency Classification:	GE	
	- 440-576-3419	Message #:	AGL-8
GEAUGA -	440-285-2210	Approximate Time:	1140
LAKE -	440-953-5469	Exercise Rumor Monger ID:	
	440-953-5470	,	-
DIRECTIONS I	OR THE EXERCI	SE RUMOR MONGER:	
"have an exercise below. Answer a is reasonably con problem; DO NO	message." Then rea ny questions and othe sistent with the stated T confound matters b	nber listed above and tell the person the Rumor Problem aloud, assurerwise interact with the Rumor Of problem. Accept reasonable and inserting outlandish or extraneous phone number and assumed	uming the identity shown Controller in a manner that swers (solutions) to the cous information. If a call
Assumed Identity	:	Rumor Problem:	•
Elaine (Richard) 4029 Oak Hill Dr	•	"This is an exercise. Is this di leaks the plant has had? This i	
Ashtabula: North	Kingsville	·	
Geauga: Chester	•		
Lake: Willowick			
		•	•
RUMOR MONO	GER NOTES:		

	ency Classification: 4-440-576-3419 440-285-2210 440-953-5469 440-953-5470	GE Message #: Approximate Time: Exercise Rumor Monger ID:	AGL-9 1150
DIRECTIONS I	FOR THE EXERCIS	SE RUMOR MONGER:	
"have an exercise below. Answer a is reasonably con problem; DO NO	e message." Then reace may questions and other sistent with the stated T confound matters be	aber listed above and tell the person the Rumor Problem aloud, assorwise interact with the Rumor Comproblem. Accept reasonable and inserting outlandish or extranspack phone number and assumed	uming the identity shown Controller in a manner that aswers (solutions) to the cous information. If a call
Assumed Identity	: :	Rumor Problem:	
Megan (Ralph) B 19 Kosar Dr. Ashtabula: Ashta		"This is an exercise. Is it true Geauga, and Ashtabula countie This is an exercise."	that the entire area of all of Lakes will have to be evacuated?
Geauga: Mulberr Lake: Mentor	_		
RUMOR MONO	GER NOTES:		

	ncy Classification:	GE	
	- 440-576-3419	Message #:	AGL-10
GEAUGA - LAKE -	440-285-2210	Approximate Time:	1200
LAKE -	440-953-5469 440-953-5470	Exercise Rumor Monger ID:	
	440-733-3470		
DIRECTIONS F	OR THE EXERCIS	SE RUMOR MONGER:	
Call the Rumor Co	ontrol telephone num	aber listed above and tell the person	who answers that you
halow Anguer as	message." Then read	d the Rumor Problem aloud, assum	ing the identity shown
is reasonably cons	ly questions and other	erwise interact with the Rumor Con	troller in a manner that
problem: DO NO	r confound matters b	problem. Accept reasonable answ	ers (solutions) to the
back to you is indi	icated give the call-h	y inserting outlandish or extraneou ack phone number and assumed ide	s information. If a call
ouch to you is mu	leated give the can-bi	ack phone number and assumed ide	muty.
Assumed Identity:		Rumor Problem:	
Jody (Scott) Wash	ington	"This is an exercise. I was going	y to evacuate my home and go to
1100 Chestnut Dr.		one of the Red Cross mass care ce since the whole County will be ev	enters, but they won't be there
Ashtabula: Genev	a-on-the-Lake	place to stay? This is an exercise	
Geauga: Thompso	on	, , , , , , , , , , , , , , , , , , , ,	
Lake: Perry			
RUMOR MONG	ER NOTES:		

	ncy Classification:	GE	
	- 440-576-3419	Message #:	AGL-11
GEAUGA -		Approximate Time:	1210
LAKE -	440-953-5469	Exercise Rumor Monger ID:	
	440-953-5470		
DIDECTIONS E	OD THE EVEDO	ISE RUMOR MONGER:	
DIRECTIONS	OR THE EXERC	ISE KUMOK MUNGER:	
Call the Rumor C	ontrol telephone nu	mber listed above and tell the pers	on who answers that you
"have an exercise	message." Then rea	ad the Rumor Problem aloud, assu	ming the identity shown
		nerwise interact with the Rumor C	
is reasonably cons	sistent with the state	d problem. Accept reasonable and	swers (solutions) to the
problem; DO NO	T confound matters	by inserting outlandish or extrane	ous information. If a call
back to you is ind	icated give the call-	back phone number and assumed i	dentity.
Assumed Identity		Rumor Problem:	
213Sumed Identity	•	Rumoi Floblem.	
Sue (Rod) Yoder		"This is an exercise. I underst	and that your emergency center is
79 Nantucket Ct.		located in the County. Where v	vill we get official word of what's
		happening when the emergency	center evacuates with the rest of
Ashtabula: Genev	va-on-the-Lake	the County?	
Geauga: Thomps	on	This is an exercise."	
Lake: Grand Rive	er		
RUMOR MONG	ER NOTES:		

PUBLIC ACCESS AND RUMOR CONTROL PROBLEMS FOR ASHTABULA, GEAUGA, AND LAKE COUNTIES March 21, 2000

GE

Message #:

Approximate Time:

AGL-12

1220

Counties: Emergency Classification:

ASHTABULA - 440-576-3419

GEAUGA - 440-285-2210

2000 EVEX

LAKE -	440-953-5469 440-953-5470	Exercise Rumor Monger ID:
DIRECTIONS	S FOR THE EXERC	CISE RUMOR MONGER:
"have an exercibelow. Answer is reasonably coproblem; DO N	ise message." Then r r any questions and o onsistent with the sta IOT confound matter	umber listed above and tell the person who answers that you lead the Rumor Problem aloud, assuming the identity shown otherwise interact with the Rumor Controller in a manner that ted problem. Accept reasonable answers (solutions) to the solutions outlandish or extraneous information. If a call l-back phone number and assumed identity.
Assumed Ident	ity:	Rumor Problem:
Barb (Sam) Cri 1021 Summer		"This is an exercise. If we are told to evacuate, where should my family and I go? This is an exercise."
Ashtabula: Yo Geauga: Youn Lake: Clevelar	gstown	
RUMOR MO	NGER NOTES:	· · · · · · · · · · · · · · · · · · ·

SECT. 10.3 Page 17 of 43

PUBLIC ACCESS AND RUMOR CONTROL PROBLEMS FOR ASHTABULA, GEAUGA, AND LAKE COUNTIES March 21, 2000

GE

Counties: Emergency Classification:

	A - 440-576-3419	Message #:	AGL-13
GEAUGA -	440-285-2210	Approximate Time:	1230
LAKE -	440-953-5469	Exercise Rumor Monger ID:	
	440-953-5470		
DIRECTIONS	FOR THE EXER	CISE RUMOR MONGER:	
Call the Rumor	Control telephone n	number listed above and tell the person	on who answers that you
		read the Rumor Problem aloud, assur	
		otherwise interact with the Rumor Co	
		ted problem. Accept reasonable ans	
		rs by inserting outlandish or extraneo	
back to you is in	dicated give the cal	l-back phone number and assumed i	dentity
•	C	F	
Assumed Identit	v:	Rumor Problem:	
	_		
Sandy (Dave) M	urphy	"This is an exercise. I'm callin	g from Chicago. My flight to
3289 Oberlin Dr			d 4:00, which would put me home
	•		s been ordered, I won't be able to
Ashtabula: Gene	eva-on-the-Lake		the police or fire department over
Geauga: Thomp			Bailey, and take care of him for
Lake: Perry Vill		me? This is an exercise."	bancy, and take care of min for
Bake. Terry vin	.ugc	me: This is an exercise.	
RUMOR MON	GER NOTES:		
KUMOK MON	<u>dernotes.</u>		
	-		

Counties: Emergency Classification ASHTABULA - 440-576-3419 GEAUGA - 440-285-2210	Message #:	AGL-14
LAKE - 440-953-5469 440-953-5470	Approximate Time: Exercise Rumor Monger ID:	1240
DIRECTIONS FOR THE EXE	RCISE RUMOR MONGER:	
"have an exercise message." Ther below. Answer any questions and is reasonably consistent with the s problem; DO NOT confound matt	e number listed above and tell the person read the Rumor Problem aloud, assured otherwise interact with the Rumor Contacted problem. Accept reasonable ansters by inserting outlandish or extraneousle back phone number and assumed in	oning the identity shown ontroller in a manner that wers (solutions) to the ous information. If a call
Assumed Identity:	Rumor Problem:	•
Sarah (Don) McPherson 47 Jones Rd.	"This is an exercise. I heard th evacuate. Does that mean me? This is an exercise."	e announcement on the radio to
Ashtabula: Geneva		
Geauga: Thompson Lake: North Perry		
RUMOR MONGER NOTES:		

Counties: Emergency Classification: ASHTABULA - 440-576-3419 GEAUGA - 440-285-2210 LAKE - 440-953-5469 440-953-5470	GE Message #: Approximate Time: Exercise Rumor Monger ID:	AGL-15 1250
DIRECTIONS FOR THE EXERCIS	SE RUMOR MONGER:	
Call the Rumor Control telephone num "have an exercise message." Then reach below. Answer any questions and other is reasonably consistent with the stated problem; DO NOT confound matters be back to you is indicated give the call-back	d the Rumor Problem aloud, assurerwise interact with the Rumor Coll problem. Accept reasonable ansity inserting outlandish or extraneous	ming the identity shown ontroller in a manner that swers (solutions) to the ous information. If a call
Assumed Identity:	Rumor Problem:	
Sherry (Ray) Baker 432 Oak Tree Lane Ashtabula: Conneaut Geauga: Burton Lake: Willoughby		told that the accident at the Perry e, and that when it's all said and hernobyl. Is that true?
RUMOR MONGER NOTES:		

PUBLIC ACCESS AND RUMOR CONTROL PROBLEMS FOR ASHTABULA, GEAUGA, AND LAKE COUNTIES March 21, 2000

GE

Message #:

Counties: Emergency Classification:

ASHTABULA - 440-576-3419

GEAUGA - 440-285-2210

GEAUGA - LAKE -	440-285-2210 440-953-5469 440-953-5470	Approximate Time: Exercise Rumor Monger ID:	1300
DIRECTIONS	FOR THE EXERC	CISE RUMOR MONGER:	
"have an exercise below. Answer a is reasonably cor problem; DO NO	e message." Then reany questions and or any questions and or asistent with the states of confound matters	umber listed above and tell the perse ead the Rumor Problem aloud, assu- therwise interact with the Rumor Co ted problem. Accept reasonable and s by inserting outlandish or extraneous back phone number and assumed in	ming the identity shown ontroller in a manner that swers (solutions) to the ous information. If a call
Assumed Identity	<u>Υ</u> :	Rumor Problem:	
Micky (Rob) Luc 83 Blue Bird Lar Warren, Ohio		"This is an exercise. My family family of evacuees, provided the Do you want to send a family to	ere's not more than four of them
RUMOR MONO	GER NOTES:		

AGL-16

PUBLIC ACCESS AND RUMOR CONTROL PROBLEMS FOR ASHTABULA, GEAUGA, AND LAKE COUNTIES March 21, 2000

Counties: Emerge: ASHTABULA GEAUGA - LAKE -		GE Message #: Approximate Time: Exercise Rumor Monger ID:	AGL-17 1330
<u>DIRECTIONS F</u>	OR THE EXERCIS	SE RUMOR MONGER:	
"have an exercise below. Answer ar is reasonably cons problem; DO NO?	message." Then read by questions and other istent with the stated confound matters b	aber listed above and tell the person of the Rumor Problem aloud, assurtives interact with the Rumor Comproblem. Accept reasonable and inserting outlandish or extrane ack phone number and assumed	ontroller in a manner that swers (solutions) to the ous information. If a call
Assumed Identity:		Rumor Problem:	
Joy (Jason) Craft 11 Avon Rd.		"This is an exercise. I've been on my telephone. Is that the rac This is an exercise."	having trouble getting a dial tone diation causing that?
Ashtabula: Andov	er		
Geauga: Chesterla			-
Lake: Timberlake			•
RUMOR MONG	ER NOTES:		

PUBLIC ACCESS AND RUMOR CONTROL PROBLEMS FOR ASHTABULA, GEAUGA, AND LAKE COUNTIES March 21, 2000

GE

Counties: Emergency Classification:

ASHTABULA	\ - 440-576-3419	Message #:	AGL-18a
GEAUGA -	440-285-2210	Approximate Time:	1345
LAKE -	440-953-5469	Exercise Rumor Monger ID:	
	440-953-5470	č	
DIRECTIONS	FOR THE EXERC	CISE RUMOR MONGER:	
Call the Rumor (Control telephone nu	umber listed above and tell the pers	on who answers that you
"have an exercise	e message." Then re	ead the Rumor Problem aloud, assu	ming the identity shown
below. Answer	any questions and of	therwise interact with the Rumor Co	ontroller in a manner that
is reasonably cor	sistent with the stat	ed problem. Accept reasonable ans	swers (solutions) to the
problem: DO NO	T confound matters	by inserting outlandish or extraneo	ous information. If a call
back to you is in	licated give the call	-back phone number and assumed i	dentity
	arouted give the cun	back phone number and assumed i	dentity.
Assumed Identity	<u>Z</u> :	Rumor Problem:	
Beatrice (Arthur)	Clancy	"This is an exercise. I'm told t	hat the covered bridge in the
321 St. Christoph	•		ere in Harpersfield is cracked du
Harpersfield		to the heavy weight of the traffic	
. 4		Shouldn't it be blocked off? Th	
			is in the cast cise.
DIMEOD ROOM		·	
RUMOR MONO	GER NOTES:		
			····
			· · · · · · · · · · · · · · · · · · ·

	ncy Classification:	GE	
	- 440-576-3419	Message #:	AGL-18b
GEAUGA -	440-285-2210	Approximate Time:	1345
LAKE -	440-953-5469	Exercise Rumor Monger ID:	
	440-953-5470		
DIRECTIONS F	OR THE EXERCI	SE RUMOR MONGER:	
"have an exercise below. Answer as is reasonably cons problem; DO NO	message." Then rea ny questions and othe sistent with the stated T confound matters b	nber listed above and tell the person the Rumor Problem aloud, assumerwise interact with the Rumor Coll problem. Accept reasonable and inserting outlandish or extraneous pack phone number and assumed in	ming the identity shown ontroller in a manner that swers (solutions) to the ous information. If a call
Assumed Identity	:	Rumor Problem:	
Matilda (Tim) Ko		"This is an exercise. A lot of p	
1945 Overlook Di	•	_	that their cars are contaminated,
Thompson		-	lace worse than it already is. Tell
			nent people to stop this, or we'll
		never be able to live here again.	Why are you allowing this to
		happen? This is an exercise."	
RUMOR MONG	ER NOTES:		

PUBLIC ACCESS AND RUMOR CONTROL PROBLEMS FOR ASHTABULA, GEAUGA, AND LAKE COUNTIES March 21, 2000

Message #:

AGL-18c

GE

Counties: Emergency Classification:

ASHTABULA - 440-576-3419

GEAUGA - LAKE -	440-285-2210 440-953-5469 440-953-5470	Approximate Time: Exercise Rumor Monger ID:	1345
DIRECTIONS I	FOR THE EXERG	CISE RUMOR MONGER:	-
"have an exercise below. Answer a is reasonably con problem; DO NO	e message." Then range of the messag	number listed above and tell the personant the Rumor Problem aloud, assurant the Rumor Counterwise interact with the Rumor Counted problem. Accept reasonable and its by inserting outlandish or extraneously back phone number and assumed it	ming the identity shown ontroller in a manner that swers (solutions) to the ous information. If a call
Assumed Identity	<u>ı</u> :	Rumor Problem:	
Phyllis (Jim) Wil 2431 Valley Forg Mentor		"This is an exercise. If I become how will I know? This is an ex	
RUMOR MONO	GER NOTES:		
· · · · · · · · · · · · · · · · · · ·			

Counties: Emerge	ncy Classification: - 440-576-3419	SAE	
GEAUGA -	440-285-2210	Message #: Approximate Time:	Lake-1 1005
LAKE -	440-953-5469	Exercise Rumor Monger ID:	1003
	440-953-5470	3 :	
DIRECTIONS F	OR THE EXERCIS	SE RUMOR MONGER:	
a			
Call the Rumor C	ontrol telephone num	aber listed above and tell the pers	on who answers that you
halow A navion as	message." Then read	d the Rumor Problem aloud, assu	ming the identity shown
is reasonably cons	ly questions and other	erwise interact with the Rumor Co	ontroller in a manner that
problem: DO NO	rent with the stated	problem. Accept reasonable ansy inserting outlandish or extraneous	swers (solutions) to the
back to you is ind	icated give the call-h	ack phone number and assumed i	ous information. If a call
	ioatoa givo the can-o	ack phone number and assumed t	dentity,
Assumed Identity:	:	Rumor Problem:	
Brandy (Damian)	Smith	MTT-in in an annual and Ti	and the property of the
Reporter	Simui	"This is an exercise. I'm a report Have plant officials determined	orter with the Pittsburgh Pres
Pittsburgh Press		What is the worst-case scenario	
Pittsburgh, Pennsy	/lvania	What is the Worst-case section to	: I mis is an exercise.
RUMOR MONG	ER NOTES:		
	····		•

PUBLIC ACCESS AND RUMOR CONTROL PROBLEMS FOR ASHTABULA, GEAUGA, AND LAKE COUNTIES March 21, 2000

Counties: Emerger ASHTABULA GEAUGA - LAKE -		SAE Message #: Approximate Time: Exercise Rumor Monger ID:	Lake-2 1020
DIRECTIONS F	OR THE EXERCI	SE RUMOR MONGER:	
"have an exercise: below. Answer and is reasonably cons problem; DO NO?	message." Then rea by questions and oth istent with the stated confound matters by	nber listed above and tell the pers d the Rumor Problem aloud, assu erwise interact with the Rumor Col d problem. Accept reasonable and by inserting outlandish or extrane back phone number and assumed in	uming the identity shown ontroller in a manner that swers (solutions) to the ous information. If a call
Assumed Identity:		Rumor Problem:	•
Refuse to give ide	ntity	"This is an exercise. My child should I go pick them up? This	
RUMOR MONG	ER NOTES:		

PUBLIC ACCESS AND RUMOR CONTROL PROBLEMS FOR ASHTABULA, GEAUGA, AND LAKE COUNTIES March 21, 2000

SAE

Counties: Emergency Classification:

ASHTABUL	A - 440-576-3419	Message #:	Lake-3
GEAUGA -	440-285-2210	Approximate Time:	1035
LAKE -	440-953-5469	Exercise Rumor Monger ID:	
	440-953-5470	&	
DIRECTIONS	FOR THE EXER	CISE RUMOR MONGER:	
Call the Pumor (Cantral talanhana n	umber listed above and tell the pers	
		ead the Rumor Problem aloud, assu	
		therwise interact with the Rumor C	
is reasonably con	isistent with the sta	ted problem. Accept reasonable and	swers (solutions) to the
problem; DO NO	OT confound matter	s by inserting outlandish or extrane	ous information. If a call
		l-back phone number and assumed	
5 J G W 15 111	and give the dar	Todak phone hamoor and assumed	identity.
Assumed Identit	47. •	Rumor Problem:	
Assumed Identit	Υ ·	Rumor Problem.	
Jean (Calvin) Me	endel	"This is an exercise. I am (My	y wife is) four months pregnant.
22 Stork Lane			eleased from the Perry Plant have
Painesville			•
1 amesyme		on my unborn baby? This is an	i exercise.
RUMOR MON	GER NOTES: _		
		·	·

PUBLIC ACCESS AND RUMOR CONTROL PROBLEMS FOR ASHTABULA, GEAUGA, AND LAKE COUNTIES March 21, 2000

Counties: Emerger ASHTABULA GEAUGA - LAKE -	ncy Classification: - 440-576-3419 - 440-285-2210 - 440-953-5469 - 440-953-5470	SAE Message #: Approximate Time: Exercise Rumor Monger ID:	Lake-4 1105
DIRECTIONS F	OR THE EXERCI	SE RUMOR MONGER:	
"have an exercise below. Answer ar is reasonably cons problem; DO NO?	message." Then rea ny questions and oth- istent with the stated Γ confound matters b	nber listed above and tell the person the Rumor Problem aloud, assurerwise interact with the Rumor Cod problem. Accept reasonable and problem outlandish or extraneous pack phone number and assumed in	ming the identity shown ontroller in a manner that swers (solutions) to the ous information. If a call
Assumed Identity:		Rumor Problem:	
Marisol (Todd) Ta 3427 Red Hawk R Perry	•	that they're not telling us about.	ad has happened at the Perry Plant I know because I live right close ant employees leaving. They know
RUMOR MONG	ER NOTES:		

2000 EVEX SECT. 10.3 Page 29 of 43

PUBLIC ACCESS AND RUMOR CONTROL PROBLEMS FOR ASHTABULA, GEAUGA, AND LAKE COUNTIES March 21, 2000

SAE

Message #:

Counties: Emergency Classification:

ASHTABULA - 440-576-3419

GEAUGA - LAKE -	440-285-2210 440-953-5469 440-953-5470	Approximate Time: Exercise Rumor Monger ID:	1115
DIRECTIONS	FOR THE EXER	CISE RUMOR MONGER:	
"have an exercise below. Answer a is reasonably con problem; DO NO	e message." Then range questions and consistent with the state of confound matter	number listed above and tell the person read the Rumor Problem aloud, assurable interact with the Rumor Conted problem. Accept reasonable answers by inserting outlandish or extraneoul-back phone number and assumed in	ning the identity shown ontroller in a manner that wers (solutions) to the ous information. If a call
Assumed Identity	<u>γ</u> :	Rumor Problem:	
Christina (Brenda Reporter Perry Dispatch Perry, OH	an) Thorton	for the Perry Dispatch. If the acc	late into something much worse?
RUMOR MONO	GER NOTES:		
			<u> </u>

Lake-5

PUBLIC ACCESS AND RUMOR CONTROL PROBLEMS FOR ASHTABULA, GEAUGA, AND LAKE COUNTIES March 21, 2000

SAE

Message #:

Counties: Emergency Classification:

ASHTABULA - 440-576-3419

GEAUGA - LAKE -	440-285-2210 440-953-5469 440-953-5470	Approximate Time: Exercise Rumor Monger ID:	1125
DIRECTIONS I	FOR THE EXERC	CISE RUMOR MONGER:	
"have an exercise below. Answer a is reasonably con problem; DO NO	e message." Then romy questions and or sistent with the state of confound matters.	umber listed above and tell the peread the Rumor Problem aloud, as therwise interact with the Rumor ted problem. Accept reasonable as by inserting outlandish or extransl-back phone number and assume	Suming the identity shown Controller in a manner that answers (solutions) to the neous information. If a call
Assumed Identity	<u>/</u> :	Rumor Problem:	
Debbie (Henry) F 5392 Chatam Rd. Waite Hill	- ·	"This is an exercise. Is it sat "Spring has Sprung" festival	fe for my family to go to the in Thompson? This is an exercise."
RUMOR MONO	GER NOTES:		

Lake-6

PUBLIC ACCESS AND RUMOR CONTROL PROBLEMS FOR ASHTABULA, GEAUGA, AND LAKE COUNTIES March 21, 2000

GE

Message #:

Approximate Time:

Counties: Emergency Classification:

ASHTABULA - 440-576-3419

GEAUGA - 440-285-2210

LAKE -	440-953-5469 440-953-5470	Exercise Rumor Monger ID:
DIRECTIONS	S FOR THE EXERC	CISE RUMOR MONGER:
"have an exercibelow. Answer is reasonably coproblem; DO N	se message." Then re r any questions and ot onsistent with the state OT confound matters	ead the Rumor Problem aloud, assuming the identity shown therwise interact with the Rumor Controller in a manner that ed problem. Accept reasonable answers (solutions) to the by inserting outlandish or extraneous information. If a call-back phone number and assumed identity.
Assumed Identi	ity:	Rumor Problem:
Gina (Jeff) Elto 100 Dorothy Dr Mentor-on-the-	r.	"This is an exercise. Is it true that the Perry Plant employees left and you're running the plant by remote control from a bunker near Lakeland Community College? This is an exercise."
RUMOR MON	NGER NOTES:	
,		

Lake-7

1135

Counties: Emergency Classification:	GE	
ASHTABULA - 440-576-3419	Message #:	Lake-8
GEAUGA - 440-285-2210	Approximate Time:	1145
LAKE - 440-953-5469	Exercise Rumor Monger ID:	
440-953-5470		
DIRECTIONS FOR THE EXERCISE	RUMOR MONGER:	
Call the Rumor Control telephone number	er listed above and tell the persor	who answers that you
"have an exercise message." Then read the	he Rumor Problem aloud, assum	ing the identity shown
below. Answer any questions and otherw	vise interact with the Rumor Cor	stroller in a manner that
is reasonably consistent with the stated pr	roblem. Account reasonable arrange	en (a latia a l'allier that
problem: DO NOT confound method by	ioolem. Accept reasonable answ	vers (solutions) to the
problem; DO NOT confound matters by i	inserting outlandish or extraneou	s information. If a call
back to you is indicated give the call-back	k phone number and assumed ide	entity.
Assumed Identity: R	Lumor Problem:	
Agatha (Clarence) Weathers	This is an exercise. Is the Perry	Plant leaking radiation or not?
· · · · · · · · · · · · · · · · · · ·	'his is an exercise."	Train reaking radiation of not:
Willoughby	ms is an exercise.	
Willoughby		
DUMOD MONGED NORTH		-
RUMOR MONGER NOTES:		

PUBLIC ACCESS AND RUMOR CONTROL PROBLEMS FOR ASHTABULA, GEAUGA, AND LAKE COUNTIES March 21, 2000

GE

Message #:

Approximate Time:

Lake-9

1155

Counties: Emergency Classification:

ASHTABULA - 440-576-3419

GEAUGA - 440-285-2210

LAKE -	440-953-5469 440-953-5470	Exercise Rumor Monger ID:
DIRECTIONS	FOR THE EXERC	ISE RUMOR MONGER:
"have an exercis below. Answer is reasonably coproblem; DO NO	e message." Then re any questions and ot nsistent with the state OT confound matters	amber listed above and tell the person who answers that you ead the Rumor Problem aloud, assuming the identity shown therwise interact with the Rumor Controller in a manner that ed problem. Accept reasonable answers (solutions) to the by inserting outlandish or extraneous information. If a call back phone number and assumed identity.
Assumed Identit	t <u>y</u> :	Rumor Problem:
Lisa (Frank) Gir 8300 Meadows I Mentor	the state of the s	"This is an exercise. I've heard that Mentor Headlands Beach is closed. Is that true? This is an exercise."
RUMOR MON	GER NOTES:	

PUBLIC ACCESS AND RUMOR CONTROL PROBLEMS FOR ASHTABULA, GEAUGA, AND LAKE COUNTIES March 21, 2000

GE

Message #:

LAKE -	440-285-2210 440-953-5469 440-953-5470	Approximate Time: Exercise Rumor Monger ID:	1205
DIRECTIONS F	OR THE EXERC	CISE RUMOR MONGER:	
"have an exercise below. Answer ar is reasonably cons problem; DO NO	message." Then rently questions and of sistent with the stat Γ confound matters	umber listed above and tell the personal the Rumor Problem aloud, assurtherwise interact with the Rumor Content problem. Accept reasonable and so inserting outlandish or extraneous back phone number and assumed in	ming the identity shown ontroller in a manner that wers (solutions) to the ous information. If a call
Assumed Identity	:	Rumor Problem:	
Doris (Cory) Glen 3000 Turtle St. Painesville Towns			at <u>people</u> will be alright after this at effect the radiation will have or s, ants, raccoons and the like.
RUMOR MONG	ER NOTES:		

Counties: Emergency Classification:

ASHTABULA - 440-576-3419

Lake-10

	ncy Classification: - 440-576-3419 440-285-2210 440-953-5469 440-953-5470	GE Message #: Approximate Time: Exercise Rumor Monger ID:	Lake-11 1215
DIRECTIONS F	OR THE EXERCIS	SE RUMOR MONGER:	
"have an exercise below. Answer an is reasonably cons problem; DO NO	message." Then reach reaching questions and other resistent with the stated reconfound matters be	aber listed above and tell the person the Rumor Problem aloud, assiverwise interact with the Rumor College problem. Accept reasonable and inserting outlandish or extransack phone number and assumed	uming the identity shown Controller in a manner that aswers (solutions) to the cous information. If a call
Assumed Identity:		Rumor Problem:	
Angel (Larry) Fern 600 High St. Fairport Harbor	ris	"This is an exercise. I just wa the accident at the Perry Plant, still down at the beach. This is	ant you to know that I know about and that there are four teen-agers an exercise."
RUMOR MONG	ER NOTES:		

PUBLIC ACCESS AND RUMOR CONTROL PROBLEMS FOR ASHTABULA, GEAUGA, AND LAKE COUNTIES March 21, 2000

LAKE - 440-95		GE Message #: Approximate Time: Exercise Rumor Monger ID:	Lake-12 1225
DIRECTIONS FOR T	HE EXERCISE	RUMOR MONGER:	
"have an exercise message below. Answer any quest is reasonably consistent problem; DO NOT confe back to you is indicated	ge." Then read the stions and otherwaith the stated pround matters by it give the call-back	he Rumor Problem aloud, as vise interact with the Rumor roblem. Accept reasonable inserting outlandish or extrack phone number and assume	neous information. If a call
Assumed Identity:	<u>R</u>	Rumor Problem:	
Colleen (Roy) Farrone 2392 Vermont Circle Eastlake	c		ne once and for all, am I supposed to on Lakeshore Drive in Eastlake or
RUMOR MONGER NO	OTES:		

PUBLIC ACCESS AND RUMOR CONTROL PROBLEMS FOR ASHTABULA, GEAUGA, AND LAKE COUNTIES March 21, 2000

GE

Counties: Emergency Classification:

ASHTABULA - 440-576-3419 GEAUGA - 440-285-2210 LAKE - 440-953-5469 440-953-5470	AUGA - 440-285-2210 Approximate Time: KE - 440-953-5469 Exercise Rumor Monger ID:	
DIRECTIONS FOR THE EX	ERCISE RUMOR MONGER:	
"have an exercise message." The below. Answer any questions are is reasonably consistent with the problem; DO NOT confound ma	ne number listed above and tell the personen read the Rumor Problem aloud, assumed otherwise interact with the Rumor Coestated problem. Accept reasonable answerters by inserting outlandish or extraneous call-back phone number and assumed in	ming the identity shown ontroller in a manner that swers (solutions) to the ous information. If a call
Assumed Identity:	Rumor Problem:	
Anne (Leroy) McLaughlin 442 Simpson Rd. Kirtland Hills	"This is an exercise. We've tal there's no real danger to us, but Are we? This is an exercise."	
RUMOR MONGER NOTES:		

Counties: Emergency Classification: ASHTABULA - 440-576-3419 GEAUGA - 440-285-2210 LAKE - 440-953-5469 440-953-5470		GE Message #: Approximate Time: Exercise Rumor Monger ID:	Lake-14 1245
DIRECTIONS F	OR THE EXERCI	SE RUMOR MONGER:	
"have an exercise below. Answer as is reasonably cons problem; DO NO	message." Then rearly questions and othesistent with the states of confound matters in the states.	mber listed above and tell the persud the Rumor Problem aloud, assumerwise interact with the Rumor C d problem. Accept reasonable and by inserting outlandish or extraneousk phone number and assumed in	ontroller in a manner that swers (solutions) to the ous information. If a call
Assumed Identity	:	Rumor Problem:	
Tara (Theodore) F 700 Norman Ave. Wickliffe		"This is an exercise. We live is won't be affected by what's hap. This is an exercise."	
RUMOR MONG	EER NOTES:		
		•	

Counties: Emergency Classification ASHTABULA - 440-576-3419 GEAUGA - 440-285-2210 LAKE - 440-953-5469 440-953-5470	: GE Message #: Approximate Time: Exercise Rumor Monger ID:	Lake-15 1255
DIRECTIONS FOR THE EXERG	CISE RUMOR MONGER:	
Call the Rumor Control telephone in "have an exercise message." Then is below. Answer any questions and of is reasonably consistent with the state problem; DO NOT confound matter back to you is indicated give the call	ead the Rumor Problem aloud, assurtherwise interact with the Rumor Coted problem. Accept reasonable and some by inserting outlandish or extraneous by inserting outlandish or extraneous contractions.	ming the identity shown ontroller in a manner that swers (solutions) to the ous information. If a call
Assumed Identity:	Rumor Problem:	
Doreen (Martin) Strom 8976 Kenston Ct. Minneapolis, Minnesota TX: (999) 555-7231	with my sister Irene Murray in l	trying for hours to get in touch Perry at 2276 East Main Street, entact her and ask that she call me This is an exercise."
RUMOR MONGER NOTES:		
	· · · · · · · · · · · · · · · · · · ·	
Assumed Identity: Doreen (Martin) Strom 8976 Kenston Ct. Minneapolis, Minnesota TX: (999) 555-7231	Rumor Problem: "This is an exercise. I've been with my sister Irene Murray in I but can't reach her. Will you co	trying for hours to get in touc Perry at 2276 East Main Stree entact her and ask that she call

Counties: Emerge	ncy Classification:	GE	
ASHTABULA GEAUGA - LAKE -	- 440-576-3419 440-285-2210 440-953-5469 440-953-5470	Message #: Approximate Time: Exercise Rumor Monger ID:	Lake-16 1305
DIRECTIONS F	OR THE EXERCI	SE RUMOR MONGER:	
"have an exercise below. Answer ar is reasonably cons problem; DO NO	message." Then reany questions and othe istent with the state of confound matters between the states of the states	nber listed above and tell the persed the Rumor Problem aloud, assumerwise interact with the Rumor College problem. Accept reasonable and inserting outlandish or extraneous phone number and assumed	oming the identity shown controller in a manner that swers (solutions) to the cous information. If a call
Assumed Identity		Rumor Problem:	
Debbie (Mark) Be 783 Stevens St. Madison	11	"This is an exercise. I want ye as you think. If you've closed I week, then it's a lot worse than people; tell the truth no matter I This is an exercise."	Lake Erie for the rest of the you're letting on. Don't lie to the
RUMOR MONG	ER NOTES:		<u>.</u>

PUBLIC ACCESS AND RUMOR CONTROL PROBLEMS FOR ASHTABULA, GEAUGA, AND LAKE COUNTIES March 21, 2000

	ncy Classification: - 440-576-3419	GE Message #:	Lake-17
GEAUGA -	440-285-2210	Approximate Time:	1325
LAKE -	440-953-5469	Exercise Rumor Monger ID:	1323
	440-953-5470	Ç	
DIDECTIONS E	OD THE EVEDOR	SE RUMOR MONGER:	
DIRECTIONS F	OR THE EXERCIS	SE RUMOR MONGER:	
Call the Rumor Co	ontrol telephone nun	nber listed above and tell the pers	can who ancwere that you
"have an exercise	message " Then rea	d the Rumor Problem aloud, assu	ming the identity shown
below. Answer as	iv questions and other	erwise interact with the Rumor C	ontroller in a manner that
is reasonably cons	sistent with the stated	problem. Accept reasonable an	swers (solutions) to the
		y inserting outlandish or extrane	
		ack phone number and assumed	
		-	•
Assumed Identity:		Rumor Problem:	
Julie (Arthur) Janl		"This is an exercise. Has the	Perry Plant been fixed yet?
149 Whispering C	reek Rd.	This is an exercise."	
Eastlake			
RUMOR MONG	ER NOTES		
ROMON MONG	EKNOTES.		

Counties: Emergency Classification:	GE	
ASHTABULA - 440-576-3419	Message #:	Lake-18
GEAUGA - 440-285-2210	Approximate Time:	1340
LAKE - 440-953-5469	Exercise Rumor Monger ID:	
440-953-5470		
DIRECTIONS FOR THE EXERCIS	E RUMOR MONGER:	
Call the Rumor Control telephone number "have an exercise message." Then read below. Answer any questions and other is reasonably consistent with the stated problem; DO NOT confound matters by	the Rumor Problem aloud, assurwise interact with the Rumor C problem. Accept reasonable and inserting outlandish or extrane	aming the identity shown Controller in a manner that swers (solutions) to the cous information. If a call
back to you is indicated give the call-ba	ck phone number and assumed	identity.
Assumed Identity:	Rumor Problem:	
Alexis (Troy) Sedgewick	"This is an exercise. Should v	we evacuate now?
333 Gatewood Dr.	This is an exercise."	
Mentor		
Note: Gatewood is outside the 10-mile EPZ.	·	
RUMOR MONGER NOTES:		

SECTION 11.0

OFF-SITE SCENARIOS

This section contains:

Section No.	<u>Title</u>
11.1	Potassium Iodide (KI) Demonstration
11.2	Off-site Monitoring/Decontamination Centers and Stations
11.3	Lake County Medical Services Drill
11.4	Data for Evacuation Estimates

2000 PERRY EVALUATED EXERCISE

11.1 POTASSIUM IODIDE (KI) DEMONSTRATION

Purpose

This mini-scenario is intended to ensure that Objective 14, "Implementation of Protective Actions - Use of KI for Emergency Workers...", is fully demonstrated at all field locations where emergency workers are issued dosimetry-KI packets, regardless of decisions about KI during the "in-sequence" exercise proceedings.

Scenario

If the Department of Health's decision on KI for emergency workers is negative, i.e., KI is not recommended for emergency workers, then the controllers at each location should ensure that evaluators have full opportunity to evaluate demonstrating agencies and individuals on procedures related to KI. Normally this entails nothing more than questioning by the evaluator with corresponding answers by exercise players. Typically, players will show their bottle of KI tablets and the form to be filled out; they will explain the form, show the KI instruction sheet, indicate when KI would be taken; etc. If this is not sufficient for the evaluator, the exercise controller should orally insert the message to take KI with the lead agency person present.

2000 PERRY EVALUATED EXERCISE 11.2 OFF-SITE MONITORING/DECONTAMINATION CENTERS AND STATIONS

A. Monitoring/Decontamination Centers for the Public

Demonstrating Fire Departments:
Kirtland Fire Department
Conneaut Fire department
Middlefield Fire Department

At Monitoring/Decontamination Centers for the Public (M/D Cent. Pub.) the exercise controller will arrange for a total of six monitorings. That is, utilizing volunteers or others available, the fire department will conduct six monitorings consecutively. Six monitorings can be accomplished by monitoring: (a) six people one time; (b) three people two times; (c) two people three times; (d) one person six times, or (e) other combination such as four people once and another person twice. Only six monitorings are necessary. Conduct this process in a manner to satisfy the evaluator.

The exercise controller will orally indicate which person being monitored is contaminated. The first five will not be contaminated and the last one will be. For the contaminated person, the exercise controller will orally indicate that the portal monitor screening process shows that the individual is contaminated. Then, when the contaminated person is in the decontamination area being monitored with a CDV-700 Survey Meter, the exercise controller will provide the following data:

0.3 mR/Hour on the palm of both hands 0.2 mR/Hour on the right elbow.

The first attempt at decontamination by washing and clothing removal will be successful and the exercise controller will indicate background readings on monitoring after this step.

The exercise controller should ensure that the exercise evaluator also has opportunity to observe the locker-room area for the opposite gender.

Vehicle monitoring and decontamination procedures will be demonstrated by interview with the representatives from the responsible fire department. If necessary, the exercise controller will inject contamination readings of .4 mR/hr on the front bumper and grill of a vehicle. After decontamination (simulated), the reading on the bumper and grill will be background.

2000 PERRY EVALUATED EXERCISE 11.2 OFF-SITE MONITORING/DECONTAMINATION CENTERS AND STATIONS

B. Monitoring Decontamination Station for Emergency Workers

Demonstrating Fire Departments:

Mentor Fire Department

The exercise controller will arrange for two monitorings of people, either two people one time or one person twice. One person (the second) will be contaminated and the exercise controller will inject data in the same manner as described above for the contaminated individual at M/D Cen. Pub.

The first attempt to decontaminate by washing and clothing removal will be successful and the exercise controller will indicate background reading on monitoring after this step.

Vehicle monitoring and decontamination procedures will be demonstrated by interview with the representatives from the responsible fire department. If necessary, the exercise controller will inject contamination readings of .4 mR/hr on the front bumper and grill. After decontamination the readings on the front bumper and grill will be background.

2000 PERRY EVALUATED EXERCISE 11.3 LAKE COUNTY MEDICAL SERVICES DRILL

OVERVIEW

The Lake County Emergency Management Agency's medical services drill will be conducted in conjunction with the Perry Nuclear Power Plant on March 21, 2000. The plant will conduct a full scale exercise that will be evaluated by the NRC. As part of that exercise a "mini-scenario" involving a contaminated and injured victim has been developed (refer to Section 9.0 of the Exercise Manual, Plant Mini-Scenario No. 5).

This scenario involves the response of the Perry Township Fire Department to the Perry Plant where they will demonstrate handling of a contaminated and injured victim. The Fire Department ambulance crew will contact the Lake Hospital East (Painesville) and transport the patient to the hospital. No sirens or emergency lights will be employed and traffic laws for normal commercial traffic will be followed.

OBJECTIVE 20

Demonstrate the adequacy of vehicles, equipment, procedures and personnel for transporting contaminated, injured, or exposed individuals.

Demonstrating Agency:

Perry Twp. Fire Dept.

3742 Center Road

Perry, OH

Telephone: 440-259-2880

Contact person: Chief Robert Bates

Time Exercise Play to be Initiated: Approximately 0750 hours on March 21, 2000.

Action Location: The Perry Nuclear Power Plant

Unit #1 Controlled Access Area

10 North Center Road

Perry, OH

The evaluator should meet the exercise controller/Unit #1 escort at the Primary Access Control Point (PACP) at 0730 hours. (Refer to site map enclosed as Attachment 1.) The evaluator will need identification with a photo included.

2000 PERRY EVALUATED EXERCISE 11.3 LAKE COUNTY MEDICAL SERVICES DRILL

OBJECTIVE 21

Demonstrate the adequacy of the equipment, procedures, supplies, and personnel of medical facilities; responsible for treatment of contaminated, injured, or exposed individuals.

Demonstrating Agency:

Emergency Department

Lake East Hospital (Painesville) 10 East Washington Street

Painesville, OH

Directions:

Corner of East Washington and Liberty Streets;

Emergency Room entrance on High Street

Telephone: 440-354-1685


Contact Persons: Pat Casella or Ron Howard

Time: Estimated arrival time of the patient is 0845 hours.

NOTES: The Lake East Hospital is designated in the Lake County Radiological Emergency Response Plan as a hospital in support of the general public. The Hospital is also the primary support hospital for the Perry Plant. The Perry Plant offers its health physics resources to the Lake Hospital System for any radiological accident response for which the hospital desires such support.

Termination of Drill Play: When the patient has been monitored, decontaminated, treated, and ready for movement to regular treatment areas of the hospital the exercise controller will, with agreement of the evaluator, terminate the drill.

2000 PERRY EVALUATED EXERCISE 11.3 LAKE COUNTY MEDICAL SERVICES DRILL



2000 PERRY EVALUATED EXERCISE 11.4 LAKE COUNTY MEDICAL SERVICES DRILL

The attached sheet has data which off-site exercise controllers in each of the three counties (Lake, Ashtabula and Geauga) EOCs will utilize. Controllers will provide EOC staff persons with coordinated data on the percentage of the population that has left the area spontaneously, in response to, or in spite of official protective action decisions.

The exercise controllers with this data will announce to their respective EOC staffs that estimates of population evacuation will <u>not</u> be made-up by them. Rather, any EOC staff person wanting such information will ask the exercise controller who will refer to the attached sheet for the information.

March 21, 2000 Exercise

TIME	Subarea 1	Subarea 2	Subarea 3	Subarea 4	Subarea 5	Subarea 6	Subarea 7
0730			·				
0800							
1000	Some; too small to estimate	Some; too small to estimate	Some; too small to estimate				
1100	10 to 20%	10 to 20%	10 to 20%	Too small to estimate	Too small to estimate	Too small to estimate	Too small to estimate
1200	40 to 60% and more leaving	40 to 60% and more leaving	40 to 60% and more leaving	About 30%	About 30%	About 30%	About 15%
1300	95%	90%	90%	30%	30%	30%	30%
1400	Virtually All	Virtually All	95%	95%	95%	30%	30%