

123 Main Street
White Plains, New York 10601
914 681.6950
914 287.3309 (Fax)



James Knubel
Senior Vice President and
Chief Nuclear Officer

March 17, 2000
IPN-00-024

U.S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, DC 20555

Subject: **Indian Point 3 Nuclear Power Plant**
Docket No. 50-286
1999 Emergency Core Cooling System Evaluation Changes

- References:
1. Westinghouse letter (INT-00-204), S. Ira to R. Barrett, "10 CFR 50.46 Annual Notification and Reporting for 1999," dated February 23, 2000.
 2. NYPA letter to NRC (IPN-99-110), "Emergency Core Cooling System Evaluation Changes," dated October 14, 1999.

Dear Sir:

The Authority has reviewed the 1999 small and large break loss of coolant accident (LOCA) peak cladding temperature (PCT) changes described in Reference 1. There are no additional changes to the small or large break PCT since the submittal of Reference 2. Therefore, the Indian Point 3 PCT remains below the maximum fuel cladding temperature of 2200°F, and Indian Point 3 continues to comply with 10 CFR 50.46. This letter satisfies the annual reporting requirements of 10 CFR 50.46(a)(3)(ii).

No commitments are being made by the Authority in this submittal. If you have any questions, please contact Ms. C. D. Faison.

Very truly yours,

A handwritten signature in black ink, appearing to read 'J. Knubel', written over a large, stylized flourish.

J. Knubel
Senior Vice President and
Chief Nuclear Officer

cc: see next page

A001

cc: Regional Administrator
U.S. Nuclear Regulatory Commission
475 Allendale Road
King of Prussia, PA 19406

Resident Inspector's Office
Indian Point Unit 3
U.S. Nuclear Regulatory Commission
P.O. Box 337
Buchanan, NY 10511

Mr. George F. Wunder, Project Manager
Project Directorate I
Division of Licensing Project Management
U.S. Nuclear Regulatory Commission
Mail Stop 8C4
Washington, DC 20555