

Dave Morey  
Vice President  
Farley Project

Southern Nuclear  
Operating Company  
P.O. Box 1295  
Birmingham, Alabama 35201  
Tel 205.992.5131



March 17, 2000

Docket Nos.: 50-348  
50-364

NEL-00-0072

U. S. Nuclear Regulatory Commission  
ATTN: Document Control Desk  
Washington, DC 20555-0001


Joseph M. Farley Nuclear Plant  
Unit 1 Cycle 16 Core Operating Limits Report – Revision 1 &  
Unit 2 Cycle 14 Core Operating Limits Report – Revision 2

Ladies and Gentlemen:

In accordance with Technical Specification 5.6.5, Southern Nuclear Operating Company hereby submits Revision 1 to the Core Operating Limits Report (COLR) for Farley Nuclear Plant (FNP) Unit 1 Cycle 16 and Revision 2 to the COLR for FNP Unit 2 Cycle 14. These revisions reflect the editorial changes associated with implementation of the Improved Technical Specifications. There are no other changes in these reports.

If you have any questions, please advise.

Respectfully submitted,

  
Dave Morey

MGE/maf: colr02.doc

Attachments:

1. FNP Unit 1 Cycle 16 Core Operating Limits Report Revision 1
2. FNP Unit 2 Cycle 14 Core Operating Limits Report Revision 2

A001

Page 2

U. S. Nuclear Regulatory Commission

cc: Southern Nuclear Operating Company  
Mr. L. M. Stinson, General Manager – Farley

U. S. Nuclear Regulatory Commission, Washington, D. C.  
Mr. L. M. Padovan, Licensing Project Manager – Farley

U. S. Nuclear Regulatory Commission, Region II  
Mr. L. A. Reyes, Regional Administrator  
Mr. T. P. Johnson, Senior Resident Inspector – Farley

**ATTACHMENT 1**

**FNP Unit 1 Cycle 16 Core Operating Limits Report Revision 1**

FARLEY NUCLEAR PLANT (FNP) UNIT 1 CYCLE 16  
CORE OPERATING LIMITS REPORT REVISION 1

FEBRUARY 2000

APPROVED BY:

*Phillip E. ...*      1/31/00  
OPERATIONS MANAGER      DATE



## 1.0 CORE OPERATING LIMITS REPORT

This Core Operating Limits Report (COLR) for FNP UNIT 1 CYCLE 16 has been prepared in accordance with the requirements of Technical Specification 5.6.5.

The Technical Requirement affected by this report is listed below:

- 13.1.1 SHUTDOWN MARGIN - MODES 1 and 2 (with  $k_{eff} \geq 1$ )

The Technical Specifications affected by this report are listed below:

- 3.1.1 SHUTDOWN MARGIN - MODES 2 (with  $k_{eff} < 1$ ), 3, 4 and 5  
3.1.3 Moderator Temperature Coefficient  
3.1.5 Shutdown Bank Insertion Limits  
3.1.6 Control Bank Insertion Limits  
3.2.1 Heat Flux Hot Channel Factor -  $F_Q(Z)$   
3.2.2 Nuclear Enthalpy Rise Hot Channel Factor -  $F_{\Delta H}^N$   
3.2.3 Axial Flux Difference  
3.9.1 Boron Concentration



## 2.0 OPERATING LIMITS

The cycle-specific parameter limits for the specifications listed in Section 1.0 are presented in the following subsections. These limits have been developed using NRC-approved methodologies, including those specified in Technical Specification 5.6.5.

### 2.1 SHUTDOWN MARGIN - MODES 1 AND 2 (with $k_{eff} \geq 1.0$ ) (Technical Requirement 13.1.1)

2.1.1 The SHUTDOWN MARGIN shall be greater than or equal to 1.77 percent  $\Delta k/k$ .

### 2.2 SHUTDOWN MARGIN - MODES 2 (with $k_{eff} < 1.0$ ), 3, 4 and 5 (Specification 3.1.1)

2.2.1 Modes 2 ( $k_{eff} < 1.0$ ), 3 and 4 - The SHUTDOWN MARGIN shall be greater than or equal to 1.77 percent  $\Delta k/k$ .

2.2.2 Mode 5 - The SHUTDOWN MARGIN shall be greater than or equal to 1.0 percent  $\Delta k/k$ .

### 2.3 Moderator Temperature Coefficient (Specification 3.1.3)

2.3.1 The Moderator Temperature Coefficient (MTC) limits are:

The BOL/ARO/HZP-MTC shall be less than or equal to  $+0.7 \times 10^{-4} \Delta k/k/^\circ F$  for power levels up to 70 percent RTP with a linear ramp to 0  $\Delta k/k/^\circ F$  at 100 percent RTP.

The EOL/ARO/RTP-MTC shall be less negative than  $-4.3 \times 10^{-4} \Delta k/k/^\circ F$ .

2.3.2 The MTC Surveillance limits are:

The 300 ppm/ARO/RTP-MTC should be less negative than or equal to  $-3.65 \times 10^{-4} \Delta k/k/^\circ F$ .

The 100 ppm/ARO/RTP-MTC should be less negative than  $-4.0 \times 10^{-4} \Delta k/k/^\circ F$ .

where: BOL stands for Beginning of Cycle Life

ARO stands for All Rods Out

HZP stands for Hot Zero THERMAL POWER

EOL stands for End of Cycle Life

RTP stands for RATED THERMAL POWER



2.4 Shutdown Bank Insertion Limits (Specification 3.1.5)

2.4.1 The shutdown banks shall be withdrawn to a position greater than or equal to 225 steps.

2.5 Control Bank Insertion Limits (Specification 3.1.6)

2.5.1 The control rod banks shall be limited in physical insertion as shown in Figure 1.

2.6 Heat Flux Hot Channel Factor -  $F_Q(Z)$  (Specification 3.2.1)

$$2.6.1 \quad F_Q(Z) \leq \frac{F_Q^{RTP}}{P} \cdot K(Z) \text{ for } P > 0.5$$

$$F_Q(Z) \leq \frac{F_Q^{RTP}}{0.5} \cdot K(Z) \text{ for } P \leq 0.5$$

$$\text{where: } P = \frac{\text{THERMAL POWER}}{\text{RATED THERMAL POWER}}$$

$$2.6.2 \quad F_Q^{RTP} = 2.50$$

2.6.3  $K(Z)$  is provided in Figure 2.

$$2.6.4 \quad F_Q(Z) \leq \frac{F_Q^{RTP} \cdot K(Z)}{P \cdot W(Z)} \text{ for } P > 0.5$$

$$F_Q(Z) \leq \frac{F_Q^{RTP} \cdot K(Z)}{0.5 \cdot W(Z)} \text{ for } P \leq 0.5$$

2.6.5  $W(Z)$  values are provided in Figures 4 through 7.

2.6.6 The  $F_Q(Z)$  penalty factors are provided in Table 1.



2.7 Nuclear Enthalpy Rise Hot Channel Factor -  $F_{\Delta H}^N$  (Specification 3.2.2)

$$2.7.1 \quad F_{\Delta H}^N \leq F_{\Delta H}^{RTP} \cdot (1 + PF_{\Delta H} \cdot (1 - P))$$

$$\text{where: } P = \frac{\text{THERMAL POWER}}{\text{RATED THERMAL POWER}}$$

$$2.7.2 \quad F_{\Delta H}^{RTP} = 1.70$$

$$2.7.3 \quad PF_{\Delta H} = 0.3$$

2.8 Axial Flux Difference (Specification 3.2.3)

2.8.1 The Axial Flux Difference (AFD) acceptable operation limits are provided in Figure 3.

2.9 Boron Concentration (Specification 3.9.1)

2.9.1 The boron concentration shall be greater than or equal to 2000 ppm.<sup>1</sup>

---

<sup>1</sup>This concentration bounds the condition of  $k_{eff} \leq 0.95$  (all rods in less the most reactive rod) and subcriticality (all rods out) over the entire cycle. This concentration includes additional boron to address uncertainties and B<sup>10</sup> depletion.





**Table 1**  
 **$F_Q(Z)$  PENALTY FACTOR**


Cycle Burnup (MWD/MTU)	$F_Q(Z)$ Penalty Factor
All Burnups	1.0200

Notes:

1. The Penalty Factor, to be applied to  $F_Q(Z)$  in accordance with SR 3.2.1.2, is the maximum factor by which  $F_Q(Z)$  is expected to increase over a 39 EFPD interval (surveillance interval of 31 EFPD plus the maximum allowable extension not to exceed 25% of the surveillance interval per SR 3.0.2) starting from the burnup at which the  $F_Q(Z)$  was determined.



Figure 1  
Rod Bank Insertion Limits versus Rated Thermal Power



Fully Withdrawn shall be the condition where control rods are at a position within the interval  $\geq 225$  and  $\leq 231$  steps withdrawn.

NOTE: The Rod Bank Insertion Limits are based on the control bank withdrawal sequence A, B, C, D and a control bank tip-to-tip distance of 128 steps.



Figure 2  
K(Z) - Normalized  $F_Q(Z)$  as a Function of Core Height






Figure 3  
Axial Flux Difference Limits as a Function of  
Rated Thermal Power for RAOC









Figure 5  
RAOC W(Z) at 4000 MWD/MTU




This figure is referred to by Technical Specification B3.2.1

\* Top and Bottom 15% Excluded per Technical Specification B3.2.1



Figure 6  
RAOC W(Z) at 10000 MWD/MTU




This figure is referred to by Technical Specification B3.2.1

Axial Point	Elevation (feet)	MOL-2 W(Z)
*	1	12.00 1.0000
*	2	11.80 1.0000
*	3	11.60 1.0000
*	4	11.40 1.0000
*	5	11.20 1.0000
*	6	11.00 1.0000
*	7	10.80 1.0000
*	8	10.60 1.0000
*	9	10.40 1.0000
*	10	10.20 1.0000
*	11	10.00 1.1931
*	12	9.80 1.1884
*	13	9.60 1.1874
*	14	9.40 1.1983
*	15	9.20 1.2066
*	16	9.00 1.2133
*	17	8.80 1.2158
*	18	8.60 1.2219
*	19	8.40 1.2437
*	20	8.20 1.2650
*	21	8.00 1.2824
*	22	7.80 1.2964
*	23	7.60 1.3066
*	24	7.40 1.3133
*	25	7.20 1.3165
*	26	7.00 1.3165
*	27	6.80 1.3133
*	28	6.60 1.3073
*	29	6.40 1.2986
*	30	6.20 1.2874
*	31	6.00 1.2742
*	32	5.80 1.2581
*	33	5.60 1.2415
*	34	5.40 1.2292
*	35	5.20 1.2202
*	36	5.00 1.2141
*	37	4.80 1.2079
*	38	4.60 1.1996
*	39	4.40 1.1897
*	40	4.20 1.1778
*	41	4.00 1.1679
*	42	3.80 1.1600
*	43	3.60 1.1512
*	44	3.40 1.1413
*	45	3.20 1.1344
*	46	3.00 1.1297
*	47	2.80 1.1293
*	48	2.60 1.1356
*	49	2.40 1.1456
*	50	2.20 1.1555
*	51	2.00 1.1653
*	52	1.80 1.0000
*	53	1.60 1.0000
*	54	1.40 1.0000
*	55	1.20 1.0000
*	56	1.00 1.0000
*	57	0.80 1.0000
*	58	0.60 1.0000
*	59	0.40 1.0000
*	60	0.20 1.0000
*	61	0.00 1.0000

\* Top and Bottom 15% Excluded per Technical Specification B3.2.1



Figure 7  
RAOC W(Z) at 16000 MWD/MTU



Axial Point	Elevation (feet)	EOL W(Z)	
*	1	12.00	1.0000
*	2	11.80	1.0000
*	3	11.60	1.0000
*	4	11.40	1.0000
*	5	11.20	1.0000
*	6	11.00	1.0000
*	7	10.80	1.0000
*	8	10.60	1.0000
*	9	10.40	1.0000
*	10	10.20	1.0000
*	11	10.00	1.1922
*	12	9.80	1.1867
*	13	9.60	1.1881
*	14	9.40	1.2096
*	15	9.20	1.2295
*	16	9.00	1.2479
*	17	8.80	1.2611
*	18	8.60	1.2734
*	19	8.40	1.2975
*	20	8.20	1.3266
*	21	8.00	1.3524
*	22	7.80	1.3731
*	23	7.60	1.3893
*	24	7.40	1.4010
*	25	7.20	1.4082
*	26	7.00	1.4111
*	27	6.80	1.4099
*	28	6.60	1.4049
*	29	6.40	1.3962
*	30	6.20	1.3842
*	31	6.00	1.3689
*	32	5.80	1.3505
*	33	5.60	1.3294
*	34	5.40	1.3055
*	35	5.20	1.2786
*	36	5.00	1.2637
*	37	4.80	1.2546
*	38	4.60	1.2405
*	39	4.40	1.2246
*	40	4.20	1.2061
*	41	4.00	1.1882
*	42	3.80	1.1734
*	43	3.60	1.1613
*	44	3.40	1.1493
*	45	3.20	1.1344
*	46	3.00	1.1315
*	47	2.80	1.1336
*	48	2.60	1.1399
*	49	2.40	1.1521
*	50	2.20	1.1642
*	51	2.00	1.1762
*	52	1.80	1.0000
*	53	1.60	1.0000
*	54	1.40	1.0000
*	55	1.20	1.0000
*	56	1.00	1.0000
*	57	0.80	1.0000
*	58	0.60	1.0000
*	59	0.40	1.0000
*	60	0.20	1.0000
*	61	0.00	1.0000

This figure is referred to by Technical Specification B3.2.1

\* Top and Bottom 15% Excluded per Technical Specification B3.2.1



**ATTACHMENT 2**

**FNP Unit 2 Cycle 14 Core Operating Limits Report Revision 2**

FARLEY NUCLEAR PLANT (FNP) UNIT 2 CYCLE 14  
CORE OPERATING LIMITS REPORT REVISION 2

FEBRUARY 20000

APPROVED BY:

*William E. ...*      1 3/1/00  
OPERATIONS MANAGER      DATE



## 1.0 CORE OPERATING LIMITS REPORT

This Core Operating Limits Report (COLR) for FNP UNIT 2 CYCLE 14 has been prepared in accordance with the requirements of Technical Specification 5.6.5.

The Technical Requirement affected by this report is listed below:

- 13.1.1 SHUTDOWN MARGIN - MODES 1 and 2 (with  $k_{eff} \geq 1$ )

The Technical Specifications affected by this report are listed below:

- 3.1.1 SHUTDOWN MARGIN - MODES 2 (with  $k_{eff} < 1$ ), 3, 4 and 5  
3.1.3 Moderator Temperature Coefficient  
3.1.5 Shutdown Bank Insertion Limits  
3.1.6 Control Bank Insertion Limits  
3.2.1 Heat Flux Hot Channel Factor -  $F_Q(Z)$   
3.2.2 Nuclear Enthalpy Rise Hot Channel Factor -  $F_{\Delta H}^N$   
3.2.3 Axial Flux Difference  
3.9.1 Boron Concentration



## 2.0 OPERATING LIMITS

The cycle-specific parameter limits for the specifications listed in Section 1.0 are presented in the following subsections. These limits have been developed using NRC-approved methodologies, including those specified in Technical Specification 5.6.5.

### 2.1 SHUTDOWN MARGIN - MODES 1 AND 2 (with $k_{eff} \geq 1.0$ ) (Technical Requirement 13.1.1)

2.1.1 The SHUTDOWN MARGIN shall be greater than or equal to 1.77 percent  $\Delta k/k$ .

### 2.2 SHUTDOWN MARGIN - MODES 2 (with $k_{eff} < 1.0$ ), 3, 4 and 5 (Specification 3.1.1)

2.2.1 Modes 2 ( $k_{eff} < 1.0$ ), 3 and 4 - The SHUTDOWN MARGIN shall be greater than or equal to 1.77 percent  $\Delta k/k$ .

2.2.2 Mode 5 - The SHUTDOWN MARGIN shall be greater than or equal to 1.0 percent  $\Delta k/k$ .

### 2.3 Moderator Temperature Coefficient (Specification 3.1.3)

2.3.1 The Moderator Temperature Coefficient (MTC) limits are:

The BOL/ARO/HZP-MTC shall be less than or equal to  $+0.7 \times 10^{-4} \Delta k/k/^{\circ}F$  for power levels up to 70 percent RTP with a linear ramp to 0  $\Delta k/k/^{\circ}F$  at 100 percent RTP.

The EOL/ARO/RTP-MTC shall be less negative than  $-4.3 \times 10^{-4} \Delta k/k/^{\circ}F$ .

2.3.2 The MTC Surveillance limits are:

The 300 ppm/ARO/RTP-MTC should be less negative than or equal to  $-3.65 \times 10^{-4} \Delta k/k/^{\circ}F$ .

The 100 ppm/ARO/RTP-MTC should be less negative than  $-4.0 \times 10^{-4} \Delta k/k/^{\circ}F$ .

where: BOL stands for Beginning of Cycle Life  
ARO stands for All Rods Out  
HZP stands for Hot Zero THERMAL POWER  
EOL stands for End of Cycle Life  
RTP stands for RATED THERMAL POWER



2.4 Shutdown Bank Insertion Limits (Specification 3.1.5)

2.4.1 The shutdown banks shall be withdrawn to a position greater than or equal to 225 steps.

2.5 Control Bank Insertion Limits (Specification 3.1.6)

2.5.1 The control rod banks shall be limited in physical insertion as shown in Figure 1.

2.6 Heat Flux Hot Channel Factor -  $F_Q(Z)$  (Specification 3.2.1)

$$2.6.1 \quad F_Q(Z) \leq \frac{F_Q^{RTP}}{P} \cdot K(Z) \text{ for } P > 0.5$$

$$F_Q(Z) \leq \frac{F_Q^{RTP}}{0.5} \cdot K(Z) \text{ for } P \leq 0.5$$

$$\text{where: } P = \frac{\text{THERMAL POWER}}{\text{RATED THERMAL POWER}}$$

$$2.6.2 \quad F_Q^{RTP} = 2.50$$

2.6.3  $K(Z)$  is provided in Figure 2.

$$2.6.4 \quad F_Q(Z) \leq \frac{F_Q^{RTP} \cdot K(Z)}{P \cdot W(Z)} \text{ for } P > 0.5$$

$$F_Q(Z) \leq \frac{F_Q^{RTP} \cdot K(Z)}{0.5 \cdot W(Z)} \text{ for } P \leq 0.5$$

2.6.5  $W(Z)$  values are provided in Figures 4 through 7.

2.6.6 The  $F_Q(Z)$  penalty factors are provided in Table 1.



2.7 Nuclear Enthalpy Rise Hot Channel Factor -  $F_{\Delta H}^N$  (Specification 3.2.2)

$$2.7.1 \quad F_{\Delta H}^N \leq F_{\Delta H}^{RTP} \cdot (1 + PF_{\Delta H} \cdot (1 - P))$$

$$\text{where: } P = \frac{\text{THERMAL POWER}}{\text{RATED THERMAL POWER}}$$

$$2.7.2 \quad F_{\Delta H}^{RTP} = 1.70$$

$$2.7.3 \quad PF_{\Delta H} = 0.3$$

2.8 Axial Flux Difference (Specification 3.2.3)

2.8.1 The Axial Flux Difference (AFD) acceptable operation limits are provided in Figure 3.

2.9 Boron Concentration (Specification 3.9.1)

2.9.1 The boron concentration shall be greater than or equal to 2000 ppm.<sup>1</sup>

---

<sup>1</sup>This concentration bounds the condition of  $k_{\text{eff}} \leq 0.95$  (all rods in less the most reactive rod) and subcriticality (all rods out) over the entire cycle. This concentration includes additional boron to address uncertainties and B<sup>10</sup> depletion.



**Table 1**  
 **$F_Q(Z)$  PENALTY FACTOR**


Cycle Burnup (MWD/MTU)	$F_Q(Z)$ Penalty Factor
All Burnups	1.0200

**Notes:**

1. The Penalty Factor, to be applied to  $F_Q(Z)$  in accordance with SR 3.2.1.2, is the maximum factor by which  $F_Q(Z)$  is expected to increase over a 39 EFPD interval (surveillance interval of 31 EFPD plus the maximum allowable extension not to exceed 25% of the surveillance interval per SR 3.0.2) starting from the burnup at which the  $F_Q(Z)$  was determined.



Figure 1  
Rod Bank Insertion Limits versus Rated Thermal Power



Fully Withdrawn shall be the condition where control rods are at a position within the interval  $\geq 225$  and  $\leq 231$  steps withdrawn.

NOTE: The Rod Bank Insertion Limits are based on the control bank withdrawal sequence A, B, C, D and a control bank tip-to-tip distance of 128 steps.





Figure 2  
 $K(Z)$  - Normalized  $F_Q(Z)$  as a Function of Core Height






Figure 3  
Axial Flux Difference Limits as a Function of  
Rated Thermal Power for RAOC







Figure 4  
RAOC W(Z) at 150 MWD/MTU




This figure is referred to by Technical Specification B3.2.1

Axial Point	Elevation (feet)	BOL W(Z)
1	12.00	1.0000
2	11.80	1.0000
3	11.60	1.0000
4	11.40	1.0000
5	11.20	1.0000
6	11.00	1.0000
7	10.80	1.0000
8	10.60	1.0000
9	10.40	1.0000
10	10.20	1.0000
11	10.00	1.2487
12	9.80	1.2380
13	9.60	1.2335
14	9.40	1.2328
15	9.20	1.2283
16	9.00	1.2188
17	8.80	1.2151
18	8.60	1.2182
19	8.40	1.2292
20	8.20	1.2370
21	8.00	1.2417
22	7.80	1.2439
23	7.60	1.2433
24	7.40	1.2403
25	7.20	1.2374
26	7.00	1.2336
27	6.80	1.2281
28	6.60	1.2206
29	6.40	1.2115
30	6.20	1.2009
31	6.00	1.2365
32	5.80	1.2230
33	5.60	1.2081
34	5.40	1.1923
35	5.20	1.1828
36	5.00	1.1827
37	4.80	1.1857
38	4.60	1.1867
39	4.40	1.1873
40	4.20	1.1870
41	4.00	1.1857
42	3.80	1.1851
43	3.60	1.1854
44	3.40	1.1853
45	3.20	1.1861
46	3.00	1.1944
47	2.80	1.2136
48	2.60	1.2350
49	2.40	1.2561
50	2.20	1.2773
51	2.00	1.2983
52	1.80	1.0000
53	1.60	1.0000
54	1.40	1.0000
55	1.20	1.0000
56	1.00	1.0000
57	0.80	1.0000
58	0.60	1.0000
59	0.40	1.0000
60	0.20	1.0000
61	0.00	1.0000

\* Top and Bottom 15% Excluded per Technical Specification B3.2.1



Figure 5  
RAOC W(Z) at 4000 MWD/MTU




Axial Point	Elevation (feet)	MOL-1 W(Z)
* 1	12.00	1.0000
* 2	11.80	1.0000
* 3	11.60	1.0000
* 4	11.40	1.0000
* 5	11.20	1.0000
* 6	11.00	1.0000
* 7	10.80	1.0000
* 8	10.60	1.0000
* 9	10.40	1.0000
* 10	10.20	1.0000
* 11	10.00	1.2618
* 12	9.80	1.2641
* 13	9.60	1.2638
* 14	9.40	1.2633
* 15	9.20	1.2592
* 16	9.00	1.2500
* 17	8.80	1.2467
* 18	8.60	1.2499
* 19	8.40	1.2587
* 20	8.20	1.2642
* 21	8.00	1.2665
* 22	7.80	1.2662
* 23	7.60	1.2630
* 24	7.40	1.2574
* 25	7.20	1.2512
* 26	7.00	1.2446
* 27	6.80	1.2366
* 28	6.60	1.2264
* 29	6.40	1.2146
* 30	6.20	1.2012
* 31	6.00	1.2104
* 32	5.80	1.1941
* 33	5.60	1.1776
* 34	5.40	1.1643
* 35	5.20	1.1556
* 36	5.00	1.1541
* 37	4.80	1.1542
* 38	4.60	1.1531
* 39	4.40	1.1514
* 40	4.20	1.1488
* 41	4.00	1.1456
* 42	3.80	1.1418
* 43	3.60	1.1387
* 44	3.40	1.1378
* 45	3.20	1.1411
* 46	3.00	1.1454
* 47	2.80	1.1560
* 48	2.60	1.1748
* 49	2.40	1.1924
* 50	2.20	1.2100
* 51	2.00	1.2278
* 52	1.80	1.0000
* 53	1.60	1.0000
* 54	1.40	1.0000
* 55	1.20	1.0000
* 56	1.00	1.0000
* 57	0.80	1.0000
* 58	0.60	1.0000
* 59	0.40	1.0000
* 60	0.20	1.0000
* 61	0.00	1.0000

This figure is referred to by Technical Specification B3.2.1

\* Top and Bottom 15% Excluded per Technical Specification B3.2.1



Figure 6  
RAOC W(Z) at 10000 MWD/MTU




This figure is referred to by Technical Specification B3.2.1

Axial Point	Elevation (feet)	MOL-2 W(Z)
1	12.00	1.0000
2	11.80	1.0000
3	11.60	1.0000
4	11.40	1.0000
5	11.20	1.0000
6	11.00	1.0000
7	10.80	1.0000
8	10.60	1.0000
9	10.40	1.0000
10	10.20	1.0000
11	10.00	1.2324
12	9.80	1.2281
13	9.60	1.2215
14	9.40	1.2148
15	9.20	1.2214
16	9.00	1.2312
17	8.80	1.2371
18	8.60	1.2447
19	8.40	1.2596
20	8.20	1.2749
21	8.00	1.2917
22	7.80	1.3053
23	7.60	1.3151
24	7.40	1.3215
25	7.20	1.3243
26	7.00	1.3238
27	6.80	1.3201
28	6.60	1.3135
29	6.40	1.3040
30	6.20	1.2920
31	6.00	1.2773
32	5.80	1.2610
33	5.60	1.2411
34	5.40	1.2198
35	5.20	1.2180
36	5.00	1.2170
37	4.80	1.2131
38	4.60	1.2083
39	4.40	1.2016
40	4.20	1.1931
41	4.00	1.1833
42	3.80	1.1717
43	3.60	1.1597
44	3.40	1.1508
45	3.20	1.1480
46	3.00	1.1559
47	2.80	1.1733
48	2.60	1.1878
49	2.40	1.2024
50	2.20	1.2167
51	2.00	1.2308
52	1.80	1.0000
53	1.60	1.0000
54	1.40	1.0000
55	1.20	1.0000
56	1.00	1.0000
57	0.80	1.0000
58	0.60	1.0000
59	0.40	1.0000
60	0.20	1.0000
61	0.00	1.0000

\* Top and Bottom 15% Excluded per Technical Specification B3.2.1



Figure 7  
RAOC W(Z) at 16000 MWD/MTU



Axial Point	Elevation (feet)	EOL W(Z)
*		
1	12.00	1.0000
2	11.80	1.0000
3	11.60	1.0000
4	11.40	1.0000
5	11.20	1.0000
6	11.00	1.0000
7	10.80	1.0000
8	10.60	1.0000
9	10.40	1.0000
10	10.20	1.0000
11	10.00	1.2002
12	9.80	1.1902
13	9.60	1.1873
14	9.40	1.1922
15	9.20	1.2037
16	9.00	1.2238
17	8.80	1.2418
18	8.60	1.2598
19	8.40	1.2827
20	8.20	1.3092
21	8.00	1.3326
22	7.80	1.3513
23	7.60	1.3659
24	7.40	1.3763
25	7.20	1.3826
26	7.00	1.3849
27	6.80	1.3834
28	6.60	1.3783
29	6.40	1.3697
30	6.20	1.3580
31	6.00	1.3431
32	5.80	1.3269
33	5.60	1.3135
34	5.40	1.2973
35	5.20	1.2790
36	5.00	1.2689
37	4.80	1.2623
38	4.60	1.2513
39	4.40	1.2383
40	4.20	1.2231
41	4.00	1.2055
42	3.80	1.1895
43	3.60	1.1744
44	3.40	1.1622
45	3.20	1.1482
46	3.00	1.1381
47	2.80	1.1468
48	2.60	1.1620
49	2.40	1.1768
50	2.20	1.1913
51	2.00	1.2056
52	1.80	1.0000
53	1.60	1.0000
54	1.40	1.0000
55	1.20	1.0000
56	1.00	1.0000
57	0.80	1.0000
58	0.60	1.0000
59	0.40	1.0000
60	0.20	1.0000
61	0.00	1.0000

This figure is referred to by Technical Specification B3.2.1

\* Top and Bottom 15% Excluded per Technical Specification B3.2.1