



FOR PAID REFERENCE DRAWINGS, SYMBOLS AND ABBREVIATIONS REFER TO DRAWINGS PAID - LEGEND 1 AND PAID - LEGEND 2

LEGEND

DESIGN	TEST PRESSURE	MIN. TEST PRESSURE	TEST TEMP. F.	TEST MEDIUM
Y				TEST BOUNDARY
(E4)	150 PSIG	225/245 PSIG	60	WATER
(F1)	150 PSIG	187.5/199 PSIG	60	WATER
(N)				NO TEST REQUIRED

NOTES:
 * VENTS & DRAINS WITH CAPS/BLIND FLANGES ETC. SHALL BE TESTED TO THE LAST ISOLATION VALVE.

- NOTES:
- WORK THIS DRAWING WITH DRAWINGS 28204 THRU 28215.
 - ALL LINES, EQUIPMENT, COMPONENTS AND INSTRUMENTS HAVE SYSTEM PREFIX I-CC UNLESS NOTED OTHERWISE.
 - INSTRUMENT REFERENCES:
 (B) FROM BRS-PT-3A DWG. 28058
 (C) FROM BRS-TE-7A DWG. 28058
 (D) FROM BRS-TE-15A DWG. 28058
 - VENT & DRAIN CODE BREAKS ARE AT THE DOWNSTREAM END OF THE OUTER ISOLATION VALVE PER I-NV-08011 UNLESS OTHERWISE NOTED.
 - THE IDENTIFICATION 'J' NEAR A VALVE DENOTES THAT VALVE IS DESIGNATED FOR INSERVICE TESTING.
 - CLEANLINESS CLASS 'C'
 - PORTION OF SYSTEM HAS BEEN DOWNGRADED, HOWEVER PIPING SPECIFICATION HAS BEEN MAINTAINED TO SAFETY CLASS NOMENCLATURE. SOME COMPONENTS WITHIN THE NEW BOUNDARY HAVE BEEN PROCURED TO SAFETY CLASS 3 REQUIREMENTS, BUT USED IN INHS SERVICE.
 - S.D. NO. IS SD-23
 - * INDICATES EQUIPMENT, PIPING, VALVES & INSTRUMENTS FURNISHED WITH EVAPORATOR PACKAGE BY VENDOR & INSTALLED BY USEC.

PORTIONS OF THIS DRAWING ARE
NUCLEAR SAFETY RELATED

REV	DATE	DSGN	DRWN	CHKD	CODE	SES	DESCRIPTION
6	7/26/86	BCL		MPW	PLS	JJM	INCORP. MHOD 93-544 CAB
5	3/1/85	MRB		BCL	DWS	JCM	INCORP. MHOD 92-553 CAB
4	4/23/85	MRB		BCL	JEV	RRB	INCORP. MHODS 91-515 CAB & 91-622 CAB
3	2/27/85	MRB	RHC	GPH	APL	RRC	INCORPORATED DCR 88-85 CAB REVISED NOTE 4 & LEGEND NOTE 4 PER ANSI 801.1-1977-SEC. 137.1.2 DELETED NNS-1 CLASS BOUNDARY
2	11/14/86	JDM	OPD	WRD	BCL	RRC	REVISED SAFETY CLASS BREAKS AT VENTS & DRAINS PER USE OF NOTE 4. CORRECTED LINE NUMBER PER REVIEW OF REFERENCE DWS. REVISED CONT. DWS. COORDS. NOTE 4. PAID LEGEND NOTE 4 INTO REF. DWG. 28213. DWS. UPDATED REV'S. COMPLETED N.Y. TYPE
1	9/12/86	MPW	TAK	MHP	BCL	RRC	REVISED PER NCR 73/78148. REVISED SKID PIPING PER PP-5177. CHANGED V648 & V641 TO GATE VALVES. ADDED NOTE 8
0	6/28/86	TAK	JEV	BCL	JM	RRC	ISSUED FOR OPERATIONS

North Atlantic Energy Service Corporation

PRIMARY COMPONENT COOLING LOOP B DETAIL

28213

REF. DRAWING NO.	REV	TITLE
9763-F-908177	4	RADIOACTIVE GAS WASTE MITD
9763-F-908155	3	PCCW LOOP B MITD
9763-F-908143	3	PCCW LOOP B MITD
9763-F-908116	2	PCCW LOOP B MITD
9763-F-895612	13	RADIOACTIVE GAS WASTE SYSTEM SHT. 2 P&ID
9763-F-895816	16	PCCW LOOP B-SHT 1 P&I D.
9763-F-895828	14	PCCW LOOP B-SHT 2 P&I D.
9763-F-894982	18	PCCW LOOP B-SHT 3 P&I D.

FOR INFORMATION ONLY

D-10