ALT.	DATE	REVISION	BY	CKD.
A	12-16-68	ADDED (2) TWO 3" SCH. 80 PIPES DIAGONALLY FROM WEST SHORE PLATE TO TUBE SUPPORT PLATES REVISED STRUT ARRANGEMENT ARRIVE ELEVATION 924'-0"±1/2" A.I.E. LETTER DATED 12-12-68 ADDED DETAILS 2" & 5"	G.F.M.	M.N.R.
B	2-12-69	ZONE B2 - ADDED 1 - 3" SCH. 80 CARBON BRACE B5 - RELOCATED 5" PIPE (WAS 4" PIPE) B2 - RELOCATED CONDENSE BAFFLE C3 FIG. - ADD A 3" PIPE M1 - REVISED NOTE 1. M8 & M21 - RELOCATED HOLD W. CLOSURE PL. B2 - RELOCATED CC.W.I. K. B1 - RELOCATED CC.W.I. P. B12 - RELOCATED CC.W.I. Q. ADDED CUTS TO SUPPORTS IN PLAN VIEW. REVISED STRUT ARRANGEMENT AT ELEVATION 924'-0" PER S.I.E. LTR. DATED 1-27-69 & AS PER TELECON 2-3-69	G.F.M.	M.N.R.
C	4-17-69	RELOCATED TWO OUTLET PIPE STUBS FROM CONDENSER SHELL TO PIPE NOZZLE CTR. SHIFT 5" PIPE REVISED PER S.I.E. LTR. DATED 3-31-69 AND MARKED FIELD CHANGE 1-24-69	G.F.M.	M.N.R.
D	4-24-69	ADDED PIECE MARKERS TO DETAILS	E.F.H.	M.N.R.
E	7/16/69	RELOCATED PIPE STIFFENER IN ZONE C-4.	L.D.C.	M.N.R.
F	11-4-69	ADDED ANGLE STIFFENER TO HEATER SUPPORT ZONE K-11 PER G.E.H. LTR. DATED 5-23-69	D.R.C.	M.N.R.





(TYPICAL 4 PLACES)

VIEW P-P



(TYPICAL 4 PLACES)

VIEW Q-Q





SECTION P-P

(CENTER LINE STRUTTING ARRANGEMENT AT ELEVATION 924'-2")

DETAIL "R"



(CENTER LINE STRUTTING ARRANGEMENT AT ELEVATION 921'-6")

DETAIL "S"



VIEW M-M



VIEW N-N

NOTES:
1. SEE DWG EC938773P-1A FOR VIEWS D-D, E-E, F-F, G-G, AND V-V.
2. DETAIL "K" ON DWG EC938773P-1A APPLIES TO SOUTH CORNERS OF SHELL 1B AND DETAIL "K" APPLIES TO NORTH CORNERS OF SHELL 1B.

RECEIVED
FEB
BURNS and ROE
HEMPSTEAD

FILMED
RECEIVED
JUL 10 1975
008165

EXPIRES ON
MAR 27 2000
STOP
STOP
NOT CONTROLLED

	7/16	E
	DATE	REV.

COOPER NUCLEAR STATION
CONTRACT No. E-68-4

RELEASE FOR MFR.

INDUSTRIAL PRODUCTS DIVISION
MARYLAND SHIPBUILDING & DRYDOCK CO.
BALTIMORE, MD.

INTERNAL PIPING
STRUT ARRANGEMENT
(CONDENSER SHELL 1B)

FOR CONSUMERS PUBLIC POWER DISTRICT

DESIGNED	CHECKED	M.N.R. 4-3-69
DRAWN G.F.M.	APPROVED	

CONT. NO.	SCALE	DRWG.	REV.
93877	1/2"=1'0"	EC938773A-1B	F

OCT. 4, 1977 IN.PPD.

D-7