



FOR P&ID REFERENCE DRAWINGS, SYMBOLS AND ABBREVIATIONS REFER TO DRAWINGS PAID - LEGEND 1 AND PAID - LEGEND 2

LEGEND				
DESIGN	TEST	TEST	TEST	
PRESSURE	PRESSURE	TEMP °F	MEDIUM	
Y	TEST BOUNDARY			
YB	TEMPORARY TEST BOUNDARY			
A2	INTEGRITY TEST	2485 PSIG	3106/3242 PSIG	100 D.M. WATER
C7	INTEGRITY TEST	15	900 PSIG	900 PSIG 100 D.M. WATER
C8	INTEGRITY TEST	15	600 PSIG	900 PSIG 100 D.M. WATER
E4	INTEGRITY TEST	15	150 PSIG	22/-245 PSIG 35 D.M. WATER
F2	INTEGRITY TEST	15	100 PSIG	150/178 PSIG 35 WATER
I5	INITIAL SERVICE N.O.P.			
R	NO TEST REQUIRED			

NOTE:
A. VENTS & DRAINS WITH CAPS/BLIND FLANGES ETC. (SEE CL. 2 & 3 NMS) SHALL BE TESTED TO THE LAST ISOLATION VALUE.

- NOTES:
- INDICATES GENERAL NOTE NUMBER. REFER TO DRAWING 28848 FOR GENERAL NOTES.
 - WORK THIS DRAWING WITH DRAWINGS 28848 THRU 28849 & 28848.
 - ALL LINES, EQUIPMENT, COMPONENTS AND INSTRUMENTS HAVE SYSTEM PREFIX, UNLESS NOTED OTHERWISE.
 - VENT, DRAIN & TEST DOWN CODE BREAKS ARE AT THE DOWNSTREAM END OF THE OUTER ISOLATION VALVE PER 1-NHY-005111 UNLESS NOTED OTHERWISE.
 - INDICATES REVISION LEVEL.
 - CLEANLINESS CLASS "B".
 - SD NO. IS NAW/ANCH 281.
 - DELETED.
 - VALVE STEM LEAK-OFF ISOLATION VALVES V433 & V434 ARE TO BE MAINTAINED CLOSED. VALVE STEM LEAK-OFF TO BE CONSIDERED INOPERABLE.
 - TYGON TUBING/REINFORCED POLYURETHANE "INTERFACE" IS TO BE INSTALLED WHEN REQUIRED DURING SHUTDOWN MODE FOR VENTING RCS SYSTEM.
 - DURING PRE-OUTAGE PRESSURIZER PURGING A TEMPORARY SPOOL PIECE TAG 1-VG-MH-9808 (1/4" SS BRAIDED HOSE WITH A ROTOMEX™) TO BE INSTALLED TEMPORARY SPOOL PIECE WILL BE REMOVED FOLLOWING COMPLETION OF PURGING ACTIVITIES (DCR 97-16).

PORTIONS OF THIS DRAWING ARE

NUCLEAR SAFETY RELATED										
12	2/27/77	BCL	JAC	WFL	MAC	WFL	MAC	WFL	MAC	INCORP. DCR 97-16 CA B
11	5/13/77	DMS	MPW	FAC	DMD	INCORP. DCR 97-16 CA B				INCORP. DCR 97-16 CA B
10	5/28/77	MPW	DMS	HMM	RCB	INCORP. DCR 97-16 CA B				INCORP. DCR 97-16 CA B
9	5/14/77	MPW	DMS	HMM	WFL	PARTIAL REV. DCR 97-16 CA B				INCORP. DCR 97-16 CA B
8	2/16/76	RHC	FEB	HMB	BCL	INCORP. REV. 13/12/76				INCORP. DCR 97-16 CA B
7	9/24/75	HMB	TGB	JM	GPM	WLT	INCORP. REV. 10/22/75			INCORP. DCR 97-16 CA B
6	8/26/74	HMB	JM	FGB	GPM	W	INCORP. REV. 8/26/74			INCORP. DCR 97-16 CA B
5	12/28/73	HMB	JM	CCM	APL	MAC	INCORP. REV. 12/28/73			INCORP. DCR 97-16 CA B
4	12/13/73	HMB	RHC	GPM	APL	MJY	INCORPORATED REV. 12/13/73			INCORP. DCR 97-16 CA B
3	12/15/77	GPM	JM	DMS	BCL	PAG	INCORPORATED REV. 12/15/77			INCORP. DCR 97-16 CA B
2	11/6/76	JOM	TAK	PAL	BCL	RRC	INCORP. DCR 97-16 CA B			INCORP. DCR 97-16 CA B
1	1/26/76	PAL	JAC	BCL	VNK	RRC	INCORP. DCR 97-16 CA B			INCORP. DCR 97-16 CA B
0	6/27/76	TAK	JAC	BCL	DMS	RRC	ISSUED FOR OPERATIONS			INCORP. DCR 97-16 CA B
REV	DATE	DSGN	DRWN	CHKD	CDR	SES	ISSUED FOR OPERATIONS			INCORP. DCR 97-16 CA B
							DESCRIPTION			INCORP. DCR 97-16 CA B

North Atlantic Energy Service Corporation

REACTOR COOLANT SYSTEM PRESSURIZER

PID- 1-RC-D20846

SEABROOK STATION

REF. DRAWING NO.	REV	TITLE
9763-N-000135	2	REACTOR COOLANT PRESSURIZER-MITD
9763-F-000138	3	RCS REACTOR VESSEL MITD
9763-F-805007	14	RCS PRESSURIZER P & ID
9763-F-805002	13	RCS REACTOR VESSEL P & ID

D-59