

March 30, 2000

Mr. Ralph Phelps, Chairman
CE Owners Group
Omaha Public Power District
P.O. Box 399
Ft. Calhoun, NE 68023-0399

SUBJECT: REQUEST FOR ADDITIONAL INFORMATION (RAI) REGARDING
CE NPSD-1167, "ELIMINATION OF PRESSURE SENSOR RESPONSE TIME
TESTING REQUIREMENTS, REVISION 1" (TAC NO. MA6010)

Dear Mr. Phelps:

By letter dated September 30, 1999, the Combustion Engineering Owners Group (CEOG) submitted Revision 1 to CE NPSD-1167, "Elimination of Pressure Sensor Response Time Testing Requirements," for staff review. CE NPSD-1167, Revision 1 modified the pressure transmitter allocated response times from values based upon historical data collected at the plants to values based upon vendor data of expected response times of properly operating instruments. On March 14, 2000, ABB-CE submitted seven errata and clarifying pages to CE NPSD-1167, Revision 1. As a result of the review, the staff has determined that additional information is needed to complete the review. The information needed is detailed in the enclosure.

The enclosed request was discussed with Mr. Paggen on March 20, 2000. A mutually agreeable target date of April 10, 2000, was established for responding to the RAI. If circumstances result in the need to revise the target date, please call me at your earliest opportunity at (301) 415-1424.

Sincerely,

/RA/

Jack Cushing, Project Manager, Section 2
Project Directorate IV & Decommissioning
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Project No. 692

Enclosure: Request for Additional Information

cc w/encl: See next page

March 30, 2000

Mr. Ralph Phelps, Chairman
CE Owners Group
Omaha Public Power District
P.O. Box 399
Ft. Calhoun, NE 68023-0399

SUBJECT: REQUEST FOR ADDITIONAL INFORMATION (RAI) REGARDING
CE NPSD-1167, "ELIMINATION OF PRESSURE SENSOR RESPONSE TIME
TESTING REQUIREMENTS REVISION 1." (TAC NO. MA6010)

Dear Mr. Phelps:

By letter dated September 30, 1999, the Combustion Engineering Owners Group (CEOG) submitted Revision 1 to CE NPSD-1167, "Elimination of Pressure Sensor Response Time Testing Requirements," for staff review. CE NPSD-1167, Revision 1 modified the pressure transmitter allocated response times from values based upon historical data collected at the plants to values based upon vendor data of expected response times of properly operating instruments. On March 14, 2000, ABB-CE submitted seven errata and clarifying pages to CE NPSD-1167, Revision 1. As a result of the review, the staff has determined that additional information is needed to complete the review. The information needed is detailed in the enclosure.

The enclosed request was discussed with Mr. Paggen on March 20, 2000. A mutually agreeable target date of April 10, 2000, was established for responding to the RAI. If circumstances result in the need to revise the target date, please call me at your earliest opportunity at (301) 415-1424.

Sincerely,

/RAI/

Jack Cushing, Project Manager, Section 2
Project Directorate IV & Decommissioning
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Project No. 692

Enclosure: Request for Additional Information

cc w/encl: See next page

DISTRIBUTION:

File Center
PUBLIC
PDIV-2 Reading
SCubbage

OGC (RidsOgcRp)
ACRS (RidsAcrcsAcnwMailCenter)
SRichards (RidsNrrDlpmLpdiv)
DMcCain

SBlack (RidsNrrDlpm)
LBerry
PLoeser

| To receive a copy of this document, indicate "C" in the box | | | | | |
|---|-------------|---|-----------|---|-----------|
| OFFICE | PDIV-2/PM | C | PDIV-2/LA | C | PDIV-2/SC |
| NAME | JCushing:am | | EPeyton | | SDembek |
| DATE | 03/30/00 | | 03/30/00 | | 03/30/00 |

DOCUMENT NAME: C:\RAIA6010.wpd

OFFICIAL RECORD COPY

CE Owners Group

Project No. 692

cc:

Mr. Gordon C. Bischoff, Project Director
CE Owners Group
ABB Combustion Engineering Nuclear Power
M.S. 9615-1932
2000 Day Hill Road
Post Office Box 500
Windsor, CT 06095

Mr. Charles B. Brinkman, Manager
Washington Operations
ABB Combustion Engineering Nuclear Power
12300 Twinbrook Parkway, Suite 330
Rockville, MD 20852

Mr. Ian C. Rickard, Director
Nuclear Licensing
ABB Combustion Engineering Nuclear Power
2000 Day Hill Road
Post Office Box 500
Windsor, CT 06095

REQUEST FOR ADDITIONAL INFORMATION

CE NPSD-1167, REVISION 1, "ELIMINATION OF PRESSURE SENSOR

RESPONSE TIME TESTING REQUIREMENTS"

1. The Combustion Engineering Owners Group (CEOG) proposed using historical data to determine the allocated response times for those sensors for which the manufacturer has not provided response time values. The historic calibration data for Florida Power & Light Company, which uses a Rosemount 1154 with variable damping at the St. Lucie units, was not provided in Revision 1 of CE NPSD-1167. Please provide the historic calibration data for the Rosemount 1154 with variable damping, since this data is necessary to verify the allocated response times requested by the CEOG.

Enclosure