

Template =  
NRR-058

March 24, 2000

Mr. Craig G. Anderson  
Vice President, Operations ANO  
Entergy Operations, Inc.  
1448 S. R. 333  
Russellville, AR 72801

SUBJECT: ARKANSAS NUCLEAR ONE, UNIT NO. 2 - ISSUANCE OF AMENDMENT RE:  
DELETION OF THE 18-MONTH SURVEILLANCE OF THE BORONOMETER  
SEALED SOURCE (TAC NO. MA8103)

Dear Mr. Anderson:

The Commission has issued the enclosed Amendment No. 212 to Facility Operating License No. NPF-6 for Arkansas Nuclear One, Unit No. 2. This amendment consists of changes to the Technical Specifications (TSs) in response to your application dated January 27, 2000.

The amendment deletes the current requirements of TS 4.7.9.1.2.d, "Source installed in the Boronometer," associated with the installed boronometer sealed source. The source was recently removed and stored, and the requirements of TS 4.7.9.1.2.d are no longer applicable.

A copy of our related Safety Evaluation is also enclosed. The Notice of Issuance will be included in the Commission's next biweekly *Federal Register* notice.

Sincerely,

/RA/

Thomas W. Alexion, Project Manager, Section 1  
Project Directorate IV & Decommissioning  
Division of Licensing Project Management  
Office of Nuclear Reactor Regulation

Docket No. 50-368

Enclosures:

- 1. Amendment No. 212 to NPF-6
- 2. Safety Evaluation

cc w/encls: See next page

DISTRIBUTION

<del>File Center</del>	S.Richards (cover ltr only)
PUBLIC	W.Beckner
PDIV-1 RF	K.Brockman,RIV
G.Hill(2)	L.Hurley,RIV
ACRS	J.Kilcrease,RIV
OGC	

\*See previous concurrence

\*\* No legal objection

To receive a copy of this document, indicate "C" in the box									
OFFICE	PDIV-1/PM	C	PDIV-1/LA	C	RTSB*	OGC*	PDIV-1/SC	C	
NAME	T.Alexion		D.Johnson		W.Beckner	AHodgdon**	R.Gramm		RG
DATE	03/24/00		03/24/00		2/28/00	3/02/00	3/24/00		

DOCUMENT NAME: G:\PDIV-1\ANO2\AMDA8103.wpd

OFFICIAL RECORD COPY

DFol

Arkansas Nuclear One

cc:

Executive Vice President  
& Chief Operating Officer  
Entergy Operations, Inc.  
P. O. Box 31995  
Jackson, MS 39286-1995

Vice President, Operations Support  
Entergy Operations, Inc.  
P. O. Box 31995  
Jackson, MS 39286-1995

Director, Division of Radiation  
Control and Emergency Management  
Arkansas Department of Health  
4815 West Markham Street, Slot 30  
Little Rock, AR 72205-3867

Wise, Carter, Child & Caraway  
P. O. Box 651  
Jackson, MS 39205

Winston & Strawn  
1400 L Street, N.W.  
Washington, DC 20005-3502

Manager, Rockville Nuclear Licensing  
Framatone Technologies  
1700 Rockville Pike, Suite 525  
Rockville, MD 20852

Senior Resident Inspector  
U.S. Nuclear Regulatory Commission  
P. O. Box 310  
London, AR 72847

Regional Administrator, Region IV  
U.S. Nuclear Regulatory Commission  
611 Ryan Plaza Drive, Suite 400  
Arlington, TX 76011-8064

County Judge of Pope County  
Pope County Courthouse  
Russellville, AR 72801



**UNITED STATES  
NUCLEAR REGULATORY COMMISSION**  
WASHINGTON, D.C. 20555-0001

ENERGY OPERATIONS, INC.

DOCKET NO. 50-368

ARKANSAS NUCLEAR ONE, UNIT NO. 2

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 212  
License No. NPF-6

1. The Nuclear Regulatory Commission (the Commission) has found that:
  - A. The application for amendment by Entergy Operations, Inc. (the licensee), dated January 27, 2000, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
  - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
  - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
  - D. The issuance of this license amendment will not be inimical to the common defense and security or to the health and safety of the public; and
  - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.

2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.C.(2) of Facility Operating License No. NPF-6 is hereby amended to read as follows:

2. Technical Specifications

The Technical Specifications contained in Appendix A, as revised through Amendment No. 212, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. The license amendment is effective as of its date of issuance and shall be implemented within 30 days from the date of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION



Robert A. Gramm, Chief, Section 1  
Project Directorate IV & Decommissioning  
Division of Licensing Project Management  
Office of Nuclear Reactor Regulation

Attachment: Changes to the Technical  
Specifications

Date of Issuance: March 24, 2000

ATTACHMENT TO LICENSE AMENDMENT NO. 212

FACILITY OPERATING LICENSE NO. NPF-6

DOCKET NO. 50-368

Replace the following pages of the Appendix A Technical Specifications with the attached revised pages. The revised pages are identified by amendment number and contain marginal lines indicating the areas of change.

Remove

Insert

3/4 7-28

3/4 7-28

3/4 7-29

---

3/4 7-30

---

3/4 7-31

---

3/4 7-32

---

3/4 7-33

---

3/4 7-34

---

3/4 7-35

---

3/4 7-36

---

3/4 7-37

---

PLANT SYSTEMS

SURVEILLANCE REQUIREMENTS (Continued)

---

1. With a half-life greater than 30 days (excluding Hydrogen 3), and
  2. In any form other than gas.
- b. Stored sources not in use - Each sealed source and fission detector shall be tested prior to use or transfer to another licensee unless tested within the previous six months. Sealed sources and fission detectors transferred without a certificate indicating the last test date shall be tested prior to being placed into use.
- c. Startup sources and fission detectors - Each sealed startup source and fission detector shall be tested within 31 days prior to being subjected to core flux or installed in the core and following repair or maintenance to the source or detector.
- 4.7.9.1.3 Reports - A report shall be prepared and submitted to the Commission on an annual basis if sealed source or fission detector leakage tests reveal the presence of  $\geq 0.005$  microcuries of removable contamination.



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D.C. 20555-0001

SAFETY EVALUATION BY THE OFFICE OF NUCLEAR REACTOR REGULATION

RELATED TO AMENDMENT NO. 12 TO

FACILITY OPERATING LICENSE NO. NPF-6

ENTERGY OPERATIONS, INC.

ARKANSAS NUCLEAR ONE, UNIT NO. 2

DOCKET NO. 50-368

1.0 INTRODUCTION

By letter dated January 27, 2000, Entergy Operations, Inc. (the licensee), submitted a request for changes to the Arkansas Nuclear One, Unit No. 2, Technical Specifications (TSs). The requested changes would delete the current requirements of TS 4.7.9.1.2.d, "Source installed in the Boronometer," associated with the installed boronometer sealed source. The source was recently removed and stored, and the requirements of TS 4.7.9.1.2.d are no longer applicable.

2.0 BACKGROUND

Section 182a of the Atomic Energy Act of 1954, as amended (the Act), requires that applicants for nuclear power plant operating licenses state TSs and that these TSs be included as a part of the license. The Nuclear Regulatory Commission's (NRC or Commission) regulatory requirements related to the content of TSs are set forth in Title 10 of the Code of Federal Regulations (10 CFR) Section 50.36. That regulation requires that the TSs include items in five specific categories, including (1) safety limits, limiting safety system settings, and limiting control settings; (2) limiting conditions for operation; (3) surveillance requirements; (4) design features; and (5) administrative controls, and states also that the Commission may include additional TSs as it finds to be appropriate. However, the regulation does not specify the particular TSs to be included in a plant's license.

The regulation sets forth four criteria to be used in determining whether a limiting condition for operation (LCO) is required to be included in the TS, as follows: (1) installed instrumentation that is used to detect, and indicate in the control room, a significant abnormal degradation of the reactor coolant pressure boundary; (2) a process variable, design feature, or operating restriction that is an initial condition of a design basis accident or transient analysis that either assumes the failure of or presents a challenge to the integrity of a fission product barrier; (3) a structure, system, or component that is part of the primary success path and which functions or actuates to mitigate a design basis accident or transient that either assumes the failure of or presents a challenge to the integrity of a fission product barrier; and/or (4) a structure, system, or component which operating experience or probabilistic risk assessment has shown to be

significant to public health and safety. Existing LCOs and related surveillances included as TS requirements which fall within or satisfy any of the criteria must be retained in the TSs, while those TS requirements which do not fall within or satisfy these criteria may be relocated to other, licensee-controlled documents.

### 3.0 EVALUATION

The existing requirement for sealed source contamination (TS 3/4.7.9) specifies limitations on fixed contamination for sources requiring leak testing, and states that sealed sources containing radioactive material shall be free of specified levels of removable contamination. The associated action statement requires that if the removable contamination exceeds limitations, the sealed source shall be either decontaminated or disposed of. The limitations expressed in this TS do not impact reactor operation, do not identify a parameter which is an initial condition assumption for a design basis accident or transient, do not identify a significant abnormal degradation of the reactor coolant pressure boundary, and do not provide any mitigation of a design basis event.

The licensee proposes to delete the current requirements of Surveillance Requirement (SR) 4.7.9.1.2.d, "Source installed in the Boronometer," associated with the installed boronometer sealed source. This SR states that the boronometer sealed source shall be tested for leakage at least once per 18 months. However, SR 4.7.9.1.2.d does not play a direct part in meeting any of the four LCO criteria, as discussed in the preceding paragraph. In addition, the source was recently removed from the boronometer and stored; therefore, SR 4.7.9.1.2.d no longer applies. Further, SR 4.7.9.1.2.b, "Stored sources not in use," requires this source to be tested for leakage and/or contamination prior to its next use or prior to being transferred to another licensee. Therefore, the deletion of SR 4.7.9.1.2.d does not preclude proper control and testing of the sealed source because SR 4.7.9.1.2.b now applies. Accordingly, the staff finds that the requirements of TS 4.7.9.1.2.d may be deleted for the reasons discussed above.

In addition, a note is added to the footer of page 3/4 7-28 indicating that the next page is 3/4 7-38. This allows the removal of 9 pages from the TSs that have previously had all their information deleted, except for the heading at the top and the page number at the bottom. This is acceptable because this change is editorial in nature.

### 4.0 STATE CONSULTATION

In accordance with the Commission's regulations, the Arkansas State official was notified of the proposed issuance of the amendment. The State official had no comments.

### 5.0 ENVIRONMENTAL CONSIDERATION

The amendment changes a requirement with respect to installation or use of a facility component located within the restricted area as defined in 10 CFR Part 20 and changes surveillance requirements. The NRC staff has determined that the amendment involves no significant increase in the amounts, and no significant change in the types, of any effluents that may be released offsite, and that there is no significant increase in individual or cumulative occupational radiation exposure. The Commission has previously issued a proposed finding that the amendment involves no significant hazards consideration, and there has been no



public comment on such finding (65 FR 9007, published February 23, 2000). Accordingly, the amendment meets the eligibility criteria for categorical exclusion set forth in 10 CFR 51.22(c)(9). Pursuant to 10 CFR 51.22(b), no environmental impact statement or environmental assessment need be prepared in connection with the issuance of the amendment.

#### 6.0 CONCLUSION

The Commission has concluded, based on the considerations discussed above, that (1) there is reasonable assurance that the health and safety of the public will not be endangered by operation in the proposed manner, (2) such activities will be conducted in compliance with the Commission's regulations, and (3) the issuance of the amendment will not be inimical to the common defense and security or to the health and safety of the public.

Principal Contributor: T. Alexion

Date: March 24, 2000