

# Upgrading Westinghouse Plants .8 to 1.1% RTP with Existing or New Feedwater Venturi $\Delta P$ Measurement Devices

NRC/Westinghouse Meeting

March 30, 2000

# Meeting Agenda

---

- I. Overview and Meeting Purpose
- II. Power Calorimetric Uncertainties
- III. Relationship to Plant Safety Analyses
- IV. Licensing Approach
- V. Questions and Wrap-Up

# Westinghouse Attendees

---

Mr. R. Easterling

Manager,  
Engineering Services Integration

Mr. J. Fasnacht

Technical and Licensing Lead, Safety  
Analysis Engineering

Mr. R. Tuley

Fellow Engineer, Setpoints

# Purpose and Overview

---

## Purpose

- Propose and discuss approach for applying NRC approved and accepted 95/95 uncertainty methodology to facilitate plant power uprate.
- Power Measurement uncertainty based in part on use of existing feedwater flow venturi measurement.

# Purpose and Overview (Cont)

---

## Overview of Approach

- Use existing power measurement uncertainty based on NRC approved methodology. For discussion purposes, assume that present uncertainty is  $x\%$  and is less than  $2\%$ .
- Increase plant core power by  $(2-x)\%$ .
- Safety analyses utilizing nominal full power conditions and statistical combination of uncertainties – evaluate analyses at the new power level.
- Analyses performed at nominal full power conditions – re-evaluate at new power level.

# Purpose and Overview (Cont)

---

## Overview of Approach

- Safety analyses performed with a 2% or greater power uncertainty - Do not re-perform analyses. Demonstrate intent of safety analysis is still met since actual power uncertainty is less than 2%.
- Prepare 10 CFR 50.92 evaluation and associated Technical Specification changes to increase plant power by  $(2-x)\%$ .

# Purpose and Overview (Cont)

---

## Key Concepts for Approach

- NRC has accepted and approved methodology for 95/95 uncertainty calculations.
- Regulatory basis for 2% power uncertainty in applicable safety analyses is to solely account for power measurement uncertainty.
- The intent of the applicable safety analyses is also satisfied by other prescribed conservative features and requirements of the NRC approved and licensed evaluation models.

# Purpose and Overview (Cont)

---

## Key Concepts for Approach

- Approach is consistent with NRC proposed rule making to modify Appendix K.



# Power Calorimetric Uncertainties with Existing or New Feedwater Venturi $\Delta P$ Measurement Devices (Cont)

---

## Power Calorimetric Uncertainties - Single Venturi Tap Measurement per Loop

- 3 Loop - 1996 1.1% RTP
- 3 Loop - 1998 1.1% RTP
- 4 Loop - 1999 1.2% RTP
- 4 Loop - 1998 1.1% RTP
- 4 Loop - 1995 1.1% RTP
- 4 Loop - 1996 1.2% RTP

# Power Calorimetric Uncertainties with Existing or New Feedwater Venturi $\Delta P$ Measurement Devices (Cont)

---

## Power Calorimetric Uncertainties - Two Venturi Tap Measurement per Loop

- 3 Loop - 1996      0.9% RTP
- 3 Loop - 1998      0.9% RTP
- 4 Loop - 1999      1.0% RTP
- 4 Loop - 1998      1.0% RTP
- 4 Loop - 1995      0.9% RTP
- 4 Loop - 1996      1.0% RTP
- 3 Loop - 1998      1.1% RTP

# Power Calorimetric Uncertainties with Existing or New Feedwater Venturi $\Delta P$ Measurement Devices (Cont)

---

## Calculation Assumptions

- Existing Plant Installed Hardware
- 1 Venturi Tap  $\Delta P$  Measurement per Loop
- 2 Venturi Tap  $\Delta P$  Measurements per Loop
- Standard Westinghouse Uncertainty Calculation Methodology (95/95 results and in use in basic form since 1978)
- Consistent with NUREG/CR-3659

# Power Calorimetric Uncertainties with Existing or New Feedwater Venturi $\Delta P$ Measurement Devices (Cont)

---

## Potential Results - New Hardware

- 3 Loop - 1998                      0.8 % RTP
- 4 Loop - 1999                      0.8 % RTP
  
- Feedwater Temperature becomes significant contributor

# Power Calorimetric Uncertainties with Existing or New Feedwater Venturi $\Delta P$ Measurement Devices (Cont)

---

## Potential Result Assumptions

- Utilize More Accurate Feedwater Venturi  $\Delta P$  Transmitters
- Incorporate Decreased Rack Drift (supported by plant data)
- Incorporate More Accurate Feedwater Temperature Measurement

# Power Calorimetric Uncertainties with Existing or New Feedwater Venturi $\Delta P$ Measurement Devices (Cont)

---

## Conclusions

- Westinghouse Uncertainty Calculations Easily Support approximately .8 to 1.1% Calorimetric Power Measurement Uncertainty with **NO** Change in Plant Hardware
- Utilization of More Accurate Feedwater  $\Delta P$  and Feedwater Temperature Measurement Devices can Result in Total Uncertainty of ~0.8 % RTP or an Uprating of ~1.2 % RTP

# Typical Relationship to Safety Analyses

---

## Typical Analyses Performed at Nominal Full Power Conditions

- Evaluate analysis at new power level
- Confirm design basis performance at new power level
  - NSSS fluid systems and applicable components
  - NSSS/BOP interface systems
  - BOP fluid systems
  - NSSS control systems/Class I transients
  - Other plant support systems

# Typical Relationship to Safety Analyses (Cont)

---

## Typical Analyses Performed at Nominal Full Power Level

- Confirm acceptable fatigue/stress at new power level
  - Design transient review
  - Applicable NSSS primary and auxiliary support systems



# Typical Relationship to Safety Analyses (Cont)

---

## Analyses typically performed at 104.5% power

- No changes needed
- Radiological source term calculations
- Long-term LOCA mass and energy releases

## Analyses typically performed at 102% power

- No changes needed
- Appendix K LBLOCA and SBLOCA analyses
- Selected non-LOCA transient analyses
- Long term SLB mass and energy releases
- Selected SGTR analyses

# Typical Relationship to Safety Analyses (Cont)

---

## Analyses using nominal full power conditions and statistical uncertainty combinations

- Evaluate analyses at new power level and/or power measurement uncertainty
- Non-LOCA transient - DNB related analyses
- Uncertainty analysis for applicable key safety analysis parameters and protection system setpoints
- Best estimate LBLOCA analysis

# Licensing Approach

---

- Prepare Technical Specification changes
- Submit 10 CFR 50.92 evaluation
- No significant increase in probability or consequences of an accident previously evaluated
- No possibility of a new or different kind of accident from any accident previously evaluated

# Licensing Approach (Cont)

---

- No significant reduction in margin of safety
  - NRC accepted and approved methodology used for 95/95 power measurement uncertainty calculation
  - Analyses appropriately account for power uncertainty measurement
  - Affected analyses have been re-evaluated at revised power level and/or uncertainty
  - Analysis presently performed at 102% power still account for power measurement uncertainties and retain existing conservative assumptions/modeling

# Conclusions

---

- Present uncertainty calculations support a .8 to 1.1% Calorimetric Power Measurement uncertainty with no change to plant hardware
- Utilization of more accurate feedwater  $\Delta P$  and feedwater temperature measurement devices can result in total uncertainty of approximately .8%
- Licensing approach consistent with NRC approved methodology