



REGULATORY GUIDE

OFFICE OF STANDARDS DEVELOPMENT

REGULATORY GUIDE 1.124

SERVICE LIMITS AND LOADING COMBINATIONS FOR CLASS 1 LINEAR-TYPE COMPONENT SUPPORTS

A. INTRODUCTION

General Design Criterion 2, "Design Bases for Protection Against Natural Phenomena," of Appendix A, "General Design Criteria for Nuclear Power Plants," to 10 CFR Part 50, "Licensing of Production and Utilization Facilities," requires that the design bases for structures, systems, and components important to safety reflect appropriate combinations of the effects of normal and accident conditions with the effects of natural phenomena such as earthquakes. The failure of members designed to support safety-related components could jeopardize the ability of the supported component to perform its safety function.

This guide delineates acceptable levels of service limits and appropriate combinations of loadings associated with normal operation, postulated accidents, and specified seismic events for the design of Class 1 linear-type component supports as defined in Subsection NF of Section III of the American Society of Mechanical Engineers (ASME) Boiler and Pressure Vessel Code. This guide applies to light-water-cooled reactors. The Advisory Committee on Reactor Safeguards has been consulted concerning this guide and has concurred in the regulatory position.

B. DISCUSSION

Load-bearing members classified as component supports are essential to the safety of nuclear power plants since they retain components in place during the loadings associated with normal and upset plant conditions under the stress of specified seismic events, thereby permitting system components to function properly. They also prevent excessive component movement during the loadings associated with emergency and faulted plant conditions combined

with the specified seismic event, thus helping to mitigate the consequences of system damage. Component supports are deformation sensitive because large deformations in them may significantly change the stress distribution in the support system and its supported components.

In order to provide uniform requirements for construction, the component supports should, as a minimum, have the same ASME Boiler and Pressure Vessel Code classification as that of the supported components. This guide delineates levels of service limits and loading combinations, in addition to supplementary criteria, for ASME Class 1 linear-type component supports as defined by NF-1213 of Section III. Snubbers are not addressed in this guide.

Subsection NF and Appendix XVII of Section III permit the use of four methods for the design of Class 1 linear-type component supports: linear elastic analysis, load rating, experimental stress analysis, and limit analysis. For each method, the ASME Code delineates allowable stress or loading limits for various Code levels of service limits as defined by NF-3113 of Section III so that these limits can be used in conjunction with the resultant loadings or stresses from the appropriate plant conditions. Since the Code does not specify loading combinations, guidance is required to provide a consistent basis for the design of component supports.

Component supports considered in this guide are located within Seismic Category I structures and are therefore protected against loadings from natural phenomena or man-made hazards other than the specified seismic events. Thus only the specified seismic events need to be considered in combination with the loadings associated with plant conditions to develop appropriate loading combinations. Loadings caused

* Lines indicate substantive change from previous issue.

USNRC REGULATORY GUIDES

Regulatory Guides are issued to describe and make available to the public methods acceptable to the NRC staff of implementing specific parts of the Commission's regulations, to delineate techniques used by the staff in evaluating specific problems or postulated accidents, or to provide guidance to applicants. Regulatory Guides are not substitutes for regulations, and compliance with them is not required. Methods and solutions different from those set out in the guides will be acceptable if they provide a basis for the findings requisite to the issuance or continuance of a permit or license by the Commission.

Comments and suggestions for improvements in these guides are encouraged at all times, and guides will be revised, as appropriate, to accommodate comments and to reflect new information or experience. This guide was revised as a result of substantive comments received from the public and additional staff review.

Comments should be sent to the Secretary of the Commission, U.S. Nuclear Regulatory Commission, Washington, D.C. 20555, Attention: Docketing and Service Branch.

The guides are issued in the following ten broad divisions:

- | | |
|-----------------------------------|------------------------|
| 1. Power Reactors | 6. Products |
| 2. Research and Test Reactors | 7. Transportation |
| 3. Fuels and Materials Facilities | 8. Occupational Health |
| 4. Environmental and Siting | 9. Antitrust Review |
| 5. Materials and Plant Protection | 10. General |

Requests for single copies of issued guides (which may be reproduced) or for placement on an automatic distribution list for single copies of future guides in specific divisions should be made in writing to the U.S. Nuclear Regulatory Commission, Washington, D.C. 20555, Attention: Director, Division of Document Control.

by natural phenomena other than seismic events, when they exist, should be considered on a case-by-case basis.

1. Design by Linear Elastic Analysis

a. *S_u at Temperature.* When the linear elastic analysis method is used to design Class 1 linear-type component supports, material properties are given by Tables I-2.1, I-2.2, I-13.1, and I-13.3 in Appendix I of Section III and Tables 3 and 4 in the latest accepted version¹ of Code Case 1644. These tables list values for the minimum yield strength S_y at various temperatures but only room temperature values for the ultimate tensile strength S_u . At room temperature, S_y varies from 50% to 87% of S_u for component support materials.

Levels of service limits derived from either material property alone may not be sufficient to provide a consistent safety margin. This is recognized by Section III, since XVII-2211(a) of Section III defines the allowable stress in tension on a net section as the smaller value of $0.6S_y$ and $0.5S_u$. To alleviate the lack of defined values of S_u at temperatures above room temperature and to provide a safe design margin, an interim method is given in this guide to obtain values of S_u at temperature.

While XVII-2211(a) specifies allowable tensile stress in terms of both S_y and S_u , the rest of XVII-2000 specifies other allowable service limits in terms of S_y only. This does not maintain a consistent design margin for those service limits related only to material properties. Modifications similar to XVII-2211(a) should be employed for all those service limits.

b. *Allowable Increase of Service Limits.* While NF-3231.1(a), XVII-2110(a), and F-1370(a) of Section III all permit the increase of allowable stresses under various loading conditions, XVII-2110(b) limits the increase so that two-thirds of the critical buckling stress for compression and compression flange members is not exceeded, and the increase allowed by NF-3231.1(a) is for stress range. Critical buckling stresses with normal design margins are derived in XVII-2200 of Section III. Since buckling prevents "shakedown" in the load-bearing member, XVII-2110(b) must be regarded as controlling. Also, buckling is the result of the interaction of the configuration of the load-bearing member and its material properties (i.e., elastic modulus E and minimum yield strength S_y). Because both of these material properties change with temperature, the critical buckling

¹ Regulatory Guide 1.85, "Code Case Acceptability—ASME Section III Materials," provides guidance for the acceptability of ASME Section III Code Cases and their revisions, including Code Case 1644. Supplementary provisions for the use of specific code cases and their revisions may also be provided and should be considered when applicable.

stresses should be calculated with the values of E and S_y of the component support material at temperature. Allowable service limits for bolted connections are derived from tensile and shear stress limits and their nonlinear interaction; they also change with the size of the bolt. For this reason, the increases permitted by NF-3231.1, XVII-2110(a), and F-1370(a) of Section III are not directly applicable to allowable shear stresses and allowable stresses for bolts and bolted connections. The increase permitted by NF-3231.1 and F-1370(a) of Section III for shear stresses or shear stress range should not be more than 1.5 times the level A service limits because of the potential for non-ductile behavior.

The range of primary plus secondary stresses should be limited to $2S_y$ but not more than S_u to ensure shakedown. For many allowable stresses above the value of $0.6S_y$, the increase permitted by NF-3231.1(a) will be above the value of $2S_y$ and will thus violate the normal shakedown range. A shakedown analysis is necessary to justify the increase of stress above $2S_y$ or S_u .

For the linear elastic analysis method, F-1370(a) of Section III permits increase of tension limits for the Code level D service limits by a variable factor, that is the smaller value of $1.2S_y/F_t$ or $0.7S_u/F_t$. Depending on whether the section considered is a net section at pinholes in eyebars, pin-connected plates, or built-up structural members, F_t may assume the smaller value of $0.45S_y$ or $0.375S_u$ (as recommended by this guide for a net section of pinholes, etc.) or the smaller value of $0.6S_y$ or $0.5S_u$ (for a net section without pinholes, etc.). Thus greater values of the factor may be obtained for sections at pinholes, which does not account for local stress and is not consistent with NF-3231.1 and XVII-2110(a) of Section III. A procedure to correct this factor is provided in this guide.

2. Design by Load Rating

When load-rating methods are used, Subsection NF and Appendix F of Section III do not provide a faulted condition load rating. This guide provides an interim method for the determination of faulted condition load rating.

3. Design by Experimental Stress Analysis

While the collapse load for the experimental stress analysis method is defined by II-1430 in Appendix II of Section III, the various levels of service limits for experimental stress analysis are not delineated. This deficiency is remedied by the method described in this guide.

4. Large Deformation

The design of component supports is an integral part of the design of the system and its components.

A complete and consistent design is possible only when system/component/component-support interaction is properly considered. When all three are evaluated on an elastic basis, the interaction is usually valid because individual deformations are small. However, if plastic analysis methods are employed in the design process, large deformations that would result in substantially different stress distributions may occur.

When component supports are designed for loadings associated with the faulted plant conditions, Appendix F of Section III permits the use of plastic analysis methods in certain acceptable combinations for all three elements. These acceptable combinations are selected on the assumption that component supports are more deformation sensitive (i.e., their deformation in general will have a large effect on the stress distribution in the system and its components.) Since large deformations always affect the stress distribution, care should be exercised even if the plastic analysis method is used in the Appendix F-approved methodology combination. This is especially important for identifying buckling or instability problems where the change of geometry should be taken into account to avoid erroneous results.

5. Function of Supported System

In selecting the level of service limits for different loading combinations, the function of the supported system must be taken into account. To ensure that systems whose normal function is to prevent or mitigate consequences of events associated with an emergency or faulted plant condition (e.g., the function of ECCS during faulted plant conditions) will operate properly regardless of plant condition, the Code level A or B service limits of Subsection NF (which are identical) or other justifiable limits provided by the Code should be used.

Since Appendix XVII derived all equations from AISC rules and many AISC compression equations have built-in constants based on mechanical properties of steel at room temperature, to use these equations indiscriminately for all NF and the latest accepted version of Code Case 1644 materials at all temperatures would not be prudent. For materials other than steel and working temperatures substantially different from room temperature, these equations should be rederived with the appropriate material properties.

6. Deformation Limits

Since component supports are deformation-sensitive load-bearing elements, satisfying the service limits of Section III will not automatically ensure their proper function. Deformation limits, if specified by the Code Design Specification, may be the controlling criterion. On the other hand, if the function of a component support is not required for a particu-

lar plant condition, the stresses or loads resulting from the loading combinations under that plant condition do not need to satisfy the design limits for the plant condition.

7. Definitions

Design Condition. The loading condition defined by NF-3112 of Section III of the ASME Boiler and Pressure Vessel Code.

Emergency Plant Condition. Those operating conditions that have a low probability of occurrence.

Faulted Plant Condition. Those operating conditions associated with postulated events of extremely low probability.

Levels of Service Limits. Four levels, A, B, C, and D, of service limits defined by Section III for the design of loadings associated with different plant conditions for components and component supports in nuclear power plants.

Normal Plant Condition. Those operating conditions in the course of system startup, operation, hot standby, refueling, and shutdown other than upset, emergency, or faulted plant conditions.

Operating Basis Earthquake (OBE). As defined in Appendix A to 10 CFR Part 100.

Plant Conditions. Operating conditions of the plant categorized as normal, upset, emergency, and faulted plant conditions.

Safe Shutdown Earthquake (SSE). As defined in Appendix A to 10 CFR Part 100.

Service Limits. Stress limits for the design of component supports as defined by Subsection NF of Section III.

Specified Seismic Events. Operating Basis Earthquake and Safe Shutdown Earthquake.

System Mechanical Loadings. The static and dynamic loadings that are developed by the system operating parameters, including deadweight, pressure, and other external loadings, but excluding effects resulting from constraints of free-end movements and thermal and peak stresses.

Ultimate Tensile Strength. Material property based on engineering stress-strain relationship.

Upset Plant Conditions. Those deviations from the normal plant condition that have a high probability of occurrence.

C. REGULATORY POSITION

ASME Code² Class 1 linear-type component sup-

² American Society of Mechanical Engineers Boiler and Pressure Vessel Code, Section III, Division 1, 1974 Edition, including the 1976 Winter Addenda thereto.

ports excluding snubbers, which are not addressed herein, should be constructed to the rules of Subsection NF of Section III as supplemented by the following:³

1. The classification of component supports should, as a minimum, be the same as that of the supported components.

2. Values of S_u at a temperature t should be estimated by one of the three following methods on an interim basis until Section III includes such values:

a. *Method 1.* This method applies to component support materials whose values of ultimate strength S_u at temperature have been tabulated by their manufacturers in catalogs or other publications.

$$S_u = S_{ur} \frac{S'_u}{S_{ur}}, \text{ but not greater than } S_{ur}$$

where

S_u = ultimate tensile strength at temperature t to be used to determine the service limits

S_{ur} = ultimate tensile strength at room temperature tabulated in Section III, Appendix I, or the latest accepted version¹ of Code Case 1644

S'_u = ultimate tensile strength at temperature t tabulated by manufacturers in their catalogs or other publications

S_{ur} = ultimate tensile strength at room temperature tabulated by manufacturers in the same publications.

b. *Method 2.* This method applies to component support materials whose values of ultimate tensile strength at temperature have not been tabulated by their manufacturers in any catalog or publication.

$$S_u = S_{ur} \frac{S_y}{S_{yr}}$$

where

S_u = ultimate tensile strength at temperature t to be used to determine the service limits

S_{ur} = ultimate tensile strength at room temperature tabulated in Section III, Appendix I, or the latest accepted version¹ of Code Case 1644

S_y = minimum yield strength at temperature t tabulated in Section III, Appendix I, or the latest accepted version¹ of Code Case 1644

S_{yr} = minimum yield strength at room temperature, tabulated in Section III, Appendix I,

or the latest accepted version¹ of Code Case 1644.

c. *Method 3.* When the values of allowable stress or stress intensity at temperature for a material are listed in Section III, the ultimate tensile strength at temperature for that material may be approximated by the following expressions:

$$S_u = 4S \text{ or}$$

$$S_u = 3S_m$$

where

S_u = ultimate tensile strength at temperature t to be used to determine the service limits

S = listed value of allowable stress at temperature t in Section III.

S_m = listed value of allowable stress intensity at temperature t in Section III

3. The Code levels A and B service limits for component supports designed by linear elastic analysis which are related to S_y should meet the appropriate stress limits of Appendix XVII of Section III but should not exceed the limit specified when the value of $5/6 S_u$ is substituted for S_y . Examples are shown below in a and b.

a. The tensile stress limit F_t for a net section as specified in XVII-2211(a) of Section III should be the smaller value of $0.6S_y$ or $0.5S_u$ at temperature. For net sections at pinholes in eye-bars, pin-connected plates, or built-up structural members, F_t as specified in XVII-2211(b) should be the smaller value of $0.45S_y$ or $0.375S_u$ at temperature.

b. The shear stress limit F_v for a gross section as specified in XVII-2212 of Section III should be the smaller value of $0.4S_y$ or $0.33S_u$ at temperature.

Many limits and equations for compression strength specified in Sections XVII-2214, XVII-2224, XVII-2225, XVII-2240, and XVII-2260 have built-in constants based on Young's Modulus of 29,000 Ksi. For materials with Young's Modulus at working temperatures substantially different from 29,000 Ksi, these constants should be rederived with the appropriate Young's Modulus unless the conservatism of using these constants as specified can be demonstrated.

4. Component supports designed by linear elastic analysis may increase their level A or B service limits according to the provisions of NF-3231.1(a), XVII-2110(a), and F-1370(a) of Section III. The increase of level A or B service limits provided by NF-3231.1(a) is for stress range. The increase of level A

³ If the function of a component support is not required during a plant condition, the design limits of the support for that plant condition need not be satisfied, provided excessive deflection or failure of the support will not result in the loss of function of any other safety-related system.

or B service limits provided by F-1370(a) for level D service limits, should be the smaller factor of 2 or $1.167S_u/S_y$, if $S_u \geq 1.2S_y$ or 1.4 if $S_u \leq 1.2S_y$, where S_y and S_u are component-support material properties at temperature.

However, all increases [i.e., those allowed by NF-3231.1(a), XVII-2110(a), and F-1370(a)] should always be limited by XVII-2110(b) of Section III. The critical buckling strengths defined by XVII-2110(b) of Section III should be calculated using material properties at temperature. This increase of level A or B service limits does not apply to limits for bolted connections. Any increase of limits for shear stresses above 1.5 times the Code level A service limits should be justified.

If the increased service limit for stress range by NF-3231.1(a) is more than $2S_y$ or S_u , it should be limited to the smaller value of $2S_y$ or S_u unless it can be justified by a shakedown analysis.

5. Component supports subjected to the combined loadings of system mechanical loadings associated with (1) either (a) the Code design condition or (b) the normal or upset plant conditions and (2) the vibratory motion of the OBE should be designed within the following limits:^{4,5}

a. The stress limits of XVII-2000 of Section III and Regulatory Position 3 of this guide should not be exceeded for component supports designed by the linear elastic analysis method. These stress limits may be increased according to the provisions of NF-3231.1(a) of Section III and Regulatory Position 4 of this guide when effects resulting from constraints of free-end displacements are added to the loading combination.

b. The normal condition load rating or the upset condition load rating of NF-3262.3 of Section III should not be exceeded for component supports designed by the load-rating method.

c. The lower bound collapse load determined by XVII-4200 adjusted according to the provision of XVII-4110(a) of Section III should not be exceeded for component supports designed by the limit analysis method.

d. The collapse load determined by II-1400 of

⁴ Since component supports are deformation sensitive in the performance of their service requirements, satisfying these criteria does not ensure that their functional requirements will be fulfilled. Any deformation limits specified by the design specification may be controlling and should be satisfied.

⁵ Since the design of component supports is an integral part of the design of the system and the design of the component, the designer must make sure that methods used for the analysis of the system, component, and component support are compatible (see Table F-1322.2-1 in Appendix F of Section III). Large deformations in the system or components should be considered in the design of component supports.

Section III divided by 1.7 should not be exceeded for component supports designed by the experimental stress analysis method.

6. Component supports subjected to the system mechanical loadings associated with the emergency plant condition should be designed within the following design limits except when the normal function of the supported system is to prevent or mitigate the consequences of events associated with the emergency plant condition (at which time Regulatory Position 8 applies):^{4,5}

a. The stress limits of XVII-2000 of Section III and Regulatory Positions 3 and 4, increased according to the provisions of XVII-2110(a) of Section III and Regulatory Position 4 of this guide, should not be exceeded for component supports designed by the linear elastic analysis method.

b. The emergency condition load rating of NF-3262.3 of Section III should not be exceeded for component supports designed by the load-rating method.

c. The lower bound collapse load determined by XVII-4200 adjusted according to the provision of XVII-4110(a) of Section III should not be exceeded for component supports designed by the limit analysis method.

d. The collapse load determined by II-1400 of Section III divided by 1.3 should not be exceeded for component supports designed by the experimental stress analysis method.

7. Component supports subjected to the combined loadings of (1) the system mechanical loadings associated with the normal plant condition, (2) the vibratory motion of the SSE, and (3) the dynamic system loadings associated with the faulted plant condition should be designed within the following limits except when the normal function of the supported system is to prevent or mitigate the consequences of events associated with the faulted plant condition (at which time Regulatory Position 8 applies):

a. The stress limits of XVII-2000 of Section III and Regulatory Position 3 of this guide, increased according to the provisions of F-1370(a) of Section III and Regulatory Position 4 of this guide, should not be exceeded for component supports designed by the linear elastic analysis method.

b. The smaller value of $T.L. \times 2S/S_u$ or $T.L. \times 0.7S_u/S_u$ should not be exceeded, where T.L., S, and S_u are defined according to NF-3262.1 of Section III, and S_u is the minimum ultimate tensile strength of the material at service temperature for component supports designed by the load-rating method.

c. The lower bound collapse load determined by XVII-4200 adjusted according to the provision of F-1370(b) of Section III should not be exceeded for

component supports designed by the limit analysis method.

d. The collapse load determined by II-1400 adjusted according to the provision of F-1370(b) of Section III should not be exceeded for component supports designed by the experimental stress analysis method.

8. Component supports in systems whose normal function is to prevent or mitigate the consequences of events associated with an emergency or faulted plant condition should be designed within the limits described in Regulatory Position 5 or other justifiable limits provided by the Code. These limits should be defined by the Design Specification and stated in the PSAR, such that the function of the supported system will be maintained when they are subjected to the loading combinations described in Regulatory Positions 6 and 7.

D. IMPLEMENTATION

The purpose of this section is to provide guidance to applicants and licensees regarding the NRC staff's plans for using this regulatory guide.

Except in those cases in which the applicant proposes an acceptable alternative method for complying with the specified portions of the Commission's regulations, the method described herein will be used in the evaluation of submittals for construction permit applications docketed after January 10, 1978. If an applicant wishes to use this regulatory guide in developing submittals for construction permit applications docketed on or before January 10, 1978, the pertinent portions of the application will be evaluated on the basis of this guide.