

## 2.0 SAFETY LIMITS (SLs)

---

### 2.1 SLs

#### 2.1.1 Reactor Core SLs

In MODES 1 and 2, the combination of THERMAL POWER, Reactor Coolant System (RCS) highest loop average temperature, and pressurizer pressure shall not exceed the limits specified in the COLR; and the following SLs shall not be exceeded.

2.1.1.1 In MODE 1, the Departure from Nucleate Boiling Ratio (DNBR) shall be maintained  $\geq 1.24$  for the WRB-2 DNB correlation for a thimble cell and  $\geq 1.25$  for the WRB-2 DNB correlation for a typical cell.

2.1.1.2 In MODE 2, the DNBR shall be maintained  $\geq 1.17$  for the WRB-2 DNB correlation, and  $\geq 1.30$  for the W-3 DNB correlation.

2.1.1.3 In MODES 1 and 2, the peak fuel centerline temperature shall be maintained  $< 5080^{\circ}\text{F}$ , decreasing by  $58^{\circ}\text{F}$  per 10,000 MWD/MTU burnup.

#### 2.1.2 RCS Pressure SL

In MODES 1, 2, 3, 4, and 5, the RCS pressure shall be maintained  $\leq 2735$  psig.

---

### 2.2 SL Violations

2.2.1 If SL 2.1.1 is violated, restore compliance and be in MODE 3 within 1 hour.

2.2.2 If SL 2.1.2 is violated:

2.2.2.1 In MODE 1 or 2, restore compliance and be in MODE 3 within 1 hour.

2.2.2.2 In MODE 3, 4, or 5, restore compliance within 5 minutes.

---

## 2.0 SAFETY LIMITS (SLs)

---

### 2.1 SLs

#### 2.1.1 Reactor Core SLs

In MODES 1 and 2, the combination of THERMAL POWER, Reactor Coolant System (RCS) highest loop average temperature, and pressurizer pressure shall not exceed the limits specified in the COLR; and the following SLs shall not be exceeded.

- 2.1.1.1 In MODE 1, the Departure from Nucleate Boiling Ratio (DNBR) shall be maintained  $\geq 1.24$  for the WRB-2 DNB correlation for a thimble cell and  $\geq 1.25$  for the WRB-2 DNB correlation for a typical cell.
- 2.1.1.2 In MODE 2, the DNBR shall be maintained  $\geq 1.17$  for the WRB-2 DNB correlation, and  $\geq 1.30$  for the W-3 DNB correlation.
- 2.1.1.3 In MODES 1 and 2, the peak fuel centerline temperature shall be maintained  $< 5080^{\circ}\text{F}$ , decreasing by  $58^{\circ}\text{F}$  per 10,000 MWD/MTU burnup.

#### 2.1.2 RCS Pressure SL

In MODES 1, 2, 3, 4, and 5, the RCS pressure shall be maintained  $\leq 2735$  psig.

---

### 2.2 SL Violations

- 2.2.1 If SL 2.1.1 is violated, restore compliance and be in MODE 3 within 1 hour.
  - 2.2.2 If SL 2.1.2 is violated:
    - 2.2.2.1 In MODE 1 or 2, restore compliance and be in MODE 3 within 1 hour.
    - 2.2.2.2 In MODE 3, 4, or 5, restore compliance within 5 minutes.
-