

Entergy Nuclear Northeast Entergy Nuclear Operations, Inc. 440 Hamilton Avenue White Plains, NY 10601 Tel 914 272 3200 Fax 914 272 3205

Michael R. Kansler President

August 11, 2003 JPN-03-020 NL-03-130 ENO 1.2.03.091 BVY 03-63

U. S. Nuclear Regulatory Commission ATTN: Document Control Desk Mail Stop O-P1-17 Washington, DC 20555-0001

SUBJECT:

James A. FitzPatrick Nuclear Power Plant

Docket No. 50-333

Indian Point Nuclear Generating Units No. 2 and No. 3

Docket No. 50-247, and 50-286 Pilgrim Nuclear Power Station

Docket No. 50-293

Vermont Yankee Nuclear Power Station

Docket No. 50-271

Relief Request to Use ASME Code Case N-600

References:

 USNRC letter from L. Raghavan to F. Cayia, dated March 21, 2003 regarding "Point Beach Nuclear Plant, Units 1 and 2 – Relief Request No. 9 Associated with the 10-Year Interval Inservice Inspection Program (TAC NOS. MB5403 and MB5404)"

Dear Sir:

Pursuant to 10CFR50.55a(a)(3)(i), Entergy (ENO) hereby requests the Nuclear Regulatory Commission (NRC) to approve the use of an alternative to the American Society of Mechanical Engineers (ASME) Boiler and Pressure Vessel Code, Section XI (Subsection IWA) regarding the welder qualification requirements.

Enclosed are five (5) requests for relief to use ASME Code Case N-600 for James A. FitzPatrick Nuclear Power Plant (JAF, Attachment 1), Indian Point Nuclear Generating Unit No. 2 (IP2, Attachment 2), Indian Point Nuclear Generating Unit No. 3 (IP3, Attachment 3), Pilgrim Nuclear Power Station (Attachment 4), and Vermont Yankee Nuclear Power Station (VY, Attachment 5). The proposed alternative would allow the Entergy plants the flexibility to utilize welders qualified by other licensees under similar qualification programs.

for

Please note that the requests for relief for JAF, IP2, IP3, and Pilgrim are for their 3rd ISI Interval, and the applicable code of record is the 1989 Edition, No Addenda of the ASME Section XI Code. For Vermont Yankee, the request for relief is for the 4th ISI Interval, which begins on September 1, 2003, and the applicable code of record is the 1998 Edition, 2000 Addenda of the ASME Section XI Code.

Approval is requested by February 28, 2004 to support the JAF and IP2 Fall 2004 outages. Due to the similarity of these requests for relief, it is also requested that approval for IP3, Pilgrim and VY be granted at the same time.

A similar request for relief was approved for Point Beach Nuclear Plant, Units 1 and 2 (Reference 1).

There are no new commitments made in this letter. If you have any questions, please contact Ms. Charlene Faison at 914-272-3378.

Very truly yours,

Michael R. Kansler

President

Entergy Nuclear Operations, Inc.

List of Attachments:

- 1. James A. FitzPatrick Nuclear Power Plant, RR-32
- 2. Indian Point Generating Station Unit No. 2, RR-64
- 3. Indian Point Generating Station Unit No. 3, RR 3-33 (A)
- 4. Pilgrim Nuclear Power Station, PRR-33
- 5. Vermont Yankee Nuclear Power Station, Relief Request No. ISI-012
- 6. ASME Code Case N-600 (for information)

CC:

Mr. Hubert J. Miller Regional Administrator, Region I U.S. Nuclear Regulatory Commission 475 Allendale Road King of Prussia, PA 19406-1415

Mr. Guy S. Vissing, Project Manager Project Directorate I Division of Licensing Project Management Office of Nuclear Reactor Regulation U.S. Nuclear Regulatory Commission Mail Stop 8-C2 Washington, DC 20555-0001 Mr. Patrick D. Milano, Sr. Project Manager Project Directorate I Division of Licensing Project Management Office of Nuclear Reactor Regulation U.S. Nuclear Regulatory Commission Mail Stop 0-8-C2 Washington, DC 20555-0001

Mr. John L. Minns, Project Manager License Project Directorate IV-1 Division of Licensing Project Management U.S. Nuclear Regulatory Commission Mail Stop 7-D-1 Washington, DC 20555-0001 Mr. Travis Tate, Project Manager License Project Directorate I Division of Licensing Project Management Office of Nuclear Reactor Regulation U.S. Nuclear Regulatory Commission Mail Stop 7-D-1 Washington, DC 20555-0001

Mr. Robert M. Pulsifer, Project Manager License Project Directorate I Division of Licensing Project Management Office of Nuclear Reactor Regulation U.S. Nuclear Regulatory Commission Mail Stop 08-B-1 Washington, DC 20555-0001

Resident Inspector's Office Indian Point Unit 3 U.S. Nuclear Regulatory Commission P.O. Box 337 Buchanan, NY 10511-0337

Senior Resident Inspector's Office Indian Point Unit 2 U.S. Nuclear Regulatory Commission P.O. Box 38 Buchanan, NY 10511-0038

Resident Inspector's Office James A. FitzPatrick U.S. Nuclear Regulatory Commission P.O. Box 136 Lycoming, NY 13093-0136

Senior Resident Inspector Pilgrim Nuclear Power Station U.S. Nuclear Regulatory Commission 600 Rocky Hill Road Mail Stop 66 Plymouth, MA 02360

USNRC Resident Inspector Vermont Yankee Nuclear Power Station 320 Governor Hunt Road P.O. Box 157 Vernon, VT 05354 Mr. Paul Eddy
New York State Department
of Public Service
3 Empire State Plaza
Albany, NY 12223

Mr. Peter R. Smith, Acting President New York State Energy, Research, and Development Authority Corporate Plaza West 286 Washington Avenue Extension Albany, NY 12203-6399

Mr. David O'Brien Commissioner Department of Public Service 112 State Street, Drawer 20 Montpelier, VT 05620-2601

Attachment 1 to JPN-03-020/NL-03-130/ENO 1.2.03.091/BVY 03-63

JAMES A. FITZPATRICK THIRD INSERVICE INSPECTION INTERVAL RELIEF REQUEST RR-32, Rev. 0

A. COMPONENT IDENTIFICATION:

Class:

All

Identification of System:

All

B. CODE REQUIREMENTS:

Article IWA-4400(b) - All welders shall be qualified by the repair organization in accordance with the requirements of the codes specified in the Repair Program in accordance with IWA-4120.

C. RELIEF REQUEST:

Relief is requested from the requirements of ASME Section XI, Article IWA-4400(b).

D. BASIS FOR RELIEF:

The basis for this relief is to implement the alternative requirements of ASME Code Case N-600 for the performance qualification testing of welders, welding operators, brazers, and brazing operators. Code Case N-600 proposes an alternative that would allow the transfer of performance qualifications between Owners, thereby eliminating redundant performance qualifications between facilities. This proposed alternative provides an acceptable level of quality and safety pursuant to 10 CFR 50.55a(a)(3)(i).

A similar request for relief was approved for Point Beach Nuclear Plant, Units 1 and 2 (TAC NOS. MB5403 and MB5404, dated March 21, 2003).

E. ALTERNATIVE EXAMINATIONS OR TESTS:

- 1. Entergy will perform a technical review of the supplying Owner's records of Welder Performance Qualification (WPQ), Welding Operator Performance Qualification (WOPQ), or Brazer/Brazing Operator Performance Qualification (BPQ).
- 2. The supplying Owner will state in writing that the WPQ, WOPQ, or BPQ was performed under an acceptable Nuclear Quality Assurance program that meets ASME Section XI, IWA-1400, and that the tests were performed in accordance with ASME Section IX.
- 3. Entergy will obtain any necessary supporting information to satisfy the requirements of ASME Section IX, QW-301.4 or QB-301.4.

Attachment 1 to JPN-03-020/NL-03-130/ENO 1.2.03.091/BVY 03-63

JAMES A. FITZPATRICK THIRD INSERVICE INSPECTION INTERVAL RELIEF REQUEST RR-32, Rev. 0

- 4. Entergy will require each welder, welding operator, brazer, or brazing operator to demonstrate proficiency by completing a renewal qualification test in accordance with ASME Section IX, QW-322.2(a) or QB-322(b), as applicable, with the following additional requirements.
 - a. When the WPQ transfer involves prior groove tests, the renewal test shall use a groove configuration.
 - b. When the WPQ transfer involves prior fillet tests, the renewal tests may use either a groove or a fillet configuration.
- 5. Entergy will accept the responsibility for the Performance Qualification Test(s), and will document this acceptance on the renewal test record(s) for the WPQ/WOPQ/BPQ. The renewal test record(s) will reference the original WPQ/WOPQ/BPQ test record(s) supplied by the Owner that provided the qualification.
- 6. Entergy will accept the responsibility for compliance with ASME Section IX, QW-322 or QB-322, as applicable.
- 7. Entergy will not accept qualifications from any Owner that was not the qualifying organization nor transfer the supplied qualifications to any other Owner.
- 8. Entergy will comply with the Quality Assurance requirements of ASME Section XI, Article IWA-1400.
- 9. Entergy will document the use of this Case on the record of the WPQ/WOPQ/BPQ for the renewal qualification test(s).

F. IMPLEMENTATION SCHEDULE

The alternative requirements of ASME Code Case N-600 are applicable to the Entergy's Inservice Inspection Program for the Third Ten-Year ISI Interval.

G. ATTACHMENTS

Attachment 2 to JPN-03-020/NL-03-130/ENO 1.2.03.091/BVY 03-63

INDIAN POINT GENERATING STATION UNIT NO. 2 THIRD 10-YEAR INSERVICE INSPECTION INTERVAL RELIEF REQUEST NO. RR-64

A. COMPONENT IDENTIFICATION:

Class:

All

Identification of System:

All

B. CODE REQUIREMENTS:

Article IWA-4400(b) - All welders shall be qualified by the repair organization in accordance with the requirements of the codes specified in the Repair Program in accordance with IWA-4120.

C. RELIEF REQUEST:

Relief is requested from the requirements of ASME Section XI, Article IWA-4400(b).

D. BASIS FOR RELIEF:

The basis for this relief is to implement the alternative requirements of ASME Code Case N-600 for the performance qualification testing of welders, welding operators, brazers, and brazing operators. Code Case N-600 proposes an alternative that would allow the transfer of performance qualifications between Owners, thereby eliminating redundant performance qualifications between facilities. This proposed alternative provides an acceptable level of quality and safety pursuant to 10 CFR 50.55a(a)(3)(i).

A similar request for relief was approved for Point Beach Nuclear Plant, Units 1 and 2 (TAC NOS. MB5403 and MB5404, dated March 21, 2003).

E. ALTERNATIVE EXAMINATIONS OR TESTS:

- 1. Entergy will perform a technical review of the supplying Owner's records of Welder Performance Qualification (WPQ), Welding Operator Performance Qualification (WOPQ), or Brazer/Brazing Operator Performance Qualification (BPQ).
- 2. The supplying Owner will state in writing that the WPQ, WOPQ, or BPQ was performed under an acceptable Nuclear Quality Assurance program that meets ASME Section XI, IWA-1400, and that the tests were performed in accordance with ASME Section IX.
- 3. Entergy will obtain any necessary supporting information to satisfy the requirements of ASME Section IX, QW-301.4 or QB-301.4.

Attachment 2 to JPN-03-020/NL-03-130/ENO 1.2.03.091/BVY 03-63

INDIAN POINT GENERATING STATION UNIT NO. 2 THIRD 10-YEAR INSERVICE INSPECTION INTERVAL RELIEF REQUEST NO. RR-64

- 4. Entergy will require each welder, welding operator, brazer, or brazing operator to demonstrate proficiency by completing a renewal qualification test in accordance with ASME Section IX, QW-322.2(a) or QB-322(b), as applicable, with the following additional requirements.
 - a. When the WPQ transfer involves prior groove tests, the renewal test shall use a groove configuration.
 - b. When the WPQ transfer involves prior fillet tests, the renewal tests may use either a groove or a fillet configuration.
- 5. Entergy will accept the responsibility for the Performance Qualification Test(s), and will document this acceptance on the renewal test record(s) for the WPQWOPQ/BPQ. The renewal test record(s) will reference the original WPQWOPQ/BPQ test record(s) supplied by the Owner that provided the qualification.
- 6. Entergy will accept the responsibility for compliance with ASME Section IX, QW-322 or QB-322, as applicable.
- 7. Entergy will not accept qualifications from any Owner that was not the qualifying organization nor transfer the supplied qualifications to any other Owner.
- 8. Entergy will comply with the Quality Assurance requirements of ASME Section XI, Article IWA-1400.
- 9. Entergy will document the use of this Case on the record of the WPQ/WOPQ/BPQ for the renewal qualification test(s).

F. IMPLEMENTATION SCHEDULE

The alternative requirements of ASME Code Case N-600 are applicable to the Entergy's Inservice Inspection Program for the Third Ten-Year ISI Interval.

G. ATTACHMENTS

Attachment 3 to JPN-03-020/NL-03-130/ENO 1.2.03.091/BVY 03-63

INDIAN POINT GENERATING STATION UNIT NO. 3 THIRD 10-YEAR INSERVICE INSPECTION INTERVAL RELIEF REQUEST No. RR 3-33 (A)

A. COMPONENT IDENTIFICATION:

Class:

All

Identification of System:

All

B. CODE REQUIREMENTS:

Article IWA-4400(b) - All welders shall be qualified by the repair organization in accordance with the requirements of the codes specified in the Repair Program in accordance with IWA-4120.

C. RELIEF REQUEST:

Relief is requested from the requirements of ASME Section XI, Article IWA-4400(b).

D. BASIS FOR RELIEF:

The basis for this relief is to implement the alternative requirements of ASME Code Case N-600 for the performance qualification testing of welders, welding operators, brazers, and brazing operators. Code Case N-600 proposes an alternative that would allow the transfer of performance qualifications between Owners, thereby eliminating redundant performance qualifications between facilities. This proposed alternative provides an acceptable level of quality and safety pursuant to 10 CFR 50.55a(a)(3)(i).

A similar request for relief was approved for Point Beach Nuclear Plant, Units 1 and 2 (TAC NOS. MB5403 and MB5404, dated March 21, 2003).

E. ALTERNATIVE EXAMINATIONS OR TESTS:

- 1. Entergy will perform a technical review of the supplying Owner's records of Welder Performance Qualification (WPQ), Welding Operator Performance Qualification (WOPQ), or Brazer/Brazing Operator Performance Qualification (BPQ).
- 2. The supplying Owner will state in writing that the WPQ, WOPQ, or BPQ was performed under an acceptable Nuclear Quality Assurance program that meets ASME Section XI, IWA-1400, and that the tests were performed in accordance with ASME Section IX.
- 3. Entergy will obtain any necessary supporting information to satisfy the requirements of ASME Section IX, QW-301.4 or QB-301.4.

Attachment 3 to JPN-03-020/NL-03-130/ENO 1.2.03.091/BVY 03-63

INDIAN POINT GENERATING STATION UNIT NO. 3 THIRD 10-YEAR INSERVICE INSPECTION INTERVAL RELIEF REQUEST No. RR 3-33 (A)

- 4. Entergy will require each welder, welding operator, brazer, or brazing operator to demonstrate proficiency by completing a renewal qualification test in accordance with ASME Section IX, QW-322.2(a) or QB-322(b), as applicable, with the following additional requirements.
 - a. When the WPQ transfer involves prior groove tests, the renewal test shall use a groove configuration.

b. When the WPQ transfer involves prior fillet tests, the renewal tests may use either a groove or a fillet configuration.

- 5. Entergy will accept the responsibility for the Performance Qualification Test(s), and will document this acceptance on the renewal test record(s) for the WPQ/WOPQ/BPQ. The renewal test record(s) will reference the original WPQ/WOPQ/BPQ test record(s) supplied by the Owner that provided the qualification.
- 6. Entergy will accept the responsibility for compliance with ASME Section IX, QW-322 or QB-322, as applicable.
- 7. Entergy will not accept qualifications from any Owner that was not the qualifying organization nor transfer the supplied qualifications to any other Owner.
- 8. Entergy will comply with the Quality Assurance requirements of ASME Section XI. Article IWA-1400.
- 9. Entergy will document the use of this Case on the record of the WPQ/WOPQ/BPQ for the renewal qualification test(s).

F. IMPLEMENTATION SCHEDULE

The alternative requirements of ASME Code Case N-600 are applicable to the Entergy's Inservice Inspection Program for the Third Ten-Year ISI Interval.

G. ATTACHMENTS

Attachment 4 to JPN-03-020/NL-03-130/ENO 1.2.03.091/BVY 03-63

PILGRIM RELIEF REQUEST NO. PRR-33 THIRD 10-YEAR INSERVICE INSPECTION INTERVAL

A. COMPONENT IDENTIFICATION:

Class:

All

Identification of System:

All

B. CODE REQUIREMENTS:

Article IWA-4400(b) - All welders shall be qualified by the repair organization in accordance with the requirements of the codes specified in the Repair Program in accordance with IWA-4120.

C. RELIEF REQUEST:

Relief is requested from the requirements of ASME Section XI, Article IWA-4400(b).

D. BASIS FOR RELIEF:

The basis for this relief is to implement the alternative requirements of ASME Code Case N-600 for the performance qualification testing of welders, welding operators, brazers, and brazing operators. Code Case N-600 proposes an alternative that would allow the transfer of performance qualifications between Owners, thereby eliminating redundant performance qualifications between facilities. This proposed alternative provides an acceptable level of quality and safety pursuant to 10 CFR 50.55a(a)(3)(i).

A similar request for relief was approved for Point Beach Nuclear Plant, Units 1 and 2 (TAC NOS. MB5403 and MB5404, dated March 21, 2003).

E. ALTERNATIVE EXAMINATIONS OR TESTS:

- Entergy will perform a technical review of the supplying Owner's records of Welder Performance Qualification (WPQ), Welding Operator Performance Qualification (WOPQ), or Brazer/Brazing Operator Performance Qualification (BPQ).
- 2. The supplying Owner will state in writing that the WPQ, WOPQ, or BPQ was performed under an acceptable Nuclear Quality Assurance program that meets ASME Section XI, IWA-1400, and that the tests were performed in accordance with ASME Section IX.
- 3. Entergy will obtain any necessary supporting information to satisfy the requirements of ASME Section IX, QW-301.4 or QB-301.4.

Attachment 4 to JPN-03-020/NL-03-130/ENO 1.2.03.091/BVY 03-63

PILGRIM RELIEF REQUEST NO. PRR-33 THIRD 10-YEAR INSERVICE INSPECTION INTERVAL

- 4. Entergy will require each welder, welding operator, brazer, or brazing operator to demonstrate proficiency by completing a renewal qualification test in accordance with ASME Section IX, QW-322.2(a) or QB-322(b), as applicable, with the following additional requirements.
 - a. When the WPQ transfer involves prior groove tests, the renewal test shall use a groove configuration.

b. When the WPQ transfer involves prior fillet tests, the renewal tests may use either a groove or a fillet configuration.

5. Entergy will accept the responsibility for the Performance Qualification Test(s), and will document this acceptance on the renewal test record(s) for the WPQ/WOPQ/BPQ. The renewal test record(s) will reference the original WPQ/WOPQ/BPQ test record(s) supplied by the Owner that provided the qualification.

6. Entergy will accept the responsibility for compliance with ASME Section IX, QW-322 or QB-322, as applicable.

- 7. Entergy will not accept qualifications from any Owner that was not the qualifying organization nor transfer the supplied qualifications to any other Owner.
- 8. Entergy will comply with the Quality Assurance requirements of ASME Section XI, Article IWA-1400.
- 9. Entergy will document the use of this Case on the record of the WPQ/WOPQ/BPQ for the renewal qualification test(s).

F. IMPLEMENTATION SCHEDULE

The alternative requirements of ASME Code Case N-600 are applicable to the Entergy's Inservice Inspection Program for the Third Ten-Year ISI Interval.

G. ATTACHMENTS

Attachment 5 to JPN-03-020/NL-03-130/ENO 1.2.03.091/BVY 03-63

VERMONT YANKEE NUCLEAR POWER STATION THIRD 10-YEAR INSERVICE INSPECTION INTERVAL RELIEF REQUEST NO. ISI-012

A. COMPONENT IDENTIFICATION:

Class:

All

Identification of System:

All

B. CODE REQUIREMENTS:

Article IWA-4440(b) - All welders shall be qualified by the repair organization in accordance with the requirements of the codes specified in the Repair Program in accordance with IWA-4120.

C. RELIEF REQUEST:

Relief is requested from the requirements of ASME Section XI, Article IWA-4440(b).

D. BASIS FOR RELIEF:

The basis for this relief is to implement the alternative requirements of ASME Code Case N-600 for the performance qualification testing of welders, welding operators, brazers, and brazing operators. Code Case N-600 proposes an alternative that would allow the transfer of performance qualifications between Owners, thereby eliminating redundant performance qualifications between facilities. This proposed alternative provides an acceptable level of quality and safety pursuant to 10 CFR 50.55a(a)(3)(i).

A similar request for relief was approved for Point Beach Nuclear Plant, Units 1 and 2 (TAC NOS. MB5403 and MB5404, dated March 21, 2003).

E. ALTERNATIVE EXAMINATIONS OR TESTS:

- Entergy will perform a technical review of the supplying Owner's records of Welder Performance Qualification (WPQ), Welding Operator Performance Qualification (WOPQ), or Brazer/Brazing Operator Performance Qualification (BPQ).
- 2. The supplying Owner will state in writing that the WPQ, WOPQ, or BPQ was performed under an acceptable Nuclear Quality Assurance program that meets ASME Section XI, IWA-1400, and that the tests were performed in accordance with ASME Section IX.

Attachment 5 to JPN-03-020/NL-03-130/ENO 1.2.03.091/BVY 03-63

VERMONT YANKEE NUCLEAR POWER STATION THIRD 10-YEAR INSERVICE INSPECTION INTERVAL RELIEF REQUEST NO. ISI-012

- 3. Entergy will obtain any necessary supporting information to satisfy the requirements of ASME Section IX, QW-301.4 or QB-301.4.
- 4. Entergy will require each welder, welding operator, brazer, or brazing operator to demonstrate proficiency by completing a renewal qualification test in accordance with ASME Section IX, QW-322.2(a) or QB-322(b), as applicable, with the following additional requirements.
 - a. When the WPQ transfer involves prior groove tests, the renewal test shall use a groove configuration.
 - b. When the WPQ transfer involves prior fillet tests, the renewal tests may use either a groove or a fillet configuration.
- 5. Entergy will accept the responsibility for the Performance Qualification Test(s), and will document this acceptance on the renewal test record(s) for the WPQ/WOPQ/BPQ. The renewal test record(s) will reference the original WPQ/WOPQ/BPQ test record(s) supplied by the Owner that provided the qualification.
- 6. Entergy will accept the responsibility for compliance with ASME Section IX, QW-322 or QB-322, as applicable.
- 7. Entergy will not accept qualifications from any Owner that was not the qualifying organization nor transfer the supplied qualifications to any other Owner.
- 8. Entergy will comply with the Quality Assurance requirements of ASME Section XI. Article IWA-4142(a).
- 9. Entergy will document the use of this Case on the record of the WPQ/WOPQ/BPQ for the renewal qualification test(s).

F. IMPLEMENTATION SCHEDULE

The alternative requirements of ASME Code Case N-600 are applicable to the Entergy's Inservice Inspection Program for the Fourth Ten-Year ISI Interval, beginning September 1, 2003.

G. ATTACHMENTS

- Attachment 6 to JPN-03-020/NL-03-130/ENO 1.2.03.091/BVY 03-63

CASE

N-600

CASES OF ASME BOILER AND PRESSURE VESSEL CODE

Approval Date: September 18, 2001

See Numeric Index for expiration
and any reaffirmation dates.

Case N-600
Transfer of Welder, Welding Operator, Brazer, and Brazing Operator Qualifications Between Owners
Section XI, Division 1

Inquiry: What alternative to the welding and brazing performance qualification requirements of IWA-4000 may be used?

Reply: It is the opinion of the Committee that as an alternative to the welding and brazing performance qualification requirements of IWA-4000, a welder, welding operator, brazer, or brazing operator qualified by one Owner may be used by another Owner. The following requirements shall be met.

- (a) The Owner who performed the qualification test shall certify that testing was performed in accordance with Section IX by signing the record of Welder/Welding Operator/Brazer/Brazing Operator Performance Qualification (WPO/BPO).
- (b) The Owner who performed the qualification test shall certify, in writing, that qualification was conducted in accordance with a Quality Assurance Program that satisfies the requirements of IWA-1400.
- (c) The Owner accepting the WPQ/BPQ shall obtain any necessary supporting information to satisfy QW-

- 301.4 (e.g., Welding Procedure Specification, type of tests).
- (d) The Owner accepting the WPQ/BPQ shall require each welder, welding operator, brazer, or brazing operator to demonstrate proficiency by completing a renewal qualification test in accordance with QW-322.2(a) or QB-322(b).
- (1) When WPQ transfer involves prior groove tests, the renewal test shall use a groove configuration.
- (2) When WPQ transfer involves prior fillet tests, the renewal tests may use either a groove or a fillet configuration.
- (e) The Owner accepting the WPQ/BPQ shall accept responsibility for the Performance Qualification Test, and shall document acceptance on the WPQ/BPQ for the renewal test. This WPQ/BPQ shall reference the WPQ/BPQ supplied by the Owner that performed the qualification.
- (f) The Owner accepting the WPQ/BPQ shall accept responsibility for compliance with QW-322.
- (g) The Owner may accept and use a WPQ/BPQ only when it is received directly from the Owner who performed the qualification.
- (h) The Owner accepting the WPQ/BPQ shall comply with the Quality Assurance requirements of IWA-4142(a).
- (i) Use of this Case shall be documented on the WPQ/BPQ for the renewal test in lieu of on the Repair/Replacement Plan and the NIS-2 Form.