

POLICY ISSUE INFORMATION

April 6, 2004

SECY-04-0052

FOR: The Commissioners

FROM: William D. Travers
Executive Director for Operations

SUBJECT: FY 2003 RESULTS OF THE INDUSTRY TRENDS PROGRAM FOR
OPERATING POWER REACTORS AND STATUS OF ONGOING
DEVELOPMENT

PURPOSE:

To inform the Commission of the results of the Nuclear Regulatory Commission's (NRC) Industry Trends Program (ITP) for FY 2003 and the status of ongoing development.

SUMMARY:

The NRC staff implemented the ITP in 2001, and is continuing to develop the program as a means to confirm that the nuclear industry is maintaining the safety of operating power plants and to increase public confidence in the efficacy of the NRC's processes. The NRC uses industry-level indicators to identify adverse trends. Adverse trends are assessed for safety significance and the NRC responds as necessary to any safety issues identified. One important output of this program is to report to Congress each year on the performance goal measure of "no statistically significant adverse industry trends in safety performance" as part of the NRC's Performance and Accountability Report. Based on the information currently available from the industry-level indicators originally developed by the former Office for Analysis and Evaluation of Operational Data (AEOD) and the Accident Sequence Precursor (ASP) Program implemented by RES, no statistically significant adverse industry trends have been identified through FY 2003. However, three of the industry trend indicators met or exceeded their prediction limits and are discussed in more detail within this paper.

CONTACT: David Wrona, NRR/DIPM
301-415-1924

The staff is continuing to use the AEOD and ASP indicators while it develops additional industry-level indicators that are more risk-informed and better aligned with the cornerstones of safety in the Reactor Oversight Process (ROP). These additional indicators will be developed in phases and qualified for use in the ITP and the annual Performance and Accountability Report to Congress. The results of this program, along with any actions taken or planned, are reviewed annually during the Agency Action Review Meeting (AARM) and reported to the Commission.

BACKGROUND:

This paper is the fourth annual report to the Commission on the ITP. The previous Commission reports were SECY-01-0111, "Development of an Industry Trends Program for Operating Power Reactors;" SECY-02-0058, "Results of the Industry Trends Program for Operating Power Reactors and Status of Ongoing Development;" and SECY-03-0057, "FY 2002 Results of the Industry Trends Program for Operating Power Reactors and Status of Ongoing Development." Additional information on the ITP and the process for identifying and addressing adverse trends was provided in SECY-03-0057.

The ROP uses both plant-level performance indicators (PIs) and inspections to provide plant-specific oversight of safety performance. The ITP provides a means to assess overall industry performance using industry-level indicators. Issues that are identified from either the ROP or the ITP are evaluated using information from agency databases, and those assessed as having generic safety significance are addressed using existing NRC processes, including generic safety inspections in the ROP, the generic communications process, and the generic safety issue process.

The ITP is a joint effort between the Inspection Program Branch in the Office of Nuclear Reactor Regulation (NRR) and the Operating Experience and Risk Analysis Branch in the Office of Nuclear Regulatory Research (RES). The purposes of the ITP are to provide a means to assess whether the nuclear industry is maintaining the safety performance of operating reactors and, by clearly communicating that performance, to enhance stakeholder confidence in the efficacy of the NRC's processes. The specific objectives of the ITP are as follows:

- (1) Collect and monitor industry-wide data that can be used to assess whether the nuclear industry is maintaining the safety performance of operating plants and to provide feedback on the ROP;
- (2) Assess the safety significance and causes of any statistically significant adverse industry trends, determine if the trends represent an actual degradation in overall industry safety performance, and respond appropriately to any safety issues that may be identified;
- (3) Communicate industry-level information to Congress and other stakeholders in an effective and timely manner; and
- (4) Support the NRC's performance goals of maintaining safety and enhancing public confidence in the agency's regulatory processes.

The NRC currently uses the results of the ITP in the following ways:

- (1) The NRC reports the industry indicators to Congress annually in the NRC's "Performance and Accountability Report, Fiscal Year 200X" (NUREG-1542 series) and in the NRC's "Budget Estimates and Performance Plan Fiscal Year 200X" (NUREG-1100 series). The indicators demonstrate how the agency's ROP produced successful results by meeting the measure of "no statistically significant adverse industry trends in safety performance" for the performance goal of maintaining safety;
- (2) The NRC communicates overall industry performance to stakeholders by publishing the ITP indicators on the Nuclear Reactors portion of the agency's public Web site at <http://www.nrc.gov/reactors/operating/oversight/industry-trends.html>. The staff believes that communication of the industry-level indicators, when added to the information on individual plants from the ROP, enhances stakeholder confidence in the efficacy of the NRC's oversight of the nuclear industry;
- (3) The results of the ITP are a key element of the review by senior NRC managers of the agency's oversight of operating facilities in the annual AARM;
- (4) The staff informs the Commission of the results of the ITP in an annual report in the same timeframe as the AARM;
- (5) The Commission uses the ITP indicators when presenting the status of industry performance to the NRC's oversight committees and at major conferences with stakeholders; and
- (6) NRC managers use the ITP indicators to provide an overview of industry performance at various conferences with stakeholders, such as the NRC's Regulatory Information Conference.

DISCUSSION:

The ITP is intended to monitor trends in industry safety performance so that the staff can identify and address adverse industry trends. The ITP does so using indicators of known conditions and issues that are compiled from the best available data. The staff monitors a comprehensive set of indicators; however, the staff recognizes that there are limits on what can be tracked and trended by the ITP. Oversight of plant-specific conditions and events is provided by the ROP. The staff recognizes that although the ITP attempts to identify developing trends, new and unforeseen events can occur, such as the significant erosion of the reactor vessel head at Davis-Besse. The staff is mindful of the need to respond promptly to these events, as well as the need to review its regulatory processes in light of the issues revealed by these events.

RESULTS OF FY 2003 TREND ANALYSES

A key output of the ITP is that it provides the basis for agency monitoring and reporting to Congress against the performance goal measure of “no statistically significant adverse industry trends in safety performance,” as established by the NRC’s Strategic Plan. The current bases for assessing performance against this measure are trends in the industry indicators developed by the former AEOD (henceforth referred to as the “AEOD indicators”) and trends identified by the ASP Program. Notably, these indicators were among those cited as demonstrating improvements in industry safety performance that contributed to the agency’s decision to revise the oversight process for operating power reactors.

Based on the AEOD indicators and the ASP Program results, no statistically significant adverse trends in industry safety performance were identified through the end of FY 2003. Graphs of the trends for each of these indicators are presented in Attachment 1.

In addition, as discussed in SECY-01-0111, the staff adopted a statistical approach using “prediction limits” to provide a consistent method to identify potential short-term year-to-year emergent issues before they manifest themselves as long-term trends. Three AEOD indicators, automatic scrams while critical, safety system actuations (SSA), and equipment-forced outage (EFO) rate reached or exceeded their prediction limit during FY 2003 and are discussed below. The staff followed the process for investigating adverse trends that was outlined in Attachment 1 of SECY-03-0057, which included analyzing in detail the data supporting each indicator to understand the causes.

- Automatic Scrams and Safety System Actuations

The automatic scrams while critical prediction limit was 0.680 per plant and the actual FY 2003 value was 0.748 per plant, which equates to the threshold being exceeded by 7 scrams. The SSA prediction limit was 0.340 per plant and the actual FY 2003 value was 0.398 per plant, which equates to 6 actuations over the prediction limit.

Automatic scrams and SSAs have a clear and established interdependency; events that trigger scrams often trigger one or more SSAs. For example, and as part of the explanation for the increases seen in FY 2003, the August 14, 2003, Northeast blackout event resulted in 9 automatic scrams and 12 SSAs at the 10 nuclear plants affected (Davis-Besse was shut down at the time and thus did not experience a scram). This single event alone did not account for all of the FY 2003 increase over the FY 2002 values for these two indicators. In fact, this event did not even account for the majority of the increase over FY 2002 numbers in the case of automatic scrams. The same is true if the FY 2003 numbers are compared with the average of the previous 3 years (FY 2000 through 2002).

Also of note is that of the nine plants that scrambled from the blackout, four plants contributed four previous scrams to the FY 2003 scram count that were directly caused by problems with the offsite power grid and/or the plant’s interface with the grid. Subsequent to the blackout, three other Northeast plants scrambled due to loss of offsite power. A similar pattern was seen with SSAs.

A detailed analysis of the contributing factors and causes of the increased number of automatic scrams and SSAs was performed and a summary of this analysis is provided in Attachment 2. The data review was expanded to include a review of plant comparison groups, activities in progress at the time of the event, and apparent causes. The results indicate that the number of automatic scrams increased primarily due to grid-related problems and the increase in the number of automatic scrams resulted in a related increase in SSAs. ASP analysis will provide some safety and risk significance on the blackout event. Preliminary ASP analyses have been completed and forwarded to the licensees for review. The NRC has previously developed an action plan for reviewing U.S. nuclear power plant issues relating to recent electric power grid events (see Memorandum from W. Travers to Chairman Diaz, "Action Plan for Resolving Electrical Grid Concerns," dated February 4, 2004). In the Memorandum, the staff stated that it has not identified any safety issues warranting immediate regulatory action and will evaluate whether generic communications or other regulatory processes are needed to highlight and address grid issues. Since the increase in SSAs was due to an increase in the number of scrams, no additional action beyond what will be done due to the increase in the number of scrams is needed.

Although not tracked as an industry trends indicator, the number of plants that exceeded the green to white threshold of the unplanned scrams per 7,000 critical hours PI of the ROP increased in FY 2003. Eight plants crossed the green to white threshold in FY 2003, while only two and three plants crossed the threshold in FY 2002 and 2001, respectively. Supplemental inspections, as required by the ROP Action Matrix, were performed or are planned at these plants that crossed the ROP PI threshold.

- Equipment-Forced Outage Rate

The FY 2003 equipment-forced outage rate was at the prediction limit of 0.157 per 1000 commercial critical hours.

In contrast to the automatic scrams and safety system actuation indicators discussed above, the August 14 blackout event had very little effect on the FY 2003 EFO rate. None of the plant outages initiated by the blackout event were classified as equipment-forced outages, and the associated outages were collectively of short duration (thus having little effect on the denominator of the EFO calculation). A breakdown of the EFO rate calculation shows that both the numerator and the denominator were instrumental in driving the rate increase. The total number of industry critical hours (EFO denominator) in FY 2003 was less than those in the 3 preceding years (FYs 2000 through 2002). The extended Davis-Besse shutdown and the increase in the number of scrams contributed to this decrease. The number of equipment-forced outages (EFO numerator) was larger than those in the preceding four years (FYs 1999 through 2002). Several factors contributed to this increase. For example, one plant reported a total of 11 individual equipment-forced outages in FY 2003, 9 of which were consecutive delays in recovering from a single refueling outage.

Since the equipment-forced outage rate was influenced by one plant that was specifically related to the extension of a refueling outage, NRR did not identify any industry-wide safety issues associated with reaching the FY 2003 prediction limit for the

equipment-forced outage rate indicator, and any plant specific issues identified will be addressed via the ROP.

In last year's industry trend SECY paper, SECY-03-0057, the ASP indicator chart displayed preliminary results for FY 2000 and FY 2001. Although the ASP indicator did not cross a prediction limit, the staff noted an increasing number of potential precursors in 2000 and 2001 when compared to the relatively low number of precursors between 1997 and 1999 and planned to analyze these short-term variations in the number of ASP events. Further, last year's SECY paper mentioned staff's intentions to investigate the nature of the short-term variations as part of the ITP. However, due to other priorities, staff was unable to meet prior expectations, including the completion of the preliminary analysis of FY 2001 events and the evaluation of the short-term variations.

ITP PROGRAM DEVELOPMENT

1. Incorporation of Additional Industry Operating Experience

The NRC's Davis-Besse Lessons Learned Task Force (DBLLTF) provided a number of recommendations to improve NRC utilization of operating experience information. An Operating Experience Task Force was chartered to evaluate the agency's reactor operating experience program and to recommend specific program improvements. On November 26, 2003, the "Reactor Operating Experience Task Force Report" was issued. The staff is currently assessing the recommendations of the task force to determine what changes or enhancements to the ITP may be appropriate, and will highlight any necessary changes in the next ITP annual report to the Commission.

The staff has updated the data and trends that were previously published in various NUREG-series reports for system reliability studies, component reliability studies, common-cause failure studies, and other special studies for which industry-wide trends were reported. In addition, as a means of providing greater stakeholder access to this information, the staff has posted the results of these updates on an internal RES Web page and is working towards posting these results on the NRC public Web site. While these results are not formally reported as indicators in the ITP, they are an integral part of any evaluation that will be performed if any ITP indicator exceeds a prediction limit or shows an adverse trend.

2. Development of Additional, More Risk-Informed Indicators

The staff has continued to develop additional indicators that are more risk-informed and better aligned with the cornerstones of safety in the ROP. For example, the staff has continued development of industry-level indicators from the data that licensees submit for the plant-level ROP PIs. However, since the ROP was only implemented in April 2000 and some of the PI data submitted to support initial implementation were best estimates, there is still insufficient data for reliable long-term trending of these indicators. Nonetheless, based on a review of the indicator data submitted to date, no statistically significant adverse trends have emerged.

In SECY-03-0057, the staff reported on the development of an index for boiling water reactors that monitors 9 risk-significant initiating events and a similar index for pressurized water reactors that monitors 10 events (the additional category of events is steam generator tube

ruptures). Each initiating event is weighted in the index based on its relative contribution to industry core damage frequency. This indicator is called the Baseline Risk Index for Initiating Events (BRIIE) and is discussed in more detail in Attachment 3.

The staff has continued development work during FY 2003 and has given briefings on the BRIIE concept during periodic ROP working group public meetings, at subcommittee meetings of the Advisory Committee on Reactor Safeguards (ACRS), and during a public workshop. The staff has received valuable feedback during these meetings, and is addressing comments that have been received. The staff intends to increase its interactions with stakeholders on the BRIIE during this fiscal year. NRR is currently evaluating BRIIE for inclusion into the ITP and expects to make a decision on BRIIE by mid 2004. If the BRIIE concept is deemed acceptable for use in the ITP, the staff plans to work towards a pilot program and possible implementation within 1–2 years.

3. Risk-Informed Response Thresholds

As discussed in SECY-01-0111, the staff intends to develop risk-informed thresholds to the extent practicable and use them to determine the appropriate agency response to trends in indicator data. The Commission supported this position and in the staff requirements memorandum (SRM) related to SECY-01-0111, dated August 2, 2001, directed the staff to develop risk-informed thresholds for the industry-level indicators “as soon as practicable.”

However, as discussed in SECY-03-0057, the staff continues to develop more risk-informed indicators for the initiating events cornerstone (e.g., the BRIIE). The staff continues to focus its resources on developing those potential replacement indicators rather than on developing risk-informed thresholds for the current set of ITP indicators since the AEOD indicators are not easily risk-informed.

4. Potential Single Integrated Indicator of Industry Performance

Attachment 4 shows an integrated indicator known as the Action Matrix Summary. It is a histogram that shows the number of plants in each column of the NRC’s Action Matrix since initial implementation of the revised ROP. This single indicator provides a representative picture of industry performance because it effectively rolls up both performance indicators and inspection findings from the ROP in all cornerstones of safety.

The staff has proposed to establish a new performance measure that will count the number of plants with significant performance issues, using the Action Matrix Summary indicator for reporting against the measure. The measure would be “number of operating reactors whose integrated performance is in the multiple/repetitive degraded cornerstone column or above of the ROP Action Matrix is less than or equal to five...” This measure has the advantage that the staff is already taking actions to address safety issues for these plants in an objective and predictable manner in accordance with the ROP Action Matrix.

This measure is in addition to the existing measure related to adverse industry trends in safety performance. The staff is pursuing this measure for use in the NRC’s Budget Estimates and Performance Plan for FY 2006 (also known as the Green Book).

5. Improved Data Collection and Reporting

Licensees report operating experience data to the NRC, including data for the ROP plant-level indicators, licensee event reports (LERs), and monthly operating reports. Licensees also report additional data to other organizations such as the Institute of Nuclear Power Operations (INPO). The staff uses all of these reports as data sources for the indicators used in the ITP, and the databases are essential to investigating safety issues when trends in the ITP indicators are identified.

The staff continues to work extensively with industry to develop a consistent set of data elements, definitions, and reporting guidelines for reliability and unavailability data that would meet the needs of all stakeholders. To reduce unnecessary regulatory burden, the industry has proposed changes to the method of supplying monthly operating reports to the NRC. The staff is evaluating the possibility of obtaining the data quarterly in an electronic format from an industry database. The new process for submitting monthly operating report data to the NRC could be in place for FY 2005.

6. Industry Trend Communication Mechanisms

Currently the staff prepares a SECY paper on the results of the ITP for operating power reactors. Industry trend indicators are also published on the NRC external Web page quarterly and reported to Congress annually in the NRC's Performance and Accountability Report and in the NRC's Budget Estimates and Performance Plan. The staff plans to evaluate these communication methods in calendar year 2004 to determine if they are the most effective and efficient way to communicate the ITP results to the interested stakeholders.

RESOURCES:

For FY 2004, NRR has budgeted approximately 1.5 full-time equivalent (FTE) and \$278K for the continued development and implementation of the ITP. For FYs 2005 through 2007, NRR estimates resource requirements of approximately 1.5 FTE per year, with estimated contract assistance funding requirements of about \$350K per year. NRR has included these requirements in its budget request submittals. Research support for the industry trends program utilizes operating experience data and models developed and budgeted under other RES programs.

The Commissioners

-9-

COORDINATION:

The Office of the Chief Financial Officer has reviewed this paper and concurs.

The Office of the General Counsel has reviewed this paper and has no legal objection.

/RA William F. Kane Acting For/

William D. Travers
Executive Director
for Operations

- Attachments:
1. FY 2003 Trend Results Based on AEOD and ASP Indicators
 2. Scram and Safety System Actuation Review
 3. Summary of Industry Trends Program Enhancement Effort for the Initiating Events Cornerstone of Safety
 4. Action Matrix Summary

COORDINATION:

The Office of the Chief Financial Officer has reviewed this paper and concurs.

The Office of the General Counsel has reviewed this paper and has no legal objection.

/RA William F. Kane Acting For/

William D. Travers
Executive Director
for Operations

- Attachments: 1. FY 2003 Trend Results Based on AEOD and ASP Indicators
2. Scram and Safety System Actuation Review
3. Summary of Industry Trends Program Enhancement Effort for the Initiating Events Cornerstone of Safety
4. Action Matrix Summary

WITS 200100034

ADAMS Accession Number: ML040640629

*SEE PREVIOUS CONCURRENCE

OFFICE	IIPB:DIPM	IIPB:DIPM	IIPB:DIPM	Tech Editing	IROB:DIPM
NAME	DWrona*	JAndersen*	SRichards*	PKleene*	TReis*
DATE	3/22/04	3/11/04	3/11/04	2/24/04	3/15/04
OFFICE	PPRB:PMAS	OCFO	DIPM:NRR	OGC	RES
NAME	RCorreia*	DDrucker (via email)*	BBoger*	NLO GMLongo for DD*	AThadani*
DATE	3/17/04	3/23/04	3/15/04	3/12/04	3/23/04
OFFICE	ADIP	NRR	EDO		
NAME	JCraig (BBoger for)*	JDyer*	WTravers		
DATE	3/26/04	03/30/04	04/6/04		

OFFICIAL RECORD COPY

**FY 2003 Trend Results
Based on AEOD and ASP Indicators**

**Indicators Originally Developed by the Former Office of AEOD and
Accident Sequence Precursor (ASP) Indicators**




Figure A1-1




Figure A1-2




Figure A1-3




Figure A1-4




Figure A1-5




Figure A1-6




Figure A1-7

Accident Sequence Precursor Trends

Figure A1-8 below shows the occurrence rate per reactor-year for all Accident Sequence Precursor (ASP) events by fiscal year. No statically significant adverse trend was observed in the occurrence rate for all precursor (CCDP or Δ CDP $> 10^{-6}$) during the 1993–2001 period. The trend is based on the number of all precursors starting in FY 1993. ASP results prior to FY 1993 use less rigorous methodology and are shown in the figure to provide historical perspective.

No trend was identified in the occurrence rate of all precursors during the 1993–2001 period. The FY 1993–2000 data is final. Several analyses of FY 2001 events are ongoing. This includes conditions involving the primary water stress corrosion cracking of control rod drive mechanism (CRDM) nozzles which require the completion of the RES probabilistic analysis of the time dependent failure frequencies of the CRDM nozzles. CRDM cracks were found at nine plants in FY 2001 and FY 2002 and may result in nine precursors. The on-going analysis of seven events in FY 2001 are conservatively included in the trending analysis.

Preliminary results for FY 2002 and FY 2003 are provided for information. The bar graph includes final results and preliminary results that have undergone internal staff review, as well as on-going analysis of potential precursors. Not all of these ongoing analyses will necessarily meet the precursor threshold when completed. Typically, 30 to 50 events per year undergo detailed analysis in the ASP Program of which more than half do not meet the precursor threshold upon further analysis.




Figure A1-8. Occurrence rate of all precursors, by fiscal year. No trend was identified during the FY 1993–2001 period (on-going analysis of seven events in FY 2001 are conservatively included in the trend). A trend line is not shown in the figure because the slope is not statistically significant. Results are current as of 3/15/2004.

Scram and Safety System Actuation Review

INTRODUCTION

During the annual review of industry trend performance indicator (PI) data, Idaho National Engineering and Environmental Laboratory (INEEL) reported that the 2003 automatic scram and safety system actuation (SSA) PIs exceeded their early-warning and action thresholds (see Table A4-1). These thresholds represent 95 and 99% prediction limits, respectively, developed from a baseline period (Fiscal Year [FY] 1997-2002 for scrams and 1999-2002 for SSAs).

Table A4-1. FY 2003 Scram and SSA data.

Indicator	FY 2003	Base Period Average	Early-Warning Threshold	Action Threshold
Automatic scrams	0.748/plant 77 scrams total	0.534/plant 55 scrams total	0.680/plant 70 scrams total	0.738/plant 76 scrams total
Safety system actuations	0.398/plant 41 SSAs total	0.241/plant 25 SSAs total	0.340/plant 35 SSAs total	0.388/plant 40 SSAs total
Equipment forced outage rate	0.157 outages per 1000 critical hours	0.131 outages per 1000 critical hours	0.157 outages per 1000 critical hours	0.166 outages per 1000 critical hours

Exceeding a single early-warning threshold is not uncommon, because this threshold is based on a 95 percent prediction limit. For each PI, the probability of exceeding warning-level and action level thresholds are 1/20 (5%) and 1/100 (1%), respectively, from random fluctuation. However, the probability of a PI reaching its early-warning threshold, and two other PIs exceeding their action thresholds from random fluctuation, without the influence of external factors, is extremely small (0.043%).

In response to this unusual PI activity, NRC requested that the INEEL perform an in-depth review of the scram and SSA data to identify any factors that may have caused the FY 2003 increase. This report contains the results of that review.

SUMMARY

Scrams

An increase in automatic scrams occurred in FY 2003 primarily due to grid-related problems.

SSAs

An increase in SSAs occurred in FY 2003. This increase resulted from the increase in total scrams (primarily automatic scrams). This change was not isolated to FY 2003. Although SSA numbers were decreasing before FY 2003, the number of SSAs associated with scrams was not decreasing. This resulted in an almost continuous increase in the percentage of SSAs that were associated with scrams. Thus, the increase in FY 2003 scrams resulted in a related increase in SSAs.

AUTOMATIC SCRAMS

INEEL conducted an analysis of the increase in the number of automatic scrams. The analysis included a review of the information listed below (similar data was also reviewed during the analysis of SSAs):

- scram causes (equipment, personnel error, or other)
- systems involved in equipment-related scrams (feedwater, turbine, generator, or other)
- activities in progress at the time the scram occurred (normal operation, maintenance, testing, or power changes)
- scrams by reactor type (PWR or boiling water reactor [BWR])
- the number of automatic scrams caused by problems associated with offsite power grid and/or the plants' interface with the grid
- a histogram of the number of plants that experienced different levels of scrams in a year

FY 2003 automatic scrams were at the highest level since FY 1996 (greater than any year in the FY 1997-2002 baseline period). The early-warning and action thresholds correspond to 70 and 76 scrams, respectively, for 103 plants (including Davis-Besse). In FY 2003, 77 automatic scrams occurred, exceeding the thresholds by 7 and 1 scrams, respectively; and exceeding the baseline period average (55) by 22 scrams (40%). It was noted that the August 14, 2003, Northeast blackout event resulted in 9 automatic scrams. Had this event not occurred, neither of the two thresholds would have been exceeded. However, the increase in FY 2003 automatic scrams would still be notable, exceeding the baseline period average by 13 scrams (24%).

Grid-related scrams rose dramatically in FY 2003; 23 scrams in FY 2003 compared to only 26 for the entire 6-year baseline period. The fact that FY 2003 grid-related scrams were 19 greater than the baseline period average accounts for most of the increase in FY 2003 automatic scrams.

Equipment failure continued to be the leading cause of automatic scrams, accounting for 48 (62%) of the FY 2003 automatic scrams. FY 2003 scrams due to equipment failure were 9 scrams (23%) greater than the baseline period average (48 vs. 39). However, when viewed as a percentage of all automatic scrams, the FY 2003 equipment failure scrams were 9% less than the baseline period average (62% vs. 71%).

The next leading cause category is "Other", accounting for 21 (27%) of FY 2003 automatic scrams. This category includes causes such as Procedure, Natural Phenomena, Unknown, and Other (including the grid related events that are outside of the affected plants' control). This category accounted for 13 scrams (163%) greater than the baseline period average (21 vs. 8). The Northeast blackout accounted for 9 of those 13 scrams.

During the baseline period, three systems resulted in more equipment scrams than others: feedwater, main generator, and turbine. This trend continued in FY 2003. In addition to the grid-related scrams discussed above, the main generator accounted for 5 scrams (71%) more than the baseline period average (12 vs. 7). The other systems accounted for a level of scrams similar to their baseline period averages.

Scrams during normal operation continued to dominate the other categories, accounting for 78% of FY 2003 automatic scrams. These figures indicate that the increase in the FY 2003 scrams occurred almost exclusively in the normal operation category.

Of the 103 operating commercial nuclear power plants, 67% are PWRs, and 33% are BWRs. Over the baseline period, PWRs experienced 63% of automatic scrams, and BWRs 37%. FY 2003 data were essentially identical, with PWRs experiencing 62% of auto scrams, and BWRs 38%. This indicates that the increase in automatic scrams was not isolated to a reactor type.

A histogram of the number of plants that experienced different levels of automatic scrams per year was generated. For example, in FY 2003, 39 plants experienced only a single automatic scram. The FY 2003 data exceeded the baseline period average in essentially every level, with no plant exceeding 4 automatic scrams per year. This indicates that the increase in automatic scrams was not isolated to a few plants.

Conclusion

This review identified that a single factor was primarily responsible for the increase in FY 2003 automatic scrams; problems associated with the offsite power grid and/or the plants' interface with the grid resulted in 23 FY 2003 automatic scrams. This included the Northeast blackout event, which resulted in 9 automatic scrams. Without the blackout event, the early-warning and action thresholds for automatic scrams would not have been exceeded, but the increase in FY 2003 automatic scrams (most of which was due to grid-related events) would still be notable. It was also noted that the baseline period from which the thresholds were developed did not include a singular event (such as the blackout) that resulted in multiple scrams. Additionally, relatively few scrams from grid-related events occurred during the baseline period.

SAFETY SYSTEM ACTUATIONS

Safety System Actuations (SSAs) are comprised of challenges to two classes of systems, emergency diesel generators (EDGs) and emergency core cooling systems (ECCS). The criteria that determines an SSA does not align exactly with the criteria for engineered safety feature (ESF) actuation reporting. Rather, SSAs are a subset of ESFs as determined by the type of system and circumstances of the actuation. Certain criteria must be satisfied to classify an actuation event as an SSA, and the classification is not solely restricted to actual safety needs. Basically, an EDG SSA is an event in which the EDG did, or should have, re-powered the associated de-energized emergency bus. An ECCS SSA is an event in which any ECCS actuation signal occurs, valid or not, or any ECCS equipment actuates. In either case, determination of an SSA may require some interpretation of the event report information. For this reason, SSAs are not as strictly objective as scrams.

FY 2003 SSAs were at the highest level since FY 1996 (greater than any year in the FY 1999-2002 baseline period). The early-warning and action thresholds correspond to 35 and 40 SSAs, respectively, for 103 plants (including Davis-Besse). In FY 2003, the industry experienced 41 SSAs, exceeding the thresholds by 6 and 1, respectively, and exceeding the baseline period average (25) by 16 (64%). Note that the August 14, 2003, Northeast blackout event resulted in 12 SSAs. Had this event not occurred, neither of the two thresholds would

have been exceeded, but the increase in FY 2003 SSAs would still be notable, exceeding the baseline period average by 4 SSAs (16%).

Due to the nature of SSAs, it is common for an event to cause both an SSA and a scram, or for an SSA to occur during a scram transient. For example, an EDG SSA and scram can both result from a loss of offsite power. Furthermore, an ECCS SSA can result from the level transient following a scram. During the baseline period, 39% of SSAs occurred with scrams. However, during FY 2003, 68% of SSAs occurred with scrams, indicating that the increase in FY 2003 SSAs was largely driven by the increase in scrams. For example, the events resulting in the 23 automatic scrams caused by problems associated with offsite power grid and/or the plants' interface with the grid also resulted in 19 SSAs.

Both types of SSAs (EDG and ECCS) increased in FY 2003. The FY 2003 EDG SSAs were 7 (47%) greater than the baseline period average (22 vs. 15), and ECCS SSAs were 9 (90%) greater than the baseline period average (19 vs. 10).

Of the 103 operating commercial nuclear power plants, 67% are PWRs and 33% are BWRs. Over the baseline period, PWRs experienced 60% of SSAs, and BWRs 40%. In FY 2003 data, the data reversed, with PWRs experiencing 39% of SSAs, and BWRs 61%. In fact, while FY 2003 PWR SSAs were essentially equal to their baseline period average (16 vs. 15), BWR SSAs were 15 (150%) greater than their baseline period average (25 vs. 10), in part due to automatic scrams at BWRs. This indicates that the increase in FY 2003 SSAs occurred mostly at BWRs.

A histogram of the number of plants that experienced different levels of annual SSAs was generated. For example, in FY 2003, 17 plants experienced only a single SSA. The FY 2003 data exceeded the baseline period average in every category (because there are no counts in the baseline 4/year category, compare the FY2003 4/year category with the baseline 3/year category), with no plant exceeding 4 SSAs per year. This indicates that the increase in SSAs was not isolated to a few plants.

Conclusions

The increase in FY 2003 SSAs was largely driven by the increase in scrams (primarily automatic scrams). The Northeast blackout event resulted in 12 SSAs. Without this event, neither of the two thresholds would have been exceeded. It is noted that the baseline period from which the thresholds were developed did not include a singular event (such as the blackout) that resulted in multiple SSAs.

Summary of Industry Trends Program Enhancement Effort for the Initiating Events Cornerstone of Safety

1 Reasons for Enhancing Current ITP Performance Indicators

Current ITP performance indicators have both strengths and weaknesses. Strengths include availability of historical results, continuity and consistency in yearly evaluations, and broad coverage of the Cornerstones of Safety. However, ITP performance indicator weaknesses in the Initiating Events and Mitigating Systems Cornerstones of Safety include (1) overlapping coverage for certain cornerstones, (2) limited risk coverage, and (3) difficulties in interpreting the risk significance of significant adverse trends that are detected.

In terms of risk coverage, work documented in NUREG-1753, "Risk-Based Performance Indicators: Results of Phase 1 Development," indicates that the ROP indicators "unplanned scrams" and "scrams with loss of normal heat removal" probably cover less than 20 percent of the total internal event core damage risk for the Initiating Events Cornerstone of Safety. (The other 80 percent of risk involves less frequent initiating events that cannot be monitored on a plant-specific basis over the limited, 3-year period covered by the ROP indicators.) This limited coverage of risk by the ROP performance indicators is supplemented by inspections.

Moreover, it can be difficult to determine whether an adverse trend is risk significant if one is detected. This is because not all scrams are equally serious in terms of risk. For example, an adverse trend in "automatic scrams" due to "general transients" might be offset by a favorable (decreasing frequency) trend in "scrams with loss of normal heat removal." The ITP has no established method for determining risk significance of broad categories such as "unplanned scrams," nor a mechanism for aggregating and interpreting offsetting trends at the Cornerstone of Safety level.

As a first step in enhancing the ITP to remedy the weaknesses discussed above, the Initiating Event Cornerstone of Safety was chosen as the area of focus. Work focused on development of performance indicators that did not overlap in coverage, significantly increased the risk coverage, and provided a mechanism for determining the risk significance of changes in performance, at both the individual initiating event level and at the integrated Cornerstone of Safety level. The process and results are documented in the following sections.

2 Enhancement Process for Initiating Events Cornerstone of Safety

To enhance the ITP coverage of the Initiating Events Cornerstone of Safety, a three-step process was used. The first step was to identify appropriate classes of initiating events. Then methods for trending and establishing performance-based prediction limits for these individual event classes were developed (Tier 1, performance-based monitoring of classes of initiating events). Finally, an integrated, risk-informed indicator was developed by combining the individual initiating event class information (Tier 2, risk-informed monitoring at the Cornerstone of Safety level). Figure A2-1 shows the ITP process with respect to the integrated initiating event indicator.




Figure A2-1 BRIIE and the ITP process

2.1 Identification of Risk-Significant Initiating Events

The initiating event study (NUREG/CR-5750, “Rates of Initiating Events at U.S. Nuclear Power Plants”) provides data for a large number of initiating event types for calendar year (CY) 1987 through CY 1995. (NRC is continually updating these data, but NUREGs are no longer being published. Instead, the results are posted on an internal NRC Web site with plans to post them on the NRC public Web site.) Initiating event types are defined in that study as unplanned reactor trips that occur while a plant is critical and at or above the point of adding heat. A subset of these events has been identified as being risk significant (NUREG-1753). The list of risk-significant initiating event types considered in the ITP consists of the following 10 initiating events applicable to PWRs and 9 applicable to BWRs:

General Transients	Loss of Heat Sink
Loss of Feedwater	Loss of Offsite Power
Loss of Vital AC Bus	Loss of Vital DC Bus
Stuck-Open SRV	Loss of Instrument Air
Small/Very Small LOCA	Steam Generator Tube Rupture (PWR only)

In general, these risk-significant initiating event types cover approximately 90% of the internal event core damage risk (excluding internal flooding) from the 103 operating commercial nuclear power plants in the U.S. Also, these initiating events do not overlap.

2.2 Performance Monitoring of Risk-Significant Initiating Event Classes (Tier 1)

The proposed Tier 1 activity involves trending risk-significant initiating events and monitoring yearly industry performance against prediction limits. To accomplish this, up-to-date baseline frequencies were established for each of the risk-significant initiating events. Then, given these baseline frequencies and estimated yearly industry total critical reactor years of operation, the ITP enhancement determined performance-based prediction limits. Data for these initiating events (numbers of event occurrences and corresponding reactor critical years) are already being collected and analyzed by the NRC on a continual basis, so no additional data collection is needed to support the Tier 1 activities.

The prediction limits are statistically determined and performance based. Both 95% and 99% limits have been estimated for illustrative purposes. An expert elicitation approach is proposed to select the appropriate limits for the Tier 1 activity.

As an example of the Tier 1 trending analysis, the historical performance of the PWR general transients is shown in Figure A2-2. Over the period FY 1988 through approximately FY 1997, industry performance improved considerably (the initiating event frequency dropped). However, over the period FY 1998 through FY 2001 (the period used for determining an up-to-date baseline frequency), the industry performance was essentially constant. Including the FY 2002 initiating event data in the Tier 1 trending analysis did not produce any increasing trends.




Figure A2-2 Estimated annual frequency of PWR general transient initiating event. The trend over the baseline period is not statistically significant (p-value = 0.625).

These ITP Tier 1 activities will help the NRC identify degrading industry performance as an adjunct to the plant-specific performance assessment performed as part of the ROP. Potential NRC responses if one or more of the prediction limits are reached or exceeded are outlined in Section 4 of this attachment. Also, example scenarios are presented in Section 4 for illustrative purposes. Tier 1 activities and results are not reported to the U.S. Congress, but they are used by the NRC as a diagnostic tool. The Tier 1 results will be placed on the NRC Web site for access by interested stakeholders. Therefore, the proposed Tier 1, performance-based monitoring of risk-significant initiating event types supports many uses of ITP results discussed in the main body of this paper.

2.3 Risk-Informed Monitoring of Initiating Events Cornerstone of Safety (Tier 2)

An integrated performance indicator is proposed for ITP Tier 2 coverage of the Initiating Events Cornerstone of Safety. It involves evaluating the risk significance of changes in industry initiating event class performance (the results of the Tier 1 activity). Risk significance is evaluated in terms of a measure related to core damage frequency (CDF) or to changes in the measure (related to Δ CDF). The indicator combines operating experience for risk-significant initiating event classes with associated internal event CDF-based importance information. The indicator is able to appropriately combine frequent and infrequent initiating event class frequencies with different risk measures (Birnbaum importances). This indicator is termed the Baseline Risk Index for Initiating Events, or BRIIE. The main use of the BRIIE would be to combine individual initiating event class performance changes into an integrated, risk-informed indicator at the Initiating Events Cornerstone of Safety level. The BRIIE would solve several deficiencies in the present ITP: no systematic and defined method for determining whether individual initiating event class performance changes or adverse trends are risk significant, no systematic and defined method for integrating individual initiating event class performance changes into an overall risk result at the Cornerstone of Safety level, and untimely risk-informed industry trend results. Results of the BRIIE would be reported to the U.S. Congress.

Several different quantification methods were considered for evaluating the BRIIE. One method related to CDF is the following:

$$BRIIE = \sum_{i=1}^m \bar{B}_i \lambda_{ic}^*$$

where

\bar{B}_i = industry - average Birnbaum for initiating event i (1)

λ_{ic}^* = common industry current frequency for initiating event i

Another formulation, related to changes in CDF (Δ CDF), is given by the following equation:

$$BRIIE = \sum_{i=1}^m \bar{B}_i (\lambda_{ic}^* - \lambda_{ib}),$$

where

\bar{B}_i = industry - average Birnbaum for initiating event i (2)

λ_{ic}^* = common industry current frequency for initiating event i

λ_{ib} = baseline frequency for initiating event i

BWRs and PWRs have different core damage frequencies, which depend to some extent on different initiating event types. The risk weights for various initiating events are also different for the two types of reactors. Therefore, BRIIE results are proposed for each reactor type. However, the two BRIIE results could be combined into a single index, if desired.

The BRIIE formulations in Equations 1 and 2 use industry-average (or PWR- or BWR-average) Birnbaum importance measures and combine the industry-wide data to generate the “common industry current frequency” for each initiating event type. Alternative formulations are possible using plant-specific Birnbaum importances and plant-specific initiating event data and then summing the individual plant results to obtain an industry result. Results using all of the various calculation methods indicated that the proposed formulations in Equations 1 and 2 provide the most BRIIE sensitivity.

BRIIE results, although representing industry-wide results, are presented as average results per plant. This is done because NRC and stakeholders are more familiar with results per plant than with integrated industry-wide impacts. If the PWR BRIIE result for a future year is calculated to be 1.0E-6/year (per PWR), then the PWR-wide impact is actually (1.0E-6/year/PWR)(69 PWRs) = 6.9E-5/year. Similarly, if the BWR BRIIE is 1.0E-6/year (per BWR), then the BWR-wide impact is actually (1.0E-6/year/BWR)(34 BWRs) = 3.4E-5/year. These industry-wide impacts should be kept in mind when establishing reporting thresholds for the BRIIE.

Simulations of expected future performance of the PWR and BWR BRIIEs were performed to understand the nature of the distribution and to obtain 95% and 99% prediction limits. Reporting thresholds for the two BRIIEs should be established considering the following information:

- (1) Uncertainty in the BRIIEs and the 95% and 99% prediction limits from simulations
- (2) Distribution of the Birnbaum importance measures for each initiating event class and understanding of the groups of plants that have large values for each class
- (3) Major contributors (i.e., dominant initiating event classes) to the BRIIEs
- (4) Sensitivity of BRIIEs to initiating event classes, especially those with lower frequencies
- (5) Other factors, such as the NRC safety goal policy and Regulatory Guide 1.174

An expert panel would be established to propose BRIIE threshold values that satisfy policy and operational needs and objectives.

3 BRIIE Historical Performance and Sensitivity

Historical performance of the BRIIE (Δ CDF basis) is shown in Figure A2-3 for FY 1997 through FY 2002. For all 6 years, the PWR BRIIE dominates the BWR BRIIE in terms of variance from a baseline Δ CDF of 0.0. This shows why separate BRIIEs are proposed for PWRs and BWRs. For FY 1999, the PWR BRIIE peak of approximately $1.1E-5$ /year (per plant) is driven by two occurrences of a loss of DC bus. This illustrates the sensitivity of the BRIIE to relatively infrequent but risk-important initiating event types.




Figure A2-3 PWR and BWR BRIIE historical performance

To further investigate the sensitivity of the BRIIE to changes in frequency of individual initiating event types, results were calculated assuming all initiating event types are occurring at baseline frequency except for one, which is occurring at the Tier 1 prediction limit (95% or 99%). Sensitivity studies show the following. The PWR BRIIE is most sensitive to the small loss-of-coolant accident (LOCA) and loss of DC bus initiator types. Loss of offsite power, steam generator tube rupture, and stuck-open safety/relief valve initiator types also can affect the PWR BRIIE. Sensitivity results for the BWR BRIIE are different, with the loss of offsite power initiator class significantly affecting the BRIIE. To a lesser degree, loss of DC bus and stuck-open safety/relief valve initiator classes can affect BWR BRIIE results.

4 Potential Responses to Tier 1 and Tier 2 Results

In this section we present two examples to show how the ITP might treat initiating event performance changes. For the first example, suppose we observe four events in 1 year that are classified as small/very small break LOCAs. Each event occurred in a separate plant. This initiating event is very rare. The 95% prediction limit is three events, and the 99% prediction

limit is four events. We have exceeded the 95% prediction limit and hit the 99% prediction limit. Because the number of actual events exceeds the prediction limit, this initiating event is a candidate for further investigation.

Because small LOCAs do not occur very often, NRC would probably look at each event in more detail after it occurred. Thus, NRC would have inspectors and staff reviewing each event. The ITP would look at these events to see if there were similarities among the events and to provide any lessons learned from this evaluation. These lessons would be communicated to the industry via some type of generic communication. Further regulatory action would probably not be necessary since the NRC investigated each event in detail.

Although BRIIE calculations have not been performed for this hypothetical case, the sensitivity study results (assuming the other initiating event types are at baseline performance) indicate that the PWR BRIIE would be approximately $9E-5$ /year (per PWR). This is significantly above the prediction limits of $2.2E-5$ /year (95%) and $3.5E-5$ /year (99%). However, an expert panel will decide what the actual thresholds for reporting to Congress will be. If the threshold were chosen to be the 99% prediction limit, then the report to Congress would identify the Initiating Events Cornerstone of Safety as a risk-significant departure from expected baseline performance and safety.

As another example, suppose that we see a marked increase in the number of general transients at a certain reactor type (PWR or BWR). We observe 74 general transients for the year. This exceeds both the 95% and 99% prediction limits, which are 61 and 67 respectively at the Tier 1 level. However, no unit has exceeded the white/green ROP threshold for scrams. The ITP investigates this situation and finds that the majority of the scrams occurred at plants of a specific reactor type. Further investigation reveals that a given device has been the cause of the majority of the general transients. This information could be communicated to industry via some type of generic communication.

In terms of reporting to Congress, at the Tier 2 level the BRIIE would probably indicate that this increase in general transients is not risk significant and would not exceed the threshold.

Action Matrix Summary

The NRC provided oversight of 103 operating power reactors using the Reactor Oversight Process (ROP). On average, approximately 75% of the plants were listed in the Licensee Response column of the ROP Action Matrix, which corresponds to the baseline level of NRC oversight. The chart below shows trends in the numbers of plants that are listed in the Regulatory Response, Degraded Cornerstone, Multiple/Repetitive Degraded Cornerstone, and Unacceptable Performance columns of the Action Matrix, which correspond to increasing levels of regulatory engagement with the licensee, plus the number of plants in the MC 0350 process.




Figure A3-1