

JUN 09 2006

L-PI-06-046 10 CFR 50.73

U S Nuclear Regulatory Commission ATTN: Document Control Desk Washington, DC 20555-0001

Prairie Island Nuclear Generating Plant Unit 1 Docket 50-282 License No. DPR-42

<u>Cancellation of Licensee Event Report (LER) 1-05-01, Discovery of Single Failure Vulnerability of Unit 1 Safeguards Buses</u>

Reference: 1) LER 1-05-01, April 4, 2005, (ML050960556).

Reference 1 transmitted the LER for a condition discovered in the Prairie Island Unit 1 safeguards 4 kV buses. At the time the LER was submitted, Nuclear Management Company, LLC (NMC) postulated that the Unit 1 safeguards bus 15 and bus 16 did have a single failure vulnerability due to current transformer (CT) circuits for the source breakers for these buses from the CT11 (Cooling Tower 11 transformer) source. The CT circuits are tied together with a secondary CT on the common wires which feeds metering equipment. Thus, because NMC believed the condition violated the single failure criterion for redundant components, the condition was reported pursuant to 10 CFR 50.73(a)(2)(ii)(B).

Subsequent to the transmittal of the LER, NMC conducted additional analysis that has concluded that a common mode failure resulting in a simultaneous lockout of both Bus 15 and Bus 16 due to the common metering circuit was not a credible event in the asfound condition. To demonstrate that a dual lockout of bus 15 and bus 16 is not credible under hot short conditions, the analysis showed that the required magnitude of the fire induced fault is much greater than the available fault current in any of the associated circuits. To demonstrate that a dual bus lockout due to an open circuit under non-fire induced conditions is not credible, the analysis showed that the resultant imbalance current will be less than the trip setpoint of the affected relays.

Therefore, because subsequent analysis has concluded that bus 15 and bus 16 were not vulnerable to a potential single failure, the as-found condition is no longer reportable and NMC hereby cancels LER 1-05-01. Notwithstanding cancellation of the LER, NMC

will still pursue corrective actions to address this condition via the site corrective action program.

## **Summary of Commitments**

This letter contains no new commitments and no revisions to existing commitments.

Thomas J. Palmisano

Site Vice President, Prairie Island Nuclear Generating Plant

Nuclear Management Company, LLC

cc: Administrator, Region III, USNRC

Project Manager, Prairie Island, USNRC Resident Inspector, Prairie Island, USNRC