

Duke Power Oconee Unit 3R EOC22 ECT Examination Status Report



SCOPE DESCRIPTION			S/G A				S/G B			
Leg	Exam Description	Extents	Acquired	Analyzed	Scope	% Completed	Acquired	Analyzed	Scope	% Completed
Both	100% Bobbin	UTE-LTE	14,716	13,841	15,631	88.5%	13,722	12,811	15,631	82.0%
Both	Special Interest Array Bobbin	Various	N/A	1,823	1,852	98.4%	N/A	712	717	99.3%
Both	Special Interest MULC Bobbin	Various	0	0	9	0.0%	0	0	0	0.0%
Tubes with Wear Indications			1477				567			
Tubes with Wear Indications by Support: NOTE: Some tubes may have multiple indications at different supports.			015	2	007	75	015	0	007	55
			014	130	006	34	014	41	006	8
			013	190	005	8	013	63	005	8
			012	533	004	9	012	104	004	21
			011	396	003	7	011	82	003	17
			010	166	002	14	010	134	002	15
			009	50	001	14	009	42	001	11
			008	180			008	69		
Tubes with Wear Indications by Size			0 - 9%	1289			0 - 9%	496		
			10 - 19%	291			10 - 19%	107		
			20 - 29%	2			20 - 29%	1		
			30 - 39%	0			30 - 39%	0		
			>=40%	0			>=40%	0		