

ENCLOSURE 1

REVISED PAGE OF RENEWED FACILITY OPERATING LICENSE NO. DPR-31

REVISED PAGE OF RENEWED FACILITY OPERATING LICENSE NO. DPR-41

TURKEY POINT NUCLEAR GENERATING UNITS 3 AND 4

DOCKET NOS. 50-250 AND 50-251

Replace the following pages of the Facility Operating Licenses. The revised pages identified by the date of the letter issuing these pages and contain marginal lines indicating the areas of change.

REMOVE

License DPR-31
Page 5

License DPR-41
Page 5

INSERT PAGE

License DPR-31
Page 5

License DPR-41
Page 5

G. Mitigation Strategy License Condition

Develop and maintain strategies for addressing large fires and explosions and that include the following key areas:

- (a) Fire fighting response strategy with the following elements:
 - 1. Pre-defined coordinated fire response strategy and guidance
 - 2. Assessment of mutual aid fire fighting assets
 - 3. Designated staging areas for equipment and materials
 - 4. Command and control
 - 5. Training of response personnel

 - (b) Operations to mitigate fuel damage considering the following:
 - 1. Protection and use of personnel assets
 - 2. Communications
 - 3. Minimizing fire spread
 - 4. Procedures for implementing integrated fire response strategy
 - 5. Identification of readily-available pre-staged equipment
 - 6. Training on integrated fire response strategy
 - 7. Spent fuel pool mitigation measures

 - (c) Actions to minimize release to include consideration of:
 - 1. Water spray scrubbing
 - 2. Dose to onsite responders
4. This renewed license is effective as of the date of issuance, and shall expire at midnight July 19, 2032.

FOR THE NUCLEAR REGULATORY COMMISSION

Signed by
Samuel J. Collins, Director
Office of Nuclear Reactor Regulation

Attachments:
Appendix A – Technical Specifications for Unit 3
Appendix B – Environmental Protection Plan

Date of Issuance: June 6, 2002

G. Mitigation Strategy License Condition

Develop and maintain strategies for addressing large fires and explosions and that include the following key areas:

- (a) Fire fighting response strategy with the following elements:
 1. Pre-defined coordinated fire response strategy and guidance
 2. Assessment of mutual aid fire fighting assets
 3. Designated staging areas for equipment and materials
 4. Command and control
 5. Training of response personnel

- (b) Operations to mitigate fuel damage considering the following:
 1. Protection and use of personnel assets
 2. Communications
 3. Minimizing fire spread
 4. Procedures for implementing integrated fire response strategy
 5. Identification of readily-available pre-staged equipment
 6. Training on integrated fire response strategy
 7. Spent fuel pool mitigation measures

- (c) Actions to minimize release to include consideration of:
 1. Water spray scrubbing
 2. Dose to onsite responders

4. This renewed license is effective as of the date of issuance, and shall expire at midnight April 10, 2033.

FOR THE NUCLEAR REGULATORY COMMISSION

Signed by
 Samuel J. Collins, Director
 Office of Nuclear Reactor Regulation

Attachments:

Appendix A – Technical Specifications for Unit 4
 Appendix B – Environmental Protection Plan

Date of Issuance: June 6, 2002