

September 7, 2007

Mr. Thomas D. Walt, Vice President
H. B. Robinson Steam Electric Plant,
Unit No. 2
Carolina Power & Light Company
3581 West Entrance Road
Hartsville, South Carolina 29550-0790

SUBJECT: H. B. ROBINSON STEAM ELECTRIC PLANT, UNIT NO. 2 - RESPONSE TO
GENERIC LETTER 2006-02, "GRID RELIABILITY AND THE IMPACT ON
PLANT RISK AND THE OPERABILITY OF OFFSITE POWER"
(TAC NO. MD1025)

Dear Mr. Walt:

On February 1, 2006, the U.S. Nuclear Regulatory Commission (NRC) issued Generic Letter (GL) 2006-02, "Grid Reliability and the Impact on Plant Risk and the Operability of Offsite Power" (Agencywide Documents Access and Management System (ADAMS) Accession No. ML060180352), to all holders of operating licenses for nuclear power reactors except those who have permanently ceased operations and have certified that fuel has been removed from the reactor vessel.

GL 2006-02 notified licensees of the NRC staff's need for information in four areas as follows:

- (1) use of protocols between the nuclear power plant (NPP) and the transmission system operator (TSO), independent system operator (ISO), or reliability coordinator/authority (RC/RA) and the use of transmission load flow analysis tools (analysis tools) by TSOs to assist NPPs in monitoring grid conditions to determine the operability of offsite power systems under plant technical specifications (TSs). (The TSO, ISO, or RC/RA is responsible for preserving the reliability of the local transmission system. In this GL the term TSO is used to denote these entities);
- (2) use of NPP/TSO protocols and analysis tools by TSOs to assist NPPs in monitoring grid conditions for consideration in maintenance risk assessments;
- (3) offsite power restoration procedures in accordance with Section 2 of NRC Regulatory Guide (RG) 1.155, "Station Blackout;" and
- (4) losses of offsite power caused by grid failures at a frequency equal to or greater than once in 20 site-years in accordance with RG 1.155.

T. Walt

- 2 -

Subsequent to the GL, the NRC issued a request for additional information (RAI), (ADAMS Accession No. ML063380308) regarding the resolution of GL 2006-02 to 63 of 65 holders of operating licenses for nuclear power reactors. The RAI requested licensees respond to questions in the following areas:

- (1) Switchyard Minimum Voltage
- (2) Loss of Real-Time Contingency Analysis (RTCA) Capability
- (3) Verification of RTCA Predicted Post-Trip Voltage
- (4) Identification of Applicable Single Contingencies
- (5) Seasonal Variation in Grid Stress (reliability and Loss-of-offsite power (LOOP) Probability
- (6) Interface With Transmission System Operator During Extended Plant Maintenance

By letters dated April 3, 2006 (ADAMS Accession No. ML060950359), and January 31, 2007 (ADAMS Accession No. ML070330593), you responded to the information request of GL 2006-02 and the subsequent RAI. Based on the information you provided, the staff has concluded that compliance is being maintained with NRC regulatory requirements governing electric power sources and associated personnel training, and considers your response to GL 2006-02 complete.

If you have any questions, please contact me 301-415-3178.

Sincerely,

/RA/

Marlayna Vaaler, Project Manager
Plant Licensing Branch II-2
Division of Operating Reactor Licensing
Office of Nuclear Reactor Regulation

Docket Nos. 50-261

cc: See next page

Subsequent to the GL, the NRC issued a request for additional information (RAI), (ADAMS Accession No. ML063380308) regarding the resolution of GL 2006-02 to 63 of 65 holders of operating licenses for nuclear power reactors. The RAI requested licensees respond to questions in the following areas:

- (1) Switchyard Minimum Voltage
- (2) Loss of Real-Time Contingency Analysis (RTCA) Capability
- (3) Verification of RTCA Predicted Post-Trip Voltage
- (4) Identification of Applicable Single Contingencies
- (5) Seasonal Variation in Grid Stress (reliability and Loss-of-offsite power (LOOP) Probability
- (6) Interface With Transmission System Operator During Extended Plant Maintenance

By letters dated April 3, 2006 (ADAMS Accession No. ML060950359), and January 31, 2007 (ADAMS Accession No. ML070330593), you responded to the information request of GL 2006-02 and the subsequent RAI. Based on the information you provided, the staff has concluded that compliance is being maintained with NRC regulatory requirements governing electric power sources and associated personnel training, and considers your response to GL 2006-02 complete.

If you have any questions, please contact me 301-415-3178.

Sincerely,

/RA/

Marlayna Vaaler, Project Manager
Plant Licensing Branch II-2
Division of Operating Reactor Licensing
Office of Nuclear Reactor Regulation

Distribution:

Public	RidsNrrDorlLpl2-2(TBoyce)
LPL2-2 R/F	RidsNrrPMMVaaler (hard copy)
JRobinson, NRR	RidsNrrDprPgcb
RidsAcrsAcnwMailCenter	RidsNrrLACSola (hard copy)
RidsOgcRp	RidsRgn2MailCenter(JMoorman)

Accession Number: ML072400351

NRR-106

OFFICE	LPL2-2/PM	LPL2-2/SR PM	LPL2-2/LA	EEEE/BC	LPL2-2/BC
NAME	MVaaler		CSola	GWilson	TBoyce
DATE	08/30/07	08/30/07	08/30/07	09/07/07	09/07/07

OFFICIAL RECORD COPY

H. B. Robinson Steam Electric Plant, Unit No. 2

cc:

David T. Conley
Associate General Counsel II - Legal
Department
Progress Energy Service Company, LLC
Post Office Box 1551
Raleigh, North Carolina 27602-1551

Ms. Margaret A. Force
Assistant Attorney General
State of North Carolina
Post Office Box 629
Raleigh, North Carolina 27602

U. S. Nuclear Regulatory Commission
Resident Inspector's Office
H. B. Robinson Steam Electric Plant
2112 Old Camden Road
Hartsville, South Carolina 29550

Mr. Ernest J. Kapopoulos, Jr.
Plant General Manager
H. B. Robinson Steam Electric Plant,
Unit No. 2
Carolina Power & Light Company
3581 West Entrance Road
Hartsville, South Carolina 29550

Director of Site Operations
H. B. Robinson Steam Electric Plant,
Unit No. 2
Carolina Power & Light Company
3581 West Entrance Road
Hartsville, South Carolina 29550

Public Service Commission
State of South Carolina
Post Office Drawer 11649
Columbia, South Carolina 29211

Ms. J. F. Lucas
Manager - Support Services - Nuclear
H. B. Robinson Steam Electric Plant,
Unit No. 2
Carolina Power & Light Company
3581 West Entrance Road
Hartsville, South Carolina 29550

Mr. C. T. Baucom
Supervisor, Licensing/Regulatory Programs
H. B. Robinson Steam Electric Plant,
Unit No. 2
Carolina Power & Light Company
3581 West Entrance Road
Hartsville, South Carolina 29550

Ms. Beverly Hall, Section Chief
N.C. Department of Environment
and Natural Resources
Division of Radiation Protection
3825 Barrett Dr.
Raleigh, North Carolina 27609-7721

Mr. Robert P. Gruber
Executive Director
Public Staff - NCUC
4326 Mail Service Center
Raleigh, North Carolina 27699-4326

Mr. Henry H. Porter, Assistant Director
South Carolina Department of Health
Bureau of Land & Waste Management
2600 Bull Street
Columbia, South Carolina 29201

Mr. J. Paul Fulford
Manager, Performance Evaluation and
Regulatory Affairs PEB 5
Carolina Power & Light Company
Post Office Box 1551
Raleigh, North Carolina 27602-1551

Mr. John H. O'Neill, Jr.
Pillsbury Winthrop Shaw Pittman, LLP
2300 N Street NW.
Washington, DC 20037-1128