
WCAP 16406-P Revision 1

Evaluation of Downstream Sump Debris Effects in Support of GSI-191

8/24/2007

Tim Andreychek
Westinghouse Electric Co., LLC
412-374-6246
andreyts@westinghouse.com



Status of WCAP-16406-P

- NRC RAIs received
 - Regular communication held to address issues
 - Asymmetric wear of pump wear rings
 - Pump wear description was rewritten to incorporate Archard wear model
 - FlowServe work to support Rotor Dynamics being completed
 - All known RAIs addressed
 - Amended WCAP and full RAI responses scheduled to be submitted to NRC by no later than September 7, 2007

Summary

- Web cast to be scheduled to discuss Rev 1 in middle of September 2007
 - Focus on pump wear evaluations
- Amended WCAP to be submitted no later than September 7, 2007