



Cense Renewal Drawing Legend

rary drawings are numbered by unit, system
a drawing identifier. The format is
[unit]-[system number]-[drawing identifier].

ings are highlighted to depict the
tional boundaries of fluid or gas-retaining
ponents needed to support intended
tions. Structural and electrical
ponents are not highlighted on these
ings.

Red highlighting shows components that are credited by the CLB for performing an intended function as defined in 10 CFR 54.4(a)(1), (a)(2) or (a)(3).

Blue highlighting shows components that are in scope for 10 CFR 54.4(a)(2) spatial concerns (e.g., leakage, spray, pipe whip, jet impingement), but are not credited by the CLB.

Bright green highlighting shows components that are in scope because they provide mechanical support to safety-related components per 10 CFR 54.4(a)(2), and do not meet one of the other scoping criteria.

Black lines (no highlighting) shows components that are not in scope for License Renewal.

Where portions of a system that are in scope for (a)(2) transition to a non-safety building, the blue highlighting stops and a dark green lines indicates that building boundary

s identify system scoping boundaries.
s with text on both sides indicate a
position between systems, where both sides
ain in scope equipment. The format is
[system number]

One-sided flags indicate the limit of a system
The equipment beyond the flag is not in scope
and does not require equivalent anchor
testing.

agonal boxes identify safety/non-safety positions. A number or letter will identify a relevant anchor treatment. A number responds to a "SR/NSR Boundary Note" located at the bottom of a drawing.

Callout boxes show the limits of
valent anchors and have letters
responding to the letters in the safety/non-
transition boxes.

ALL COMPONENTS ON THIS DRAWING
ARE PRECEDED BY "2HVB" UNLESS
OTHERWISE INDICATED.

SR/NSR Boundary Notes:

Depicted LR Systems:

LR Drawing 2-41A-2 Rev. 3
Hot Water Heating System (HVH)

FENOC
FirstEnergy Nuclear Operating Company