

**From:** Yoira Diaz Sanabria  
**To:** Kaihwa Hsu  
**Date:** 07/26/2007 1:46:19 PM  
**Subject:** Revised AMR tables

Robert,

I talked to the applicant and everything that is in red and underlined is new or added to the application. They are sending a working version (see attached) of the response to expedite our review, the formal letter will come tomorrow or Monday. I'm also going to confirm this facts with them. The front portion of the response corresponds to Ron Young (scoping), as a result of his request the applicant had to revised the AMR tables and add more mechanical systems components.

What I need from you:

1. Please check the attachment and let me know the extent of the work for these new AMR tables
2. Promptly notification of the reviewers responsible for Section 3.3.2
3. Identify if any items do not correspond to the audit review.
4. Notify me if we need to address any items with the applicant
5. Notify if we might have potential open items

I will appreciate your prompt response in this matter. Just a friendly reminder the **SER due date is Wednesday, August 1st** (next week), therefore your prompt action is critical!

Thanks in advance,  
Yoira

**CC:** bhr@nrc.gov; Jonathan Rowley; Rajender Auluck; Ron Young

**Mail Envelope Properties** (46A8DDE0.91A : 20 : 35820)

**Subject:** Revised AMR tables  
**Creation Date** 07/26/2007 1:46:08 PM  
**From:** Yoira Diaz Sanabria

**Created By:** YKS@nrc.gov

**Recipients**

nrc.gov  
OWGWPO01.HQGWDO01  
RCA CC (Rajender Auluck)

nrc.gov  
OWGWPO04.HQGWDO01  
KRH2 (Kaihwa Hsu)

nrc.gov  
TWGWPO03.HQGWDO01  
BHR CC (Billy Rogers)  
JGR CC (Jonathan Rowley)

nrc.gov  
TWGWPO04.HQGWDO01  
RMY CC (Ron Young)

**Post Office**

OWGWPO01.HQGWDO01  
OWGWPO04.HQGWDO01  
TWGWPO03.HQGWDO01  
TWGWPO04.HQGWDO01

**Route**

nrc.gov  
nrc.gov  
nrc.gov  
nrc.gov

Files	Size	Date & Time
MESSAGE	1965	07/26/2007 1:46:08 PM
BVY 07-054 Att 2 - 54.4(a)(2) Scoping_2.doc		1822208 07/26/2007 1:31:40
PM		

**Options**

**Expiration Date:** None  
**Priority:** Standard  
**ReplyRequested:** No  
**Return Notification:**  
Send Notification when Opened  
Send Notification when Deleted

**Concealed Subject:** No  
**Security:** Standard

**Junk Mail Handling Evaluation Results**

Message is not eligible for Junk Mail handling  
Message is from an internal sender

**Junk Mail settings when this message was delivered**

Junk Mail handling disabled by User  
Junk Mail handling disabled by Administrator  
Junk List is not enabled  
Junk Mail using personal address books is not enabled  
Block List is not enabled

**VERMONT YANKEE NUCLEAR POWER STATION  
LICENSE RENEWAL APPLICATION SUPPLEMENT  
ATTACHMENT 2**

**License Renewal Application Changes**

**VERMONT YANKEE NUCLEAR POWER STATION  
LICENSE RENEWAL APPLICATION SUPPLEMENT  
ATTACHMENT 2**

The following information is provided as a supplement to the previously submitted License Renewal Application. The need for this information was identified as a Safety Evaluation Report (SER) Confirmatory Item.

Note: Insertions = underlined, deletions = strike-through

**Nonsafety-Related Components Affecting Safety-Related Systems  
Subject to Aging Management Review**

The following is provided to clarify the systems which are included in the scope of license renewal.

- Table 2.2-1a is revised to include the following new information :

**Table 2.2-1a  
Mechanical Systems within the Scope of License Renewal**

<b>System Code</b>	<b>System Code Name</b>	<b>LRA Section</b>
<u>103</u>	<u>HD &amp; HV Instruments</u>	<u>Section 2.3.3.13, Miscellaneous Systems in Scope for (a)(2)</u>
<u>AE</u>	<u>Air Evacuation</u>	<u>Section 2.3.3.13, Miscellaneous Systems in Scope for (a)(2)</u>
<u>BLD</u>	<u>Building (drainage system components)</u>	<u>Section 2.3.3.13, Miscellaneous Systems in Scope for (a)(2)</u>
<u>CWP</u>	<u>Circulating Water Priming</u>	<u>Section 2.3.3.13, Miscellaneous Systems in Scope for (a)(2)</u>
<u>ES</u>	<u>Extraction Steam</u>	<u>Section 2.3.3.13, Miscellaneous Systems in Scope for (a)(2)</u>
<u>HD</u>	<u>Heater Drain</u>	<u>Section 2.3.3.13, Miscellaneous Systems in Scope for (a)(2)</u>
<u>HV</u>	<u>Heater Vent</u>	<u>Section 2.3.3.13, Miscellaneous Systems in Scope for (a)(2)</u>
<u>HWC</u>	<u>Hydrogen Water Chemistry</u>	<u>Section 2.3.3.13, Miscellaneous Systems in Scope for (a)(2)</u>
<u>MUD</u>	<u>Make-up Demineralizer</u>	<u>Section 2.3.3.13, Miscellaneous Systems in Scope for (a)(2)</u>

**VERMONT YANKEE NUCLEAR POWER STATION  
LICENSE RENEWAL APPLICATION SUPPLEMENT  
ATTACHMENT 2**

<u>SO</u>	<u>Seal Oil</u>	<u>Section 2.3.3.13, Miscellaneous Systems in Scope for (a)(2)</u>
<u>TBCCW</u>	<u>Turbine Building Closed Cooling Water</u>	<u>Section 2.3.3.13, Miscellaneous Systems in Scope for (a)(2)</u>
<u>TG</u>	<u>Main Turbine Generator</u>	<u>Section 2.3.3.13, Miscellaneous Systems in Scope for (a)(2)</u>
<u>TLO</u>	<u>Turbine Lube Oil</u>	<u>Section 2.3.3.13, Miscellaneous Systems in Scope for (a)(2)</u>

- The mechanical systems added to Table 2.2-1a (above) are hereby removed from Table 2.2-2 "Mechanical Systems Not within the Scope of License Renewal"

**VERMONT YANKEE NUCLEAR POWER STATION  
LICENSE RENEWAL APPLICATION SUPPLEMENT  
ATTACHMENT 2**

The following is provided to clarify the description of systems which are included in the scope of license renewal.

- Table 2.3.3.13-A is revised to include the following new information:

**Table 2.3.3.13-A  
Systems within the Scope of License Renewal based on the Potential for  
Physical Interaction with Safety-Related Components (10 CFR 54.4(a)(2))**

<b>System Code</b>	<b>System Name</b>	<b>Section with System Description</b>
<u>103</u>	<u>HD &amp; HV Instruments</u>	Section 2.3.3.13, Miscellaneous Systems in Scope for (a)(2)
<u>AE</u>	<u>Air Evacuation</u>	Section 2.3.3.13, Miscellaneous Systems in Scope for (a)(2)
<u>AS</u>	<u>Auxiliary Steam</u>	Section 2.3.4.1, Auxiliary Steam
<u>BLD</u>	<u>Building (drainage system components)</u>	Section 2.3.3.13, Miscellaneous Systems in Scope for (a)(2)
<u>CWP</u>	<u>Circulating Water Priming</u>	Section 2.3.3.13, Miscellaneous Systems in Scope for (a)(2)
<u>ES</u>	<u>Extraction Steam</u>	Section 2.3.3.13, Miscellaneous Systems in Scope for (a)(2)
<u>HD</u>	<u>Heater Drain</u>	Section 2.3.3.13, Miscellaneous Systems in Scope for (a)(2)
<u>HV</u>	<u>Heater Vent</u>	Section 2.3.3.13, Miscellaneous Systems in Scope for (a)(2)
<u>HWC</u>	<u>Hydrogen Water Chemistry</u>	Section 2.3.3.13, Miscellaneous Systems in Scope for (a)(2)
<u>MS</u>	<u>Main Steam</u>	Section 2.3.4.3, Main Steam
<u>MUD</u>	<u>Make-up Demineralizer</u>	Section 2.3.3.13, Miscellaneous Systems in Scope for (a)(2)
<u>SA</u>	<u>Service Air</u>	Section 2.3.3.7, Instrument Air

**VERMONT YANKEE NUCLEAR POWER STATION  
LICENSE RENEWAL APPLICATION SUPPLEMENT  
ATTACHMENT 2**

<u>SO</u>	<u>Seal Oil</u>	Section 2.3.3.13, Miscellaneous Systems in Scope for (a)(2)
<u>TBCCW</u>	<u>Turbine Building Closed Cooling Water</u>	Section 2.3.3.13, Miscellaneous Systems in Scope for (a)(2)
<u>TG</u>	<u>Main Turbine Generator</u>	Section 2.3.3.13, Miscellaneous Systems in Scope for (a)(2)
<u>TLO</u>	<u>Turbine Lube Oil</u>	Section 2.3.3.13, Miscellaneous Systems in Scope for (a)(2)

- LRA Section 2.3.3.13.2 is revised to add descriptions of systems newly added to the scope of license renewal as follows.

HD & HV Instruments

The purpose of the 103 system is to provide indication, alarm, and control functions for associated systems (heater drains and heater vents).

Air Evacuation

The purpose of the AE system is to evacuate gases from the main turbine and main condenser during startup and maintain the system free of noncondensable gases during operation.

Building (drainage system components)

The BLD system includes floor drains and the site sewers. This system classification also designates buildings and structures which are evaluated in Section 2.4 of this LRA..

Circulating Water Priming

The purpose of the CWP system is to provide for evacuation of the discharge side of the main condenser.

Extraction Steam

The purpose of the ES system is to supply steam to the shell side of various feedwater heaters for condensate and feedwater heating.

Heater Drain



**VERMONT YANKEE NUCLEAR POWER STATION  
LICENSE RENEWAL APPLICATION SUPPLEMENT  
ATTACHMENT 2**

The purpose of the HD system is to provide proper level and control for the moisture separator and feedwater heaters by providing drain capability to the main condenser.

Heater Vent

The purpose of the HV system is to provide for venting of non-condensable gases back to the main condenser.

Hydrogen Water Chemistry

The purpose of the HWC system is to mitigate the chemical conditions in the reactor that allow IGSCC in the recirculation piping and reactor vessel internals. The HWC system injects hydrogen into the reactor feedwater at the suction of the feedwater pumps.

Make-up Demineralizer

The purpose of the MUD system is to provide a supply of treated water to the DW system that may be used as makeup for the station and reactor cycles.

Seal Oil

The purpose of the SO system is to provide shaft sealing for the main generator.

Turbine Building Closed Cooling Water

The purpose of the TBCCW system is to supply demineralized water to cool various nonsafety-related auxiliary equipment located in the turbine building in support of power generation

Main Turbine Generator

The purpose of the TG system is to convert the thermodynamic energy of steam into a reliable source of electrical energy for use on the transmission network and the station auxiliary busses.

Turbine Lube Oil

The purpose of the TLO system is to provide lube oil for lubrication of the main turbine.

**VERMONT YANKEE NUCLEAR POWER STATION  
LICENSE RENEWAL APPLICATION SUPPLEMENT  
ATTACHMENT 2**

The following is provided to clarify the description of components subject to aging management review which are to be included in aging management programs during the period of extended operation.

- Table 2.3.3.13-B is revised to include the following new information:

**Table 2.3.3.13-B  
Description of Nonsafety-Related System Components Subject to Aging Management  
Review Based on 10 CFR 54.4(a)(2) for Physical Interactions**

System Code	Nonsafety-Related Components Subject to AMR
<u>103</u>	<u>Portion of the system in the turbine building</u>
<u>AE</u>	<u>Portion of the system in the turbine building</u>
AOG	Portion of the system <u>inside</u> <del>associated with the plant stack loop seal structure</del>
<u>AS</u>	<u>Portion of the system in the turbine building</u>
<u>BLD</u>	<u>The portion of the system in the reactor building and the turbine building</u>
C	Portion of the system <del>at the ECCS keep full station in the turbine building, as well as the area on elevation 252 in the turbine building where service water piping runs along the wall.</del> Components outside the safety class pressure boundary, yet relied upon to provide structural/seismic support for the pressure boundary.
CD	<u>Portion of the system in the turbine building.</u> Components outside the safety class pressure boundary, yet relied upon to provide structural/seismic support for the pressure boundary.
CST	Portion of the system in the CST valve and instrument enclosure, the primary containment building, <del>and the reactor building, and the turbine building.</del> Components outside the safety class pressure boundary, yet relied upon to provide structural/seismic support for the pressure boundary.

**VERMONT YANKEE NUCLEAR POWER STATION  
LICENSE RENEWAL APPLICATION SUPPLEMENT  
ATTACHMENT 2**

CW	Portion of the system in cooling tower #2 cell 1 <u>and the turbine building.</u>
<u>CWP</u>	<u>Portion of the system in the turbine building</u>
DG	Portion of the system <del>in the diesel generator rooms</del> in the turbine building Components outside the safety class pressure boundary, yet relied upon to provide structural/seismic support for the pressure boundary.
DW	Portion of the system in the control building, the reactor building, and <del>at the diesel generator rooms</del> in the turbine building and in the CST valve and instrument enclosure. Components outside the safety class pressure boundary, yet relied upon to provide structural/seismic support for the pressure boundary.
<u>ES</u>	<u>Portion of the system in the turbine building</u>
FDW	Portion of the system in the reactor building and in primary containment <u>and the turbine building</u>
FO	Portion of the system in the fuel oil transfer pump house <u>and the turbine building.</u> Components outside the safety class pressure boundary, yet relied upon to provide structural/seismic support for the pressure boundary.
FP	Portion of the system in cooling tower #2 cell 1 and the reactor building, <u>the turbine building, and the service water pump area of the intake structure.</u> Components outside the safety class pressure boundary, yet relied upon to provide structural/seismic support for the pressure boundary.
HB	Portion of the system in the CST valve and instrument enclosure, the control building, the reactor building, and <del>at the diesel generator rooms</del> in the turbine building Components outside the safety class pressure boundary yet relied upon to provide structural/seismic support for the pressure boundary.
<u>HD</u>	<u>Portion of the system in the turbine building</u>

**VERMONT YANKEE NUCLEAR POWER STATION  
LICENSE RENEWAL APPLICATION SUPPLEMENT  
ATTACHMENT 2**

<u>HV</u>	<u>Portion of the system in the turbine building</u>
HVAC	Portion of the system in the reactor building <u>and the turbine building</u> . Components outside the safety class pressure boundary yet relied upon to provide structural/seismic support for the pressure boundary.
<u>HWC</u>	<u>Portion of the system in the turbine building</u>
IA	The portion of the system in the reactor building <u>and the turbine building</u> that requires aging management review due to potential spatial interaction are <del>the cooling and lubrication subcomponents for the containment air compressor (C-2-1A) and its precooler and aftercooler, as well as</del> the air dryer towers (tanks), drain piping, valves, and traps associated with the <u>instrument air dryers (D-1-1A and D-1-1B)</u> and the containment air dryer (D-2-1A), as well as the drain piping, valves, and traps associated with the air receiver tank and knock-out drum (TK-55-1A and TK-154-1A). Components outside the safety class pressure boundary yet relied upon to provide structural/seismic support for the pressure boundary.
<u>MS</u>	<u>Portion of the system in the turbine building</u>
<u>MUD</u>	<u>Portion of the system in the turbine building</u>
PASS	Portion of the system in the reactor building <u>and the turbine building</u> . Components outside the safety class pressure boundary, yet relied upon to provide structural/seismic support for the pressure boundary.
PW	Portion of the system in the " <del>A</del> " <del>diesel generator room in the</del> turbine building
RDW	Portion of the system in the CST valve and instrument enclosure, service water pump area of the intake structure, plant stack, primary containment building, and reactor building <u>and turbine building</u> . Components outside the safety class pressure boundary, yet relied upon to provide structural/seismic support for the pressure boundary.
RHRSW	Portion of the system in the reactor building <u>and the turbine building</u> . Components outside the safety class pressure boundary, yet relied upon to provide structural/seismic support for the pressure boundary.

**VERMONT YANKEE NUCLEAR POWER STATION  
LICENSE RENEWAL APPLICATION SUPPLEMENT  
ATTACHMENT 2**

<u>SA</u>	<p><u>The portion of the system in the turbine building that requires aging management review due to potential spatial interaction includes the drain piping, valves, and traps associated with the air receiver tanks (TK-5-1A and TK-5-1B).</u></p> <p><u>Components outside the safety class pressure boundary, yet relied upon to provide structural/seismic support for the pressure boundary.</u></p>
<u>SC</u>	<p><u>Portion of the system in the turbine building</u></p> <p>Components outside the safety class pressure boundary, yet relied upon to provide structural/seismic support for the pressure boundary.</p>
<u>SO</u>	<u>Portion of the system in the turbine building</u>
<u>SPL</u>	<p>Portion of the system in the reactor building, <u>turbine building</u>, and plant stack.</p> <p>Components outside the safety class pressure boundary, yet relied upon to provide structural/seismic support for the pressure boundary.</p>
<u>SW</u>	<p>Portion of the system in the service water pump area of the intake structure and the reactor building <u>and the turbine building.</u></p> <p>Components outside the safety class pressure boundary, yet relied upon to provide structural/seismic support for the pressure boundary.</p>
<u>TBCCW</u>	<u>Portion of the system in the turbine building</u>
<u>TG</u>	<u>Portion of the system in the turbine building</u>
<u>TLO</u>	<u>Portion of the system in the turbine building</u>

**VERMONT YANKEE NUCLEAR POWER STATION  
LICENSE RENEWAL APPLICATION SUPPLEMENT  
ATTACHMENT 2**

The following is provided to clarify the description of components subject to aging management review which are to be included in aging management programs during the period of extended operation.

- LRA Section 2.3.3 is revised to add a new Table 2.3.3-13-43, HD & HV Instruments (103) System, Nonsafety-Related Components Affecting Safety-Related Systems-Components Subject to Aging Management Review, as follows.

<b>Component Type</b>	<b>Intended Function<sup>1</sup></b>
<u>Bolting</u>	<u>Pressure boundary</u>
<u>Piping</u>	<u>Pressure boundary</u>
<u>Tubing</u>	<u>Pressure boundary</u>
<u>Valve body</u>	<u>Pressure boundary</u>

1. For component types included under 10 CFR 54.4(a)(2), the intended function of pressure boundary includes providing structural/seismic support for components that are included for nonsafety-related SSCs directly connected to safety-related SSCs.

**VERMONT YANKEE NUCLEAR POWER STATION  
LICENSE RENEWAL APPLICATION SUPPLEMENT  
ATTACHMENT 2**

- LRA Section 2.3.3 is revised to add a new Table 2.3.3-13-44, Air Evacuation (AE) System, Nonsafety-Related Components Affecting Safety-Related Systems-Components Subject to Aging Management Review, as follows.

<b>Component Type</b>	<b>Intended Function<sup>1</sup></b>
<u>Bolting</u>	<u>Pressure boundary</u>
<u>Filter housing</u>	<u>Pressure boundary</u>
<u>Heat exchanger (shell)</u>	<u>Pressure boundary</u>
<u>Piping</u>	<u>Pressure boundary</u>
<u>Pump casing</u>	<u>Pressure boundary</u>
<u>Rupture disk</u>	<u>Pressure boundary</u>
<u>Strainer housing</u>	<u>Pressure boundary</u>
<u>Trap</u>	<u>Pressure boundary</u>
<u>Tubing</u>	<u>Pressure boundary</u>
<u>Valve body</u>	<u>Pressure boundary</u>

1. For component types included under 10 CFR 54.4(a)(2), the intended function of pressure boundary includes providing structural/seismic support for components that are included for nonsafety-related SSCs directly connected to safety-related SSCs.

- LRA Table 2.3.3-13-1, Augmented Offgas (AOG) System, Nonsafety-Related Components Affecting Safety-Related Systems-Components Subject to Aging Management Review, is revised adding the following line item.

<b>Component Type</b>	<b>Intended Function<sup>1</sup></b>
<u>Steam trap</u>	<u>Pressure boundary</u>

1. For component types included under 10 CFR 54.4(a)(2), the intended function of pressure boundary includes providing structural/seismic support for components that are included for nonsafety-related SSCs directly connected to safety-related SSCs.

**VERMONT YANKEE NUCLEAR POWER STATION  
LICENSE RENEWAL APPLICATION SUPPLEMENT  
ATTACHMENT 2**

- LRA Section 2.3.3 is revised to add a new Table 2.3.3-13-45, Auxiliary Steam (AS) System, Nonsafety-Related Components Affecting Safety-Related Systems-Components Subject to Aging Management Review, as follows.

<b>Component Type</b>	<b>Intended Function<sup>1</sup></b>
<u>Bolting</u>	<u>Pressure boundary</u>
<u>Heat exchanger (shell)</u>	<u>Pressure boundary</u>
<u>Piping</u>	<u>Pressure boundary</u>
<u>Stream trap</u>	<u>Pressure boundary</u>
<u>Tubing</u>	
<u>Valve body</u>	<u>Pressure boundary</u>

1. For component types included under 10 CFR 54.4(a)(2), the intended function of pressure boundary includes providing structural/seismic support for components that are included for nonsafety-related SSCs directly connected to safety-related SSCs.

- LRA Section 2.3.3 is revised to add a new Table 2.3.3-13-46, Building (drainage system components) System (BLD), Nonsafety-Related Components Affecting Safety-Related Systems-Components Subject to Aging Management Review, as follows.

<b>Component Type</b>	<b>Intended Function<sup>1</sup></b>
<u>Bolting</u>	<u>Pressure boundary</u>
<u>Piping</u>	<u>Pressure boundary</u>

1. For component types included under 10 CFR 54.4(a)(2), the intended function of pressure boundary includes providing structural/seismic support for components that are included for nonsafety-related SSCs directly connected to safety-related SSCs.



**VERMONT YANKEE NUCLEAR POWER STATION  
LICENSE RENEWAL APPLICATION SUPPLEMENT  
ATTACHMENT 2**

- LRA Table 2.3.3-13-2, Condensate (C) System, Nonsafety-Related Components Affecting Safety-Related Systems-Components Subject to Aging Management Review, is revised adding the following line items.

<b>Component Type</b>	<b>Intended Function<sup>1</sup></b>
<u>Heat exchanger (shell)</u>	<u>Pressure boundary</u>
<u>Orifice</u>	<u>Pressure boundary</u>
<u>Pump casing</u>	<u>Pressure boundary</u>
<u>Steam trap</u>	<u>Pressure boundary</u>
<u>Tank</u>	<u>Pressure boundary</u>

1. For component types included under 10 CFR 54.4(a)(2), the intended function of pressure boundary includes providing structural/seismic support for components that are included for nonsafety-related SSCs directly connected to safety-related SSCs.

- LRA Table 2.3.3-13-4, Condensate Demineralizer (CD) System, Nonsafety-Related Components Affecting Safety-Related Systems-Components Subject to Aging Management Review, is revised adding the following line items.

<b>Component Type</b>	<b>Intended Function<sup>1</sup></b>
<u>Bolting</u>	<u>Pressure boundary</u>
<u>Filter housing</u>	<u>Pressure boundary</u>
<u>Pump casing</u>	<u>Pressure boundary</u>
<u>Tank</u>	<u>Pressure boundary</u>
<u>Tubing</u>	<u>Pressure boundary</u>

1. For component types included under 10 CFR 54.4(a)(2), the intended function of pressure boundary includes providing structural/seismic support for components that are included for nonsafety-related SSCs directly connected to safety-related SSCs.

**VERMONT YANKEE NUCLEAR POWER STATION  
LICENSE RENEWAL APPLICATION SUPPLEMENT  
ATTACHMENT 2**

- LRA Table 2.3.3-13-7, Condensate Storage and Transfer (CST) System, Nonsafety-Related Components Affecting Safety-Related Systems-Components Subject to Aging Management Review, is revised adding the following line item.

<b>Component Type</b>	<b>Intended Function<sup>1</sup></b>
<u>Filter housing</u>	<u>Pressure boundary</u>

1. For component types included under 10 CFR 54.4(a)(2), the intended function of pressure boundary includes providing structural/seismic support for components that are included for nonsafety-related SSCs directly connected to safety-related SSCs.

- LRA Table 2.3.3-13-9, Circulating Water (CW) System, Nonsafety-Related Components Affecting Safety-Related Systems-Components Subject to Aging Management Review, is revised adding the following line items.

<b>Component Type</b>	<b>Intended Function<sup>1</sup></b>
<u>Expansion joint</u>	<u>Pressure boundary</u>
<u>Tank</u>	<u>Pressure boundary</u>

1. For component types included under 10 CFR 54.4(a)(2), the intended function of pressure boundary includes providing structural/seismic support for components that are included for nonsafety-related SSCs directly connected to safety-related SSCs.

**VERMONT YANKEE NUCLEAR POWER STATION  
LICENSE RENEWAL APPLICATION SUPPLEMENT  
ATTACHMENT 2**

- LRA Section 2.3.3 is revised to add a new Table 2.3.3-13-47, Circulating Water Priming (CWP) System, Nonsafety-Related Components Affecting Safety-Related Systems-Components Subject to Aging Management Review, as follows.

<b>Component Type</b>	<b>Intended Function<sup>1</sup></b>
<u>Bolting</u>	<u>Pressure boundary</u>
<u>Piping</u>	<u>Pressure boundary</u>
<u>Pump casing</u>	<u>Pressure boundary</u>
<u>Tank</u>	<u>Pressure boundary</u>
<u>Trap</u>	<u>Pressure boundary</u>
<u>Tubing</u>	<u>Pressure boundary</u>
<u>Valve body</u>	<u>Pressure boundary</u>

1. For component types included under 10 CFR 54.4(a)(2), the intended function of pressure boundary includes providing structural/seismic support for components that are included for nonsafety-related SSCs directly connected to safety-related SSCs.

- LRA Table 2.3.3-13-10, Diesel Generator and Auxiliaries (DG) System, Nonsafety-Related Components Affecting Safety-Related Systems-Components Subject to Aging Management Review, is revised to delete the following line item.

<b>Component Type</b>	<b>Intended Function<sup>1</sup></b>
<u>Compressor-housing</u>	<u>Pressure boundary</u>

1. For component types included under 10 CFR 54.4(a)(2), the intended function of pressure boundary includes providing structural/seismic support for components that are included for nonsafety-related SSCs directly connected to safety-related SSCs.

**VERMONT YANKEE NUCLEAR POWER STATION  
LICENSE RENEWAL APPLICATION SUPPLEMENT  
ATTACHMENT 2**

- LRA Section 2.3.3 is revised to add a new Table 2.3.3-13-48, Extraction Steam (ES) System, Nonsafety-Related Components Affecting Safety-Related Systems-Components Subject to Aging Management Review, as follows.

<b>Component Type</b>	<b>Intended Function<sup>1</sup></b>
Bolting	Pressure boundary
Expansion joint	Pressure boundary
Orifice	Pressure boundary
Piping	Pressure boundary
Tubing	Pressure boundary
Valve body	Pressure boundary

1. For component types included under 10 CFR 54.4(a)(2), the intended function of pressure boundary includes providing structural/seismic support for components that are included for nonsafety-related SSCs directly connected to safety-related SSCs.

- LRA Table 2.3.3-13-13, Feedwater (FDW) System, Nonsafety-Related Components Affecting Safety-Related Systems-Components Subject to Aging Management Review, is revised adding the following line items.

<b>Component Type</b>	<b>Intended Function<sup>1</sup></b>
<u>Heat exchanger (shell)</u>	<u>Pressure boundary</u>
<u>Orifice</u>	<u>Pressure boundary</u>
<u>Pump casing</u>	<u>Pressure boundary</u>
<u>Strainer housing</u>	<u>Pressure boundary</u>

1. For component types included under 10 CFR 54.4(a)(2), the intended function of pressure boundary includes providing structural/seismic support for components that are included for nonsafety-related SSCs directly connected to safety-related SSCs.

**VERMONT YANKEE NUCLEAR POWER STATION  
LICENSE RENEWAL APPLICATION SUPPLEMENT  
ATTACHMENT 2**

- LRA Table 2.3.3-13-14, Fuel Oil (FO) System, Nonsafety-Related Components Affecting Safety-Related Systems-Components Subject to Aging Management Review, is revised adding the following line item.

<b>Component Type</b>	<b>Intended Function<sup>1</sup></b>
<u>Strainer housing</u>	<u>Pressure boundary</u>

1. For component types included under 10 CFR 54.4(a)(2), the intended function of pressure boundary includes providing structural/seismic support for components that are included for nonsafety-related SSCs directly connected to safety-related SSCs.

- LRA Table 2.3.3-13-15, Fire Protection (FP) System, Nonsafety-Related Components Affecting Safety-Related Systems-Components Subject to Aging Management Review, is revised adding the following line items.

<b>Component Type</b>	<b>Intended Function<sup>1</sup></b>
<u>Orifice</u>	<u>Pressure boundary</u>
<u>Strainer housing</u>	<u>Pressure boundary</u>

1. For component types included under 10 CFR 54.4(a)(2), the intended function of pressure boundary includes providing structural/seismic support for components that are included for nonsafety-related SSCs directly connected to safety-related SSCs.

- LRA Table 2.3.3-13-18, House Heating Boiler (HB) System, Nonsafety-Related Components Affecting Safety-Related Systems-Components Subject to Aging Management Review, is revised adding the following line items.

<b>Component Type</b>	<b>Intended Function<sup>1</sup></b>
<u>Heat exchanger (shell)</u>	<u>Pressure boundary</u>
<u>Strainer housing</u>	<u>Pressure boundary</u>

1. For component types included under 10 CFR 54.4(a)(2), the intended function of pressure boundary includes providing structural/seismic support for components that are included for nonsafety-related SSCs directly connected to safety-related SSCs.

**VERMONT YANKEE NUCLEAR POWER STATION  
LICENSE RENEWAL APPLICATION SUPPLEMENT  
ATTACHMENT 2**

- LRA Section 2.3.3 is revised to add a new Table 2.3.3-13-49, Heater Drain (HD) System, Nonsafety-Related Components Affecting Safety-Related Systems-Components Subject to Aging Management Review, as follows.

<b>Component Type</b>	<b>Intended Function<sup>1</sup></b>
<u>Bolting</u>	<u>Pressure boundary</u>
<u>Piping</u>	<u>Pressure boundary</u>
<u>Pump casing</u>	<u>Pressure boundary</u>
<u>Tank</u>	<u>Pressure boundary</u>
<u>Tubing</u>	<u>Pressure boundary</u>
<u>Valve body</u>	<u>Pressure boundary</u>

1. For component types included under 10 CFR 54.4(a)(2), the intended function of pressure boundary includes providing structural/seismic support for components that are included for nonsafety-related SSCs directly connected to safety-related SSCs.

- LRA Section 2.3.3 is revised to add a new Table 2.3.3-13-50, Heater Vent (HV) System, Nonsafety-Related Components Affecting Safety-Related Systems-Components Subject to Aging Management Review, as follows.

<b>Component Type</b>	<b>Intended Function<sup>1</sup></b>
<u>Bolting</u>	<u>Pressure boundary</u>
<u>Orifice</u>	<u>Pressure boundary</u>
<u>Piping</u>	<u>Pressure boundary</u>
<u>Tank</u>	<u>Pressure boundary</u>
<u>Tubing</u>	<u>Pressure boundary</u>
<u>Valve body</u>	<u>Pressure boundary</u>

1. For component types included under 10 CFR 54.4(a)(2), the intended function of pressure boundary includes providing structural/seismic support for components that are included for nonsafety-related SSCs directly connected to safety-related SSCs.

**VERMONT YANKEE NUCLEAR POWER STATION  
LICENSE RENEWAL APPLICATION SUPPLEMENT  
ATTACHMENT 2**

- LRA Table 2.3.3-13-21, Heating, Ventilation, and Air Conditioning (HVAC) System, Nonsafety-Related Components Affecting Safety-Related Systems-Components Subject to Aging Management Review, is revised adding the following line items and deleting one line item.

<b>Component Type</b>	<b>Intended Function<sup>1</sup></b>
<u>Duct</u>	<u>Pressure boundary</u>
<u>Fan housing</u>	<u>Pressure boundary</u>
<u>Heat exchanger (shell)</u>	<u>Pressure boundary</u>
<u>Heat exchanger (tubes)</u>	<u>Pressure boundary</u>
<u>Pump casing</u>	<u>Pressure boundary</u>
<u>Strainer housing</u>	<u>Pressure boundary</u>

1. For component types included under 10 CFR 54.4(a)(2), the intended function of pressure boundary includes providing structural/seismic support for components that are included for nonsafety-related SSCs directly connected to safety-related SSCs.

- LRA Section 2.3.3 is revised to add a new Table 2.3.3-13-51, Hydrogen Water Chemistry (HWC) System, Nonsafety-Related Components Affecting Safety-Related Systems-Components Subject to Aging Management Review, as follows.

<b>Component Type</b>	<b>Intended Function<sup>1</sup></b>
<u>Bolting</u>	<u>Pressure boundary</u>
<u>Piping</u>	<u>Pressure boundary</u>
<u>Tubing</u>	<u>Pressure boundary</u>
<u>Valve body</u>	<u>Pressure boundary</u>

1. For component types included under 10 CFR 54.4(a)(2), the intended function of pressure boundary includes providing structural/seismic support for components that are included for nonsafety-related SSCs directly connected to safety-related SSCs.

**VERMONT YANKEE NUCLEAR POWER STATION  
LICENSE RENEWAL APPLICATION SUPPLEMENT  
ATTACHMENT 2**

- LRA Table 2.3.3-13-22, Instrument Air (IA) System, Nonsafety-Related Components Affecting Safety-Related Systems-Components Subject to Aging Management Review, is revised to delete the following line item.

<b>Component Type</b>	<b>Intended Function<sup>1</sup></b>
Compressor-housing	Pressure boundary

1. For component types included under 10 CFR 54.4(a)(2), the intended function of pressure boundary includes providing structural/seismic support for components that are included for nonsafety-related SSCs directly connected to safety-related SSCs.

- LRA Section 2.3.3 is revised to add a new Table 2.3.3-13-52, Main Steam (MS) System, Nonsafety-Related Components Affecting Safety-Related Systems-Components Subject to Aging Management Review, as follows.

<b>Component Type</b>	<b>Intended Function<sup>1</sup></b>
<u>Bolting</u>	<u>Pressure boundary</u>
<u>Heat exchanger (shell)</u>	<u>Pressure boundary</u>
<u>Orifice</u>	<u>Pressure boundary</u>
<u>Piping</u>	<u>Pressure boundary</u>
<u>Strainer housing</u>	<u>Pressure boundary</u>
<u>Tubing</u>	<u>Pressure boundary</u>
<u>Valve body</u>	<u>Pressure boundary</u>

1. For component types included under 10 CFR 54.4(a)(2), the intended function of pressure boundary includes providing structural/seismic support for components that are included for nonsafety-related SSCs directly connected to safety-related SSCs.



**VERMONT YANKEE NUCLEAR POWER STATION  
LICENSE RENEWAL APPLICATION SUPPLEMENT  
ATTACHMENT 2**

- LRA Section 2.3.3 is revised to add a new Table 2.3.3-13-53, Make-up Demineralizer (MUD) System, Nonsafety-Related Components Affecting Safety-Related Systems-Components Subject to Aging Management Review, as follows.

<b>Component Type</b>	<b>Intended Function<sup>1</sup></b>
<u>Bolting</u>	<u>Pressure boundary</u>
<u>Filter housing</u>	<u>Pressure boundary</u>
<u>Piping</u>	<u>Pressure boundary</u>
<u>Pump casing</u>	<u>Pressure boundary</u>
<u>Tank</u>	<u>Pressure boundary</u>
<u>Tubing</u>	<u>Pressure boundary</u>
<u>Valve body</u>	<u>Pressure boundary</u>

1. For component types included under 10 CFR 54.4(a)(2), the intended function of pressure boundary includes providing structural/seismic support for components that are included for nonsafety-related SSCs directly connected to safety-related SSCs.

- LRA Table 2.3.3-13-29, Potable Water (PW) System, Nonsafety-Related Components Affecting Safety-Related Systems-Components Subject to Aging Management Review, is revised adding the following line items.

<b>Component Type</b>	<b>Intended Function<sup>1</sup></b>
<u>Filter housing</u>	<u>Pressure boundary</u>
<u>Strainer housing</u>	<u>Pressure boundary</u>
<u>Tank</u>	<u>Pressure boundary</u>
<u>Valve body</u>	<u>Pressure boundary</u>

1. For component types included under 10 CFR 54.4(a)(2), the intended function of pressure boundary includes providing structural/seismic support for components that are included for nonsafety-related SSCs directly connected to safety-related SSCs.

**VERMONT YANKEE NUCLEAR POWER STATION  
LICENSE RENEWAL APPLICATION SUPPLEMENT  
ATTACHMENT 2**

- LRA Section 2.3.3 is revised to add a new Table 2.3.3-13-54, Service Air (SA) System, Nonsafety-Related Components Affecting Safety-Related Systems-Components Subject to Aging Management Review, as follows.

<b>Component Type</b>	<b>Intended Function<sup>1</sup></b>
<u>Bolting</u>	<u>Pressure boundary</u>
<u>Piping</u>	<u>Pressure boundary</u>
<u>Tank</u>	<u>Pressure boundary</u>
<u>Trap</u>	<u>Pressure boundary</u>
<u>Valve body</u>	<u>Pressure boundary</u>

1. For component types included under 10 CFR 54.4(a)(2), the intended function of pressure boundary includes providing structural/seismic support for components that are included for nonsafety-related SSCs directly connected to safety-related SSCs.

- LRA Table 2.3.3-13-39, Stator Cooling (SC) System, Nonsafety-Related Components Affecting Safety-Related Systems-Components Subject to Aging Management Review, is revised adding the following line items.

<b>Component Type</b>	<b>Intended Function<sup>1</sup></b>
<u>Bolting</u>	<u>Pressure boundary</u>
<u>Filter housing</u>	<u>Pressure boundary</u>
<u>Heat exchanger (shell)</u>	<u>Pressure boundary</u>
<u>Pump casing</u>	<u>Pressure boundary</u>
<u>Strainer housing</u>	<u>Pressure boundary</u>
<u>Tank</u>	<u>Pressure boundary</u>
<u>Tubing</u>	<u>Pressure boundary</u>

1. For component types included under 10 CFR 54.4(a)(2), the intended function of pressure boundary includes providing structural/seismic support for components that are included for nonsafety-related SSCs directly connected to safety-related SSCs.

**VERMONT YANKEE NUCLEAR POWER STATION  
LICENSE RENEWAL APPLICATION SUPPLEMENT  
ATTACHMENT 2**

- LRA Section 2.3.3 is revised to add a new Table 2.3.3-13-55, Seal Oil (SO) System, Nonsafety-Related Components Affecting Safety-Related Systems-Components Subject to Aging Management Review, as follows.

<b>Component Type</b>	<b>Intended Function<sup>1</sup></b>
<u>Bolting</u>	<u>Pressure boundary</u>
<u>Filter housing</u>	<u>Pressure boundary</u>
<u>Piping</u>	<u>Pressure boundary</u>
<u>Pump casing</u>	<u>Pressure boundary</u>
<u>Sight glass</u>	<u>Pressure boundary</u>
<u>Tank</u>	<u>Pressure boundary</u>
<u>Tubing</u>	<u>Pressure boundary</u>
<u>Valve body</u>	<u>Pressure boundary</u>

1. For component types included under 10 CFR 54.4(a)(2), the intended function of pressure boundary includes providing structural/seismic support for components that are included for nonsafety-related SSCs directly connected to safety-related SSCs.

- LRA Table 2.3.3-13-41, Sampling (SPL) System, Nonsafety-Related Components Affecting Safety-Related Systems-Components Subject to Aging Management Review, is revised adding the following line item.

<b>Component Type</b>	<b>Intended Function<sup>1</sup></b>
<u>Strainer housing</u>	<u>Pressure boundary</u>

1. For component types included under 10 CFR 54.4(a)(2), the intended function of pressure boundary includes providing structural/seismic support for components that are included for nonsafety-related SSCs directly connected to safety-related SSCs.

**VERMONT YANKEE NUCLEAR POWER STATION  
LICENSE RENEWAL APPLICATION SUPPLEMENT  
ATTACHMENT 2**

- LRA Table 2.3.3-13-42, Service Water (SW) System, Nonsafety-Related Components Affecting Safety-Related Systems-Components Subject to Aging Management Review, is revised adding the following line item.

<b>Component Type</b>	<b>Intended Function<sup>1</sup></b>
<u>Heat exchanger (shell)</u>	<u>Pressure boundary</u>

1. For component types included under 10 CFR 54.4(a)(2), the intended function of pressure boundary includes providing structural/seismic support for components that are included for nonsafety-related SSCs directly connected to safety-related SSCs.

- LRA Section 2.3.3 is revised to add a new Table 2.3.3-13-56, Turbine Building Closed Cooling Water (TBCCW) System, Nonsafety-Related Components Affecting Safety-Related Systems-Components Subject to Aging Management Review, as follows.

<b>Component Type</b>	<b>Intended Function<sup>1</sup></b>
<u>Bolting</u>	<u>Pressure boundary</u>
<u>Heat exchanger (shell)</u>	<u>Pressure boundary</u>
<u>Piping</u>	<u>Pressure boundary</u>
<u>Pump casing</u>	<u>Pressure boundary</u>
<u>Tank</u>	<u>Pressure boundary</u>
<u>Tubing</u>	<u>Pressure boundary</u>
<u>Valve body</u>	<u>Pressure boundary</u>

1. For component types included under 10 CFR 54.4(a)(2), the intended function of pressure boundary includes providing structural/seismic support for components that are included for nonsafety-related SSCs directly connected to safety-related SSCs.

**VERMONT YANKEE NUCLEAR POWER STATION  
LICENSE RENEWAL APPLICATION SUPPLEMENT  
ATTACHMENT 2**

- LRA Section 2.3.3 is revised to add a new Table 2.3.3-13-57, Main Turbine Generator (TG) System, Nonsafety-Related Components Affecting Safety-Related Systems-Components Subject to Aging Management Review, as follows.

<b>Component Type</b>	<b>Intended Function<sup>1</sup></b>
<u>Bolting</u>	<u>Pressure boundary</u>
<u>Filter housing</u>	<u>Pressure boundary</u>
<u>Piping</u>	<u>Pressure boundary</u>
<u>Pump casing</u>	<u>Pressure boundary</u>
<u>Turbine casing</u>	<u>Pressure boundary</u>
<u>Tubing</u>	<u>Pressure boundary</u>
<u>Valve body</u>	<u>Pressure boundary</u>

1. For component types included under 10 CFR 54.4(a)(2), the intended function of pressure boundary includes providing structural/seismic support for components that are included for nonsafety-related SSCs directly connected to safety-related SSCs.

**VERMONT YANKEE NUCLEAR POWER STATION  
LICENSE RENEWAL APPLICATION SUPPLEMENT  
ATTACHMENT 2**

- LRA Section 2.3.3 is revised to add a new Table 2.3.3-13-58, Turbine Lube Oil (TLO) System, Nonsafety-Related Components Affecting Safety-Related Systems-Components Subject to Aging Management Review, as follows.

<b>Component Type</b>	<b>Intended Function<sup>1</sup></b>
<u>Bolting</u>	<u>Pressure boundary</u>
<u>Filter housing</u>	<u>Pressure boundary</u>
<u>Heat exchanger (shell)</u>	<u>Pressure boundary</u>
<u>Piping</u>	<u>Pressure boundary</u>
<u>Pump casing</u>	<u>Pressure boundary</u>
<u>Strainer housing</u>	<u>Pressure boundary</u>
<u>Tank</u>	<u>Pressure boundary</u>
<u>Tubing</u>	<u>Pressure boundary</u>
<u>Valve body</u>	<u>Pressure boundary</u>

1. For component types included under 10 CFR 54.4(a)(2), the intended function of pressure boundary includes providing structural/seismic support for components that are included for nonsafety-related SSCs directly connected to safety-related SSCs.

**VERMONT YANKEE NUCLEAR POWER STATION  
LICENSE RENEWAL APPLICATION SUPPLEMENT  
ATTACHMENT 2**

- LRA Section 3.3.2 is revised to add a new Table 3.3.2-13-43, HD & HV Instruments (103) System, Nonsafety-Related Components Affecting Safety-Related Systems - Summary of Aging Management Evaluation, as follows.

Component Type	Intended Function	Material	Environment	Aging Effect Requiring Management	Aging Management Programs	NUREG-1801, Vol.2 Item	Table 1 Item	Notes
Bolting	Pressure boundary	Carbon steel	Air – indoor (ext)	Loss of material	System Walkdown	VII.I-4 (AP-27)	3.3.1-43	E
Bolting	Pressure boundary	Stainless steel	Air – indoor (ext)	None	None	VII.J-15 (AP-17)	3.3.1-94	C
Piping	Pressure boundary	Carbon steel	Air – indoor (ext)	Loss of material	System Walkdown	VII.I-8 (A-77)	3.3.1-58	A
Piping	Pressure boundary	Carbon steel	Treated water (int)	Loss of material	Water Chemistry Control - BWR	VII.E3-18 (A-35)	3.3.1-17	C
Tubing	Pressure boundary	Copper alloy < 15% Zn	Air – indoor (ext)	None	None	V.F-3 (EP-10)	3.2.1-53	C
Tubing	Pressure boundary	Copper alloy < 15% Zn	Treated water (int)	Loss of material	Water Chemistry Control - BWR	VII.E3-9 (AP-64)	3.3.1-31	C
Valve body	Pressure boundary	Carbon steel	Air – indoor (ext)	Loss of material	System Walkdown	VII.I-8 (A-77)	3.3.1-58	A
Valve body	Pressure boundary	Carbon steel	Treated water (int)	Loss of material	Water Chemistry Control - BWR	VIII.E-33 (S-09)	3.4.1-4	A

**VERMONT YANKEE NUCLEAR POWER STATION  
LICENSE RENEWAL APPLICATION SUPPLEMENT  
ATTACHMENT 2**

- LRA Section 3.3.2 is revised to add a new Table 3.3.2-13-44, Air Evacuation (AE) System, Nonsafety-Related Components Affecting Safety-Related Systems - Summary of Aging Management Evaluation, as follows.

Component Type	Intended Function	Material	Environment	Aging Effect Requiring Management	Aging Management Programs	NUREG-1801, Vol.2 Item	Table 1 Item	Notes
Bolting	Pressure boundary	Carbon steel	Air – indoor (ext)	Loss of material	System Walkdown	VII.I-4 (AP-27)	3.3.1-43	E
Bolting	Pressure boundary	Stainless steel	Air – indoor (ext)	None	None	VII.J-15 (AP-17)	3.3.1-94	C
Filter housing	Pressure boundary	Carbon steel	Air – indoor (ext)	Loss of material	System Walkdown	VII.I-8 (A-77)	3.3.1-58	A
Filter housing	Pressure boundary	Carbon steel	Treated water (int)	Loss of material	Water Chemistry Control - BWR	VII.E3-18 (A-35)	3.3.1-17	C
Heat exchanger (shell)	Pressure boundary	Carbon steel	Air – indoor (ext)	Loss of material	System Walkdown	VII.F1-10 (AP-41)	3.3.1-59	C
Heat exchanger (shell)	Pressure boundary	Carbon steel	Treated water (int)	Loss of material	Water Chemistry Control - BWR	VII.E3-18 (A-35)	3.3.1-17	C
Piping	Pressure boundary	Carbon steel	Air – indoor (ext)	Loss of material	System Walkdown	VII.I-8 (A-77)	3.3.1-58	A
Piping	Pressure boundary	Carbon steel	Treated water (int)	Loss of material	Water Chemistry Control - BWR	VII.E3-18 (A-35)	3.3.1-17	C
Pump casing	Pressure boundary	Carbon steel	Air – indoor (ext)	Loss of material	System Walkdown	VII.I-8 (A-77)	3.3.1-58	A
Pump casing	Pressure boundary	Carbon steel	Treated water (int)	Loss of material	Water Chemistry Control - BWR	VII.E3-18 (A-35)	3.3.1-17	C
Rupture disk	Pressure boundary	Carbon steel	Air – indoor (ext)	Loss of material	System Walkdown	VII.I-8 (A-77)	3.3.1-57	A
Rupture disk	Pressure boundary	Carbon steel	Treated water (int)	Loss of material	Water Chemistry Control - BWR	VIII.A-15 (S-04)	3.4.1-4	C
Strainer housing	Pressure boundary	Carbon steel	Air – indoor (ext)	Loss of material	System Walkdown	VIII.H-7 (S-29)	3.4.1-28	A
Strainer housing	Pressure boundary	Carbon steel	Treated water (int)	Loss of material	Water Chemistry Control - BWR	VIII.E-33 (S-09)	3.4.1-4	A
Trap	Pressure boundary	Carbon steel	Air – indoor (ext)	Loss of material	System Walkdown	VIII.H-7 (S-29)	3.4.1-28	A
Trap	Pressure boundary	Carbon steel	Treated water (int)	Loss of material	Water Chemistry Control - BWR	VIII.E-33 (S-09)	3.4.1-4	A
Tubing	Pressure boundary	Copper alloy < 15% Zn	Air – indoor (ext)	None	None	V.F-3 (EP-10)	3.2.1-53	C
Tubing	Pressure boundary	Copper alloy < 15% Zn	Treated water (int)	Loss of material	Water Chemistry Control - BWR	VII.E3-9 (AP-64)	3.3.1-31	C



**VERMONT YANKEE NUCLEAR POWER STATION  
LICENSE RENEWAL APPLICATION SUPPLEMENT  
ATTACHMENT 2**

Valve body	Pressure boundary	Carbon steel	Air – indoor (ext)	Loss of material	System Walkdown	VII.I-8 (A-77)	3.3.1-58	A
Valve body	Pressure boundary	Carbon steel	Treated water (int)	Loss of material	Water Chemistry Control - BWR	VIII.E-33 (S-09)	3.4.1-4	A

**VERMONT YANKEE NUCLEAR POWER STATION  
LICENSE RENEWAL APPLICATION SUPPLEMENT  
ATTACHMENT 2**

- LRA Section 3.3.2, Table 3.3.2-13-1, Augmented Offgas (AOG) System, Nonsafety-Related Components Affecting Safety-Related Systems - Summary of Aging Management Evaluation, is revised adding the following line items.

Component Type	Intended Function	Material	Environment	Aging Effect Requiring Management	Aging Management Programs	NUREG-1801, Vol.2 Item	Table 1 Item	Notes
Piping	Pressure boundary	Carbon steel	Steam > 220°F (int)	Loss of material	Flow accelerated corrosion	VIII.A-17 (S-15)	3.4.1-29	C
Piping	Pressure boundary	Carbon steel	Steam > 220°F (int)	Loss of material	Water Chemistry Control - BWR	VIII.A-15 (S-04)	3.4.1-2	C
Piping	Pressure boundary	Carbon steel	Steam > 220°F (int)	Cracking - fatigue	TLAA – metal fatigue	VIII.B2-5 (S-08)	3.4.1-1	C
Piping	Pressure boundary	Carbon steel	Treated water > 220°F (int)	Cracking - fatigue	TLAA – metal fatigue	VIII.B2-5 (S-08)	3.4.1-1	C
Steam trap	Pressure boundary	Carbon steel	Air – indoor (ext)	Loss of material	System Walkdown	V.E-7 (E-44)	3.2.1-31	A
Steam trap	Pressure boundary	Carbon steel	Steam > 220°F (int)	Loss of material	Water Chemistry Control - BWR	VIII.A-15 (S-04)	3.4.1-2	C
Steam trap	Pressure boundary	Carbon steel	Steam > 220°F (int)	Cracking - fatigue	TLAA – metal fatigue	VIII.B2-5 (S-08)	3.4.1-1	C
Steam trap	Pressure boundary	Carbon steel	Treated water > 220°F (int)	Cracking - fatigue	TLAA – metal fatigue	VIII.B2-5 (S-08)	3.4.1-1	C
Valve body	Pressure boundary	Carbon steel	Air – indoor (ext)	Loss of material	System Walkdown	V.E-7 (E-44)	3.2.1-31	A
Valve body	Pressure boundary	Carbon steel	Steam > 220°F (int)	Loss of material	Flow accelerated corrosion	VIII.A-17 (S-15)	3.4.1-29	C
Valve body	Pressure boundary	Carbon steel	Steam > 220°F (int)	Loss of material	Water Chemistry Control - BWR	VIII.A-15 (S-04)	3.4.1-2	C
Valve body	Pressure boundary	Carbon steel	Steam > 220°F (int)	Cracking - fatigue	TLAA – metal fatigue	V.D2-32 (E-10)	3.2.1-1	A
Valve body	Pressure boundary	Carbon steel	Treated water (int)	Loss of material	Water Chemistry Control - BWR	VIII.E-33 (S-09)	3.4.1-4	A
Valve body	Pressure boundary	Carbon steel	Treated water > 220°F (int)	Cracking - fatigue	TLAA – metal fatigue	VIII.B2-5 (S-08)	3.4.1-1	C

**VERMONT YANKEE NUCLEAR POWER STATION  
LICENSE RENEWAL APPLICATION SUPPLEMENT  
ATTACHMENT 2**

- LRA Section 3.3.2 is revised to add a new Table 3.3.2-13-45, Auxiliary Steam (AS) System, Nonsafety-Related Components Affecting Safety-Related Systems - Summary of Aging Management Evaluation, as follows.

Component Type	Intended Function	Material	Environment	Aging Effect Requiring Management	Aging Management Programs	NUREG-1801, Vol.2 Item	Table 1 Item	Notes
Bolting	Pressure boundary	Carbon steel	Air – indoor (ext)	Loss of material	System Walkdown	VII.I-4 (AP-27)	3.3.1-43	E
Bolting	Pressure boundary	Stainless steel	Air – indoor (ext)	None	None	VII.J-15 (AP-17)	3.3.1-94	C
Heat exchanger (shell)	Pressure boundary	Carbon steel	Air – indoor (ext)	Loss of material	System Walkdown	VII.F1-10 (AP-41)	3.3.1-59	C
Heat exchanger (shell)	Pressure boundary	Carbon steel	Treated water > 220°F (int)	Cracking - fatigue	One-Time Inspection			H
Heat exchanger (shell)	Pressure boundary	Carbon steel	Treated water (int)	Loss of material	Water Chemistry Control - BWR	VII.E3-18 (A-35)	3.3.1-17	C
Piping	Pressure boundary	Carbon steel	Air – indoor (ext)	Loss of material	System Walkdown	VII.I-8 (A-77)	3.3.1-58	A
Piping	Pressure boundary	Carbon steel	Steam > 220°F (int)	Loss of material	Flow accelerated corrosion	VIII.A-17 (S-15)	3.4.1-29	C
Piping	Pressure boundary	Carbon steel	Steam > 220°F (int)	Loss of material	Water Chemistry Control - BWR	VIII.A-15 (S-04)	3.4.1-2	C
Piping	Pressure boundary	Carbon steel	Steam > 220°F (int)	Cracking - fatigue	TLAA – metal fatigue	VIII.B2-5 (S-08)	3.4.1-1	C
Piping	Pressure boundary	Carbon steel	Treated water > 220°F (int)	Cracking - fatigue	TLAA – metal fatigue	VIII.B2-5 (S-08)	3.4.1-1	C
Piping	Pressure boundary	Carbon steel	Treated water (int)	Loss of material	Water Chemistry Control - BWR	VII.E3-18 (A-35)	3.3.1-17	C
Steam trap	Pressure boundary	Carbon steel	Air – indoor (ext)	Loss of material	System Walkdown	V.E-7 (E-44)	3.2.1-31	A
Steam trap	Pressure boundary	Carbon steel	Steam > 220°F (int)	Loss of material	Flow accelerated corrosion	VIII.A-17 (S-15)	3.4.1-29	C
Steam trap	Pressure boundary	Carbon steel	Steam > 220°F (int)	Loss of material	Water Chemistry Control - BWR	VIII.A-15 (S-04)	3.4.1-2	C
Steam trap	Pressure boundary	Carbon steel	Steam > 220°F (int)	Cracking - fatigue	TLAA – metal fatigue	VIII.B2-5 (S-08)	3.4.1-1	C
Steam trap	Pressure boundary	Carbon steel	Treated water > 220°F (int)	Cracking - fatigue	TLAA – metal fatigue	VIII.B2-5 (S-08)	3.4.1-1	C
Steam trap	Pressure boundary	Carbon steel	Treated water (int)	Loss of material	Water Chemistry Control - BWR	VII.E3-18 (A-35)	3.3.1-17	C
Tubing	Pressure boundary	Carbon steel	Air – indoor (ext)	Loss of material	System Walkdown	V.E-7 (E-44)	3.2.1-31	A

**VERMONT YANKEE NUCLEAR POWER STATION  
LICENSE RENEWAL APPLICATION SUPPLEMENT  
ATTACHMENT 2**

Tubing	Pressure boundary	Carbon steel	Steam > 220°F (int)	Loss of material	Flow accelerated corrosion	V.D2-31 (E-07)	3.2.1-19	A
Tubing	Pressure boundary	Carbon steel	Treated water (int)	Loss of material	Water Chemistry Control - BWR	VII.E3-18 (A-35)	3.3.1-17	C
Valve body	Pressure boundary	Carbon steel	Air – indoor (ext)	Loss of material	System Walkdown	VII.I-8 (A-77)	3.3.1-58	A
Valve body	Pressure boundary	Carbon steel	Steam > 220°F (int)	Loss of material	Flow accelerated corrosion	VIII.A-17 (S-15)	3.4.1-29	C
Valve body	Pressure boundary	Carbon steel	Steam > 220°F (int)	Loss of material	Water Chemistry Control - BWR	VIII.A-15 (S-04)	3.4.1-2	C
Valve body	Pressure boundary	Carbon steel	Steam > 220°F (int)	Cracking - fatigue	TLAA – metal fatigue	V.D2-32 (E-10)	3.2.1-1	A
Valve body	Pressure boundary	Carbon steel	Treated water > 220°F (int)	Cracking - fatigue	TLAA – metal fatigue	VIII.B2-5 (S-08)	3.4.1-1	C
Valve body	Pressure boundary	Carbon steel	Treated water (int)	Loss of material	Water Chemistry Control - BWR	VIII.E-33 (S-09)	3.4.1-4	A

- LRA Section 3.3.2 is revised to add a new Table 3.3.2-13-46, Buildings (drainage system components) System (BLD), Nonsafety-Related Components Affecting Safety-Related Systems - Summary of Aging Management Evaluation, as follows.

Component Type	Intended Function	Material	Environment	Aging Effect Requiring Management	Aging Management Programs	NUREG-1801, Vol.2 Item	Table 1 Item	Notes
Bolting	Pressure boundary	Carbon steel	Air – indoor (ext)	Loss of material	System Walkdown	VII.I-4 (AP-27)	3.3.1-43	E
Bolting	Pressure boundary	Stainless steel	Air – indoor (ext)	None	None	VII.J-15 (AP-17)	3.3.1-94	C
Piping	Pressure boundary	Carbon steel	Air – indoor (ext)	Loss of material	System Walkdown	VII.I-8 (A-77)	3.3.1-58	A
Piping	Pressure boundary	Carbon steel	Untreated water (int)	Loss of material	Periodic Surveillance and Preventive Maintenance	VII.G-24 (A-33)	3.3.1-68	E

**VERMONT YANKEE NUCLEAR POWER STATION  
LICENSE RENEWAL APPLICATION SUPPLEMENT  
ATTACHMENT 2**

- LRA Section 3.3.2, Table 3.3.2-13-2, Condensate (C) System, Nonsafety-Related Components Affecting Safety-Related Systems - Summary of Aging Management Evaluation, is revised adding the following line items.

Component Type	Intended Function	Material	Environment	Aging Effect Requiring Management	Aging Management Programs	NUREG-1801, Vol.2 Item	Table 1 Item	Notes
Heat exchanger (shell)	Pressure boundary	Carbon steel	Air – indoor (ext)	Loss of material	System Walkdown	VIII.H-7 (S-29)	3.4.1-28	A
Heat exchanger (shell)	Pressure boundary	Carbon steel	Treated water > 220°F (int)	Cracking - fatigue	One-Time Inspection			H
Heat exchanger (shell)	Pressure boundary	Carbon steel	Treated water (int)	Loss of material	Water Chemistry Control - BWR	VIII.E-7 (S-18)	3.4.1-5	A
Orifice	Pressure boundary	Carbon steel	Air – indoor (ext)	Loss of material	System Walkdown	VIII.H-7 (S-29)	3.4.1-28	A
Orifice	Pressure boundary	Carbon steel	Treated water (int)	Loss of material	Water Chemistry Control - BWR	VIII.E-33 (S-09)	3.4.1-4	A
Piping	Pressure boundary	Carbon steel	Steam > 220°F (int)	Loss of material	Water Chemistry Control - BWR	VIII.A-15 (S-04)	3.4.1-2	A
Piping	Pressure boundary	Carbon steel	Steam > 220°F (int)	Loss of material	Flow accelerated corrosion	VIII.B2-4 (S-15)	3.4.1-29	C
Piping	Pressure boundary	Carbon steel	Steam > 220°F (int)	Cracking - fatigue	TLAA – metal fatigue	VIII.B2-5 (S-08)	3.4.1-1	C
Piping	Pressure boundary	Carbon steel	Treated water > 220°F (int)	Cracking - fatigue	TLAA – metal fatigue	VIII.B2-5 (S-08)	3.4.1-1	C
Pump casing	Pressure boundary	Carbon steel	Air – indoor (ext)	Loss of material	System Walkdown	VIII.H-7 (S-29)	3.4.1-28	A
Pump casing	Pressure boundary	Carbon steel	Treated water (int)	Loss of material	Water Chemistry Control - BWR	VIII.E-33 (S-09)	3.4.1-4	A
Steam trap	Pressure boundary	Carbon steel	Air – indoor (ext)	Loss of material	System Walkdown	VIII.H-7 (S-29)	3.4.1-28	A
Steam trap	Pressure boundary	Carbon steel	Steam > 220°F (int)	Loss of material	Flow accelerated corrosion	VIII.B2-4 (S-15)	3.4.1-29	C
Steam trap	Pressure boundary	Carbon steel	Steam > 220°F (int)	Loss of material	Water Chemistry Control - BWR	VIII.A-15 (S-04)	3.4.1-2	A
Steam trap	Pressure boundary	Carbon steel	Steam > 220°F (int)	Cracking - fatigue	TLAA – metal fatigue	VIII.B2-5 (S-08)	3.4.1-1	C
Steam trap	Pressure boundary	Carbon steel	Treated water (int)	Loss of material	Water Chemistry Control - BWR	VIII.E-33 (S-09)	3.4.1-4	A
Steam trap	Pressure boundary	Carbon steel	Treated water > 220°F (int)	Cracking - fatigue	TLAA – metal fatigue	VIII.B2-5 (S-08)	3.4.1-1	C

**VERMONT YANKEE NUCLEAR POWER STATION  
LICENSE RENEWAL APPLICATION SUPPLEMENT  
ATTACHMENT 2**

Tank	Pressure boundary	Carbon steel	Air – indoor (ext)	Loss of material	System Walkdown	VIII.H-7 (S-29)	3.4.1-28	A
Tank	Pressure boundary	Carbon steel	Treated water (int)	Loss of material	Water Chemistry Control - BWR	VIII.E-33 (S-09)	3.4.1-4	A

**VERMONT YANKEE NUCLEAR POWER STATION  
LICENSE RENEWAL APPLICATION SUPPLEMENT  
ATTACHMENT 2**

- LRA Section 3.3.2, Table 3.3.2-13-4, Condensate Demineralizer (CD) System, Nonsafety-Related Components Affecting Safety-Related Systems - Summary of Aging Management Evaluation, is revised adding the following line items.

Component Type	Intended Function	Material	Environment	Aging Effect Requiring Management	Aging Management Programs	NUREG-1801, Vol.2 Item	Table 1 Item	Notes
Bolting	Pressure boundary	Carbon steel	Air – indoor (ext)	Loss of material	System Walkdown	VIII.H-4 (S-34)	3.4.1-22	E
Bolting	Pressure boundary	Stainless steel	Air – indoor (ext)	None	None	VIII.I-10 (SP-12)	3.4.1-41	C
Filter housing	Pressure boundary	Carbon steel	Air – indoor (ext)	Loss of material	System Walkdown	VIII.H-7 (S-29)	3.4.1-28	A
Filter housing	Pressure boundary	Carbon steel	Treated water (int)	Loss of material	Water Chemistry Control - BWR	VIII.E-33 (S-09)	3.4.1-4	A
Pump casing	Pressure boundary	Carbon steel	Air – indoor (ext)	Loss of material	System Walkdown	VIII.H-7 (S-29)	3.4.1-28	A
Pump casing	Pressure boundary	Carbon steel	Treated water (int)	Loss of material	Water Chemistry Control - BWR	VIII.E-33 (S-09)	3.4.1-4	A
Tank	Pressure boundary	Carbon steel	Air – indoor (ext)	Loss of material	System Walkdown	VIII.H-7 (S-29)	3.4.1-28	A
Tank	Pressure boundary	Carbon steel	Treated water (int)	Loss of material	Water Chemistry Control - BWR	VIII.E-33 (S-09)	3.4.1-4	A
Tubing	Pressure boundary	Copper alloy < 15% Zn	Air – indoor (ext)	None	None	VIII.I-2 (SP-6)	3.4.1-41	A
Tubing	Pressure boundary	Copper alloy < 15% Zn	Treated water (int)	Loss of material	Water Chemistry Control - BWR	VIII.A-5 (SP-61)	3.4.1-15	C

**VERMONT YANKEE NUCLEAR POWER STATION  
LICENSE RENEWAL APPLICATION SUPPLEMENT  
ATTACHMENT 2**

- LRA Section 3.3.2, Table 3.3.2-13-7, Condensate Storage and Transfer (CST) System, Nonsafety-Related Components Affecting Safety-Related Systems - Summary of Aging Management Evaluation, is revised adding the following line items.

Component Type	Intended Function	Material	Environment	Aging Effect Requiring Management	Aging Management Programs	NUREG-1801, Vol.2 Item	Table 1 Item	Notes
Filter housing	Pressure boundary	Carbon steel	Air – outdoor (ext)	Loss of material	System Walkdown	VIII.H-7 (S-29)	3.4.1-28	A
Filter housing	Pressure boundary	Carbon steel	Treated water (int)	Loss of material	Water Chemistry Control - BWR	VIII.E-33 (S-09)	3.4.1-4	A

- LRA Section 3.3.2, Table 3.3.2-13-9, Circulating Water (CW) System, Nonsafety-Related Components Affecting Safety-Related Systems - Summary of Aging Management Evaluation, is revised adding the following line items.

Component Type	Intended Function	Material	Environment	Aging Effect Requiring Management	Aging Management Programs	NUREG-1801, Vol.2 Item	Table 1 Item	Notes
Expansion joint	Pressure boundary	Stainless steel	Condensation (ext)	Loss of material	System Walkdown	VII.I-11 (A-81)	3.3.1-58	A
Expansion joint	Pressure boundary	Stainless steel	Raw water (int)	Loss of material	Periodic Surveillance and Preventive Maintenance	VII.G-24 (A-33)	3.3.1-68	E
Tank	Pressure boundary	Carbon steel	Condensation (ext)	Loss of material	System Walkdown	VII.I-8 (A-77)	3.3.1-58	A
Tank	Pressure boundary	Carbon steel	Raw water (int)	Loss of material	Periodic Surveillance and Preventive Maintenance	VII.G-24 (A-33)	3.3.1-68	E



**VERMONT YANKEE NUCLEAR POWER STATION  
LICENSE RENEWAL APPLICATION SUPPLEMENT  
ATTACHMENT 2**

- LRA Section 3.3.2 is revised to add a new Table 3.3.2-13-47, Circulating Water Priming (CWP) System, Nonsafety-Related Components Affecting Safety-Related Systems - Summary of Aging Management Evaluation, as follows.

Component Type	Intended Function	Material	Environment	Aging Effect Requiring Management	Aging Management Programs	NUREG-1801, Vol.2 Item	Table 1 Item	Notes
Bolting	Pressure boundary	Carbon steel	Air – indoor (ext)	Loss of material	System Walkdown	VII.I-4 (AP-27)	3.3.1-43	E
Bolting	Pressure boundary	Carbon steel	Air – outdoor (ext)	Loss of material	System Walkdown	VII.I-1 (AP-28)	3.3.1-43	E
Bolting	Pressure boundary	Stainless steel	Air – indoor (ext)	None	None	VII.J-15 (AP-17)	3.3.1-94	C
Bolting	Pressure boundary	Stainless steel	Air – outdoor (ext)	None	None			G
Piping	Pressure boundary	Carbon steel	Condensation (ext)	Loss of material	System walkdown	VIII.H-10 (S-42)	3.4.1-28	A
Piping	Pressure boundary	Carbon steel	Raw water (int)	Loss of material	Periodic Surveillance and Preventive Maintenance	VIII.E-6 (S-24)	3.4.1-31	E
Pump casing	Pressure boundary	Carbon steel	Condensation (ext)	Loss of material	System walkdown	VIII.H-10 (S-42)	3.4.1-28	A
Pump casing	Pressure boundary	Carbon steel	Raw water (int)	Loss of material	Periodic Surveillance and Preventive Maintenance	VIII.E-6 (S-24)	3.4.1-31	E
Tank	Pressure boundary	Carbon steel	Condensation (ext)	Loss of material	System walkdown	VIII.H-10 (S-42)	3.4.1-28	A
Tank	Pressure boundary	Carbon steel	Raw water (int)	Loss of material	Periodic Surveillance and Preventive Maintenance	VIII.E-6 (S-24)	3.4.1-31	E
Trap	Pressure boundary	Carbon steel	Condensation (ext)	Loss of material	System walkdown	VIII.H-10 (S-42)	3.4.1-28	A
Trap	Pressure boundary	Carbon steel	Raw water (int)	Loss of material	Periodic Surveillance and Preventive Maintenance	VIII.E-6 (S-24)	3.4.1-31	E
Tubing	Pressure boundary	Copper alloy < 15% Zn	Condensation (ext)	Loss of material	System walkdown	VII.F1-16 (A-46)	3.3.1-25	E
Tubing	Pressure boundary	Copper alloy < 15% Zn	Raw water (int)	Loss of material	Periodic Surveillance and Preventive Maintenance	VIII.E-18 (SP-31)	3.4.1-32	E
Valve body	Pressure boundary	Carbon steel	Condensation (ext)	Loss of material	System walkdown	VIII.H-10 (S-42)	3.4.1-28	A

**VERMONT YANKEE NUCLEAR POWER STATION  
LICENSE RENEWAL APPLICATION SUPPLEMENT  
ATTACHMENT 2**

Valve body	Pressure boundary	Carbon steel	Raw water (int)	Loss of material	Periodic Surveillance and Preventive Maintenance	VIII.E-6 (S-24)	3.4.1-31	E
------------	-------------------	--------------	-----------------	------------------	--	-----------------	----------	---

**VERMONT YANKEE NUCLEAR POWER STATION  
LICENSE RENEWAL APPLICATION SUPPLEMENT  
ATTACHMENT 2**

- LRA Section 3.3.2, Table 3.3.2-13-10, Diesel Generator & Auxiliaries (DG) System, Nonsafety-Related Components Affecting Safety-Related Systems - Summary of Aging Management Evaluation, is revised to delete the following line items.

Component Type	Intended Function	Material	Environment	Aging Effect Requiring Management	Aging Management Programs	NUREG-1801, Vol.2 Item	Table 1 Item	Notes
Compressor housing	Pressure boundary	Carbon steel	Air—indoor (ext)	Loss of material	System Walkdown	VII.H2-8 (A-77)	3.3.1-58	A
Compressor housing	Pressure boundary	Carbon steel	Treated water (int)	Loss of material	Water Chemistry Control—Closed Cooling Water	VII.H2-23 (A-25)	3.3.1-47	B
Compressor housing	Pressure boundary	Carbon steel	Untreated air (int)	Loss of material	Periodic Surveillance and Preventive Maintenance	VII.H2-24 (A-23)	3.3.1-74	E, 302

**VERMONT YANKEE NUCLEAR POWER STATION  
LICENSE RENEWAL APPLICATION SUPPLEMENT  
ATTACHMENT 2**

- LRA Section 3.3.2 is revised to add a new Table 3.3.2-13-48, Extraction Steam (ES) System, Nonsafety-Related Components Affecting Safety-Related Systems - Summary of Aging Management Evaluation, as follows.

Component Type	Intended Function	Material	Environment	Aging Effect Requiring Management	Aging Management Programs	NUREG-1801, Vol.2 Item	Table 1 Item	Notes
Bolting	Pressure boundary	Carbon steel	Air – indoor (ext)	Loss of material	System Walkdown	VIII.H-4 (S-34)	3.4.1-22	E
Bolting	Pressure boundary	Stainless steel	Air – indoor (ext)	None	None	VIII.I-10 (SP-12)	3.4.1-41	C
Expansion joint	Pressure boundary	Stainless steel	Air – indoor (ext)	None	None	VIII.I-10 (SP-12)	3.4.1-41	A
Expansion joint	Pressure boundary	Stainless steel	Steam > 270°F (int)	Loss of material	Water Chemistry Control - BWR	VIII.A-13 (SP-46)	3.4.1-37	C
Expansion joint	Pressure boundary	Stainless steel	Steam > 270°F (int)	Cracking – fatigue	TLAA – metal fatigue			H
Expansion joint	Pressure boundary	Stainless steel	Steam > 270°F (int)	Cracking	Water Chemistry Control - BWR	VIII.B2-1 (SP-45)	3.4.1-13	A
Expansion joint	Pressure boundary	Stainless steel	Treated water > 270°F (int)	Cracking	Water Chemistry Control - BWR	VIII.A-11 (SP-45)	3.4.1-13	C
Expansion joint	Pressure boundary	Stainless steel	Treated water > 270°F (int)	Cracking – fatigue	TLAA – metal fatigue			H
Expansion joint	Pressure boundary	Stainless steel	Treated water > 270°F (int)	Loss of material	Water Chemistry Control - BWR	VIII.C-1 (SP-16)	3.4.1-16	A
Orifice	Pressure boundary	Carbon steel	Air – indoor (ext)	Loss of material	System Walkdown	VIII.H-7 (S-29)	3.4.1-28	A
Orifice	Pressure boundary	Carbon steel	Steam > 220°F (int)	Loss of material	Flow accelerated corrosion	VIII.C-5 (S-15)	3.4.1-29	A
Orifice	Pressure boundary	Carbon steel	Steam > 220°F (int)	Cracking – fatigue	TLAA – metal fatigue	VIII.B2-5 (S-08)	3.4.1-1	C
Orifice	Pressure boundary	Carbon steel	Steam > 220°F (int)	Loss of material	Water Chemistry Control - BWR	VIII.C-3 (S-04)	3.4.1-2	A
Orifice	Pressure boundary	Carbon steel	Treated water > 220°F (int)	Cracking - fatigue	TLAA – metal fatigue	VIII.B2-5 (S-08)	3.4.1-1	C
Orifice	Pressure boundary	Carbon steel	Treated water (int)	Loss of material	Water Chemistry Control - BWR	VIII.C-6 (S-09)	3.4.1-4	A
Piping	Pressure boundary	Carbon steel	Air – indoor (ext)	Loss of material	System Walkdown	VIII.H-7 (S-29)	3.4.1-28	A
Piping	Pressure boundary	Carbon steel	Steam > 220°F (int)	Loss of material	Flow accelerated corrosion	VIII.C-5 (S-15)	3.4.1-29	A
Piping	Pressure boundary	Carbon steel	Steam > 220°F (int)	Loss of material	Water Chemistry Control - BWR	VIII.C-3 (S-04)	3.4.1-2	A
Piping	Pressure boundary	Carbon steel	Steam > 220°F (int)	Cracking - fatigue	TLAA – metal fatigue	VIII.B2-5 (S-08)	3.4.1-1	C

**VERMONT YANKEE NUCLEAR POWER STATION  
LICENSE RENEWAL APPLICATION SUPPLEMENT  
ATTACHMENT 2**

Piping	Pressure boundary	Carbon steel	Treated water > 220°F (int)	Cracking - fatigue	TLAA – metal fatigue	VIII.B2-5 (S-08)	3.4.1-1	C
Piping	Pressure boundary	Carbon steel	Treated water (int)	Loss of material	Water Chemistry Control - BWR	VIII.C-6 (S-09)	3.4.1-4	A
Tubing	Pressure boundary	Carbon steel	Air – indoor (ext)	Loss of material	System Walkdown	VIII.H-7 (S-29)	3.4.1-28	A
Tubing	Pressure boundary	Carbon steel	Treated water (int)	Loss of material	Water Chemistry Control - BWR	VIII.C-6 (S-09)	3.4.1-4	A
Valve body	Pressure boundary	Carbon steel	Air – indoor (ext)	Loss of material	System Walkdown	VIII.H-7 (S-29)	3.4.1-28	A
Valve body	Pressure boundary	Carbon steel	Steam > 220°F (int)	Loss of material	Flow accelerated corrosion	VIII.C-5 (S-15)	3.4.1-29	A
Valve body	Pressure boundary	Carbon steel	Steam > 220°F (int)	Loss of material	Water Chemistry Control - BWR	VIII.C-3 (S-04)	3.4.1-2	A
Valve body	Pressure boundary	Carbon steel	Steam > 220°F (int)	Cracking - fatigue	TLAA – metal fatigue	VIII.B2-5 (S-08)	3.4.1-1	C
Valve body	Pressure boundary	Carbon steel	Treated water > 220°F (int)	Cracking - fatigue	TLAA – metal fatigue	VIII.B2-5 (S-08)	3.4.1-1	C
Valve body	Pressure boundary	Carbon steel	Treated water (int)	Loss of material	Water Chemistry Control - BWR	VIII.C-6 (S-09)	3.4.1-4	A

- LRA Section 3.3.2, Table 3.3.2-13-13, Feedwater (FDW) System, Nonsafety-Related Components Affecting Safety-Related Systems - Summary of Aging Management Evaluation, is revised adding the following line items.

Component Type	Intended Function	Material	Environment	Aging Effect Requiring Management	Aging Management Programs	NUREG-1801, Vol.2 Item	Table 1 Item	Notes
Heat exchanger (shell)	Pressure boundary	Carbon steel	Air – indoor (ext)	Loss of material	System Walkdown	VII.F1-10 (AP-41)	3.3.1-59	C
Heat exchanger (shell)	Pressure boundary	Carbon steel	Steam > 220°F (int)	Cracking - fatigue	One-Time Inspection			H
Heat exchanger (shell)	Pressure boundary	Carbon steel	Steam > 220°F (int)	Loss of material	Water Chemistry Control - BWR	VII.E3-18 (A-35)	3.3.1-17	C
Heat exchanger (shell)	Pressure boundary	Carbon steel	Treated water > 220°F (int)	Cracking - fatigue	One-Time Inspection			H
Heat exchanger (shell)	Pressure boundary	Carbon steel	Treated water > 220°F (int)	Loss of material	Water Chemistry Control - BWR	VII.E3-18 (A-35)	3.3.1-17	C
Orifice	Pressure boundary	Carbon steel	Air – indoor (ext)	Loss of material	System Walkdown	VIII.H-7 (S-29)	3.4.1-28	A
Orifice	Pressure boundary	Carbon steel	Treated water > 220°F (int)	Cracking - fatigue	TLAA – metal fatigue	VIII.D2-6 (S-11)	3.4.1-1	A

**VERMONT YANKEE NUCLEAR POWER STATION  
LICENSE RENEWAL APPLICATION SUPPLEMENT  
ATTACHMENT 2**

Orifice	Pressure boundary	Carbon steel	Treated water > 220°F (int)	Loss of material	Water Chemistry Control - BWR	VIII.D2-7 (S-09)	3.4.1-4	A
Piping	Pressure boundary	Carbon steel	Lube oil (int)	Loss of material	Oil analysis	VII.G-22 (AP-30)	3.3.1-14	E
Piping	Pressure boundary	Carbon steel	Steam > 220°F (int)	Loss of material	Flow accelerated corrosion	VIII.C-5 (S-15)	3.4.1-29	A
Piping	Pressure boundary	Carbon steel	Steam > 220°F (int)	Cracking - fatigue	TLAA – metal fatigue	VIII.B2-5 (S-08)	3.4.1-1	C
Piping	Pressure boundary	Carbon steel	Steam > 220°F (int)	Loss of material	Water Chemistry Control - BWR	VIII.C-3 (S-04)	3.4.1-2	A
Pump casing	Pressure boundary	Carbon steel	Air – indoor (ext)	Loss of material	System Walkdown	VIII.H-7 (S-29)	3.4.1-28	A
Pump casing	Pressure boundary	Carbon steel	Lube oil (int)	Loss of material	Oil analysis	VII.G-22 (AP-30)	3.3.1-14	E
Pump casing	Pressure boundary	Carbon steel	Treated water > 220°F (int)	Cracking - fatigue	One-time inspection			H
Pump casing	Pressure boundary	Carbon steel	Treated water > 220°F (int)	Loss of material	Water Chemistry Control - BWR	VIII.D2-7 (S-09)	3.4.1-4	A
Strainer housing	Pressure boundary	Carbon steel	Air – indoor (ext)	Loss of material	System Walkdown	VIII.H-7 (S-29)	3.4.1-28	A
Strainer housing	Pressure boundary	Carbon steel	Treated water > 220°F (int)	Cracking - fatigue	One-time inspection			H
Strainer housing	Pressure boundary	Carbon steel	Treated water > 220°F (int)	Loss of material	Water Chemistry Control - BWR	VIII.D2-7 (S-09)	3.4.1-4	A
Tubing	Pressure boundary	Copper alloy < 15% Zn	Lube oil (int)	Loss of material	Oil analysis	VII.G-22 (AP-30)	3.3.1-14	E
Tubing	Pressure boundary	Copper alloy < 15% Zn	Treated water > 220°F (int)	Loss of material	Water Chemistry Control - BWR	VII.E3-18 (A-35)	3.3.1-17	C
Tubing	Pressure boundary	Stainless steel	Air – indoor (ext)	None	None	VII.J-15 (AP-17)	3.3.1-94	A
Tubing	Pressure boundary	Stainless steel	Lube oil (int)	Loss of material	Oil analysis	VII.C1-8 (AP-47)	3.3.1-26	E
Tubing	Pressure boundary	Stainless steel	Treated water > 270°F (int)	Cracking – fatigue	TLAA – metal fatigue			H
Tubing	Pressure boundary	Stainless steel	Treated water > 270°F (int)	Loss of material	Water chemistry control – BWR	VIII.D2-4 (SP-16)	3.4.1-16	A
Tubing	Pressure boundary	Stainless steel	Treated water > 270°F (int)	Cracking	Water Chemistry Control - BWR	VIII.A-11 (SP-45)	3.4.1-13	C
Valve body	Pressure boundary	Carbon steel	Lube oil (int)	Loss of material	Oil analysis	VII.C1-17 (AP-30)	3.3.1-14	E
Valve body	Pressure boundary	Carbon steel	Steam > 220°F (int)	Loss of material	Flow accelerated corrosion	VIII.C-5 (S-15)	3.4.1-29	A
Valve body	Pressure boundary	Carbon steel	Steam > 220°F (int)	Cracking - fatigue	TLAA – metal fatigue	VIII.B2-5 (S-08)	3.4.1-1	A
Valve body	Pressure boundary	Carbon steel	Steam > 220°F (int)	Loss of material	Water Chemistry Control - BWR	VIII.C-3 (S-04)	3.4.1-2	A

**VERMONT YANKEE NUCLEAR POWER STATION  
LICENSE RENEWAL APPLICATION SUPPLEMENT  
ATTACHMENT 2**

- LRA Section 3.3.2, Table 3.3.2-13-14, Fuel Oil (FO) System, Nonsafety-Related Components Affecting Safety-Related Systems - Summary of Aging Management Evaluation, is revised adding the following line items.

Component Type	Intended Function	Material	Environment	Aging Effect Requiring Management	Aging Management Programs	NUREG-1801, Vol.2 Item	Table 1 Item	Notes
Strainer housing	Pressure boundary	Carbon steel	Air – indoor (ext)	Loss of material	System Walkdown	VIII.H-7 (S-29)	3.4.1-28	A
Strainer housing	Pressure boundary	Carbon steel	Fuel oil (int)	Loss of material	Diesel fuel monitoring	VII.H1-10 (A-30)	3.3.1-20	E
Strainer housing	Pressure boundary	Stainless steel	Air – indoor (ext)	None	None	VII.J-15 (AP-17)	3.3.1-94	A
Strainer housing	Pressure boundary	Stainless steel	Fuel oil (int)	Loss of material	Diesel fuel monitoring	VII.H1-6 (AP-54)	3.3.1-32	E

**VERMONT YANKEE NUCLEAR POWER STATION  
LICENSE RENEWAL APPLICATION SUPPLEMENT  
ATTACHMENT 2**

- LRA Section 3.3.2, Table 3.3.2-13-15, Fire Protection (FP) System, Nonsafety-Related Components Affecting Safety-Related Systems - Summary of Aging Management Evaluation, is revised adding the following line items.

Component Type	Intended Function	Material	Environment	Aging Effect Requiring Management	Aging Management Programs	NUREG-1801, Vol.2 Item	Table 1 Item	Notes
Orifice	Pressure boundary	Carbon steel	Air – indoor (ext)	Loss of material	System Walkdown	VII.I-8 (A-77)	3.3.1-58	A
Orifice	Pressure boundary	Carbon steel	Raw water (int)	Loss of material	Fire water system	VII.G-24 (A-33)	3.3.1-68	B
Strainer housing	Pressure boundary	Carbon steel	Air – indoor (ext)	Loss of material	System Walkdown	VIII.H-7 (S-29)	3.4.1-28	A
Strainer housing	Pressure boundary	Carbon steel	Raw water (int)	Loss of material	Fire Water System	VII.G-24 (A-33)	3.3.1-68	B
Strainer housing	Pressure boundary	Gray cast iron	Air – indoor (ext)	Loss of material	System Walkdown	VII.I-8 (A-77)	3.3.1-58	A
Strainer housing	Pressure boundary	Gray cast iron	Raw water (int)	Loss of material	Fire Water System	VII.G-24 (A-33)	3.3.1-68	B
Strainer housing	Pressure boundary	Gray cast iron	Raw water (int)	Loss of material	Selective leaching	VII.G-14 (A-51)	3.3.1-85	A



**VERMONT YANKEE NUCLEAR POWER STATION  
LICENSE RENEWAL APPLICATION SUPPLEMENT  
ATTACHMENT 2**

- LRA Section 3.3.2, Table 3.3.2-13-18, House Heating Boiler (HB) System, Nonsafety-Related Components Affecting Safety-Related Systems - Summary of Aging Management Evaluation, is revised adding the following line items.

Component Type	Intended Function	Material	Environment	Aging Effect Requiring Management	Aging Management Programs	NUREG-1801, Vol.2 Item	Table 1 Item	Notes
Heat exchanger (shell)	Pressure boundary	Carbon steel	Air – indoor (ext)	Loss of material	System Walkdown	VII.F1-10 (AP-41)	3.3.1-59	C
Heat exchanger (shell)	Pressure boundary	Carbon steel	Condensation (ext)	Loss of material	System walkdown	VII.I-11 (A-81)	3.3.1-58	A
Heat exchanger (shell)	Pressure boundary	Carbon steel	Steam > 220° F (int)	Loss of material	Water chemistry control – auxiliary systems	VII.C2-14 (A-25)	3.3.1-47	E, 305
Heat exchanger (shell)	Pressure boundary	Carbon steel	Steam > 220° F (int)	Cracking - fatigue	One-time inspection			H
Heat exchanger (shell)	Pressure boundary	Carbon steel	Treated water (int)	Loss of material	Water chemistry control – auxiliary systems	VII.C2-14 (A-25)	3.3.1-47	E, 305
Strainer housing	Pressure boundary	Carbon steel	Air – indoor (ext)	Loss of material	System Walkdown	VIII.H-7 (S-29)	3.4.1-28	A
Strainer housing	Pressure boundary	Carbon steel	Condensation (ext)	Loss of material	System walkdown	VII.I-11 (A-81)	3.3.1-58	A
Strainer housing	Pressure boundary	Carbon steel	Treated water (int)	Loss of material	Water chemistry control – auxiliary systems	VII.C2-14 (A-25)	3.3.1-47	E, 305

**VERMONT YANKEE NUCLEAR POWER STATION  
LICENSE RENEWAL APPLICATION SUPPLEMENT  
ATTACHMENT 2**

- LRA Section 3.3.2 is revised to add a new Table 3.3.2-13-49, Heater Drain (HD) System, Nonsafety-Related Components Affecting Safety-Related Systems - Summary of Aging Management Evaluation, as follows.

Component Type	Intended Function	Material	Environment	Aging Effect Requiring Management	Aging Management Programs	NUREG-1801, Vol.2 Item	Table 1 Item	Notes
Bolting	Pressure boundary	Carbon steel	Air – indoor (ext)	Loss of material	System Walkdown	VIII.H-4 (S-34)	3.4.1-22	E
Bolting	Pressure boundary	Stainless steel	Air – indoor (ext)	None	None	VIII.I-10 (SP-12)	3.4.1-41	C
Piping	Pressure boundary	Carbon steel	Air – indoor (ext)	Loss of material	System Walkdown	VIII.H-7 (S-29)	3.4.1-28	A
Piping	Pressure boundary	Carbon steel	Treated water (int)	Loss of material	Water Chemistry Control - BWR	VIII.D2-7 (S-09)	3.4.1-4	A
Pump casing	Pressure boundary	Carbon steel	Air – indoor (ext)	Loss of material	System Walkdown	VIII.H-7 (S-29)	3.4.1-28	A
Pump casing	Pressure boundary	Carbon steel	Treated water (int)	Loss of material	Water Chemistry Control - BWR	VIII.D2-7 (S-09)	3.4.1-4	A
Tank	Pressure boundary	Carbon steel	Air – indoor (ext)	Loss of material	System Walkdown	VIII.H-7 (S-29)	3.4.1-28	A
Tank	Pressure boundary	Carbon steel	Treated water (int)	Loss of material	Water Chemistry Control - BWR	VIII.D2-7 (S-09)	3.4.1-4	A
Tubing	Pressure boundary	Copper alloy < 15% Zn	Air – indoor (ext)	None	None	VIII.I-2 (SP-6)	3.4.1-41	A
Tubing	Pressure boundary	Copper alloy < 15% Zn	Treated water (int)	Loss of material	Water Chemistry Control - BWR	VIII.A-5 (SP-61)	3.4.1-15	C
Valve body	Pressure boundary	Carbon steel	Air – indoor (ext)	Loss of material	System Walkdown	VIII.H-7 (S-29)	3.4.1-28	A
Valve body	Pressure boundary	Carbon steel	Treated water (int)	Loss of material	Water Chemistry Control - BWR	VIII.D2-7 (S-09)	3.4.1-4	A

**VERMONT YANKEE NUCLEAR POWER STATION  
LICENSE RENEWAL APPLICATION SUPPLEMENT  
ATTACHMENT 2**

- LRA Section 3.3.2 is revised to add a new Table 3.3.2-13-50, Heater Vents (HV) System, Nonsafety-Related Components Affecting Safety-Related Systems - Summary of Aging Management Evaluation, as follows.

Component Type	Intended Function	Material	Environment	Aging Effect Requiring Management	Aging Management Programs	NUREG-1801, Vol.2 Item	Table 1 Item	Notes
Bolting	Pressure boundary	Carbon steel	Air – indoor (ext)	Loss of material	System Walkdown	VIII.H-4 (S-34)	3.4.1-22	E
Bolting	Pressure boundary	Stainless steel	Air – indoor (ext)	None	None	VIII.I-10 (SP-12)	3.4.1-41	C
Orifice	Pressure boundary	Carbon steel	Air – indoor (ext)	Loss of material	System Walkdown	VIII.H-7 (S-29)	3.4.1-28	A
Orifice	Pressure boundary	Carbon steel	Treated water (int)	Loss of material	Water Chemistry Control - BWR	VIII.D2-7 (S-09)	3.4.1-4	A
Piping	Pressure boundary	Carbon steel	Air – indoor (ext)	Loss of material	System Walkdown	VIII.H-7 (S-29)	3.4.1-28	A
Piping	Pressure boundary	Carbon steel	Treated water (int)	Loss of material	Water Chemistry Control - BWR	VIII.D2-7 (S-09)	3.4.1-4	A
Tank	Pressure boundary	Carbon steel	Air – indoor (ext)	Loss of material	System Walkdown	VIII.H-7 (S-29)	3.4.1-28	A
Tank	Pressure boundary	Carbon steel	Treated water (int)	Loss of material	Water Chemistry Control - BWR	VIII.D2-7 (S-09)	3.4.1-4	A
Tubing	Pressure boundary	Copper alloy < 15% Zn	Air – indoor (ext)	None	None	VIII.I-2 (SP-6)	3.4.1-41	A
Tubing	Pressure boundary	Copper alloy < 15% Zn	Treated water (int)	Loss of material	Water Chemistry Control - BWR	VIII.A-5 (SP-61)	3.4.1-15	C
Valve body	Pressure boundary	Carbon steel	Air – indoor (ext)	Loss of material	System Walkdown	VIII.H-7 (S-29)	3.4.1-28	A
Valve body	Pressure boundary	Carbon steel	Treated water (int)	Loss of material	Water Chemistry Control - BWR	VIII.D2-7 (S-09)	3.4.1-4	A

**VERMONT YANKEE NUCLEAR POWER STATION  
LICENSE RENEWAL APPLICATION SUPPLEMENT  
ATTACHMENT 2**

- LRA Section 3.3.2, Table 3.3.2-13-21, Heating, Ventilation, and Air Conditioning (HVAC) System, Nonsafety-Related Components Affecting Safety-Related Systems - Summary of Aging Management Evaluation, is revised adding the following line items.

Component Type	Intended Function	Material	Environment	Aging Effect Requiring Management	Aging Management Programs	NUREG-1801, Vol.2 Item	Table 1 Item	Notes
Duct	Pressure boundary	Carbon steel	Air – indoor (ext)	Loss of material	System Walkdown	VII.I-8 (A-77)	3.3.1-58	A
Duct	Pressure boundary	Carbon steel	Air – indoor (int)	Loss of material	System Walkdown	VII.I-8 (A-77)	3.3.1-58	A
Fan housing	Pressure boundary	Carbon steel	Air – indoor (ext)	Loss of material	System Walkdown	VII.I-8 (A-77)	3.3.1-58	A
Fan housing	Pressure boundary	Carbon steel	Air – indoor (int)	Loss of material	System Walkdown	VII.I-8 (A-77)	3.3.1-58	A
Heat exchanger (shell)	Pressure boundary	Carbon steel	Condensation (ext)	Loss of material	System Walkdown	VII.I-11 (A-81)	3.3.1-58	A
Heat exchanger (shell)	Pressure boundary	Carbon steel	Raw water (int)	Loss of material	Service water integrity	VII.C1-19 (A-38)	3.3.1-76	D
Pump casing	Pressure boundary	Carbon steel	Air – indoor (ext)	Loss of material	System Walkdown	VII.I-8 (A-77)	3.3.1-58	A
Pump casing	Pressure boundary	Carbon steel	Raw water (int)	Loss of material	Service water integrity	VII.C1-19 (A-38)	3.3.1-76	D
Strainer housing	Pressure boundary	Carbon steel	Air – indoor (ext)	Loss of material	System Walkdown	VII.I-8 (A-77)	3.3.1-58	A
Strainer housing	Pressure boundary	Carbon steel	Raw water (int)	Loss of material	Service water integrity	VII.C1-19 (A-38)	3.3.1-76	D

**VERMONT YANKEE NUCLEAR POWER STATION  
LICENSE RENEWAL APPLICATION SUPPLEMENT  
ATTACHMENT 2**

- LRA Section 3.3.2 is revised to add a new Table 3.3.2-13-51, Hydrogen Water Chemistry (HWC) System, Nonsafety-Related Components Affecting Safety-Related Systems - Summary of Aging Management Evaluation, as follows.

Component Type	Intended Function	Material	Environment	Aging Effect Requiring Management	Aging Management Programs	NUREG-1801, Vol.2 Item	Table 1 Item	Notes
Bolting	Pressure boundary	Carbon steel	Air – indoor (ext)	Loss of material	System Walkdown	VII.I-4 (AP-27)	3.3.1-43	E
Bolting	Pressure boundary	Stainless steel	Air – indoor (ext)	None	None	VII.J-15 (AP-17)	3.3.1-94	C
Piping	Pressure boundary	Carbon steel	Air – indoor (ext)	Loss of material	System Walkdown	VII.I-8 (A-77)	3.3.1-58	A
Piping	Pressure boundary	Carbon steel	Treated water (int)	Loss of material	Water Chemistry Control - BWR	VII.E3-18 (A-35)	3.3.1-17	C
Tubing	Pressure boundary	Copper alloy < 15% Zn	Air – indoor (ext)	None	None	V.F-3 (EP-10)	3.2.1-53	C
Tubing	Pressure boundary	Copper alloy < 15% Zn	Treated water (int)	Loss of material	Water Chemistry Control - BWR	VII.E3-9 (AP-64)	3.3.1-31	C
Valve body	Pressure boundary	Carbon steel	Air – indoor (ext)	Loss of material	System Walkdown	VII.I-8 (A-77)	3.3.1-58	A
Valve body	Pressure boundary	Carbon steel	Treated water (int)	Loss of material	Water Chemistry Control - BWR	VIII.E-33 (S-09)	3.4.1-4	A

- LRA Section 3.3.2, Table 3.3.2-13-22, Instrument Air (IA) System, Nonsafety-Related Components Affecting Safety-Related Systems - Summary of Aging Management Evaluation, is revised to delete the following line items.

Component Type	Intended Function	Material	Environment	Aging Effect Requiring Management	Aging Management Programs	NUREG-1801, Vol.2 Item	Table 1 Item	Notes
Compressor housing	Pressure boundary	Carbon steel	Air – indoor (ext)	Loss of material	System Walkdown	VII.D-3 (A-80)	3.3.1-57	A
Compressor housing	Pressure boundary	Carbon steel	Treated water (int)	Loss of material	Water Chemistry Control – Closed-Cooling Water	VII.C2-14 (A-25)	3.3.1-47	D
Piping	Pressure boundary	Carbon steel	Lube oil (int)	Loss of material	Oil Analysis	VII.C1-17 (AP-30)	3.3.1-14	E
Piping	Pressure boundary	Carbon steel	Treated water (int)	Loss of material	Water Chemistry Control – BWR	VII.E3-18 (A-35)	3.3.1-17	C

**VERMONT YANKEE NUCLEAR POWER STATION  
LICENSE RENEWAL APPLICATION SUPPLEMENT  
ATTACHMENT 2**

- LRA Section 3.3.2 is revised to add a new Table 3.3.2-13-52, Main Steam (MS) System, Nonsafety-Related Components Affecting Safety-Related Systems - Summary of Aging Management Evaluation, as follows.

Component Type	Intended Function	Material	Environment	Aging Effect Requiring Management	Aging Management Programs	NUREG-1801, Vol.2 Item	Table 1 Item	Notes
Bolting	Pressure boundary	Carbon steel	Air – indoor (ext)	Loss of material	System Walkdown	VIII.H-4 (S-34)	3.4.1-22	E
Bolting	Pressure boundary	Stainless steel	Air – indoor (ext)	None	None	VIII.I-10 (SP-12)	3.4.1-41	C
Heat exchanger (shell)	Pressure boundary	Carbon steel	Air – indoor (ext)	Loss of material	System Walkdown	VII.F1-10 (AP-41)	3.3.1-59	C
Heat exchanger (shell)	Pressure boundary	Carbon steel	Steam > 270°F (int)	Cracking - fatigue	One-Time Inspection			H
Heat exchanger (shell)	Pressure boundary	Carbon steel	Steam > 270°F (int)	Loss of material	Water Chemistry Control - BWR	VII.E3-18 (A-35)	3.3.1-17	C
Orifice	Pressure boundary	Carbon steel	Air – indoor (ext)	Loss of material	System Walkdown	VIII.H-7 (S-29)	3.4.1-28	A
Orifice	Pressure boundary	Carbon steel	Steam > 270°F (int)	Cracking – fatigue	TLAA – metal fatigue	VIII.B2-5 (S-08)	3.4.1-1	A
Orifice	Pressure boundary	Carbon steel	Steam > 270°F (int)	Loss of material	Flow accelerated corrosion	VIII.B2-4 (S-15)	3.4.1-29	A
Orifice	Pressure boundary	Carbon steel	Steam > 270°F (int)	Loss of material	Water Chemistry Control - BWR	VIII.B2-3 (S-05)	3.4.1-37	A
Piping	Pressure boundary	Carbon steel	Air – indoor (ext)	Loss of material	System Walkdown	VIII.H-7 (S-29)	3.4.1-28	A
Piping	Pressure boundary	Carbon steel	Steam > 270°F (int)	Cracking - fatigue	TLAA – metal fatigue	VIII.B2-5 (S-08)	3.4.1-1	A
Piping	Pressure boundary	Carbon steel	Steam > 270°F (int)	Loss of material	Flow accelerated corrosion	VIII.B2-4 (S-15)	3.4.1-29	A
Piping	Pressure boundary	Carbon steel	Steam > 270°F (int)	Loss of material	Water Chemistry Control - BWR	VIII.B2-3 (S-05)	3.4.1-37	A
Piping	Pressure boundary	Carbon steel	Treated water (int)	Loss of material	Water Chemistry Control - BWR	VIII.D2-7 (S-09)	3.4.1-4	C
Strainer housing	Pressure boundary	Carbon steel	Air – indoor (ext)	Loss of material	System Walkdown	VIII.H-7 (S-29)	3.4.1-28	A
Strainer housing	Pressure boundary	Carbon steel	Treated water (int)	Loss of material	Water Chemistry Control - BWR	VIII.D2-7 (S-09)	3.4.1-4	C
Tubing	Pressure boundary	Copper alloy < 15% Zn	Air – indoor (ext)	None	None	V.F-3 (EP-10)	3.2.1-53	C
Tubing	Pressure boundary	Copper alloy < 15% Zn	Steam > 270°F (int)	Loss of material	Water Chemistry Control - BWR	VII.E3-9 (AP-64)	3.3.1-31	C

**VERMONT YANKEE NUCLEAR POWER STATION  
LICENSE RENEWAL APPLICATION SUPPLEMENT  
ATTACHMENT 2**

Tubing	Pressure boundary	Copper alloy < 15% Zn	Treated water (int)	Loss of material	Water Chemistry Control - BWR	VII.E3-9 (AP-64)	3.3.1-31	C
Tubing	Pressure boundary	Stainless steel	Air – indoor (ext)	None	None	VIII.I-10 (SP-12)	3.4.1-41	A
Tubing	Pressure boundary	Stainless steel	Steam > 270°F (int)	Cracking – fatigue	TLAA – metal fatigue			H
Tubing	Pressure boundary	Stainless steel	Steam > 270°F (int)	Loss of material	Water chemistry control – BWR	VIII.B2-2 (SP-46)	3.4.1-37	A
Tubing	Pressure boundary	Stainless steel	Steam > 270°f (int)	Cracking	Water Chemistry Control - BWR	VIII.B2-1 (SP-45)	3.4.1-13	A
Valve body	Pressure boundary	Carbon steel	Air – indoor (ext)	Loss of material	System Walkdown	VIII.H-7 (S-29)	3.4.1-28	A
Valve body	Pressure boundary	Carbon steel	Steam > 270°F (int)	Cracking - fatigue	TLAA – metal fatigue	VIII.B2-5 (S-08)	3.4.1-1	A
Valve body	Pressure boundary	Carbon steel	Steam > 270°F (int)	Loss of material	Flow accelerated corrosion	VIII.B2-4 (S-15)	3.4.1-29	A
Valve body	Pressure boundary	Carbon steel	Steam > 270°F (int)	Loss of material	Water Chemistry Control - BWR	VIII.B2-3 (S-05)	3.4.1-37	A
Valve body	Pressure boundary	Carbon steel	Treated water (int)	Loss of material	Water Chemistry Control - BWR	VIII.D2-7 (S-09)	3.4.1-4	C

**VERMONT YANKEE NUCLEAR POWER STATION  
LICENSE RENEWAL APPLICATION SUPPLEMENT  
ATTACHMENT 2**

- LRA Section 3.3.2 is revised to add a new Table 3.3.2-13-53, Make-up Demineralizer (MUD) System, Nonsafety-Related Components Affecting Safety-Related Systems - Summary of Aging Management Evaluation, as follows.

Component Type	Intended Function	Material	Environment	Aging Effect Requiring Management	Aging Management Programs	NUREG-1801, Vol.2 Item	Table 1 Item	Notes
Bolting	Pressure boundary	Carbon steel	Air – indoor (ext)	Loss of material	System Walkdown	VII.I-4 (AP-27)	3.3.1-43	E
Bolting	Pressure boundary	Stainless steel	Air – indoor (ext)	None	None	VII.J-15 (AP-17)	3.3.1-94	C
Filter housing	Pressure boundary	Carbon steel	Air – indoor (ext)	Loss of material	System Walkdown	VII.I-8 (A-77)	3.3.1-58	A
Filter housing	Pressure boundary	Carbon steel	Treated water (int)	Loss of material	Water Chemistry Control - BWR	VII.E3-18 (A-35)	3.3.1-17	C
Piping	Pressure boundary	Carbon steel	Air – indoor (ext)	Loss of material	System Walkdown	VII.I-8 (A-77)	3.3.1-58	A
Piping	Pressure boundary	Carbon steel	Treated water (int)	Loss of material	Water Chemistry Control - BWR	VII.E3-18 (A-35)	3.3.1-17	C
Pump casing	Pressure boundary	Carbon steel	Air – indoor (ext)	Loss of material	System Walkdown	VII.I-8 (A-77)	3.3.1-58	A
Pump casing	Pressure boundary	Carbon steel	Treated water (int)	Loss of material	Water Chemistry Control - BWR	VII.E3-18 (A-35)	3.3.1-17	C
Tank	Pressure boundary	Carbon steel	Air – indoor (ext)	Loss of material	System Walkdown	VII.I-8 (A-77)	3.3.1-58	A
Tank	Pressure boundary	Carbon steel	Treated water (int)	Loss of material	Water Chemistry Control - BWR	VII.E3-18 (A-35)	3.3.1-17	C
Tubing	Pressure boundary	Copper alloy < 15% Zn	Air – indoor (ext)	None	None	V.F-3 (EP-10)	3.2.1-53	C
Tubing	Pressure boundary	Copper alloy < 15% Zn	Treated water (int)	Loss of material	Water Chemistry Control - BWR	VII.E3-9 AP-64)	3.3.1-31	C
Valve body	Pressure boundary	Carbon steel	Air – indoor (ext)	Loss of material	System Walkdown	VII.I-8 (A-77)	3.3.1-58	A
Valve body	Pressure boundary	Carbon steel	Treated water (int)	Loss of material	Water Chemistry Control - BWR	VIII.E-33 (S-09)	3.4.1-4	A



**VERMONT YANKEE NUCLEAR POWER STATION  
LICENSE RENEWAL APPLICATION SUPPLEMENT  
ATTACHMENT 2**

- LRA Section 3.3.2, Table 3.3.2-13-29, Potable Water (PW) System, Nonsafety-Related Components Affecting Safety-Related Systems - Summary of Aging Management Evaluation, is revised adding the following line items.

Component Type	Intended Function	Material	Environment	Aging Effect Requiring Management	Aging Management Programs	NUREG-1801, Vol.2 Item	Table 1 Item	Notes
Filter housing	Pressure boundary	Carbon steel	Air – indoor (ext)	Loss of material	System Walkdown	VII.I-8 (A-77)	3.3.1-58	A
Filter housing	Pressure boundary	Carbon steel	Untreated water (int)	Loss of material	Periodic Surveillance and Preventive Maintenance	VII.G-24 (A-33)	3.3.1-68	E
Strainer housing	Pressure boundary	Carbon steel	Air – indoor (ext)	Loss of material	System Walkdown	VII.I-8 (A-77)	3.3.1-58	A
Strainer housing	Pressure boundary	Carbon steel	Untreated water (int)	Loss of material	Periodic Surveillance and Preventive Maintenance	VII.G-24 (A-33)	3.3.1-68	E
Tank	Pressure boundary	Carbon steel	Air – indoor (ext)	Loss of material	System Walkdown	VII.I-8 (A-77)	3.3.1-58	A
Tank	Pressure boundary	Carbon steel	Untreated water (int)	Loss of material	Periodic Surveillance and Preventive Maintenance	VII.G-24 (A-33)	3.3.1-68	E
Valve body	Pressure boundary	Carbon steel	Air – indoor (ext)	Loss of material	System Walkdown	VII.I-8 (A-77)	3.3.1-58	A
Valve body	Pressure boundary	Carbon steel	Untreated water (int)	Loss of material	Periodic Surveillance and Preventive Maintenance	VII.G-24 (A-33)	3.3.1-68	E

**VERMONT YANKEE NUCLEAR POWER STATION  
LICENSE RENEWAL APPLICATION SUPPLEMENT  
ATTACHMENT 2**

- LRA Section 3.3.2 is revised to add a new Table 3.3.2-13-54, Service Air (SA) System, Nonsafety-Related Components Affecting Safety-Related Systems - Summary of Aging Management Evaluation, as follows.

Component Type	Intended Function	Material	Environment	Aging Effect Requiring Management	Aging Management Programs	NUREG-1801, Vol.2 Item	Table 1 Item	Notes
Bolting	Pressure boundary	Carbon steel	Air – indoor (ext)	Loss of material	System Walkdown	VII.I-4 (AP-27)	3.3.1-43	E
Bolting	Pressure boundary	Stainless steel	Air – indoor (ext)	None	None	VII.J-15 (AP-17)	3.3.1-94	C
Piping	Pressure boundary	Carbon steel	Air – indoor (ext)	Loss of material	System Walkdown	VII.I-8 (A-77)	3.3.1-58	A
Piping	Pressure boundary	Carbon steel	Air – indoor (int)	Loss of material	System Walkdown	VII.I-8 (A-77)	3.3.1-58	A
Tank	Pressure boundary	Carbon steel	Air – indoor (ext)	Loss of material	System Walkdown	VII.I-8 (A-77)	3.3.1-58	A
Tank	Pressure boundary	Carbon steel	Untreated water (int)	Loss of material	Periodic Surveillance and Preventive Maintenance	VII.G-24 (A-33)	3.3.1-68	E
Trap	Pressure boundary	Carbon steel	Air – indoor (ext)	Loss of material	System Walkdown	VII.I-8 (A-77)	3.3.1-58	A
Trap	Pressure boundary	Carbon steel	Untreated water (int)	Loss of material	Periodic Surveillance and Preventive Maintenance	VII.G-24 (A-33)	3.3.1-68	E
Valve body	Pressure boundary	Carbon steel	Air – indoor (ext)	Loss of material	System Walkdown	VII.I-8 (A-77)	3.3.1-58	A
Valve body	Pressure boundary	Carbon steel	Air – indoor (int)	Loss of material	System Walkdown	VII.I-8 (A-77)	3.3.1-58	A
Valve body	Pressure boundary	Carbon steel	Untreated water (int)	Loss of material	Periodic Surveillance and Preventive Maintenance	VII.G-24 (A-33)	3.3.1-68	E

**VERMONT YANKEE NUCLEAR POWER STATION  
LICENSE RENEWAL APPLICATION SUPPLEMENT  
ATTACHMENT 2**

- LRA Section 3.3.2, Table 3.3.2-13-39, Stator Cooling (SC) System, Nonsafety-Related Components Affecting Safety-Related Systems - Summary of Aging Management Evaluation, is revised adding the following line items.

Component Type	Intended Function	Material	Environment	Aging Effect Requiring Management	Aging Management Programs	NUREG-1801, Vol.2 Item	Table 1 Item	Notes
Bolting	Pressure boundary	Carbon steel	Air – indoor (ext)	Loss of material	System Walkdown	VII.I-4 (AP-27)	3.3.1-43	E
Bolting	Pressure boundary	Stainless steel	Air – indoor (ext)	None	None	VII.J-15 (AP-17)	3.3.1-94	C
Filter housing	Pressure boundary	Carbon steel	Air – indoor (ext)	Loss of material	System Walkdown	VII.I-8 (A-77)	3.3.1-58	A
Filter housing	Pressure boundary	Carbon steel	Treated water (int)	Loss of material	Water Chemistry Control – Auxiliary Systems	VII.C2-14 (A-25)	3.3.1-47	E
Heat exchanger (shell)	Pressure boundary	Carbon steel	Air – indoor (ext)	Loss of material	System Walkdown	VII.F1-10 (AP-41)	3.3.1-59	C
Heat exchanger (shell)	Pressure boundary	Carbon steel	Treated water (int)	Loss of material	Water Chemistry Control – Auxiliary Systems	VII.C2-14 (A-25)	3.3.1-47	E
Pump casing	Pressure boundary	Carbon steel	Air – indoor (ext)	Loss of material	System Walkdown	VII.I-8 (A-77)	3.3.1-58	A
Pump casing	Pressure boundary	Carbon steel	Treated water (int)	Loss of material	Water Chemistry Control – Auxiliary Systems	VII.C2-14 (A-25)	3.3.1-47	E
Strainer housing	Pressure boundary	Carbon steel	Air – indoor (ext)	Loss of material	System Walkdown	VII.I-8 (A-77)	3.3.1-58	A
Strainer housing	Pressure boundary	Carbon steel	Treated water (int)	Loss of material	Water Chemistry Control – Auxiliary Systems	VII.C2-14 (A-25)	3.3.1-47	E
Tank	Pressure boundary	Carbon steel	Air – indoor (ext)	Loss of material	System Walkdown	VII.I-8 (A-77)	3.3.1-58	A
Tank	Pressure boundary	Carbon steel	Treated water (int)	Loss of material	Water Chemistry Control – Auxiliary Systems	VII.C2-14 (A-25)	3.3.1-47	E
Tubing	Pressure boundary	Copper alloy < 15% Zn	Air – indoor (ext)	None	None	V.F-3 (EP-10)	3.2.1-53	C
Tubing	Pressure boundary	Copper alloy < 15% Zn	Treated water (int)	Loss of material	Water Chemistry Control – Auxiliary Systems	VII.C2-14 (A-25)	3.3.1-47	E

**VERMONT YANKEE NUCLEAR POWER STATION  
LICENSE RENEWAL APPLICATION SUPPLEMENT  
ATTACHMENT 2**

- LRA Section 3.3.2 is revised to add a new Table 3.3.2-13-55, Seal Oil (SO) System, Nonsafety-Related Components Affecting Safety-Related Systems - Summary of Aging Management Evaluation, as follows.

Component Type	Intended Function	Material	Environment	Aging Effect Requiring Management	Aging Management Programs	NUREG-1801, Vol.2 Item	Table 1 Item	Notes
Bolting	Pressure boundary	Carbon steel	Air – indoor (ext)	Loss of material	System Walkdown	VII.I-4 (AP-27)	3.3.1-43	E
Bolting	Pressure boundary	Stainless steel	Air – indoor (ext)	None	None	VII.J-15 (AP-17)	3.3.1-94	C
Filter housing	Pressure boundary	Carbon steel	Air – indoor (ext)	Loss of material	System Walkdown	VII.I-8 (A-77)	3.3.1-58	A
Filter housing	Pressure boundary	Carbon steel	Lube oil (int)	Loss of material	Oil analysis	VII.G-22 (AP-30)	3.3.1-14	E
Piping	Pressure boundary	Carbon steel	Air – indoor (ext)	Loss of material	System Walkdown	VII.I-8 (A-77)	3.3.1-58	A
Piping	Pressure boundary	Carbon steel	Lube oil (int)	Loss of material	Oil analysis	VII.G-22 (AP-30)	3.3.1-14	E
Pump casing	Pressure boundary	Carbon steel	Air – indoor (ext)	Loss of material	System Walkdown	VII.I-8 (A-77)	3.3.1-58	A
Pump casing	Pressure boundary	Carbon steel	Lube oil (int)	Loss of material	Oil analysis	VII.G-22 (AP-30)	3.3.1-14	E
Sight glass	Pressure boundary	Carbon steel	Air – indoor (ext)	Loss of material	System Walkdown	VII.I-8 (A-77)	3.3.1-58	A
Sight glass	Pressure boundary	Carbon steel	Lube oil (int)	Loss of material	Oil analysis	VII.G-22 (AP-30)	3.3.1-14	E
Sight glass	Pressure boundary	Glass	Air – indoor (ext)	None	None	VII.J-8 (AP-14)	3.3.1-93	A
Sight glass	Pressure boundary	Glass	Lube oil (int)	None	None	VII.J-10 (AP-15)	3.3.1-93	A
Tank	Pressure boundary	Carbon steel	Air – indoor (ext)	Loss of material	System Walkdown	VII.I-8 (A-77)	3.3.1-58	A
Tank	Pressure boundary	Carbon steel	Lube oil (int)	Loss of material	Oil analysis	VII.G-22 (AP-30)	3.3.1-14	E
Tubing	Pressure boundary	Copper alloy < 15% Zn	Air – indoor (ext)	None	None	V.F-3 (EP-10)	3.2.1-53	C
Tubing	Pressure boundary	Copper alloy < 15% Zn	Lube oil (int)	Loss of material	Oil analysis	VII.G-22 (AP-30)	3.3.1-14	E
Valve body	Pressure boundary	Carbon steel	Air – indoor (ext)	Loss of material	System Walkdown	VII.I-8 (A-77)	3.3.1-58	A
Valve body	Pressure boundary	Carbon steel	Lube oil (int)	Loss of material	Oil analysis	VII.G-22 (AP-30)	3.3.1-14	E

**VERMONT YANKEE NUCLEAR POWER STATION  
LICENSE RENEWAL APPLICATION SUPPLEMENT  
ATTACHMENT 2**

- LRA Section 3.3.2, Table 3.3.2-13-41, Sampling (SPL) System, Nonsafety-Related Components Affecting Safety-Related Systems - Summary of Aging Management Evaluation, is revised adding the following line items.

Component Type	Intended Function	Material	Environment	Aging Effect Requiring Management	Aging Management Programs	NUREG-1801, Vol.2 Item	Table 1 Item	Notes
Strainer housing	Pressure boundary	Carbon steel	Air – indoor (ext)	Loss of material	System Walkdown	VIII.H-7 (S-29)	3.4.1-28	A
Strainer housing	Pressure boundary	Carbon steel	Treated water (int)	Loss of material	Water Chemistry Control - BWR	VIII.E-33 (S-09)	3.4.1-4	A
Strainer housing	Pressure boundary	Stainless steel	Air – indoor (ext)	None	None	VII.J-15 (AP-17)	3.3.1-94	A
Strainer housing	Pressure boundary	Stainless steel	Treated water (int)	Loss of material	Water Chemistry Control - BWR	VIII.E-33 (S-09)	3.4.1-4	A

- LRA Section 3.3.2, Table 3.3.2-13-42, Service Water (SW) System, Nonsafety-Related Components Affecting Safety-Related Systems - Summary of Aging Management Evaluation, is revised adding the following line items.

Component Type	Intended Function	Material	Environment	Aging Effect Requiring Management	Aging Management Programs	NUREG-1801, Vol.2 Item	Table 1 Item	Notes
Heat exchanger (shell)	Pressure boundary	Carbon steel	Air – indoor (ext)	Loss of material	System Walkdown	VII.F1-10 (AP-41)	3.3.1-59	C
Heat exchanger (shell)	Pressure boundary	Carbon steel	Condensation (ext)	Loss of material	System walkdown	VII.I-11 (A-81)	3.3.1-58	A
Heat exchanger (shell)	Pressure boundary	Carbon steel	Raw water (int)	Loss of material	Service water integrity	VII.C1-5 (A-64)	3.3.1-77	B
Heat exchanger (shell)	Pressure boundary	Stainless steel	Air – indoor (ext)	None	None	VII.J-15 (AP-17)	3.3.1-94	A
Heat exchanger (shell)	Pressure boundary	Stainless steel	Condensation (ext)	Loss of material	System walkdown	VII.F1-1 (A-09)	3.3.1-27	E
Heat exchanger (shell)	Pressure boundary	Stainless steel	Raw water (int)	Loss of material	Service water integrity	VII.C1-15 (A-54)	3.3.1-79	D
Pump casing	Pressure boundary	Carbon steel	Condensation (ext)	Loss of material	System walkdown	VII.I-11 (A-81)	3.3.1-58	A
Pump casing	Pressure boundary	Stainless steel	Air – indoor (ext)	None	None	VII.J-15 (AP-17)	3.3.1-94	A
Pump casing	Pressure boundary	Stainless steel	Condensation (ext)	Loss of material	System walkdown	VII.F1-1 (A-09)	3.3.1-27	E
Pump casing	Pressure boundary	Stainless steel	Raw water (int)	Loss of material	Service water integrity	VII.C1-15 (A-54)	3.3.1-79	D

**VERMONT YANKEE NUCLEAR POWER STATION  
LICENSE RENEWAL APPLICATION SUPPLEMENT  
ATTACHMENT 2**

- LRA Section 3.3.2 is revised to add a new Table 3.3.2-13-56, Turbine Building Closed Cooling Water (TBCCW) System, Nonsafety-Related Components Affecting Safety-Related Systems - Summary of Aging Management Evaluation, as follows.

Component Type	Intended Function	Material	Environment	Aging Effect Requiring Management	Aging Management Programs	NUREG-1801, Vol.2 Item	Table 1 Item	Notes
Bolting	Pressure boundary	Carbon steel	Air – indoor (ext)	Loss of material	System Walkdown	VII.I-4 (AP-27)	3.3.1-43	E
Bolting	Pressure boundary	Stainless steel	Air – indoor (ext)	None	None	VII.J-15 (AP-17)	3.3.1-94	C
Heat exchanger (shell)	Pressure boundary	Carbon steel	Air – indoor (ext)	Loss of material	System Walkdown	VII.F1-10 (AP-41)	3.3.1-59	C
Heat exchanger (shell)	Pressure boundary	Carbon steel	Treated water (int)	Loss of material	Water Chemistry Control – Closed Cooling Water	VII.C2-14 (A-25)	3.3.1-47	B
Piping	Pressure boundary	Carbon steel	Air – indoor (ext)	Loss of material	System Walkdown	VII.I-8 (A-77)	3.3.1-58	A
Piping	Pressure boundary	Carbon steel	Treated water (int)	Loss of material	Water Chemistry Control – Closed Cooling Water	VII.C2-14 (A-25)	3.3.1-47	B
Pump casing	Pressure boundary	Carbon steel	Air – indoor (ext)	Loss of material	System Walkdown	VII.I-8 (A-77)	3.3.1-58	A
Pump casing	Pressure boundary	Carbon steel	Treated water (int)	Loss of material	Water Chemistry Control – Closed Cooling Water	VII.C2-14 (A-25)	3.3.1-47	B
Tank	Pressure boundary	Carbon steel	Air – indoor (ext)	Loss of material	System Walkdown	VII.I-8 (A-77)	3.3.1-58	A
Tank	Pressure boundary	Carbon steel	Treated water (int)	Loss of material	Water Chemistry Control – Closed Cooling Water	VII.C2-14 (A-25)	3.3.1-47	B
Tubing	Pressure boundary	Copper alloy < 15% Zn	Air – indoor (ext)	None	None	V.F-3 (EP-10)	3.2.1-53	C
Tubing	Pressure boundary	Copper alloy < 15% Zn	Treated water (int)	Loss of material	Water Chemistry Control – Closed Cooling Water	VII.C2-14 (A-25)	3.3.1-47	B
Valve body	Pressure boundary	Carbon steel	Air – indoor (ext)	Loss of material	System Walkdown	VII.I-8 (A-77)	3.3.1-58	A
Valve body	Pressure boundary	Carbon steel	Treated water (int)	Loss of material	Water Chemistry Control – Closed Cooling Water	VII.C2-14 (A-25)	3.3.1-47	B

**VERMONT YANKEE NUCLEAR POWER STATION  
LICENSE RENEWAL APPLICATION SUPPLEMENT  
ATTACHMENT 2**

- LRA Section 3.3.2 is revised to add a new Table 3.3.2-13-57, Main Turbine Generator (TG) System, Nonsafety-Related Components Affecting Safety-Related Systems - Summary of Aging Management Evaluation, as follows.

Component Type	Intended Function	Material	Environment	Aging Effect Requiring Management	Aging Management Programs	NUREG-1801, Vol.2 Item	Table 1 Item	Notes
Bolting	Pressure boundary	Carbon steel	Air – indoor (ext)	Loss of material	System Walkdown	VII.I-4 (AP-27)	3.3.1-43	E
Bolting	Pressure boundary	Stainless steel	Air – indoor (ext)	None	None	VII.J-15 (AP-17)	3.3.1-94	C
Filter housing	Pressure boundary	Carbon steel	Air – indoor (ext)	Loss of material	System Walkdown	VII.I-8 (A-77)	3.3.1-58	A
Filter housing	Pressure boundary	Carbon steel	Steam > 270°F (int)	Cracking – fatigue	TLAA – metal fatigue	VIII.B2-5 (S-08)	3.4.1-1	C
Filter housing	Pressure boundary	Carbon steel	Steam > 270°F (int)	Loss of material	Water Chemistry Control – BWR	VIII.A-15 (S-04)	3.4.1-2	C
Piping	Pressure boundary	Carbon steel	Air – indoor (ext)	Loss of material	System Walkdown	VII.I-8 (A-77)	3.3.1-58	A
Piping	Pressure boundary	Carbon steel	Steam > 270°F (int)	Cracking – fatigue	TLAA – metal fatigue	VIII.B2-5 (S-08)	3.4.1-1	C
Piping	Pressure boundary	Carbon steel	Steam > 270°F (int)	Loss of material	Flow Accelerated Corrosion	VIII.A-17 (S-15)	3.4.1-29	C
Piping	Pressure boundary	Carbon steel	Steam > 270°F (int)	Loss of material	Water Chemistry Control – BWR	VIII.A-15 (S-04)	3.4.1-2	C
Pump casing	Pressure boundary	Carbon steel	Air – indoor (ext)	Loss of material	System Walkdown	VII.I-8 (A-77)	3.3.1-58	A
Pump casing	Pressure boundary	Carbon steel	Treated water > 270°F (int)	Cracking - fatigue	One-time inspection			H
Pump casing	Pressure boundary	Carbon steel	Treated water > 270°F (int)	Loss of material	Water Chemistry Control - BWR	VII.E3-18 (A-35)	3.3.1-17	C
Turbine casing	Pressure boundary	Carbon steel	Air – indoor (ext)	Loss of material	System Walkdown	VII.I-8 (A-77)	3.3.1-58	A
Turbine casing	Pressure boundary	Carbon steel	Steam > 270°F (int)	Cracking - fatigue	One-time inspection			H
Turbine casing	Pressure boundary	Carbon steel	Steam > 270°F (int)	Loss of material	Water Chemistry Control - BWR	VII.E3-18 (A-35)	3.3.1-17	C
Turbine casing	Pressure boundary	Carbon steel	Treated water (int)	Loss of material	Water Chemistry Control - BWR	VII.E3-18 (A-35)	3.3.1-17	C
Tubing	Pressure boundary	Copper alloy < 15% Zn	Air – indoor (ext)	None	None	V.F-3 (EP-10)	3.2.1-53	C
Tubing	Pressure boundary	Copper alloy < 15% Zn	Steam > 270°F (int)	Loss of material	Water Chemistry Control - BWR	VII.E3-9 (AP-64)	3.3.1-31	C
Tubing	Pressure boundary	Copper alloy < 15% Zn	Treated water (int)	Loss of material	Water Chemistry Control - BWR	VII.E3-9 (AP-64)	3.3.1-31	C
Valve body	Pressure boundary	Carbon steel	Air – indoor (ext)	Loss of material	System Walkdown	VII.I-8 (A-77)	3.3.1-58	A

**VERMONT YANKEE NUCLEAR POWER STATION  
LICENSE RENEWAL APPLICATION SUPPLEMENT  
ATTACHMENT 2**

Valve body	Pressure boundary	Carbon steel	Steam > 270°F (int)	Cracking - fatigue	TLAA - metal fatigue	VIII.B2-5 (S-08)	3.4.1-1	C
Valve body	Pressure boundary	Carbon steel	Steam > 270°F (int)	Loss of material	Flow accelerated corrosion	VIII.A-17 (S-15)	3.4.1-29	C
Valve body	Pressure boundary	Carbon steel	Steam > 270°F (int)	Loss of material	Water Chemistry Control - BWR	VIII.A-15 (S-04)	3.4.1-2	C
Valve body	Pressure boundary	Carbon steel	Treated water (int)	Loss of material	Water Chemistry Control - BWR	VIII.E-33 (S-09)	3.4.1-4	A



**VERMONT YANKEE NUCLEAR POWER STATION  
LICENSE RENEWAL APPLICATION SUPPLEMENT  
ATTACHMENT 2**

- LRA Section 3.3.2 is revised to add a new Table 3.3.2-13-58, Turbine Lube Oil (TLO) System, Nonsafety-Related Components Affecting Safety-Related Systems - Summary of Aging Management Evaluation, as follows.

Component Type	Intended Function	Material	Environment	Aging Effect Requiring Management	Aging Management Programs	NUREG-1801, Vol.2 Item	Table 1 Item	Notes
Bolting	Pressure boundary	Carbon steel	Air – indoor (ext)	Loss of material	System Walkdown	VII.I-4 (AP-27)	3.3.1-43	E
Bolting	Pressure boundary	Stainless steel	Air – indoor (ext)	None	None	VII.J-15 (AP-17)	3.3.1-94	C
Filter housing	Pressure boundary	Carbon steel	Air – indoor (ext)	Loss of material	System Walkdown	VII.I-8 (A-77)	3.3.1-58	A
Filter housing	Pressure boundary	Carbon steel	Lube oil (int)	Loss of material	Oil analysis	VII.G-22 (AP-30)	3.3.1-14	E
Heat exchanger (shell)	Pressure boundary	Carbon steel	Air – indoor (ext)	Loss of material	System Walkdown	VII.F1-10 (AP-41)	3.3.1-59	C
Heat exchanger (shell)	Pressure boundary	Carbon steel	Lube oil (int)	Loss of material	Oil analysis	VII.G-22 (AP-30)	3.3.1-14	E
Piping	Pressure boundary	Carbon steel	Air – indoor (ext)	Loss of material	System Walkdown	VII.I-8 (A-77)	3.3.1-58	A
Piping	Pressure boundary	Carbon steel	Lube oil (int)	Loss of material	Oil analysis	VII.G-22 (AP-30)	3.3.1-14	E
Pump casing	Pressure boundary	Carbon steel	Air – indoor (ext)	Loss of material	System Walkdown	VII.I-8 (A-77)	3.3.1-58	A
Pump casing	Pressure boundary	Carbon steel	Lube oil (int)	Loss of material	Oil analysis	VII.G-22 (AP-30)	3.3.1-14	E
Strainer housing	Pressure boundary	Carbon steel	Air – indoor (ext)	Loss of material	System Walkdown	VIII.H-7 (S-29)	3.4.1-28	A
Strainer housing	Pressure boundary	Carbon steel	Lube oil (int)	Loss of material	Oil analysis	VII.G-22 (AP-30)	3.3.1-14	E
Tank	Pressure boundary	Carbon steel	Air – indoor (ext)	Loss of material	System Walkdown	VIII.H-7 (S-29)	3.4.1-28	A
Tank	Pressure boundary	Carbon steel	Lube oil (int)	Loss of material	Oil analysis	VII.G-22 (AP-30)	3.3.1-14	E
Tubing	Pressure boundary	Copper alloy < 15% Zn	Air – indoor (ext)	None	None	V.F-3 (EP-10)	3.2.1-53	C
Tubing	Pressure boundary	Copper alloy < 15% Zn	Lube oil (int)	Loss of material	Oil analysis	VII.G-22 (AP-30)	3.3.1-14	E
Valve body	Pressure boundary	Carbon steel	Air – indoor (ext)	Loss of material	System Walkdown	VIII.H-7 (S-29)	3.4.1-28	A
Valve body	Pressure boundary	Carbon steel	Lube oil (int)	Loss of material	Oil analysis	VII.G-22 (AP-30)	3.3.1-14	E

**VERMONT YANKEE NUCLEAR POWER STATION  
LICENSE RENEWAL APPLICATION SUPPLEMENT  
ATTACHMENT 2**

- LRA Section B.1.21 is revised to add the following systems to the list of nonsafety-related systems affecting safety-related components managed by the One-Time Inspection Program.
  - Auxiliary Steam (AS)
  - Condensate (C)
  - Feedwater (FDW)
  - House Heating Boiler (HB)
  - Main Steam (MS)
  - Main Turbine Generator (TG)
  
- LRA Section B.1.22 is revised to add the following systems to the list of nonsafety-related systems affecting safety-related components managed by the Periodic Surveillance and Preventive Maintenance Program.
  - Buildings (drainage system components) (BLD)
  - Circulating Water Priming (CWP)
  - Service Air (SA)