

SURVEILLANCE REQUIREMENTS (continued)

SURVEILLANCE	FREQUENCY
SR 3.3.1.1.5 Deleted	
SR 3.3.1.1.6 Deleted	
SR 3.3.1.1.7 Calibrate the local power range monitors.	2000 MWD/T average core exposure
SR 3.3.1.1.8 Perform CHANNEL FUNCTIONAL TEST.	92 days
SR 3.3.1.1.9 Calibrate the trip units.	92 days

(continued)