Use and Application 1.0

1.0 USE AND APPLICATION

The information in this section of the reference ABWR DCD, including all subsections, is incorporated by reference with the following departure.

STD DEP T1 3.4-1

1.1 Definitions

DIVISION FUNCTIONAL TEST	The injection of simulated or actual signals into a division as close to the sensors as practicable to verify OPERABILITY of SENSOR CHANNELS and LOGIC CHANNELS in that division. The DIVISION FUNCTIONAL TEST may be performed by means of a series of sequential or overlapping steps. The test shall comprise all the equipment from the DTM <u>DTF</u> inputs to LOGIC CHANNEL outputs. This test shall also verify that the inputs to the DTMs <u>DTFs</u> are the same as the information presented at the control room indicators.
LOGIC CHANNEL	A LOGIC CHANNEL is defined as a set of interconnecting hardware and software components that process the inputs to produce an identifiable RPS trip signal or ESF actuation signal within a division. For the RPS, this includes the trip signal's associated TLU 2-out-of-4 voters, TLU bistable functions, operator controls, interlocks, data transmission, alarms, displays, division-of-sensors bypass, transmission lines out to the OLU inputs. Each ESF function will have two ESF LOGIC CHANNELs to include one of the ESF actuation signal's associated SLU DLC 2-out-of-4 voters, SLU DLC bistable functions, operator controls, interlocks, data transmission, alarms, displays, division-of-sensors bypass, EMSDCF, and, as applicable, transmission lines out to the input of the 2-out-of-2 voters. The ESF actuation signal includes the system actuation signal and all its associated device actuation signals generated in the SLU DLC out to the 2-out-of-2 voter, if present.

Use and Application 1.0

1.0 USE AND APPLICATION (continued)

OUTPUT CHANNEL An OUTPUT CHANNEL is defined as a set of interconnected components that process outputs from associated LOGIC *CHANNELS to produce an identifiable signal that deenergizes* scram solenoids, deenergizes MSIV Isolation solenoids, or energizes ESF device actuators within a division. For the RPS, this includes the signal's associated OLU, transmission lines, manual divisional trip and reset switches, trip logic output bypass switch, parallel load driver test switch, and scram pilot valve solenoid load drivers. For the MSIVs, this includes the signal's associated OLU. data transmission. manual divisional isolation and reset switches, trip logic output bypass switch, and MSIV isolation pilot valve solenoid load drivers. For the *ESF*, this includes the signal's associated DLC or 2-out-of-2 voter, as applicable, ESF Output Channel Bypass switch, and data transmission out to the ESF device actuator. SENSOR CHANNEL A SENSOR CHANNEL is defined as a set of interconnected hardware and software components that process an identifiable sensor signal within a division. This includes the sensor, data acquisition, signal conditioning, data transmission, alarms, displays, and all transmission lines in the division and between divisions associated with the sensor signal up to an input of a 2-out-of-4 voter or an input of a bistable function within the TLU or SLU DLC.