## SURVEILLANCE REQUIREMENTS

~	SURVEILLANCE	FREQUENCY
SR 3.8.2.1	NOTEThe following SRs are not required to be performed: SR 3.8.1.3, SR 3.8.1.10 through SR 3.8.1.12, SR 3.8.1.15 through SR 3.8.1.17, and SR 3.8.1.18.	
	For AC sources required to be OPERABLE, the SRs of Specification 3.8.1, "AC Sources Operating," except SR 3.8.1.9, SR 3.8.1.13, SR 3.8.1.14 (ESF actuation signal portion only), SR 3.8.1.19, SR 3.8.1.20, SR 3.8.1.21, and SR 3.8.1.22, are applicable.	In accordance with applicable SRs
SR 3.8.2.2	One of the following SRs is applicable when the electrical distribution subsystem is being supplied by "backfeed" from an offsite source via the main transformer and a unit auxiliary transformer:	In accordance with applicable SR
	a. SR 3.8.1.9.a when the preferred offsite circuit is required to be OPERABLE by LCO 3.8.2.a, or	
	b. SR 3.8.1.9.b when the alternate offsite circuit is required to be OPERABLE by LCO 3.8.2.a.	

## SURVEILLANCE REQUIREMENTS

	SURVEILLANCE	FREQUENCY
SR 3.8.2.1	The following SRs are not required to be performed: SR 3.8.1.3, SR 3.8.1.10 through SR 3.8.1.12, SR 3.8.1.15 through SR 3.8.1.17, and SR 3.8.1.18.	
	For AC sources required to be OPERABLE, the SRs of Specification 3.8.1, "AC Sources Operating," except SR 3.8.1.9, SR 3.8.1.13, SR 3.8.1.14 (ESF actuation signal portion only), SR 3.8.1.19, SR 3.8.1.20, SR 3.8.1.21, and SR 3.8.1.22, are applicable.	In accordance with applicable SRs
SR 3.8.2.2	One of the following SRs is applicable when the electrical distribution subsystem is being supplied by "backfeed" from an offsite source via the main transformer and a unit auxiliary transformer:	In accordance with applicable S'R
·	a. SR 3.8.1.9.a when the preferred offsite circuit is required to be OPERABLE by LCO 3.8.2.a, or	·
÷	b. SR 3.8.1.9.b when the alternate offsite circuit is required to be OPERABLE by LCO 3.8.2.a.	·