



Tennessee Valley Authority, 1101 Market Street, LP 5A, Chattanooga, Tennessee 37402-2801

May 30, 2008

10 CFR 52.79

U.S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, D.C. 20555

In the Matter of)
Tennessee Valley Authority)

Docket No. 52-014 and 52-015

**BELLEFONTE COMBINED LICENSE APPLICATION – RESPONSE TO REQUEST FOR
ADDITIONAL INFORMATION – REACTOR VESSEL MATERIALS SURVEILLANCE**

Reference Letter: Letter from Ravindra G. Joshi (NRC) to Andrea L. Sterdis (TVA), Request for
Additional Information Letter No. 002 Related to SRP Section 05.03.01 for the
Bellefonte Units 3 and 4 Combined License Application, dated April 17, 2008.

This letter provides the Tennessee Valley Authority's (TVA) response to the Nuclear Regulatory
Commission (NRC) request for additional information (RAI) items included in the reference
letter. The items address the reactor vessel materials surveillance requirements.

The enclosures provide responses to the RAI. No changes based on this response are anticipated
to future revisions of the BLN application.

If there are any questions regarding this application, please contact Phillip Ray at 1101 Market
Street, LP 5A, Chattanooga, Tennessee 37402-2801, by telephone at (423) 751-7030, or via email
at pmray@tva.gov.

I declare under penalty of perjury that the foregoing is true and correct.

Executed on this 30th day of MAY, 2008.

Andrea L. Sterdis
Manager, New Nuclear Licensing and Industry Affairs
Nuclear Generation Development & Construction

Enclosures

DCBS
MLD

Document Control Desk

Page 2

May 30, 2008

cc (Enclosures and Attachments):

J. M. Sebrosky, NRC/HQ
M.P. Cazaubon, NuStart
R.B. Clary, SCE&G
E. Cummins, Westinghouse
S. P. Frantz, Morgan Lewis
M.W. Gettler, FP&L
R.C. Grumbir, NuStart
P. S. Hastings, NuStart
P. Hinnenkamp, Entergy
R.H. Kitchen, PGN
M.C Kray, NuStart
D. Lindgren, Westinghouse
G.D. Miller, PG&N
R.G. Joshi, NRC
G. Serviere,
G.A Zinke, NuStart

cc (w/o Enclosures and Attachments):

M.P. Cazaubon, NuStart
A.M Monroe, SCE&G
C. R Pierce, SNC
R. Register, DOE/PM
L. Reyes, NRC/RII

Enclosure
TVA letter dated May 30, 2008
RAI Responses

Responses to NRC Request for Additional Information letter No. 002 dated April 17, 2008
(3 Pages, including this list)

Subject: Reactor Vessel Materials Surveillance in the Final Safety Analysis Report

<u>RAI Number</u>	<u>Date of TVA Response</u>
05.03.01-01(a)	This letter – see following pages
05.03.01-01(b)	This letter – see following pages

Attachments / Enclosures

Pages Included

None

Enclosure
TVA letter dated May 30, 2008
RAI Responses

NRC Letter Dated: April 17, 2008

NRC Review of Final Safety Analysis Report

NRC RAI NUMBER: 05.03.01-01(a)

a. Program Description:

The purpose of the reactor vessel (RV) surveillance capsule program, as described in ASTM E 185, is to monitor radiation effects on RV materials under operating conditions. Section C.III.1, Chapter 5, C.I.5.3.1.6 of Regulatory Guide (RG) 1.206 states, "because the material surveillance program is an operational program, as discussed in SECY-05-0197, the applicant must describe the program and its implementation in sufficient scope and level of detail for the staff to make a reasonable assurance finding on its acceptability." The NRC staff recognizes that certain information about the program, such as actual material properties of the RV, is not currently known, but in order to complete its review of the adequacy of the RV surveillance capsule program, the staff needs the following information at this time:

Describe the process for preparing the capsule specimens. This description will confirm that the materials selected for the capsules are samples of those materials most likely to limit the operation of the RV.

BLN RAI ID: 0022

BLN RESPONSE:

While "the material surveillance program is an operational program," the selection of materials for the capsules is a design function, and as such, it is addressed in the AP1000 design control document (DCD). As stated in the DCD, the program conforms to ASTM E-185. The location of the capsules is shown in DCD Figure 5.3-4 which is referenced from the second paragraph of DCD Subsection 5.3.2.6. The first four paragraphs of DCD Subsection 5.3.2.6 describe the contents of the surveillance capsules including reactor vessel weld metal, base metal, and heat-affected zone metal specimens and the basis for the selection of the specimens included. The figure and DCD Subsection are incorporated by reference into the FSAR.

This response is expected to be STANDARD for the S-COLAs.

ASSOCIATED BLN COL APPLICATION REVISIONS:

No COLA Part 2, FSAR, revisions have been identified associated with this response.

ATTACHMENTS/ENCLOSURES:

None

Enclosure
TVA letter dated May 30, 2008
RAI Responses

NRC Letter Dated: April 17, 2008

NRC Review of Final Safety Analysis Report

NRC RAI NUMBER: 05.03.01-01(b)

b. RV Surveillance Capsule Program:

In order for the NRC staff to complete its review of the RV surveillance capsule program for Bellefonte Units 3 and 4, the COL applicant must fully describe its RV surveillance capsule program in accordance with ASTM E 185 and other requirements listed in 10 CFR Part 50, Appendix H. Specifically, the NRC staff still needs detailed information on the RV surveillance capsule program associated with the AP1000 design, including, but not limited to, the capsule environment and the material types of the capsule specimens. This information will need to be included in the RV surveillance capsule program in order to support planning and conduct of NRC inspections. Discuss whether this information will be provided before the NRC's determination on issuance of the COL, or, if this information will not be available until after the RV is procured, explain whether a license condition requiring that this information be provided by the COL holder (i.e., included in Bellefonte COLA Part 10, Section 2, "COL Holder Items.") would be necessary and sufficient for COL issuance.

BLN RAI ID: 0023

BLN RESPONSE:

While "the material surveillance program is an operational program," the requested details including "the capsule environment and the material types of the capsule specimens" are determined by the design, and as such, have been addressed in the AP1000 design control document (DCD). The first four paragraphs of DCD Subsection 5.3.2.6 describe the contents of the surveillance capsules including reactor vessel weld metal, base metal, and heat-affected zone metal specimens. The orientation of base metal specimens relative to the principal rolling direction is defined. The basis for the selection of the specimens is included. Conformance to ASTM E-185 and 10 CFR 50 Appendix H is noted in the DCD write-up. As noted in the DCD write-up the complete capsule is helium leak tested. The DCD subsection is incorporated by reference in the FSAR,

Part 10 of the COLA identifies two related proposed license conditions. Proposed condition 3, item J.1, identifies that the reactor vessel materials surveillance program will be fully implemented no later than initial criticality. Support for planning and conduct of NRC inspections is addressed by proposed condition 6 which indicates that a schedule for availability of the actual program documents will be submitted to NRC no later than 12 months after issuance of the COL, to support "planning for and conduct of NRC inspections of operational programs" listed in the operational program FSAR Table 13.4-201.

This response is expected to be STANDARD for the S-COLAs.

ASSOCIATED BLN COL APPLICATION REVISIONS:

No COLA Part 2, FSAR, revisions have been identified associated with this response.

ATTACHMENTS/ENCLOSURES:

None