



ENCLOSURE 3
"FEEDWATER NOZZLE GREEN'S FUNCTIONS"
(FILE NO. OC-05Q-307), REVISION 0

ATTACHMENT 1
Design Analysis Cover Sheet
Page 1


Design Analysis (Major Revision)		Last Page No. ⁶ 31 (calc.) & A17 (Appx.)	
Analysis No.: ¹ SIA # OC-05Q-307	Revision: ² 0		
Title: ³ Feedwater Nozzle Green's Functions			
EC/ECR No.: ⁴ 05 - 00365	Revision: ⁵ 0		
Station(s): ⁷ Oyster Creek	Component(s): ¹⁴		
Unit No.: ⁸ 1			
Discipline: ⁹ Mechanical Eng.			
Descrip. Code/Keyword: ¹⁰ Fatigue Analysis			
Safety/QA Class: ¹¹ Q			
System Code: ¹² 422 & 104			
Structure: ¹³ Feedwater Nozzle			
CONTROLLED DOCUMENT REFERENCES ¹⁵			
Document No.:	From/To	Document No.:	From/To
MPR Report # MPR-783	From		
SIA Report # SIR-88-028	From		
Calculation # C-1302-422-E540-046	From		
Is this Design Analysis Safeguards Information? ¹⁶ Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> If yes, see SY-AA-101-106 Does this Design Analysis contain Unverified Assumptions? ¹⁷ Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> If yes, ATI/AR#: _____ This Design Analysis SUPERCEDES: ¹⁸ _____ in its entirety.			
Description of Revision (list affected pages for partials): ¹⁹ Initial Issue to OC Records Management, as part of Licensing Renewal Project.			
Preparer: ²⁰	See Page 1b for SIA Sign's		
	<small>Print Name</small>	<small>Sign Name</small>	<small>Date</small>
Method of Review: ²¹	Detailed Review <input checked="" type="checkbox"/> Alternate Calculations (attached) <input type="checkbox"/> Testing <input type="checkbox"/>		
Reviewer: ²²	See Page 1b for SIA Sign's		
	<small>Print Name</small>	<small>Sign Name</small>	<small>Date</small>
Review Notes: ²³	Independent review <input checked="" type="checkbox"/> Peer review <input type="checkbox"/>		
<small>(For External Analyses Only)</small>			
External Approver: ²⁴	See Page 1b for SIA Sign's		
	<small>Print Name</small>	<small>Sign Name</small>	<small>Date</small>
Exelon Reviewer: ²⁵	Julien Abramovici		8-15-05
	<small>Print Name</small>	<small>Sign Name</small>	<small>Date</small>
Is a Supplemental Review Required? ²⁶ Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> If yes, complete Attachment 3			
Exelon Approver: ²⁷	F. Howie Ray		
	<small>Print Name</small>	<small>Sign Name</small>	<small>Date</small>
			8-15-05

ATTACHMENT 2
Owners Acceptance Review Checklist for External Design Analysis
Page 1 of 1

DESIGN ANALYSIS NO. SIA # OC-05Q-307 REV: 0 SHEET 1a of 1

		Yes	No	N/A
1.	Do assumptions have sufficient rationale?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2.	Are assumptions compatible with the way the plant is operated and with the licensing basis?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
3.	Do the design inputs have sufficient rationale?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
4.	Are design inputs correct and reasonable?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
5.	Are design inputs compatible with the way the plant is operated and with the licensing basis?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
6.	Are Engineering Judgments clearly documented and justified?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
7.	Are Engineering Judgments compatible with the way the plant is operated and with the licensing basis?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
8.	Do the results and conclusions satisfy the purpose and objective of the Design Analysis?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
9.	Are the results and conclusions compatible with the way the plant is operated and with the licensing basis?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
10.	Does the Design Analysis include the applicable design basis documentation?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
11.	Have any limitations on the use of the results been identified and transmitted to the appropriate organizations?	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
12.	Are there any unverified assumptions?	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
13.	Do all unverified assumptions have a tracking and closure mechanism in place?	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
14.	Have all affected design analyses been documented on the Affected Documents List (ADL) for the associated Configuration Change?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
15.	Do the sources of inputs and analysis methodology used meet current technical requirements and regulatory commitments? (If the input sources or analysis methodology are based on an out-of-date methodology or code, additional reconciliation may be required if the site has since committed to a more recent code)	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
16.	Have vendor supporting technical documents and references (including GE DRFs) been reviewed when necessary?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

EXELON REVIEWER: Julien Abramovici


Print / Sign

DATE: 8/10/15



**STRUCTURAL
INTEGRITY
Associates, Inc.**

**CALCULATION
PACKAGE**

FILE No.: OC-05Q-307

PROJECT No.: OC-05Q

PROJECT NAME: Oyster Creek Neutron Embrittlement and Fatigue License Renewal Activities

CLIENT: Exelon Generation Company, LLC

CONTRACT NUMBER: 10002039 dated 6/8/2004

CALCULATION TITLE: Feedwater Nozzle Green's Functions


Document Revision	Affected Pages	Revision Description	Project Mgr. Approval Signature & Date	Preparer(s) & Checker(s) Signatures & Date
0	1-31, Appendix A A1-A17 In Computer Files	Initial issue.	G. L. Stevens <i>G. L. Stevens</i> 7/20/2005	Eric Jones EEJ 07/20/2005 <i>Eric Jones</i> M. Qin MQ 07/20/2005 <i>Minghao Qin</i>

Table of Contents

1.0	OBJECTIVE	4
2.0	GEOMETRY	4
3.0	MATERIAL PROPERTIES	4
4.0	APPLIED LOADS.....	7
4.1	Pressure Load.....	7
4.2	Thermal Load.....	11
5.0	THERMAL AND PRESSURE LOAD RESULTS	14
6.0	ATTACHED PIPING LOADS.....	22
7.0	PEAK STRESS FACTOR.....	26
8.0	CONCLUSIONS.....	26
9.0	REFERENCES	31
APPENDIX A: COMPUTER INPUT AND OUTPUT FILES.....		A1

List of Tables

Table 1:	Feedwater Nozzle Material Properties	6
Table 2:	Heat Transfer Coefficients for Oyster Creek Feedwater Nozzle	12
Table 3:	Pressure Results.....	15
Table 4:	Piping Load Calculations	25
Table 5:	Safe-End Node 1344 Data.....	27
Table 6:	Blend Radius Node 584 Data	28

	Revision	0			
	Preparer/Date	EEJ 07/20/2005			
	Checker/Date	MQ 07/20/2005			
	File No.	OC-05Q-307			Page 2 of 31

List of Figures

Figure 1: Oyster Creek Unit 1 Feedwater Finite Element Model5
 Figure 2: Element Plot of Applied Cap Load to As-Modeled FW Nozzle8
 Figure 3: Element Plot of Applied Internal Pressure Load to As-Modeled FW Nozzle9
 Figure 4: Element Plot of Applied Mechanical Boundary Conditions to As-Modeled FW Nozzle10
 Figure 5: Thermal Regions of Oyster Creek Feedwater Nozzle12
 Figure 6: Applied Green's Function Temperature Step Change13
 Figure 7: Temperature Plot of Steady-State Condition (550°F).....16
 Figure 8: Temperature Plot at Time = 3.1 Seconds.....17
 Figure 9: Maximum Total Thermal Stress Intensity (Time = 3.1 seconds)18
 Figure 10: Maximum Total Pressure Stress Intensity from Applied Pressure Load.....19
 Figure 11: Safe End Critical Thermal Stress Location, Node 134420
 Figure 12: Blend Radius Critical Pressure Stress Location, Node 58421
 Figure 13: External Forces and Moments on the Recirculation Outlet Nozzle.....22
 Figure 14: Safe-End Node 1344 Green's Function29
 Figure 15: Blend Radius Node 584 Green's Function30



	Revision	0			
	Preparer/Date	EEJ 07/20/2005			
	Checker/Date	MQ 07/20/2005			
	File No.	OC-05Q-307	Page 3 of 31		

1.0 OBJECTIVE

The objective of this calculation is to develop Green's Functions (GF) for the feedwater nozzle at Oyster Creek (OC). To accomplish this task, a temperature step change was applied to a detailed, two-dimensional (2-D) axisymmetric finite element model (FEM) of the feedwater nozzle, exclusive of the thermal sleeve. Bounding stress histories were extracted from two peak stress locations, one each in the blend radius and the safe end regions. These stress histories were then divided by the actual temperature step change applied to develop Green's Functions for each location. The Green's Function methodology is described in Section 3.3.1 of Reference [7]. This Green's Function is input to the **FatiguePro** software, and is used with actual plant feedwater temperature data to develop "on-line" thermal stress histories for the feedwater nozzle. From these stress histories, fatigue usage is determined and monitored at each feedwater nozzle location.

2.0 GEOMETRY

A 2-D axisymmetric finite element model (FEM) was developed using the ANSYS finite element analysis software [2]. The geometry and material properties used in Reference [1] and [4] were utilized in this evaluation. The meshed model is shown in Figure 1. Reference [1] reflects the changes made in geometry due to work done on the nozzles in 1977.

3.0 MATERIAL PROPERTIES

The original construction drawing, Reference [4], designates the material for the feedwater nozzle safe-end to be SA-105, Grade II¹. The nozzle forging is SA-336 (equivalent to SA-508 Class 2) and the vessel plate material is SA-302 Grade B low alloy steel. The material properties used for the finite element analysis can be found in Table 1. For the FEM analysis, material properties at 325°F were used, because it is the average of the original feedwater nozzle temperature (550°F) and the thermal shock temperature (100°F).

Use of temperature dependent material properties is not appropriate since this is a linear analysis that uses Green's Functions to determine stresses. The Green's Function integration process requires linear characteristics, so the introduction of temperature dependent non-linearities would lead to inaccuracies and difficulties in the Green's Function integration process. In addition, the product of E_a for low alloy steel, which is the most influential parameter for thermal stress analysis, varies by less than 6% between 325°F and the maximum operating temperature of 550°F. This is considered to be

¹ Note: All material identifiers in this calculation utilize "SA" designations to line up with current-day material specifications. It is recognized that most OC material identifiers originally used "A" designations. For the purposes of this calculation, both identifiers are considered to be identical.



Revision	0			
Preparer/Date	EEJ 07/20/2005			
Checker/Date	MQ 07/20/2005			
File No.	OC-05Q-307	Page 4 of 31		

within the accuracy of this analysis. Considering that the peak stress for many of the significant (controlling) transients occurs at a temperature less than 325°F, the use of the E_a product at 325°F is bounding for these severe transients (since E_a is less for low temperatures).

The coefficients of thermal expansion (α) are instantaneous coefficients. They are used instead of mean values because they are more conservative. Also, since temperature dependent coefficients are not used, and the instantaneous coefficient at 325°F is very close to the mean value at 550°F, so the usage of an instantaneous coefficient is appropriate.




Figure 1: Oyster Creek Unit 1 Feedwater Finite Element Model


	Revision	0			
	Preparer/Date	EEJ 07/20/2005			
	Checker/Date	MQ 07/20/2005			
	File No.	OC-05Q-307	Page 5 of 31		

Table 1: Feedwater Nozzle Material Properties

Material Properties						
All Steels: <i>Poisson's Ratio</i>		0.3				
<i>Density</i>		0.283				
Reactor Vessel Plate (SA 302 Gr.B) [5, Material Group D]						
T	α	E	Thermal Conductivity, K	Thermal Diffusivity	Specific Heat, Cp	
F	in/in*F	psi	BTU/hr*ft*F	ft ² /hr	BTU/lb*F	
300	7.74E-06	2.80E+07	24.7	0.42	0.12	
350	7.88E-06		24.7	0.409	0.123	
400	8.01E-06	2.74E+07	24.6	0.398	0.126	
325	7.81E-06	2.79E+07	24.7	0.4145	0.1216	
Nozzle Forging (SA 336 with Code Case 1236-1) [5, Material Group A]						
T	α	E	Thermal Conductivity, K	Thermal Diffusivity	Specific Heat, Cp	
F	in/in*F	psi	BTU/hr*ft*F	ft ² /hr	BTU/lb*F	
300	7.30E-06	2.85E+07	23.9	0.406	0.120	
350	7.49E-06		23.7	0.396	0.122	
400	7.66E-06	2.79E+07	23.6	0.385	0.125	
325	7.395E-06	2.84E+07	23.8	0.401	0.121	
Safe End (CS-I SA-106 Gr. II) [5, Material Group B]						
T	α	E	Thermal Conductivity, K	Thermal Diffusivity	Specific Heat, Cp	
F	in/in*F	psi	BTU/hr*ft*F	ft ² /hr	BTU/lb*F	
300	7.18E-06	2.81E+07	28.4	0.481	0.1207	
350	7.47E-06		28.0	0.464	0.1234	
400		2.75E+07				
325	7.325E-06	2.80E+07	28.2	0.4725	0.1221	



Revision	0			
Preparer/Date	EEJ 07/20/2005			
Checker/Date	MQ 07/20/2005			
File No.	OC-05Q-307	Page 6 of 31		

4.0 APPLIED LOADS

Both pressure and thermal loads will be applied to the finite element model.

4.1 Pressure Load

A uniform pressure of 1000 psi was applied along the inside surface of the feedwater nozzle and the reactor vessel wall. A pressure load of 1000 psi was used because it is easily scaled up or down to account for different pressures that occur during transients. In addition, a cap load was applied to the piping at the end of the nozzle to account for the attached piping, which is not modeled. This cap load was calculated as follows:

$$P_{CAP} = \frac{P * D_i^2}{D_o^2 - D_i^2}$$

where:

P = Pressure = 1000 psi
 D_i = Inner Diameter = 9.375 in
 D_o = Outer Diameter = 11.000 in

Therefore, the cap load is 2654.6 psi. The calculated value was given a negative sign in order for it to exert tension on the end of the model. The nodes on the end of the safe-end are coupled in the axial direction (UY) to ensure mutual displacement of the end of the nozzle due to attached piping.

In order to properly model the feedwater nozzle in ANSYS, the analysis was done as a penetration in a sphere and not a cylinder. To make up for this difference in geometry, a conversion factor of 3.2 times the cylinder radius was used to model the sphere (sphere radius equals 341.501”).

The ANSYS input file OC_FWN_GEOM.inp generates the feedwater nozzle geometry and OC_FWN_PRES.inp performs the internal pressure load case just described. Figures 2, 3, and 4 show the applied axial cap load on the safe end, the applied internal pressure distribution, and the applied symmetric boundary conditions on the vessel wall and coupling on the safe end, respectively.



Revision	0			
Preparer/Date	EEJ 07/20/2005			
Checker/Date	MQ 07/20/2005			
File No.	OC-05Q-307	Page 7 of 31		




Figure 2: Element Plot of Applied Cap Load to As-Modeled FW Nozzle



Revision	0			
Preparer/Date	EEJ 07/20/2005			
Checker/Date	MQ 07/20/2005			
File No.	OC-05Q-307	Page 8 of 31		





Figure 3: Element Plot of Applied Internal Pressure Load to As-Modeled FW Nozzle

	Revision	0			
	Preparer/Date	EEJ 07/20/2005			
	Checker/Date	MQ 07/20/2005			
	File No.	OC-05Q-307	Page 9 of 31		






Figure 4: Element Plot of Applied Mechanical Boundary Conditions to As-Modeled FW Nozzle

	Revision	0			
	Preparer/Date	EEJ 07/20/2005			
	Checker/Date	MQ 07/20/2005			
	File No.	OC-05Q-307	Page 10 of 31		

4.2 Thermal Load

Thermal loads are applied to the feedwater nozzle model for a 100% rated flow thermal shock. The regions were given an initial temperature of 550°F and then the heat transfer coefficients and temperatures were changed to simulate the 100°F flow condition. The total flow rate of the feedwater system is 7.217 Mlb/hr divided into four feedwater nozzles. Thus, the total flow rate divided by four gives a rated flow rate for each feedwater nozzle equal to 1.80425 Mlb/hr, or 3,964 gallons per minute (gpm).

The heat transfer coefficients (HTC) for each of the GFs were determined and obtained from FWN-HT-COEFF.xls. This set of Excel worksheets calculates HTC's with geometry and flow condition input. HTC's were found for regions 1-4 and 6 of Figure 5. Region 5 uses a HTC that is an average of Region 1 and Region 2. The HTC's calculated from this spreadsheet are similar to the ones used in the original **FatiguePro** calculations [3]. The HTC value for region 4 at 100% flow case is the same as that used in reference [3], because the spreadsheet used in the calculations for other regions does not allow for HTC calculation at the inner wall of a vessel. Figure 5 shows the regions for application of HTC's. Table 2 depicts the HTC's at no flow and full flow conditions.

	Revision	0			
	Preparer/Date	EEJ 07/20/2005			
	Checker/Date	MQ 07/20/2005			
	File No.	OC-05Q-307	Page 11 of 31		




Figure 5: Thermal Regions of Oyster Creek Feedwater Nozzle

Table 2: Heat Transfer Coefficients for Oyster Creek Feedwater Nozzle

0% Flow Case			100% Flow Case		
Region	Temperature °F	Heat Transfer Coefficient Btu/hr-ft ² -°F	Region	Temperature °F	Heat Transfer Coefficient Btu/hr-ft ² -°F
1	550.0	205.1	1	100.0	2108.8
2	550.0	205.1	2	325.0	673.9
3	550.0	205.1	3	325.0	191.8
4	550.0	205.1	4	550.0	1000.0



Revision	0			
Preparer/Date	EEJ 07/20/2005			
Checker/Date	MQ 07/20/2005			
File No.	OC-05Q-307	Page 12 of 31		

Figure 6 depicts the graphical representation of the applied temperature step change to the feedwater nozzle. Thermal Regions 1, 2, 3, and 5 experience the step change. Thermal Region 4 remains at 550°F and Thermal Region 6 remains at 70°F (ambient temperature) during the step change, which occurs on the inner diameter of the feedwater nozzle (i.e., flow path). The thermal response of the shock is analyzed out to 20,000 seconds.




Figure 6: Applied Green's Function Temperature Step Change



Revision	0			
Preparer/Date	EEJ 07/20/2005			
Checker/Date	MQ 07/20/2005			
File No.	OC-05Q-307	Page 13 of 31		

5.0 THERMAL AND PRESSURE LOAD RESULTS

The thermal load described in the previous section was run on the feedwater FEM. The thermal transient input file is OC_FWN_THM. The input file used to find the stress due to thermal loading is OC_FWN_THSTR.inp.

Fatigue usage in components such as the feedwater nozzle are almost always controlled by limiting stresses caused by the severe "step change" thermal transients specified in the design basis. Since the Green's Function unit input transient is a step change, the peak stress response from this input transient provides a valid way of establishing the limiting point.


The limiting safe end location was chosen as the node with the highest stress intensity due to thermal loading. Figure 7 shows the temperature distribution for steady-state condition at 550°F. Figure 8 shows the temperature distribution at time = 3.1 seconds, which corresponds to the greatest thermal response produced by the applied temperature step change. The highest total stress intensity due to thermal loading occurs at Node 1344 on the inside diameter of the feedwater nozzle safe-end at a time of 3.1 seconds. Figure 9 depicts the location showing a total thermal stress intensity value of 67,246 psi for Node 1344. Node 1344, shown in Figure 11, was therefore selected as the limiting safe end location for analysis.

The limiting blend radius location was chosen based upon the highest total stress intensity due to pressure loading as shown in Figure 10. The input file used to apply the pressure loading is OC_FWN_PRES.inp. The limiting location is at Node 584 and is depicted in Figure 12.

The stress intensity time history for the limiting safe-end and blend radius locations were extracted using the ANSYS post-processing files XTR_BR.POS and XTR_SE.POS for the blend radius and safe end locations, respectively. The ANSYS PRESECT command is executed to extract the linearized stress history along a path from the selected location (safe end and blend radius) to a node on the external surface. Figures 11 and 12 show the linearized stress path for the safe end and blend radius, respectively. The post-processing file produces two raw output files, one for the safe-end and one for the blend radius location (contain the membrane plus bending and Total thermal stress histories), SE_FLW.out and BR_FLW.out. The membrane plus bending (M+B) stresses and total stresses for the Green's Functions were extracted from the raw output files to produce the corresponding 'clean' files SE.cln and BR.cln.

All *.POS, *.OUT, and *.CLN files are located in the computer files.

As the models were run with a 450°F step change in temperature at the safe end and 225°F step change at the blend radius and the Green's Functions are for a 1°F step change in temperature, all safe end data values were divided by -450 (ΔT) and blend radius data values were divided by -450



Revision	0			
Preparer/Date	EEJ 07/20/2005			
Checker/Date	MQ 07/20/2005			
File No.	OC-05Q-307	Page 14 of 31		

(ΔT). The governing Green's Function plots for the feedwater nozzle safe-end and blend radius locations are shown in Figures 14 and 15. The data for the Green's Functions is contained in Excel files OC_GreenFCN.XLS, which is located in the computer files.

The pressure stress intensities for the safe-end and blend radius paths were extracted using the ANSYS post-processing files XTR_SE_PRES.POS and XTR_BR_PRES.POS for the Safe End and Blend Radius locations, respectively. These files produced SE_PRES_FLW.OUT for the safe-end and BR_PRES_FLW.OUT for the blend radius.

Results of the internal pressure load case are for Node 584 (blend radius) with total stress intensity of 56,070 psi (BR_PRES_FLW.OUT) and for Node 1344 (safe-end) a total stress intensity of 7,767 psi (SE_PRES_FLW.OUT). The M+B stress intensity at Node 584 and Node 1344 are 53,150 psi and 7,732 psi, respectively. Table 3 shows the final pressure results for the safe-end and blend radius.

Table 3: Pressure Results

Location	Membrane plus Bending Stress Intensity (psi)	Total Stress Intensity (psi)
Safe End	7,732	7,767
Blend Radius	53,150	56,070



Revision	0			
Preparer/Date	EEJ 07/20/2005			
Checker/Date	MQ 07/20/2005			
File No.	OC-05Q-307	Page 15 of 31		




Figure 7: Temperature Plot of Steady-State Condition (550°F)



Revision	0			
Preparer/Date	EEJ 07/20/2005			
Checker/Date	MQ 07/20/2005			
File No.	OC-05Q-307	Page 16 of 31		





Figure 8: Temperature Plot at Time = 3.1 Seconds

	Revision	0			
	Preparer/Date	EEJ 07/20/2005			
	Checker/Date	MQ 07/20/2005			
	File No.	OC-05Q-307	Page 17 of 31		





Figure 9: Maximum Total Thermal Stress Intensity (Time = 3.1 seconds)

	Revision	0		
	Preparer/Date	EEJ 07/20/2005		
	Checker/Date	MQ 07/20/2005		
	File No.	OC-05Q-307	Page 18 of 31	





Figure 10: Maximum Total Pressure Stress Intensity from Applied Pressure Load

	Revision	0			
	Preparer/Date	EEJ 07/20/2005			
	Checker/Date	MQ 07/20/2005			
	File No.	OC-05Q-307	Page 19 of 31		





Figure 11: Safe End Critical Thermal Stress Location, Node 1344

	Revision	0			
	Preparer/Date	EEJ 07/20/2005			
	Checker/Date	MQ 07/20/2005			
	File No.	OC-05Q-307	Page 20 of 31		





Figure 12: Blend Radius Critical Pressure Stress Location, Node 584

	Revision	0			
	Preparer/Date	EEJ 07/20/2005			
	Checker/Date	MQ 07/20/2005			
	File No.	OC-05Q-307	Page 21 of 31		

6.0 ATTACHED PIPING LOADS

Along with pressure and thermal effects, the piping stress intensity (stress caused by the attached piping) was determined. These piping forces and moments are determined as shown in Figure 13.




Figure 13: External Forces and Moments on the Recirculation Outlet Nozzle

The following formulas are used to determine the maximum stress intensity in the nozzle at the two locations of interest. From engineering statics, the piping loads at the end of the model can be translated to the first and second cut locations using the following equations:

$$\begin{aligned} \text{For Cut I: } (M_x)_1 &= M_x - F_y L_1 \\ (M_y)_1 &= M_y + F_x L_1 \end{aligned}$$

$$\begin{aligned} \text{For Cut II: } (M_x)_2 &= M_x - F_y L_2 \\ (M_y)_2 &= M_y + F_x L_2 \end{aligned}$$



Revision	0			
Preparer/Date	EEJ 07/20/2005			
Checker/Date	MQ 07/20/2005			
File No.	OC-05Q-307	Page 22 of 31		

The total bending moment and shear loads are obtained using the equations below:

$$\text{For Cut I: } M_{xy} = \sqrt{(M_x)_1^2 + (M_y)_1^2}$$

$$F_{xy} = \sqrt{(F_x)_1^2 + (F_y)_1^2}$$

$$\text{For Cut II: } M_{xy} = \sqrt{(M_x)_2^2 + (M_y)_2^2}$$

$$F_{xy} = \sqrt{(F_x)_2^2 + (F_y)_2^2}$$

The distributed loads for a thin-walled cylinder are obtained using the equations below:

$$N_z = \frac{1}{\pi R_N} \left[\frac{1}{2} F_z + \frac{M_{xy}}{R_N} \right]$$

$$q_N = \frac{1}{\pi R_N} \left[F_{xy} - \frac{M_z}{2R_N} \right]$$

To determine the primary stresses, P_M , due to internal pressure and piping loads, the following equations are used.

For Cut I, using thin-walled equations:

$$(P_M)_z = \frac{Pa_N}{2t_N} + \frac{Nz}{t_N}$$

$$(P_M)_\theta = \frac{Pa_N}{t_N}$$

$$(P_M)_R = -P$$

$$\tau_M = \frac{q_N}{t_N}$$

$$SI_{MAX} = 2 \sqrt{\left(\frac{(P_M)_\theta - (P_M)_R}{2} \right)^2 + (\tau_M)_{z\theta}^2}$$

or

$$SI_{MAX} = 2 \sqrt{\left(\frac{(P_M)_z - (P_M)_R}{2} \right)^2 + (\tau_M)_{z\theta}^2}$$



Revision	0			
Preparer/Date	EEJ 07/20/2005			
Checker/Date	MQ 07/20/2005			
File No.	OC-05Q-307	Page 23 of 31		

Note: For this analysis, the pressure load was applied to the ANSYS model and the resulting pressure stresses were taken from ANSYS. Therefore, they were excluded from the above equations.

Because pressure was not considered in this analysis, the equations used for Cut I are valid for Cut II.

- where:
- L_1 = The length from the end of the nozzle where the piping loads are applied to the location of interest in the safe end.
 - L_2 = The length from the end of the nozzle where the piping loads are applied to the location of interest in the blend radius.
 - M_{xy} = The maximum bending moment in the xy plane.
 - F_{yx} = The maximum shear force in the xy plane.
 - N_z = The normal force per inch of circumference applied to the end of the nozzle in the z direction.
 - q_N = The shear force per inch of circumference applied to the nozzle.
 - R_N = The mid-wall nozzle radius.

There are four feedwater nozzles in the system (N4A, N4B, N4C, and N4D). The largest reaction forces need to be found and applied for this analysis. It is assumed that nozzles N4A and N4B bound N4C and N4D. Nodes 5 and 140 represent N4A and N4B. The node with greater reaction forces found from previous Autopipe analysis [8] will be the one used to base the piping load analysis.

In this case, the reaction loads from node 5 are higher than node 140 for the "MAX LVL A" load case [8, pg. 126]. This load case is used because it models the most severe conditions. The forces and moments from node 5 are shown below.

$$\begin{array}{ll} F_x = 1341 \text{ lbs} & M_x = 241,920 \text{ in-lb} \\ F_y = 2206 \text{ lbs} & M_y = 77,820 \text{ in-lb} \\ F_z = 1786 \text{ lbs} & M_z = 62,592 \text{ in-lb} \end{array}$$

The loads are rotated into the local coordinate system shown in Figure 13 based on the coordinate values of nodes 5 and 10 [8]. The converted loads are as follows:

$$\begin{array}{ll} F_x' = 2,211 \text{ lbs} & M_x' = 215,233 \text{ in-lb} \\ F_y' = 2206 \text{ lbs} & M_y' = 77,820 \text{ in-lb} \\ F_z' = 315 \text{ lbs} & M_z' = -126,804 \text{ in-lb} \end{array}$$

Since the location of the input piping load is on the outside surface of the vessel, it is assumed this location is equivalent to the second cut. Therefore, the L_2 is equal to zero and the L_1 is with a



Revision	0			
Preparer/Date	EEJ 07/20/2005			
Checker/Date	MQ 07/20/2005			
File No.	OC-05Q-307	Page 24 of 31		

negative value for the distance between first cut and second cut (Cut II). The calculations for the safe end and blend radius are shown in Table 4. The first cut location is the same as the Green's Function cross section at the safe end, and the second cut is assumed to be on the vessel ID (i.e., Node 5 from the AUTOPIPE model [8]). The maximum stress intensities due to piping loads are 4598.60 psi at the safe end and 343.12 psi at the blend radius, respectively.

Table 4: Piping Load Calculations

Safe End External Piping Loads			Blend Radius External Piping Loads		
Parameters			Parameters		
$F_x =$	2.21	kips	$F_x =$	2.21	kips
$F_y =$	2.21	kips	$F_y =$	2.21	kips
$F_z =$	0.31	kips	$F_z =$	0.31	kips
$M_x =$	215.32	in-kips	$M_x =$	215.32	in-kips
$M_y =$	77.82	in-kips	$M_y =$	77.82	in-kips
$M_z =$	-126.80	in-kips	$M_z =$	-126.80	in-kips
OD=	11.00	in	OD=	20.00	in
ID=	9.375	in	ID=	11.140	in
$R_N =$	5.09	in	$R_N =$	7.79	in
L =	-18.72	in	L =	0.00	in
$t_N =$	0.81	in	$t_N =$	4.43	in
$(M_x)_2 =$	256.62	in-kips	$(M_x)_2 =$	215.32	in-kips
$(M_y)_2 =$	36.43	in-kips	$(M_y)_2 =$	77.82	in-kips
$M_{xy} =$	259.19	in-kips	$M_{xy} =$	228.95	in-kips
$F_{xy} =$	3.12	kips	$F_{xy} =$	3.12	kips
$N_z =$	3.19	kips/in	$N_z =$	1.21	kips/in
$q_N =$	0.97	kips/in	$q_N =$	0.46	kips/in
Primary Membrane Stress Intensity			Primary Membrane Stress Intensity		
$PM_z =$	3.93	ksi	$PM_z =$	0.27	ksi
$\tau =$	1.20	ksi	$\tau =$	0.10	ksi
$SI_{max} =$	4.60	ksi	$SI_{max} =$	0.34	ksi
$SI_{max} =$	4598.60	psi	$SI_{max} =$	343.12	psi



Revision	0			
Preparer/Date	EEJ 07/20/2005			
Checker/Date	MQ 07/20/2005			
File No.	OC-05Q-307	Page 25 of 31		

7.0 PEAK STRESS FACTOR

The piping load stress intensity value is also included in Tables 5 and 6. Total stress intensity values for membrane plus bending are obtained by combining the thermal membrane plus bending stress for 450°F, the pressure membrane plus bending stress, and the piping stress intensity. Total stress intensity values for membrane plus bending plus peak are then obtained by combining the total thermal stress for 450°F, the total pressure stress, and the piping stress intensity. These values are also given in Tables 5 and 6.

Maximum (σ_{max}) and steady-state (σ_{ss}) values are then determined for the membrane plus bending and total stress cases. Then the maximum possible stress range ($2\sigma_{max} - \sigma_{ss}$) is obtained. The ratio of this range for membrane plus bending over total equals the Peak Stress Factor (PSF), which is calculated for both feedwater locations, as shown in Tables 5 and 6. These values are implemented into *FatiguePro*. The peak stress factor for the nozzle safe end is **0.677** and the peak stress factor for the blend radius is **0.993**. All peak stress calculations are included in the Excel file *OC_GreenFCN.xls*, which is included in the project files.

8.0 CONCLUSIONS

The files *SE.CLN* and *BR.CLN* contain the stress histories necessary to develop 100% flow Green's Functions. A total stress intensity history Green's Function is produced for each of these files. The Green's Function is calculated by dividing the Total Stress Intensity (sixth column) by the change in temperature. It should be noted that the (Membrane + Bending) column (fourth column) does not always equal the sum of Column 2 (Membrane) and Column 3 (Bending) because the values are stress intensities and therefore vary due to changing magnitudes of stress direction. Tables 5 and 6 and Figures 14 and 15 show the thermal stress histories produced by *SE.CLN* and *BR.CLN*.

The project files contain all files associated with this calculation.


	Revision	0			
	Preparer/Date	EEJ 07/20/2005			
	Checker/Date	MQ 07/20/2005			
	File No.	OC-05Q-307	Page 26 of 26		

Table 5: Safe-End Node 1344 Data

Inputs: $\Delta T = -450$
M+B Pressure Stress Intensity, Safe End = 7,732
Total Pressure Stress Intensity, Safe End = 7,767
Piping Load $S_{LMAX} = 4,599$

Results: **Peak Stress Factor, PSF = 0.677**
 $\sigma_{max} = 57,611$ 79,616
 $\sigma_{ss} = 25,261$ 26,396
 $2 * \sigma_{max} - \sigma_{ss} = 89960.60$ 132835.60

TIME (sec)	Membrane (psi)	Bending (psi)	Membrane + Bending (psi)	Peak (psi)	Total (psi)	TOTAL Green's Function (psi/F)	MEM+BND Stress Intensity (Thermal+Pressure) (psi)	TOTAL Stress Intensity (Thermal+Pressure) (psi)
1.00E-10	35	32	64	14	63	-0.14	12,395	12,429
0.01	19	267	272	3027	3259	-7.24222222	12,603	15,625
0.02	68	566	606	5799	6319	-14.0422222	12,937	18,685
0.03	117	864	937	8336	9144	-20.32	13,268	21,510
0.04	163	1162	1266	10660	11750	-26.1111111	13,597	24,116
0.05	208	1459	1594	12790	14170	-31.4888889	13,925	26,536
0.06	252	1755	1919	14750	16410	-36.4666667	14,250	28,776
0.07	294	2049	2243	16540	18480	-41.0666667	14,574	30,846
0.08	335	2343	2564	18200	20410	-45.3555556	14,895	32,776
0.09	375	2634	2882	19720	22210	-49.3555556	15,213	34,576
0.1	414	2925	3199	21120	23880	-53.0666667	15,530	36,246
20000	7566	9169	12930	5103	14030	-31.1777778	25,261	26,396

Note: The actual EXCEL spreadsheet (OC_GreenFCN.xls) contains more time points than are shown here.



Revision	0			
Preparer/Date	EEJ 07/20/2005			
Checker/Date	MQ 07/20/2005			
File No.	OC-05Q-307	Page 27 of 31		

Table 6: Blend Radius Node 584 Data

Inputs:

$\Delta T =$	-450
M+B Pressure Stress Intensity, Blend Radius=	53,150
Total Pressure Stress Intensity, Blend Radius=	56,070
Piping Load $S_{I_{MAX}}$ =	343

Results:

Peak Stress Factor, PSF =	0.993
$\sigma_{max} =$	85,033 85,673
$\sigma_{ss} =$	85,033 85,673
$2 * \sigma_{max} - \sigma_{ss} =$	85033.12 85673.12

TIME (sec)	Membrane (psi)	Bending (psi)	Membrane + Bending (psi)	Peak (psi)	Total (psi)	TOTAL Green's Function (psi/F)	MEM+BND Stress Intensity (Thermal+Pressure) (psi)	TOTAL Stress Intensity (Thermal+Pressure) (psi)
1.00E-10	3160	3162	6274	1196	5886	-13.08	59,767	62,299
0.01	3161	3160	6273	1196	5896	-13.1022	59,766	62,309
0.02	3161	3158	6272	1196	5907	-13.1267	59,765	62,320
0.03	3162	3156	6271	1197	5917	-13.1489	59,764	62,330
0.04	3162	3154	6270	1197	5927	-13.1711	59,763	62,340
0.05	3163	3151	6269	1199	5937	-13.1933	59,762	62,350
0.06	3163	3149	6268	1200	5948	-13.2178	59,761	62,361
0.07	3164	3147	6267	1202	5958	-13.24	59,760	62,371
0.08	3164	3145	6267	1204	5968	-13.2622	59,760	62,381
0.09	3165	3143	6266	1206	5978	-13.2844	59,759	62,391
0.1	3165	3141	6265	1209	5988	-13.3067	59,758	62,401
20000	13630	18030	31540	9486	29260	-65.0222	85,033	85,673

Note: The actual EXCEL spreadsheet (OC_GreenFCN.xls) contains more time points than are shown here.



Revision	0		
Preparer/Date	EEJ 07/20/2005		
Checker/Date	MQ 07/20/2005		
File No.	OC-05Q-307	Page 28 of 31	




Figure 14: Safe-End Node 1344 Green's Function



Revision	0			
Preparer/Date	EEJ 07/20/2005			
Checker/Date	MQ 07/20/2005			
File No.	OC-05Q-307	Page 29 of 31		




Figure 15: Blend Radius Node 584 Green's Function



Revision	0		
Preparer/Date	EEJ 07/20/2005		
Checker/Date	MQ 07/20/2005		
File No.	OC-05Q-307		Page 30 of 31


9.0 REFERENCES

1. MPR Report No. MPR-783, "Oyster Creek Nuclear Generating Station Evaluation of Low Flow Feedwater Control System," August 1983, SI File No. OC-05Q-205.
2. ANSYS Release 8.1 (with Service Pack 1), ANSYS, Inc, April 2004.
3. Structural Integrity Report Number SIR-88-028, Revision 0, "Operating Instructions Feedwater and CRD Return Nozzle Thermal Transient Monitoring System Oyster Creek Nuclear Generating Station," September 16, 1988, SI File No. GPUN-13-101.
4. General Electric, Co. Drawing No. 232-566, "Nozzle Details – Vessel," Revision 6, 9-3-64, SI File No. OC-05Q-232.
5. ASME Boiler and Pressure Vessel Code, Section II, Part D – Properties, 1995 Edition (with 1996 Addenda).
6. E-mail from Michael J. May (OC) to Gary Stevens (SI) dated September 24, 2004, Subject: "Heat Balance," Attached "Heat Balance OC.pdf," SI File No. OC-05Q-228.
7. EPRI Report No. TR-107448, "FatiguePro, Version 2: Fatigue Monitoring Software," December 1997.
8. GPU Nuclear Report No. C-1302-422-E540-046, "Oyster Creek NSR Pipe Analysis, Feedwater System Reactor Nozzles N-4A & N-4B thru penetration X-4A to Anchor 422-14," Revision 2, January 2001, SI File No. OC-05Q-217.



Revision	0			
Preparer/Date	EEJ 07/20/2005			
Checker/Date	MQ 07/20/2005			
File No.	OC-05Q-307	Page 31 of 31		

APPENDIX A: COMPUTER INPUT AND OUTPUT FILES


	Revision	0			
	Preparer/Date	EEJ 07/20/2005			
	Checker/Date	MQ 07/20/2005			
	File No.	OC-05Q-307	Page A1 of A1		

The following list of electronic files is included in the project files:

FILENAME	DESCRIPTION
BR_FLW.OUT	Blend Radius Stress Intensity output file from extraction of Thermal Load application
BR_PRES_FLW.OUT	Blend Radius Stress Intensity output file from extraction of Pressure Load application
OC_FWN_GEOM.INP	Ansys input file for creation of Nozzle Geometry
OC_FWN_PRES.INP	Ansys input file for application of pressure loads
OC_FWN_THM.INP	Ansys input file for application of thermal transients
OC_FWN_THSTR.INP	Ansys input file for application of thermal shock
OC_GreenFCN.XLS	Excel file containing Safe End and Blend Radius Green's Functions
SE_FLW.OUT	Safe End Stress Intensity output file from extraction of thermal shock application
SE_PRES_FLW.OUT	Safe End Stress Intensity output file from extraction of pressure load application
FWN_HT_COEFF.XLS	Spreadsheet that generates Heat Transfer Coefficients
BR.CLN	Output file containing raw information for Blend Radius location Green's Function
SE.CLN	Output file containing raw information for Safe End location Green's Function
XTR_BR.POS	Stress Intensity extraction file for Blend Radius location from Thermal Load application
XTR_BR_PRES.POS	Stress Intensity extraction file for Blend Radius location from Pressure Load application
XTR_SE.POS	Stress Intensity extraction file for Safe End location from Thermal Load application
XTR_SE_PRES.POS	Stress Intensity extraction file for Safe End location from Pressure Load application

Listed Files in Appendix A:

OC_FWN_GEOM.INP	A3-A7
OC_FWN_PRES.INP	A8-A9
OC_FWN_THM.INP	A10-A14
OC_FWN_THSTR.INP	A15-A16
XTR_BR.POS	A17

	Revision	0		
	Preparer/Date	EEJ 07/20/2005		
	Checker/Date	MQ 07/20/2005		
	File No.	OC-05Q-307	Page A2 of A2	

OC_FWN_GEOM.INP

```
!finish
!/clear,start
!/config,nres,100000
!/filn,OC_FWN_GEOM
!/prep7
!et,1,plane42,,1
```

!! Geometry for Oyster Creek Feedwater Nozzle !!

! Material 1 (Reactor Vessel Plate SA 302 Grade B)

```
mp,ex,1,2.79E+07
mp,alpx,1,7.81E-06
mp,kxx,1,24.7/3600/12
mp,c,1,0.1215
mp,nuxy,1,0.3
mp,dens,1,0.283
```

! Material 2 (Nozzle Forging SA 336)

```
mp,ex,2,2.84E+07
mp,alpx,2,7.395E-06
mp,kxx,2,23.8/3600/12
mp,c,2,0.121
mp,nuxy,2,0.3
mp,dens,2,0.283
```

! Material 3 (Safe End SA-105 Gr.II)

```
mp,ex,3,2.80E+07
mp,alpx,3,7.325E-06
mp,kxx,3,28.2/3600/12
mp,c,3,0.1221
mp,nuxy,3,0.3
mp,dens,3,0.283
```

! Geometry

```
*AFUN,deg
local,13,1,,,,-90,
```

```
csys,13
```

! 0,0 is at the end of the Safe End, center line

! inner radius geometry - keypoints

```
k, 1,4.6875,,0
k, 2,4.6875,,3.844
k, 3,4.914 ,,4.75
k, 4,4.914 ,,5.75
k, 5,5.1015,,6.5
k, 6,5.1015,,20.003
k, 7,5.57 ,,21.875
```

! outer radius geometry - keypoints

```
k, 8,5.5 ,,0
k, 9,5.5 ,,0.75
```



	Revision	0			
	Preparer/Date	EEJ 07/20/2005			
	Checker/Date	MQ 07/20/2005			
	File No.	OC-05Q-307	Page A3 of A17		

k,10,5.5 ,,0.93957
 k,11,5.5 ,,3.625
 k,13,5.9375 ,,5.75
 k,14,5.9375 ,,11.0625
 k,15,9.625 ,,14.75
 k,16,9.625 ,,25
 k,19,5.57 ,,40
 l,7,19
 k,50,5.5 ,,6
 k,51,4.6875 ,,6

! lines connecting inner/outer radius keypoints

l,1,2
 l,2,3
 l,3,4
 l,4,5
 l,5,6
 l,6,7
 l,50,51
 l,8,9
 l,9,10
 l,10,11
 l,11,13
 l,13,14
 l,14,15
 l,15,16

! Creating vessel wall

local,14,1,,371.12,,,
 k,21,0,0,0
 k,17,341.501,270,0
 k,18,341.501,299,0
 k,20,348.626,299,0
 k,21,348.626,270,0

l,17,18
 l,20,21
 l,18,20

linter,15,17
 ldele,20
 linter,16,1
 ldele,17
 ldele,23
 ldele,22

k,24,341.501,271.492674
 k,25,343.7096,270
 l,24,25

linter,1,15
 linter,22,20

ldele,15
 ldele,17
 ldele,23

! Creating Fillets

lfillt,19,21,2.375



Revision	0			
Preparer/Date	EEJ 07/20/2005			
Checker/Date	MQ 07/20/2005			
File No.	OC-05Q-307	Page A4 of A17		

ifilt,13,14,1
 ifilt,14,19,1
 ifilt,3,4,0.125
 ifilt,4,5,0.125
 ifilt,5,6,0.125
 ifilt,16,22,2.125
 ifilt,2,3,0.125
 ldele,9,11,1
 ldele,2
 l,2,51
 l,11,50

! Mapping
 ! Vessel Wall

MSHKEY,1 ! Mapped Meshing - user defined
 MAT,1

csys,13
 k,53,10.625,,15 ! Additional geometry
 k,54,10.625,,35
 l,53,54

linter,10,15
 linter,1,30
 ldele,32
 ldele,29
 l,26,39
 k,55,17.5,,15
 k,56,17.5,,35
 l,55,56
 linter,10,29
 linter,21,33
 ldele,34,36,2
 lesize,18,,,10
 lesize,35,,,10
 lesize,30,,,40
 lesize,10,,,40
 al,35,30,18,10

! AREA 1

ldele,1
 lesize,31,,,10
 lesize,32,,,10
 lesize,29,,,8
 lesize,28,,,2
 al,31,32,35,29,28 ! AREA 2

! Corner - Nozzle Forging

! Creating 2 pie shaped pieces - this is the first

Mat,2
 kl,11,0.5,60
 l,60,38
 linter,1,26
 linter,1,11
 lesize,1,,,10
 lesize,26,,,5
 lesize,22,,,3
 lesize,15,,,2
 lesize,33,,,10
 al,33,1,26,22,15,31 ! AREA 3

! Creating second pie shape



Revision	0			
Preparer/Date	EEJ 07/20/2005			
Checker/Date	MQ 07/20/2005			
File No.	OC-05Q-307	Page A5 of A17		

l,6,26
 lesize,11,,10
 lesize,21,,12
 lesize,16,,9
 lesize,7,,3
 al,21,11,7,16,1

! AREA 4

! Meshing the final portion of the Nozzle End forging

csys,13
 k,70,5,,7.8125
 k,71,6,,7.8125
 l,70,71
 linter,6,34
 ldele,38
 linter,13,39
 ldele,40
 kl,36,0.4,73
 kl,36,0.765,74
 l,31,73
 l,28,74

! Additional Geometry

! First section (3) of the final portion of nozzle end forging

linter,13,36
 linter,39,41
 lesize,13,,10
 lesize,19,,10
 lesize,40,,10
 al,11,19,13,40

! AREA 5

! Second section (3) of the final portion of nozzle end forging

lesize,39,,10
 lesize,17,,2
 lesize,14,,8
 lesize,20,,2
 lesize,42,,12
 al,39,17,14,20,42,13

! AREA 6

! Third section (3) of the final portion of nozzle end forging

lesize,38,,10
 lesize,36,,5
 lesize,34,,5
 al,34,39,36,38

! AREA 7

! Creating the first mesh (3) of Safe End

Mat,3

l,34,13
 l,40,11
 lesize,37,,6
 lesize,25,,1
 lesize,5,,4
 lesize,24,,1
 lesize,41,,10
 lesize,6,,12
 al,37,25,5,24,41,6,38

! AREA 8



Revision	0			
Preparer/Date	EEJ 07/20/2005			
Checker/Date	MQ 07/20/2005			
File No.	OC-05Q-307	Page A6 of A17		

! Creating the second mesh (3) of Safe End

lesize,4,,4
 lesize,23,,1
 lesize,3,,4
 lesize,27,,1
 lesize,43,,10
 lesize,12,,10
 al,41,12,43,27,3,23,4 ! AREA 9

! Complete the final section---something wrong with Geometry...

ldele,2
 l,40,51
 lesize,8,,10
 lesize,2,,15
 lesize,9,,15
 al,2,8,9,43 ! AREA 10

! Concatenating lines for Meshing
 lccat,28,29 ! For Area 2

flst,2,3,4,orde,3 ! For Area 3
 fitem,2,15
 fitem,2,22
 fitem,2,26
 lccat,p51x

lccat,7,16 ! For Area 4

FLST,2,3,4,ORDE,3 ! For Area 6
 FITEM,2,14
 FITEM,2,17
 FITEM,2,20
 LCCAT,P51X

FLST,2,4,4,ORDE,4 ! For Area 8
 FITEM,2,5
 FITEM,2,24
 FITEM,2,-25
 FITEM,2,37
 LCCAT,P51X

FLST,2,4,4,ORDE,4 ! For Area 9
 FITEM,2,3
 FITEM,2,-4
 FITEM,2,23
 FITEM,2,27
 LCCAT,P51X

! Creating Meshes from areas

Mat,1 ! Meshing for Material 1 Areas
 amesh,1,2,1
 mat,2 ! Meshing for Material 2 Areas
 amesh,3,7,1
 mat,3 ! Meshing for Material 3 Areas
 amesh,8,10,1

/PNUM,LINE,1
 /PNUM,KP,1
 lplot



Revision	0			
Preparer/Date	EEJ 07/20/2005			
Checker/Date	MQ 07/20/2005			
File No.	OC-05Q-307	Page A7 of A17		

OC_FWN_PRES.INP

```

finish
/clear,start
/config,nres,100000
/filn,OC_FWN_STR
/prep7
! Oyster Creek
/title, Feedwater Nozzle Finite Element Model

! 2D model for generating Greene's Functions

et,1,plane42,,,1 ! axisymmetric

/input,OC_FWN_GEOM,inp

!!!!!!!!!!!!!!!!!!!!!!!!!!!!!!
!! Boundary Conditions !!
!!!!!!!!!!!!!!!!!!!!!!!!!!!!!!

! Coupled Nodes on the Nozzle Safe End
FLST,5,11,1,ORDE,3
FITEM,5,1343
FITEM,5,1358
FITEM,5,-1367
NSEL,S,,P51X
cp,1,uy,all

! Symmetry Conditions
nsel,all
DL,18,,SYMM,,

/solu

! Define Pressure Value and Cap Load
*set,Pressure,1000 ! Pressure (psi), internal pressure applied
*set,PCAP,Pressure*((2*4.6875)**2)/((2*5.5)**2-(2*4.6875)**2)

! ** Apply Cap Load**
SFL,8,PRES,-PCAP

! ** Apply Pressure Load **
SFL, 2,PRES,Pressure ! ID of Safe End
SFL,27,PRES,Pressure ! ID of Safe End
SFL, 3,PRES,Pressure ! ID of Safe End
SFL,23,PRES,Pressure ! ID of Safe End
SFL, 4,PRES,Pressure ! ID of Safe End
SFL,24,PRES,Pressure ! ID of Safe End
SFL, 5,PRES,Pressure ! ID of Safe End
SFL,25,PRES,Pressure ! ID of Safe End
SFL,37,PRES,Pressure ! ID of Safe End
SFL,36,PRES,Pressure ! ID of Nozzle Forging
SFL,42,PRES,Pressure ! ID of Nozzle Forging
SFL,40,PRES,Pressure ! ID of Nozzle Forging
SFL, 7,PRES,Pressure ! ID of Nozzle Forging
SFL,16,PRES,Pressure ! ID of Nozzle Forging
SFL,26,PRES,Pressure ! ID of Nozzle Forging
SFL,22,PRES,Pressure ! ID of Nozzle Forging
SFL,15,PRES,Pressure ! ID of Nozzle Forging
SFL,32,PRES,Pressure ! ID of Vessel Wall
    
```



	Revision	0		
	Preparer/Date	EEJ 07/20/2005		
	Checker/Date	MQ 07/20/2005		
File No. OC-05Q-307				Page A8 of A17

SFL,30,PRES,Pressure !ID of Vessel Wall

SOLVE
SAVE
FINISH
/ANG,1,30,ZS,1
/REP,FAST
/ANG,1,30,ZS,1
/REP,FAST
/ANG,1,30,ZS,1
/REP,FAST



Revision	0			
Preparer/Date	EEJ 07/20/2005			
Checker/Date	MQ 07/20/2005			
File No.	OC-05Q-307	Page A9 of A17		

OC_FWN_THM.INP

```
finish
/clear,start
/config,nres,100000
/file,OC_FWN_THM
/prep7
```

! Oyster Creek Feedwater Nozzle

/title, 2-D Axisymmetric OC Feedwater Nozzle FEM for Green's Functions

et,1,plane55,,1 !Axisymmetric

/input,OC_FWN_GEOM,inp

```
!!!!!!!!!!!!!!!!!!!!!!!!!!!!!!
!! Boundary Conditions !!
!!!!!!!!!!!!!!!!!!!!!!!!!!!!!!
```

! Coupled Nodes on the Nozzle Safe End

```
FLST,5,11,1,ORDE,3
FITEM,5,1343
FITEM,5,1358
FITEM,5,-1367
NSEL,S,,P51X
cp,1,uy,all
```

! Symmetry Conditions
DL,18,symm

```
/solu
!!!!!!!!!!!!!!!!!!!!!!!!!!!!!!
! Thermal Boundary Conditions !
!!!!!!!!!!!!!!!!!!!!!!!!!!!!!!
```

! Heat Transfer Coefficients - Steady State

```
Tamb=70                ! Ambient Temperature

h1=205.1/(3600*144)    ! Safe End
h2=205.1/(3600*144)    ! Nozzle Forging step 1
h3=205.1/(3600*144)    ! Nozzle Forging step 2
h4=205.1/(3600*144)    ! Vessel Wall
h5=(h1+h2)/2           ! Thermal sleeve rest
ho=0.2/(3600*144)      ! Outside Heat Temperature Coefficient
```

```
T1=550
T2=550
T3=550
T4=550
T5=550
```

```
/solu
!!!!!!!!!!!!!!!!!!!!!!!!!!!!!!
!! Load Step 1 - Steady-State, No Flow !!
!!!!!!!!!!!!!!!!!!!!!!!!!!!!!!
```

! Apply HTC's



	Revision	0			
	Preparer/Date	EEJ 07/20/2005			
	Checker/Date	MQ 07/20/2005			
	File No.	OC-05Q-307		Page A10 of A17	

! Region 1
 SFL, 2, CONV, h1,, T1
 SFL, 27, CONV, h1,, T1
 SFL, 3, CONV, h1, h5, T1, T5

! Region 5
 SFL, 23, CONV, h5,, T5
 SFL, 4, CONV, h5,, T5
 SFL, 24, CONV, h5,, T5
 SFL, 5, CONV, h5, h2, T5, T2

! Region 2
 SFL, 25, conv, h2,, T2
 SFL, 37, conv, h2,, T2
 SFL, 36, conv, h2,, T2
 SFL, 42, conv, h2,, T2
 SFL, 40, conv, h2,, T2
 SFL, 7, conv, h2, h3, T2, T3

! Region 3
 SFL, 16, conv, h3,, T3
 SFL, 26, conv, h3, h4, T3, T4

! Blend Radius

! Region 4
 SFL, 22, conv, h4,, T4
 SFL, 15, conv, h4,, T4
 SFL, 32, conv, h4,, T4
 SFL, 30, conv, h4,, T4

SFL, 18, conv, ho,, Tamb
 SFL, 10, conv, ho,, Tamb
 SFL, 29, conv, ho,, Tamb
 SFL, 28, conv, ho,, Tamb
 SFL, 33, conv, ho,, Tamb
 SFL, 21, conv, ho,, Tamb
 SFL, 19, conv, ho,, Tamb
 SFL, 20, conv, ho,, Tamb
 SFL, 14, conv, ho,, Tamb
 SFL, 17, conv, ho,, Tamb
 SFL, 34, conv, ho,, Tamb
 SFL, 6, conv, ho,, Tamb
 SFL, 12, conv, ho,, Tamb
 SFL, 9, conv, ho,, Tamb
 SFL, 8, conv, ho,, Tamb

!!!!!!!!!!!!!!!!!!!!!!!!!!!!
 !! Perform Steady State Run
 !!!!!!!!!!!!!!!!!!!!!!!!!!!!!

ANTYPE, TRANS
 allsel, all
 outres, all, all
 TIMINT, off
 TIME, 1e-10
 SOLVE
 SAVE

!!!!!!!!!!!!!!!!!!!!
 !! Load Step 2 !!
 !!!!!!!!!!!!!!!!!!!!!



Revision	0			
Preparer/Date	EEJ 07/20/2005			
Checker/Date	MQ 07/20/2005			
File No.	OC-05Q-307	Page A11 of A17		

! Heat Transfer Coefficients - Shock

h1=2108.8/(3600*144)
 h2=673.9/(3600*144)
 h3=191.8/(3600*144)
 h4=1000/(3600*144)
 h5=(h1+h2)/2
 ho=0.2/(3600*144)

! Safe End
 ! Nozzle Forging step 1
 ! Nozzle Forging step 2
 ! Vessel Wall
 ! Thermal sleeve rest
 ! Outside Heat Temperature Coefficient

T1=100
 T2=325
 T3=325
 T4=550
 T5=325

/solu

!!
 !! Load Step 2 - Thermal Shock - Max Flow !!
 !!!

! Region 1
 SFL, 2, CONV, h1,, T1
 SFL, 27, CONV, h1,, T1
 SFL, 3, CONV, h1, h5, T1, T5

! Step Region
 SFL, 23, CONV, h5,, T5
 SFL, 4, CONV, h5,, T5
 SFL, 27, CONV, h5,, T5
 SFL, 5, CONV, h5, h2, T5, T2

! Region 2
 SFL, 25, conv, h2,, T2
 SFL, 37, conv, h2,, T2
 SFL, 36, conv, h2,, T2
 SFL, 42, conv, h2,, T2
 SFL, 40, conv, h2,, T2
 SFL, 7, conv, h2, h3, T2, T3

! Region 3
 SFL, 16, conv, h3,, T3
 SFL, 26, conv, h3, h4, T3, T4
 ! Blend Radius

! Region 4
 SFL, 22, conv, h4,, T4
 SFL, 15, conv, h4,, T4
 SFL, 32, conv, h4,, T4
 SFL, 30, conv, h4,, T4

SFL, 18, conv, ho,, Tamb
 SFL, 10, conv, ho,, Tamb
 SFL, 29, conv, ho,, Tamb
 SFL, 28, conv, ho,, Tamb
 SFL, 33, conv, ho,, Tamb
 SFL, 21, conv, ho,, Tamb
 SFL, 19, conv, ho,, Tamb
 SFL, 20, conv, ho,, Tamb
 SFL, 14, conv, ho,, Tamb
 SFL, 17, conv, ho,, Tamb
 SFL, 34, conv, ho,, Tamb



Revision	0			
Preparer/Date	EEJ 07/20/2005			
Checker/Date	MQ 07/20/2005			
File No.	OC-05Q-307	Page A12 of A17		

SFL, 6,conv,ho,,Tamb
 SFL, 12,conv,ho,,Tamb
 SFL, 9,conv,ho,,Tamb
 SFL, 8,conv,ho,,Tamb

! Load Step 2 - Thermal Shock

nset,all
 esel,all
 outres,all,all

KBC,1
 TIMINT,ON
 AUTOTS,OFF
 NSUBST,300,
 TIME,3
 SOLVE
 SAVE

! Load Step 3

nset,all
 esel,all
 outres,all,all

KBC,1
 TIMINT,ON
 AUTOTS,OFF
 NSUBST,70,
 TIME,10
 SOLVE
 SAVE

! Load Step 4

nset,all
 esel,all
 outres,all,all

KBC,1
 TIMINT,ON
 AUTOTS,OFF
 NSUBST,900,
 TIME,100
 SOLVE
 SAVE

! Load Step 5

nset,all
 esel,all
 outres,all,all

KBC,1
 TIMINT,ON
 AUTOTS,OFF
 NSUBST,900,
 TIME,1000
 SOLVE
 SAVE

! Load Step 6

nset,all
 esel,all
 outres,all,all



Revision	0			
Preparer/Date	EEJ 07/20/2005			
Checker/Date	MQ 07/20/2005			
File No.	OC-05Q-307	Page A13 of A17		

KBC,1
TIMINT,ON
AUTOTS,ON
NSUBST,100,200,10
NROPT,AUTO,,ON
TIME,20000
SOLVE
SAVE
FINISH



Revision	0			
Preparer/Date	EEJ 07/20/2005			
Checker/Date	MQ 07/20/2005			
File No.	OC-05Q-307	Page A14 of A17		

OC_FWN_THSTR.INP

```

finish
/clear,start
/CONFIG,NRES,100000
/FILN,OC_FWN_TS
/prep7
! , Oyster Creek Nuclear Power Plant
/title, Feedwater Nozzle Finite Element Model
/com, title, 2D Model for generating Greene's functions
    
```

```
ct,1,plane42,,,1 ! axisymmetric
```

```
/input,OC_FWN_GEOM,inp
```

```

!!!!!!!!!!!!!!!!!!!!!!!!!!!!!!
!! Boundary Conditions !!
!!!!!!!!!!!!!!!!!!!!!!!!!!!!!!
    
```

```

! Coupled Nodes on the Nozzle Safe End
FLST,5,11,1,ORDE,3
FITEM,5,1343
FITEM,5,1358
FITEM,5,-1367
NSEL,S,,P51X
cp,1,uy,all
    
```

```

! Symmetry Conditions
nsel,all
DL,18,,SYMM,,
    
```

```
/solu
```

```

/COM,*****
/COM, Read Thermal Stress
/COM,*****
Tref,70
/COM, LOAD STEP 1, STEADY STATE
!dread,temp,,,1e-10,,OC_FWN_THM,rth
time,1e-10
solve
    
```

```

/COM, LOAD STEP 2, FIRST THREE SECONDS
*do,i,0.01,3,0.01
!dread,temp,,,i,,OC_FWN_THM,rth
time,i
solve
*enddo
    
```

```

/COM, LOAD STEP 3
*do,i,3.1,10,0.1
!dread,temp,,,i,,OC_FWN_THM,rth
time,i
solve
*enddo
    
```

```

/COM, LOAD STEP 4
*do,i,10.2,100,0.1
!dread,temp,,,i,,OC_FWN_THM,rth
time,i
solve
    
```



	Revision	0			
	Preparer/Date	EEJ 07/20/2005			
	Checker/Date	MQ 07/20/2005			
	File No.	OC-05Q-307			Page A15 of A17

*enddo

/COM, LOAD STEP 5

*do,i,101,1000,1

!dread,temp,,i,,OC_FWN_THM,rth

time,i

solve

*enddo

/COM, LOAD STEP 6

*do,i,1200,20000,200

!dread,temp,,i,,OC_FWN_THM,rth

time,i

solve

*enddo

SAVE

FINI

! /INP,XTR_FLW,POS



Revision

0

Preparer/Date

EEJ 07/20/2005

Checker/Date

MQ 07/20/2005

File No. OC-05Q-307

Page A16 of A17

