

CONDITION	REQUIRED ACTION	COMPLETION TIME
C. (continued)	C.2 Restore one offsite circuit to OPERABLE status.	24 hours <u>AND</u> 8 days from discovery of failure to meet LCO except for Condition A
D. Two DGs inoperable.	D.1 Restore one DG to OPERABLE status.	2 hours
E. Required Action and Associated Completion Time of Condition A, B, C, or D not met.	E.1 Be in MODE 3. <u>AND</u> E.2 Be in MODE 4.	12 hours 36 hours
F. Three or more AC sources inoperable.	F.1 Enter LCO 3.0.3.	Immediately