SECTION I

INSPECTION OBJECTIVES

1. Ensure that the test procedure is technically adequate.

2. Ensure that the described test is consistent with regulatory requirements, guidance, and licensee commitments.

SECTION II

INSPECTION REQUIREMENTS

The inspector shall:

1. Obtain and review an approved copy of the test procedure(s) for technical adequacy prior to the date scheduled for the test.

2. Review the FSAR, SER, Technical Specifications, docketed correspondence, and Regulatory Guide 1.68. Verify that the test procedure adequately addresses NRC requirements and licensee commitments relating to the shutdown of the reactor from a remote location, (i.e., not the Control Room).

3. Review the test procedure(s) in accordance with inspection procedure MC 70300B.

SECTION III

INSPECTION GUIDANCE

1. The review should insure that important system performance functions are adequately reflected in this test procedure. Examples of items which should be adequately tested as part of the test procedure include (but are not limited to):

   a. operations and indications available at the Remote Shutdown Instrument and Control Panel,

   b. instrumentation and indicating device verification,

   c. demonstration of override control functions,

   d. communications network between stations, and

   e. electrical independence and redundancy.

NOTE: Items may be part of other systems tests.