

Table 6.2.4-1—Containment Isolation Valve and Actuator Data
Sheet 1 of 18

Pent-ration No. (JMK)	GDC Req.	System Name	Fluid	Line Size (in)	Essent System	Potent Bypass Path	Valve Number	Valve Location	Type C Leak Test	Valve Type and Operator	Pri-ary Act-uation	Sec-on-dary Act-uation	Normal Position	Shut-down Position	Post Accident Position	Power Failure Position	Cont. Isolation Signal	Valve Closure Time	Power Source
12BQ017	56	FPCPS	water	6.0	no	no	FAL15 AA003	inside	yes	swing check	self	self	o/c	o/c	close	n/a	n/a	n/a	n/a
12BQ016	56	FPCPS	water	6.0	no	no	FAL12 AA001	inside	yes	gate / MOV	PS	RM	o/c	o/c	close	as-is	stage 1	≤ 30 sec	34BRA
12BQ017	56	FPCPS	water	6.0	no	no	FAL15 AA002	outside	yes	gate / MOV	PS	RM	o/c	o/c	close	as-is	stage 1	≤ 30 sec	31BNB03
12BQ016	56	FPCPS	water	6.0	no	no	FAL12 AA002	outside	yes	gate / MOV	PS	RM	o/c	o/c	close	as-is	stage 1	≤ 30 sec	31BNB03
60BQ042	56	FPCPS	water	20.0	no	no	FAL40 AA002	inside	no	gate / manual	manual	manual	close	o/c	close	n/a	n/a	n/a	n/a
60BQ042	56	FPCPS	water	20.0	no	no	FAL40 AA001	outside	no	gate / manual	manual	manual	close	o/c	close	n/a	n/a	n/a	n/a
74BQ034	57	DWDS	water	2.0	no	no	GHC74 AA002	inside	yes	globe/ MOV	PS	RM	open	open	close	as-is	stage 1	≤ 15 sec	34BRA
74BQ034	57	DWDS	water	2.0	no	no	GHC74 AA001	outside	yes	globe/ MOV	PS	RM	open	open	close	as-is	stage 1	≤ 15 sec	31BNB03
10BQ021	55	EBS loop 1&2	water	2.0	yes	no	JDH10 AA007	inside	yes	lift check	self	self	close	close	open	n/a	n/a	n/a	n/a
40BQ022	55	EBS loop 3&4	water	2.0	yes	no	JDH40 AA007	inside	yes	lift check	self	self	close	close	open	n/a	n/a	n/a	n/a
10BQ021	55	EBS loop 1&2	water	2.0	yes	no	JDH10 AA006	outside	yes	globe/ MOV	PS	RM	open	open	open	as-is	stage 1	≤ 15 sec	31BNB03
40BQ022	55	EBS loop 3&4	water	2.0	yes	no	JDH40 AA006	outside	yes	globe/ MOV	PS	RM	open	open	open	as-is	stage 1	≤ 15 sec	34BNB03
10BQ001	55	CVCS Seal return	water	2.0	yes	no	JEW50 AA001	inside	yes	globe/ MOV	PS	RM	open	close	o/c	as-is	stage 2	≤ 15 sec	34BRA
10BQ004	55	CVCS Seal injection	water	2.0	yes	no	JEW01 AA006	inside	yes	lift check	self	self	open	close	o/c	n/a	n/a	n/a	n/a
10BQ001	55	CVCS Seal return	water	2.0	yes	no	JEW50 AA002	outside	yes	globe/ MOV	PS	RM	open	close	o/c	as-is	stage 2	≤ 15 sec	31BNB03

Table 6.2.4-1—Containment Isolation Valve and Actuator Data
Sheet 2 of 18

Pent-ration No. (JMK)	GDC Req.	System Name	Fluid	Line Size (in)	Essent System	Potent Bypass Path	Valve Number	Valve Location	Type C Leak Test	Valve Type and Operator	Pri-ary Act-uation	Sec-on-dary Act-uation	Normal Position	Shut-down Position	Post Accident Position	Power Failure Position	Cont. Isolation Signal	Valve Closure Time	Power Source	
10BQ004	55	CVCS Seal injection	water	2.0	yes	no	JEW01 AA005	outside	yes	globe/ MOV	PS	RM	open	close	o/c	as-is	stage 2	≤ 15 sec	31BNB03	
60BQ054	56	Equip. Hatch	air	n/a	n/a	n/a	n/a	n/a	no	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
BQ211	56	Personnel airlock	air	n/a	n/a	n/a	n/a	n/a	no	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
BQ053	56	Emer. airlock	air	n/a	n/a	n/a	n/a	n/a	no	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
BQ052	56	Const. Opening	air	n/a	n/a	n/a	n/a	n/a	no	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
10BQ048	56	Leak Off System	air	10.0	no	no	JMM10 AA006	inside	yes	gate/ MOV	PS	RM	close	o/c	close	as-is	stage 1	≤ 50 sec	34BRA	
10BQ048	56	Leak Off System	air	10.0	no	no	JMM10 AA007	outside	yes	gate/ MOV	PS	RM	close	o/c	close	as-is	stage 1	≤ 50 sec	31BNB03	
30BQ312	56	Leak Off System	air	0.5	no	no	JMM30 AA001	inside	yes	globe/ manual	n/a	n/a	close	o/c	close	n/a	n/a	n/a	n/a	n/a
30BQ312	56	Leak Off System	air	0.5	no	no	JMM30 AA003	outside	yes	globe/ manual	n/a	n/a	close	o/c	close	n/a	n/a	n/a	n/a	n/a
23BQ065	57	Leak Off System	air	2.0	yes	no	JMM23 AA001	inside	yes	globe/ MOV	RM	RM	open	o/c	open	as-is	no	≤ 15 sec	31BRA	
23BQ065	57	Leak Off System	air	2.0	yes	no	JMM23 AA002	outside	yes	globe/ MOV	RM	RM	open	o/c	open	as-is	no	≤ 15 sec	34BRA	
41BQ104	56	SAHRS Spray line	water	8.0	no	no	JMQ41 AA002	inside	yes	swing check	self	self	close	close	o/c	n/a	n/a	n/a	n/a	n/a
41BQ104	56	SAHRS Spray line	water	8.0	no	no	JMQ41 AA001	outside	yes	globe/ MOV	PS	RM	close	close	o/c	as-is	stage 1	≤ 40 sec	34BNB03	
42BQ105	56	SAHRS Basemat cooling line	water	8.0	no	no	JMQ42 AA002	inside	yes	swing check	self	self	close	close	o/c	n/a	n/a	n/a	n/a	n/a

Table 6.2.4-1—Containment Isolation Valve and Actuator Data
Sheet 3 of 18

Pent-ration No. (JMK)	GDC Req.	System Name	Fluid	Line Size (in)	Essent System	Potent Bypass Path	Valve Number	Valve Location	Type C Leak Test	Valve Type and Operator	Pri-ary Act-uation	Sec-on-dary Act-uation	Normal Position	Shut-down Position	Post Accident Position	Power Failure Position	Cont. Isolation Signal	Valve Closure Time	Power Source
42BQ105	56	SAHRS Basemat cooling line	water	8.0	no	no	JMQ42 AA001	outside	yes	globe/ MOV	PS	RM	close	close	o/c	as-is	stage 1	≤ 40 sec	34BNB03
43BQ116	56	SAHRS Screen flushing line	water	4.0	no	no	JMQ43 AA002	inside	yes	swing check	self	self	close	close	o/c	n/a	n/a	n/a	n/a
43BQ116	56	SAHRS Screen flushing line	water	4.0	no	no	JMQ43 AA001	outside	yes	globe/ MOV	PS	RM	open	close	o/c	as-is	stage 1	≤ 20 sec	34BNB03
50BQ150	56	HMS Anal 1	gas	0.125	no	no	JMU50 AA075	inside	yes	globe/ SOV	PS	RM	close	close	o/c	close	stage 1	≤ 15 sec	33BNB03
50BQ150	56	HMS Anal 1	gas	0.125	no	no	JMU50 AA077	inside	Yes	globe/ SOV	PS	RM	close	close	o/c	close	stage 1	≤ 15 sec	33BNB03
50BQ150	56	HMS Anal 1	gas	0.125	no	no	JMU50 AA079	inside	yes	globe/ SOV	PS	RM	close	close	o/c	close	stage 1	≤ 15 sec	33BNB03
50BQ150	56	HMS Anal 1	gas	0.125	no	no	JMU50 AA081	inside	yes	globe/ SOV	PS	RM	close	close	o/c	close	stage 1	≤ 15 sec	33BNB03
50BQ150	56	HMS Anal 1	gas	0.125	no	no	JMU50 AA076	outside	yes	globe/ SOV	PS	RM	close	close	o/c	close	stage 1	≤ 15 sec	34BNB03
50BQ150	56	HMS Anal 1	gas	0.125	no	no	JMU50 AA078	outside	yes	globe/ SOV	PS	RM	close	close	o/c	close	stage 1	≤ 15 sec	34BNB03
50BQ150	56	HMS Anal 1	gas	0.125	no	no	JMU50 AA080	outside	yes	globe/ SOV	PS	o/c	o/c	o/c	o/c	close	stage 1	≤ 15 sec	34BNB03
50BQ150	56	HMS Anal 1	gas	0.125	no	no	JMU50 AA082	outside	yes	globe/ SOV	PS	RM	close	close	o/c	close	stage 1	≤ 15 sec	34BNB03
50BQ150	56	HMS Anal 1 return	gas	0.125	no	no	JMU50 AA083	outside	yes	globe/ SOV	PS	RM	close	close	o/c	close	stage 1	≤ 15 sec	34BNB03
50BQ150	56	HMS Anal 1 return	gas	0.125	no	no	JMU50 AA084	inside	yes	globe/ SOV	PS	RM	close	close	o/c	close	stage 1	≤ 15 sec	33BNB03
50BQ451	56	HMS Anal 2	gas	0.125	no	no	JMU51 AA085	inside	yes	globe/ SOV	PS	RM	close	close	o/c	close	stage 1	≤ 15 sec	32BNB03

Table 6.2.4-1—Containment Isolation Valve and Actuator Data
Sheet 4 of 18

Pent-ration No. (JMK)	GDC Req.	System Name	Fluid	Line Size (in)	Essent System	Potent Bypass Path	Valve Number	Valve Location	Type C Leak Test	Valve Type and Operator	Pri-ary Act-uation	Sec-on-dary Act-uation	Normal Position	Shut-down Position	Post Accident Position	Power Failure Position	Cont. Isolation Signal	Valve Closure Time	Power Source
50BQ451	56	HMS Anal 2	gas	0.125	no	no	JMU51 AA087	inside	yes	globe/ SOV	PS	RM	close	close	o/c	close	stage 1	≤ 15 sec	32BNB03
50BQ451	56	HMS Anal 2	gas	0.125	no	no	JMU51 AA089	inside	yes	globe/ SOV	PS	RM	close	close	o/c	close	stage 1	≤ 15 sec	32BNB03
50BQ451	56	HMS Anal 2	gas	0.125	no	no	JMU51 AA091	inside	yes	globe/ SOV	PS	RM	close	close	o/c	close	stage 1	≤ 15 sec	32BNB03
50BQ451	56	HMS Anal 2	gas	0.125	no	no	JMU51 AA086	outside	yes	globe/ SOV	PS	RM	close	close	o/c	close	stage 1	≤ 15 sec	31BNB03
50BQ451	56	HMS Anal 2	gas	0.125	no	no	JMU51 AA088	outside	yes	globe/ SOV	PS	RM	close	close	o/c	close	stage 1	≤ 15 sec	31BNB03
50BQ451	56	HMS Anal 2	gas	0.125	no	no	JMU51 AA090	outside	yes	globe/ SOV	PS	RM	close	close	o/c	close	stage 1	≤ 15 sec	31BNB03
50BQ451	56	HMS Anal 2	gas	0.125	no	no	JMU51 AA092	outside	yes	globe/ SOV	PS	RM	close	close	o/c	close	stage 1	≤ 15 sec	31BNB03
50BQ451	56	HMS Anal 2 return	gas	0.125	no	no	JMU51 AA093	outside	yes	globe/ SOV	PS	RM	close	close	o/c	close	stage 1	≤ 15 sec	31BNB03
50BQ451	56	HMS Anal 2 return	gas	0.125	no	no	JMU51 AA094	inside	yes	globe/ SOV	PS	RM	close	close	o/c	close	stage 1	≤ 15 sec	32BNB03
10BQ103	55	LHSI/ RHR Train 1	water	10.0	yes	no	JNA10 AA002	inside	yes	globe/ MOV	PS	RM	close	open	o/c	as-is	no	≤ 50 sec	32BRA
20BQ203	55	LHSI/ RHR Train 2	water	10.0	yes	no	JNA20 AA002	inside	yes	globe/ MOV	PS	RM	close	open	o/c	as-is	no	≤ 50 sec	31BRA
30BQ308	55	LHSI/ RHR Train 3	water	10.0	yes	no	JNA30 AA002	inside	yes	globe/ MOV	PS	RM	close	open	o/c	as-is	no	≤ 50 sec	34BRA
40BQ403	55	LHSI/ RHR Train 4	water	10.0	yes	no	JNA40 AA002	inside	yes	globe/ MOV	PS	RM	close	open	o/c	as-is	no	≤ 50 sec	33BRA
10BQ103	55	LHSI/ RHR Train 1	water	1.0	yes	no	JNG15 AA004	inside	yes	globe/ MOV	PS	RM	close	close	close	as-is	no	≤ 15 sec	32BRA

Table 6.2.4-1—Containment Isolation Valve and Actuator Data
Sheet 5 of 18

Pent-ration No. (JMK)	GDC Req.	System Name	Fluid	Line Size (in)	Essent System	Potent Bypass Path	Valve Number	Valve Location	Type C Leak Test	Valve Type and Operator	Pri-ary Act-uation	Sec-on-dary Act-uation	Normal Position	Shut-down Position	Post Accident Position	Power Failure Position	Cont. Isolation Signal	Valve Closure Time	Power Source
10BQ103	55	LHSI/RHR Train 1	water	10.0	yes	no	JNA10 AA003	outside	yes	globe/MOV	PS	RM	close	open	o/c	as-is	no	≤ 50 sec	31BNB03
10BQ103	55	LHSI/RHR Train 1	water	8.0	yes	no	JNG12 AA001	outside	yes	globe/MOV	PS	RM	close	close	o/c	as-is	no	≤ 40 sec	31BNB03
20BQ203	55	LHSI/RHR Train 2	water	10.0	yes	no	JNA20 AA003	outside	yes	globe/MOV	PS	RM	close	open	o/c	as-is	no	≤ 50 sec	32BNB03
20BQ203	55	LHSI/RHR Train 2	water	1.0	yes	no	JNG25 AA004	inside	yes	globe/MOV	PS	RM	close	close	close	as-is	no	≤ 15 sec	31BRA
20BQ203	55	LHSI/RHR Train 2	water	8.0	yes	no	JNG22 AA001	outside	yes	globe/MOV	PS	RM	close	close	o/c	as-is	no	≤ 40 sec	32BNB03
30BQ308	55	LHSI/RHR Train 3	water	10.0	yes	no	JNA30 AA003	outside	yes	globe/MOV	PS	RM	close	open	o/c	as-is	no	≤ 50 sec	33BNB03
30BQ308	55	LHSI/RHR Train 3	water	1.0	yes	no	JNG35 AA004	inside	yes	globe/MOV	PS	RM	close	close	close	as-is	no	≤ 15 sec	34BRA
30BQ308	55	LHSI/RHR Train 3	water	8.0	yes	no	JNG32 AA001	outside	yes	globe/MOV	PS	RM	close	close	o/c	as-is	no	≤ 40 sec	33BNB03
40BQ403	55	LHSI/RHR Train 4	water	10.0	yes	no	JNA40 AA003	outside	yes	globe/MOV	PS	RM	close	open	o/c	as-is	no	≤ 50 sec	34BNB03
40BQ403	55	LHSI/RHR Train 4	water	1.0	yes	no	JNG45 AA004	inside	yes	globe/MOV	PS	RM	close	close	close	as-is	no	≤ 15 sec	33BRA
40BQ403	55	LHSI/RHR Train 4	water	8.0	yes	no	JNG42 AA001	outside	yes	globe/MOV	PS	RM	close	close	o/c	as-is	no	≤ 40 sec	34BNB03
10BQ102	55	MHSI Train 1	water	6.0	yes	no	JND10 AA007	inside	yes	swing check	self	self	close	close	o/c	n/a	n/a	n/a	n/a
10BQ102	55	MHSI Train 1	water	6.0	yes	no	JND10 AA002	outside	yes	globe/MOV	PS	RM	open	open	o/c	as-is	no	≤ 30 sec	31BNB03

Table 6.2.4-1—Containment Isolation Valve and Actuator Data
Sheet 6 of 18

Pent-ration No. (JMK)	GDC Req.	System Name	Fluid	Line Size (in)	Essent System	Potent Bypass Path	Valve Number	Valve Location	Type C Leak Test	Valve Type and Operator	Pri-ary Act-uation	Sec-on-dary Act-uation	Normal Position	Shut-down Position	Post Accident Position	Power Failure Position	Cont. Isolation Signal	Valve Closure Time	Power Source
20BQ202	55	MHSI Train 2	water	6.0	yes	no	JND20 AA007	inside	yes	swing check	self	self	close	close	o/c	n/a	no	n/a	n/a
20BQ202	55	MHSI Train 2	water	6.0	yes	no	JND20 AA002	outside	yes	globe/ MOV	PS	RM	open	open	o/c	as-is	no	≤ 30 sec	32BNB03
30BQ302	55	MHSI Train 3	water	6.0	yes	no	JND30 AA007	inside	yes	swing check	self	self	close	close	o/c	n/a	n/a	n/a	n/a
30BQ302	55	MHSI Train 3	water	6.0	yes	no	JND30 AA002	outside	yes	globe/ MOV	PS	RM	open	open	o/c	as-is	no	≤ 30 sec	33BNB03
40BQ402	55	MHSI Train 4	water	6.0	yes	no	JND40 AA007	inside	yes	swing check	self	self	close	close	o/c	n/a	n/a	n/a	n/a
40BQ402	55	MHSI Train 4	water	6.0	yes	no	JND40 AA002	outside	yes	globe/ MOV	PS	RM	open	open	o/c	as-is	no	≤ 30 sec	34BNB03
10BQ101	55	LHSI/ RHR Train 1	water	8.0	yes	no	JNG10 AA009	inside	yes	swing check	self	self	close	o/c	o/c	n/a	n/a	n/a	n/a
20BQ201	55	LHSI/ RHR Train 2	water	8.0	yes	no	JNG20 AA009	inside	yes	swing check	self	self	close	o/c	o/c	n/a	n/a	n/a	n/a
30BQ301	55	LHSI/ RHR Train 3	water	8.0	yes	no	JNG30 AA009	inside	yes	swing check	self	self	close	o/c	o/c	n/a	n/a	n/a	n/a
40BQ401	55	LHSI/ RHR Train 4	water	8.0	yes	no	JNG40 AA009	inside	yes	swing check	self	self	close	o/c	o/c	n/a	n/a	n/a	n/a
10BQ101	55	LHSI/ RHR Train 1	water	8.0	yes	no	JNG10 AA060	outside	yes	globe/ MOV	SIS	RM	open	open	o/c	as-is	n/a	≤ 40 sec	31BNB03
20BQ201	55	LHSI/ RHR Train 2	water	8.0	yes	no	JNG20 AA060	outside	yes	globe/ MOV	SIS	RM	open	open	o/c	as-is	n/a	≤ 40 sec	32BNB03
30BQ301	55	LHSI/ RHR Train 3	water	8.0	yes	no	JNG30 AA060	outside	yes	globe/ MOV	SIS	RM	open	open	o/c	as-is	n/a	≤ 40 sec	33BNB03

Table 6.2.4-1—Containment Isolation Valve and Actuator Data
 Sheet 7 of 18

Pent-ration No. (JMK)	GDC Req.	System Name	Fluid	Line Size (in)	Essent System	Potent Bypass Path	Valve Number	Valve Location	Type C Leak Test	Valve Type and Operator	Pri-ary Act-uation	Sec-on-dary Act-uation	Normal Position	Shut-down Position	Post Accident Position	Power Failure Position	Cont. Isolation Signal	Valve Closure Time	Power Source
40BQ401	55	LHSI/RHR Train 4	water	8.0	yes	no	JNG40 AA060	outside	yes	globe/MOV	SIS	RM	open	open	o/c	as-is	n/a	≤ 40 sec	34BNB03
10BQ101	55	LHSI/RHR Bypass Train 1	water	4.0	yes	no	JNG10 AA061	outside	yes	globe/MOV	SIS	RM	open	open	o/c	as-is	n/a	≤ 20 sec	31BNB03
20BQ201	55	LHSI/RHR Bypass Train 2	water	4.0	yes	no	JNG20 AA061	outside	yes	globe/MOV	SIS	RM	open	open	o/c	as-is	n/a	≤ 20 sec	32BNB03
30BQ301	55	LHSI/RHR Bypass Train 3	water	4.0	yes	no	JNG30 AA061	outside	yes	globe/MOV	SIS	RM	open	open	o/c	as-is	n/a	≤ 20 sec	33BNB03
40BQ401	55	LHSI/RHR Bypass Train 4	water	4.0	yes	no	JNG40 AA061	outside	yes	globe/MOV	SIS	RM	open	open	o/c	as-is	n/a	≤ 20 sec	34BNB03
60BQ100	56	IRWST Sump Train1	water	16.0	yes	no	guard pipe buried	n/a	no	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
60BQ100	56	IRWST Sump Train1	water	16.0	yes	no	JNK10 AA001	outside	yes	globe/MOV	RM	RM	open	open	open	as-is	n/a	≤ 60 sec	31BNB03
60BQ105	56	IRWST Sump to CVCS/FPCPS	water	6.0	yes	no	guard pipe buried	n/a	no	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
60BQ105	56	IRWST Sump to CVCS/FPCPS	water	6.0	yes	no	JNK10 AA009	outside	yes	globe/MOV	PS	RM	close	o/c	close	as-is	stage 1	≤ 30 sec	31BNB03
60BQ105	56	IRWST Sump to CVCS/FPCPS	water	6.0	yes	no	JNK10 AA013	outside	yes	globe/MOV	PS	RM	close	o/c	close	as-is	stage 1	≤ 30 sec	34BNB03

Table 6.2.4-1—Containment Isolation Valve and Actuator Data
Sheet 8 of 18

Pent-ration No. (JMK)	GDC Req.	System Name	Fluid	Line Size (in)	Essent System	Potent Bypass Path	Valve Number	Valve Location	Type C Leak Test	Valve Type and Operator	Pri-ary Act-uation	Sec-on-dary Act-uation	Normal Position	Shut-down Position	Post Accident Position	Power Failure Position	Cont. Isolation Signal	Valve Closure Time	Power Source
60BQ200	56	IRWST Sump SIS Train 2	water	16.0	yes	no	guard pipe buried	n/a	no	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
60BQ200	56	IRWST Sump SIS Train 2	water	16.0	yes	no	JNK20 AA001	outside	yes	globe/ MOV	RM	RM	open	open	open	as-is	n/a	≤ 60 sec	32BNB03
60BQ300	56	IRWST Sump SIS Train 3	water	16.0	yes	no	guard pipe buried	n/a	no	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
60BQ300	56	IRWST Sump SIS Train 3	water	16.0	yes	no	JNK30 AA001	outside	yes	globe/ MOV	RM	RM	open	open	open	as-is	n/a	≤ 60 sec	33BNB03
60BQ400	56	IRWST Sump SIS Train 4	water	16.0	yes	no	guard pipe buried	n/a	no	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
60BQ400	56	IRWST Sump SIS Train 4	water	16.0	yes	no	JNK40 AA001	outside	yes	globe/ MOV	RM	RM	open	open	open	as-is	n/a	≤ 60 sec	34BNB03
60BQ405	56	IRWST Sump SAHRS	water	14.0	yes	no	guard pipe buried	n/a	no	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
60BQ405	56	IRWST Sump SAHRS	water	14.0	yes	no	JNK11 AA009	outside	yes	globe/ MOV	PS	RM	o/c	close	close	as-is	stage 2	≤ 60 sec	34BNB03
60BQ405	56	IRWST Sump SAHRS	water	14.0	no	no	JMQ40 AA001	outside	yes	globe/ MOV	PS	RM	close	o/c	close	as-is	stage 2	≤ 60 sec	31BNB03
60BQ107	57	CCWS & CVCS to RCP	water	12.0	no	no	KAB60 AA014	inside	yes	swing check	self	self	open	o/c	close	n/a	n/a	n/a	n/a
60BQ107	57	CCWS & CVCS to RCP	water	12.0	no	no	KAB60 AA013	outside	yes	gate/ MOV	PS	RM	open	o/c	close	as-is	stage 2	≤ 60 sec	31BNB03
60BQ108	57	CCWS & CVCS to RCP	water	12.0	no	no	KAB60 AA018	inside	yes	gate/ MOV	PS	RM	open	o/c	close	as-is	stage 2	≤ 60 sec	34BRA

Table 6.2.4-1—Containment Isolation Valve and Actuator Data
Sheet 9 of 18

Pent-ration No. (JMK)	GDC Req.	System Name	Fluid	Line Size (in)	Essent System	Potent Bypass Path	Valve Number	Valve Location	Type C Leak Test	Valve Type and Operator	Pri-ary Act-uation	Sec-on-dary Act-uation	Normal Position	Shut-down Position	Post Accident Position	Power Failure Position	Cont. Isolation Signal	Valve Closure Time	Power Source
60BQ108	57	CCWS & CVCS to RCP	water	12.0	no	no	KAB60 AA019	outside	yes	gate/ MOV	PS	RM	open	o/c	close	as-is	stage 2	≤ 60 sec	31BNB03
60BQ113	57	CCWS to HVAC & PEH	water	10.0	no	no	KAB40 AA002	inside	yes	swing check	self	self	open	o/c	close	n/a	n/a	n/a	n/a
60BQ113	57	CCWS to HVAC & PEH	water	10.0	no	no	KAB40 AA001	outside	yes	gate/ MOV	PS	RM	open	o/c	close	as-is	stage 1	≤ 50 sec	31BNB03
60BQ114	57	CCWS return HVAC & PEH	water	10.0	no	no	KAB40 AA012	inside	yes	gate/ MOV	PS	RM	open	o/c	close	as-is	stage 1	≤ 50 sec	34BRA
60BQ114	57	CCWS return HVAC & PEH	water	10.0	no	no	KAB40 AA006	outside	yes	gate/ MOV	PS	RM	open	o/c	close	as-is	stage 1	≤ 50 sec	31BNB03
60BQ117	57	CCWS supply to RCP	water	4.0	yes	no	KAB30 AA050	inside	yes	swing check	self	self	open	open	open	n/a	n/a	n/a	n/a
60BQ117	57	CCWS supply to RCP	water	4.0	yes	no	KAB30 AA049	outside	yes	gate/ MOV	RM	RM	open	open	open	as-is	no	≤ 15 sec	31BNB03
60BQ118	57	CCWS return RCP	water	4.0	yes	no	KAB30 AA052	outside	yes	gate/ MOV	RM	RM	open	open	open	as-is	no	≤ 15 sec	31BNB03
60BQ118	57	CCWS return RCP	water	4.0	yes	no	KAB30 AA051	inside	yes	gate/ MOV	RM	RM	open	open	open	as-is	no	≤ 15 sec	34BRA
60BQ407	57	CCWS & CVCS to RCP	water	12.0	no	no	KAB70 AA014	inside	yes	swing check	self	self	open	o/c	close	n/a	n/a	n/a	n/a
60BQ407	57	CCWS & CVCS to RCP	water	12.0	no	no	KAB70 AA013	outside	yes	gate/ MOV	PS	RM	open	o/c	close	as-is	stage 2	≤ 60 sec	34BNB03

Table 6.2.4-1—Containment Isolation Valve and Actuator Data
Sheet 10 of 18

Pent-ration No. (JMK)	GDC Req.	System Name	Fluid	Line Size (in)	Essent System	Potent Bypass Path	Valve Number	Valve Location	Type C Leak Test	Valve Type and Operator	Pri-ary Act-uation	Sec-on-dary Act-uation	Normal Position	Shut-down Position	Post Accident Position	Power Failure Position	Cont. Isolation Signal	Valve Closure Time	Power Source
60BQ408	57	CCWS & CVCS return RCP	water	12.0	no	no	KAB70 AA018	inside	yes	gate/ MOV	PS	RM	open	o/c	close	as-is	stage 2	≤ 60 sec	31BRA
60BQ408	57	CCWS & CVCS return RCP	water	12.0	no	no	KAB70 AA019	outside	yes	gate/ MOV	PS	RM	open	o/c	close	as-is	stage 2	≤ 60 sec	34BNB03
60BQ420	57	CCWS supply to RCP	water	4.0	yes	no	KAB30 AA054	inside	yes	swing check	self	self	open	open	open	n/a	n/a	n/a	n/a
60BQ420	57	CCWS supply to RCP	water	4.0	yes	no	KAB30 AA053	outside	yes	gate/ MOV	RM	RM	open	open	open	as-is	no	≤ 15 sec	34BNB03
60BQ421	57	CCWS return RCP	water	4.0	yes	no	KAB30 AA055	inside	yes	gate/ MOV	RM	RM	open	open	open	as-is	no	≤ 15 sec	31BRA
60BQ421	57	CCWS return RCP	water	4.0	yes	no	KAB30 AA056	outside	yes	gate/ MOV	RM	RM	open	open	open	as-is	no	≤ 15 sec	34BNB03
10BQ002	55	CVCS Charging	water	4.0	no	no	KBA34 AA003	inside	yes	swing check	self	self	open	close	close	n/a	n/a	n/a	n/a
10BQ002	55	CVCS Charging	water	4.0	no	no	KBA34 AA002	outside	yes	globe/ MOV	PS	RM	open	close	close	as-is	stage 2	≤ 20 sec	31BNB03
10BQ003	55	CVCS Letdown	water	6.0	no	no	KBA14 AA002	inside	yes	globe/ MOV	PS	RM	open	close	close	as-is	stage 1	≤ 30 sec	31BRA
10BQ003	55	CVCS Letdown	water	6.0	no	no	KBA14 AA003	outside	yes	globe/ MOV	PS	RM	open	close	close	as-is	stage 1	≤ 30 sec	34BNB03
30BQ044	56	CVS supply	air	39.0	no	no	KLA30 AA003	inside	yes	special/air	PS	RM	close	o/c	close	close	stage 1	n/a	n/a
30BQ044	56	CVS supply	air	39.0	no	no	KLA30 AA002	outside	yes	special/air	PS	RM	close	o/c	close	close	stage 1	n/a	n/a
40BQ045	56	CVS exhaust	air	39.0	no	no	KLA40 AA001	inside	yes	special/air	PS	RM	close	o/c	close	close	stage 1	n/a	n/a

Table 6.2.4-1—Containment Isolation Valve and Actuator Data
Sheet 11 of 18

Pent-ration No. (JMK)	GDC Req.	System Name	Fluid	Line Size (in)	Essent System	Potent Bypass Path	Valve Number	Valve Location	Type C Leak Test	Valve Type and Operator	Pri- mary Act-uation	Secon- dary Act-uation	Normal Position	Shut- down Position	Post Accident Position	Power Failure Position	Cont. Isolation Signal	Valve Closure Time	Power Source
40BQ045	56	CVS exhaust	air	39.0	no	no	KLA40 AA002	outside	yes	special/air	PS	RM	close	o/c	close	close	stage 1	n/a	n/a
20BQ046	56	CVS exhaust	air	20.0	no	no	KLA20 AA001	inside	yes	special/air	PS	RM	o/c	o/c	close	close	stage 1	≤ 5 sec	n/a
20BQ046	56	CVS exhaust	air	20.0	no	no	KLA20 AA003	outside	yes	special/air	PS	RM	o/c	o/c	close	close	stage 1	≤ 5 sec	n/a
10BQ047	56	CVS supply	air	20.0	no	no	KLA10 AA003	inside	yes	special/air	PS	RM	o/c	o/c	close	close	stage 1	≤ 5 sec	n/a
10BQ047	56	CVS supply	air	20.0	no	no	KLA10 AA001	outside	yes	special/air	PS	RM	o/c	o/c	close	close	stage 1	≤ 5 sec	n/a
60BQ250	56	CEC pressure	air	0.5	no	no	KLA60 AA703	outside	yes	gate/ manual	manual	manual	open	open	open	n/a	n/a	n/a	n/a
60BQ250	56	CSC pressure	air	0.5	no	no	KLA70 AA706	outside	yes	gate/ manual	manual	manual	open	open	open	n/a	n/a	n/a	n/a
60BQ250	56	CSC pressure	air	0.5	no	no	KLA70 AA707	outside	yes	gate/ manual	manual	manual	open	open	open	n/a	n/a	n/a	n/a
60BQ350	56	CEC pressure	air	0.5	no	no	KLA60 AA701	outside	yes	gate/ manual	manual	manual	open	open	open	n/a	n/a	n/a	n/a
60BQ350	56	CSC pressure	air	0.5	no	no	KLA70 AA701	outside	yes	gate/ manual	manual	manual	open	open	open	n/a	n/a	n/a	n/a
60BQ350	56	CSC pressure	air	0.5	no	no	KLA70 AA702	outside	yes	gate/ manual	manual	manual	open	open	open	n/a	n/a	n/a	n/a
60BQ151	56	CEC pressure	air	0.5	no	no	KLA60 AA704	outside	yes	gate/ manual	manual	manual	open	open	open	n/a	n/a	n/a	n/a
60BQ151	56	CSC pressure	air	0.5	no	no	KLA70 AA708	outside	yes	gate/ manual	manual	manual	open	open	open	n/a	n/a	n/a	n/a
60BQ151	56	CSC pressure	air	0.5	no	no	KLA70 AA709	outside	yes	gate/ manual	manual	manual	open	open	open	n/a	n/a	n/a	n/a
60BQ452	56	CEC pressure	air	0.5	no	no	KLA60 AA702	outside	yes	gate/ manual	manual	manual	open	open	open	n/a	n/a	n/a	n/a
60BQ452	56	CSC pressure	air	0.5	no	no	KLA70 AA703	outside	yes	gate/ manual	manual	manual	open	open	open	n/a	n/a	n/a	n/a

Table 6.2.4-1—Containment Isolation Valve and Actuator Data
Sheet 12 of 18

Pent-ration No. (JMK)	GDC Req.	System Name	Fluid	Line Size (in)	Essent System	Potent Bypass Path	Valve Number	Valve Location	Type C Leak Test	Valve Type and Operator	Pri-ary Act-uation	Sec-on-dary Act-uation	Normal Position	Shut-down Position	Post Accident Position	Power Failure Position	Cont. Isolation Signal	Valve Closure Time	Power Source
60BQ452	56	CSC pressure	air	0.5	no	no	KLA70 AA704	outside	yes	gate/manual	manual	manual	open	open	open	n/a	n/a	n/a	n/a
60BQ005	55	GWPS	gas	2.0	no	no	KPL84 AA003	inside	yes	globe/MOV	PS	RM	open	o/c	close	as-is	stage 1	≤ 15 sec	31BRA
60BQ005	55	GWPS	gas	2.0	no	no	KPL84 AA002	outside	yes	globe/MOV	PS	RM	open	o/c	close	as-is	stage 1	≤ 15 sec	34BNB03
60BQ006	55	GWPS	gas	2.0	no	no	KPL85 AA003	inside	yes	globe/MOV	PS	RM	open	o/c	close	as-is	stage 1	≤ 15 sec	31BRA
60BQ006	55	GWPS	gas	2.0	no	no	KPL85 AA004	outside	yes	globe/MOV	PS	RM	open	o/c	close	as-is	stage 1	≤ 15 sec	34BNB03
10BQ007	57	NIDVS	water	3.0	no	no	KTA10 AA017	inside	yes	globe/MOV	PS	RM	open	open	close	as-is	stage 1	≤ 15 sec	34BRA
10BQ007	57	NIDVS	water	3.0	no	no	KTA10 AA018	outside	yes	globe/MOV	PS	RM	open	open	close	as-is	stage 1	≤ 15 sec	31BNB03
10BQ008	56	NIDVS	water	2.0	no	no	KTC10 AA005	inside	yes	globe/MOV	PS	RM	close	o/c	close	as-is	stage 1	≤ 15 sec	31BRA
10BQ008	56	NIDVS	water	2.0	no	no	KTC10 AA006	outside	yes	globe/MOV	PS	RM	close	o/c	close	as-is	stage 1	≤ 15 sec	34BNB03
10BQ012	56	NIDVS return	water	2.0	no	no	KTC10 AA029	inside	yes	lift check	self	self	open	o/c	close	n/a	n/a	n/a	n/a
10BQ012	56	NIDV return	water	2.0	no	no	KTC10 AA010	outside	yes	globe/MOV	PS	RM	close	o/c	close	as-is	stage 1	≤ 15 sec	34BNB03
10BQ014	56	NIDVS	water	2.0	no	no	KTD10 AA024	inside	yes	globe/MOV	PS	RM	close	o/c	close	as-is	stage 1	≤ 15 sec	31BRA
10BQ014	56	NIDVS	water	2.0	no	no	KTD10 AA015	outside	yes	globe/MOV	PS	RM	close	o/c	close	as-is	stage 1	≤ 15 sec	34BNB03
10BQ070	56	NIDVS to annulus	water	1.0	no	no	KTD10 AA008	inside annulus	yes	lift check	self	self	o/c	o/c	close	n/a	n/a	n/a	n/a
10BQ070	56	NIDVS to annulus	water	1.0	no	no	KTD10 AA025	outside	yes	globe/MOV	PS	RM	close	close	close	as-is	stage 1	≤ 15 sec	34BNB03
10BQ009	55	NSS LS	water	0.25	no	no	KUA10 AA003	inside	yes	globe/MOV	PS	RM	open	open	close	as-is	stage 1	≤ 15 sec	31BRA

Table 6.2.4-1—Containment Isolation Valve and Actuator Data
Sheet 13 of 18

Pent-ration No. (JMK)	GDC Req.	System Name	Fluid	Line Size (in)	Essent System	Potent Bypass Path	Valve Number	Valve Location	Type C Leak Test	Valve Type and Operator	Pri-ary Act-uation	Sec-on-dary Act-uation	Normal Position	Shut-down Position	Post Accident Position	Power Failure Position	Cont. Isolation Signal	Valve Closure Time	Power Source
10BQ009	55	NSS LS	water	0.25	no	no	KUA10 AA004	outside	yes	globe/ MOV	PS	RM	open	open	close	as-is	stage 1	≤ 15 sec	34BNB03
20BQ011	55	NSS LS	water	0.25	no	no	KUA20 AA002	inside	yes	globe/ MOV	PS	RM	open	open	close	as-is	stage 1	≤ 15 sec	31BRA
20BQ011	55	NSS LS	water	0.25	no	no	KUA20 AA003	outside	yes	globe/ MOV	PS	RM	open	open	close	as-is	stage 1	≤ 15 sec	34BNB03
30BQ010	55	NSS LS	water	0.25	no	no	KUA30 AA003	inside	yes	globe/ MOV	PS	RM	open	open	close	as-is	stage 1	≤ 15 sec	34BRA
30BQ010	55	NSS LS	water	0.25	no	no	KUA30 AA004	outside	yes	globe/ MOV	PS	RM	open	open	close	as-is	stage 1	≤ 15 sec	31BNB03
10BQ027	55	NSS LLS	water	0.25	no	no	KUB10 AA001	inside	yes	globe/ MOV	PS	RM	close	o/c	close	as-is	stage 1	≤ 15 sec	31BRA
10BQ027	55	NSS LLS	water	0.25	no	no	KUB10 AA002	outside	yes	globe/ MOV	PS	RM	close	o/c	close	as-is	stage 1	≤ 15 sec	34BNB03
51BQ449	56	SASS	air	0.375	no	no	KUL51 AA002	outside	yes	ball/MOV	PS	RM	close	close	close	as-is	stage 1	≤ 15 sec	31BNB03
51BQ449	56	SASS	air	0.375	no	no	KUL51 AA003	outside	yes	ball/MOV	PS	RM	close	close	close	as-is	stage 1	≤ 15 sec	34BNB03
52BQ450	56	SASS	air	0.375	no	no	KUL52 AA002	outside	yes	ball/MOV	PS	RM	close	close	close	as-is	stage 1	≤ 15 sec	31BNB03
52BQ450	56	SASS	air	0.375	no	no	KUL52 AA003	outside	yes	ball/MOV	PS	RM	close	close	close	as-is	stage 1	≤ 15 sec	34BNB03
60BQ109	57	FW to SG1	water	20.0	no	no	LAB60 AA002	outside	no	gate/ MOV	RM	RM	open	o/c	close	as-is	no	≤60 sec	31BNB02
60BQ109	57	FW to SG1	water	20.0	no	no	LAB60 AA003	inside	no	lift check	self	self	open	o/c	close	n/a	n/a	n/a	n/a
70BQ207	57	FW to SG2	water	20.0	no	no	LAB70 AA002	outside	no	gate/ MOV	RM	RM	open	o/c	close	as-is	no	≤60 sec	32BNB02
70BQ207	57	FW to SG2	water	20.0	no	no	LAB70 AA003	inside	no	lift check	self	self	open	o/c	close	n/a	n/a	n/a	n/a
80BQ306	57	FW to SG3	water	20.0	no	no	LAB80 AA002	outside	no	gate/ MOV	RM	RM	open	o/c	close	as-is	no	≤ 60 sec	33BNB02

Table 6.2.4-1—Containment Isolation Valve and Actuator Data
Sheet 14 of 18

Pent-ration No. (JMK)	GDC Req.	System Name	Fluid	Line Size (in)	Essent System	Potent Bypass Path	Valve Number	Valve Location	Type C Leak Test	Valve Type and Operator	Pri-ary Act-uation	Sec-on-dary Act-uation	Normal Position	Shut-down Position	Post Accident Position	Power Failure Position	Cont. Isolation Signal	Valve Closure Time	Power Source
80BQ306	57	FW to SG3	water	20.0	no	no	LAB80 AA003	inside	no	lift check	self	self	open	o/c	close	n/a	n/a	n/a	n/a
90BQ409	57	FW to SG4	water	20.0	no	no	LAB90 AA002	outside	no	gate/ MOV	RM	RM	open	o/c	close	as-is	no	≤ 60 sec	34BNB02
90BQ409	57	FW to SG4	water	20.0	no	no	LAB90 AA003	inside	no	lift check	self	self	open	o/c	close	n/a	n/a	n/a	n/a
11BQ106	57	EFWS to SG 1	water	4.0	yes	no	LAR11 AA006	outside	no	gate/ MOV	RM	RM	open	open	open	as-is	no	≤ 20 sec	31BRA
11BQ106	57	EFWS to SG 1	water	4.0	yes	no	LAR11 AA007	inside	no	swing check	self	self	open	close	open	n/a	n/a	n/a	n/a
21BQ204	57	EFWS to SG 2	water	4.0	yes	no	LAR21 AA006	outside	no	gate/ MOV	RM	RM	open	open	open	as-is	no	≤ 20 sec	32BRA
21BQ204	57	EFWS to SG 2	water	4.0	yes	no	LAR21 AA007	inside	no	swing check	self	self	close	close	open	n/a	n/a	n/a	n/a
31BQ303	57	EFWS to SG 3	water	4.0	yes	no	LAR31 AA006	outside	no	gate/ MOV	RM	RM	open	open	open	as-is	no	≤ 20 sec	33BRA
31BQ303	57	EFWS to SG 3	water	4.0	yes	no	LAR31 AA007	inside	no	swing check	self	self	close	close	open	n/a	n/a	n/a	n/a
41BQ406	57	EFWS to SG 4	water	4.0	yes	no	LAR41 AA006	outside	no	gate/ MOV	RM	RM	open	open	open	as-is	no	≤ 20 sec	34BRA
41BQ406	57	EFWS to SG 4	water	4.0	yes	no	LAR41 AA007	inside	no	swing check	self	self	close	close	open	n/a	n/a	n/a	n/a
10BQ110	57	MS from SG1	steam	27.5	no	no	LBA10 AA002	outside	no	gate/HOV	RM	RM	open	close	o/c	close	no	n/a	n/a
10BQ110	57	MS to MSRIV	steam	14.0	no	no	LBA13 AA001	outside	no	globe/ PORV	self	self	close	close	o/c	close	no	n/a	n/a
10BQ110	57	MS to MSRCV	steam	14.0	no	no	LBA13 AA101	outside	no	globe cont /MOV	RM	RM	close	close	o/c	as-is	no	n/a	31BRA
10BQ110	57	MS to MSSV	steam	8.0	no	no	LBA11 AA191	outside	no	safety	self	self	close	close	o/c	n/a	n/a	n/a	n/a
10BQ110	57	MS to MSSV	steam	8.0	no	no	LBA12 AA191	outside	no	safety	self	self	close	close	o/c	n/a	n/a	n/a	n/a

Table 6.2.4-1—Containment Isolation Valve and Actuator Data
Sheet 15 of 18

Pent-ration No. (JMK)	GDC Req.	System Name	Fluid	Line Size (in)	Essent System	Potent Bypass Path	Valve Number	Valve Location	Type C Leak Test	Valve Type and Operator	Pri-ary Act-uation	Sec-on-dary Act-uation	Normal Position	Shut-down Position	Post Accident Position	Power Failure Position	Cont. Isolation Signal	Valve Closure Time	Power Source
10BQ110	57	MS warm up line	steam	6.0	no	no	LBA14 AA001	outside	no	globe/ MOV	RM	RM	close	close	close	as-is	n/a	≤ 30 sec	31BNB02
10BQ110	57	MS drain line	steam	2.0	no	no	LBA10 AA441	outside	no	globe/ MOV	RM	RM	close	close	close	as-is	n/a	≤ 15 sec	31BNB02
20BQ208	57	MS from SG 2	steam	27.5	no	no	LBA20 AA002	outside	no	gate/HOV	RM	RM	open	close	o/c	close	no	n/a	n/a
20BQ208	57	MS to MSRIV	steam	14.0	no	no	LBA23 AA001	outside	no	globe/ PORV	self	self	close	close	o/c	close	no	n/a	n/a
20BQ208	57	MS to MSRCV	steam	14.0	no	no	LBA23 AA101	outside	no	globe cont /MOV	RM	RM	close	close	o/c	as-is	no	n/a	32BRA
20BQ208	57	MS to MSSV	steam	8.0	no	no	LBA21 AA191	outside	no	safety	self	self	close	close	o/c	n/a	n/a	n/a	n/a
20BQ208	57	MS to MSSV	steam	8.0	no	no	LBA22 AA191	outside	no	safety	self	self	close	close	o/c	n/a	n/a	n/a	n/a
20BQ208	57	MS warm up line	steam	6.0	no	no	LBA24 AA001	outside	no	globe/ MOV	RM	RM	close	close	close	as-is	n/a	≤ 30 sec	32BNB02
20BQ208	57	MS drain line	steam	2.0	no	no	LBA20 AA441	outside	no	globe/ MOV	RM	RM	close	close	close	as-is	n/a	≤ 15 sec	32BNB02
30BQ307	57	MS from SG 3	steam	27.5	no	no	LBA30 AA002	outside	no	gate/HOV	RM	RM	open	close	o/c	close	no	n/a	n/a
30BQ307	57	MS to MSRIV	steam	14.0	no	no	LBA33 AA001	outside	no	globe/ PORV	self	self	close	close	o/c	close	no	n/a	n/a
30BQ307	57	MS to MSRCV	steam	14.0	no	no	LBA33 AA101	outside	no	globe cont /MOV	RM	RM	close	close	o/c	as-is	no	n/a	33BRA
30BQ307	57	MS to MSSV	steam	8.0	no	no	LBA31 AA191	outside	no	safety	self	self	close	close	o/c	n/a	n/a	n/a	n/a
30BQ307	57	MS to MSSV	steam	8.0	no	no	LBA32 AA191	outside	no	safety	self	self	close	close	o/c	n/a	n/a	n/a	n/a
30BQ307	57	MS warm up line	steam	6.0	no	no	LBA34 AA001	outside	no	globe/ MOV	RM	RM	close	close	close	as-is	n/a	≤ 30 sec	33BNB02
30BQ307	57	MS drain line	steam	2.0	no	no	LBA30 AA441	outside	no	globe/ MOV	RM	RM	close	close	close	as-is	n/a	≤ 15 sec	33BNB02

Table 6.2.4-1—Containment Isolation Valve and Actuator Data
Sheet 16 of 18

Pent-ration No. (JMK)	GDC Req.	System Name	Fluid	Line Size (in)	Essent System	Potent Bypass Path	Valve Number	Valve Location	Type C Leak Test	Valve Type and Operator	Pri-ary Act-uation	Sec-on-dary Act-uation	Normal Position	Shut-down Position	Post Accident Position	Power Failure Position	Cont. Isolation Signal	Valve Closure Time	Power Source
40BQ410	57	MS from SG 4	steam	27.5	no	no	LBA40 AA002	outside	no	gate/HOV	RM	RM	open	close	o/c	close	no	n/a	n/a
40BQ410	57	MS to MSRIV	steam	14.0	no	no	LBA43 AA001	outside	no	globe/PORV	self	self	close	close	o/c	close	no	n/a	n/a
40BQ410	57	MS to MSRCV	steam	14.0	no	no	LBA43 AA101	outside	no	globe cont /MOV	RM	RM	close	close	o/c	as-is	no	n/a	34BRA
40BQ410	57	MS to MSSV	steam	8.0	no	no	LBA41 AA191	outside	no	safety	Self	self	close	close	o/c	n/a	n/a	n/a	n/a
40BQ410	57	MS to MSSV	steam	8.0	no	no	LBA42 AA191	outside	no	safety	Self	self	close	close	o/c	n/a	n/a	n/a	32BNB02
40BQ410	57	MS warm up line	steam	6.0	no	no	LBA44 AA001	outside	no	globe/MOV	RM	RM	close	close	close	as-is	n/a	≤ 30 sec	34BNB02
40BQ410	57	MS drain line	steam	2.0	no	no	LBA40 AA441	outside	no	globe/MOV	RM	RM	close	close	close	as-is	n/a	≤ 15 sec	34BNB02
10BQ304	57	MC to BD Clrs	water	6.0	no	no	LCA90 AA004	inside	yes	swing check	self	self	open	close	close	n/a	n/a	n/a	n/a
10BQ304	57	MC to BD Clrs	water	6.0	no	no	LCA90 AA003	outside	yes	gate/MOV	PS	RM	open	close	close	as-is	stage 1	≤ 30 sec	32BNB03
10BQ305	57	MC from BD Clrs	water	6.0	no	no	LCA90 AA005	inside	yes	gate/MOV	PS	RM	open	close	close	as-is	stage 1	≤ 30 sec	33BRA
10BQ305	57	MC from BD Clrs	water	6.0	no	no	LCA90 AA006	outside	yes	gate/MOV	PS	RM	open	close	close	as-is	stage 1	≤ 30 sec	32BNB03
60BQ019	57	SG BD Clrs	water	6.0	no	no	LCQ51 AA002	inside	yes	gate/MOV	PS	RM	open	close	close	as-is	stage 1	≤ 30 sec	31BRA
60BQ019	57	SG BD Clrs	water	6.0	no	no	LCQ51 AA003	outside	yes	gate/MOV	PS	RM	open	close	close	as-is	stage 1	≤ 30 sec	34BNB03
60BQ205	57	SG BD Clrs	water	12.0	no	no	LCQ52 AA001	inside	yes	gate/MOV	PS	RM	open	close	close	as-is	stage 1	≤ 60 sec	33BRA
60BQ205	57	SG BD Clrs	water	12.0	no	no	LCQ52 AA002	outside	yes	gate/MOV	PS	RM	open	close	close	as-is	stage 1	≤ 60 sec	32BNB03
60BQ041	57	NGDS	gas	1.0	no	no	QJB40 AA002	inside	yes	globe/MOV	PS	RM	open	open	close	as-is	stage 1	≤ 15 sec	34BRA

Table 6.2.4-1—Containment Isolation Valve and Actuator Data
Sheet 17 of 18

Pent-ration No. (JMK)	GDC Req.	System Name	Fluid	Line Size (in)	Essent System	Potent Bypass Path	Valve Number	Valve Location	Type C Leak Test	Valve Type and Operator	Pri-ary Act-uation	Sec-on-dary Act-uation	Normal Position	Shut-down Position	Post Accident Position	Power Failure Position	Cont. Isolation Signal	Valve Closure Time	Power Source
60BQ041	57	NGDS	gas	1.0	no	no	QJB40 AA001	outside	yes	globe/ MOV	PS	RM	open	open	close	as-is	stage 1	≤ 15 sec	31BNB03
60BQ066	57	NGDS	gas	1.0	no	no	QJB40 AA003	outside	yes	globe/ MOV	PS	RM	open	open	close	as-is	stage 1	≤ 15 sec	31BNB03
60BQ066	57	NGDS	gas	1.0	no	no	QJB40 AA004	inside	yes	globe/ MOV	PS	RM	open	open	close	as-is	stage 1	≤ 15 sec	34BRA
41BQ035	57	CW Supply to CVS	water	8.0	no	no	QNJ41 AA003	inside	yes	lift check	self	self	open	open	close	n/a	n/a	n/a	n/a
41BQ035	57	Op CW Supply to CVS	water	8.0	no	no	QNJ41 AA002	outside	yes	globe/ MOV	PS	RM	open	open	close	as-is	stage 1	≤ 40 sec	34BNB03
41BQ036	57	Op CW return CVS	water	8.0	no	no	QNJ41 AA027	inside	yes	globe/ MOV	PS	RM	open	open	close	as-is	stage 1	≤ 40 sec	31BRA
41BQ036	57	Op CW return CVS	water	8.0	no	no	QNJ41 AA028	outside	yes	globe/ MOV	PS	RM	open	open	close	as-is	stage 1	≤ 40 sec	34BNB03
11BQ023	57	NSS for SG BD	water	0.375	no	no	QUC11 AA011	inside	yes	globe/ MOV	PS	RM	open	close	close	as-is	stage 1	≤ 15 sec	34BRA
11BQ023	57	NSS for SG BD	water	0.375	no	no	QUC11 AA001	outside	yes	globe/ MOV	PS	RM	open	close	close	as-is	stage 1	≤ 15 sec	31BNB03
12BQ024	57	NSS for SG BD	water	0.375	no	no	QUC12 AA011	inside	yes	globe/ MOV	PS	RM	open	close	close	as-is	stage 1	≤ 15 sec	34BRA
12BQ024	57	NSS for SG BD	water	0.375	no	no	QUC12 AA001	outside	yes	globe/ MOV	PS	RM	open	close	close	as-is	stage 1	≤ 15 sec	31BNB03
13BQ025	57	NSS for SG BD	water	0.375	no	no	QUC13 AA011	inside	yes	globe/ MOV	PS	RM	open	close	close	as-is	stage 1	≤ 15 sec	31BRA
13BQ025	57	NSS for SG BD	water	0.375	no	no	QUC13 AA001	outside	yes	globe/ MOV	PS	RM	open	close	close	as-is	stage 1	≤ 15 sec	34BNB03
14BQ026	57	NSS for SG BD	water	0.375	no	no	QUC14 AA011	inside	yes	globe/ MOV	PS	RM	open	close	close	as-is	stage 1	≤ 15 sec	31BRA
14BQ026	57	NSS for SG BD	water	0.375	no	no	QUC14 AA001	outside	yes	globe/ MOV	PS	RM	open	close	close	as-is	stage 1	≤ 15 sec	34BNB03

Table 6.2.4-1—Containment Isolation Valve and Actuator Data
Sheet 18 of 18

Pent-ration No. (JMK)	GDC Req.	System Name	Fluid	Line Size (in)	Essent System	Potent Bypass Path	Valve Number	Valve Location	Type C Leak Test	Valve Type and Operator	Pri- mary Act-uation	Sec-ondary Act-uation	Normal Position	Shut-down Position	Post Accident Position	Power Failure Position	Cont. Isolation Signal	Valve Closure Time	Power Source
10BQ030	56/57	CADS to IA	air	2.0	no	no	SCB01 AA002	inside	yes	globe/ MOV	PS	RM	open	open	close	as-is	stage 1	≤ 15 sec	31BRA
10BQ030	56/57	CADS to IA	air	2.0	no	no	SCB01 AA001	outside	yes	globe/ MOV	PS	RM	open	open	close	as-is	stage 1	≤ 15 sec	34BNB03
01BQ031	56/57	CADS to SA	air	2.0	no	no	SCB02 AA002	inside	yes	globe/ manual	n/a	n/a	close	open	close	n/a	admin close	n/a	n/a
01BQ031	56/57	CADS to SA	air	2.0	no	no	SCB02 AA001	outside	yes	globe/ manual	n/a	n/a	close	open	close	n/a	admin close	n/a	n/a
30BQ033	56/57	FWDS inside NI	water	8.0	no	no	SGB30 AA032	inside	yes	gate/ MOV	PS	RM	open	open	close	as-is	stage 1	≤ 40 sec	31BRA
30BQ033	56/57	FWDS inside NI	water	8.0	no	no	SGB30 AA031	outside	yes	gate/ MOV	PS	RM	open	open	close	as-is	stage 1	≤ 40 sec	34BNB03