



Progress Energy

Serial: NPD-NRC-2009-179
August 6, 2009

10CFR52.79

U.S. Nuclear Regulatory Commission
Attention: Document Control Desk
Washington, D.C. 20555-0001

**LEVY NUCLEAR POWER PLANT, UNITS 1 AND 2
DOCKET NOS. 52-029 AND 52-030
SUPPLEMENT 1 TO RESPONSE TO REQUEST FOR ADDITIONAL INFORMATION LETTER
NO. 001 RELATED TO DESIGN BASIS ACCIDENTS RADIOLOGICAL CONSEQUENCE
ANALYSES**

- References:
1. Letter from Ravindra G. Joshi (NRC) to Garry Miller (PEF), dated November 25, 2008, "Request for Additional Information Letter No. 001 Related to SRP Section 15.00.03 for the Levy County Nuclear Plant, Units 1 and 2 Combined License Application"
 2. Letter from Garry D. Miller (PEF) to U. S. Nuclear Regulatory Commission, dated December 19, 2008, "Response to Request for Additional Information Letter No. 001 Related to Design Basis Accidents Radiological Consequence Analyses", Serial: NPD-NRC-2008-092

Ladies and Gentlemen:

Progress Energy Florida, Inc. (PEF) hereby submits a revised response to the Nuclear Regulatory Commission's (NRC) request for additional information provided in the referenced letter.

A revised response to the NRC request is addressed in the enclosure. The enclosure also identifies changes that will be made in a future revision of the Levy Nuclear Power Plant Units 1 and 2 application.

If you have any further questions, or need additional information, please contact Bob Kitchen at (919) 546-6992, or me at (919) 546-6107.

I declare under penalty of perjury that the foregoing is true and correct.

Executed on August 6, 2009.

Sincerely,

Garry D. Miller
General Manager
Nuclear Plant Development

Enclosure

cc : U.S. NRC Region II, Regional Administrator
Mr. Brian C. Anderson, U.S. NRC Project Manager
Mr. Doug Bruner, U.S. NRC Environmental Project Manager

**Levy Nuclear Power Plant Units 1 and 2
Supplement 1 to Response to NRC Request for Additional Information Letter No. 001
Related to SRP Section 15.00.03 for the Combined License Application,
Dated November 25, 2008**

| <u>NRC RAI #</u> | <u>Progress Energy RAI #</u> | <u>Progress Energy Response</u> |
|------------------|------------------------------|---|
| 15.00.03-1 | L-0517 | Revised response enclosed – see following pages |

NRC Letter No.: LEVY-RAI-LTR-001

NRC Letter Date: November 25, 2008

NRC Review of Final Safety Analysis Report

NRC RAI #: 15.00.03-1

Text of NRC RAI:

By letter dated August 14, 2008, NRC informed the AP1000 vendor that an unacceptable assumption was made in evaluating the LOCA DBA for Revision 16 of the AP1000 DCD. Both FSAR Chapter 15 and Section 6.4 of the subject COL application incorporate by reference the design basis accident analyses in Revision 16 of the AP1000 DCD. Provide an evaluation of the LOCA that does not make use of the unacceptable assumption. Describe any design or siting changes that are intended to compensate for the unacceptable assumption.

PGN RAI ID #: L-0517

PGN Response to NRC RAI:

Westinghouse has issued Revision 17 of the AP1000 DCD, which contained a reevaluation of the LOCA. This reevaluation does not make use of the rejected assumption, but does include design changes. DCD Revision 17 will be incorporated by reference into the next revision of the COLA. Although no siting changes for LNP are necessary, LNP COLA FSAR Tables 2.0-201, 2.0-202, 2.3.4-201 and 2.3.4-206 and LNP COLA ER Section 7.1.3 and Tables 7.1-2 through 7.1-12 will be updated as a result of this change to include the DCD Revision 17 values. The change involves incorporation of the short-term (accident) and Control Room X/Q values used in the DCD accident evaluation to which the LNP site-specific values are compared and revision to the LNP ER site specific accident doses.

Associated LNP COL Application Revisions:

The following changes will be made in a future revision to the LNP application:

1. Revise LNP COLA FSAR Table 2.0-201 (Sheet 7 of 8) as shown on page 4.
2. Revise LNP COLA FSAR Table 2.0-202 (Sheet 1 of 2) as shown on page 5.
3. Revise LNP COLA FSAR Table 2.3.4-201 as shown on page 6.
4. Revise LNP COLA FSAR Table 2.3.4-206 (Sheet 1 of 2) as shown on page 7.
5. Revise the third sentence of the second paragraph of ER Section 7.1.3 from:

The X/Q value for 1.2 to 3.2 hours at the LNP site was not calculated.

To read:

The X/Q value for 1.4 to 3.4 hours at the LNP site was not calculated.

6. Replace existing ER Tables 7.1-2 through 7.1-12 with the tables shown on pages 8 through 17.

Attachments/Enclosures:

None.

LNP SUP 2.0-1

Table 2.0-201 (Sheet 7 of 8)
Comparison of AP1000 DCD Site Parameters and LNP Site Characteristics

| | AP 1000 DCD Site Parameters | LNP Site Characteristics | LNP Site Characteristic Reference | Bounding Yes/No |
|--|---|--|--|----------------------------|
| Plant Grade Elevation | Less than plant elevation 100 ft., except for portion at a higher elevation adjacent to the annex building | The nominal plant grade floor elevation is 51 ft. NAVD88 or 52 ft. NGVD29, which corresponds to AP1000 elevation of 100 ft. The actual plant grade will be lower and will vary to accommodate site grading, drainage, and local site flooding. Therefore, DCD plant elevation of 100 ft. = 51 ft. NAVD88 or 52 ft. NGVD29. | FSAR Subsection 2.4.1.1 | Yes |
| Precipitation | | | | |
| Rain | 20.7 in./hr [1-hr 1-mi ² PMP] | 19.6 in./hr | FSAR Subsection 2.4.2.3 | Yes |
| Snow / Ice | 75 lb/ft ² on ground with exposure factor of 1.0 and important factor of 1.2 (safety) and 1.0 (non-safety) | The 50-year recurrent Ground Snow Load for all monitoring stations is zero; therefore, estimations of the weight of snowpack are not necessary for the LNP site. | FSAR Subsection 2.3.1.2.3 | Yes |
| Atmospheric Dispersion Values X/Q (f) | | | | |
| Site Boundary (0-2 hours) | $\leq 4.0 \times 10^{-3} \text{ } 5.1 \times 10^{-4} \text{ sec/m}^3$ | 3.46 $2.56 \times 10^{-4} \text{ sec/m}^3$ | Table 2.3.4-201 | Yes |
| Site Boundary (annual average) | $\leq 2.0 \times 10^{-5} \text{ sec/m}^3$ | $1.52 \times 10^{-6} \text{ sec/m}^3$ | Table 2.3.4-205 | Yes |
| Low population zone boundary | | | | Yes |
| 0-8 hours | $\leq 5.0 \text{ } 2.2 \times 10^{-4} \text{ sec/m}^3$ | 4.65 $4.44 \times 10^{-5} \text{ sec/m}^3$ | Table 2.3.4-201 | Yes |
| 8-24 hours | $\leq 3.0 \text{ } 1.6 \times 10^{-4} \text{ sec/m}^3$ | 2.97 $3.18 \times 10^{-5} \text{ sec/m}^3$ | Table 2.3.4-201 | Yes |
| 24-96 hours | $\leq 1.5 \text{ } 1.0 \times 10^{-4} \text{ sec/m}^3$ | 1.42 $1.54 \times 10^{-5} \text{ sec/m}^3$ | Table 2.3.4-201 | Yes |
| 96-720 hours | $\leq 8.0 \times 10^{-5} \text{ sec/m}^3$ | 2.75 $5.44 \times 10^{-6} \text{ sec/m}^3$ | Table 2.3.4-201 | Yes |
| Population Distribution | | | | |
| Exclusion area (site) ⁽⁹⁾ | 0.5 miles | The minimum distance from the effluent release boundary to the exclusion area boundary is 1340 m (4396 ft. or 0.83 mi.). | FSAR Subsection 2.1.1.2 | Yes |

LNP SUP 2.0-1

Table 2.0-202 (Sheet 1 of 2)
Comparison of Predicted LNP Control Room Chi/Q Values with AP1000 DCD Acceptance Criteria

Chi/Q (sec/m³) at HVAC Intake for the Identified Release Points^(a)

| Release Time | Plant Vent or PCS Air Diffuser ^(b) | Plant Vent | PCS Air Diffuser | Ground Level Containment Release Points ^(c,h) | Ground Level Containment Release Points | PORV and Safety Valve Releases ^(d) | PORV and Safety Valve Releases | Condenser Air Removal Stack ^(g) | Condenser Air Removal Stack | Steam Line Break Releases | Steam Vent | Fuel Handling Area ^(e) | Fuel Handling Area Blowout Panel | Radwaste Building Truck Staging Area Door |
|--------------|---|------------|------------------|--|---|---|--------------------------------|--|-----------------------------|---------------------------|------------|-----------------------------------|----------------------------------|---|
| | DCD | LNP | LNP | DCD | LNP | DCD | LNP | DCD | LNP | DCD | LNP | DCD | LNP | LNP |
| 0 - 2 hours | 3.0E-03 | 1.7E-03 | 1.5E-03 | 6.0E-03 | 4.3E-03 | 2.0E-02 | 1.0E-02 | 6.0E-03 | 1.7E-03 | 2.4E-02 | 1.1E-02 | 6.0E-03 | 1.3E-03 | 1.0E-03 |
| 2 - 8 hours | 2.5E-03 | 1.0E-03 | 8.4E-04 | 3.6E-03 | 3.5E-03 | 1.8E-02 | 5.7E-03 | 4.0E-03 | 1.4E-03 | 2.0E-02 | 6.1E-03 | 4.0E-03 | 8.3E-04 | 6.4E-04 |
| 8 - 24 hours | 1.0E-03 | 4.5E-04 | 3.7E-04 | 1.4E-03 | 1.2E-03 | 7.0E-03 | 2.7E-03 | 2.0E-03 | 6.4E-04 | 7.5E-03 | 3.0E-03 | 2.0E-03 | 3.7E-04 | 3.0E-04 |
| 1 - 4 days | 8.0E-04 | 4.5E-04 | 3.8E-04 | 1.8E-03 | 1.2E-03 | 5.0E-03 | 2.1E-03 | 1.5E-03 | 5.9E-04 | 5.5E-03 | 2.3E-03 | 1.5E-03 | 3.4E-04 | 2.6E-04 |
| 4 - 30 days | 6.0E-04 | 3.6E-04 | 3.0E-04 | 1.5E-03 | 9.9E-04 | 4.5E-03 | 1.3E-03 | 1.0E-03 | 4.7E-04 | 5.0E-03 | 1.5E-03 | 1.0E-03 | 2.7E-04 | 2.0E-04 |

Chi/Q (sec/m³) at Annex Building Door for the Identified Release Points^(f)

| Release Time | Plant Vent or PCS Air Diffuser ^(b) | Plant Vent | PCS Air Diffuser | Ground Level Containment Release Points ^(c) | Ground Level Containment Release Points | PORV and Safety Valve Releases ^(d) | PORV and Safety Valve Releases | Condenser Air Removal Stack ^(g) | Condenser Air Removal Stack | Steam Line Break Releases | Steam Vent | Fuel Handling Area ^(e) | Fuel Handling Area Blowout Panel | Radwaste Building Truck Staging Area Door |
|--------------|---|------------|------------------|--|---|---|--------------------------------|--|-----------------------------|---------------------------|------------|-----------------------------------|----------------------------------|---|
| | DCD | LNP | LNP | DCD | LNP | DCD | LNP | DCD | LNP | DCD | LNP | DCD | LNP | LNP |
| 0 - 2 hours | 1.0E-03 | 3.7E-04 | 3.8E-04 | 1.0E-03 | 3.4E-04 | 4.0E-03 | 8.3E-04 | 2.0E-02 | 3.2E-03 | 4.0E-03 | 8.0E-04 | 6.0E-03 | 3.3E-04 | 3.2E-04 |
| 2 - 8 hours | 7.5E-04 | 2.4E-04 | 2.5E-04 | 7.5E-04 | 2.8E-04 | 3.2E-03 | 4.8E-04 | 1.8E-02 | 1.8E-03 | 3.2E-03 | 4.7E-04 | 4.0E-03 | 2.2E-04 | 2.1E-04 |
| 8 - 24 hours | 3.5E-04 | 1.1E-04 | 1.1E-04 | 3.5E-04 | 1.3E-04 | 1.2E-03 | 2.3E-04 | 7.0E-03 | 7.8E-04 | 1.2E-03 | 2.2E-04 | 2.0E-03 | 1.0E-04 | 1.0E-04 |
| 1 - 4 days | 2.8E-04 | 1.1E-04 | 1.1E-04 | 2.8E-04 | 1.2E-04 | 1.0E-03 | 2.2E-04 | 5.0E-03 | 6.9E-04 | 1.0E-03 | 2.1E-04 | 1.5E-03 | 9.8E-05 | 9.4E-05 |
| 4 - 30 days | 2.5E-04 | 8.9E-05 | 9.1E-05 | 2.5E-04 | 1.0E-04 | 8.0E-04 | 1.8E-04 | 4.5E-03 | 5.3E-04 | 8.0E-04 | 1.8E-04 | 1.0E-03 | 7.8E-05 | 7.5E-05 |

LNP COL 2.3-4

Table 2.3.4-201
Predicted LNP 1 and LNP 2 Chi/Q Values

| Location and Averaging Period | AP1000 DCD Acceptance Criteria Chi/Q | LNP 1 and LNP 2 Maximum Predicted Chi/Q ^(a) |
|-------------------------------|---|--|
| Exclusion Area Boundary | | |
| 0 – 2 hr. | $\leq 1.0 \times 10^{-3} \text{ } 5.1 \times 10^{-4} \text{ sec/m}^3$ | $3.16 \text{ } 2.56 \times 10^{-4} \text{ sec/m}^3$ |
| Low Population Zone | | |
| 0 – 8 hr. | $\leq 5.0 \text{ } 2.2 \times 10^{-4} \text{ sec/m}^3$ | $4.65 \text{ } 4.44 \times 10^{-5} \text{ sec/m}^3$ |
| 8 – 24 hr. | $\leq 3.0 \text{ } 1.6 \times 10^{-4} \text{ sec/m}^3$ | $2.97 \text{ } 3.18 \times 10^{-5} \text{ sec/m}^3$ |
| 24 – 96 hr. | $\leq 1.5 \text{ } 1.0 \times 10^{-4} \text{ sec/m}^3$ | $1.42 \text{ } 1.54 \times 10^{-5} \text{ sec/m}^3$ |
| 96 – 720 hr. | $\leq 8.0 \times 10^{-5} \text{ sec/m}^3$ | $2.75 \text{ } 5.44 \times 10^{-6} \text{ sec/m}^3$ |

Notes:

a) Maximum predicted Chi/Q values occurred in the SW sector for EAB and W sector for LPZ.

Chi/Q = atmospheric dilution factor
 sec/m^3 = second per cubic meter
hr. = hour

LNP COL 2.3-4

Table 2.3.4-206 (Sheet 1 of 2)
Comparison of Control Room Atmospheric Dispersion Factors for Accident Analysis for AP1000 DCD and LNP Units 1 and 2

Chi/Q (sec/m³) at HVAC Intake for the Identified Release Points^(a)

| Release Time | Plant Vent or PCS Air Diffuser ^(b) | | | Ground Level Containment Release Points ^(c,h) | | PORV and Safety Valve Releases ^(d) | | Condenser Air Removal Stack ^(g) | | Steam Line Break Releases | | Fuel Handling Area ^(e) | | Radwaste Building Truck Staging Area Door |
|--------------|---|---------|---------|--|---------|---|---------|--|---------|---------------------------|---------|-----------------------------------|---------|---|
| | DCD | LNP | LNP | DCD | LNP | DCD | LNP | DCD | LNP | DCD | LNP | DCD | LNP | LNP |
| 0 - 2 hours | 3.0E-03 | 1.7E-03 | 1.5E-03 | 6.0E-03 | 4.3E-03 | 2.0E-02 | 1.0E-02 | 6.0E-03 | 1.7E-03 | 2.4E-02 | 1.1E-02 | 6.0E-03 | 1.3E-03 | 1.0E-03 |
| 2 - 8 hours | 2.5E-03 | 1.0E-03 | 8.4E-04 | 3.6E-03 | 3.5E-03 | 1.8E-02 | 5.7E-03 | 4.0E-03 | 1.4E-03 | 2.0E-02 | 6.1E-03 | 4.0E-03 | 8.3E-04 | 6.4E-04 |
| 8 - 24 hours | 1.0E-03 | 4.5E-04 | 3.7E-04 | 1.4E-03 | 1.2E-03 | 7.0E-03 | 2.7E-03 | 2.0E-03 | 6.4E-04 | 7.5E-03 | 3.0E-03 | 2.0E-03 | 3.7E-04 | 3.0E-04 |
| 1 - 4 days | 8.0E-04 | 4.5E-04 | 3.8E-04 | 1.8E-03 | 1.2E-03 | 5.0E-03 | 2.1E-03 | 1.5E-03 | 5.9E-04 | 5.5E-03 | 2.3E-03 | 1.5E-03 | 3.4E-04 | 2.6E-04 |
| 4 - 30 days | 6.0E-04 | 3.6E-04 | 3.0E-04 | 1.5E-03 | 9.9E-04 | 4.5E-03 | 1.3E-03 | 1.0E-03 | 4.7E-04 | 5.0E-03 | 1.5E-03 | 1.0E-03 | 2.7E-04 | 2.0E-04 |

Chi/Q (sec/m³) at Annex Building Door for the Identified Release Points^(f)

| Release Time | Plant Vent or PCS Air Diffuser ^(b) | | | Ground Level Containment Release Points ^(c) | | PORV and Safety Valve Releases ^(d) | | Condenser Air Removal Stack ^(g) | | Steam Line Break Releases | | Fuel Handling Area ^(e) | | Radwaste Building Truck Staging Area Door |
|--------------|---|---------|---------|--|---------|---|---------|--|---------|---------------------------|---------|-----------------------------------|---------|---|
| | DCD | LNP | LNP | DCD | LNP | DCD | LNP | DCD | LNP | DCD | LNP | DCD | LNP | LNP |
| 0 - 2 hours | 1.0E-03 | 3.7E-04 | 3.8E-04 | 1.0E-03 | 3.4E-04 | 4.0E-03 | 8.3E-04 | 2.0E-02 | 3.2E-03 | 4.0E-03 | 8.0E-04 | 6.0E-03 | 3.3E-04 | 3.2E-04 |
| 2 - 8 hours | 7.5E-04 | 2.4E-04 | 2.5E-04 | 7.5E-04 | 2.8E-04 | 3.2E-03 | 4.8E-04 | 1.8E-02 | 1.8E-03 | 3.2E-03 | 4.7E-04 | 4.0E-03 | 2.2E-04 | 2.1E-04 |
| 8 - 24 hours | 3.5E-04 | 1.1E-04 | 1.1E-04 | 3.5E-04 | 1.3E-04 | 1.2E-03 | 2.3E-04 | 7.0E-03 | 7.8E-04 | 1.2E-03 | 2.2E-04 | 2.0E-03 | 1.0E-04 | 1.0E-04 |
| 1 - 4 days | 2.8E-04 | 1.1E-04 | 1.1E-04 | 2.8E-04 | 1.2E-04 | 1.0E-03 | 2.2E-04 | 5.0E-03 | 6.9E-04 | 1.0E-03 | 2.1E-04 | 1.5E-03 | 9.8E-05 | 9.4E-05 |
| 4 - 30 days | 2.5E-04 | 8.9E-05 | 9.1E-05 | 2.5E-04 | 1.0E-04 | 8.0E-04 | 1.8E-04 | 4.5E-03 | 5.3E-04 | 8.0E-04 | 1.8E-04 | 1.0E-03 | 7.8E-05 | 7.5E-05 |

**Table 7.1-2
Summary of LNP Site-Specific Off-Site Doses Consequences**

| Accident | EAB Dose TEDE (Sv [rem]) | LPZ Dose TEDE (Sv [rem]) | Guideline Limit TEDE (Sv [rem]) |
|--|-----------------------------|--------------------------------|--|
| Main Steam Line Break | | | |
| Preexisting Iodine Spike | 7.8E-04 (7.8E-02) | 1.7E-04 (1.7E-02) | 0.25 (25) |
| Accident-Initiated Iodine Spike | 8.6E-04 (8.6E-02) | 4.6E-04 (4.6E-02) | 0.025 (2.5) |
| Reactor Coolant Pump Locked Rotor | | | |
| No Feedwater | 6.2E-04 (6.2E-02) | 8.2E-05 (8.2E-03) | 0.025 (2.5) |
| Feedwater Available | 4.7E-04 (4.7E-02) | 1.7E-04 (1.7E-02) | 0.025 (2.5) |
| Control Rod Ejection Accident | 2.8E-03 (2.8E-01) | 1.2E-03 (1.2E-01) | 0.063 (6.3) |
| Steam Generator Tube Rupture | | | |
| Preexisting Iodine Spike | 1.7E-03 (1.7E-01) | 2.6E-04 (2.6E-02) | 0.25 (25) |
| Accident-Initiated Iodine Spike | 8.6E-04 (8.6E-02) | 1.8E-04 (1.8E-02) | 0.025 (2.5) |
| Small Line Break | 1.6E-03 (1.6E-01) | 2.2E-04 (2.2E-02) | 0.025 (2.5) |
| Design Basis LOCA | 3.7E-02 (3.7E+00) | 1.1E-02 (1.1E+00) | 0.25 (25) |
| Fuel Handling Accident | 4.1E-03 (4.1E-01) | 5.5E-04 (5.5E-02) | 0.063 (6.3) |

Notes:

Doses are based on Federal Guidance Report 11 and Federal Guidance Report 12 dose conversion.

TEDE guidelines are from Regulatory Guide 1.183. Small line break criteria based on Environmental Standard Review Plan 15.6.2.

EAB = exclusion area boundary
 LOCA = loss of coolant accident
 LPZ = low population zone
 rem = roentgen equivalent man
 Sv = Sievert
 TEDE = total effective dose equivalent

Table 7.1-3
Ratio of LNP 50 Percent Accident Site X/Q Values to AP1000 DCD X/Q Values

| Post Accident Time Period (Hours) | LNP Site X/Q Values (sec/m ³) | AP1000 DCD X/Q Values (sec/m ³) | X/Q Ratio |
|--------------------------------------|--|--|--------------------------|
| | | | LNP Site / AP1000 DCD |
| LOCA | | | |
| EAB | | | |
| 1.4--3.4 hr (1) | 7.81E-05 | 5.1E-04 | 1.53E-01 |
| LPZ | | | |
| 0--8 hr | 1.06E-05 | 2.2E-04 | 4.82E-02 |
| 8--24 hr | 7.81E-06 | 1.6E-04 | 4.88E-02 |
| 24--96 hr | 4.01E-06 | 1.0E-04 | 4.01E-02 |
| 96--720 hr | 1.54E-06 | 8.0E-05 | 1.93E-02 |
| All Other Accidents | | | |
| EAB | | | |
| 0--2 hr | 7.81E-05 | 1.0E-03 | 7.81E-02 |
| LPZ | | | |
| 0--8 hr | 1.06E-05 | 5.00E-04 | 2.12E-02 |
| 8--24 hr | 7.81E-06 | 3.00E-04 | 2.60E-02 |
| 24--96 hr | 4.01E-06 | 1.50E-04 | 2.67E-02 |
| 96--720 hr | 1.54E-06 | 8.00E-05 | 1.93E-02 |

Notes:

(1): The EAB X/Q value for the period 0 to 2 hours was used for the 1.4 to 3.4 hour period for the LNP site. The 1.4 to 3.4 hour period represents the worst two hour period for the EAB dose.

Definitions:

EAB = exclusion area boundary

LPZ = low population zone

sec/m³ = seconds per cubed meter

X/Q = atmospheric dispersion coefficient

**Table 7.1-4
Main Steam Line Break, 0 to 72 Hours, Preexisting Iodine Spike**

| Time (Hours) | EAB Dose TEDE (Sv [rem]) | LPZ Dose TEDE (Sv [rem]) |
|----------------------|-----------------------------|-----------------------------|
| AP1000 Tier 2 | | |
| 0 to 2 | 1.00E-02 (1.00E+00) | |
| 0 to 8 | -- | 5.81E-03 (5.81E-01) |
| 8 to 24 | -- | 7.18E-04 (7.18E-02) |
| 24 to 96 | -- | 1.08E-03 (1.08E-01) |
| Total | 1.00E-02 (1.00E+00) | 7.61E-03 (7.61E-01) |
| LNP Site | | |
| 0 to 2 | 7.81E-04 (7.81E-02) | |
| 0 to 8 | -- | 1.23E-04 (1.23E-02) |
| 8 to 24 | -- | 1.87E-05 (1.87E-03) |
| 24 to 96 | -- | 2.89E-05 (2.89E-03) |
| Total | 7.81E-04 (7.81E-02) | 1.71E-04 (1.71E-02) |
| Limit | 0.25 (25) | 0.25 (25) |

Notes:

EAB = exclusion area boundary
 LPZ = low population zone
 rem = roentgen equivalent man
 Sv = Sievert
 TEDE = total effective dose equivalent

**Table 7.1-5
Main Steam Line Break, 0 to 72 Hours, Accident-Initiated Iodine Spike**

| Time (Hours) | EAB Dose TEDE (Sv [rem]) | LPZ Dose TEDE (Sv [rem]) |
|----------------------|-----------------------------|-----------------------------|
| AP1000 Tier 2 | | |
| 0 to 2 | 1.10E-02 (1.10E+00) | |
| 0 to 8 | -- | 1.02E-02 (1.02E+00) |
| 8 to 24 | -- | 3.77 E-03 (3.77E-01) |
| 24 to 96 | -- | 5.36E-03 (5.36E-01) |
| Total | 1.10E-02 (1.10E+00) | 1.93E-02 (1.93E+00) |
| LNP Site | | |
| 0 to 2 | 8.59E-04 (8.59E-02) | |
| 0 to 8 | -- | 2.16E-04 (2.16E-02) |
| 8 to 24 | -- | 9.81E-05 (9.81E-03) |
| 24 to 72 | -- | 1.43E-04 (1.47E-02) |
| Total | 8.59E-04 (8.59E-02) | 4.58E-04 (4.58E-02) |
| Limit | 0.025 (2.5) | 0.025 (2.5) |

Notes:

EAB = exclusion area boundary
 LPZ = low population zone
 rem = roentgen equivalent man
 Sv = Sievert
 TEDE = total effective dose equivalent

**Table 7.1-6
Locked Rotor Accident, 0 to 1.5 Hours, Preexisting Iodine Spike**

| Time (Hours) | EAB Dose TEDE (Sv [rem]) | LPZ Dose TEDE (Sv [rem]) |
|--|-------------------------------------|-------------------------------------|
| No Feedwater | | |
| AP1000 Tier 2 | | |
| 0 to 1.5 | 8.00E-03 (8.00E-01) | 3.89E-03 (3.89E-01) |
| LNP Site | | |
| 0 to 1.5 | 6.25E-04 (6.25E-02) | 8.25E-05 (8.25E-03) |
| Locked Rotor Accident, 0 to 8 Hours, Preexisting Iodine Spike | | |
| Feedwater Available | | |
| AP1000 Tier 2 | | |
| 0 to 2 | 6.00E-03 (6.00E-01) | |
| 0 to 8 | -- | 7.94 E-03 (7.94E-01) |
| Total | 6.00E-03 (6.00E-01) | 7.94E-03 (7.94E-01) |
| LNP Site | | |
| 0 to 2 | 4.69E-04 (4.69E-02) | |
| 0 to 8 | -- | 1.68E-04 (1.68E-02) |
| Total | 4.69E-04 (4.69E-02) | 1.68E-04 (1.68E-02) |
| Limit | 0.025 (2.5) | 0.025 (2.5) |

Notes:

EAB = exclusion area boundary
 LPZ = low population zone
 rem = roentgen equivalent man
 Sv = Sievert
 TEDE = total effective dose equivalent

**Table 7.1-7
Control Rod Ejection Accident, 0 to 720 Hours, Preexisting Iodine Spike**

| Time (Hours) | EAB Dose TEDE (Sv [rem]) | LPZ Dose TEDE (Sv [rem]) |
|----------------------|-----------------------------|-----------------------------|
| AP1000 Tier 2 | | |
| 0 to 2 | 3.60E-02 (3.60E+00) | |
| 0 to 8 | -- | 4.58E-02 (4.58E+00) |
| 8 to 24 | -- | 7.84E-03 (7.84E-01) |
| 24 to 96 | -- | 6.82E-04 (6.32E-02) |
| 96 to 720 | -- | 2.06E-04 (2.06E-02) |
| Total | 3.60E-02 (3.60E+00) | 5.45E-02 (5.45E+00) |
| LNP Site | | |
| 0 to 2 | 2.81E-03 (2.8E-01) | |
| 0 to 8 | -- | 9.71E-04 (9.71E-02) |
| 8 to 24 | -- | 2.04E-04 (2.04E-02) |
| 24 to 96 | -- | 1.69E-05 (1.69E-03) |
| 96 to 720 | -- | 3.97E-06 (3.97E-04) |
| Total | 2.81E-03 (2.81E-01) | 1.20E-03 (1.20E-01) |
| Limit | 0.063 (6.3) | 0.063 (6.3) |

Notes:

EAB = exclusion area boundary
LPZ = low population zone
rem = roentgen equivalent man
Sv = Sievert
TEDE = total effective dose equivalent

**Table 7.1-8
Steam Generator Tube Rupture, 0 to 24 Hours, Accident-Initiated Iodine
Spike**

| Time (Hours) | EAB Dose TEDE (Sv [rem]) | LPZ Dose TEDE (Sv [rem]) |
|----------------------|-------------------------------------|-------------------------------------|
| AP1000 Tier 2 | | |
| 0 to 2 | 1.10E-02 (1.10E+00) | |
| 0 to 8 | -- | 6.27E-03 (6.27E-01) |
| 8 to 24 | -- | 1.69E-03 (1.69E-01) |
| Total | 1.10E-02 (1.10E+00) | 7.96E-03 (7.96E-01) |
| LNP Site | | |
| 0 to 2 | 8.59E-04 (8.59E-02) | |
| 0 to 8 | -- | 1.33E-04 (1.33E-02) |
| 8 to 24 | -- | 4.40E-05 (4.40E-03) |
| Total | 8.59E-04 (8.59E-02) | 1.77E-04 (1.77E-02) |
| Limit | 0.025 (2.5) | 0.025 (2.5) |

Notes:

EAB = exclusion area boundary
 LPZ = low population zone
 rem = roentgen equivalent man
 Sv = Sievert
 TEDE = total effective dose equivalent

**Table 7.1-9
Steam Generator Tube Rupture, 0 to 24 Hours, Preexisting Iodine Spike**

| Time (Hours) | EAB Dose TEDE (Sv [rem]) | LPZ Dose TEDE (Sv [rem]) |
|----------------------|-----------------------------|-----------------------------|
| AP1000 Tier 2 | | |
| 0 to 2 | 2.20E-02 (2.20E+00) | |
| 0 to 8 | -- | 1.16E-02 (1.16E+00) |
| 8 to 24 | -- | 7.24E-04 (7.24E-02) |
| Total | 2.20E-02 (2.20E+00) | 1.23E-02 (1.23E+00) |
| LNP Site | | |
| 0 to 2 | 1.72E-03 (1.72E-01) | |
| 0 to 8 | -- | 2.46E-04 (2.46E-02) |
| 8 to 24 | -- | 1.88E-05 (1.88E-03) |
| Total | 1.72E-03 (1.72E-01) | 2.65E-04 (2.65E-02) |
| Limit | 0.25 (2.5) | 0.25 (2.5) |

Notes:

EAB = exclusion area boundary
LPZ = low population zone
rem = roentgen equivalent man
Sv = Sievert
TEDE = total effective dose equivalent

**Table 7.1-10
Small Line Break Accident, 0 to 0.5 Hours, Accident-Initiated Iodine Spike**

| Time (Hours) | EAB Dose TEDE (Sv [rem]) | LPZ Dose TEDE (Sv [rem]) |
|----------------------|-----------------------------|-----------------------------|
| AP1000 Tier 2 | | |
| 0 to 0.5 | 2.10E-02 (2.10E+00) | 1.02E-02 (1.02E+00) |
| LNP Site | | |
| 0 to 0.5 | 1.64E-03 (1.64E-01) | 2.16E-04 (2.16E-02) |
| Limit | 0.025 (2.5) | 0.025 (2.5) |

Notes:

EAB = exclusion area boundary
LPZ = low population zone
rem = roentgen equivalent man
Sv = Sievert
TEDE = total effective dose equivalent

**Table 7.1-11
AP1000 Design Basis LOCA**

| Time (Hours) | EAB Dose TEDE (Sv [rem])^(a) | LPZ Dose TEDE (Sv [rem]) |
|----------------------|---|-------------------------------------|
| AP1000 Tier 2 | | |
| 1.4 to 3.4 | 2.46E-01 (2.46E+01) | - |
| 0 to 8 | -- | 2.17E-01 (2.17E+01) |
| 8 to 24 | -- | 7.50E-03 (7.50E-01) |
| 24 to 96 | -- | 2.93E-03 (2.93E-01) |
| 96 to 720 | -- | 5.49E-03 (5.49E-01) |
| Total | 2.46E-01 (2.46E+01) | 2.33E-01 (2.33E+01) |
| LNP Site | | |
| 1.4 to 3.4 | 3.74E-02 (3.74E+00) | - |
| 0 to 8 | -- | 1.05E-02 (1.05E+00) |
| 8 to 24 | -- | 3.66E-04 (3.66E-02) |
| 24 to 96 | -- | 1.17E-04 (1.17E-02) |
| 96 to 720 | -- | 1.06E-04 (1.06E-02) |
| Total | 3.74E-02 (3.74E+00) | 1.10E-02 (1.10E+00) |
| Limit | 0.25 (25) | 0.25 (25) |

Notes:

a) The EAB dose is for the worst 2-hour period.

EAB = exclusion area boundary

LOCA = loss of coolant accident

LPZ = low population zone

rem = roentgen equivalent man

Sv = Sievert

TEDE = total effective dose equivalent

**Table 7.1-12
Fuel Handling Accidents, 0 to 2 Hours**

| Time (Hours) | EAB Dose TEDE (Sv [rem]) | LPZ Dose TEDE (Sv [rem]) |
|----------------------|-------------------------------------|-------------------------------------|
| AP1000 Tier 2 | | |
| 0 to 2 | 5.20E-02 (5.20E+00) | 2.59E-02 (2.59E+00) |
| LNP Site | | |
| 0 to 2 | 4.06E-03 (4.06E-01) | 5.49E-04 (5.49E-02) |
| Limit | 0.063 (6.3) | 0.063 (6.3) |

Notes:

EAB = exclusion area boundary
 LPZ = low population zone
 rem = roentgen equivalent man
 Sv = Sievert
 TEDE = total effective dose equivalent