



**UNITED STATES
NUCLEAR REGULATORY COMMISSION**
REGION II
SAM NUNN ATLANTA FEDERAL CENTER
61 FORSYTH STREET, SW, SUITE 23T85
ATLANTA, GEORGIA 30303-8931

November 20, 2009

Mr. J. R. Morris
Site Vice President
Duke Power Company, LLC
d/b/a Duke Energy Carolinas, LLC
Catawba Nuclear Station
4800 Concord Road
York, SC 29745-9635

**SUBJECT: CATAWBA NUCLEAR STATION - NRC COMPONENT DESIGN BASES
INSPECTION - INSPECTION REPORT 05000413/2009006 AND
05000414/2009006**

Dear Mr. Morris:

On August 27, 2009, U. S. Nuclear Regulatory Commission (NRC) completed an inspection at your Catawba Nuclear Station Units 1 and 2. The enclosed inspection report documents the inspection results, which were discussed on August 27, 2009, with Mr. Tom Ray and other members of your staff. A re-exit was conducted by telephone on October 15, 2009 with Mr. Randy Hart and other members of your staff.

The inspection examined activities conducted under your license as they relate to safety and compliance with the Commission's rules and regulations and with the conditions of your license. The inspectors reviewed selected procedures and records, observed activities, and interviewed personnel.

This report documents one NRC-identified finding of very low safety significance (Green) which was determined to be a violation of NRC requirements. However, because of the very low safety significance and because it is entered into your corrective action program, the NRC is treating the finding as a non-cited violation (NCV) consistent with Section VI.A.1 of the NRC Enforcement Policy. If you contest this NCV, you should provide a response within 30 days of the date of this inspection report, with the basis for your denial, to the Nuclear Regulatory Commission, ATTN.: Document Control Desk, Washington DC 20555-0001; with copies to the Regional Administrator, Region II; the Director, Office of Enforcement, United States Nuclear Regulatory Commission, Washington, DC 20555-0001; and the NRC resident inspector at the Catawba Nuclear Plant. In addition, if you disagree with the characterization of any finding in this report, you should provide a response within 30 days of the date of this inspection report, with the basis for your disagreement, to the Regional Administrator, Region II, and the NRC resident inspector at the Catawba Nuclear Plant. The information you provide will be considered in accordance with Inspection Manual Chapter 0305.

In accordance with 10 CFR 2.390 of the NRC's "Rules of Practice," a copy of this letter, its enclosure, and your response (if any) will be available electronically for public inspection in the

DEC

2

NRC Public Document Room or from the Publicly Available Records (PARS) component of the NRC's document system (ADAMS). ADAMS is accessible from the NRC web site at <http://www.nrc.gov/reading-rm/adams.html> (the Public Electronic Reading Room).

Sincerely,

/RA/

David A. Jones, Acting Chief
Engineering Branch 1
Division of Reactor Safety

Docket Nos.: 50-413, 50-414
License Nos.: NPF-35, NPF-52

Enclosure:
Inspection Report 05000413/2009006,
05000414/2009006 w/Attachment:
Supplemental Information

cc w/encl: (See page 3)

DEC

2

NRC Public Document Room or from the Publicly Available Records (PARS) component of the NRC's document system (ADAMS). ADAMS is accessible from the NRC web site at <http://www.nrc.gov/reading-rm/adams.html> (the Public Electronic Reading Room).

Sincerely,

/RA/

David A. Jones, Acting Chief
Engineering Branch 1
Division of Reactor Safety

Docket Nos.: 50-413, 50-414
License Nos.: NPF-35, NPF-52

Enclosure:
Inspection Report 05000413/2009006,
05000414/2009006 w/Attachment:
Supplemental Information

cc w/encl: (See page 3)

PUBLICLY AVAILABLE NON-PUBLICLY AVAILABLE SENSITIVE NON-SENSITIVE
ADAMS:X Yes ACCESSION NUMBER: _____ SUNSI REVIEW COMPLETE

OFFICE	RII:DRS	RII:DRS	RII:DRS	RII:DRS	RII:DRS	CONTRACTOR	CONTRACTOR
SIGNATURE	RA	RA	RA	RA	RA	RA	RA
NAME	R. LEWIS	R. BERRYMAN	D. MAS	R. PATTERSON	A. ALLEN	C. EDWARDS	O. MAZZONI
DATE	11/19/2009	11/19/2009	11/19/2009	11/19/2009	11/19/2009	11/19/2009	11/19/2009
E-MAIL COPY?	YES NO	YES NO	YES NO	YES NO	YES NO	YES NO	YES NO
OFFICE	RII:DRP	RII:DRS					
SIGNATURE	RA	RA					
NAME	J. BARTLEY	D. JONES					
DATE	11/20/2009	11/120/2009					
E-MAIL COPY?	YES NO	YES NO	YES NO	YES NO	YES NO	YES NO	YES NO

OFFICIAL RECORD COPY DOCUMENT NAME: S:\DRS\Eng Branch 1\BRANCH INSPECTION FILES\CDBI INSPECTIONS\CDBI INSPECTIONS\INSP REPORTS\CDBI Final Inspection Reports\CatawbaCDBI_2009006_Report(Ver1).doc

cc w/encl:

Randy D. Hart
Regulatory Compliance Manager
Duke Energy Carolinas, LLC
Electronic Mail Distribution

R. L. Gill, Jr.
Manager
Nuclear Regulatory Issues & Industry Affairs
Duke Energy Carolinas, LLC
Electronic Mail Distribution

Dhiaa M. Jamil
Group Executive and Chief Nuclear Officer
Duke Energy Carolinas, LLC
Electronic Mail Distribution

Kathryn B. Nolan
Senior Counsel
Duke Energy Carolinas, LLC
526 South Church Street-EC07H
Charlotte, NC 28202

Lisa F. Vaughn
Associate General Counsel
Duke Energy Carolinas, LLC
526 South Church Street-EC07H
Charlotte, NC 28202

Senior Resident Inspector
U.S. Nuclear Regulatory Commission
Catawba Nuclear Station
U.S. NRC
4830 Concord Road
York, SC 29745

David A. Repka
Winston Strawn LLP
Electronic Mail Distribution

North Carolina MPA-1
Suite 600
P.O. Box 29513
Raleigh, NC 27525-0513

Susan E. Jenkins
Section Manager, Division of Waste Management
Bureau of Land and Waste Management
S.C. Department of Health and Environmental
Control
Electronic Mail Distribution

R. Mike Gandy
Division of Radioactive Waste Mgmt.
S.C. Department of Health and Environmental
Control
Electronic Mail Distribution

W. Lee Cox III
(Acting) Section Chief
Radiation Protection Section
N.C. Department of Environmental
Commerce & Natural Resources
Electronic Mail Distribution

Vanessa Quinn
Federal Emergency Management Agency
500 C Street, SW
Room 840
Washington, DC 20472

Steve Weatherman, Operations Analyst
North Carolina Electric Membership Corporation
Electronic Mail Distribution

County Manager of York County
York County Courthouse
York, SC 29745

Piedmont Municipal Power Agency
Electronic Mail Distribution

Peggy Force
Assistant Attorney General
State of North Carolina
P.O. Box 629
Raleigh, NC 27602

DEC

4

Letter to J. R. Morris from David Jones dated November 20, 2009.

SUBJECT: CATAWBA NUCLEAR STATION - NRC COMPONENT DESIGN BASES
INSPECTION - INSPECTION REPORT 05000413/2009006 AND
05000414/2009006

Distribution w/encl:

RIDSNRRDIRS

PUBLIC

A. Adams, NRR

RidsNrrPMCatawba Resource

U. S. NUCLEAR REGULATORY COMMISSION

REGION II

Docket Nos.: 50-413, 50-414

License Nos.: NPF-35, NPF-52

Report Nos.: 05000413/2009006, 05000414/2009006

Licensee: Duke Energy Carolinas, LLC

Facility: Catawba Nuclear Station, Units 1 and 2

Location: York, SC 29745

Dates: July 27 – August 27, 2009

Inspectors: R. Lewis, Senior Reactor Inspector (Lead)
R. Berryman, Senior Reactor Inspector
D. Mas-Peñaranda, Reactor Inspector
R. Patterson, Reactor Inspector
A. Allen, Reactor Inspector (Trainee)
O. Mazzoni, Contractor
C. Edwards, Contractor

Approved by: David Jones, Acting Chief
Engineering Branch 1
Division of Reactor Safety

Enclosure

SUMMARY OF FINDINGS

IR 05000413/2009006, 05000414/2009006; 7/27/2009 – 08/27/2009; Catawba Nuclear Station, Units 1 and 2; Component Design Basis Inspection.

This inspection was conducted by a team of four NRC inspectors from the Region II office, one trainee, and two NRC contract inspectors. One finding of very low safety significance (i.e. Green) was identified during this inspection. The significance of most findings is indicated by their color (Green, White, Yellow, Red) using IMC 0609, "Significance Determination Process" (SDP). Findings for which the SDP does not apply may be Green or be assigned a severity level after NRC management review. The NRC's program for overseeing the safe operation of commercial nuclear power reactors is described in NUREG-1649, "Reactor Oversight Process," (ROP) Revision 4, dated December 2006.

Cornerstone: Mitigating Systems

Green: The team identified a non-cited violation of 10 CFR 50.65(a)(1) for the licensee's failure to monitor the turbine-driven auxiliary feedwater pump (CAPT) sump valves for Units 1 and 2. PIPs C-09-05020 and C-09-04390 initiated immediate corrective actions, including testing of the subject valves during the inspection, wherein valve 1WL848 failed to stroke. Additionally, the licensee increased the maintenance category of the affected components and made procedural modifications to provide positive valve position controls.

The team determined that the licensee's failure to monitor the performance and condition of Valve 1WL848 was a performance deficiency. This finding is more than minor because it is associated with equipment performance attribute of the Mitigating Systems cornerstone and adversely affected the cornerstone objective to ensure the availability, reliability and capability of systems that respond to initiating events to prevent undesirable consequences. Specifically, the failure to perform periodic testing or preventative maintenance resulted in a lack of reasonable assurance that the valves would perform their function of protecting CAPT. The team determined that the finding is of very low safety significance (Green) using the SDP because the finding did not represent an actual loss of safety function. This finding was reviewed for cross-cutting aspects and none were identified since the performance deficiency was not indicative of current licensee performance. (Section 1R21.2.5)

REPORT DETAILS

1. REACTOR SAFETY

Cornerstones: Initiating Events, Mitigating Systems, Barrier Integrity

1R21 Component Design Bases Inspection (71111.21)

.1 Inspection Sample Selection Process

The team selected risk significant components and operator actions for review using information contained in the licensee's Probabilistic Risk Assessment (PRA). In general, this included components and operator actions that had a risk achievement worth factor greater than 1.3 or Birnbaum value greater than 1×10^{-6} . The components selected were generally located within the following systems: Component Cooling, Auxiliary Feedwater, Service Water, Residual Heat Removal, Charging, Safety Injection, 4kV Distribution, Hydrogen Mitigation, and Standby Shutdown Facility. The sample included 19 components, 3 operating experience items, and 5 operator actions.

The team performed a margin assessment and detailed review of the selected risk-significant components to verify that the design bases had been correctly implemented and maintained. This design margin assessment considered original design issues, margin reductions due to modifications, or margin reductions identified as a result of material condition issues. Equipment reliability issues were also considered in the selection of components for detailed review. These reliability issues included items related to failed performance test results, significant corrective action, repeated maintenance, maintenance rule (a)1 status, RIS 05-020 (formerly GL 91-18) conditions, NRC resident inspector input of problem equipment, System Health Reports, industry operating experience and licensee problem equipment lists. Consideration was also given to the uniqueness and complexity of the design, operating experience, and the available defense in depth margins. An overall summary of the reviews performed and the specific inspection findings identified is included in the following sections of the report.

.2 Results of Detailed Reviews

.2.1 2KCPUA1, 2A1 Component Cooling Pump

a. Inspection Scope

The inspectors reviewed the plant technical specifications (TS), updated final safety analysis (UFSAR), design basis documents (DBDs) and associated system lesson plans to establish an overall understanding of the design bases of the component. Design calculations (i.e. net positive suction head (NPSH), total dynamic head (TDH), pump curves, vortex, seismic qualification, component cooling system flow distribution) and site procedures were reviewed against these bases to verify design assumptions have been appropriately translated into these documents. The team requested and reviewed system modifications over the life of the component to verify that the subject modifications did not serve to degrade the component's performance capability and were

Enclosure

appropriately incorporated into relevant drawings and procedures. Equipment ratings and specifications were reviewed against design basis requirements to ensure that the equipment qualification is suitable for all expected conditions. A component walkdown was conducted to verify that the installed configuration will support design basis function under accident/event conditions and have been maintained to be consistent with design assumptions. Test procedures and more recent test results were reviewed against design basis documents to verify that acceptance criteria for tested parameters were supported by calculations or other engineering documents and that individual tests and/or analyses validated component operation under accident/event conditions. Vendor documentation, system health reports, preventive and corrective maintenance history, and corrective action system documents were reviewed in order to verify that potential degradation was monitored or prevented and the component replacement was consistent with in service/equipment qualification life. The team reviewed the licensee's response to BL 88-04, Potential Safety-Related Pump Loss, in order to verify that applicable insights from operating experience have been applied to the selected components.

b. Findings

No findings of significance were identified.

.2.2 1RNPUB, 1B Nuclear Service Water Pump

a. Inspection Scope

The inspectors reviewed the plant TS, UFSAR, DBDs and associated system lesson plans to establish an overall understanding of the design bases of the component. Design calculations (i.e., CNC 1223.24-00-0027 and CNC 1223.24-00-0058) and site procedures were reviewed against these bases to verify design assumptions have been appropriately translated into these documents. The team requested and reviewed system modifications over the life of the component to verify that the subject modifications did not serve to degrade the component's performance capability and were appropriately incorporated into relevant drawings and procedures. Equipment ratings and specifications were reviewed against design basis requirements to ensure that the equipment qualification was suitable for all expected conditions. A component walkdown was conducted to verify that the installed configuration would support design basis function under accident/event conditions and had been maintained to be consistent with design assumptions. Test procedures and more recent test results were reviewed against design basis documents to verify that acceptance criteria for tested parameters were supported by calculations or other engineering documents and that individual tests and/or analyses validated component operation under accident/event conditions. Vendor documentation, system health reports, preventive and corrective maintenance history, and corrective action system documents were reviewed in order to verify that potential degradation was monitored or prevented and the component replacement was consistent with in-service/equipment qualification life.

b. Findings

No findings of significance were identified.

.2.3 2CAPUA, 2A Motor-Driven Auxiliary Feedwater Pump

a. Inspection Scope

The inspectors reviewed the plant TS, UFSAR, DBDs and associated system lesson plans to establish an overall understanding of the design bases of the component. Design calculations (i.e. minimum flow and test acceptance) and site procedures were reviewed against these bases to verify design assumptions have been appropriately translated into these documents. The team requested and reviewed system modifications over the life of the component to verify that the subject modifications did not serve to degrade the component's performance capability and were appropriately incorporated into relevant drawings and procedures. A component walkdown was conducted to verify that the installed configuration would support design basis function under accident/event conditions and have been maintained to be consistent with design assumptions. Control panel indicators were observed and operating procedures reviewed to verify that component operation and alignments were consistent with design and licensing basis assumptions. Additionally, the inspectors reviewed time critical operator actions where those actions supported design basis assumptions or conclusions. Alternate flow paths and water sources, as well as possible diversion paths, were reviewed to verify that the process medium would be available and unimpeded during an accident. Test procedures and more recent test results were reviewed against design basis documents to verify that acceptance criteria for tested parameters were supported by calculations or other engineering documents and that individual tests and/or analyses validated component operation under accident/event conditions. Vendor documentation, system health reports, preventive and corrective maintenance history, and corrective action system documents were reviewed in order to verify that potential degradation was monitored or prevented and the component replacement was consistent with in service/equipment qualification life.

b. Findings

No findings of significance were identified.

.2.4 2KDHXA, Emergency Diesel Generator Jacket Cooling Water Heat Exchanger

a. Inspection Scope

The inspectors reviewed the plant TS, UFSAR, DBDs and associated system lesson plans to establish an overall understanding of the design bases of the component. Design calculations (i.e., CNC 1223.59-01-0005) and site procedures were reviewed against these bases to verify design assumptions have been appropriately translated into these documents. The team requested and reviewed system modifications over the life of the component to verify that the subject modifications did not serve to degrade the component's performance capability and were appropriately incorporated into relevant

drawings and procedures. A component walkdown was conducted to verify that the installed configuration would support design basis function under accident/event conditions and had been maintained to be consistent with design assumptions. External event analyses were reviewed against design specifications and requirements in order to verify that the equipment was adequately protected. Test procedures and more recent test results were reviewed against design basis documents to verify that acceptance criteria for tested parameters were supported by calculations or other engineering documents and that individual tests and/or analyses validated component operation under accident/event conditions. Vendor documentation, system health reports, preventive and corrective maintenance history, and corrective action system documents were reviewed in order to verify that potential degradation was monitored or prevented and the component replacement was consistent with in service/equipment qualification life.

b. Findings

No findings of significance were identified.

.2.5 1WL848, Floor Drain Sump D Discharge to Turbine Bldg Sump Air-Operated Valve

a. Inspection Scope

The inspectors reviewed the plant TS, UFSAR, DBDs and associated system lesson plans to establish an overall understanding of the design bases of the component. Design calculations (i.e., site flooding analysis) and site procedures were reviewed against these bases to verify design assumptions have been appropriately translated into these documents. The team requested and reviewed system modifications over the life of the component to verify that the subject modifications did not serve to degrade the component's performance capability and were appropriately incorporated into relevant drawings and procedures. A component walkdown was conducted to verify that the installed configuration would support design basis function under accident/event conditions and have been maintained to be consistent with design assumptions. Control panel indicators were observed and operating procedures reviewed to verify that component operation and alignments were consistent with design and licensing basis assumptions. Where manual actions were credited, the inspector's review included the availability of any necessary tools or accessibility aids. Additionally, the inspectors reviewed time critical operator actions where those actions supported design basis assumptions or conclusions. Test procedures and more recent test results were reviewed against design basis documents to verify that acceptance criteria for tested parameters were supported by calculations or other engineering documents and that individual tests and/or analyses validated component operation under accident/event conditions. Vendor documentation, system health reports, preventive and corrective maintenance history, and corrective action system documents were reviewed in order to verify that potential degradation was monitored or prevented and the component replacement was consistent with in service/equipment qualification life.

b. Findings

Introduction: The team identified a Green non-cited violation of 10 CFR 50.65(a)(1) for the licensee's failure to monitor, in accordance with established criteria, the performance and condition of the turbine-driven auxiliary feedwater pump (CAPT) sump valves for Units 1 and 2.

Description: Valve 1/2WL848 is a normally open, fail as-is, locally controlled, plug valve with a pneumatic operator and a packless stem. The valve is located in the common discharge header from the auxiliary feedwater (CA) pump pit sumps.

Valve 1/2WL848, when open, permits the discharge of the CAPT sumps to the turbine building sump when less than pre-determined levels of radiation are sensed by radiation monitor 1/2EMF52. Valve 1/2WL848 closes upon receipt of a high radiation signal so that effluent from floor drain sump D would not be discharged to the turbine building sump. To ensure that any release to the environment would be kept as low as reasonably achievable (ALARA), the closure of valve 1/2WL848 results in the diversion of this potentially contaminated stream to the residual heat removal (ND) and containment spray (NS) pump rooms sump through valve 1/2WL847, a normally closed valve of the same type which opens upon the high radiation signal.

Valve 1/2WL848, if failed closed, could result in the overflow of the CAPT sump and eventually affect the continued operation of the CAPT. The CAPT, a safety-related component, requires a small amount of cooling flow (typically less than 15gpm) which creates a constant input to the CAPT pit sump. The conservative estimate of the time for increased water level to impact CAPT operation was 86.8 minutes following failure of the sump system.

The team noted that since plant start-up the licensee failed to inspect, test or perform preventative maintenance on 1/2WL848 and 1/2WL847. During the inspection, the licensee performed performance test (PT/1/A/4700/020) and Valve 1WL848 failed to stroke closed. When the closed pushbutton was pressed, the valve remained in the full open position and air was leaking from both above and below the valve's air actuator. In several attempts, the valve would not move from the full open position. The licensee also tested valve 1WL847; it stroked successfully open and closed. 1/2WL847 is normally closed to isolate the flow path to the ND/NS auxiliary building sump.

The team determined that the licensee failed to provide reasonable assurance that valve 1WL848 was capable of fulfilling its intended function. During the inspection the licensee repaired the 1WL848 actuator and retested it satisfactorily. Also the licensee re-categorized the valves in the discharge flow path from risk category C (run-to-failure) to risk category A (highly risk-significant) and enhanced procedural guidance to ensure a flow path will always be available from the CAPT pit sump.

Analysis: The team determined that the licensee's failure to monitor the performance and condition of valve 1/2WL848 was a performance deficiency. This finding was more than minor because it was associated with equipment performance attribute of the Mitigating Systems cornerstone and adversely affected the cornerstone objective to

ensure the availability, reliability and capability of systems that respond to initiating events to prevent undesirable consequences. Specifically, the failure to perform periodic testing or preventative maintenance resulted in a lack of reasonable assurance that the valves would perform their safety important function in protecting the CAPT. Using Inspection Manual Chapter 0609, "Significance Determination Process," Phase 1 Worksheet, the team determined that the finding is of very low safety significance (Green) because the finding did not represent an actual loss of safety function. This finding was reviewed for cross-cutting aspects and none were identified since the performance deficiency was not indicative of current licensee performance.

Enforcement: 10 CFR 50.65(a)(1) states, in part, that licensees shall monitor the performance or condition of structures, systems and components (SSCs) within the scope of the rule as defined by 10 CFR 50.65(b), against license established goals, in a manner sufficient to provide reasonable assurance that such SSCs are capable of fulfilling their intended function. 10 CFR 50.65(a)(2) states that monitoring as specified in paragraph (a)(1)... is not required where it has been demonstrated that the performance or condition of a SSC is being effectively controlled through the performance of appropriate preventative maintenance, such that the SSC remains capable of performing its intended function. Contrary to the above, the licensee failed to demonstrate that the performance or condition of the CAPT pit sump discharge valve had been effectively controlled through the performance of appropriate preventive maintenance, testing or inspection and did not monitor against licensee established goals. Specifically, since plant start-up the licensee failed to monitor the performance and condition of Valve 1/2WL848, an expectation which was enacted by regulation effective July 10, 1996. Because this finding is of very low safety significance and because it was entered into the licensee's corrective action program as PIP C-09-05020 and PIP C-09-04390, this violation is being treated as an NCV, consistent with the NRC Enforcement Policy: NCV 05000413, 414/2009006-001, Failure to monitor the turbine-driven auxiliary feedwater pump sump valves for units 1 and 2.

.2.6 2ND28A, ND Supply to NV and 2A NI Pumps Motor-Operated Valve

a. Inspection Scope

The inspectors reviewed the plant TS, UFSAR, DBDs and associated system lesson plans to establish an overall understanding of the design bases of the component. Design calculations (i.e., CNC 1205.19-00-0060) and site procedures were reviewed against these bases to verify design assumptions have been appropriately translated into these documents. The inspector reviewed the calculations for the degraded voltage at the motor-operated valve (MOV) terminals, to ensure the proper voltage was utilized in the team's review of MOV torque calculations. The team requested and reviewed system modifications over the life of the component to verify that the subject modifications did not serve to degrade the component's performance capability and were appropriately incorporated into relevant drawings and procedures. A component walkdown was conducted to verify that the installed configuration would support design basis function under accident/event conditions and had been maintained to be consistent with design assumptions. Control room indicators were observed and

operating procedures reviewed to verify that component operation and alignments were consistent with design and licensing basis assumptions. Additionally, the inspectors reviewed time critical operator actions where those actions supported design basis assumptions or conclusions. Test procedures and more recent test results were reviewed against design basis documents to verify that acceptance criteria for tested parameters were supported by calculations or other engineering documents and that individual tests and/or analyses validated component operation under accident/event conditions. Vendor documents, system health reports, preventive and corrective maintenance history, and corrective action system documents were reviewed in order to verify that potential degradation was monitored or prevented and the component replacement was consistent with in service/equipment qualification life.

b. Findings

No findings of significance were identified.

.2.7 2NI136B, ND Supply to NI Pump 2B Motor-Operated Valve

a. Inspection Scope

The inspectors reviewed the plant TS, UFSAR, DBDs and associated system lesson plans to establish an overall understanding of the design bases of the component. Design calculations (i.e., CNC 1205.19-00-0021) and site procedures were reviewed against these bases to verify design assumptions have been appropriately translated into these documents. The inspector reviewed the calculations for the degraded voltage at the MOV terminals, to ensure the proper voltage was utilized in the team's review of MOV torque calculations. The team requested and reviewed system modifications over the life of the component to verify that the subject modifications did not serve to degrade the component's performance capability and were appropriately incorporated into relevant drawings and procedures. A component walkdown was conducted to verify that the installed configuration would support design basis function under accident/event conditions and had been maintained to be consistent with design assumptions. Control room indicators were observed and operating procedures reviewed to verify that component operation and alignments were consistent with design and licensing basis assumptions. Additionally, the inspectors reviewed time critical operator actions where those actions supported design basis assumptions or conclusions. Test procedures and more recent test results were reviewed against design basis documents to verify that acceptance criteria for tested parameters were supported by calculations or other engineering documents and that individual tests and/or analyses validated component operation under accident/event conditions. Vendor documents, system health reports, preventive and corrective maintenance history, and corrective action system documents were reviewed in order to verify that potential degradation was monitored or prevented and the component replacement was consistent with in service/equipment qualification life.

b. Findings

No findings of significance were identified.

.2.8 1NV865, Standby M/U Pump Suction from Transfer Tube Motor-Operated Valve

a. Inspection Scope

The inspectors reviewed the plant TS, UFSAR, DBDs and associated system lesson plans to establish an overall understanding of the design bases of the component. Design calculations (i.e., operating parameters and MOV calculations) and site procedures were reviewed against these bases to verify design assumptions have been appropriately translated into these documents. The inspector reviewed the calculations for the degraded voltage at the MOV terminals, to ensure the proper voltage was utilized in the team's review of MOV torque calculations. The team requested and reviewed system modifications over the life of the component to verify that the subject modifications did not serve to degrade the component's performance capability and were appropriately incorporated into relevant drawings and procedures. A component walkdown was conducted to verify that the installed configuration would support design basis function under accident/event conditions and have been maintained to be consistent with design assumptions. Test procedures and more recent test results were reviewed against design basis documents to verify that acceptance criteria for tested parameters were supported by calculations or other engineering documents and that individual tests and/or analyses validated component operation under accident/event conditions. Vendor documents, system health reports, preventive and corrective maintenance history, and corrective action system documents were reviewed in order to verify that potential degradation was monitored or prevented and the component replacement was consistent with in service/equipment qualification life.

b. Findings

No findings of significance were identified.

.2.9 1NV872A, Standby M/U Pump Filter Outlet Motor-Operated Valve

a. Inspection Scope

The inspectors reviewed the plant TS, UFSAR, DBDs and associated system lesson plans to establish an overall understanding of the design bases of the component. Design calculations (i.e., operating parameters and MOV calculations) and site testing procedures were reviewed against these bases to verify design assumptions have been appropriately translated into these documents. The inspector reviewed the calculations for the degraded voltage at the MOV terminals, to ensure the proper voltage was utilized in the team's review of MOV torque calculations. The team requested and reviewed system modifications over the life of the component to verify that the subject modifications did not serve to degrade the component's performance capability and were appropriately incorporated into relevant drawings and procedures. A component walkdown was conducted to verify that the installed configuration would support design basis function under accident/event conditions and have been maintained to be consistent with design assumptions. Test procedures and more recent test results were

reviewed against design basis documents to verify that acceptance criteria for tested parameters were supported by calculations or other engineering documents and that individual tests and/or analyses validated component operation under accident/event conditions. Vendor documentation, system health reports, preventive and corrective maintenance history, and corrective action system documents were reviewed in order to verify that potential degradation was monitored or prevented and the component replacement was consistent with in service/equipment qualification life.

b. Findings

No findings of significance were identified.

.2.10 1NV813, ND Pump Discharge to NI Pump Suction Check Valve

a. Inspection Scope

The inspectors reviewed the plant TS, UFSAR, DBDs and associated system lesson plans to establish an overall understanding of the design bases of the component. Site procedures were reviewed against these bases to verify design assumptions have been appropriately translated into these documents. A component walkdown was conducted to verify that the installed configuration would support design basis function under accident/event conditions and had been maintained to be consistent with design assumptions. External event analyses were reviewed against design specifications and requirements in order to verify that the equipment was adequately protected. Test procedures and more recent test results were reviewed against design basis documents to verify that acceptance criteria for tested parameters were supported by calculations or other engineering documents and that individual tests and/or analyses validated component operation under accident/event conditions. Vendor documentation, system health reports, preventive and corrective maintenance history, and corrective action system documents were reviewed in order to verify that potential degradation was monitored or prevented and the component replacement was consistent with in service/equipment qualification life.

b. Findings

No findings of significance were identified.

.2.11 1WL850, CA Pump Room Sump Discharge Header Check Valve

a. Inspection Scope

The inspectors reviewed the plant TS, UFSAR, DBDs and associated system lesson plans to establish an overall understanding of the design bases of the component. Design calculations, site testing procedures and vendor documentation were reviewed against these bases to verify design assumptions have been appropriately translated into these documents. The team requested and reviewed system modifications over the life of the component to verify that the subject modifications did not serve to degrade the component's performance capability and were appropriately incorporated into relevant

drawings and procedures. A component walkdown was conducted to verify that the installed configuration would support design basis function under accident/event conditions and have been maintained to be consistent with design assumptions. Test procedures and more recent test results were reviewed against design basis documents to verify that acceptance criteria for tested parameters were supported by calculations or other engineering documents and that individual tests and/or analyses validated component operation under accident/event conditions. System health reports, preventive and corrective maintenance history, and corrective action system documents were reviewed in order to verify that potential degradation was monitored or prevented and the component replacement was consistent with in service/equipment qualification life.

b. Findings

No findings of significance were identified.

.2.12 2ETA, 4160VAC Essential Power Switchgear

a. Inspection Scope

The inspectors reviewed the plant TS, UFSAR, DBDs and associated system lesson plans to establish an overall understanding of the design bases of the component. Voltage and short circuit calculations, as well as switchgear test, maintenance and operational procedures were reviewed to verify that design bases and design assumptions have been appropriately translated into design calculations and procedures. Testing procedures and recent results were reviewed to verify that acceptance criteria for tested parameters were supported by calculations or other engineering documents to ensure that design and licensing bases were met and to verify that individual tests and/or analyses validated component operation under accident/event conditions. The inspectors conducted a walkdown of the switchgear, reviewed vendor manuals and construction drawings, and performed alignment verifications to verify that the component's installed configuration would support its design basis function under accident/event conditions and that the equipment was properly protected. Control wiring diagrams and DC loading calculations were reviewed to verify that component inputs and outputs were suitable for application and would be acceptable under accident/event conditions. System health reports, component maintenance history and licensee corrective action program reports were reviewed to verify that potential degradation was monitored or prevented and the component replacement was consistent with in service/equipment qualification life. Environmental qualification documents and procurement specifications were reviewed to verify that equipment qualification was suitable for the environment expected under all conditions.

b. Findings

No findings of significance were identified.

.2.13 1ETA06, 1A1 KC Pump Motor Power Supply Breaker

a. Inspection Scope

The inspectors reviewed the plant TS, UFSAR, DBDs and associated system lesson plans to establish an overall understanding of the design bases of the component. Coordination and motor starting curves were reviewed, along with short circuit calculations, and maintenance and testing procedures, to verify that design bases and design assumptions have been appropriately translated into design calculations and procedures. Control wiring diagrams and DC loading calculations were reviewed to verify that component inputs and outputs were suitable for application and would be acceptable under accident/event conditions. System health reports, component maintenance history and licensee corrective action program reports were reviewed to verify that potential degradation was monitored or prevented and the component replacement was consistent with in service/equipment qualification life. Environmental qualification documents and procurement specifications were reviewed to verify that equipment qualification was suitable for the environment expected under all conditions.

b. Findings

No findings of significance were identified.

.2.14 1EBA, 1A Essential Battery Bank

a. Inspection Scope

The inspectors reviewed the plant TS, UFSAR, DBDs and associated system lesson plans to establish an overall understanding of the design bases of the component. Battery sizing, loading, and voltage calculations were reviewed, as were maintenance and operational procedures, in order to verify that design bases and design assumptions have been appropriately translated into design calculations and procedures. Test procedures and recent testing results were reviewed in order to verify that acceptance criteria for tested parameters were supported by calculations or other engineering documents to ensure that design and licensing bases were met and that individual tests and or analyses validated component operation under accident/event conditions. Battery room temperature evaluations were reviewed to verify that the equipment qualification was suitable for the environment expected under all conditions. The inspectors conducted a walkdown of the batteries and their associated chargers, reviewed vendor manuals and construction drawings, and performed focused field inspections to verify that the component's installed configuration would support its design basis function under accident/event conditions and that the equipment was properly protected. Interviews with system engineers and maintenance personnel were conducted, system health reports, component maintenance history and licensee corrective action program reports were reviewed to verify that potential degradation was monitored or prevented and the component replacement was consistent with in service/equipment qualification life.

b. Findings

No findings of significance were identified.

.2.15 Standby Shutdown Facility (SSF) Aux Diesel

a. Inspection Scope

The inspectors reviewed the plant TS, UFSAR, DBDs and associated system lesson plans to establish an overall understanding of the design bases of the component. Loading, voltage drop, and short circuit calculations were reviewed, as were maintenance and operational procedures, in order to verify that design bases and design assumptions have been appropriately translated into design calculations and procedures. Coordination capability was not specifically addressed. Test procedures and recent testing results were reviewed in order to verify that acceptance criteria for tested parameters were supported by calculations or other engineering documents to ensure that design and licensing bases were met and that individual tests and or analyses validated component operation under accident/event conditions. The inspectors conducted a walkdown of the engine and associated support systems and distribution, reviewed vendor manuals and construction drawings, and performed focused field inspections to verify that the component's installed configuration would support its design basis function under accident/event conditions and that the equipment was properly protected. Interviews with system engineers and maintenance personnel were conducted, system health reports, component maintenance history and licensee corrective action program reports were reviewed to verify that potential degradation was monitored or prevented and the component replacement was consistent with in service/equipment qualification life.

b. Findings

No findings of significance were identified.

.2.16 EHM, Hydrogen Mitigation System

a. Inspection Scope

The inspectors reviewed the plant TS, UFSAR, DBDs and associated system lesson plans to establish an overall understanding of the design bases of the component. System one line diagrams and control circuit drawings were reviewed to develop an understanding of system architecture. Test procedures and recent testing results were reviewed in order to verify that acceptance criteria for tested parameters were supported by calculations or other engineering documents to ensure that design and licensing bases were met and that individual tests and or analyses validated component operation under accident/event conditions. The inspectors conducted a walkdown of the system, reviewed vendor manuals and construction drawings, and performed focused field inspections to verify that the component's installed configuration would support its design basis function under accident/event conditions and that the equipment was properly protected. Interviews with system engineers and maintenance personnel were

conducted, system health reports, component maintenance history and licensee corrective action program reports were reviewed to verify that potential degradation was monitored or prevented and the component replacement was consistent with in service/equipment qualification life.

b. Findings

No findings of significance were identified.

.2.17 1NC31B, Unit 1 Pressurizer PORV Isolation

a. Inspection Scope

The inspectors reviewed the plant TS, UFSAR, DBDs and associated system lesson plans to establish an overall understanding of the design bases of the component. System one line diagrams and control circuit drawings were reviewed to develop an understanding of system architecture. Test procedures and recent testing results were reviewed in order to verify that acceptance criteria for tested parameters were supported by calculations or other engineering documents to ensure that design and licensing bases were met and that individual tests and or analyses validated component operation under accident/event conditions. The inspectors conducted a walkdown of the system, reviewed vendor manuals and construction drawings, and performed focused field inspections to verify that the component's installed configuration would support its design basis function under accident/event conditions and that the equipment was properly protected. Interviews with system engineers and maintenance personnel were conducted, system health reports, component maintenance history and licensee corrective action program reports were reviewed to verify that potential degradation was monitored or prevented and the component replacement was consistent with in service/equipment qualification life.

b. Findings

No findings of significance were identified.

.2.18 1NDPG5040/5050, ND Pump Minimum Flow

a. Inspection Scope

The inspectors reviewed the plant TS, UFSAR, DBDs and associated system lesson plans to establish an overall understanding of the design bases of the component. Instrument control drawings, setpoint and loop uncertainty calculations were reviewed to verify that design bases and design assumptions have been appropriately translated. Instrument modifications were reviewed to verify that the performance capability of the component had not been degraded. Calibration procedures and testing results were reviewed to verify that acceptance criteria for tested parameters were supported by calculations or other engineering documents and that individual tests and or analyses validated component operation under accident/event conditions. The inspectors conducted a walkdown of the instrument, reviewed vendor manuals and construction

drawings, and performed alignment verifications to verify that the component's installed configuration would support its design basis function under accident/event conditions and that the equipment was properly protected. Interviews with system engineers and maintenance personnel were conducted, system health reports, component maintenance history and licensee corrective action program reports were reviewed to verify that potential degradation was monitored or prevented and the component replacement was consistent with in service/equipment qualification life.

b. Findings

No findings of significance were identified.

.2.19 1NVLT5760/5761, Volume Control Tank Level

a. Inspection Scope

The inspectors reviewed the plant TS, UFSAR, DBDs and associated system lesson plans to establish an overall understanding of the design bases of the component. Instrument control drawings, setpoint and loop uncertainty calculations were reviewed to verify that design bases and design assumptions have been appropriately translated. Instrument modifications were reviewed to verify that the performance capability of the component had not been degraded. Calibration procedures and testing results were reviewed to verify that acceptance criteria for tested parameters were supported by calculations or other engineering documents and that individual tests and or analyses validated component operation under accident/event conditions. The inspectors conducted a walkdown of the instrument, reviewed vendor manuals and construction drawings, and performed alignment verifications to verify that the component's installed configuration would support its design basis function under accident/event conditions and that the equipment was properly protected. Interviews with system engineers and maintenance personnel were conducted, system health reports, component maintenance history and licensee corrective action program reports were reviewed to verify that potential degradation was monitored or prevented and the component replacement was consistent with in service/equipment qualification life.

b. Findings

No findings of significance were identified.

.3 Review of Low Margin Operator Actions

a. Inspection Scope

The team performed a margin assessment and detailed review of five risk significant and time critical operator actions. Where possible, margins were determined by the review of the assumed design basis and UFSAR response times and performance times documented by job performance measures (JPMs). For the selected components and operator actions, the team performed an assessment of the Emergency Procedures (EPs), Abnormal Procedures (APs), control room alarm response procedures, and other

operations procedures to determine the adequacy of the procedures and availability of equipment required to complete the actions. Operator actions were observed on the plant simulator and during plant walk downs.

The following operator actions were observed on the licensee's operator training simulator:

- EP actions to establish high pressure recirculation flow per EP/1/A/5000/ES-1.3, Transfer to Cold Leg Recirculation
- EP actions to energize hydrogen igniters per EP/1/A/5000/E-0, Reactor Trip or Safety Injection
- EP actions to recognize and close the block valve in the event of a stuck open pressurizer PORV per EP/1/A/5000/E-0, Reactor Trip or Safety Injection
- Recover from a loss of nuclear service water (RN) due to the failure of an RN pump discharge valve to open per OP/1/A/6100/010M, Panel 1AD-12, A/1, RN Pump A Flow Hi/Lo and OP/0/A/6400/006C, Nuclear Service Water System.

Additionally, the team walked down, "table-topped" and investigated the following operational scenario:

- AP actions to align back-up cooling to the 1A NV pump per AP/1/A/5500/021, Loss of Component Cooling, Enclosure 4

b. Findings

No findings of significance were identified.

.4 Review of Industry Operating Experience

a. Inspection Scope

The team reviewed selected operating experience issues that had occurred at domestic and foreign nuclear facilities for applicability at the Catawba Nuclear Plant. The team performed an independent applicability review for issues that were identified as applicable to the Catawba Nuclear Plant and were selected for a detailed review. The issues that received a detailed review by the team included:

- IN 86-37, Degradation of Station Batteries
- IN 06-15, Vibration-Induced Degradation and Failure of Safety-Related Valves
- IN 07-05, Vertical Deep Draft Pump Shaft and Coupling Failures

b. Findings

No findings of significance were identified.

4. OTHER ACTIVITIES

4OA6 Meetings, Including Exit

On August 27, 2009, the team presented the inspection results to Mr. Tom Ray and other members of the licensee staff. A re-exit was conducted by telephone on October 15, 2009, with Mr. Randy Hart and other members of the licensee staff, following the successful isochronous testing of your standby shutdown facility (SSF) emergency diesel generator and the team's review of circumstances surrounding your SSF coordination calculations. No proprietary information was reviewed as part of the inspection.

ATTACHMENT: SUPPLEMENTAL INFORMATION

Enclosure

SUPPLEMENTAL INFORMATION

KEY POINTS OF CONTACT

Licensee personnel:

T. Brooks, Operations Requalification Supervisor
W. Smith, Operations Instructor
R. Hart, Licensing Manager
T. Ray, Engineering Manager
M. Perry, Power Supervisor, RES

NRC personnel

A. Sabich, Former Senior Resident Inspector
A. Hutto, Senior Resident Inspector

LIST OF ITEMS OPENED, CLOSED AND DISCUSSED

Opened and Closed

05000413, 414/2009006-01	NCV	Failure to monitor the turbine-driven auxiliary feedwater pump sump valves for units 1 and 2 (Section 1R21.2.5)
--------------------------	-----	---

LIST OF DOCUMENTS REVIEWED

Licensing Documents

TS, Current
UFSAR, Current
SER and Supplements

Design Basis Documents (Functional System Descriptions)

CNS-0165.EHM-00-0001, **Error! Reference source not found.****Error! Reference source not found.**, Rev. 8
CNS-115.01-EPC-0001, 4.16KV Essential Auxiliary Power System (EPC) and Class 1E DG Protective Relaying and Metering System (ERN), Rev. 9
CNS-1554.NV-00-0001 Chemical and Volume Control (NV) System, Rev. 36
CNS-1560.SS-00-0001, SSF, Standby Shutdown Facility Aux Diesel System, Rev. 25
CNS-1561.ND-00-0001, Residual Heat Removal (ND) System, Rev. 29
CNS-1562.NI-00-0001, Design basis Specification for Safety Injection System, Rev. 39
CNS-1565.WL-00-0001 Liquid Waste System, Rev. 34, 04/25/2009
CNS-1573.KC-00-0001, Design Basis Specification for the Component Cooling System (KC), Rev. 34

CNS-1574.RN-00-0001, Nuclear Service Water System (RN), Rev. 52
 CNS-1592.CA-00-0001, Auxiliary Feedwater (CA) System, Rev. 37
 CNS-1605.VI-00-0001, Instrument Air (VI) System, Rev. 21

Drawings

CN-1499-CA.07-00, Instrument Detail Motor Driven Auxiliary Feedwater Pump to Steam Generator Flow Control, Rev. 11
 CN-1554-1.6, Flow Diagram of Chemical and Volume Control System (NV), Rev. 20
 CN-1499-ND.01.04-01, Catawba Nuclear Station Unit 1 Instrument Location auxiliary Building EL. 543'-0", Rev. 86
 CN-1499-ND.01-00, Instrument detail RHR Pump Minimum Flow Control, Rev. 8
 CN-1550-1.0, Symbols for Diagrams, Rev. 23
 CN-1550-1.1, Symbols for Diagrams, Rev. 14
 CN-1550-2.0, Symbols for Diagrams, Rev. 14
 CN-1553-1.1, Flow Diagram of Reactor Coolant System (NC), Rev. 21
 CN-1554-1.7, Flow Diagram of Chemical and Volume Control System (NV), Rev. 28
 CN-1554-1.8, Flow Diagram of Chemical & Volume Control System(NV), Rev.8, 06/19/07
 CN-1561-1.0, Flow Diagram of Residual Heat Removal System (ND), Rev. 30
 CN-1561-1.1, Flow Diagram of Residual Heat Removal System (ND), Rev. 24
 CN-1562-1.2, Flow Diagram of Safety Injection System (NI), Rev. 30
 CN-1562-1.3, Flow Diagram of Safety Injection System (NI), Rev. 16
 CN-1565-2.2, Liquid Radwaste System Flow Diagram, Rev.36, 01/30/08
 CN-1571-1.0, Flow Diagram of Refueling Water System (FW), Rev. 29
 CN-1573-2.2, Flow Diagram of Component Cooling System (KC), Rev. 7
 CN-1574-1.0, Flow Diagram of Nuclear Service Water System (RN), Rev. 52
 CN-1574-1.2, Flow Diagram of Nuclear Service Water System (RN), Rev. 49
 CN-1601-2.1, Flow Diagram of Drinking Water System (YD), Rev. 27
 CN-1601-2.2, Flow Diagram of Drinking Water System (YD), Rev. 6
 CN-1601-2.3, Flow Diagram of Drinking Water System (YD), Rev. 22
 CN-1601-2.4, Flow Diagram of Drinking Water System (YD), Rev. 9
 CN-1703-03.24, One Line Diagram, 600V Non Essential Load Center #1SLXG Standby Shutdown facility, Rev. 3
 CN-1703-08.01, Three Line Diagram, 250/125VDC Aux. Power System (ETM) Standby Shutdown, Rev. 13
 CN-1703-08.02, One Line Diagram, 250/125VDC and 120VAC Aux. Power System/ETM and ETL, Rev. 15
 CN-1938-01.01, Computer Cable Routing Outdoor Area General Plan, Rev. 64
 CN-1938-06.01, Computer Cable Routing Outdoor Area Sections & Detail, Rev. 9
 CN-2499-CA.07-00, Instrument Detail Motor Driven Auxiliary Feedwater Pump to Steam Generator Flow Control, Rev. 9
 CN-2554-1.6, Flow Diagram of Chemical and Volume Control System (NV), Rev. 15
 CN-2554-1.7, Flow Diagram of Chemical and Volume Control System (NV), Rev. 19
 CN-2561-1.0, Flow Diagram of Residual Heat Removal System (ND), Rev. 33
 CN-2561-1.1, Flow Diagram of Residual Heat Removal System (ND), Rev. 24
 CN-2562-1.2, Flow Diagram of Safety Injection System (NI), Rev. 30
 CN-2562-1.3, Flow Diagram of Safety Injection System (NI), Rev. 24

CN-2571-1.0, Flow Diagram of Refueling Water System (FW), Rev. 23
 CN-2573-1.0, Flow Diagram of Component Cooling (KC) System, Rev. 24
 CN-2573-1.1, Flow Diagram of Component Cooling (KC) System, Rev. 15
 CN-2573-1.2, Flow Diagram of Component Cooling (KC) System, Rev. 13
 CN-2573-1.3, Flow Diagram of Component Cooling (KC) System, Rev. 11
 CN-2573-1.4, Flow Diagram of Component Cooling (KC) System, Rev. 12
 CN-2573-1.5, Flow Diagram of Component Cooling (KC) System, Rev. 11
 CN-2573-1.7, Flow Diagram of Component Cooling (KC) System, Rev. 12
 CN-2573-2.0, Flow Diagram of Component Cooling (KC) System, Rev. 7
 CN-2573-2.1, Flow Diagram of Component Cooling (KC) System, Rev. 7
 CN-2573-2.2, Flow Diagram of Component Cooling (KC) System, Rev. 4
 CN-2573-2.3, Flow Diagram of Component Cooling (KC) System, Rev. 6
 CN-2592-1.1, Flow Diagram of Auxiliary Feedwater System (CA), Rev. 30
 CN-2605-1.12, Flow Diagram of Instrument Air System (VI), Rev. 14
 CN-2609-1.0, Flow Diagram of Diesel Generator Engine Cooling Water System (KD), Rev. 16
 CNEE-0111-02.39, Elementary Diagram 600V Non Essential Load Center No. 1SLXG, compt
 4A, 4B incoming bkr., P.T. & Synch. Ckts., Rev. 6
 CNEE-0111-02.43, Elementary Diagram 600V Non-Essential Load Center No. 1SLXG, Cpt.5B
 Diesel Generator "S", Fdr. Bkr., Rev. 7
 CNEE-0111-02.44, Elementary Diagram 600V Non-Essential Load Center No. 1SLXG, Cpt.5B
 Diesel Generator "S", Fdr. Bkr., Rev. 6
 CNEE-01114-00.10, Elementary Diagram Diesel Generator No. 1A Load sequencer (Part 8)
 committed & accelerated sequence circuits, Rev.10
 CNEE-0115-01.06, Elementary diagram 4160V switchgear 2ETA Unit 6 Component Cooling
 Water PMP MTR. 1A1, Rev. 8
 CNEE-0115-01.13, Elementary Diagram Nuclear Service Water System (RN) RN Pump B
 Discharge Isolation Valve 1RN038B, Rev. 11
 CNEE-0115-01.20, Elementary Diagram 4160V Switchgear 1ETA Breaker Failure, Mode
 Selector and Degraded Bus Voltage Circuit, Rev. 17
 CNEE-0115-01.34, Elementary Diagram 4160V Switchgear Unit #14 Nuclear Service Water
 Pump Motor 1B (1PMTR0156), Rev. 8
 CNEE-0115-01.40, Elementary Diagram 4160V Switchgear 1ETB Breaker Failure, Mode
 Selector and Degraded Bus Voltage Circuit, Rev. 16
 CNEE-0115-01.41, Elementary Diagram 4KV Switchgear 1ETA and 1ETB Breaker Internal
 Controls, Rev, 0
 CNEE-0141-01.04, Elementary Diagram Residual Heat Removal System (ND) ND pump 1A
 Miniflow Valve 1ND025A, Rev. 9
 CNEE-0141-01.10, Elementary Diagram Residual Heat Removal System (ND) ND pump 1B
 Miniflow Valve 1ND059B, Rev. 8
 CNEE-0144-01.01, Elementary Diagram SSF Diesel Controls and Instrumentation Sys (EQD)
 Misc. Diesel Controls and Alarms, Rev. 10
 CNEE-0150-01.10, Elementary Diagram Reactor Coolant System (NC) PZR Power Operated
 Relief Isolation Valve 1NC031B, Rev. 15
 CNEE-0151-01.31, Elementary Diagram Safety Injection System (NI) Containment Sump Line
 1A Isolation Valve 1NI185A, Rev. 16
 CNEE-0157-03.13, Elementary Diagram Chemical & Volume Control Sys (NV) Solenoid Valves
 – Aux. Bldg. 1NV153A, 1NV172A, Rev. 13

CNEE-0160-02.30-02, WL Solenoid Valves 1WL847&1WL848, Rev.7, 01/16/85
 CNEE-0165-02.01, Elementary Diagram Hydrogen Mitigation System (EHM) Ignitor Box Group
 "A" Alternate Source, Rev. 6
 CNEE-0165-02.02, Elementary Diagram Hydrogen Mitigation System (EHM) Ignitor Box Group
 "B" Normal Source, Rev. 5
 CNEE-0215-01.03-01, Elementary diagram 4160V switchgear 2ETA Unit 3 NOR. INC. BKR.
 Transf. 2ATC, Rev. 5
 CNEE-0215-01.04-01, Elementary diagram 4160V switchgear 2ETA Unit 4 STD-BY INC. BKR.
 Transf. SATA, Rev. 5
 CNEE-0215-01.06, Elementary diagram 4160V switchgear 2ETA Unit 6 Component Cooling
 Water PMP MTR. 2A1, Rev. 5
 CNEE-0215-01.13, Elementary diagram 4160V switchgear 2ETA Unit 13 Auxiliary Feedwater
 PMP MTR. 2A, Rev. 5
 CNEE-0215-01.18-01, Elementary Diagram 4160V Switchgear 2ETA Unit 18 Diesel Generator
 A2, Rev. 7
 CNEE-0215-01.20, Elementary Diagram 4160V Switchgear 2ETA Breaker Failure, Mode
 Selector and Degraded Bus Voltage Circuit, Rev. 10
 CNEE-0215-01.40, Elementary Diagram 4160V Switchgear 2ETB Breaker Failure, Mode
 Selector and Degraded Bus Voltage Circuit, Rev. 11
 CNEE-0215-01.41, Elementary Diagram 4160V Switchgear 2ETA and 2ETB Breaker Internal
 Controls, Rev. 0
 CNEE-0241-01.01, Elementary Diagram (ND) Residual Heat Removal System NC Loop 2
 Supply to ND Train 2B Isolation Valve 2 ND001B, Rev. 13
 CNEE-0241-01.02, Elementary Diagram (ND) Residual Heat Removal System NC Loop 2
 Supply to ND Train 2A Isolation Valve 2 ND002A, Rev. 14
 CNEE-0241-01.02-01, Elementary Diagram (ND) Residual Heat Removal System NC Loop 2
 To ND Train 2A Isolation Valve 2 ND002A, Rev. 8
 CNEE-0241-01.05, Elementary Diagram Residual Heat Removal System (ND) Supply to NV &
 2A NI Pumps Valve 2 ND028A, Rev. 7
 CNEE-0251-01.07, Elementary Diagram Residual Heat Removal System (ND) Supply to Safety
 Injection Sys (NI) Pumps 2B Valve 2 NI136B, Rev. 10
 CNEE-0251-01.10, Elementary Diagram Safety Injection System (NI) Safety Injection Pump
 Miniflow Header to F.W. Valve 2NI147B, Rev. 7
 CNEE-0251-01.28, Elementary Diagram Safety Injection System (NI) Safety Injection Pump 2B
 Miniflow Line Isolation Valve 2NI144A, Rev. 4
 CNEE-0255-02.08, Elementary Diagram Refueling Water System (FW) ND Pump 2A Suction
 From FWST Valve 2 FW027A, Rev. 10
 CNEE-0259-01.05, Elementary Diagram Containment Spray System (NS) Safety Injection
 Spray Isolation Valve 2NS043A, Rev. 6
 CNEE-0265-02.01, Elementary Diagram Hydrogen Mitigation System (EHM) Ignitor Box Group
 "A" Normal Source, Rev. 7
 CNEE-0265-02.01-01, Elementary Diagram Hydrogen Mitigation System (EHM) Ignitor Box
 Group "A" Alternate Source, Rev. 0
 CN-FSAR-FIG.08-001, Onsite Power System, Rev. 2
 CN-FSAR-FIG.08-021, Essential and Blackout Auxiliary Power Systems, Rev. 3
 CN-FSAR-FIG.08-19, Non-Class 1E AC Power Systems, Rev. 1
 CN-FSAR-FIG.6-136.01, ECCS Process Flow Diagram (NV) System, Rev. 0

CN-FSAR-FIG.6-136.02, ECCS Process Flow Diagram (NI) System, Rev. 0
 CN-FSAR-FIG.6-136.03, ECCS Process Flow Diagram (ND) System, Rev. 0
 CNM-1201.05-0282, Service water Pump Vendor Manual, 4/15/07
 CNM-1201.05-0555 001, Bingham Type "VTM" Pump Outline, Rev. DF
 CNM-1201.05-299, Nuclear Service Water Pump Certified Performance Test Curve, 5/8/79
 CNM-1205.00-0152 001, Valve Assembly, 8 Inch, 300 lb, Swing Check Valve, Rev. A
 CNM-1205.00-0207 001, Valve Assembly, 8 Inch, 600 lb, Gate Valve, 11/6/07
 CNM-1205-00-1652, Borg-Warner Seismic Report NSR 76130, 1/27/83
 CNM-1301.00-0237 006, Diesel Generator Instruction Manual, 12/8/98
 CNM-1301.00-0285, Seismic Qualification of Transamerica Delaval Diesel Generator Set,
 10/25/82
 CNM-1301.02-0016, sh 1, DC schematics 700kW, 346/600V, 60 Hz Generator Control Panel,
 Rev. D4
 CNM-1301.02-0016, sh 2, A.C. Elementary Diagram, Rev. D5
 CNM-2201.05-0045, MDAFW Pump Curves Document, Rev.0, 05/14/80
 CNM-2201.05-0046, MDAFW Pump Curve Data Sheet, Rev.0, 05/14/80
 CNSF-1574-RN.01, Summary Flow Diagram, Nuclear Service Water System (RN), Rev. 6
 CNSF-2592-CA.01 Auxiliary Feedwater System Flow Diagram, Rev.5, 10/20/01
 CNTC-2573-KC.P001-01, Component Cooling Pumps Test Acceptance Criteria, Rev. 3
 CNTC-2573-KC.P002-01, KC Minimum Flow Lines, Rev. 2
 CNTC-2573-KC.P003-01, Component Cooling Pump Matching, Rev 0
 CNTC-2573-KC.S001-01, KC System Nonessential Header Flow Balance, Rev 0
 CNTC-2573-KC.S001-02, KC System Nonessential Header Flow Balance, Rev 3
 CNTC-2592-CA-V001-02 CA Test Acceptance Criteria, Rev.2, 03/26/93
 Fisher Controls Drawing 54A7671, 657-ET Diaphragm Actuated Control Valve, Rev. DJ

Corrective Action Documents (PIPs)

C-03-01608, KD HX 2B ECT identified crack-like indications on 8 tubes, 3/13/03
 C-03-04625, RN pump 1A UBOC flow long term declining trend, 8/20/03
 C-04-01569, KD HX trends indicate potential degraded thermal performance, 3/31/04
 C-07-01547 CA Discharge MOV Failure to Re-Open after Testing, 05/01/2007
 C-07-02443, 2A1 KC pump Outboard seal though has a 65 dpm leak, 05/16/07
 C-07-02475, Problems were found with breaker 1ETB14 in the performance of its PM on
 17MAY07 by crew 462, 05/17/2007
 C-07-04311, 2A1 KC Pump Outboard Bearing Seal Leakage is at 60 DPM, 08/19/07
 C-07-06881, Observation of data for SWGDT-B pressure, 11/10/2007
 C-07-06890, Discovered loose test tee on 2NVLT5761 (VCT level), 11/11/2007
 C-07-07610, KC pump 2A1 outboard seal leak rate observed as approx 50 dpm, 12/22/07
 C-08-00284, KC pump 2A1 outboard seal leakage is transitioning from drops per minute and
 approaching a small steady stream, 02/18/2008
 C-08-00356, Leakage on 2A1 KC pump OB bearing has doubled since last night shift from
 about 88 dpm to about 190 dpm, 01/20/08
 C-08-00487, 2B NV pump balance line pressure above rounds limit of 80 psig, 01/26/2008
 C-08-00562, Acceptance Criteria not met, 2B ND pump Flow reading was high, 01/31/2008
 C-08-00880, 1ETA 18 Breaker Racked in Indication failed to operate when OPS racked breaker
 into cubicle, 02/13/2008

- C-08-01465, Found during performance of Unit 1, Channel 1 18 month Channel Calibration, 03/11/2008
- C-08-03245, Black substance/coating found in water box & on tube sheet of 1A KD HX, 5/26/08
- C-08-03729, Perform cal under W/O 1723634, 06/12/2008
- C-08-04289, Unplanned entry into Tech Specs 3.7.8 for loss of 1B RN pump, 7/12/08
- C-08-04393, RN flow to B YC chiller exceeded Hi alarm setpoint of 2000 gpm for approximately 2 minutes while throttling flow for 1B RN Head Curve Testing. Maximum flow per OAC was 2049.1 gpm, 07/18/2008
- C-08-04399, Need to establish new baseline values for 1B RN pump, 7/19/08
- C-08-04691, Unit 1 VCT level indication is failing low, 08/04/2008
- C-08-04906, Invl5761 remote bellows isolation valves and bellows not labeled, 08/14/2008
- C-08-05074, During performance of 2A ND IWP the 2A ND pump failed to start, 08/22/2008
- C-08-05137, Breaker 1ETA 17 failed as found minimum DC voltage testing for a close operation, 08/26/2008
- C-08-05147, 1A RN pump motor vibration is noticeable different than the other pumps when in service. NLO's need some INFO as to how much vibration is acceptable when performing rounds, 08/27/2008
- C-08-05937, The Catawba Vital I&C Battery system is nearing the end of its available load growth capacity for future load additions, 10/06/2008
- C-08-06130, Results of RN Lake Discharge Pipe UT Examination, 10/16/08
- C-08-06329, 1B2 KC Pump Outboard seal leakage >30gpm upon pump start, 10/29/2008
- C-08-06396, Unit 2 dilutions and blended makeups show unexpected VCT level changes, 11/02/2008
- C-08-06840, the capacity margin for loads growth seems to run out on the 125 Volts DC Vital I&C Battery System, 12/02/2008
- C-09-01380, 2 ETA-2 Breaker has cracked arc chutes, discovered during PM inspection, 03/08/2009
- C-09-01902, PT/2/A/4400/003 A KC Train 2A Performance Test was aborted due to no local flow indication on 2A1 KC Pump start with 2KC-6 "2A1 KC Pump Discharge" throttle 90% CLOSED per procedure, 3/24/2009
- C-09-01903, Performed IWP on 2A1 KC pump after pump maintenance. The data taken is considered new baseline values, 03/22/2009
- C-09-02770, Excessive noise on suction of 2A1 KC Pump. 04/22/2009
- C-09-03784, The inboard oil bubbler on the 2A1 KC Pump is discolored and appears milky, 06/21/2009
- C-09-03910, KC pump 2B1 4160V feeder has damaged armor cable with exposed insulation, 06/27/2009
- C-09-04390 WL Sump Pump Check Valve Inservice Test & PM Changes, 07/23/2009
- C-09-04844, Determine if any operator actions are credited to control AFW flow during LOOP
- C-09-04847- SSF Load and Voltage Calculation, minor clarifications and elimination of inconsistencies -CDBI items 266, and 369, 8/14/09
- C-09-05020 1WL 848 AOV Failed to stroke closed during PT, 08/21/2009
- C-09-05061- (SSF Load Center Breaker Coordination and Diesel Generator Relay Setting Calculation) - CDBI item 367, 8/25/09
- C-09-05073- SSF D/G Testing Issue (Load Bank Testing and Power Factor value) -CDBI items 293, 294, 370, and 371, 8/25/09
- C-93-00703, KC Pump Calculation uses incorrect pump performance data, 08/25/1993

C-99-01308, Review of CNC-1223.24-00-0017, CNC-1223.24-00-0018 & CNC-1223.24-00-0019, 4/13/99
 G-06-00154, Busmann – Vendor Notification # 42021. Potential Part 21, 04/04/2006
 G-07-00269, Three Site Response to IN 2007-05, Vertical Deep Draft Pump Shaft and Coupling Failures, 3/22/07
 G-08-00341, IN08-2 Findings Identified during the Component Design Bases Inspections, 04/07/2008
 M-06-3978 Valve Working Group to access IN 06-15, 12/07/06

Completed Surveillances

CNM 1301.02-0061, Full Load Test (Start up test data, SSF D/G, isochronous mode) , dated 3/24/80
 IP/1/A/3170/003 A, 1EHM -PFM Insp of Trn 1A H2 Ignitors, completed 11/10/08, 2/3/09, 3/4/09 and 4/28/09
 OST-1080, Auxiliary Feedwater Pump 1SX-SAB Full Flow completed September 5, 2007
 OST-1214, ESW System Operability Train A Quarterly Interval Modes 1-2-3-4-5-6-Defueled, completed 2/4/08, 2/5/08 2/25/08, 5/3/06, 5/19/07, 6/17/06, 7/27/06, 8/18/07, 9/9/06, 11/10/07, and 12/3/06
 OST-1215, ESW System Operability Train B Quarterly Interval Modes 1-2-3-4-5-6-Defueled, completed 1/17/07, 2/15/08, 3/11/08, 3/17/08, 4/17/07, 5/16/06, 7/6/07, 7/29/06, ; September 24, 2007; October 21, 2006; December 29, 2007
 PT/0/A/4400/022 B, RN Pump IST Comprehensive, 7/18/08
 PT/0/A/4400/022 B, RN Pump IST Quarterly, 1/24/09, 3/29/09 & 6/17/09
 PT/1/A/4200/013 H, NI/NV Check Valve Test, completed 5/26/05 and 5/28/08
 PT/2/A/4200/013 F ND Valve Inservice Test, completed 10/6/07, 4/1/09 and 4/7/09
 PT/2/A/4200/013 G NI Valve Inservice Test, completed 4/1/06, 10/13/07 & 3/28/09
 PT/2/A/4400/003 A, Component Cooling (KC) Train 2A Performance Test completed 2/15/08, 5/09/08, 8/01/08, 10/24/08, 1/16/09, 3/22/09, 5/09/09, 7/03/09
 PT/2/A/4400/06 E, 2A KD Heat Exchanger Heat Capacity Trending 6/96 thru 3/09

Calculations

CNC 1223.23-00-0016, Component Cooling Surge Tank Verification, Rev. 6
 CNC-1205.19-00-0026 GL 89-10 MOV Calculation, NV System: 1(2)NV865A, Rev.5
 CNC-1205.19-00-0153 GL 89-10 MOV Calculation, NV System: 1(2)NV872A, Rev.1
 CNC-1205.41-00-0003, Auxiliary Feedwater Control Valve (1&2CA36, 40, 44, 48, 52, 56, 60, and 64) Accumulator Sizing, Rev. 0
 CNC-1205.41-00-0022, 1(2) CA 040, 044, 056, 060 and 1(2) 036, 048, 052, 064 Actuator Capability Evaluation Supporting Air Operated Valve (AOV) Program, Rev. 0
 CNC-1206.03-00-0001 Flood Levels for Structures Outside of the Reactor Building, Rev.4, 07/15/83
 CNC-1206.03-00-0109, Moderate Energy Spray Interaction Study, NSW Pump House, Rev. 4
 CNC-1210.04-00-0016, RHR Pump Miniflow Control Instrument Loop Accuracy Calculation NDPG5040/5050, Rev. 7
 CNC-1210.04-00-0096, ASME Section XI Inservice Pump Testing Instrumentation Accuracies, Rev. 5

CNC-1210.04-00-0131, VCT PCS Level Instrument Uncertainty, Rev. 0
 CNC-1223.04-00-0041 Parameters for Standby Makeup Pump Filter Outlet Valve, Rev.3,
 12/28/93
 CNC-1223.04-00-0057 Operating Parameters for Valves 1(2)NV-865A
 CNC-1223.04-00-0107, VCT NPSH and Low-Low Level Auto-swap Setpoint, Rev. 0
 CNC-1223.11-00-0011, Design Parameters for RHR Valves 1 & 2 ND 28A, Rev. 6
 CNC-1223.12-00-0036, Operating Parameters for Valves 1(2) NI-136B, Rev. 4
 CNC-1223.12-00-0061, NI and NV Check Valve Test Acceptance Criteria Verification, Rev. 3
 CNC-1223.13-00-0038, Unit 2 CA Condensate Source Vortexing Determination, Rev. 0
 CNC-1223.23-00-0011, Component Cooling System Test Acceptance Criteria, Rev. 17
 CNC-1223.23-00-0022, Component Cooling Heat Load and Flow Requirements, Rev. 11
 CNC-1223.23-00-0033, Supporting Calc for Response to NRC IE Bulletin 88-04, "Potential
 Safety Related Pump Loss" (Component Cooling Pumps), Rev. 13
 CNC-1223.23-00-0041. Evaluation of KC Pump Operation Near Maximum Tested Flow Rates,
 Rev. 1
 CNC-1223.24-00-0027, Flow Distribution Model of the RN System, Rev. 6
 CNC-1223.24-00-0052, Mechanical Design Inputs Calculation for NSM CN-50492/00, Nuclear
 Service Water (RN) System Chemical Treatment, Rev. 1
 CNC-1223.24-00-0058, Effect of RN System Flushing on Operability, Rev. 3
 CNC-1223.24-00-0060, RN Single Supply Header Operation Evaluation
 CNC-1223.24-00-0064, RN Single Supply Header Operation Design Basis Rev. [??]
 CNC-1223.42-00-0013 CA System Test Acceptance Criteria, Rev.0
 CNC-1223.42-00-0014 CA Pumps Mini-Flow Design Verification, Rev.1
 CNC-1223.42-00-0043 Unit 2 System Response to Chp.15 Accidents, Rev.5
 CNC-1223.59-01-0005, RN Flow and Fouling Acceptance Criteria on KD Heat Exchangers,
 Rev. 15
 CNC-1381.05-00-0011, 125VDC Vital Instrumentation and Control Power System Battery and
 Battery Charger Sizing Calculation, Rev. 8
 CNC-1381.05-00-0012, 4160 Volt Essential Auxiliary Power System Switchgear Relay Setting,
 Rev. 14
 CNC-1381.05-00-0014, 4160/600V Essential Load Center Transformer Feeder Relay Settings
 and Essential Load Center Breaker Coordination, Rev. 7
 CNC-1381.05-00-0017, Class 1E Diesel Protective Relaying and Sequence Undervoltage Relay
 Settings, Rev. 15
 CNC-1381.05-00-0108, Verification of Equipment Qualification Under Degraded Conditions,
 Rev. 1
 CNC-1381.05-00-0147, U1/2, 4.16KV Essential Auxiliary Power System (EPC) Diesel-
 Generator (D/G) LOCA/LOOP (Blackout) Loading Analysis, Rev. 10
 CNC-1381.05-00-0149, Vital DC System Voltage Analysis, Rev. 15
 CNC-1381.05-00-0198, Catawba Unit 1, 6.9kV, 4.16kV, 600V Auxiliary Power Systems Safety-
 Related Voltage Analysis, Rev. 9
 CNC-1381.05-00-0199, U2, 6.9kV, 4.16kV & 600V Auxiliary Power System Safety- Related
 Voltage Analysis, Rev. 14
 CNC-1381.05-00-0209, Catawba Unit 1 ETAP Power Station Auxiliary Power System Fault
 Study, Rev. 3
 CNC-1381.05-00-0210, Catawba Unit 2 ETAP Power Station Auxiliary Power System Fault
 Study, Rev. 5

CNC-1381.06-00-0035, 250/125 VDC SSF Aux Power System Battery and Battery Charger Sizing Calc, Rev. V5
 CNC-1381.06-00-0036, Standby Shutdown Facility Load Center Breaker Coordination and Diesel Generator Relay Setting Calculation, Rev. 07
 CNC-1381.06-00-0060, ETAP Power Station Loading/Voltage Calculation For Catawba SSF D/G And SSF Auxiliary Power System, Rev. 3
 CNM 1201.05-0272, Component Cooling Pump Seismic Rpt and Nzl Loads, Rev. 6
 CNM 1205.01-0064.001 Kerotest Instruction Manual, 02/03/87
 CNM 1205.19-0083.001 Rotork Vendor Manual, Rev. D6
 CNM-1205.00-1103 Operation and Maintenance Manual OMM2057, dtd. 03/26/1981
 CNM-1205.00-1498 Seismic Analysis of Motor Operator Globe Valves, Rev.B
 CNTC-2592-CA.V001-03, MPD 2A (Flow to SGs A or B) Test Acceptance Criteria Sheet, Rev. 4

Procedures

AP/0/A/5500/022, Loss of Instrument Air, Rev. 28
 AP/1/A/5500/002, Turbine Generator Trip, Rev. 29
 AP/1/A/5500/003, Load Rejection, Rev. 35
 AP/1/A/5500/009, Rapid Down Power, Rev. 25
 AP/1/A/5500/011, Pressurizer Pressure Anomalies, Rev. 020
 AP/1/A/5500/020, Loss of Nuclear Service Water, Rev. 36
 AP/1/A/5500/021, Loss of Component Cooling, Rev. 35
 AP/2/A/5500/007, Loss of Normal Power, Rev. 54
 EDM 101, Engineering Calculations/Analyses, Rev. 14
 EDM 601, Engineering Change, Rev. 9
 EP/1/A/5000/E-0, Reactor Trip or Safety Injection, Rev. 34
 EP/1/A/5000/E-0, Reactor Trip or Safety Injection, Rev. 35
 EP/1/A/5000/ES-1.3, Transfer to Cold Leg Recirculation, Rev. 21
 EP/1/A/5000/F-0, Critical Safety Function Status Trees – Containment, Rev. 7
 IP/0/A/3816/010, Barton Model 580 and 581 DP Switch Calibration, Rev. 29
 IP/0/A/3820/001B, Limitorque Operator Preventive Maintenance, Rev.006
 IP/0/A/4974/021, Procedure for Motor On-Line Testing, Rev. 7
 IP/0/A/4974/032, Induction Motor Inspection and Testing, Rev. 11
 IP/0/B/3817/013 E, Rosemount Model 3051S (Scalable) Series Transmitters Configuration/Calibration Check and Maintenance Procedure, Rev. 04
 IP/1/A/3144/001 B, Calibration Procedure for ND Miniflow Control Pressure Switches, Rev. 20
 IP/1/B/3222/023 A, Volume Control Tank Level Cabinet 5, Loop 1NVLT5761 (LT-112) Calibration, Rev. 25
 IP/1/B/3222/023 B, Volume Control Tank Level Cabinet 8, Loop 1NVLT5760 (LT-185) Calibration, Rev. 22
 MP/0/A/7150/004 A, Component Cooling Pumps Rotating Element Assembly, Rev. 12
 MP/0/A/7600/038, Borg Warner Bonnet Hung Swing Check Valve Low Pressure, Rev. 17
 MP/0/A/7600/108, Anderson Greenwood Wafer Check Valve Maintenance, Rev. 017
 MP/0/A/7650/002, Lubrication Of Station Equipment, Rev. 25
 MP/0/A/7650/056 D, Diesel Generator Jacket Water Heat Exchanger Corrective Maintenance, Rev. 15
 MP/0/A/7650/166, HX/CH Tube Pull & Replacement, Rev. 4

OP/0/A/6400/006 C, Nuclear Service Water System, Rev. 266
 OP/0/A/6400/006C, Nuclear Service Water System, Rev. 266
 OP/1/A/6100/010G, Panel 1AD-6, A/8, PZR HI PRESS ALERT, Rev. 63
 OP/1/A/6100/010J, Panel 1AD-9, D/8, FWST 2/4 LO LEVEL, Rev. 65
 OP/1/A/6100/010M, Panel 1AD-12, A/1(4), RN Pump A(B) Flow Hi/Lo, Rev. 40
 OP/1/A/6350/005, Change Hold, Alternate AC Power Sources, Rev. 67
 OP/1/A/6550/002, Diesel Generator Operation, Rev. 144
 OP/1/B/6100/009S, Annunciator Response for Standby Shutdown Facility, Rev.022
 OP/1/B/6100/010F, Annunciator Response for Panel 1AD-5, Rev. 053
 OP/1/B/6100/010Y, Annunciator Response for Radiation Monitoring Panel, Rev. 041
 OP/2/A/6100/010M, Panel 2AD-12, A/1(4), RN Pump A(B) Flow Hi/Lo, Rev. 30
 PT/0/A/4200/017 A, Standby Shutdown Facility Diesel Test, Rev. 20
 PT/0/A/4200/019, Standby Shutdown Facility Diesel Generator Operating Parameters, Rev. 4
 PT/0/A/4400/008 B, RN Flow Balance Train B, Rev. 48
 PT/0/B/4450/015 A, Air Quality Periodic Test for the VI System, Rev. 011
 PT/0/B/4450/015 B, Air Quality Periodic Test for the VI System, Rev. 0219
 PT/1/A/4200/001 I, As Found Containment Isolation Valve Leak Rate Test, Rev. 011
 PT/1/A/4200/0013 B, NV Valve Inservice Test, Rev. 034
 PT/1/A/4200/013 H, NI/NV Check Valve Test, Rev. 33
 PT/1/A/4700/020, WL Sump Pump Check Valve Inservice Test, Rev. 010
 PT/1/A/4700/020, WL Sump Pump Check Valve Inservice Test, Rev. 011
 PT/2/A/4200/013 F ND Valve Inservice Test, Rev. 25
 PT/2/A/4200/013 G NI Valve Inservice Test, Rev. 34
 PT/2/A/4200/079, CA Flow Control Valve Air Accumulator Leakage Test, Rev. 8
 PT/2/A/4250/003 A, MDAFW Pump 2A Performance Test, Rev. 045
 PT/2/A/4250/003E, CA System Discharge Control Valve Throttling Procedure, Rev. 35
 PT/2/A/4400/003 A, Component Cooling (KC) Train 2A Performance Test, Rev. 42
 PT/2/A/4400/006 E, KD Heat Exchanger 2A Heat Capacity Test, Rev. 23
 RP/0/A/5000/001, Classification of Emergency, Rev. 020

Work Orders

01792301, 2KC PU A1 : Flush O/B Mechanical Seal With Warm Demin Water, 1/18/2008
 01797121, 2KC PU A1 : Flush O/B Mechanical Seal With Warm Demin Water, 3/17/2008
 01874676, 2KC PU A1- Sample And Change Oil For I/B And O/B Pump Bearings, 6/30/2009
 01736300, MP/0/A/7650/002 Verify proper oil level after pump, dtd 7/3/2007
 0184219301, MP/0/A/7650/002 Verify proper oil level after pump, dtd 5/4/2009
 01703659, 2VC PS 5530 PFM 2CRA-AHU-1 Inst. Calibration, 03/28/2007
 01723634, CE101196, 1NV LT 5761: Replace Channel 1 VCT Level Transmitter, 05/22/2008
 01735109, 1VC PS 5530 PFM 1CRA-AHU-1 Inst. Calibration, 07/31/2007
 01755847, 1RN TE 7690: PERF CHAR Test on Spare Thermocouple Conductor, 08/26/2009
 01804482, 2VC PS 5530 PFM 2CRA-AHU-1 Inst. Calibration, 06/15/2009
 01816772, 2ERN PFM Routine Test 27 relays on 2B D/G, 07/14/2008
 98031306, 2EPC Refurbish Breaker 2ETA-3 (4160 VAC), 09/14/19989
 96098715, 2EPC Insp/Maintenance on 2ETA Bus, 04/02/1997
 98120782, 1EBA Performance Test, 05/03/1999
 98122654, 2EPC SWAP BKR 2ETA-18 W/Refurbed BK, 08/29/2000

98465171, 2EPC PM Breaker 2ETA-13 (2A CA PMP MTR), 02/12/2002
98534825, 2EPC BK ETA-4 PM Breaker, 10/21/2002
98518305, 2EPC PM 2ETA-3, 5, 10, 16 Protective Relays, 03/06/2003
98650069, 1EBA Performance Test, 05/09/2004
98642861, 2EPC BK ETA-3 PM Breaker, 08/30/2004
98656044, 1EPC BK ETA-6 PM Breaker, 05/12/2005
98766017, Perform CAL 1CRA-AHU-1 Instrumentation, 02/13/2006
98717611, 2EPC BK ETA-18 PM Breaker, 04/02/2006
01122453, 1ND PG 5050: CAL ND PMP 1B Miniflow Cont, 08/17/2006
01129815, 1ND PG 5040: CAL ND PMP 1A Miniflow Cont, 08/29/2006
01703997, 2KC PU A1- Perform PM Inspection, 10/16/2006
01700517, 1NV PFM CH CAL VCT LVL (1NVP5760), 10/18/2006
01702387 01, MOV test for 1NI136B, 11/20/06
01720633 01, 1KD HX end bell leak repair, 11/25/06
01707027, 1NV PFM CH CAL VCT LVL (1NVP5761), 04/10/2007
01716114, 1EPL BA EBA PFM Vital Battery Service Test, 05/08/2007
01707459, 1EPC – Routine Test 1ETB SWGR Relays, 05/16/2007
01744979, 1EPC BK ETB-14: PM Breaker, 05/17/2007
01748590, 2EPC BK ETA-13 PM Breaker, 05/31/2007
01735398, 1EPL-VITAL Batt Charger ECA CAP Test, 08/28/2007
01746283, 2KC PU A1- Perform PM Inspection, 10/14/2007
01082722, CE73053; Revise Span for 1NDPG5040, 01/16/2008
01758391, 1ND PG 5050: CAL ND PMP 1B Miniflow Cont, 01/29/2008
01796627, 1EPC BK ETA-18; I/R Breaker T.O.C>, 02/13/2008
01813512, 2ERN PFM Routine Test 27 Relays on 2B D/G, 06/17/2008
01814963, 2ERN PFM Routine Test 27 Relays on 2A D/G, 06/26/2008
01778230, 1NV PFM CH CAL VCT LVL (1NVP5760), 07/14/2008
01818313, 2ERN PFM Routine test 27 relays on 2A D/G, 07/21/2008
01793755, 2KC PU A1- Perform PM Inspection, 7/30/2008
01816612, 2EPC BK ETA-4 PM Breaker, 08/18/2008
01818466, 1EPC BK ETA-17: PM Breaker, 08/26/2008
0173861901 1NV:Replace Optical Isolators(1NV872A), dtd. 9/17/08
01806734, 1NV PFM CH CAL VCT LVL (1NVP5761), 10/01/2008
01837102, Refurbish Spare 5-HK Breaker, 12/10/2008
0183713101, Performed PM per procedure/TAM, dtd. 12/14/2008
01810401, 1EPL BA EBA PFM Vital Battery Service Test, 12/16/2008
01850544, 1EPC BK ETA-6 Swap Breaker W/refurbered BKR, 02/12/2009
01822040, 2EPC BK ETA-2: PM Breaker, 03/08/2009
01820231, 2EPC PM 2ETA-3,5,10,16 Protective Relays, 03/14/2009
01787948, 2KC PU A1: Replace Outboard Mechanical Seal, 3/18/2009
01820443, 2KC PU A1- Perform Outage PM Inspection, 3/21/2009
01820496, 2KC PU A1- Refurbish Pump, 3/21/2009
01857255, Performed AFW PT Acceptance criteria met, dtd. 5/1/2009
01801315, 1ND PG 5050: CAL ND PMP 1B Miniflow Cont, 05/21/2009
01801316, 1ND PG 5040: CAL ND PMP 1A Miniflow Cont, 06/03/2009
01824860, 1NV P5761 Unit 1VCT Level CH 1 Slowly Failing Low, 08/12/2008

Miscellaneous

1B RN Oil Analysis Data, 12/08, 3/09 & 6/09
 1EBA Vendor Test, 06/27/1995
 ASME Section XI Code, 1983 Ed.
 Attachment 1 to 50.59 Evaluation for NSM CN-50492/0, Nuclear Service Water (RN) System
 Chemical Treatment, 10/19/00
 Catawba Check Valve Condition Monitoring Program, 4/29/02
 CNM 1201.05-0273, Component Cooling Water Pumps, Rev D24
 CNM 1205.04-0086.001 I/B Nuclear Safety Related Plug Valves, Rev. 4
 CNM 1225.00-0068.001 Check Valve Vendor Manual
 CNM 2201.05-0031, Component Cooling Pump Certified H/Q Curves, Rev D2
 CNM-1210.00-0039.001, NSSS Precautions, Limitations, and Setpoints, Rev. D49
 CNM-1210.04-0276.001, Technical Manual for Model 580A-0 Differential Pressure Indicating
 Switch, 05/12/1983
 CNM-1210.04-0421.001, Product Manual for Rosemount Model 3051 Smart Pressure
 Transmitter Family, Rev. 0
 CNM-1210.04-0503.001, Rosemount Transmitters models 3051C, 3051T, 1151, and 2088
 Manual, 01/25/1999
 CNM-1312-02-00-0054, ABB Installation/ Maintenance Instructions, Metal-Clad Medium-Voltage
 Power Switchgear, Type 5HK, 7.5HK, Rev. 6
 CNM-1312-02-00-0054, Key Interlock General Information Dimensions, Rev. 0
 CNM-1318.00-00004-001, Environmental Qualification Test Report/ Analysis Summary,
 02/12/1986
 CNM-1356.01-0026.001, Install and Maintenance Manual for Vital Battery & Racks Unit 1, rev.
 D4
 CNS 1201.05-00-0006, Component Cooling Pumps, Rev 6
 CNS-1201.05-00-0001, Nuclear Service Water Pumps, 12/1/08
 CNS-1205.00-00-0005, Nuclear Safety Related Stainless Steel Valves, 12/29/82
 CNS-1465.00-00-0007, Plant Seismic Design, Rev. 2
 Coupling Correspondence with Johnston Pump, B Felker w/ E. Huffaker, 10/22/03
 DC-3.12, Cable Ampacity Design Criteria, Rev. 2
 Duke Power Generic Letter 96-05 Program Plan, Rev. 2
 EQMM-1393.01-A01-01 Environmental Qualification Maintenance Manual, 4/16/03
 EQMM-1393.01-G04-00, Environmental Qualification Maintenance Manual for Westinghouse
 Motors, Rev. 7
 EQMM-1393.01-N01-01, Environmental Qualification Maintenance Manual, Rev. 5
 IEEE Std 450-2002, Recommended Practice for Maintenance, testing, and Replacement of
 Vented Lead –Acid Batteries for Stationary applications, 04/03/2003
 IEEE Std 485-1997, Recommended Practice for Sizing Lead-Acid Batteries for Stationary
 applications, 03/20/1997
 Letter (draft), T. Hamilton (CN) to Sulzer Pump, Subject: Potential Part 21 Reportability, File:
 CN-211.55, 9/25/08
 Letter, B. Woodford (Cooper Energy Services) to G. Yezefski (CN), Subject: Diesel Generator
 Engine Heat Rejection, 11/1/2000
 Letter, R. Kayler (CN) to B. Woodford (Cooper Energy Services), Subject: Diesel Generator
 Jacket Water Cooler Fouling Factor Design Data, 5/13/04

Maintenance Rule Scoping Documentation
 NRC Bulletin No. 88-04: Potential Safety-Related Pump Loss
 NSD229 Evaluation and Reporting of Potential Defects Per 10CFR21, Rev.4, 10/20/08
 Nuclear Policy Manual, Directive 229, Evaluation and Reporting of Potential Defects and
 Noncompliance per 10 CFR Part 21, Rev. 4
 OMB Code, 1971 Ed.
 OP-CN-PSS-KC, Component Cooling Lesson Plan, Rev. 57
 OP-CN-PSS-KC-004, JPM for Alternate Cooling to 1A NV Pump, Rev. 8
 Operator Awareness Review, Recent Changes to E-0 (Reactor Trip or Safety Injection) Unit 1
 Rev. 35, Unit 2 Rev. 33
 PO # CN-35364, Rebuild of Nuclear Service Water Pumps, 10/28/98
 RE – 3.02 Electrical Engineering Criteria, Relaying – 600 and 480 VAC Auxiliary Systems –
 Equipment Protection Settings, Rev. 4
 RN Pump 1B dp trend data 8/15/07 thru 6/17/09
 SDQA-00055-CNS, KD Heat Capacity, Rev. 5
 Service Water System Program Manual, Rev. 9
 Vendor Manual: SSF Diesel Generator Instruction Manual Volume II, Duke File Number CNM
 1301.02-0058.002, Rev. D10
 Vendor Manual, CNM 1308.01-0021.001, Inductrol Regulator Type Airs Single Phase Motor-
 Operated Manual or Automatic Control” Rev. D1,
 Vendor Manual, CNM 1341.01-0001.001, “Tayco Engineering Hydrogen Assembly and
 Qualification Report” , Rev. D3

Modifications

Engineering Change 0000095020, CD 101434 – Power Train A Hydrogen Igniters From the
 SSF, Rev. 000
 Minor Modification CD201435, Power from Unit 2A Hydrogen Igniters from SSF Diesel, dated
 7/25/08
 CN-11372, Rev 00, Modification to revise the run-out set-points for the Component Cooling (KC)
 single pump and two pump operation
 CNCE-72672, Perform various MOV operator replacements and MOV testing to support GL 89-
 10 & 96-05, 9/9/04
 CD-100548, Replace MOV operators due to Rotork Part 21 issue (Ref. PIP C-04-2668), 11/7/06
 EC101196, Replace 1NVLT5761 Channel 1 VCT Level Transmitter, 06/14/2008
 EC200902, Replace 2NVLT5761 Level Transmitter, 12/14/2006

System Health Reports

CA - Auxiliary Feedwater Health Report 2008Q4
 EPC - 4KV Unit 1/2 Health Report 2008Q3
 EPL - 125VDC Vital I&C Power System Health Report 2009Q1
 KC - Component Cooling Health Report 2008Q4
 ND - Residual Heat Removal Health Report 2008Q2
 NI - Safety Injection Health Report 2008Q3
 NV - Chemical And Volume Control Health Report 2009Q1
 RN - Nuclear Service Water Health Report 2009Q1

Valves and Heat Exchangers Executive Report 4th Quarter/2008
Valves and Heat Exchangers Summary Report 2009 2nd Quarter

PIPs Initiated as a Result of Inspection

- C-09-04390, Valves 1/2WL-847/848 do not have objective evidence of periodic testing or maintenance for the life of the plant,
- C-09-04685, Field Walkdown Identified Damaged Capillary Armor for 1/2NVLT5760, 8/5/09
- C-09-04813, Unit 1 Aux Feed Control Valve Accumulator Drawings not in NAS, 8/12/09
- C-09-04822, Incorrect stroke times for 1/2ND28A shown on flow diagrams CN-1561-1.0 & CN-2561-1.0, 8/12/09
- C-09-04847, SSF Load and Voltage Calculation, minor clarifications and elimination of inconsistencies, 8/13/09
- C-09-04969, A reference cited in CNC-1223.23-00-0041, Evaluation of KC Pump Operation Near Maximum Tested Flow Rates, Rev 1, does not point to the correct source document, 8/19/09
- C-09-05007, Documentation discrepancy in 4160VAC switchgear EQ documentation, 8/20/09
- C-09-05020, Valve 1WL848 failed to stroke closed, 8/21/09
- C-09-05061, SSF Load Center Breaker Coordination and Diesel Generator Relay Setting Calculation concerns, 8/24/09
- C-09-05073, SSF D/G Testing Issue Load Bank Testing and Power Factor value concerns, 8/25/09
- C-09-05125, Revision of the horsepower (hp) used in CNM 1201.05-0272, Rev 6, to determine the shaft torque, 8/26/09
- C-09-05132, CNC-1223.24-00-0058 & CNC-1223.24-00-0060 need to demonstrate that pump curves used are bounded by IST limits, 8/27/09
- C-09-05137, Convective heat losses from KD HX not included in determination of maximum heat load for fouling and tube plugging limits, 8/27/09
- C-09-05142, In reference to pump failure documented in C-08-4289, Part 21 notification to pump vendor been may not have been provided, 8/27/09
- C-09-05144, Clarification of the Basis for Aux Bldg Room Temperatures, 8/27/09
- C-09-05146, Apparent non-conservative (low) weight used in seismic analysis for 1(2) ND028A & 1(2) NI0136B, 8/27/09
- C-09-05147, CNC-1223.24-00-0027 does not confirm that throttle valve positions calculated match up with actual field settings, 8/27/09