



---

**TENNESSEE VALLEY AUTHORITY**  
**BROWNS FERRY NUCLEAR PLANT (BFN)**

License Amendment Request to Extend the Completion Time  
for an Inoperable Diesel Generator  
from 7 Days to 14 Days

Rockville, Maryland  
June 29, 2010



## Agenda

---

- Introduction Terry Cribbe
- Revised Technical Specifications (TS)  
and TS Bases Changes Dan Green
- BFN Electrical System Rick Sampson
- Probabilistic Risk Assessment (PRA)  
Evaluations Ching Guey
- Closing Remarks Terry Cribbe



## Revised TS and TS Bases Changes

---

### TS 3.8.1, AC Sources - Operating

- New Proposed Required Action B.1
- New Proposed Condition C and Required Action C.1
- Associated TS Bases Changes
- Questions?



## Independent Offsite Power Sources

---

- Robust Offsite Power Distribution System
  - Seven 500kV Lines
  - Two 161kV Lines
  - Six Unit Station Service Transformers (USSTs) (2 per Unit)
  - Two Common Station Service Transformers (CSSTs)



## Normal Power Alignment to 4kV Unit Boards

---

- Unit 1 - USST 1B
- Unit 2 - USST 2B
- Unit 3 - USST 3B



## Alternate Power Alignment to 4kV Unit Boards

---

- Unit 1 - CSSTs via 4kV Start Bus
- Unit 2 - CSSTs via 4kV Start Bus
- Unit 3 - CSSTs via 4kV Start Bus



## Normal Power Alignment to 4kV Shutdown Boards

---

- Unit 1 - 4kV Unit Board Via 4kV Shutdown Bus 1
- Unit 2 - 4kV Unit Board Via 4kV Shutdown Bus 2
- Unit 3 - 4kV Unit Board (Direct Feed)



## Alternate Power Alignment to 4kV Shutdown Boards

---

- Unit 1 - 4kV Unit Board Via 4kV Shutdown Bus 2
- Unit 2 - 4kV Unit Board Via 4kV Shutdown Bus 1
- Unit 3 - 4kV Unit Board (Direct Feed)





## Emergency Power Alignment to 4kV Shutdown boards

---

- The 4kV Bus Tie Board Functions as a Tie Breaker to Provide Additional Functionality (Not Credited in Accident Analysis)
- Not Qualified



## 4kV System Supplies Entire Plant

---

- Safety-Related Loads - USSTs 1B, 2B and 3B
- Non-Safety (Balance of Plant) Loads - USSTs 1A, 2A and 3A



## 4kV Standby Power (If Offsite Power is Lost)

---

- Unit 1 and Unit 2 Share 4 Diesel Generators (DGs)
- Unit 3 has 4 DGs
- Unit 3 DGs Can Be Aligned (Direct Cross-Tie) to Supply Unit 1/2 4kV Shutdown Boards (Does Not Require the 4kV Bus Tie Board)
- Unit 1/2 DGs Can Be Aligned (Direct Cross-Tie) to Supply Unit 3 4kV Shutdown Boards (Does Not Require the 4kV Bus Tie Board)



## Example Unit 1 Alignment - DG A Out of Service

---

- Utilize DG 3EA as Alternate Supply for 4kV Shutdown Board A via the Tie Breakers on 4kV Shutdown Board A and 3EA
- Utilize DG 3EA as Emergency Supply to 4kV Shutdown Board A via the 4kV Bus Tie Board (Only If Options 1 or 2 Were Not Available - This Option Is Not Qualified)



## Example Unit 2 Alignment - DG C Out of Service

---

- Utilize DG 3EC as Alternate Supply for 4kV Shutdown Board C via the Tie Breakers on 4kV Shutdown Board C and 3EC
- Utilize DG 3EC as Emergency Supply to 4kV Shutdown Board C via the 4kV Bus Tie Board (Only If Options 1 or 2 Were Not Available - This Option Is Not Qualified)



## Example Unit 3 Alignment - DG 3EA Out of Service

---

- Utilize DG A as Alternate Supply for 4kV Shutdown Board 3EA via the Tie Breakers on 4kV Shutdown Board 3EA and A
- Utilize DG 3EB as Emergency Supply for 4kV Shutdown Board 3EA via the 4kV Bus Tie Board (Only If Options 1 or 2 Were Not Available - This Option Is Not Qualified)



## DG Loading

---

- Load Shedding Performed As Necessary to Utilize Alternate Feeds/Alignments
- Loading Monitored In Accordance With Operating Instructions
- Load Restrictions, Where Necessary, On Single Line Drawings As Operating Limit (OPL) Notes
- OPL Notes Referenced in Operating Instructions



## BFN Electrical System

---

- Questions?





## PRA Supporting DG 14 Day Completion Time

---

- Topics Of Interest
  - BFN PRA Upgrade
  - Risk Insights from DG Completion Time Studies



## Introduction

---

- Unit 1 BFN PRA RISKMAN Model Updated in 2006
  - Significant Findings and Observations (F&Os) Found During Peer Review
  - RISKMAN Software Requires More Resources to Understand, Develop and Apply
- PRA Upgrade Began in 2007
  - Model Converted from RISKMAN to CAFTA
  - Every Element of Model Re-Examined
  - Peer Review of Internal Events May 2009
  - Peer Review of Internal Flooding August 2009



## Programs/Tools Used for Conversion

---

| <b>Software Package</b> | <b>Version</b> | <b>Description</b>                        |
|-------------------------|----------------|---|
| CAFTA                   | 5.4            | Computer Aided Fault Tree Analysis System |
| PRAQuant                | 5.0a           | PRAQuant Accident Sequence Quantification |
| FTREX                   | 1.4            | Fault Tree Reliability Evaluation eXpert  |
| HRA Calculator          | 4.0            | Human Reliability Analysis Calculator     |
| MAAP                    | 4.0.5          | Modular Accident Analysis Program         |



## General Aspects of Upgrade

---

- New CAFTA Model Integrates All Three Units
  - Allows Evaluation of Risk for All Units for Outage of Common Systems, Structures, and Components
  - Allows Simultaneous Update for Data
- New Calculations Issued for All PRA Elements
- Documentation Developed to Meet Regulatory Guide (RG) 1.200
- PRA Updates Follow Industry PRA Configuration and Control Practices



## Initiating Events (IE)

---

- 101 New Initiators Added to 3-Unit Model
  - 57 Flood Initiators Replaced 7 Previously Modeled
  - 3 Initiators Added for Intake Structure Plugging (1 per Unit)
  - 51 Initiators Added for Various Combinations of AC and DC Electrical Board Failures
- Initiators That Could Affect More than 1 Unit Considered
- Previous Peer Review Findings Resolved
- NUREG/CR-6928 used for Industry IE Frequencies
  - Bayesian Update of Industry IE with Plant Specific Data



## Accident Sequences

---

- IEs Grouped and Evaluated Collectively
- Event Trees Developed for Each Accident Class (e.g., Large LOCA, General Transient, etc.)
- Operations Personnel Interviewed to Reflect Plant Responses



## Success Criteria

---

- All Success Criteria Re-Evaluated for PRA Upgrade
- Realistic Success Criteria Established
  - Existing Safety Analyses Reviewed for Applicability
  - Plant Specific Thermal Hydraulic (T-H) Calculations Performed
- T-H analyses Based on MAAP 4.0.5 runs



## Systems Analysis

---

- All Systems in PRA Re-Evaluated
- Includes All Systems that are
  - Required for Accident Mitigation
  - Systems Supporting Accident Mitigating Systems
- Identified Support System Initiating Events
- Ensured Models are Consistent With As-Built As-Operated Plant
  - System Engineers Reviewed Documentation





## Data Analysis

---

- Freeze Date for Data was January 2008
- Industry Data Based on NUREG/CR-6928
  - Bayesian Updated with Plant Specific Data
- Unavailability Data Based on
  - Maintenance Rule Data
  - System Engineer/Operations Staff Estimates
- Data Will Be Updated Every 4 Years
- Common Cause Failures Accounted for Within Systems



## Human Reliability Analysis (HRA)

---

- HRA Calculator Used to
  - Document and Quantify all Independent Human Error Probabilities
  - Document and Quantify Human Error Probabilities for Dependent Actions
- HRA Performed Developed to Meet RG 1.200



## Internal Flooding

---

- Internal Flooding Was Completely Re-evaluated to Address RG 1.200, Revision 2
- Several Walkdowns Performed to Assess the Impact of Flooding, Spray, and Impingement
- Peer Reviewed in August 2009
- All Findings Resolved



## Large Early Release Frequency (LERF) Analysis

---

- New Containment Event Trees Developed
- New MAAP Analyses Performed to Define Realistic LERF Sequences



## Quantification

---

- Single Fault Tree (for each Unit) Quantified Using CAFTA and FTREX 1.4
- Uncertainty Analysis Performed Quantitatively Using UNCERT
- Sensitivity Studies Performed for Significant Modeling Uncertainties



## Modeling for DG Completion Time

---

- Additional Initiators Added to Evaluate Fires That Could Cause Loss of Offsite Power
- Impact of Extended DG Completion Time On All Units Evaluated for each DG



## Summary Of Risk Impact of EDG (Internal Events)

---

| Case    | Base PRA Model | DG Using Unavailability 14-Day AOT | Change   | % Change |
|---------|----------------|------------------------------------|----------|----------|
| U1 CDF  | 6.57E-06       | 6.67E-06                           | 9.49E-08 | 1.44%    |
| U2 CDF  | 6.88E-06       | 6.95E-06                           | 7.74E-08 | 1.13%    |
| U3 CDF  | 7.30E-06       | 7.53E-06                           | 2.29E-07 | 3.13%    |
| U1 LERF | 2.13E-06       | 2.14E-06                           | 6.80E-09 | 0.32%    |
| U2 LERF | 2.70E-06       | 2.71E-06                           | 4.90E-09 | 0.18%    |
| U3 LERF | 1.01E-06       | 1.02E-06                           | 5.10E-09 | 0.50%    |



## Summary Of Risk Impact of EDG (Fire-Induced LOOP Events)

---

| <b>Fire Area / Fire Zone</b> | <b>Description</b>                        | <b>Frequency</b> | <b>Severe Fire Factor</b> | <b>Major Fire Frequency</b> | <b>New Initiator Name*</b> |
|------------------------------|---|------------------|---------------------------|-----------------------------|----------------------------|
| 16-3 (case 2B)               | Control Building - 617'<br>(Control Room) | 4.62E-05         | 0.049                     | 2.26E-06                    | %xLOOPFRCB                 |
| 24                           | 4kV Bus Tie Board Room                    | 1.92E-02         | 0.10                      | 1.92E-03                    | %xLOOPFRBT                 |
| 25-3 (case 3B)               | Turbine Deck                              | 1.34E-02         | 0.119                     | 1.59E-03                    | %xLOOPFRTD                 |
| Yard Area<br>(case 2)        | Yard Area                                 | 5.10E-03         | 0.25                      | 1.28E-03                    | %xLOOPFRYD                 |

\* There are four new fire initiators per unit (x in the Init Name = unit number)





## Summary Of Risk Impact of EDG (Fire-Induced LOOP Events)

---

**Table 6. Effect on CDF and LERF of 14-Day DG AOT Unavailability for Fires Resulting in a LOOP**

| Case    | Base PRA Model | DG Using Unavailability 14-Day AOT | Change   | % Change |
|---------|----------------|------------------------------------|----------|----------|
| U1 CDF  | 1.22E-06       | 1.35E-06                           | 1.28E-07 | 10.44%   |
| U2 CDF  | 9.92E-07       | 1.08E-06                           | 8.97E-08 | 9.05%    |
| U3 CDF  | 2.26E-06       | 2.53E-06                           | 2.74E-07 | 12.14%   |
| U1 LERF | 2.25E-07       | 2.33E-07                           | 7.95E-09 | 3.54%    |
| U2 LERF | 2.03E-07       | 2.08E-07                           | 4.49E-09 | 2.21%    |
| U3 LERF | 1.83E-07       | 1.86E-07                           | 3.38E-09 | 1.85%    |



## Summary Of Risk Impact of EDG (Total Including Internal and Fire)

---

**Table 7. Total Effect on CDF and LERF of 14-Day DG AOT Unavailability**

| Case    | Base PRA Model | DG Using Unavailability 14-Day AOT | Change   | % Change |
|---------|----------------|------------------------------------|----------|----------|
| U1 CDF  | 7.79E-06       | 8.01E-06                           | 2.23E-07 | 2.86%    |
| U2 CDF  | 7.87E-06       | 8.03E-06                           | 1.67E-07 | 2.12%    |
| U3 CDF  | 9.56E-06       | 1.01E-05                           | 5.02E-07 | 5.26%    |
| U1 LERF | 2.36E-06       | 2.37E-06                           | 1.48E-08 | 0.63%    |
| U2 LERF | 2.90E-06       | 2.91E-06                           | 9.39E-09 | 0.32%    |
| U3 LERF | 1.19E-06       | 1.20E-06                           | 8.48E-09 | 0.71%    |



## PRA Conclusions

---

- BFN PRA Model Significantly Upgraded Since 2006
- Internal Events and Internal Flooding Meet RG 1.200, Revision 2
- Extended DG Completion Time Meets RG 1.177



## Probabilistic Risk Assessment

---

– Questions?



- 
- Closing Remarks