

**Official Transcript of Proceedings**  
**NUCLEAR REGULATORY COMMISSION**

Title:                   Advisory Committee on Reactor Safeguards  
                          U.S. EPR Subcommittee Meeting

Docket Number:   (n/a)

Location:                 Rockville, Maryland

Date:                    Monday, February 7, 2011

Work Order No.:        NRC-695

Pages 1-317

**NEAL R. GROSS AND CO., INC.**  
**Court Reporters and Transcribers**  
**1323 Rhode Island Avenue, N.W.**  
**Washington, D.C. 20005**  
**(202) 234-4433**

DISCLAIMER1  
2  
3  
4 UNITED STATES NUCLEAR REGULATORY COMMISSION'S  
5 ADVISORY COMMITTEE ON REACTOR SAFEGUARDS  
6  
78 The contents of this transcript of the  
9 proceeding of the United States Nuclear Regulatory  
10 Commission Advisory Committee on Reactor Safeguards,  
11 as reported herein, is a record of the discussions  
12 recorded at the meeting.  
1314 This transcript has not been reviewed,  
15 corrected, and edited, and it may contain  
16 inaccuracies.  
17  
1819 UNITED STATES OF AMERICA  
20 NUCLEAR REGULATORY COMMISSION  
21 + + + + +  
22 ADVISORY COMMITTEE ON REACTOR SAFEGUARDS  
23 (ACRS)  
24 U.S. EPR SUBCOMMITTEE MEETING  
25 OPEN SESSION  
26 + + + + +**NEAL R. GROSS**COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17

MONDAY

FEBRUARY 7, 2011

+ + + + +

ROCKVILLE, MARYLAND

+ + + + +

The Advisory Committee met, at the Nuclear  
Regulatory Commission, Two White Flint North, Room  
T2B1, 11545 Rockville Pike, at 8:30 a.m., Sanjoy  
Banerjee, Chairman, presiding.

COMMITTEE MEMBERS:

- SANJOY BANERJEE, Chairman
- JOHN W. STETKAR, Member-at-Large
- WILLIAM J. SHACK, Member

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

## 1 NRC STAFF PRESENT:

2 STEVE BAJOREK, NRO/RES

3 JASON CARNEAL, NRO

4 JOSEPH COLACCINO, NRO

5 RONALD HARRINGTON, NRO/RES

6 MICHELLE HART, NRO/DSER/RSAC

7 BILL KROTIUK, NRO/RES

8 SHANLAI LU, NRO

9 SHAWN O. MARSHALL, NRO/RES

10 GETACHEW TESFAYE, NRO

11 ANTHONY ULSES, NRR

12 DEREK WIDMAYER, Designated Federal Official

## 13 ALSO PRESENT:

14 PAUL BERGERON, AREVA NP

15 DOUGLAS BROWNSON, AREVA NP

16 KENNETH COFFEY, AREVA NP

17 JERRY HOLM, AREVA NP

18 KEITH MAUPIN, AREVA NP

19 MARTIN PARECE, AREVA NP

20 PEDRO PEREZ, AREVA NP

21 JACK ROSENTHAL, ISL

22 ROBERT SALM, AREVA NP

23 LILIANE SCHOR, AREVA NP

24 SANDRA SLOAN, AREVA NP

25 JONATHAN WITTER, AREVA NP

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25

C-O-N-T-E-N-T-S

Call to Order, Opening Remarks,	4
Sanjoy Banerjee	
Chairman	
NRC Staff Introduction	6
Getachew Tesfaye	
U.S. EPR DC Application FSAR, Chapter 15	8
Transient and Accident Analyses	
Sandra Sloan	8
Douglas Brownson	11, 93
Jonathan Witter	26
Pedro Perez	139
Kenneth Coffey	187
U.S. EPR DC SER with Open Items for	211
Chapter 15, Transient and Accident Analyses	
Getachew Tesfaye	213
Jason Carneal	213
Michelle Hart	216
Shanlai Lu	221, 289
Shawn Marshall	263
Anthony Ulises	284
Radioactive Waste Cleanup System	312
Pedro Perez	312

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1  
2

Adjournment

317

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

P-R-O-C-E-E-D-I-N-G-S

8:30 a.m.

CHAIRMAN BANERJEE: The meeting will now come to order.

This is a meeting of the Advisory Committee on Reactor Safeguards, U.S. EPR Subcommittee. I am Sanjoy Banerjee, replacing just for this meeting, for the Subcommittee, Dana Powers, who, of course, is irreplaceable -- immiscible and irreplaceable.

(Laughter.)

ACRS members in attendance are Bill Shack, John Stetkar. We are supposed to have Harold Ray and Joy Rempe. So, if they come, we will know.

Derek Widmayer of the ACRS staff is the Designated Federal Official for this meeting.

The purpose of the meeting is to continue our review of the SER with open items for the U.S. EPR Design Certification Document. We will hear presentations on and discuss the Chapter 15 transient and accident analyses, except for Section 15.6.5.

The Subcommittee will hear presentations by and hold discussions with representatives of AREVA NP and the NRC staff and other interested persons regarding these matters.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1           The Subcommittee will gather relevant  
2 information today and plans to take the results of  
3 this review, along with the remaining section of  
4 Chapter 15 of the U.S. EPR DCD SER with open items  
5 reviewed by the Subcommittee in a meeting scheduled in  
6 March 2011 to the full Committee at a future full  
7 Committee meeting.

8           The rules for participation in today's  
9 meeting have been announced as part of the notice of  
10 this meeting previously published in The Federal  
11 Register. We have received no requests for members of  
12 the public to speak at today's meeting.

13           A transcript of the meeting is being kept  
14 and will be made available, as stated in The Federal  
15 Register notice. Therefore, we request that  
16 participants in this meeting use the microphones  
17 located throughout the meeting room when addressing  
18 the Subcommittee. The participants should first  
19 identify themselves and speak with sufficient clarity  
20 and volume so that they can be readily heard.

21           Copies of the meeting agenda and handouts  
22 are available in the back of the meeting room.

23           A telephone bridge line has been  
24 established with the meeting room today, and I  
25 understand we will have participants from AREVA on the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 line at various times throughout the meeting.

2 We request that participants on the bridge  
3 line identify themselves when they speak and to keep  
4 your telephones on mute during the times when you are  
5 just listening.

6 Is the bridge line on, Derek? Do you  
7 know?

8 MR. WIDMAYER: Do you have anybody calling  
9 in?

10 MR. BROWNSON: I expect that there should  
11 be a couple of people calling in.

12 MR. WIDMAYER: I didn't hear anybody so  
13 far.

14 CHAIRMAN BANERJEE: Okay, but it is on.

15 So, we will now turn to Getachew Tesfaye,  
16 the NRO Project Manager, for the review of the U.S.  
17 EPR DCD, for your introductory remarks.

18 MR. TESFAYE: Good morning, Dr. Banerjee  
19 and everyone.

20 My name is Getachew Tesfaye. I am the NRC  
21 Project Manager for EPR design certification.

22 Today and tomorrow we will continue our  
23 Phase 3 ACRS presentations of the staff's safety  
24 evaluation of all those open items.

25 For the record, as I routinely do here, I

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 will go over and summarize the Phase 3 activities.

2 To date, we have completed the Phase 3  
3 presentation of 11 chapters. We presented Chapter 8,  
4 Electric Power, and Chapter 2, Site Characteristics,  
5 on November 3rd, 2009, and Chapter 10, Steam Power  
6 Conversion System, and Chapter 12, Radiation  
7 Protection, on November 19, 2009.

8 On February 18 and 19, 2010, we presented  
9 Chapter 17, Quality Assurance, and portions of Chapter  
10 19, Probabilistic Risk Assessment and Severe Accident  
11 Evaluation.

12 On March 3rd, 2010, we presented Chapter  
13 4, Reactor, and Chapter 5, Reactor Coolant System and  
14 Connected Systems.

15 On April 6th, 2010, we presented Chapter  
16 11, Radioactive Risk Management, and Chapter 16,  
17 Technical Specifications.

18 On April 8th, we briefed the ACRS full  
19 Committee on the seven chapters that were completed  
20 through March 2010.

21 On April 21, we completed the Chapter 19  
22 presentation, and on April 21, 2010, we received a  
23 letter from the ACRS full Committee Chairman on the  
24 seven chapters that were completed through March 2010.  
25 The letter indicated that ACRS has not identified any

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 issues that merit further discussion.

2 On May 27th, 2010, the staff submitted its  
3 reply to ACRS, and our last activity was last  
4 November, November 30th, where we presented Chapter  
5 13, Conduct of Operation.

6 Today and tomorrow we will present Chapter  
7 15, Transient and Accident Analysis. Please note that  
8 for Phase 2 and Phase 3 reviews, the Chapter 15  
9 sections are broken up into two groups.

10 Today's and tomorrow's staff presentation  
11 will focus on Group 1 sections.

12 Our current schedule calls for completing  
13 the Phase 3 presentation of the remaining eight  
14 chapters by mid-October 2011.

15 Mr. Chairman, that completes my prepared  
16 statement.

17 CHAIRMAN BANERJEE: Okay. Shall we turn  
18 it over to AREVA then?

19 MR. TESFAYE: If there are no question,  
20 yes, please, go ahead.

21 CHAIRMAN BANERJEE: Okay. Go ahead.

22 MS. SLOAN: Thank you. Thank you. We are  
23 glad to be back before ACRS and continuing to make  
24 progress moving through the design certification  
25 review for EPR.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1           For today, as Getachew indicated, we are  
2 here to present Chapter 15, Transient and Accident  
3 Analyses, with the exception, as Mr. Tesfaye noted, of  
4 15.6.5, which is the LOCA portion of Chapter 15.

5           You can see the agenda here. We will  
6 start with an overview of unique U.S. EPR design  
7 features.

8           Some of the members will recall that about  
9 a year and a half ago we gave an overview of these  
10 features. We thought it would be worth going back and  
11 maybe reviewing some of the key ones that are of most  
12 relevance to the analysis of non-LOCA events for U.S.  
13 EPR. And Doug Brownson will present that.

14           From there, Dr. Witter will talk about the  
15 trip functions for U.S. EPR and, then, move into a  
16 discussion of the in-core transient methodology.  
17 Following that, Mr. Brownson will again pick up and  
18 talk about the Chapter 15 evaluation of the non-LOCA  
19 and transient analyses. Pedro Perez will then join us  
20 to talk about the evaluation of radiological  
21 consequences of events.

22           And finally, at the end of the day, we  
23 understand that there may be one or more members of  
24 the Subcommittee who had a particular interest in  
25 understanding more about the steam generator tube

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 rupture mitigation strategy for the U.S. EPR. So, we  
2 have some time devoted at the end to that discussion,  
3 and Mr. Coffey will support that.

4 With that, I will turn it over to Doug  
5 Brownson.

6 CHAIRMAN BANERJEE: Sandra, can you just  
7 give us a little overview of also what is going to  
8 happen tomorrow? Or you're not prepared to do that  
9 right now?

10 MS. SLOAN: No, no, no, I'm fine with  
11 that.

12 Tomorrow we will talk about our control  
13 rod ejection methodology. Again, I think it was about  
14 a year and a half ago we came and gave an overview of  
15 that methodology. And so, we are back to review some  
16 of that and maybe answer some additional questions on  
17 that methodology.

18 And, then, after that, we will talk about  
19 our small break LOCA methodology. We understand there  
20 have been some specific questions posed to AREVA  
21 regarding potentially some unique phenomena for EPR  
22 small break LOCA response. So, we would like an  
23 opportunity to address that. So, we will be prepared  
24 to do that tomorrow.

25 CHAIRMAN BANERJEE: But that will mainly

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 be methodology, not results?

2 MS. SLOAN: Correct. We are not here to  
3 present the small break LOCA results tomorrow. That  
4 is captured in 15.6.5.

5 CHAIRMAN BANERJEE: Which will be later?

6 MS. SLOAN: Which will be later. But we  
7 did understand that the Subcommittee had some  
8 particular questions on phenomenology, reflux  
9 condensation --

10 CHAIRMAN BANERJEE: Correct.

11 MS. SLOAN: -- and potentially  
12 countercurrent flow limitations. We would like to  
13 talk about those at this opportunity.

14 CHAIRMAN BANERJEE: Okay. Great.

15 Go ahead.

16 MR. BROWNSON: Thank you.

17 My name is Douglas Brownson. I will be  
18 the first speaker here.

19 Some background on myself, before we get  
20 started, I have 27 years' experience in the nuclear  
21 industry. I have an undergraduate and master's degree  
22 from the Pennsylvania State University.

23 The first job was working for Commonwealth  
24 Edison, where, amongst other things, performed PBR  
25 core reloads, followed by 10 years at the Idaho

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 National Engineering Laboratory performing severe  
2 accident research and PRA Level 2 analyses for the  
3 U.S. NRC.

4 I have also worked at Yucca Mountain  
5 project. And most recently, I have spent the past  
6 five years involved in the performance of Chapter 15,  
7 Non-LOCA Analysis, for the U.S. EPR.

8 I would like to begin today with some  
9 background information, as Sandra pointed out. The  
10 U.S. EPR is a conventional four-loop PWR proven by  
11 decades of design licensing and operating experience.

12 The NSSS volumes of the U.S. EPR are larger compared  
13 to existing PWRs. This increases the operator grace  
14 period for many of the transients.

15 Here's just a quick comparison of some of  
16 the key parameters.

17 CHAIRMAN BANERJEE: You mean larger in  
18 volume per units of power or?

19 MR. BROWNSON: No, larger in the RCS  
20 volume, pressurizer volume, those NSSS components.

21 CHAIRMAN BANERJEE: But when it comes to  
22 per unit of power, it is about the same or not?

23 MR. BROWNSON: Well, from the slide here,  
24 are you talking about it from a core average linear  
25 heat rate or -- well, here, down at the bottom that's

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 one of the parameters here I am going to go into. The  
2 linear power rate is actually a little bit less, but  
3 the overall core thermal output and electrical output  
4 is larger. We are operating at higher temperature  
5 ranges, leading to a higher plant efficiency.

6 The primary system pressure, operating  
7 pressure, is the same as other operating PWRs. We  
8 have a much larger reactor coolant flow per loop, and  
9 we have a 14-foot core versus a 12-foot core, which  
10 results in a lower core average linear heat rate and  
11 peak linear heat rate.

12 MS. SLOAN: I think Marty would like to  
13 comment.

14 MR. BROWNSON: Yes, Marty.

15 MR. PARECE: Yes, this is Marty Parece.

16 Is this working?

17 I am Marty Parece. I am with AREVA. I am  
18 the Vice President of Products and Technology. So, I  
19 am responsible for the design authority for the unit.

20 The main points are that, from a power  
21 scaling, the primary volume is about the same, but  
22 that is about the only thing. The pressurizer volume  
23 is much greater on a per-megawatt basis and a per-  
24 volume basis, which obviously makes the pressure  
25 response slower.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 And, then, the secondary inventory, well,  
2 it is not on this slide. The secondary inventory is  
3 significantly greater per megawatt than a standard  
4 four-loop unit. So, on a typical reactor trip with a  
5 loss of feedwater, there is approximately 30 minutes  
6 of decay heat removal in the secondary steam  
7 generators all by themselves.

8 So, the secondary inventory is  
9 significantly larger. The secondary volume is  
10 significantly larger.

11 CHAIRMAN BANERJEE: Per unit of power?

12 MR. PARECE: Per unit of power, yes.

13 CHAIRMAN BANERJEE: What about the flow  
14 area in the hot leg?

15 MR. PARECE: Well, the flow area in the  
16 hot leg is approximately the same. It is a little  
17 larger. It is approximately the same.

18 CHAIRMAN BANERJEE: Per unit of power.

19 MR. PARECE: I believe the ID is 33  
20 inches. Per unit of power, it depends on the design,  
21 but the per unit of power, the area of the hot leg is  
22 a bit smaller.

23 CHAIRMAN BANERJEE: Okay. So, the hot leg  
24 is 33 inches, you said?

25 MR. PARECE: ID, I believe. And on this

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 unit, the cold leg is the same diameter as the hot  
2 leg. So, that is a difference from the existing four-  
3 loop units.

4 CHAIRMAN BANERJEE: And what is the sort  
5 of typically existing four-loop plant? It is 33  
6 inches as well?

7 MR. PARECE: Approximately. And I think  
8 the cold legs are 29 inches typically.

9 CHAIRMAN BANERJEE: Okay. And your steam  
10 generator flow areas on the riser side?

11 MR. PARECE: I don't remember. I have to  
12 do some math in my head.

13 CHAIRMAN BANERJEE: But can we come back  
14 to that?

15 MR. PARECE: Yes, we'll come back. I will  
16 do the math. I will come back to you on it.

17 CHAIRMAN BANERJEE: Yes, I am very  
18 interested in understanding the hot leg flow area per  
19 unit of power. So, that is going to be a bit less  
20 than the existing PWRs and the flow area on the steam  
21 generator side?

22 MR. PARECE: Yes. If you scaled up a  
23 current plant, if you scaled up the hot leg area just  
24 by itself on power, you would have something closer to  
25 40 inches, I believe.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 CHAIRMAN BANERJEE: Right. Okay. Thanks.

2 MR. BROWNSON: Any more questions on this  
3 slide?

4 (No response.)

5 I believe in tomorrow's presentation --

6 CHAIRMAN BANERJEE: And the loop seals are  
7 conventional?

8 MR. BROWNSON: Yes.

9 CHAIRMAN BANERJEE: Is there anything  
10 special I should know about them?

11 MR. PARECE: There's nothing special about  
12 the loop seals except that we have minimized the size  
13 of them as much as practical, the depth of them. So,  
14 the depth of the loop seals is less. And the  
15 elevation of the core to the center line of the hot  
16 leg and cold legs has been lowered to improve the  
17 amount of inventory above the core.

18 CHAIRMAN BANERJEE: Okay. So, we will get  
19 into all of this when we talk about LOCA and small  
20 breaks and things, right?

21 MS. SLOAN: There will be a discussion  
22 during small break LOCA, guaranteed.

23 CHAIRMAN BANERJEE: Excruciating detail,  
24 I'm sure, yes.

25 MR. BROWNSON: And I believe during

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 tomorrow's presentation on SB LOCA methodology a  
2 similar slide is being presented with some slightly  
3 different information. I think some of the volumes  
4 and stuff are on that slide.

5 Some of the safety-related systems and  
6 features is that the U.S. EPR has four train front-  
7 line safety systems for the medium head safety  
8 injection, the low head safety injection,  
9 accumulators, and emergency feedwater. There is one  
10 train for each primary or secondary loop.

11 This redundancy provides additional  
12 reliability for the mitigation of events, and it  
13 allows for single failures and preventative  
14 maintenance of trains while still satisfying event  
15 mitigation criteria.

16 The automatic partial cooldown feature of  
17 the steam generators allows the secondary system to  
18 drive the primary system pressure down to the medium  
19 head safety injection shutoff head in a controlled and  
20 rapid manner while maintaining saturation margin.  
21 This feature is significant in the event of a loss of  
22 coolant accident or steam generator tube rupture.

23 CHAIRMAN BANERJEE: What's the maximum  
24 rate of coolant?

25 MR. BROWNSON: A hundred and eighty

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 degrees per hour.

2 CHAIRMAN BANERJEE: Celsius or?

3 MR. BROWNSON: Fahrenheit.

4 CHAIRMAN BANERJEE: Fahrenheit.

5 MR. SALM: A hundred degrees C.

6 CHAIRMAN BANERJEE: Right. Yes. Okay.

7 Now that makes more sense.

8 (Laughter.)

9 All right. I could do that conversion.

10 All right. Go ahead.

11 MR. BROWNSON: The automatic trip of the  
12 reactor coolant pump --

13 CHAIRMAN BANERJEE: Oh, just a point. Are  
14 you going to talk a little bit about this cool-down  
15 procedure or has that already been done?

16 MR. BROWNSON: I believe the cool-down  
17 procedure is going to be discussed in the steam  
18 generator tube mitigation strategy.

19 CHAIRMAN BANERJEE: Okay.

20 MR. BROWNSON: The next slide after this  
21 slide --

22 CHAIRMAN BANERJEE: Sure. If you are  
23 going to do it later, that's fine.

24 MR. BROWNSON: Yes. And there will be a  
25 little bit of additional information on the next slide

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 on how we accomplish that.

2 The automatic trip of the reactor coolant  
3 pumps on coincident SIS signal and low delta pressure  
4 across the pumps is an important LOCA mitigation  
5 feature. This prevents excessive coolant loss through  
6 the break and prevention of pump cavitation. This  
7 feature also satisfies the post-TMI criteria.

8 As Dr. Witter will describe later in  
9 greater detail, the U.S. EPR has low DNBR and high  
10 linear core power density protection system functions.

11 The uniqueness of these trip functions, however, is  
12 that they are based on real-time in-core measurements  
13 rather than inferring the protection function from ex-  
14 core measurements.

15 The in-containment refueling water  
16 storage --

17 CHAIRMAN BANERJEE: Now, for the control  
18 rod ejections, you have ex-core measurements, don't  
19 you?

20 MR. BROWNSON: Yes, we do --

21 CHAIRMAN BANERJEE: Yes.

22 MR. BROWNSON: For some of our protection  
23 system functions, there are ex-core.

24 MS. SLOAN: And Dr. Witter will touch in  
25 more detail about the trip functions.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIRMAN BANERJEE: Okay.

2 MR. BROWNSON: Yes.

3 The in-containment refueling water storage  
4 tank provides the water source for medium head and low  
5 head emergency core cooling safety injection. This  
6 tank is sized such that there is no need to switch to  
7 external water sources during the mitigation of an  
8 event.

9 In the event of a large break LOCA, the  
10 U.S. EPR has a two-train emergency boration system to  
11 provide additional criticality shutdown margin. This  
12 is a safety grade system, but is manually actuated.

13 In order to help operators identify the  
14 occurrence of steam generator tube rupture, there is a  
15 safety grade alarm provided on high activity in steam  
16 lines.

17 Another unique steam generator tube  
18 rupture mitigation feature is the steam generator  
19 blowdown/transfer lines. These safety-grade lines  
20 allow for the transfer of inventory from the isolated,  
21 affected steam generator to a sister steam generator  
22 that is also isolated in order to reduce the pressure  
23 in the affected steam generator and allow the primary  
24 system pressure to decrease to RHR cutting conditions.

25 Again, that feature will be discussed a

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 little bit -- no, I guess we are not. So, sorry about  
2 that.

3 Main steam relief operation --

4 CHAIRMAN BANERJEE: Well, let's do  
5 understand the core has a larger diameter than the  
6 normal PWRs, the four-loop. Do you have any special  
7 devices to mix things coming in at the bottom to  
8 improve the mixing?

9 DR. WITTER: In the lower plenum regions,  
10 there is a flow device in the lower plenum regions  
11 that help with the flow distribution somewhat in there  
12 for some of the mixing. That is part of the lower  
13 internals.

14 CHAIRMAN BANERJEE: And you have tested  
15 this?

16 DR. WITTER: We will let Marty speak to  
17 that, but I believe it has been tested at the Juliette  
18 facility.

19 MR. PARECE: Yes, what we found was, when  
20 we removed all of the in-core instrumentation from the  
21 bottom, those tubes coming up through the bottom  
22 caused the flow to be well-defined. And when you  
23 remove them, the flow tends to move from quadrant to  
24 quadrant. So, we have a flow distributor device at an  
25 inlet to the core below the core support plate that

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 makes that flow stable and well-distributed. And that  
2 has been tested at a 1/6th facility called the  
3 Juliette facility in France.

4 MS. SLOAN: Is there a figure of that in  
5 the FSAR? Because, if there is, we will pull it and  
6 we will provide it to the Subcommittee.

7 MR. PARECE: Yes, I'm sure that you can  
8 see --

9 CHAIRMAN BANERJEE: I am not right on top  
10 of this because I haven't been --

11 DR. WITTER: And this is Jonathan Witter.

12 I believe it was mentioned as part of the  
13 Chapter 4 presentation material. I think there was an  
14 image of the flow distribution device in Chapter 4.

15 MS. SLOAN: We will find a picture of it,  
16 and we will provide that to the Subcommittee.

17 CHAIRMAN BANERJEE: Okay. And with regard  
18 to the borating system, I guess the mixing in the  
19 lower plenum is fairly well-documented and discussed  
20 somewhere, right? I mean how well things mix.  
21 There's no plumes coming in?

22 MR. PARECE: Well, I am not sure where it  
23 is discussed in the FSAR, but that system is a fairly  
24 low flowrate with a fairly high concentration. So,  
25 clearly, for most of the transients, when the reactor

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 coolant pumps are running, it comes in in the cold leg  
2 and mixes pretty well.

3 So, I don't know where that is discussed  
4 in the FSAR.

5 MS. SLOAN: Yes, I think we are going to  
6 take an action, Dr. Banerjee, to find. If it is in  
7 the FSAR, we will point to the section.

8 CHAIRMAN BANERJEE: Okay.

9 MS. SLOAN: If it is not in the FSAR, we  
10 will see what supporting documentation could be  
11 provided.

12 MR. PARECE: I think it is about, what,  
13 7,000 to 7,700 ppm enriched B10. So, that is  
14 equivalent to about 12,000 ppm natural boron.

15 CHAIRMAN BANERJEE: Weren't you doing some  
16 work at Rossendorf on the mixing? I seem to remember  
17 seeing an experiment in Dresden.

18 MR. PARECE: I don't recall. I don't  
19 know.

20 CHAIRMAN BANERJEE: All right.

21 MS. SLOAN: Yes, it doesn't ring a bell  
22 for me.

23 CHAIRMAN BANERJEE: The Juliette is what  
24 you depend on?

25 MS. SLOAN: Yes. Yes.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIRMAN BANERJEE: Okay.

2 MR. BROWNSON: Anything else?

3 (No response.)

4 Main steam relief train operation. The  
5 main steam relief train, there is one of these per  
6 steam line. Each MSRT consists of two valves in  
7 series, the main steam relief isolation valve that  
8 functions as a safety relief valve and the main steam  
9 relief valve that maintains the secondary pressure at  
10 a prescribed setpoint.

11 The MSRT provides two functions for the  
12 U.S. EPR, pressure relief during overpressure events  
13 and a controlled partial cooldown during LOCA and  
14 steam generator tube ruptures. The MSRT is sized  
15 equivalent to 50 percent of the full load steam  
16 capacity.

17 And in overpressure protection mode, the  
18 relief valve opens at a prescribed setpoint of 1385  
19 psia, and the control valve maintains its initial  
20 position to allow full relief.

21 In the partial cooldown, the MSRT starts  
22 at the 1385 and regulates the pressure decrease at a  
23 secondary rate, as we discussed earlier, of 180  
24 degrees F per hour.

25 The decrease in secondary pressure drives

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 primary pressure down to allow timely actuation of the  
2 medium head safety injection system, which, again, has  
3 a shutoff head of 1405 psi. And for steam generator  
4 tube rupture, the setpoint of the MSRT on the affected  
5 steam generator is reset high, up to the 1436 psia  
6 value, to preclude its actuation in the release of  
7 radionuclides.

8 MEMBER STETKAR: Doug, you mentioned that  
9 the steam relief capacity of the MSRT is 50 percent of  
10 rated steam flow. Is that the total capacity of all  
11 four trains or is it per steam generator?

12 MR. BROWNSON: Per loop.

13 MEMBER STETKAR: Per loop?

14 MR. BROWNSON: Fifty percent per loop.

15 MEMBER STETKAR: Okay. Thanks.

16 CHAIRMAN BANERJEE: And you don't take  
17 steam through the condensers or anything to  
18 depressurize?

19 MR. BROWNSON: There's a non-safety system  
20 that actuates before the MSRTs, the turbine bypass  
21 system, which will dump directly into the condensers.  
22 That has a total capacity of 50 percent of the full  
23 load, of the entire plant full load capacity.

24 CHAIRMAN BANERJEE: But that is a non-  
25 safety system?

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 MR. BROWNSON: That is a non-safety  
2 system, which is not credited for the Chapter 15  
3 events.

4 CHAIRMAN BANERJEE: Right.

5 MR. BROWNSON: That finishes the unique  
6 features. Jonathan will now talk about the trip  
7 functions.

8 DR. WITTER: Good morning.

9 My name is Jonathan Witter. And I have  
10 spoken once or twice before the Committee, but I will  
11 give a little bit of background about myself again.

12 I have got my bachelor's and master's in  
13 nuclear engineering from Rensselaer Polytechnic  
14 Institute, 1982, 1983. Qualified EOOW in the Navy  
15 nuclear program under GE as the civilian and nuclear  
16 plant engineer for training.

17 Then, spent a stint at the James A.  
18 FitzPatrick nuclear power plant in Oswego, New York,  
19 as a station nuclear engineer for five years.

20 Then, went on to school to get my PhD at  
21 Massachusetts Institute of Technology, and I did a  
22 simulation of control for nuclear rocket control at  
23 the time. In 1993, it was going back to Mars, so it  
24 was the thing to do to get into space.

25 Then, after that, I went to the Knolls

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 Atomic Power Laboratory. I worked in the advanced  
2 concepts nuclear design for 13 years with the last two  
3 years serving for the Jupiter Icy Moons Orbiter  
4 mission, which didn't last very long.

5 And at that time, I got a little bit --  
6 decided to come back into the commercial world and  
7 joined AREVA in 2006 for the U.S. EPR project, and  
8 have been working on, whether it has been the fuel  
9 performance, thermal hydraulic performance, and core-  
10 related design aspects for the U.S. EPR.

11 Today I will be talking a little bit about  
12 the trip functions for the U.S. EPR and, then, a  
13 little bit more about the in-core monitoring system  
14 and how we verify the change in methodology and the  
15 setpoints, to verify that we do not violate the  
16 specified allowable fuel design limits during the  
17 Chapter 15 events.

18 Okay. So, the first slide here shows a  
19 little depiction of some of the instrumentation that  
20 we make use of for reactor trips for the protection  
21 system, the typical instrumentation in the hot leg and  
22 cold leg for temperatures and pressures, reactor  
23 coolant pump speeds, delta pressure taps for flow  
24 measurements. We also measure the control drop  
25 positions for the control rods, as they provide an

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 input into some of the safety systems for the in-core  
2 trip systems.

3 And what I mean by the in-cores are, for  
4 the SPNDs, they are self-powered neutron detectors  
5 where we have an array of in-core detectors within the  
6 core region that, instead of just serving as a  
7 monitoring system, they are actually used as part of  
8 the protection system. So, they monitor and then will  
9 also perform a trip function.

10 And I will have a series of slides  
11 discussing how we make use of those.

12 CHAIRMAN BANERJEE: So, I guess you have  
13 discussed these delta P over the elbow taps at some  
14 other meetings?

15 DR. WITTER: I believe so in the Chapter 4  
16 parts of it for the RCS description and the thermal  
17 hydraulics.

18 CHAIRMAN BANERJEE: And nobody asked you  
19 any questions about it?

20 DR. WITTER: Not that I recall.

21 MS. SLOAN: I don't recall any particular  
22 interest.

23 (Laughter.)

24 CHAIRMAN BANERJEE: How interesting.

25 (Laughter.)

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1                   What are you claiming for these delta P --

2                   DR. WITTER: It is primarily a measure for  
3 the low-low flow reactor trips. Well, I will get into  
4 it a little bit with our high core power level  
5 monitoring. They don't feed into the core power  
6 calculation. They are just used there to essentially  
7 predict the flow rate and whether or not we have flow  
8 in a loop or low-low flow for the total system to  
9 cause a reactor trip on that.

10                  So, there is no real flow measurement  
11 being used for an enthalpy-based calculation.

12                  CHAIRMAN BANERJEE: Okay. So, you are  
13 using your ultrasonic detector? I noticed you get a  
14 .48 percent.

15                  DR. WITTER: Yes, sir.

16                  CHAIRMAN BANERJEE: For your LOCA initial  
17 conditions, I assume?

18                  DR. WITTER: Yes. Yes, for the  
19 secondary --

20                  CHAIRMAN BANERJEE: We would like to  
21 discuss that, of course, in depth for sure.

22                  DR. WITTER: We can discuss that a little  
23 bit.

24                  MS. SLOAN: Did you want to do that during  
25 the LOCA discussion, Dr. Banerjee?

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIRMAN BANERJEE: Oh, okay. We can do  
2 it then. That would be good.

3 MS. SLOAN: We have an open item related  
4 to this with the staff. So, we are not prepared  
5 necessarily today. I think Marty has a couple of  
6 comments, Marty Parece, that he can make, but that is  
7 an open item still under resolution with the staff  
8 right now.

9 Marty, did you want to say a couple of  
10 words at this point?

11 CHAIRMAN BANERJEE: You just referred to  
12 LOCA, but go ahead.

13 MR. PARECE: Well, for the heat balance  
14 uncertainty itself, we have a fairly rigorous  
15 statistical application for the EPR based on what we  
16 have done on several Appendix K uprates or MURs using  
17 the Caldon equipment.

18 And we think we know that the .48 percent  
19 is bounding, but it includes uncertainty. The biggest  
20 uncertainty is the feedwater measurement itself, which  
21 is around .3 percent or less. And, then, we have  
22 uncertainties in specifically the RTDs for getting  
23 temperatures to do enthalpies for the heat balance.

24 And this flow in these elbows is actually  
25 calibrated to the secondary heat balance and the core

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 power from the in-cores and the ex-cores and a primary  
2 heat balance. So, the flow in those elbows ends up  
3 getting correlated to the heat balance itself.

4 CHAIRMAN BANERJEE: Right.

5 MR. PARECE: So, we are fairly rigorous on  
6 that, and the Caldon equipment has been shown to be  
7 very accurate in their testing at Alden Labs.

8 This is the leading-edge-plus flow meter.

9 CHAIRMAN BANERJEE: I know the machine,  
10 yes.

11 MR. PARECE: Right.

12 CHAIRMAN BANERJEE: Of course, in the  
13 staff SER there is a requirement to do both for  
14 typical testing in the lab -- well, there is a  
15 parallel path. You can install it and you can test  
16 it, but, in general, it has to be tested in a  
17 prototypical situation --

18 MR. PARECE: Right.

19 CHAIRMAN BANERJEE: -- installed, and then  
20 there has to be in situ tests.

21 MR. PARECE: Correct.

22 CHAIRMAN BANERJEE: Then, the problem, of  
23 course, is the Reynolds number scaling on that because  
24 you cannot do the calibration tests of the Reynolds  
25 numbers in the plant and the viscosity conditions.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 So, while it may have gone through some MURs, this is  
2 a different application. And every plant, it has to  
3 be tested for every plant, right?

4 MR. PARECE: I don't think we disagree.

5 CHAIRMAN BANERJEE: Yes. So, you have a  
6 program in place to do the testing and everything or  
7 are you going to leave this to the COLAs?

8 MR. PARECE: Well, this will be part of  
9 the startup procedures for the unit.

10 CHAIRMAN BANERJEE: Right.

11 MR. PARECE: And getting the first heat  
12 balance. So, that part of it will definitely be the  
13 plant owner's responsibilities.

14 CHAIRMAN BANERJEE: Sure. All this  
15 testing, calibration.

16 MR. PARECE: And we haven't written the  
17 equipment specifications yet for the flow meters. So,  
18 some of this can be or a lot of it, the testing will  
19 be flowed down to the manufacturer.

20 CHAIRMAN BANERJEE: Are you actually  
21 specifying how they meet this requirement or leaving  
22 it up to the COLA as to what instrument they use? I  
23 mean, is this your spec or you are actually specifying  
24 the instrument? I'm a little confused.

25 MR. PARECE: Well, at this point, for this

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 particular instrument with this quality of  
2 measurement, there's only one manufacturer. So, I  
3 would hate to say that I'm specifying a manufacturer  
4 for the owners to purchase, but at this point there's  
5 really only one.

6 MS. SLOAN: And, Dr. Banerjee, I would  
7 suggest that we carry that -- this is an open item in  
8 the LOCA section of the FSAR. We understand and are  
9 following ACRS interest in power measurement  
10 uncertainty. So, when we get to 15.6.5 for LOCA, we  
11 understand we have to come prepared to discuss that  
12 measurement.

13 CHAIRMAN BANERJEE: You have seen our  
14 Vogtle letter?

15 MS. SLOAN: We have seen the letter to  
16 Vogtle, yes, sir.

17 CHAIRMAN BANERJEE: Okay. And you saw the  
18 requirement was somewhat different from what you are  
19 asking?

20 MS. SLOAN: We understand there is  
21 heightened interest.

22 CHAIRMAN BANERJEE: Yes. Okay.

23 DR. WITTER: Okay. I think that it is  
24 within this slide.

25 MEMBER STETKAR: Jonathan?

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 DR. WITTER: Yes, sir?

2 MEMBER STETKAR: Before you leave it --

3 DR. WITTER: Sure.

4 MEMBER STETKAR: -- all of the  
5 instrumentation that you show on the slide with the  
6 exception of the steam generator pressure  
7 measurements, the sensors are located inside the  
8 containment, is that true?

9 DR. WITTER: The containment, that is  
10 correct.

11 MEMBER STETKAR: The steam generator  
12 pressure sensors are located outside containment, the  
13 safeguards building? Okay. How far from the  
14 containment penetration are they? You know, half a  
15 meter, 12 meters, 120 meters?

16 DR. WITTER: We have to take an action to  
17 that.

18 MS. SLOAN: Yes, we will take an action to  
19 follow up and find the distance.

20 MEMBER STETKAR: The reason I am  
21 interested, obviously, is when we get into steam line  
22 break, you very carefully craft the location of the  
23 steam line break based on where those sensors are  
24 located. So, I was curious where they are.

25 DR. WITTER: Yes, the protection system

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 functions are broken into kind of like three areas:  
2 core-related, the RCS-related, and, then, secondary  
3 related.

4 This slide provides an overview of the key  
5 reactor trips that are core-related. Where we have  
6 the first two bullets, the high core power level and  
7 low hot leg saturation margin trips are enthalpy-based  
8 calculations based on the conditions of the cold leg  
9 and hot leg of each of the RCS loops. And in this  
10 case, the high core power level trip is 105 percent  
11 with a 10 percent uncertainty associated with that.  
12 The low hot leg saturation margin -- we will talk a  
13 little bit more about these -- is basically there to  
14 protect the calculation of the enthalpy to ensure that  
15 we are not outside the bounds of the core relations  
16 used to determine the enthalpies.

17 Then, for the ex-core detector, so we  
18 still make use of ex-core power range and intermediate  
19 range detectors located on the outside of the reactor  
20 vessel, where we have a high neutron fluctuated change  
21 for the power range detectors and then a high neutron  
22 flux and low doubling time or short period trips for  
23 the intermediate range detectors, primarily used in  
24 the startup regions for the intermediate range and,  
25 then, at power conditions or at all conditions the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 high neutron fluctuated change.

2 And that one is made use of in the control  
3 rod ejection, as we model that with our stuff. And we  
4 will talk a little bit about that tomorrow in detail  
5 for the control rod methodology and the results from  
6 15.4.8.

7 Then, the next two sets for the linear  
8 power density and the low DNBR, these are the ones  
9 that are based upon the in-core measurement system  
10 where we make use of the readings from the self-  
11 powered neutron detectors to determine the linear  
12 power densities where we will set limiting conditions  
13 for operation and, then, also, have a reactor trip  
14 based on a high linear power density. And we use a  
15 second max for that to avoid spurious trips.

16 For low DNBR, we make use of the currents,  
17 but, then, make use of them in a different manner to  
18 determine a DNBR value for the core. And, then, we  
19 have a series of different reactor trips. We have the  
20 limited condition for operation which sets our  
21 operational limits. Then, we have a symmetric reactor  
22 trip, again, based on now a second min to avoid a  
23 spurious trip by using the first min.

24 And, then, if there were conditions in the  
25 core that would lead to an asymmetric condition or

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 reduced accuracy potential of the in-core monitoring  
2 system, we have an imbalance in rod drop threshold  
3 which will shift the DNBR trip setpoint up to a more  
4 conservative value. Then, also, if we have  
5 indications of rod drops in more than two of four  
6 divisions or meaning more than two rods have dropped  
7 into the core, it will shift to a first minimum  
8 calculation and also raise the threshold level for  
9 that DNBR calculation, again, to accommodate the  
10 increased uncertainty or reduced accuracy of the SPNDs  
11 when there's potential for an imbalance.

12 And, then, one other thing that isn't  
13 really a reactor trip, but it performs a function, a  
14 safety function, to isolate potential dilution events,  
15 is that it at a certain level of concentration  
16 measured for the boron concentration, if it drops  
17 below a certain level, it will isolate the CVCS system  
18 to prevent or to isolate the most probable condition  
19 potential for dilution. So, it will isolate the  
20 coolant volume tank. We will talk a little bit more  
21 about that trip in a slide coming up.

22 But they have that set for power  
23 conditions and then standard shutdown conditions and,  
24 also, shutdown for refueling conditions when no RCPs  
25 are running. And I have got another slide that goes

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 into a little bit more detail on that.

2 For the RCS-related functions, these are  
3 more of your kind of like standard PWR reactor trips  
4 on whether it is low-low RCS flow rate in one loop,  
5 low RCS flow rate in more than one loop, low RCP  
6 speeds. So, all those are flow-related-type reactor  
7 trips.

8 If we have low hot leg pressure or low  
9 pressurizer pressure, so low pressure reactor trips,  
10 and then we also have a high pressurizer water level  
11 to avoid high levels and protect the RCS system, and,  
12 then, also, a high pressurizer pressure as well to  
13 protect the RCS boundary conditions.

14 And, then, also, if there is a high  
15 containment pressure indicated, there will also be a  
16 reactor trip as a complete backup.

17 CHAIRMAN BANERJEE: So, on a low power  
18 REA, some system-level trip would be required, right?

19 DR. WITTER: A system-level trip like the  
20 ex-core system trip or a low-pressure trip if it is a  
21 depressurization event, yes, for rod ejection, yes.

22 CHAIRMAN BANERJEE: So, which trips would  
23 be operational?

24 DR. WITTER: All these would be  
25 operational.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 CHAIRMAN BANERJEE: Oh, all of these will,  
2 yes.

3 DR. WITTER: Right. So, for a rod  
4 ejection event, you could end up with a low  
5 pressurizer level. You could end up with a low  
6 pressurizer pressure, a low hot leg pressure, a high  
7 fluctuated trip from the low power conditions.

8 CHAIRMAN BANERJEE: Okay. And for the  
9 high power, of course, it would be the ex-core  
10 detectors?

11 DR. WITTER: For the high power, it would  
12 be ex-core detectors or potentially, again, if it is a  
13 depressurizer event, you will ultimately potentially  
14 trip on a low pressure signal and/or if the in-core  
15 monitoring system is operational, you may also trip on  
16 a low DNBR. It depends on the rod worths and things,  
17 and we will talk about that really more tomorrow. But  
18 it depends on the initial conditions and the rod  
19 worths and how much of a pulse you end up with,  
20 whether or not you actually trip on the ex-core  
21 system. If it is a worthy enough event, or if it does  
22 not trip on that initial ex-core power range  
23 detectors, you have to wait for another trip to come  
24 in, whether it is the low pressure or the low DNBR or  
25 something like that.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 CHAIRMAN BANERJEE: You are going to  
2 discuss this in detail tomorrow?

3 DR. WITTER: Yes. Yes. Yes, we will have  
4 examples of the limiting events for hot full power and  
5 hot zero power tomorrow.

6 Okay. And, then, for the secondary side,  
7 we have the low steam generator pressure, high steam  
8 generator pressure, and then we also have low and high  
9 level steam generator water level conditions. And,  
10 then, there is a trip that forms to protect an excess  
11 steam demand potential where it is the high steam  
12 generator pressure drop. And, essentially, it is a  
13 variable setpoint that monitors the steam generator  
14 pressure at the point in time you are at. So,  
15 essentially, it serves as a variable power trip, where  
16 if the pressure drops in the steam generator 100  
17 pounds less than where you're at, it will trip, as  
18 long as the pressure is less than 1088.

19 So, that this little nomenclature there  
20 means that if the rate of change is greater than 29  
21 pounds per minute, it will trip. If it drops more  
22 than 100 pounds in the sequence time of the  
23 acquisition of the signal, it will trip, as long as  
24 the pressure is less than 1088. So, there is a clip  
25 there to kind of make it so that you are not going to

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 trip with higher pressures at that point in time.

2           Ultimately, you will always have the low  
3 steam generator pressure to come in if it is a very  
4 rapid steam increase or a steam line break, to  
5 mitigate the event there. So, this is kind of like  
6 another intermediate reactor trip that can help  
7 protect the secondary side in the reactor.

8           Any questions on that?

9           MEMBER STETKAR: They need more brackets  
10 around things.

11          CHAIRMAN BANERJEE: Okay. No.

12          DR. WITTER: Well, we had to put the  
13 squiggly lines because we couldn't use the brackets  
14 because then it indicates proprietaries.

15          MEMBER STETKAR: No, no, no. It's "A or B  
16 and".

17          DR. WITTER: Oh, yes. Yes, exactly. Yes,  
18 "A or B" --

19          MEMBER STETKAR: All of those.

20          DR. WITTER: Yes.

21               Okay. So, a little bit of detail about  
22 the high core power level trip or the enthalpy-based  
23 reactor trips. The high core power level calculates  
24 the core power in each of the loops based on the cold  
25 leg and hot leg temperatures and the hot leg pressure.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 So, it determines the enthalpies of the inlet and  
2 outlet of each of the loops and determines a core  
3 power based on those loop indications.

4 It uses a constant volumetric flow rate  
5 for the loop and determines the flow rate by the  
6 density and that fixed flow rate. It is calibrated to  
7 also include a time-rated change of the mass inventory  
8 of the system. So, there's rates of change of the  
9 mass and the enthalpy to conserve the energy of the  
10 calculation. And, then, at the time of calibration,  
11 it is calibrated to the secondary calorimetric point.

12 So, it will read the same as the secondary  
13 calorimetric at the calibration and surveillance  
14 points.

15 If it reaches the 105 percent power level,  
16 it will trip off as that, as long as you have two of  
17 four of the loops indicating reactor power above the  
18 threshold.

19 Typically, the in-core monitoring system  
20 will be the primary reactor trip, but this serves as a  
21 backup in case that system is not kicking in, and it  
22 preserves the analysis space where we determine the  
23 maximum power level that we would assume for the DNBR  
24 calculations.

25 For the low saturation, it just makes use

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 of the hot leg conditions and determines the margin to  
2 saturation, and if it drops below the threshold level,  
3 then it will also cause a trip of two of four of the  
4 loops, indicate margin less than reactor trip  
5 threshold. In this case, it was about 30 BTUs per  
6 pound, which I think is about -- well, I had better  
7 not venture a guess. I won't guess on the temperature  
8 difference there.

9 And that essentially serves, it can serve  
10 as, because it is not fixed to one pressure, it allows  
11 you to have that margin for any pressure level that  
12 you may be operating at. So, if the pressure drops  
13 and your temperature is still high, that saturation  
14 margin will drop and you will trip on that low  
15 threshold.

16 CHAIRMAN BANERJEE: So, the flow rates for  
17 the low flow rate, is that measured with those elbow  
18 pressure taps or how is that done?

19 DR. WITTER: I believe yes. For the low  
20 flow rate and the low-low flow rate, those are used on  
21 the delta Ps, and they will trip off on the indicated  
22 percent flow for those trip levels for the delta P  
23 trips there.

24 For the high core power level trip here,  
25 there is no use of the flow per se in there.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 CHAIRMAN BANERJEE: Right. Yes. And  
2 these delta Ps are in the cold leg, right?

3 DR. WITTER: Yes, they are in the cold  
4 leg.

5 CHAIRMAN BANERJEE: And they are  
6 distributed around and you have got several taps in  
7 the periphery? How do you do that?

8 DR. WITTER: Yes, I am not exactly sure of  
9 the number of taps per loop that are available. It  
10 may just be one set per loop, but I am just not sure.  
11 I am not sure.

12 MS. SLOAN: Okay. We will follow up.

13 CHAIRMAN BANERJEE: Yes.

14 MS. SLOAN: We will find out.

15 DR. WITTER: Okay. The next aspect, which  
16 is not really a reactor trip function, but it serves  
17 as the chemical and volume control system isolation  
18 function, that we continuously monitor the boron  
19 concentration in the charging line. And, then, if the  
20 concentration drops below the threshold, it will  
21 isolate the system and isolate the control volume tank  
22 because that is the main source of a potential  
23 dilution.

24 Let's see. The setpoints, there are three  
25 levels of setpoints. One at power, where it monitors

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 the concentration in the reactor coolant system by  
2 monitoring the injection concentrations and having a  
3 calculation of the mass of the system and the  
4 concentration within the RCS. At power, it is set for  
5 an inlet temperature, and they are updated  
6 periodically as a function of the burnup or the boron  
7 letdown curve.

8 For the standard shutdown conditions, here  
9 it is a similar measurement of the boron concentration  
10 as a function of the injection rate and the  
11 concentration calculation. But now it also includes a  
12 temperature compensation for the mass of the system as  
13 you are cooling down.

14 So, in this case, the setpoint is actually  
15 a function of temperature and periodically updated as  
16 a function of burnup. And the curve here shows an  
17 example of the setpoint implementation into the  
18 system, where at zero gigawatt days where you will  
19 have a higher boron concentration required in the  
20 core, the boron concentration setpoint is a higher  
21 value. And, then, later during the cycle, the  
22 concentration setpoint would be lowered down, as the  
23 boron letdown curve comes down and as a function of  
24 temperature. As you cool down, obviously, you need  
25 more boron concentration to maintain your shutdown

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 margin and avoid criticality.

2 So, the setpoint measures the cold leg  
3 temperature to determine what value is the threshold  
4 value to be used, but it also uses that cold leg  
5 temperature to determine the mass of the RCS as well,  
6 to verify the concentration within the system.

7 CHAIRMAN BANERJEE: I notice that we don't  
8 have any coordinates here because I guess it is  
9 proprietary or something.

10 DR. WITTER: Right. Right. The boron  
11 concentration in ppms --

12 CHAIRMAN BANERJEE: But at least at some  
13 point, I imagine it is in the -- but if you could --

14 DR. WITTER: Right, the setpoint itself  
15 would appear in the core op report, and they would be  
16 updated for each cycle. At each of the burnup points  
17 that you would implement the new setpoints in, you  
18 would have the tabular set of the concentrations that  
19 you would use as a function of temperature in there.

20 CHAIRMAN BANERJEE: But this is just a  
21 qualitative --

22 DR. WITTER: This is a qualitative trend  
23 of how it would actually look.

24 CHAIRMAN BANERJEE: Sure. Right.

25 DR. WITTER: In the Chapter 4

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 descriptions, the boron letdown curves I think for  
2 cycle one had the boron concentrations of around 1,000  
3 ppm natural at the start of the cycle. And so, this  
4 setpoint would be somewhere less than that 1,000 ppm  
5 level. Typically, it is about half of what that hot  
6 operation concentration is.

7 CHAIRMAN BANERJEE: How widely does that  
8 vary typically with fluid temperature?

9 DR. WITTER: Well, up at this end would be  
10 your operating conditions, and at this end would be  
11 your refueling temperatures for that part of the  
12 curve.

13 CHAIRMAN BANERJEE: Okay.

14 DR. WITTER: I would have to look at the  
15 calculation. Maybe later today I can get the numbers  
16 for that.

17 CHAIRMAN BANERJEE: And any  
18 maldistribution of the boron or anything, does that  
19 affect --

20 DR. WITTER: Well, this is one reason why  
21 they have the trip set up as a function of whether or  
22 not the RCP pumps are running, which they will assume  
23 that there is adequate mixing. But, then, in  
24 shutdown, when no RCPs are running, then they will  
25 shift the concentration over to the IRWST or the in-

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 containment refueling water storage tank concentration  
2 minimum, based on that. So, that level will be  
3 shifted up to a much higher concentration if the RCP  
4 pumps aren't running to essentially handle the  
5 potential of having slugs moving around.

6 So, if the RCP pumps are not running, then  
7 it will shift to a concentration based off of a  
8 threshold from the IRWST.

9 CHAIRMAN BANERJEE: So, do you do any CFD  
10 or how do you sort of look at this phenomena?

11 DR. WITTER: In the shutdown modes?

12 CHAIRMAN BANERJEE: When the mixing may be  
13 expected to be less effective.

14 DR. WITTER: Okay. That is not my area of  
15 expertise.

16 MS. SLOAN: You're talking about the boron  
17 dilution analysis, Dr. Banerjee? I think that also is  
18 still being worked with the staff. So, we still have  
19 open issues left with the staff. I don't think we are  
20 prepared today to talk about the boron dilution  
21 evaluation.

22 CHAIRMAN BANERJEE: Okay.

23 MEMBER STETKAR: Let me ask a question  
24 about the boron. I know you do have open items, but  
25 none of them address the question I had. So, I might

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 as well get it on the table.

2 During shutdown, I understand the  
3 isolation signals. They close the two VTC suction  
4 valves and they close the RHR letdown isolation valve.

5 Those valves and the isolation signals come from only  
6 two divisions of the protection signal, the divisions  
7 one and four. And in particular, the RHR letdown  
8 isolation only comes from division four.

9 Now, during shutdown, if I have a failure  
10 or an excessive removal of boron out in the cleanup  
11 loop, which is completely unaffected by the VTC  
12 suction valves, a single failure to close that RHR  
13 letdown isolation valve would seem to keep that boron  
14 dilution going forever. Now not forever, but I want  
15 to know what type of analysis you have done to show  
16 how much boron dilution I can get during cold shutdown  
17 conditions with that single failure to isolate the RHR  
18 letdown loop, with the most likely condition being  
19 some sort of fault out in your cleanup system because  
20 that is where we always had problems with resin beds,  
21 for example, not being correctly saturated or people  
22 cutting in new resin beds, or something like that.

23 So, I am curious, and I did not see that  
24 type of questioning. The only reason I brought it up  
25 is I did not see that type of questioning in the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 staff's discussion of the boron dilutions. So, put  
2 that on your plate.

3 MS. SLOAN: Okay. I made a note.

4 MEMBER STETKAR: Thank you.

5 DR. WITTER: Okay. Next we move on to the  
6 aspects of the in-core monitoring system. This figure  
7 depicts making use of the ex-core neutron detectors,  
8 as historically has been done, which monitors the  
9 periphery of the core. It can provide a core axial  
10 power shape.

11 We have power range detectors in the top  
12 half and bottom half of the core, and, then, the  
13 intermediate range they are centered about the core  
14 center line access.

15 And historically, other plants may have  
16 used the control rod positions to help infer core  
17 internal power distribution, but, really, the aspect  
18 was you were using the ex-core detectors to give a  
19 view into the core.

20 And, then, they may have had in-core  
21 monitors for just surveillancing and providing some  
22 feedback of the core power, but not as a protection  
23 system function.

24 By making use of the in-core detector  
25 system, now we can take a slice into the core and

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 actually see the local power distributions at certain  
2 locations radially and axially within the core, and we  
3 can monitor the local power and we can directly  
4 measure the radial and axial power distribution  
5 effects as they may change due to any sort of accident  
6 that may induce any symmetry or control rods move.

7           So, this figure shows a power shape with  
8 some of the control rods from our controlling bank  
9 inserted about one-third of the way up the core. So,  
10 you can see these blue regions indicate where the  
11 control rods would be located. And you can see the  
12 power distribution kind of peak towards the bottom  
13 when you insert the rods in that far.

14           Whereas, the ex-core detectors, you  
15 wouldn't really necessarily see that radial  
16 distribution inside the core, and now we are able to  
17 see that by making use of these three-dimensional  
18 array of our 72 self-powered neutron detectors.

19           And so, now how do we make use of those  
20 in-core detectors? The first aspect of this, and some  
21 of this has been discussed in the Chapter 4  
22 presentation, but we will spend a little bit more time  
23 in some of the detail and how we actually make use of  
24 them in the transient analysis for the Chapter 15  
25 events.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1           So, for the DNBR, for one of the  
2 divisions, one of four, each of the 12 strings --  
3 there are 12 strings located regularly throughout the  
4 core. And we discuss in Chapter 4 where they are  
5 located, coming in off the lances from the top of the  
6 core. So, we have bottom penetrations for  
7 instrumentation.

8           So, we have 12 SPND strings, each of which  
9 has six elevations of SPNDs located at six different  
10 axial elevations. Each of those 12 strings is  
11 calibrated to read the hot channel. So, in this  
12 figure, the hot channel is indicated by this red line  
13 showing the hot assembly or the hot channel.

14           Each of the 12 strings at the time of  
15 calibration, using the aeroball measurement system,  
16 and getting the fine core map of the power  
17 distribution, determining the hot channel, each one of  
18 the strings, then, is set to read that flux shape or  
19 that linear heat generation rate of that hot channel.

20           So, if the hot channel is the smooth shape in the  
21 fine detail, then the six elevations of SPNDs are  
22 calibrated to read that linear heat rate for that hot  
23 channel, to reconstruct the limiting DNBR channel.

24           Those six elevations are used to  
25 reconstruct that flux shape at any given time post

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 calibration between the calibration periods there. At  
2 the time of calibration, all of them will read  
3 identical. But, then, after that, they are left to  
4 their own wiles to monitor the linear heat rates  
5 locally, but tied to that hot channel, monitoring that  
6 hot channel.

7 The DNBR is estimated by using that  
8 reconstructed power shape, but also using each of the  
9 loops. In this case, each division has its own  
10 reactor coolant loop. We use the inlet temperature,  
11 the flow signal based on the reactor coolant pump  
12 speed, and then the pressure of the pressurizer, fed  
13 into the DNBR algorithm, which is a single-channel  
14 algorithm for the online monitoring.

15 And, then, it determines a sensed minimum  
16 DNBR. It will determine the DNBR at eight different  
17 elevations in the channel for each one of those SPND  
18 locations, determine the minimum for each of the  
19 strings, and then each of those 12 strings are  
20 compared for the second minimum DNBR. And that is  
21 compared against the reactor trip threshold. If the  
22 reactor trip threshold, if the minimum DNBR is less  
23 than the threshold, it will cause the reactor to --

24 CHAIRMAN BANERJEE: So, the flow, the  
25 pumps are calibrated against your secondary site flow

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 or how are the pumps' speed --

2 DR. WITTER: Right. Right. The pump  
3 speed and the volumetric flow rate is calibrated and  
4 used as a constant. The inlet temperature and  
5 pressure are then used to determine the inlet density,  
6 to then provide a mass flow rate or a mass flux for  
7 the core signal based on the pump speeds. So, the  
8 pump speed serves as the volumetric flow rate  
9 adjuster.

10 CHAIRMAN BANERJEE: So, you said they are  
11 divided into quadrants.

12 DR. WITTER: Quadrants only by loop. Each  
13 division handles each of the RCS loops, will provide  
14 its own protection system channel calculation of the  
15 DNBR. So, each of the loops will provide the inlet  
16 signals for the thermal hydraulic boundary conditions.

17 All 12 SPNDs are used in each one of the  
18 four divisions. Then, you will end up with 12  
19 calculations times four of DNB to be then compared  
20 against the thresholds in each of the protection  
21 system divisions. If you have two of four divisions  
22 indicate the DNBR is less than the threshold, then you  
23 will have a trip.

24 CHAIRMAN BANERJEE: So, let me just try to  
25 understand the physics of this.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 DR. WITTER: Yes.

2 CHAIRMAN BANERJEE: You have got all this  
3 flow coming together in the plenum.

4 DR. WITTER: Yes.

5 CHAIRMAN BANERJEE: Somehow it gets  
6 distributed. We haven't looked into this yet. And,  
7 then, it goes to the channels.

8 DR. WITTER: Yes.

9 CHAIRMAN BANERJEE: So, you have a way to  
10 figure out how it distributes. Okay. Once it is in  
11 these channels, of course, there's all sorts of other  
12 things that go on, crossflows and so on. And  
13 eventually, you have a way to do the calculation for  
14 the hot channel.

15 So, you have a DNBR algorithm clearly  
16 because that can only be done for a channel at your  
17 testing facility at KATHY, wherever it is, or  
18 Karlstein -- I don't know -- does this stuff. And  
19 then, you reconstruct using some sort of table lookup  
20 or computer code, or whatever, the flow. So, that  
21 flow is an inferred quantity?

22 DR. WITTER: The flow is an inferred mass  
23 inlet, inlet mass flux to the channel. That's right.

24 CHAIRMAN BANERJEE: Well, there are  
25 crossflows, obviously, as well.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 DR. WITTER: There are, but that all goes  
2 into the correlation and the bias factors that are put  
3 into the simulation algorithm. It is the single-  
4 channel representation, but there are bias factors and  
5 correlations that fit it back to the full crossflow,  
6 full channel, open channel models.

7 So, this all ties back to essentially our  
8 LYNXT database and the correlation limits and CHF  
9 correlations, which are tied to the test data from  
10 Karlstein.

11 CHAIRMAN BANERJEE: I assume that you have  
12 got something that is like COBRA IV or something  
13 running.

14 DR. WITTER: Yes, that's right. Right,  
15 COBRA LYNXT, exactly.

16 CHAIRMAN BANERJEE: LYNXT. And you have  
17 some little calculation or a lookup table or something  
18 which takes your RCS speeds and reconstructs things  
19 and comes up with the flow?

20 DR. WITTER: Yes.

21 CHAIRMAN BANERJEE: Now is that all  
22 validated? Because the prediction of DNBR obviously  
23 depends on the flow as well as, of course, the power  
24 and the power shape, and all these things that go into  
25 that. But the flow is all the measurements you have

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 of the RCS pump speeds. Maybe you have the delta Ps  
2 around the taps. Okay. At this point, you have got  
3 sort of an overall flow in each of these loops, which  
4 are all getting mixed up and coming to these channels.

5 And, then, you have to reconstruct.

6 What is the sort of validation of that  
7 that is done?

8 DR. WITTER: Where that comes in is it  
9 really kind of comes into the whole setpoint and  
10 transient methodology for the topical report of  
11 ANP-10287P, where the buildup of all the uncertainties  
12 and the allowances from a hydraulic flow or the flow  
13 maldistributions, the uncertainty of the measurements  
14 of all the boundary condition inputs, and then, also,  
15 just the measurement accuracy or tracking error of the  
16 SPNDs themselves. Then, tying the single-channel  
17 algorithm to the open channel with bias factors and  
18 correction factors as well. All that gets fed into  
19 both the setpoint calculation to have a threshold that  
20 is high enough or far enough removed from the actual  
21 CHF condition, and, then, within the transient  
22 methodology, monitoring the sensor lags and inputs  
23 from that aspect of it. The two tied together handle,  
24 I guess, the uncertainties of not really knowing what  
25 that flow is in that one particular channel at the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 real-time condition.

2 So, the setpoints themselves are set up to  
3 handle the conditions of all the uncertainties  
4 associated with the real plant versus test versus  
5 open-channel versus single-channel calculations of the  
6 DNB.

7 CHAIRMAN BANERJEE: So, has that  
8 methodology -- you know, I am just coming into this in  
9 the middle.

10 DR. WITTER: Yes, yes.

11 CHAIRMAN BANERJEE: So, has that  
12 methodology -- I presume there is a whole suite of  
13 computer codes, including your LYNXT code, and so on,  
14 which have probably been accepted or approved at some  
15 point. The applicability of those codes to this  
16 specific situation with a larger plenum, with a  
17 different mixing situation, has that been explored  
18 already and discussed?

19 DR. WITTER: I imagine it is part of  
20 the --

21 MS. SLOAN: Well, let's just be clear.  
22 The methodology is specific to EPR. So, it is not a  
23 generic, it is not necessarily a generic methodology.

24 There was a special in-core trip setpoint methodology  
25 developed for EPR, and that is what Dr. Witter is

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 referring to, and it has been reviewed by the staff.  
2 I am not sure we have come -- did that come up in  
3 Chapter 4?

4 DR. WITTER: A little bit in Chapter 4.

5 MS. SLOAN: I thought we covered a little  
6 bit of this material in Chapter 4. I am not recalling  
7 the specific questions that you are asking have been  
8 raised before.

9 CHAIRMAN BANERJEE: Yes, I am simply  
10 trying to understand whether the methodology which you  
11 are using has been explored and discussed and approved  
12 by --

13 DR. WITTER: It is in the process of  
14 approval.

15 CHAIRMAN BANERJEE: Okay.

16 DR. WITTER: We don't have the approved  
17 topical report.

18 MS. SLOAN: We have the draft SER.

19 DR. WITTER: We have the draft SER.

20 MS. SLOAN: We have a draft SER.

21 CHAIRMAN BANERJEE: Okay.

22 MS. SLOAN: And we discussed this in some  
23 detail at the Chapter 4 meeting.

24 CHAIRMAN BANERJEE: But will it come to  
25 this Committee under some other chapter, the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 Subcommittee, or has the Subcommittee already seen it?

2 MS. SLOAN: I believe it came in Chapter  
3 4.

4 CHAIRMAN BANERJEE: So, it is already --

5 MS. SLOAN: It was folded in in the  
6 Chapter 4 review along with some other fuels-related  
7 methodologies.

8 CHAIRMAN BANERJEE: Okay. And so, the  
9 issues related to flow distribution, and so on, were  
10 covered at that point?

11 MS. SLOAN: You know, I think the answer  
12 is yes. We will have to follow up. I don't remember  
13 these specific questions that were asked, Dr.  
14 Banerjee. We will have to go back and look at the  
15 transcripts.

16 Okay. Go ahead, Jerry.

17 MR. HOLM: This is Jerry Holm. I work for  
18 AREVA.

19 The questions of mixing the lower plenum  
20 and the flow mixing device, those were all RAIs on  
21 Chapter 4.

22 CHAIRMAN BANERJEE: Okay.

23 MR. HOLM: They were discussed a little  
24 bit in the ACRS meeting on Chapter 4, but more in the  
25 background during the staff's review of the --

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 CHAIRMAN BANERJEE: How to go from 1/6th  
2 to full scale and --

3 MR. HOLM: Yes, all that is really  
4 addressed in that topical report, that ANP-10287 --

5 CHAIRMAN BANERJEE: Okay.

6 MR. HOLM: -- where we have a draft SER  
7 from the staff.

8 CHAIRMAN BANERJEE: And just to sort of  
9 give me an idea, I assume you used CFD tools of some  
10 sort to go from 1/6th to full scale for mixing. Or  
11 how did you bridge that gap, so that you know what is  
12 getting to these channels and things?

13 MR. HOLM: You know, LYNXT is like a COBRA  
14 code.

15 CHAIRMAN BANERJEE: Right.

16 MR. HOLM: So, it has got open-channel  
17 calculations.

18 CHAIRMAN BANERJEE: Within the core, I see  
19 how you are doing this, of course. Yes.

20 MR. HOLM: Right.

21 MS. SLOAN: I think he is asking about the  
22 scaling of the flow mixing.

23 CHAIRMAN BANERJEE: Yes.

24 MS. SLOAN: I think we are back to an  
25 earlier topic that you brought up. If we have these

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 mixing devices and they have been tested, how was that  
2 scaling evaluated for those test facilities to scale  
3 that up to applicability to EPR? I think it is a  
4 slightly different question.

5 MR. HOLM: Yes, I think that question was  
6 asked also, but we would have to go back and review  
7 the RAI response for Chapter 4.

8 MS. SLOAN: All right.

9 CHAIRMAN BANERJEE: Okay.

10 MS. SLOAN: We will go back and check it.

11 CHAIRMAN BANERJEE: So, the staff asked it  
12 and you responded?

13 MS. SLOAN: We are going to go back and  
14 check the questions.

15 CHAIRMAN BANERJEE: Okay. Because,  
16 clearly, that is an important issue, that you have got  
17 to get the flow right because your DNBR is going to be  
18 fairly --

19 DR. WITTER: Or to make sure that it falls  
20 within the uncertainties that you have accommodated --

21 CHAIRMAN BANERJEE: Sure. Yes.

22 DR. WITTER: -- in your setpoint.

23 CHAIRMAN BANERJEE: Yes. So, if you have  
24 quantified the uncertainties, of course, it is there.

25 DR. WITTER: Right.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIRMAN BANERJEE: All right.

2 DR. WITTER: Okay.

3 CHAIRMAN BANERJEE: Yes, you can move --

4 DR. WITTER: I think that is it with the  
5 DNBR part of it.

6 CHAIRMAN BANERJEE: And the DNBR, just for  
7 me to get, you have developed this, I assume, in your  
8 facilities in Germany --

9 MS. SLOAN: Yes.

10 CHAIRMAN BANERJEE: -- with full-scale,  
11 typical --

12 MS. SLOAN: We did specific testing for  
13 this.

14 CHAIRMAN BANERJEE: Yes.

15 MS. SLOAN: And there is an approved CHF  
16 correlation for use in EPR.

17 CHAIRMAN BANERJEE: With different flux  
18 shapes, and you have explored all that stuff?

19 DR. WITTER: Right, uniform and cosine.

20 CHAIRMAN BANERJEE: Yes.

21 DR. WITTER: Right.

22 CHAIRMAN BANERJEE: All right.

23 DR. WITTER: And the 14-foot height test.

24 CHAIRMAN BANERJEE: With stop peaking and  
25 things like that, well, something like that profile

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 you are showing there?

2 DR. WITTER: Whatever the standard CHF  
3 testing they would do for non-uniform flux shapes is  
4 what is in this for the ACH 2 correlation that we are  
5 using.

6 One other aspect about this is that the  
7 reactor trip thresholds, depending on the number of  
8 failed SPNDs, if one SPND of the string has failed, it  
9 will fail the entire string from consideration for  
10 DNBR calculations. And so, let's say if one fails,  
11 then you are left with 11 strings that are left to  
12 monitor the core. And so, the reactor trip thresholds  
13 will also shift based on the number of failed  
14 detectors up to allowable number of five. And then,  
15 if there are more than five, it either puts us into an  
16 LCL clock period or, if there are seven or more, then  
17 it will cause an automatic reactor trip.

18 So, there is a limitation on the number of  
19 SPNDs that can be failed, and the thresholds will  
20 shift depending on the number of failed SPNDs.

21 CHAIRMAN BANERJEE: Okay.

22 DR. WITTER: Okay. For the LPD, it is a  
23 little bit simpler, a little bit more straightforward.

24 But we make use of the currents coming from the  
25 SPNDs, and now we calibrate them in a different

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 manner.

2 This just depicts two axial slices of the  
3 six that we have. In each of the axial slices, there  
4 are the 12 SPNDs. Each one of them will be calibrated  
5 to read the local hotspot in that zone, axial zone, of  
6 measurement.

7 And so, in this case, this region here was  
8 the hotspot or the hot local linear heat rate. Each  
9 of the 12 SPNDs in that elevation will be calibrated  
10 to read that value. Each of the six elevations have  
11 their own calibration point for the hotspot in its  
12 axial zone.

13 So, each one of the six axial slices will  
14 be calibrated to read a particular hotspot value for  
15 that zone. This allows, instead of just globally  
16 tying all 72 to one spot, now we are tying six  
17 elevations to six different hotspots.

18 It can give us a feel for changing in  
19 power distributions from either global power, rod  
20 influences, xenon transients, et cetera, or  
21 asymmetries induced into the core.

22 For the high linear power density  
23 function, all 72 SPND readings are then ranked and  
24 sorted, and then compared against the reactor trip  
25 threshold. And again, now we have the second max as

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 the reactor trip to avoid a spurious trip on the first  
2 max. And again, if we have a number of SPNDs that are  
3 failed, the reactor trip set point is also lowered in  
4 this case to a more conservative value, depending on  
5 the number of failed SPNDs.

6 CHAIRMAN BANERJEE: So, is this  
7 methodology exactly the same as, say, the EPRs that  
8 you have under construction right now?

9 DR. WITTER: The setpoints, well,  
10 actually, the trip functions are identical, yes.

11 Okay. As an example of some of the  
12 aspects of having the calibrations tied at each axial  
13 elevation to one level, and making use of the LPD  
14 signals to shift the thresholds for the DNBR reactor  
15 trip threshold comparisons, this slide, it is a little  
16 busy, but it is an example of, if we calibrated one of  
17 the axial slices, in this case the hotspot was at 8.6  
18 kilowatts per foot. All 12 SPNDs in that elevation  
19 were reading identically at the time of calibration.

20 Then, if there was something that happened  
21 during the course of operation between calibration  
22 periods, in this case if, say, the centered J-09  
23 control rod dropped into the core, we have symmetric  
24 pairs of strings. Each of the 12 SPNDs have a  
25 symmetric partner. So, there are six pairs of

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 symmetric locations. In this case, the dashed line  
2 indicates the symmetric pair in this case.

3 Because the J-09 dropping in the center of  
4 the core, it is a symmetric event, this wouldn't  
5 necessarily pick up that there was an imbalance in the  
6 core, although the readings of the SPNDs at the edge  
7 of the core are indicating higher than the calibration  
8 point, and the center of the core are reading lower,  
9 just due to the flux perturbation due to the rod drop.

10 If the rod drop wasn't picked up, the rod  
11 drop 104 divisions, the center rod is in one of the  
12 divisions. If that is picked up, the imbalanced  
13 threshold would be triggered.

14 There is no imbalance indicated because  
15 all the symmetric pairs are reading identical in this  
16 case. And so, then, the DNBR normal symmetric  
17 setpoint would have to also accommodate this single  
18 rod drop in its setpoint for the conditions to monitor  
19 the DNBR. In this case, these are the LPD readings,  
20 not the DNBR readings.

21 If it happened to be an asymmetric event,  
22 or in this case if we dropped the NO7 control rod, in  
23 this case you can see the flux tilt from the hot  
24 orange side, reading about 10 kilowatts per foot, down  
25 to the colder side, about 5 kilowatts per foot. In

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 this case, the imbalance would be more likely  
2 triggered based on the calculation of the SPNDs, and  
3 it would trigger the DNBR threshold to be raised up.  
4 And then, if the DNBR happened to be lower than that  
5 higher DNBR threshold, you would have a reactor trip  
6 based on that asymmetry.

7 So, this provides an indication of sort of  
8 the real-time monitoring that the SPNDs can provide,  
9 making use of the symmetric pairs, but also making use  
10 of the maximum readings of each of the LPDs as well.

11 For asymmetry structures, asymmetric  
12 cooldowns or heatups, the asymmetry may not be as  
13 dramatic as this, but it will still be able to pick up  
14 the readings and any shifts in the power  
15 distributions, such that even if the core power  
16 remains the same, one part of the core may get hotter  
17 and ruin your heat generation rate. And you would  
18 want to monitor that for the DNBR and be able to trip  
19 if the DNBR thresholds were exceeded.

20 Okay. So, that provides the overview of  
21 the actual trip functions, how we calibrate them. Now  
22 we will talk about, well, how do we actually make use  
23 of them to verify that during the safety analysis  
24 portion of the Chapter 15 that we did not violate any  
25 of the SAFDLs.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 CHAIRMAN BANERJEE: So, I think if we  
2 could plan to finish this section, which is to slide  
3 26, and then we will take a break whenever that comes.

4 DR. WITTER: Okay.

5 CHAIRMAN BANERJEE: Okay. Is that okay  
6 with you?

7 MS. SLOAN: I need to step out for just a  
8 second. I might ask Mr. Gardner to step in for me.

9 CHAIRMAN BANERJEE: Sure. All right.

10 DR. WITTER: Okay. So, we will talk a  
11 little bit about our in-core transient methodology.  
12 Again, this is described as an overview in Section  
13 15.6.3, I believe, and also in ANP-10287P, which is  
14 the setpoint and transient methodology topical report.

15 Okay. This provides kind of a process map  
16 of how we worked through the transient analysis for  
17 any one of the events in Chapter 15. So, the normal  
18 S-RELAP runs for the monitoring or simulating the  
19 plant system responses is the typical historical  
20 method of analyzing the plant response to any of the  
21 events, whether it is uncontrolled bank withdrawal, an  
22 increase in steam flow. An S-RELAP analysis is  
23 performed for varying conditions to determine various  
24 scenarios of plant conditions and provides bounding  
25 conditions which will then be used for the inlet

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 temperature, the flow rates, and the pressures of the  
2 reactor plant and the core power levels, to provide  
3 that as a boundary condition into our transient in  
4 core simulation algorithms.

5 Also, upfront work is done in the  
6 neutronics area with our PRISM calculations, our PRISM  
7 code, to provide power distributions for multitudes of  
8 different power distributions and also provide  
9 simulated SPND responses to the core for those  
10 different power conditions.

11 CHAIRMAN BANERJEE: Where does your LYNXT  
12 code come in?

13 DR. WITTER: The LYNXT code part comes in  
14 as part of the setpoints and part of the bias factor  
15 aspects, where the online algorithm aspects are tied  
16 back to the LYNXT code through the bias factors as  
17 part of the methodology.

18 CHAIRMAN BANERJEE: So, that ANP-10287P  
19 is --

20 DR. WITTER: Is the heart of everything.  
21 Yes.

22 CHAIRMAN BANERJEE: Yes. This is actually  
23 a suite of codes?

24 DR. WITTER: It is a suite of codes that  
25 end up being combined to build up the validation of

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 the transient in-core simulation of the protection  
2 system itself.

3 So, the protection system isn't part of  
4 the S-RELAP model. Now we run it, because S-RELAP  
5 also uses the point kinetics to drive the core power,  
6 where we need core power shapes for the in-core  
7 monitoring system.

8 So, we take the core power distributions  
9 from PRISM. We take the plant bounding conditions  
10 from S-RELAP. We take the setpoints, which are  
11 determined from a series of ties to LYNXT calculations  
12 for the database of the correlations and the power  
13 shapes, to determine setpoints for wide varying  
14 conditions of pressure temperature flows in the core  
15 power distributions to determine the most limiting  
16 setpoints for DNBR and LPD to provide the 95/95  
17 setpoint values.

18 Then, we use those setpoints. Now the  
19 process is to validate those setpoints and also verify  
20 that we have adequate dynamic compensation or dynamic  
21 response of the protection system itself.

22 So, by simulating the protection system,  
23 where as RELAP currently does with a series of control  
24 variables and different things for the normal sorts of  
25 trips, like low pressurizer pressure, our in-core

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 simulation algorithms simulate the protection system  
2 for the DNBR and the LPD with the various process  
3 logic diagrams from the protection system itself to  
4 provide -- the protection itself has a series of lead-  
5 lag functions. We also handle the instrumentation  
6 response delays from the signals being provided from  
7 the S-RELAP bounding conditions.

8 So, this simulates the protection system  
9 to the best that we can and, also, handles taking in  
10 all the SPND readings, providing the filtering of  
11 them, and then determining the DNBR in an online sense  
12 using the same online algorithm that the protection  
13 system will use to determine a trip time, if there  
14 needs to be one, from the bounding conditions during  
15 the event.

16 So, for one particular PRISM power shape  
17 for SPND readings for a particular S-RELAP plant  
18 event, we then simulate that event, taking those  
19 bounding conditions, and proceed along to determine  
20 whether or not we predict --

21 CHAIRMAN BANERJEE: So, the filtering is  
22 done in the simulation --

23 DR. WITTER: Right.

24 CHAIRMAN BANERJEE: Not in PRISM?

25 DR. WITTER: Not in PRISM, no. No, PRISM

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 provides the raw SPND signals for a static condition.

2 Then, those are used, they are scaled based on the  
3 power level from those RELAP conditions to provide a  
4 response to the core for that.

5 If an in-core trip is predicted out of the  
6 two of four division logic, we will run through a  
7 series of these. We will keep track of any reactor  
8 trip time that is predicted by this in-core system,  
9 whether it is an LPD trip or a DNBR trip. We will  
10 just continue the log of those as we sequence through  
11 all the various power shapes for one particular  
12 S-RELAP event.

13 CHAIRMAN BANERJEE: What is chi again?

14 DR. WITTER: That is a quality. There is  
15 also a quality trip to verify that the calculation of,  
16 again, the enthalpy parameters, and that your quality  
17 is within the limits of the DNBR correlation itself.  
18 The correlation will have quality limits. So, to  
19 ensure that our calculation of the DNBR is adequate or  
20 correct, or within allowances, there is a trip on the  
21 quality calculation.

22 CHAIRMAN BANERJEE: Just an enthalpy  
23 calculation?

24 DR. WITTER: Right, it is an ex aequali  
25 enthalpy-based calculation. As long as that quality

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 is within the limits, that validates the DNBR  
2 calculation. So, it is a reactor trip. If that  
3 quality out of whack or if it is too high, then it  
4 invalidates the DNBR calculation and says, well, I  
5 can't trust my DNBR calculation; I had better trip the  
6 plant.

7 CHAIRMAN BANERJEE: Really?

8 DR. WITTER: So, it protects --

9 CHAIRMAN BANERJEE: So, you don't switch  
10 to a different DNBR calculation at that point?

11 DR. WITTER: No. It will trip the plant  
12 on the high quality.

13 CHAIRMAN BANERJEE: What is the limit on  
14 quality?

15 DR. WITTER: Right now it's --

16 CHAIRMAN BANERJEE: Unless you can't say  
17 it in an open session.

18 DR. WITTER: I think it is in -- it should  
19 be. Well, I had better --

20 MS. SLOAN: We will look it up. Better to  
21 look it up --

22 DR. WITTER: Right, we will look it up.

23 MS. SLOAN: -- and be certain than to try  
24 to get a --

25 DR. WITTER: It is pretty high.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIRMAN BANERJEE: Okay.

2 DR. WITTER: Okay. So, we keep track of  
3 all these in-core trips. And within the algorithm  
4 here itself, we will start the events at the limiting  
5 condition for operation. So, we bring it to the  
6 maximum, and then we will run the simulation. Then,  
7 we will continue to back off on the linear heat rate  
8 or the  $F \Delta H$ , to essentially move ourselves  
9 further and further away from the LCO until the point  
10 where we reach a maximum DNBR that we want to start  
11 the event or a minimum LPD that would start the event.

12 So, we run through a series of power  
13 shapes, initial boundary conditions, initial plant  
14 conditions, and run through the sequence for each of  
15 the event types and keep track of all these reactor  
16 trips.

17 In some cases, each of those will be  
18 checked for the amount of undershoot or overshoot. I  
19 will have a figure that shows this a little bit before  
20 everybody gets too confused.

21 But, then, ultimately, for a few of the  
22 trips that we predict, we will provide those back into  
23 the S-RELAP to have them rerun the event with that  
24 trip that we predict for the trip, and then allow them  
25 to insert the reactor trip with the scram delays and

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 the loss of offsite power. So, we also get a loss of  
2 flow event coupled to this. We run that through the  
3 simulation one more time to verify that the undershoot  
4 of our uncompensated or real DNBR does not violate.  
5 And I will show you what I mean by that.

6 CHAIRMAN BANERJEE: How many scenarios do  
7 you run through?

8 DR. WITTER: Many, many, many.

9 CHAIRMAN BANERJEE: Yes, it seems --

10 DR. WITTER: So, there is no more one  
11 limiting event where the maximum overpower and minimum  
12 pressure and come up with a fixed power shape assumed  
13 and a maximum F delta H assumed. We run through the  
14 whole suite because we are monitoring it online in  
15 real time.

16 CHAIRMAN BANERJEE: So, did, say, AREVA  
17 for its PWRs in France, for example, follow a  
18 procedure like this in the past?

19 DR. WITTER: They have followed a similar  
20 procedure where they will run through many, many,  
21 many, many, many shapes to determine their tracking  
22 error. And, then, they will apply a maximum tracking  
23 error to the different events and run through to  
24 verify that their setpoints are adequate as well.

25 So, yes.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIRMAN BANERJEE: And this is done  
2 online?

3 DR. WITTER: The online, meaning, yes, we  
4 are monitoring the shapes --

5 CHAIRMAN BANERJEE: Yes.

6 DR. WITTER: -- online, yes, and comparing  
7 them against one setpoint. So, what we are doing here  
8 is simulating multiple possible scenarios as part of  
9 the safety analysis to cover the range of potential  
10 real operating conditions that you might end up at.

11 CHAIRMAN BANERJEE: I see.

12 DR. WITTER: So, online it is just  
13 constantly monitoring the power shape and the SPND  
14 readings, determining linear power density that you  
15 are checking, and then determining a DNBR that you are  
16 checking. So, it is an online real-time estimate of  
17 the DNBR using in-core measurement systems rather than  
18 inferring it from some assumed power shapes from the  
19 ex-core detectors.

20 Okay. So, an example of what that whole  
21 process map does for one particular event, as provided  
22 in the Final Safety Analysis Report in Section 15.1.3  
23 for the increased steam flow event, this shows a  
24 typical response for the DNBR for one of the multitude  
25 of scenarios that we ran through.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1           In this case, the dark, solid line is what  
2 the transient in-core simulation algorithms would  
3 provide with all the compensation, the dynamic  
4 compensation, of the lead-lag filters and the  
5 instrumentation response for the signals providing the  
6 online algorithm in the protection systems. So, this  
7 is essentially what your plant computer would be  
8 indicating for the DNBR during this event.

9           In this case, we have our reactor trip  
10 threshold setting as the dashed line here, which has  
11 reached about six, six and a half seconds into this  
12 event. At that point in time, we provided that  
13 reactor trip time to the S-RELAP analysis, and they  
14 induced that trip at that time. Then, the rods begin  
15 to insert after the signal delays. And essentially,  
16 at this point, there is enough of a power turn to  
17 cause the DNBR to increase again.

18           What we then also check is what we call  
19 the uncompensated minimum DNBR, which is based on a  
20 bunch of static snapshots of the plant condition,  
21 bounded conditions, using a static snapshot. So, it  
22 is not a transient calculation. It is a static  
23 calculation of the DNBR using the power shape,  
24 reconstructed power shape, and then the inlet  
25 conditions, which in this case we used the core exit

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 pressure instead of the pressurizer pressure. So,  
2 that is why there is a difference between the DNBR  
3 values here.

4 And what we do is we ensure that with the  
5 post-trip and the loss of offsite power, with a loss  
6 of flow, that the undershoot of this DNBR does not  
7 drop below the reactor trip setpoint. And that was  
8 what we call our SAFDL for these conditions.

9 So, we verify for each of the events that  
10 the uncompensated minimum DNBR signal never drops  
11 below the reactor trip setpoint. This was validated  
12 for each of the events.

13 CHAIRMAN BANERJEE: But the reality that  
14 you expect is the blue line, isn't it?

15 DR. WITTER: The reality is the measured.

16 CHAIRMAN BANERJEE: Yes.

17 DR. WITTER: The measured is the blue  
18 line, right. And that can go below, as long as we  
19 trip at that point, and we verify that we don't let  
20 the uncompensated drop below the trip setpoint, then  
21 we have validated that setpoint. If, for some reason,  
22 this red line had dropped below the dashed reactor  
23 trip SAFDL line, we would either have to change the  
24 setpoint to have a higher setpoint or change the lead-  
25 lag function such that the rate of change of this blue

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 line would be such that it would be indicating the  
2 DNBR would be decreasing more rapidly, so that we  
3 would, let's say, increase the gain on the signal,  
4 such that it would trip earlier, such that the real  
5 one never dropped below it because the trip would come  
6 in earlier for that.

7 And this is just one particular case. The  
8 most challenging ones were the cases that came in most  
9 quickly or had the highest rate of change of the blue  
10 line. And so, we had to validate that, that we never  
11 let the red line drop below the dashed line for that.

12 So, that is how the DNBR events, most of  
13 the events were handled with the DNBR trip. There  
14 were a handful that were handled by the high LPD  
15 trips.

16 In this case, a very similar aspect is  
17 done, except for in this case it is just the raw  
18 reading that you are compensating or lead-lag  
19 filtering again. So, again, the dark blue line is the  
20 sensed, measured from the protection system. It  
21 reaches a reactor trip threshold for high LPD at  
22 around 16 seconds or thereabouts. We provide that  
23 trip time to the S-RELAP analysis. They put it in,  
24 put in the reactor trip signals with the scram curve  
25 for the reactivity insertion rates and, also, the loss

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 of flow. Then, we get the turn in power.

2 In this case, the turn happens much more  
3 quickly because it is truly tied to the neutronics,  
4 and not to a calculation of a delayed thermal  
5 hydraulic condition for that.

6 Let's see. That should be it with the LPD  
7 signals.

8 So, the number of cases that we look at,  
9 just for this one uncontrolled bank withdrawal event,  
10 all these dots essentially are all the various scram  
11 times that we have predicted using our transient in-  
12 core algorithm simulators, where the lower left-hand  
13 side shows the full suite of S-RELAP runs for  
14 beginning of cycle, end of cycle, reactivity  
15 conditions, different rates of addition, different  
16 magnitudes of addition of reactivity for the control  
17 banks.

18 Then, moving up and down the initial F  
19 delta H of the assembly, where we are limited by the  
20 tech spec limit of 1.7, and then it would back off, as  
21 I mentioned, automatically to continue to reduce it  
22 down to a certain level. So, we have variable  
23 multiple starting times.

24 The general trend is that, if you have a  
25 lower starting F delta H, you will have a later trip

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 time. The general trend, also, is the longer trip  
2 times or maybe not even a reactor trip based on the  
3 in-core system is such that the event was benign  
4 enough in the RELAP world that we didn't need the in-  
5 core trip. And so, later scram times meant typically  
6 lower initial F delta H's or less challenging plant  
7 responses to the system.

8 Zooming into the less-than-30-second  
9 timeframe for the reactor scram, you can see there's  
10 still a very large number of points that can be used,  
11 and we would pick one of these points along here to  
12 then provide a representative plot back into the Final  
13 Safety Analysis Report to provide one of the plots  
14 similar to this for the Chapter 15 events.

15 So, essentially, we look at several  
16 thousand different conditions as a combination of  
17 S-RELAP events, power shapes, initial starting  
18 conditions, and that we have validated each one of  
19 those through the process of the topical report  
20 methodology approach, that we have predicted for all  
21 of the cases that we predicted in core trips, all of  
22 them had valid setpoints and that we did not violate  
23 the SAFDLs in any of those cases.

24 Okay. So, finishing up, as a broad  
25 summary of those, each of the events were analyzed in

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 a spectrum of times for reactor trips, based on the  
2 in-core monitoring system, and we have several  
3 thousand renditions for each of the events.

4 The shortest time to trip and also the  
5 highest rate in signal change are typically the most  
6 adverse for the minimum DNBR undershoot and the LPD  
7 overshoot.

8 For events that were too fast to be  
9 covered by the in-core system, the limited conditions  
10 for minimum DNBR and LPD are specified to protect  
11 those SAFDLs in the events that are too fast, say, for  
12 instance, the loss-of-flow event.

13 For some combinations of 3D power shapes,  
14 initial conditions, and magnitudes, there may not have  
15 been a trip predicted by the in-core system. In those  
16 cases, either the plant system trips or there was no  
17 system trips required to protect the plant. Those  
18 would just be covered by your LCOs or no need for a  
19 trip in those cases because the SAFDLs were not  
20 challenged.

21 CHAIRMAN BANERJEE: Let me ask you, I  
22 mean, you are sampling a space of many dimensions  
23 here, right? So, you have got many thousands of  
24 possible cases, and you have run, you know, you have  
25 sampled it in some way. And, clearly, you can't do

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 everything. So, there are some cases you haven't run.

2 Are you using some statistical methodology to assure  
3 yourself that you are within some level of uncertainty  
4 due to the fact that you are sampling these thousands  
5 of cases, but not everything? Obviously, you can't do  
6 that.

7 So, do you use some statistical  
8 methodology to put a little uncertainty on what you  
9 might have missed?

10 DR. WITTER: Right. Within the setpoint  
11 determination itself, that is where the vast majority  
12 of the statistical treatment is handled. When we are  
13 doing this sample set on the transient side of it, it  
14 is allowing us to look at more of a spectrum of,  
15 instead of just one stated point that might be maximum  
16 power, let's say, in a historical sense, we are  
17 looking at the spectrum of conditions for pressure  
18 temperature flow and power, local power, that can lead  
19 to a DNBR or LPD situation.

20 CHAIRMAN BANERJEE: I presume that gives  
21 you some relief. Otherwise, why would you do that?

22 DR. WITTER: By viewing more of them --

23 CHAIRMAN BANERJEE: Yes.

24 DR. WITTER: -- it is providing a better,  
25 I guess to say, well, how many shapes do we have to

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 use to get a 95 confidence in our setpoints --

2 CHAIRMAN BANERJEE: Right.

3 DR. WITTER: -- which are 95/95,  
4 determined to be a 95/95 --

5 CHAIRMAN BANERJEE: So, you can cut down  
6 conservatism somehow this way, right? The 95/95 and  
7 looking at this?

8 DR. WITTER: By looking at more of the  
9 plant conditions over the course of all times of the  
10 event and evaluating them, taking the RELAP plant  
11 system boundary conditions for all conditions without  
12 our trip applied, until we predict a trip would be  
13 applied, we see the full spectrum of how the  
14 protection system would really sense the DNBR or LPD  
15 in the plant itself.

16 CHAIRMAN BANERJEE: I understand the  
17 methodology, but compared to a more prescriptive way  
18 of doing this, it allows you probably to set the trips  
19 somewhat lower or less. Is that what happens at the  
20 end?

21 DR. WITTER: Let me --

22 CHAIRMAN BANERJEE: I'm just asking, why  
23 do this, I mean?

24 DR. WITTER: Right, why do this?

25 CHAIRMAN BANERJEE: Yes. There's

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 obviously a reason.

2 DR. WITTER: I guess it's, well, I will  
3 see if Keith Maupin can help me out with this.

4 MR. MAUPIN: Yes. Yes, my name is Keith  
5 Maupin.

6 It sounds like the question is getting at,  
7 does the use of a statistical methodology to establish  
8 the in-core trip thresholds that is statistical in  
9 nature allow you to have less conservative trip  
10 thresholds?

11 CHAIRMAN BANERJEE: That is exactly the  
12 question.

13 MR. MAUPIN: And my thinking on that is  
14 that, absolutely, it does. It allows us to, by  
15 sampling a large number of situations or input  
16 conditions, establish what the 95/95 is for that,  
17 rather than to take what has been identified as the  
18 most limiting combination of conditions.

19 CHAIRMAN BANERJEE: Right.

20 MR. MAUPIN: That is the subject matter in  
21 1037.

22 CHAIRMAN BANERJEE: So, how much margin?  
23 I mean, so you know, if you take something which is  
24 different, but let's take a LOCA calculation. If you  
25 go into a very prescriptive way of doing this, rather

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 than sampling of 59 runs or whatever people do --

2 MR. MAUPIN: Right.

3 CHAIRMAN BANERJEE: -- it buys you quite a  
4 bit, a couple of hundred degrees, actually, in some  
5 cases, not in all cases, you know.

6 MR. MAUPIN: In LOCA, is that what you  
7 mean?

8 CHAIRMAN BANERJEE: Yes. I don't know in  
9 your case, but I know of cases where it does, okay,  
10 for LOCAs. But what does this do to you in terms of  
11 margins? I mean, does it allow you to sort of make  
12 less conservative trip limits by a certain fairly  
13 significant amount?

14 MR. MAUPIN: I do understand the question.

15 CHAIRMAN BANERJEE: Yes.

16 MR. MAUPIN: I don't know that I know the  
17 answer.

18 MS. SLOAN: Yes, I don't think we know how  
19 to answer that.

20 DR. WITTER: Right, because the concept of  
21 margin kind of disappears with --

22 CHAIRMAN BANERJEE: I realize it  
23 disappears.

24 (Laughter.)

25 I mean it is a nice way to -- you know,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 you are saying 95/95, but, then, you may ask, why not  
2 99/99 or something, you know. It may be that it is  
3 because the staff allows 95/95.

4 DR. WITTER: Right.

5 CHAIRMAN BANERJEE: Right? That's the  
6 answer probably.

7 (Laughter.)

8 Well, let me think about this. But I  
9 think I have got the picture. So, it does allow you  
10 to be less conservative in some ways than a very  
11 prescriptive sort of way of doing this?

12 DR. WITTER: Right, and it allows, the  
13 conservatism gets applied into the setpoint itself  
14 with the accommodation for all the measurement  
15 accuracies or inaccuracies and, then, other  
16 accommodations that need to be put in there for even  
17 just the algorithm uncertainties and those sorts of  
18 things.

19 CHAIRMAN BANERJEE: Sure. You put in all  
20 your uncertainties that you have to.

21 DR. WITTER: Right. Almost all that stuff  
22 now appears into the setpoint itself.

23 CHAIRMAN BANERJEE: Yes.

24 MS. SLOAN: And, Jonathan, just to be  
25 clear, it is not the first time a statistical DNB

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 methodology has been applied to a power plant in the  
2 U.S. That is not unique --

3 DR. WITTER: No. Right.

4 MS. SLOAN: -- in and of itself.

5 CHAIRMAN BANERJEE: Do you know how many  
6 other cases there have been or how widespread this  
7 practice is?

8 MS. SLOAN: We have an approved  
9 methodology. I am going to look over at Jerry. We  
10 have a statistical DNB methodology generically for  
11 operating plants?

12 MR. HOLM: Yes, this is Jerry Holm.

13 I think certainly all the Westinghouse and  
14 Combustion Engineering design plants we support we  
15 use a statistical DNBR methodology.

16 CHAIRMAN BANERJEE: For your fuel reloads  
17 and things?

18 MR. HOLM: Right. Yes. I am not really  
19 familiar with the B&W plants. They may also use it.  
20 Marty says, yes, for the B&W plants, we use the  
21 statistical DNB.

22 Now the U.S. EPR perhaps is more  
23 extensive. We treat more parameters statistically.  
24 But, certainly, on the other plants we are using a  
25 statistical DNB methodology where we are combining

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 quite a few uncertainties, but I think we have  
2 extended it for the U.S. EPR to a more extensive with  
3 this ANP-10287.

4 CHAIRMAN BANERJEE: Okay. Well, we use it  
5 for LOCAs. We can use it here. Why not? It is the  
6 same idea.

7 (Laughter.)

8 Okay.

9 DR. WITTER: Okay. Then, the last two  
10 slides are really just meant to provide a suite of the  
11 events that were considered and made use of the in-  
12 core SPND-based reactor trips. And in this case, I  
13 have provided the example plots for the 15.1.3 for the  
14 increased steam flow and, then, the 15.4.2 for the  
15 uncontrolled bank withdrawal events. But we also  
16 considered the trips were also included in for the  
17 decrease in feedwater flow, the increase in feed flow,  
18 for the inadvertent opening of a steam generator  
19 relief valves, for other control misoperations, and,  
20 then, for the inadvertent opening of pressurizers.  
21 So, increase in steam demands, cooldowns, and things  
22 like that. All of those events demonstrated the  
23 adequacy of the reactor trips.

24 For other events, they may have also  
25 included the in-core trips, but also may have either

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 been too fast for the in-core trip system to be picked  
2 up, so, therefore, the limiting condition for  
3 operation thresholds were used, or the events may have  
4 been part of that event suite that did not call for an  
5 in-core trip because they were benign enough, or they  
6 would have tripped on something else earlier than  
7 called for for the DNBR.

8 So, for instance, the increase in steam  
9 flow, the high steam generator pressure drop trip, if  
10 it was a large enough increase in steam flow, the  
11 pressure drop was quick enough to come in to trip the  
12 plant before the DNBR trip would have been required.

13 For the loss for forced reactor coolant  
14 flow, that is the DNBR event that set the LCO. And  
15 so, that set the initial LCO, the 2.5 level, to ensure  
16 adequate protection, because that event happens too  
17 quickly for the DNBR in-core system to pick that up.

18 The loss of one pump, like a locked rotor  
19 or a broken shaft, is bounded by the loss of the full  
20 RCP flow.

21 For the spectrum of postulated rod  
22 ejection accidents, we will talk about that tomorrow,  
23 but that is a postulated accident and it is covered by  
24 the methodology report in 10286P, which we will talk  
25 about tomorrow and the results for that event tomorrow

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 as well. In that case, you are allowed to have fuel  
2 failures, but they have to stay less than the limit  
3 prescribed by the radiological release.

4 And I think that is the last slide for my  
5 part of the presentation.

6 CHAIRMAN BANERJEE: Well, I think what we  
7 should do probably is take a break now and come back a  
8 little bit early. So, we were supposed to be back at  
9 10:40. So, instead of that, let's come back at 10:35.

10 I think you have got enough time to cover  
11 your 59 slides by 2:15 today. So, if needed, we can  
12 always shrink lunch a little.

13 So, with that, we are just going to take a  
14 break.

15 We are off the record.

16 (Whereupon, the foregoing matter went off  
17 the record at 10:20 a.m. and resumed at 10:38 a.m.)

18 CHAIRMAN BANERJEE: We are going to go  
19 back in session.

20 So, let's hand this back to Sandra. Take  
21 it from here.

22 MS. SLOAN: Okay. I am going to turn it  
23 over to Mr. Brownson to talk about the event  
24 evaluation in Chapter 15.

25 MR. BROWNSON: Okay. We just finished the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 discussion of the background information. We are now  
2 going to proceed with the discussion of the Chapter 15  
3 results.

4 We will begin with a presentation of the  
5 safety analysis results, followed by the discussion of  
6 the radiological results by Mr. Perez.

7 The U.S. EPR non-LOCA methodology is  
8 conservative and deterministic methodology, as  
9 presented in the codes and methods applicability  
10 report for the U.S. EPR, that is ANP-10263PA.

11 The methodology follows the guidance and  
12 requirements as outlined in NUREG-0800, Standard  
13 Review Plan, and Regulatory Guide 1.206.

14 The non-LOCA methodology has been updated  
15 for the U.S. EPR to obtain initial fuel conditions  
16 from the COPERNIC computer code rather than RODEX2A.  
17 One of the advantages of this is that COPERNIC allows  
18 for the generation of burnup-dependent fuel  
19 characteristics.

20 The non-LOCA methodology utilizes S-RELAP5  
21 to provide system fluid boundary conditions for  
22 external DNBR, fuel centerline melt, and radiological  
23 evaluations.

24 In accordance with regulatory guidance,  
25 the U.S. EPR safety analyses do not model non-safety-

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 related functions unless their operation is  
2 detrimental to the event progression. Key parameters,  
3 such as protection system setpoints, are biased for  
4 conservatism and uncertainty in accordance with Reg.  
5 Guide 1.105.

6 Protection system trip and safety function  
7 setpoints are biased in the most challenging direction  
8 for an event.

9 As part of the methodology, the most  
10 limiting single failure is accounted for as well as  
11 sensitivities performed to consider the effect of loss  
12 of offsite power. Operator actions are assumed not to  
13 be taken until 30 minutes after event initiation.  
14 Limiting radial and axial power distributions are  
15 evaluated as part of the fuel performance evaluations.

16 Additionally, when applicable, preventative  
17 maintenance of key equipment is assumed in order to  
18 challenge plant performance.

19 Events are evaluated for all operating  
20 modes and power ranges from hot zero power to hot full  
21 power. Reactivity coefficients are determined at  
22 beginning of cycle, most reactive conditions, and end  
23 of cycle.

24 I would like to do a quick review of the  
25 Chapter 15 contents. During my presentation, I do not

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 plan to go into detail on the individual events of  
2 each category. I will, however, be presenting a  
3 summary of those events highlighted. These represent  
4 those events that are considered challenging to the  
5 event category acceptance criteria.

6 15.0.3 is the radiologic consequences.  
7 Pedro will be discussing the results of that section  
8 after I finish.

9 15.1, increase in heat removal by a  
10 secondary system. We will be talking about the  
11 increase in steam flow and the steam system piping  
12 failure, decrease in heat removal, loss of external  
13 load. Actually, we are not discussing that one. We  
14 are discussing turbine trip and inadvertent main steam  
15 isolation valve closure and feedwater line break  
16 inside and outside containment.

17 Decrease in RCS flow, we are discussing,  
18 the complete loss of forced reactor coolant flow, and  
19 reactor coolant pump rotor seizure.

20 MEMBER STETKAR: Doug?

21 MR. BROWNSON: Yes?

22 MEMBER STETKAR: If we have questions  
23 about some of the events that you are not going to  
24 explicitly highlight, when is the best time --

25 MR. BROWNSON: Probably during when we are

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 discussing that event category.

2 MEMBER STETKAR: With that category?

3 Okay, got it. Thanks.

4 MR. BROWNSON: Reactivity and power  
5 distribution anomalies, we are going to have a summary  
6 of the control rod misoperation, rod drop, and the rod  
7 ejection analysis.

8 15.5, increase in RCS inventory, we will  
9 discuss both of these events, inadvertent operation of  
10 ECCS or EBS, and chemical and volume control system  
11 malfunction.

12 And decrease in RCS inventory, we will  
13 discuss the inadvertent opening of the PSRV and steam  
14 generator tube rupture. 15.65 will be the topic of a  
15 later ACRS meeting.

16 And, then, we will finish up with a  
17 discussion of the anticipated transient without scram.

18 CHAIRMAN BANERJEE: So, when is this loss-  
19 of-coolant meeting going to be, Derek?

20 MR. WIDMAYER: We are talking about the  
21 last week of March.

22 CHAIRMAN BANERJEE: Okay. That is fixed  
23 now?

24 MS. SLOAN: No, that is the methodology  
25 for realistic LOCA. That is the methodology only. To

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 my knowledge, it is not the LOCA part of the FSAR --

2 MR. WIDMAYER: Is that right?

3 MS. SLOAN: -- 15.65.

4 MR. COLACCINO: This is Joe Colaccino of  
5 Projects.

6 What you have in front of us, Dr.  
7 Banerjee, is the first part of Chapter 15 with the  
8 exception of 15.65. So, the staff is working towards  
9 getting that safety evaluation with open items  
10 probably sometime in the late March timeframe.

11 And I was just talking about that with Joe  
12 Donoghue just a little bit ago because I knew that  
13 that's where you are heading with some of your  
14 answers.

15 So, probably when we would be presenting  
16 that information to the ACRS would probably be in a  
17 May slot, if we have that slot available to us. That  
18 is just my guess right now, looking at that. We are  
19 evaluating that.

20 Also, recognize, too, that it is 15.65  
21 without the portion on downstream effects.

22 CHAIRMAN BANERJEE: Okay.

23 MR. COLACCINO: I hope that helps you.

24 CHAIRMAN BANERJEE: Yes. Okay. Go ahead.

25 MR. BROWNSON: Okay. Moving into a

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 description of the increase in heat removal, the  
2 increase in steam flow event includes a spectrum of  
3 cases covering the ranges of all six turbine bypass  
4 valve openings. Each valve represents 10 percent of  
5 full steam load capacity, and that is not per loop;  
6 that is total steam load.

7 As a bypass valve is opened, the turbine  
8 control valve opens wider in order to maintain full  
9 steam flow to the turbine to generate 100 percent  
10 power. The resulting increase in steam flow causes  
11 heat transfer in the steam generators to increase and,  
12 consequently, reduces primary system temperatures.

13 Because of the common header prior to the  
14 turbine control valves, the resulting steam increase  
15 and overcooling effects is realized in all four steam  
16 generators. The reduction in primary system fluid  
17 temperatures may cause an increase in reactor power  
18 due to reactivity feedbacks.

19 The event is terminated due to reactor  
20 trips on load DNBR, high linear power density, or if  
21 the steam flow is great enough on high steam generator  
22 pressure drop.

23 For all scenarios evaluated, all  
24 acceptance criteria are met.

25 Moving on to the steam line break event --

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 MEMBER STETKAR: Doug?

2 MR. BROWNSON: Yes?

3 MEMBER STETKAR: Now I am going to start  
4 asking you questions.

5 MR. BROWNSON: Okay.

6 MEMBER STETKAR: On the increase in steam  
7 flow event, what happens if an MSIV fails to close?

8 MR. BROWNSON: The MSIVs do not close  
9 during this event.

10 MEMBER STETKAR: The flow is not large  
11 enough to get you the MSIV closure signal?

12 MR. BROWNSON: It will if I think all six  
13 valves pop open and you get a reactor trip on high  
14 pressure drop, steam generator high pressure drop.  
15 The MSIV will close.

16 MEMBER STETKAR: That would certainly  
17 close the MSIV.

18 MR. BROWNSON: Right.

19 MEMBER STETKAR: That is the MSIV closure  
20 signal.

21 MR. BROWNSON: Right.

22 MEMBER STETKAR: So, my question is, if  
23 this spectrum includes everything up to -- is it up to  
24 and including or up to --

25 MR. BROWNSON: Up to and including, all

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 six valves.

2 MEMBER STETKAR: So, my question is, if it  
3 is up to and including that, and you would get an MSIV  
4 closure signal, what are the consequences if an MSIV  
5 fails to close and why hasn't that been analyzed?

6 MR. BROWNSON: It would have been analyzed  
7 as part of the six valve closures. At that point, you  
8 would end up with all four of your steam generators  
9 bottled up and your pressure would increase due to the  
10 heat transfer. You would get the reactor trip on the  
11 high pressure drop as well as --

12 MEMBER STETKAR: I guess what I am asking  
13 you is, do you have an analysis that shows that  
14 transient with an MSIV failure? Have you analyzed  
15 that event?

16 MR. BROWNSON: Paul Bergeron.

17 MR. BERGERON: I think there may be a  
18 slight --

19 MS. SLOAN: Paul, can you introduce  
20 yourself?

21 MR. BERGERON: My name is Paul Bergeron,  
22 representing AREVA.

23 And I think I heard you say that you  
24 shifted to the increase in feed flow event, correct?

25 MEMBER STETKAR: No, no. No, this is

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 increase in steam flow. If, indeed, the spectrum of  
2 increase in steam flow goes all the way up to and  
3 including all six --

4 MR. BERGERON: Yes.

5 MEMBER STETKAR: -- turbine bypass valves  
6 opening --

7 MR. BERGERON: Right.

8 MEMBER STETKAR: -- which is 60 percent  
9 full flow, my question is, have you done an analysis  
10 of that limiting event with a single failure of the  
11 MSIV to close?

12 MR. BERGERON: Correct. Yes, we have.

13 MEMBER STETKAR: You have?

14 MR. BERGERON: Yes. The spectrum includes  
15 all the way up to the -- and if the MSIVs would  
16 have --

17 MEMBER STETKAR: Okay. It wasn't clear to  
18 me when I was reading that analysis because it says  
19 there is no single failure which will make this event  
20 more severe. And it seems like the cooldown, if an  
21 MSIV fails to close, would be --

22 MR. BERGERON: Yes, I understand.

23 MEMBER STETKAR: -- reasonably  
24 substantial, the post-trip cooldown.

25 MR. BERGERON: Yes. I mean, basically,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 this event takes you up to the six turbine valves. If  
2 you haven't challenged the MSIVs, the steam line break  
3 would be the event where the MSIVs would be  
4 challenged. And that spectrum just extends this one  
5 for the turbine valves.

6 MEMBER STETKAR: Except that the steam  
7 line break is presumed upstream from the MSIVs. So,  
8 you need two MSIVs to fail to get you an overcooling;  
9 whereas, here, since this is downstream --

10 MR. BERGERON: We actually look at steam  
11 line breaks on both sides --

12 MEMBER STETKAR: Okay.

13 MR. BERGERON: -- of the MSIV.

14 MEMBER STETKAR: That also wasn't clear  
15 from what was in the FSAR.

16 MR. BERGERON: Okay. Yes. No, we  
17 actually look at different locations for the steam  
18 line break --

19 MEMBER STETKAR: Okay.

20 MR. BERGERON: -- which includes upstream  
21 and downstream --

22 MEMBER STETKAR: Okay. Okay.

23 MR. BERGERON: -- of the MSIV.

24 MEMBER STETKAR: Okay.

25 MR. BERGERON: And the single failure of

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 the MSIV would be accounted for.

2 MEMBER STETKAR: And that spectrum is  
3 included. Okay.

4 One of the reasons is I had some problems  
5 as I read through the FSAR. There was a discussion in  
6 Section 15.0.0.3.8 about what limiting single failures  
7 are possible and which are not possible. The MSIVs  
8 were not listed in that section as not possible. So,  
9 I assumed that they were a possible single failure.

10 MR. BERGERON: Correct.

11 MEMBER STETKAR: And, then, I started to  
12 think about whether they were included, in which  
13 analysis. So, if I have assurance that you have  
14 included both the upstream and downstream steam line  
15 breaks with the MSIV failure, then I am pretty happy  
16 about that.

17 MR. BROWNSON: The information listed in  
18 the FSAR is the single most limiting failure for the  
19 event presented in the FSAR, not necessarily the whole  
20 range of all failures.

21 MEMBER STETKAR: Well, that is why -- I am  
22 looking at Table 15.0-11, Single Failures Assumed in  
23 the Accident Analysis, and for increase in steam flow  
24 it says one protection division. Now one protection  
25 division will not fail a single MSIV.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 MR. BERGERON: Correct.

2 MR. BROWNSON: Right.

3 MEMBER STETKAR: And, then, it says,  
4 "There is no single failure which will make this event  
5 more severe." A failure of a protection system  
6 division is inconsequential. The protection system is  
7 single failure-proof due to its redundancy.

8 So, I was led to believe from what is in  
9 the FSAR that there wasn't any single failure that  
10 could make anything in this full range of these steam  
11 flow increase events more severe. And it seems to me  
12 like a MSIV failure would.

13 MR. BERGERON: But the single failure  
14 listed in that table is the limiting single failure  
15 for that event relative to the criteria of that event.

16 For example, we are looking at -- this is an AOO --  
17 so, we are looking at DNB and linear power density.

18 So, for that event, and it turns out, I  
19 think, for the excess steam demand or the increase in  
20 steam flow, it is a 50 percent flow case, not the full  
21 case, because in the full case you get a trip right  
22 away with the steam generator pressure drop feature.

23 MEMBER STETKAR: Okay. Okay. Thanks.

24 MR. BROWNSON: Okay. Moving on to the  
25 steam line breaks, we evaluated both pre-reactor trip

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 and post-reactor trip scenarios. For both scenarios,  
2 the spectrum of break sizes were considered, both in  
3 containment and outside containment, upstream,  
4 downstream of the MSIV, depending on break size and  
5 number of protection system functions that activate a  
6 reactor trip.

7           Following the initiation of the steam line  
8 break, the four steam generators depressurized through  
9 the break due to the steam line common header.  
10 However, the individual steam lines are soon isolated  
11 due to steam generator high pressure drop, which also  
12 initiates a reactor trip.

13           The limiting single failure for this event  
14 is the failure of the MSRCV to close in one of the  
15 unaffected steam lines following steam line isolation.

16           MEMBER STETKAR: Doug, if you look at a  
17 steam line break inside containment, I understand you  
18 took the steam line break outside because that delays  
19 the reactor trip due to the adverse environmental  
20 conditions for the steam pressure transmitters. For a  
21 steam line break inside the containment, since all  
22 steam generators will continue to feed that break  
23 through the crossconnect header --

24           MR. BROWNSON: Okay.

25           MEMBER STETKAR: I am not a thermal

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 hydraulics guy.

2 MR. BROWNSON: Okay.

3 MEMBER STETKAR: Let me preface that.

4 MR. BROWNSON: Okay.

5 MEMBER STETKAR: Pumps and pipes and  
6 valves are about all I can do.

7 But if you have a steam line break inside  
8 the containment, all four steam, you know, you will  
9 feed, the broken steam generator will feed that break,  
10 and the other three will feed it through the  
11 crossconnect --

12 MR. BROWNSON: Up to the point of MSIV  
13 closure.

14 MEMBER STETKAR: Now the question is, is  
15 there a substantial delay of the MSIV closure signal  
16 due to the location of the pressure transmitters  
17 outside the containment? In other words, that line is  
18 going to hang up a little bit --

19 MR. BROWNSON: Right.

20 MEMBER STETKAR: -- because the other  
21 steam generators are still heating it.

22 MR. BROWNSON: Right.

23 MEMBER STETKAR: Is the delay for the  
24 steam line break inside the containment longer or  
25 shorter than the delay that you took for the break

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 outside with the adverse environmental conditions?

2 MR. BROWNSON: Depending upon the break,  
3 of course, this is going to depend upon the break size  
4 and how quickly you are depressurizing the system.

5 MEMBER STETKAR: Yes.

6 MR. BROWNSON: I think if it is a large  
7 enough break to catch us on -- if it is a large enough  
8 break to catch up steam line pressure drop, I don't  
9 think -- the location of the break is not going to  
10 matter. The pressure drop is going to be rapid enough  
11 that it doesn't matter what that distance from that  
12 pressure sensor is going to be.

13 And if the location of the break is near  
14 the pressure sensor --

15 MEMBER STETKAR: Yes.

16 MR. BROWNSON: That's going to be another  
17 question?

18 (Laughter.)

19 MEMBER STETKAR: No. I'm sorry. I am not  
20 going to fine-tune it that closely.

21 MR. BROWNSON: Okay. But, yes, if the  
22 break is small enough that you are not going to be  
23 caught on pressure delta P, one of our other  
24 protection system functions would catch us, if it was  
25 slow enough, if that pressure decrease was slow enough

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 that our pressure, steam generator pressure, dropped  
2 and the protection system trip did not catch us, more  
3 than likely, another function did step in.

4 MEMBER STETKAR: Well, it would be  
5 something like probably steam generator low level.

6 MR. BROWNSON: Right.

7 MEMBER STETKAR: But that has also got to  
8 be delayed because those sensors are inside the  
9 containment, and it will take a while to blow down  
10 that steam generator --

11 MR. BROWNSON: Correct. Correct.

12 MEMBER STETKAR: -- to a low-level  
13 setpoint. So, I was just curious about that relative  
14 timing because the accident analysis in Chapter 15  
15 emphasizes that point, about how carefully you  
16 selected the break location for the adverse  
17 environmental effects for the --

18 MR. BROWNSON: Right. The hostile  
19 environment, yes.

20 MEMBER STETKAR: -- hostile environment --

21 MR. BROWNSON: Right.

22 MEMBER STETKAR: -- for the location of  
23 those particular pressure sensors. And I was trying  
24 to understand whether, indeed, that is actually the  
25 most bounding break location from an event timing

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 perspective, because it all deals with the delay in  
2 the protection system signal.

3 MR. BROWNSON: Paul, do you have anything  
4 to add to clarify that?

5 MR. BERGERON: No. I think we looked at  
6 several locations and accounted for the fact of where  
7 the pressure sensors were using the harsh  
8 uncertainties.

9 MEMBER STETKAR: Yes. The question is,  
10 you know, a break inside the containment --

11 MR. BERGERON: Right.

12 MEMBER STETKAR: -- you don't have to  
13 penalize the pressure sensors for the harsh  
14 environment.

15 MR. BERGERON: Right.

16 MEMBER STETKAR: On the other hand, could  
17 there be other things that inserted an additional  
18 delay in the signal that is more than compensated by  
19 the harsh environment?

20 MR. BERGERON: I think for the steam  
21 system piping failures that the break is big enough  
22 that you get a relatively early trip, and that the  
23 isolation of the MSIVs that would isolate the --

24 MEMBER STETKAR: The other three.

25 MR. BERGERON: -- the other three, it is

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 not that far behind.

2 MEMBER STETKAR: Yes. Okay. I mean that  
3 is the relative timing that I am talking about.

4 MR. BERGERON: Right.

5 MEMBER STETKAR: Yes.

6 MR. BERGERON: Right. Yes, and we did a  
7 spectrum of breaks, so that that spectrum I am sure  
8 caught --

9 MEMBER STETKAR: Spectrum inside and  
10 outside?

11 MR. BERGERON: Yes.

12 MEMBER STETKAR: Okay.

13 MR. BROWNSON: Following the initiation of  
14 the break, four generators depressurize through the  
15 break, common header. Individual steam lines are soon  
16 isolated due to steam generator high pressure drop,  
17 which also initiates a reactor trip. The limiting  
18 single failure for this event is failure of the MSR/V  
19 to close in one of the unaffected steam generators.

20 Failure of this control valve in one of  
21 the unaffected generators further aggravates the RCS  
22 cooldown until the pressure in that steam line drops  
23 below the MSIV's closure setpoint.

24 The post-reactor trip is the most limiting  
25 of the two scenarios predicting a return to power for

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 the hot zero power case of approximately 23 percent  
2 rated thermal power. Fuel damage due to cladding  
3 strain is predicted to occur, but radiological  
4 releases are within the acceptance criteria.

5 Moving on to the decrease in heat removal  
6 from the secondary side, the two events that most  
7 challenge the primary and secondary pressure  
8 boundaries are the turbine trip and MSIV closure,  
9 single MSIV closure. The turbine trip event is the  
10 most limiting RCS overpressure event, and the single  
11 MSIV closure event is the most limiting secondary  
12 overpressure event.

13 Both events have a most limiting single  
14 failure of an MSRT to open. The peak RCS pressure  
15 calculated for the turbine trip event is 2785 psia,  
16 which is below the acceptance criteria. The peak  
17 secondary pressure calculated for the single MSIV  
18 closure event is 1567 psia, which, again, is below the  
19 acceptance criteria.

20 In addition to the failure of the MSRT,  
21 the single MSIV closure event also assumes a  
22 preventative maintenance on the low setpoint MSSV on  
23 the steam line of the MSIV closure. This results in a  
24 greater challenge to the secondary pressure acceptance  
25 criteria.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 Accounting for a similar preventative  
2 maintenance during the turbine trip evaluation was not  
3 necessary, as the secondary pressure is shared between  
4 all four steam generator lines, due to the steam line  
5 common header, as the MSIVs do not close for the  
6 turbine trip event.

7 Feedwater line break is a postulated  
8 accident that helps establish the adequacy of the  
9 emergency feedwater capacity. A spectrum of feedwater  
10 line breaks and sizes and locations is evaluated.  
11 Both peak primary and secondary pressure scenarios are  
12 assessed.

13 For the peak primary system pressure  
14 scenario, a single failure of an EFW pump train and  
15 preventative maintenance of a second EFW are assumed  
16 on two of the unaffected steam generators.

17 For the peak secondary pressure scenario,  
18 a single failure of an MSRT to open is taken on one of  
19 the unaffected steam lines.

20 And on this same line, preventative  
21 maintenance of a low setpoint MSIV is assumed. A  
22 second preventative maintenance of an EFW pump train  
23 is assumed on a second unaffected steam line.

24 Operator actions are credited at 30  
25 minutes to realign the EFW from the affected steam

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 generator to one of the steam generators with an  
2 inoperable EFW. The operator also is credited with  
3 tripping the RCPs to the two loops without EFW.

4 Again, all acceptance criteria are  
5 satisfied for this event.

6 MEMBER STETKAR: Doug, I am going to stray  
7 a bit here, but it is the only place I can ask this.

8 In the feedwater line break event and the  
9 two others that I can't find my notes, but turbine  
10 trip, closure of an MSIV, and feedwater pipe break  
11 event, one of the limiting single failures was failure  
12 of an MSRT to open.

13 I will go back to the section of the FSAR  
14 that I cited early, 15.0.0.3.8. The MSRIVs, the main  
15 steam relief isolation valves, are explicitly  
16 highlighted in that section as not being considered as  
17 single failures in --

18 MR. BROWNSON: Right.

19 MEMBER STETKAR: -- the accident analyses  
20 because the valve is designed to be single failure-  
21 proof.

22 MR. BROWNSON: Correct.

23 MEMBER STETKAR: But here it sounds like  
24 they were considered as single failures.

25 MR. BROWNSON: No. From the initial

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 presentation, the MSRTs consist of two valves in  
2 series.

3 MEMBER STETKAR: Yes.

4 MR. BROWNSON: It is the MSRCV, the  
5 control valve, and the isolation valve. It is the  
6 control valve that is assumed to fail.

7 MEMBER STETKAR: Fail to open?

8 MR. BROWNSON: Fail to open or fail to --

9 MEMBER STETKAR: It is normally open. So,  
10 it doesn't --

11 MR. BROWNSON: It fails closed, yes.

12 MEMBER STETKAR: Oh.

13 MR. BROWNSON: First, open and then goes  
14 closed.

15 MEMBER STETKAR: But an MSIV can fail to  
16 close. That is a single failure.

17 MR. BROWNSON: Yes, it could stick open,  
18 yes.

19 MEMBER STETKAR: But an MSRIV cannot fail  
20 to open? Are both of those statements true? That  
21 none of the transient or accident analyses account for  
22 failure of an MSRIV isolation valve failure to open?  
23 Is that true? Paul?

24 MR. BERGERON: The MSIV or the MSR, the  
25 IV --

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER STETKAR: Main steam relief  
2 isolation valve.

3 (Laughter.)

4 MR. BERGERON: Yes.

5 MEMBER STETKAR: The relief isolation  
6 valve. We will get away from the acronym.

7 MR. BERGERON: The added single failure --

8 MEMBER STETKAR: And the --

9 MR. BERGERON: Because it is in series  
10 with another valve that potentially could fail closed,  
11 we have taken the conservative assumption that that  
12 relief train would not be available and it would be a  
13 single failure of the CV. Because, basically, what  
14 happens, the IV would open, and that is single-proof  
15 to an overpressure event.

16 MEMBER STETKAR: Yes.

17 MR. BERGERON: That would open, and the CV  
18 would control the pressure.

19 MEMBER STETKAR: Yes, normally.

20 MR. BERGERON: Normally.

21 MEMBER STETKAR: Right.

22 MR. BERGERON: We are postulating that  
23 that CV, since it is not single failure-proof --

24 MEMBER STETKAR: Goes closed.

25 MR. BERGERON: -- is driven shut.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER STETKAR: Okay.

2 MR. BERGERON: Now it is a 40-second  
3 valve, so that we could probably credit it before it  
4 goes fully shut.

5 MEMBER STETKAR: But you don't?

6 MR. BERGERON: But we have chosen not  
7 to --

8 MEMBER STETKAR: Okay.

9 MR. BERGERON: -- in the safety analysis.

10 MEMBER STETKAR: I understand that then.  
11 Is it that carried through for things like small  
12 LOCAs?

13 MR. BERGERON: You mean as far as the IV?

14 MEMBER STETKAR: The way you explained it,  
15 I don't care whether it is the IV failing to open --

16 MR. BERGERON: Right.

17 MEMBER STETKAR: -- or the CV closing --

18 MR. BERGERON: Right.

19 MEMBER STETKAR: -- because, either way,  
20 you don't get steam relief through the control valve.

21 MR. BERGERON: Yes.

22 MEMBER STETKAR: Is that failure  
23 considered through the full spectrum of --

24 MR. BERGERON: Of all the events --

25 MEMBER STETKAR: -- of all the events,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 including small LOCA, is what I am particularly  
2 interested in?

3 MR. BERGERON: Yes, I guess Liliane has  
4 probably got the answer to that.

5 MEMBER STETKAR: I know we are not talking  
6 about small LOCAs in this particular meeting, but I  
7 was trying to understand that statement in the FSAR  
8 about what is the scope of presumed single failures  
9 within the context of the transients that we are  
10 looking at now, and seeing how that translates through  
11 all the rest of the analyses. So, that is why I am  
12 asking.

13 Go ahead. You have to speak right into  
14 the microphone.

15 MS. SCHOR: My name is Liliane Schor. I  
16 work for AREVA.

17 For small break LOCA, we did a single  
18 failure assuming the MSRCV starts to operate and then  
19 failed closed. But the single failure for small break  
20 LOCA was EDG failures being more limiting.

21 MEMBER STETKAR: Does an EDG failure  
22 -- okay. Okay. But you did look at the CV --

23 MS. SCHOR: We did look at the MSRCV  
24 closed.

25 MEMBER STETKAR: Yes. No steam release

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 through one of the four trains, basically?

2 MS. SCHOR: Correct. We did.

3 MEMBER STETKAR: Okay. Thank you.

4 All right.

5 MR. BROWNSON: Moving on to the decrease  
6 in RCS flow rate events, the complete loss-of-flow  
7 event may result from a simultaneous failure of an  
8 electrical power supply of the RCPs. The resulting  
9 decreasing reactor coolant flow degrades the core heat  
10 transfer and reduces DNBR margin.

11 The protection system logic initiates a  
12 reactor trip when two out of four loops generate a low  
13 RCP trip signal. By assuming one protection system  
14 division has failed and another is removed for  
15 preventative maintenance, the reactor will only trip  
16 when the low RCP trip signal is reached in all four  
17 coolant loops.

18 This is the limiting delta DNBR event that  
19 does not trip on DNB. It establishes the limiting  
20 condition for operation on initial DNB.

21 The RCP rotor seizure event is postulated  
22 to be an instantaneous seizure of an RCP rotor. The  
23 sudden decrease in reactor coolant flow while the  
24 reactor is at power degrades core heat transfer and  
25 can lead to fuel damage. A reactor trip signal is

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 generated when the low-low flow setpoint is reached.  
2 Eight percent of the fuel rods are conservatively  
3 predicted to undergo DNB-related fuel damage,  
4 resulting in radiological doses below the acceptance  
5 criteria, which were established assuming a 9.5  
6 percent fuel failure rate.

7 Reactor and power distribution anomalies.

8 Both single and complete bank RCCA drop events have  
9 been analyzed. Rod drop events are initiated by de-  
10 energizing an RCCA drive mechanism or by a malfunction  
11 associated with a control bank during power operation.

12 Following a rod drop, there is initial  
13 power decrease followed by a power increase due to  
14 reactivity feedback and the automatic withdrawal of  
15 control banks when the average coolant temperature  
16 control function is active.

17 The DNB limiting condition for operation  
18 and the low DNBR reactor trip provide protection  
19 against DNB-induced fuel failures. High linear power  
20 density limits are not exceeded, resulting in fuel  
21 centerline temperatures not exceeding the melting  
22 point and fuel clad strain not exceeding 1 percent.

23 The RCCA ejection accident, which will be  
24 discussed in greater detail during tomorrow's meeting,  
25 is defined as a postulated rupture of the control rod

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 drive mechanism housing that results in the complete  
2 ejection of an RCCA from the reactor core. The power  
3 spike resulting from the rod ejection is quickly  
4 countered by reactivity feedbacks when the fuel  
5 temperature begins to increase, and may be terminated  
6 by reactor trip on high neutron flux, high neutron  
7 flux rate, or low neutron flux doubling time.

8 For these scenarios, for the core  
9 evaluation scenario, a spectrum of ejected rod worths  
10 and initial power levels from hot zero power to hot  
11 full power were performed. All scenarios resulted in  
12 satisfaction of acceptance criteria.

13 For the RCS overpressure scenario, no  
14 opening in the RCCS is assumed as the ejected rod  
15 worth plugs is assumed to plug the rupture in the  
16 housing mechanism. The spectrum of power levels and  
17 rod worths were again evaluated. RCS pressure is  
18 maintained well below the 120 percent acceptance  
19 criteria, and the secondary MSSVs never actuated for  
20 this event.

21 CHAIRMAN BANERJEE: So, the cases where  
22 opening is assumed, how big are these openings?

23 DR. WITTER: This is Jonathan Witter.

24 The flange housing size diameter was the  
25 assumed flow hole leakage size for the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 depressurization.

2 CHAIRMAN BANERJEE: Which is how big a  
3 hole?

4 DR. WITTER: I can let you know in a  
5 little bit.

6 MR. BROWNSON: We will take an action --

7 MS. SLOAN: Right. We will look it up.

8 MR. BROWNSON: -- to find out that size.

9 CHAIRMAN BANERJEE: Go ahead.

10 MEMBER STETKAR: Doug, I'm sorry, I was  
11 writing notes here. Can you go back to the previous  
12 slide? Thanks.

13 The complete loss of forced reactor  
14 coolant flow, somewhere -- and I was trying to find my  
15 notes and I couldn't find it -- one of the accidents  
16 or transients that is evaluated is a loss of non-  
17 emergency AC power to station auxiliaries. Or, you  
18 know, it is an euphemism for a loss of offsite power.

19 The analysis says that that event is  
20 bounded. There is apparently not a separate analysis  
21 done for that event because it is supposedly bounded  
22 by a complete loss of forced reactor coolant flow.  
23 Obviously, the reactor coolant pumps would not operate  
24 under that condition.

25 However, the single failure for the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 complete loss of forced reactor coolant flow is one  
2 protection system division with the second one being  
3 out of service for maintenance, which is effectively a  
4 non-issue.

5 MR. BERGERON: Right.

6 MEMBER STETKAR: However, if you are using  
7 that accident to also include losses of offsite power,  
8 don't we have to care about diesel failures or not?  
9 Maybe not for DNBR. In other words, I am worried  
10 about using this thing as a surrogate for loss of  
11 offsite power and then saying, well, the most limiting  
12 failure for this thing is a protection system  
13 division. Am I losing an analysis --

14 MR. BERGERON: Right.

15 MEMBER STETKAR: -- for loss of offsite  
16 power --

17 MR. BERGERON: Right.

18 MEMBER STETKAR: -- with a single diesel  
19 failure, for example?

20 MR. BERGERON: Right. I think the loss of  
21 AC case, the FSAR says, for the beginning of the  
22 event, the loss of flow is --

23 MEMBER STETKAR: Is limited.

24 MR. BERGERON: -- is comparable.

25 MEMBER STETKAR: Yes. Okay.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. BERGERON: For the long-term event, it  
2 is the loss of normal feed. So, the loss of normal  
3 feed would also consider that as a potential single  
4 failure. And I think it turned out that worst single  
5 failure for that is an EFW train.

6 MEMBER STETKAR: EFW division, which would  
7 be picked up with --

8 MR. BERGERON: Right. Yes. So, the long-  
9 term aspects of the loss of AC would be the loss of  
10 normal feed, which we have analyzed specifically,  
11 looking with and without pumps. And, of course, the  
12 loss of normal feed is more limiting with the RCPs.

13 MEMBER STETKAR: Yes. Yes. Yes.

14 MR. BERGERON: So, that is how we cover --

15 MEMBER STETKAR: Okay. Yes. Okay.

16 MR. BERGERON: That's how we cover the  
17 long-term aspects of the loss of AC.

18 MEMBER STETKAR: Okay. Okay. Thanks.  
19 Thanks.

20 MS. SLOAN: Jonathan has an answer.

21 MEMBER STETKAR: Jonathan?

22 DR. WITTER: This is Jonathan Witter  
23 again.

24 For the flange area size, it is .246-foot  
25 diameter. So, about a 3-inch diameter hole. That is

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 the maximum hole size, if the drive mechanism were  
2 completely removed from the flange housing.

3 CHAIRMAN BANERJEE: That is what the pipe  
4 diameter is?

5 DR. WITTER: Right. Right.

6 CHAIRMAN BANERJEE: Okay. And that, you  
7 will talk about tomorrow, right?

8 DR. WITTER: Yes. Yes.

9 CHAIRMAN BANERJEE: Does that give you as  
10 big a power pulse in the sense that you probably get  
11 some voiding, right, in the region of the rod drop? I  
12 mean rod ejection.

13 DR. WITTER: In actuality, we don't  
14 consider the depressurization in the rod worth or the  
15 power pulse part of it. The depressurization part  
16 plays a role in the DNBR calculation, in the failure  
17 sense, for the post-ejection period of the --

18 CHAIRMAN BANERJEE: But you don't look at  
19 the void formation in that region?

20 DR. WITTER: Only in the sense of however  
21 our neutronics calculations would handle that part of  
22 it.

23 CHAIRMAN BANERJEE: Yes, of course. But,  
24 for the neutronics, you have got to feed it some of  
25 the hydraulics, right?

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 DR. WITTER: Exactly. Right. The event  
2 where the rod is ejected is .1 seconds. So, the  
3 impact of the depressurization part of that would  
4 happen much later than the pulse part of it. So, it  
5 really doesn't play much of a role in the initial  
6 power pulse part of it, except for the thermal  
7 hydraulics part of the feedback with the moderator  
8 feedbacks for it.

9 So, we will talk more tomorrow about the  
10 details of that.

11 CHAIRMAN BANERJEE: Yes. We will need to  
12 explore that, how you are doing it.

13 DR. WITTER: Okay. Yes.

14 CHAIRMAN BANERJEE: Fine. Okay.

15 MR. BROWNSON: Moving on to the increase  
16 in RCS inventory events, the inadvertent operation of  
17 the ECCS or EBS, of these two cases, the ECCS  
18 operation is inconsequential, as the MHSI's shutoff  
19 head is well below the operating pressure of the U.S.  
20 EPR.

21 For the EBS, the EBS system is manually-  
22 actuated and is designed to inject highly-borated  
23 liquid into the RCS against RCS pressure following a  
24 design basis event. The system consists of two  
25 trains, each with high-pressure, positive displacement

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 pumps and an EBS tank.

2 It is postulated that both pumps are  
3 started with the corresponding isolation valves  
4 simultaneously opening to increase RCS inventory.

5 CHAIRMAN BANERJEE: So, do you have a  
6 larger sort of a feed-and-bleed-type system, as you  
7 don't have a high-pressure injection system?

8 MR. BROWNSON: Well, we have the  
9 capability of performing feed and bleed through the  
10 PSRVs and the MHSI system or the EBS. For the MHSI,  
11 we would have to get the pressure of the system down  
12 to the shutoff head, which is 1405, in order to  
13 perform feed and bleed.

14 CHAIRMAN BANERJEE: And are these systems  
15 larger than would be the equivalent flows in and out?

16 I'm thinking back to the old Candu days. They had,  
17 more or less, the same issues as you have. They  
18 didn't have a high-pressure injection system, right?  
19 And they did a controlled cooldown. That is what they  
20 do. They actually divert the steam into their  
21 condensers. There are some water hammer problems, but  
22 that is a separate issue we will talk about.

23 But now they had a much oversized feed-  
24 and-bleed system to be able to handle some of it. But  
25 maybe you can answer it.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 MR. PARECE: This is Marty Parece again,  
2 for the stenographer.

3 The main steam safety valves are both  
4 media-operated and the operator can open them as well,  
5 the power operator.

6 MEMBER STETKAR: The pressurizer --

7 MR. PARECE: The pressurizer safety  
8 valves.

9 MEMBER STETKAR: The pressurizer safety  
10 valves.

11 MR. PARECE: I'm sorry, the pressurizer  
12 safety valves.

13 The pressurizer safety valves are both  
14 media- and manually-operated. They are 660,000 pounds  
15 per hour for the three valves. If you used all three,  
16 you could depressurize the plant below 200 psi in less  
17 than 20 minutes because our severe accident valve, one  
18 of those is the equivalent of three safety valves.  
19 And that is what that analysis shows.

20 So, yes, we can depressurize the plant to  
21 do feed and bleed, and that is one of the credited  
22 backup cooling methods in the PRA.

23 CHAIRMAN BANERJEE: That makes sense.

24 MR. PARECE: So, they are very big. A  
25 comparison is a current three-loop Westinghouse plant

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 has safety valves that are 420,000 pounds per hour.  
2 And those are spring-loaded. And their PORVs are only  
3 about 120,000 pounds per hour.

4 So, we can use these big valves also  
5 manually.

6 CHAIRMAN BANERJEE: Okay.

7 MR. BROWNSON: Again, it is postulated  
8 that both EBS pumps start, and corresponding isolation  
9 valves simultaneously opening to increase RCS  
10 inventory. The pressurizer level increases until  
11 reactor trip occurs. Upon reactor trip, turbine trip  
12 occurs and simultaneous loss of offsite power. Loss  
13 of offsite power results in RCP coastdown and loss of  
14 main feedwater.

15 There is a single failure of one MSRT to  
16 open, resulting in decreased heat transfer from the  
17 secondary system and greater heatup and swell to the  
18 primary system.

19 The event is terminated at 30 minutes with  
20 operator isolation of the EVS.

21 Again, all acceptance criteria are  
22 satisfied for this event.

23 The CVCS malfunction event is a  
24 malfunction of the pressurizer level control system.  
25 The CVCS maintains a constant charging flow and

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 adjusts the letdown flow to account for volume changes  
2 due to RCS temperature variations.

3 Normally, only one of the two CVS charging  
4 pumps are in operation. For this event, we assumed  
5 both pumps operate with the letdown system isolated.

6 This event is terminated by a reactor trip  
7 on high pressurizer level. A single failure of an  
8 MSRT again is assumed. A single failure of an MSRT to  
9 open is again assumed. This, again, results in a  
10 decrease in heat transfer, greater heat of the primary  
11 system and swell.

12 Additionally, the non-safety pressurizer  
13 heaters and sprays are also assumed to operate as  
14 designed. Pressurizer sprays will reduce RCS  
15 pressure, delaying actuation of the PSRVs and  
16 aggravating system overfill. If actuated, pressurizer  
17 heaters will help increase the primary system swell  
18 and also aggravate system overfill.

19 No operator actions are credited in this  
20 event to mitigation. However, it is assumed that one  
21 of the CVCS pumps are restarted following the loop in  
22 order to aggravate the overfill situation.

23 Again, all the event acceptance criteria  
24 are satisfied for this event.

25 Moving on to the decrease in RCS inventory

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 events, we will only be discussing two. The two  
2 events for discussion today are the inadvertent  
3 opening of the PSRV and the steam generator tube  
4 rupture.

5 The inadvertent opening of the pressurizer  
6 safety relief valve is defined as a spurious opening  
7 of the PSRV that is normally closed. The U.S. EPR has  
8 three such valves, as Marty just stated, located at  
9 the top of the pressurizer and automatically open to  
10 prevent RCS overpressurization. The three valves  
11 operate independently. So, a single failure can only  
12 affect one PSRV.

13 The IOPSRV causes a loss of reactor  
14 coolant inventory that cannot be offset by the CVCS  
15 charging. This causes primary system depressurization  
16 and decreases the reactor coolant density. Reactor  
17 power is initially controlled through reactivity  
18 feedbacks, through the change in moderator density,  
19 and the rod position actions of the average coolant  
20 temperature control function. The drop in RCS  
21 pressure results in a reactor trip and subsequent loss  
22 of offsite power.

23 The limiting single failure for this event  
24 is failure of one emergency diesel generator to start  
25 which results in the loss of one safety injection

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 train and EFW train.

2 A second diesel generator is assumed to be  
3 removed due to preventative maintenance resulting in  
4 the unavailability of a second SIS and EFW train.

5 Beginning-of-cycle conditions are  
6 predicted to be the most limiting, as this provides  
7 for the most positive moderator reactivity feedbacks.

8 Operator actions are credited 30 minutes  
9 into the event to align EFW flow from the two  
10 operational EFW trains to the four steam generators.  
11 The two operating medium head safety injection trains  
12 are adequate to offset RCS inventory loss in the later  
13 phase of the event and maintain core cooling  
14 throughout the transient.

15 The event's drop in RCS pressure and  
16 initial positive reactivity feedbacks make this event  
17 challenging to the DNB acceptance criteria. However,  
18 the DNB LCO and low DNBR trip are adequate to protect  
19 the fuel, and all acceptance criteria are satisfied.

20 Moving on to the steam generator tube  
21 rupture event, this event is postulated as a double-  
22 ended rupture of a single steam generator tube. The  
23 main acceptance criteria for this event is to maintain  
24 radiological releases below acceptable limits.

25 A second criteria is to prevent overfill

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 to the steam generator secondary side to prevent water  
2 from entering the steam lines. The steam generator  
3 tube rupture is taken to occur in the shortest steam  
4 generator tube, near the tube sheet, on the steam  
5 generator primary system inlet side. The location  
6 maximizes the pressure difference between the primary  
7 and secondary system and maximizes the break flow.

8 The break begins depressurizing the RCS  
9 and the level in the pressurizer begins to drop. The  
10 non-safety CVCS system flow is credited with operating  
11 to maintain pressurizer level and delay reactor trip.

12 For overfill scenarios, the limiting  
13 single failure is the failure of the main feedwater  
14 full load control valve, as the steam generator level  
15 increases.

16 For radiological scenarios, the limiting  
17 single failure is the failure of the MSRT on the  
18 affected steam generator to close.

19 The limiting overfill and radiological  
20 FSAR cases are with loss of offsite power, resulting  
21 in the loss of the CVCS, RCPs, and main feedwater  
22 pumps. Operator actions, including manual reactor  
23 trip, are not taken until 30 minutes after event  
24 initiation.

25 All overfill and radiological acceptance

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 criteria for this event are satisfied in the FSAR  
2 analyses.

3 CHAIRMAN BANERJEE: Are we going to go  
4 into this in more detail at some point?

5 MS. SLOAN: We will talk about tube  
6 rupture mitigation strategy, which is what Ken Coffey  
7 will talk about.

8 CHAIRMAN BANERJEE: Okay.

9 MS. SLOAN: Do you have a particular  
10 question?

11 CHAIRMAN BANERJEE: No, not right now.

12 MS. SLOAN: Okay.

13 MEMBER STETKAR: I do. I'll wait.

14 CHAIRMAN BANERJEE: Yes, we will wait.

15 (Laughter.)

16 MR. COFFEY: If the question pertains more  
17 towards the analysis, assumptions made, or systems  
18 used in the analysis -- this is Ken Coffey, sorry --  
19 Doug Brownson might be better to answer those. I am  
20 going to handle more the mitigation aspects of the  
21 events. So, feel free to ask your questions when you  
22 feel more appropriate.

23 MEMBER STETKAR: You are not leaving, are  
24 you, Doug?

25 (Laughter.)

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. BROWNSON: No.

2 MEMBER STETKAR: Okay. We'll wait.

3 MR. BROWNSON: The final section in  
4 Chapter 15 that we are going to talk about today is  
5 the anticipated transients without scram.

6 The ATWS occurs when the control rods fail  
7 to insert following an anticipated operational  
8 occurrence. This occurs as the result of a mechanical  
9 blockage of the control rods or an electrical or  
10 mechanical failure of the protection system.

11 A mechanical blockage of the control rods  
12 is determined to be an insignificant contributor to  
13 the probability of an ATWS, so it is not considered.

14 In the event of protection system  
15 failures, the U.S. EPR is designed with a diverse  
16 actuation system, or DAS, that provides for an  
17 independent initiation of a reactor trip, turbine  
18 trip, and other essential systems and functions  
19 required to bring the reactor to a stable condition.

20 The design of the DAS satisfies the  
21 acceptance criteria of 10 CFR 50.62.

22 MEMBER STETKAR: Doug, I read through the  
23 text trying to convince me that mechanical blockage of  
24 the control rods is insignificant, but I wasn't  
25 convinced.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. BROWNSON: Okay.

2 MEMBER STETKAR: It seemed to be saying  
3 that, well, people take 10 to the minus 5s, and 10 to  
4 the minus 5s are sort of okay for current operating  
5 plants. So, therefore, it is probably less than 10 to  
6 the minus 5. So, therefore, it is probably not  
7 important.

8 That doesn't convince me that it is an  
9 insignificant contributor to the probability of an  
10 ATWS event if everything else, indeed, is much less  
11 than that. It could be the most important contributor  
12 to an ATWS event.

13 So, I am not convinced from a  
14 probabilistic standpoint. From a deterministic  
15 standpoint, I understand what you are doing with ATWS.

16 MR. BROWNSON: Right.

17 MEMBER STETKAR: So, this is more a PRA-  
18 type question, sort of challenging that assertion in a  
19 real -- this is a probabilistic assertion.

20 MR. BROWNSON: Yes.

21 MEMBER STETKAR: It is not a deterministic  
22 assertion.

23 MR. BROWNSON: Right.

24 MEMBER STETKAR: Because your  
25 deterministic analysis says the reactor doesn't trip.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 I asked that question, by the way, in the  
2 PRA. And the PRA does not include mechanical blockage  
3 because it is assumed to be an insignificant  
4 contributor. We will just leave that as a PRA  
5 question.

6 (Laughter.)

7 But a more pertinent question for ATWS is  
8 I found in Section 15.8.1.4, which discusses the  
9 emergency feedwater system, a statement that says,  
10 "The U.S. EPR is designed so that flow from the EFW  
11 system is not required for the first 30 minutes  
12 following an ATWS."

13 It strikes me as a rather bold statement  
14 if the cause for the ATWS is loss of all main  
15 feedwater. How can I survive the loss of main  
16 feedwater without tripping the reactor for more than  
17 30 minutes, or let's say 30 minutes, with no sources  
18 of emergency feedwater?

19 MR. BROWNSON: Okay. This would have been  
20 covered under our D3, was it?

21 MEMBER STETKAR: The reason I bring it up  
22 is --

23 MR. BERGERON: We have an automatic EFW  
24 actuation for D3.

25 MR. BROWNSON: Okay. So, that was added

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 probably after --

2 MR. BERGERON: As part of the diverse  
3 actuation system.

4 MR. BROWNSON: Okay.

5 MR. BERGERON: I think we also had ATWS  
6 included as part of the diverse actuation system  
7 automatic EFW.

8 MEMBER STETKAR: Well, this is just a  
9 statement that says it's not required.

10 MR. BERGERON: Right.

11 MEMBER STETKAR: That, to me, says it's  
12 not required.

13 MR. PARECE: This is Marty Parece.

14 That assumes that the DAS operates when  
15 the reactor trips. If the reactor trips, then you  
16 don't need emergency feedwater for 30 minutes because  
17 there is decayed heat removal capability in the steam  
18 generators for at least that long.

19 MEMBER STETKAR: I guess I interpret an  
20 ATWS as the reactor did not trip. I understand, if  
21 the reactor is tripped, I have enough inventory in the  
22 steam generators, but perhaps it is my  
23 misinterpretation.

24 The reason I ask is the staff in the SER  
25 says, the staff notes that thermal hydraulic analyses

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 of an ATWS have not been provided, nor are they  
2 required, to numerically demonstrate that in the event  
3 of an ATWS, the pressure increase does not exceed ASME  
4 service-level speed conditions.

5 And the SER cites this fact, that you  
6 don't need emergency feedwater for 30 minutes during  
7 an ATWS event. So, I'm curious about whether we are  
8 understanding who is analyzing what, recognizing that  
9 an ATWS event is beyond design basis, of course.

10 MR. PARECE: This is Marty Parece again.

11 If you follow the daisy chain, it says we  
12 don't consider the blockage of all the control rods,  
13 physical blockage of all the control rods, to be  
14 credible. Then, the DAS, the Diverse Actuation  
15 System, operates, and it trips the reactor, and  
16 therefore, all the events are mitigated, all the ATWS  
17 events are mitigated with the DAS and eventually aux  
18 feedwater to provide that coolant.

19 MEMBER STETKAR: So, presuming that enough  
20 rods can always go in somehow --

21 MR. PARECE: Yes.

22 MEMBER STETKAR: -- I understand that.  
23 Okay. Thanks.

24 MR. BROWNSON: This concludes my summary  
25 of the Chapter 15. If there's no additional

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 questions, then Mr. Perez will continue on with the  
2 radiological results.

3 MR. PEREZ: Good morning.

4 My name is Pedro Perez. I have been here  
5 before you. Do you want me to do an introduction or  
6 can I continue?

7 CHAIRMAN BANERJEE: Continue.

8 MR. PEREZ: Thank you.

9 I will be presenting the radiological  
10 consequences of design basis accidents, which are  
11 summarized in the FSAR in Section 15.0.3.

12 Our design basis radiological evaluations  
13 are based on the Standard Review Plan, Section 15.0.3,  
14 with the additional guidance provided in Section of  
15 the SRP 4.2, which provides interim acceptance  
16 criteria and guidance for reactivity-initiated events.

17 Our DBAs were evaluated applying the  
18 alternative source term methodology, as documented in  
19 Regulatory Guide 1.183. We also took into  
20 consideration the Regulatory Issue Summary 2006-04,  
21 which was a summary of the experience with  
22 implementation of the alternative source term, and the  
23 AST radiological acceptance criteria you can find in  
24 10 CFR 50 and 10 CFR 52.

25 We used regulatory guidance in 1.145 for

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 the offsite atmospheric dispersion factors,  
2 determining those. In Regulatory Guide 1.94, which is  
3 ARCON-96, is the control room atmospheric dispersion  
4 factors.

5 The events evaluated are the following.

6 CHAIRMAN BANERJEE: Sorry. The onsite  
7 dispersion factors, that is what happens within your  
8 control rooms and everything. You use your own codes  
9 there to do the calculation?

10 MR. PEREZ: No. That code is the NRC's  
11 code, ARCON-96.

12 CHAIRMAN BANERJEE: Okay. Okay. That is  
13 an NRC code?

14 MR. PEREZ: Yes, which is the effluent  
15 from the release point to the control room intake,  
16 which are very short distances.

17 CHAIRMAN BANERJEE: And, then, what  
18 happens within the control? Don't they have a code  
19 called HABIT or something?

20 MR. PEREZ: That is the code that we do  
21 not use, and that is for control room habitability.

22 CHAIRMAN BANERJEE: Yes.

23 MR. PEREZ: And for control room  
24 habitability, we use our own code, and the code  
25 calculates the immersion and the inhalation doses.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIRMAN BANERJEE: Right.

2 MR. PEREZ: Of course, RADTRAD can also do  
3 that calculation, too.

4 CHAIRMAN BANERJEE: And you used your own  
5 code here?

6 MR. PEREZ: And we also used RADTRAD  
7 because we knew the staff was going to use RADTRAD,  
8 and we wanted to make sure there were not going to be  
9 any differences between codes.

10 CHAIRMAN BANERJEE: So, HABIT, it is a  
11 multi-compartment code, isn't it? It sort of looks at  
12 concentration fields within --

13 MR. PEREZ: Yes.

14 CHAIRMAN BANERJEE: -- the control rooms  
15 and things like that?

16 MR. PEREZ: Well, the control room  
17 envelope becomes one of the compartments.

18 CHAIRMAN BANERJEE: Yes.

19 MR. PEREZ: So, you basically release the  
20 radioactivity from one compartment to another  
21 compartment.

22 CHAIRMAN BANERJEE: Yes.

23 MR. PEREZ: If you would, that connection  
24 takes into account the dispersion from compartment A  
25 to compartment B. So, within either code that you

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 use, the RADTRAD or our own code, it is basically the  
2 same solution.

3 CHAIRMAN BANERJEE: I guess we will ask  
4 the staff whether they did some confirmatory analysis  
5 on this when the time comes.

6 MR. PEREZ: Okay.

7 CHAIRMAN BANERJEE: All right. Go ahead.

8 MR. PEREZ: And I know they did do it  
9 because we have had RAIs to discuss some differences  
10 in what did we assume and the specifics about our  
11 analysis.

12 CHAIRMAN BANERJEE: Okay.

13 MR. PEREZ: The events have been evaluated  
14 following the SRP and following the regulatory  
15 guidance in 1.183 as small line breaks outside of the  
16 reactor building, steam generator tube rupture, main  
17 steam line break outside the reactor building, locked  
18 rotor, rod ejection, fuel-handling accident, and the  
19 old maximum hypothetical accident, the large-break  
20 LOCA, the LOCA.

21 I will point out that the reactor cooling  
22 pump broken shaft and the feedwater line break  
23 radiological consequences are bounded by the locked  
24 rotor and the main steam line break, respectively,  
25 okay, from a radiological perspective.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER STETKAR: Pedro?

2 MR. PEREZ: Yes?

3 MEMBER STETKAR: Let me ask you about the  
4 small break outside the reactor building, and shuffle  
5 it off to someone else if the question is in a  
6 different area.

7 It is my understanding that you looked at  
8 two different lines. One was the CVCS letdown line,  
9 which is a 6-inch line, and the other lines you looked  
10 at were primary sampling lines, which are quarter-inch  
11 lines --

12 MR. PEREZ: Correct.

13 MEMBER STETKAR: -- directly connected to  
14 the primary system. The conclusion was, I believe,  
15 that from a dose perspective, the sampling line,  
16 although it is much, much smaller, was the most  
17 limiting line.

18 However, when I read the discussion of the  
19 CVCS line, there is a lot of description of the fact  
20 that the break would be downstream of the purification  
21 loops, which I believe I have lost the quote here, but  
22 it sounds like credit may be taken for the filters in  
23 the purification loops, removing a substantial amount  
24 of the radionuclides and, in particular, iodine from  
25 that particular break.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1           That break requires a manual isolation.  
2           So, the letdown line is not isolated automatically.  
3           So, therefore, the flow through the break and the  
4           release continues for 30 minutes until the operators  
5           isolate the line.

6           My question was, suppose the break in the  
7           letdown line occurs upstream from the purification  
8           loop, so that the filters and the demineralizers don't  
9           remove any of the radionuclides. Would that change  
10          the conclusions?

11          MR. PEREZ: Because it is private, yes.

12          MEMBER STETKAR: Because that also would  
13          require manual isolation.

14          MR. PEREZ: Right.

15          MEMBER STETKAR: So, you would have a  
16          release from that location for 30 minutes.

17          MR. PEREZ: Right. And what I need to do  
18          is I need to go back and take a look to understand  
19          exactly why we chose that location. Because the way  
20          you just explained it, you know, of course, that would  
21          change the consequences.

22          MEMBER STETKAR: Yes.

23          MR. PEREZ: Right now, I don't remember  
24          that description. So, in the afternoon I will look  
25          and go back to understand how we chose that location

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 for the CVCC.

2 MEMBER STETKAR: I have some suspicions,  
3 but I wanted to hear it from you. You know, the  
4 basic question is, would the location in that letdown,  
5 the location in the break in that letdown line,  
6 whether it was upstream from the purification loop  
7 versus it is my understanding that it was presumed  
8 downstream from the purification loop. Would that  
9 make enough of a difference in the radiological  
10 releases to shift the emphasis from the sampling line  
11 break? If it is still bounded by the sampling, I  
12 don't care.

13 MR. PEREZ: Right.

14 MEMBER STETKAR: There's such a big  
15 difference in the size of those lines that I am just  
16 curious.

17 MR. PEREZ: Okay, and I will get back to  
18 you.

19 MEMBER STETKAR: Okay. Thanks.

20 MR. PEREZ: This slide is a little bit  
21 difficult to see, but I wanted to show the  
22 relationship between the control room air intakes and  
23 the multiple release points on the nuclear island.

24 There are two control room intakes on this  
25 top side of the picture. These are the control room

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 intake locations. And, then, there are multiple  
2 release points, depending on the event we are  
3 analyzing. You have the stack, which is one of the  
4 prominent release points, but you also have steam  
5 generator MSRT release locations which are going to be  
6 closer to the control room.

7 The calculations we performed for the  
8 onsite chi over q's, using that ARCON-96 code,  
9 basically, looks at the dispersion between each  
10 release point and the control room intake. So, you  
11 will notice that we have in our Chapter 2 of design  
12 certification multiple onsite chi over q's, multiple  
13 onsite dispersion factors, because there are multiple  
14 potential release points to the control room intake.

15 The main control room HVAC includes  
16 charcoal and HEPA filtration. This picture, this  
17 cartoon, shows the HVAC in the filtration  
18 configuration. There is a total of 8,800 cfm of air  
19 being recirculated. Of that, you have 3,000 cfm going  
20 through the charcoal filters, plus 1,000 cfm of fresh  
21 air also going through the charcoal filter. So, the  
22 total filtration is 4,000 cfm. And this is acting as  
23 a kidney filter for the entire control room envelope,  
24 which is 8,800 recirculated air. That is how the  
25 model of the control room has been formed.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1                   We include 50 cfm of unfiltered in  
2 leakage. That 50 includes 10 cfm for ingress and  
3 egress, opening the doors of the control room for  
4 access.

5                   This unfiltered in leakage can come from  
6 basically anywhere, if there is a break inside the  
7 plant, engineering safeguard features, ESF leakage.  
8 So, all the analyses have that consideration of the 50  
9 cfm.

10                   This cartoon depicts, if you would, the  
11 different compartments that we have and how these are  
12 interconnected. You first start with the inventory in  
13 your reactor core. This happens to be the design  
14 basis LOCA, which releases the radionuclides into the  
15 reactor building. We apply natural deposition, which  
16 we will talk in a minute, meaning you have  
17 gravitational settling of the particulates that go  
18 into the IRWST. What remains airborne will go into  
19 the annulus or can bypass the annulus and go into the  
20 safeguard building mechanical area. We credit  
21 filtration of the annulus space, and we credit  
22 filtration within the mechanical area of the safeguard  
23 building.

24                   We also have to consider ESF leakage which  
25 has the concentration, the time-dependent

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 concentration, of the nuclides that have been  
2 deposited into the RWST.

3 The safeguard building ventilation system  
4 and the annulus ventilation system exhaust through the  
5 stack. We assume a ground-level release from the  
6 stack. And from that ground-level release, we  
7 calculate chi over q's dispersion factors for the  
8 exclusionary boundary, a low population zone, and, of  
9 course, from the atmospheric dispersion you have  
10 radioactivity entering the control room envelope,  
11 where, again, we credit the filters you previously  
12 saw.

13 What I would like to do is present two of  
14 the events.

15 CHAIRMAN BANERJEE: So, the way you showed  
16 that diagram, the control room is a different  
17 elevation from the base of the stack, right?

18 MR. PEREZ: This is not to scale.

19 (Laughter.)

20 CHAIRMAN BANERJEE: No, no, I am aware of  
21 that. But the way you have shown it, is there any  
22 change in elevation between the base of the stack and  
23 the control room?

24 MR. PEREZ: There is. Yes, there is. And  
25 I can't remember now. It is not much.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIRMAN BANERJEE: Okay. So, in fact,  
2 release of the base of the stack is adequate to  
3 consider --

4 MR. PEREZ: Correct. Correct.

5 CHAIRMAN BANERJEE: -- from the viewpoint  
6 of the distance for dispersion and things like that?

7 MR. PEREZ: Correct. Because there is a  
8 regulatory guidance on what can be an elevated  
9 release, and it is based on the height of the stack  
10 relative to the nearest structure. It has to be two  
11 and a half times. We don't meet that.

12 So, then, you apply a ground-level release  
13 for this type of calculation. You look at basically  
14 what is a taut-string distance. It takes into account  
15 elevation, and you also take into account the wake  
16 effects of the building. All this is within the  
17 ARCON-96 methodology.

18 CHAIRMAN BANERJEE: Yes, so you do take  
19 credit for the WIGs?

20 MR. PEREZ: Yes.

21 CHAIRMAN BANERJEE: Yes. Additional  
22 mixing in the WIGs?

23 MR. PEREZ: Well, is it mixing? It is,  
24 yes, dispersion.

25 CHAIRMAN BANERJEE: Dispersion factors,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 yes. Well, it is mixing.

2 MR. PEREZ: Okay.

3 CHAIRMAN BANERJEE: Dilution, yes.

4 MR. PEREZ: So, what we have to do is  
5 present two of the radiological analyses and, then,  
6 collected the tube rupture analysis and the design  
7 basis LOCA analysis.

8 CHAIRMAN BANERJEE: So, just remind me of  
9 how this is done. So, suppose you have a release and  
10 you are in a certain type of weather --

11 MR. PEREZ: Yes.

12 CHAIRMAN BANERJEE: -- which is the lowest  
13 dispersive, low winds. So, is there sort of a  
14 prescription on what sort of enhanced dispersion you  
15 get in the wakes then, based on that?

16 MR. PEREZ: Well, when you calculate the  
17 atmospheric dispersion factors, you follow pretty  
18 prescriptive regulatory guidance, and you take the  
19 worth, from the real data you take at a site, you  
20 would take all that hourly data, or whatever data you  
21 have for the entire year, right?

22 CHAIRMAN BANERJEE: Sure. You go to your  
23 weather.

24 MR. PEREZ: And you process it all and  
25 pick the worst atmospheric conditions, considering

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 delta T's, considering wind directions, everything.  
2 Then, for the accident, you would take the 95th  
3 percentile worst weather.

4 CHAIRMAN BANERJEE: So, we have got your  
5 worst weather. So, I know how that is done. Now  
6 where do you go from that in terms of each design has  
7 some specific geometries as to where the buildings  
8 are, where the WIGs are, and where the control room  
9 is.

10 MR. PEREZ: Yes.

11 CHAIRMAN BANERJEE: So, you have got to  
12 connect the dots now, which is, having got the  
13 weather, the wind direction, and, of course, it is  
14 clear what the dispersion factors should be if you had  
15 clear ground.

16 MR. PEREZ: Correct.

17 CHAIRMAN BANERJEE: But that is just  
18 Briggs or whoever these people are that did this about  
19 50 years ago, right? And now you have got buildings.

20 MR. PEREZ: Yes.

21 CHAIRMAN BANERJEE: That is the issue  
22 really, because you are taking credit for these  
23 buildings now --

24 MR. PEREZ: Well --

25 CHAIRMAN BANERJEE: -- in some sense

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 because you are getting dilution to that in the WIGs.

2 So, I am just looking for how you put the specific  
3 geometries --

4 MR. PEREZ: Yes.

5 CHAIRMAN BANERJEE: -- for your layout  
6 into the calculation.

7 MR. PEREZ: Okay. The computer code,  
8 ARCON-96, was developed by Pacific Northwest, by a  
9 gentleman that actually did model wind tunnel  
10 modeling, small structures, to develop --

11 CHAIRMAN BANERJEE: Hopefully, then, in  
12 water because the Reynolds numbers would not work  
13 otherwise. But let's assume he did similitude. I'm  
14 not sure of what he did, but carry on.

15 MR. PEREZ: No, I didn't do it.

16 CHAIRMAN BANERJEE: Yes. Well, what this  
17 gentleman in Pacific labs did.

18 MR. PEREZ: From all the testing that he  
19 performed, the ARCON-96 methodology includes the  
20 shapes --

21 CHAIRMAN BANERJEE: Ninety-six is the year  
22 or --

23 MR. PEREZ: No, ARCON-96 --

24 CHAIRMAN BANERJEE: Is the vintage?

25 MR. PEREZ: The vintage of the code.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIRMAN BANERJEE: Right.

2 MR. PEREZ: And it is what we use in the  
3 industry that I am aware of. There is no other  
4 alternative right now that has been accepted.

5 And you basically put your dimensions,  
6 your shapes, and from the release point to that  
7 control room intake, it gives you the dispersion.

8 CHAIRMAN BANERJEE: So, you put in the  
9 geometry?

10 MR. PEREZ: Yes.

11 CHAIRMAN BANERJEE: And this code is used  
12 to get the dispersion factors. So, you use the same  
13 thing as the staff in any case?

14 MR. PEREZ: Yes.

15 CHAIRMAN BANERJEE: Okay.

16 MR. PEREZ: So, we are going to discuss  
17 two of the events, the steam generator tube rupture,  
18 radiological consequences, and the LOCA, the loss-of-  
19 coolant accident.

20 As I mentioned earlier, we are following  
21 the NRC Regulatory Guide 1.183 guidance for the  
22 alternative source term. Appendix F is the steam  
23 generator tube rupture.

24 You do two cases. One case is called the  
25 pre-accident iodine spike case, where you have the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 reactor coolant system concentration to the maximum  
2 value of 60 times your tech spec. So, in our case,  
3 the tech spec is 1 microcurie per gram dose equivalent  
4 to iodine-131. So, you initialize the calculation  
5 with an RCS concentration of 60, and you perform the  
6 tube rupture.

7 You also perform an accident-induced  
8 concurrent iodine spike, and you look at it for eight  
9 hours. That means that the iodine spike continues to  
10 increase with an appearance rate into the primary  
11 system by a factor of 335.

12 So, you keep increasing this appearance  
13 rate of iodine over that eight-hour period, developing  
14 a higher concentration of the reactor coolant system.

15 We run the two analyses and see which one gives you  
16 the limiting radiological consequence.

17 Noble gases are set at the tech spec limit  
18 of 210 microcuries per gram dose equivalent to I-131.

19 CHAIRMAN BANERJEE: So, are your  
20 geometries about the same as what people did before?  
21 I mean, has the applicability of these codes been sort  
22 of explored?

23 MR. PEREZ: Well --

24 CHAIRMAN BANERJEE: I mean I know it is  
25 the only code around, but --

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. PEREZ: No, no.

2 CHAIRMAN BANERJEE: -- that doesn't mean  
3 it is applicable to everything.

4 MR. PEREZ: Well, the geometry, you have a  
5 cylinder and different cylinders. This is also used  
6 for boiling water reactors which are square. The  
7 reactor buildings are square.

8 CHAIRMAN BANERJEE: So, the code has been  
9 sort of looked at for applicability in these different  
10 geometries?

11 MR. PEREZ: That is my understanding.

12 CHAIRMAN BANERJEE: So, we will find out  
13 from the staff also.

14 MR. PEREZ: Yes.

15 CHAIRMAN BANERJEE: But that is your  
16 understanding? But that is your independent  
17 understanding?

18 MR. PEREZ: Correct.

19 CHAIRMAN BANERJEE: And your geometries  
20 are, more or less, the same as where the core has been  
21 used before?

22 MR. PEREZ: More or less, yes.

23 (Laughter.)

24 Absolutely, because when you look at -- I  
25 mean look at a PWR. A large PWR has --

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIRMAN BANERJEE: I mean these Siemens  
2 designs look like bunkers to me.

3 MR. PEREZ: Which?

4 CHAIRMAN BANERJEE: Your design,  
5 essentially.

6 MR. PEREZ: Okay.

7 CHAIRMAN BANERJEE: Basically, it is --  
8 (Simultaneous speaking.)

9 MR. PEREZ: Well, not quite.

10 CHAIRMAN BANERJEE: It is a bit different?  
11 Not quite? Okay.

12 MR. PEREZ: Not quite. You still have the  
13 top of a cylinder with a dome.

14 CHAIRMAN BANERJEE: Right.

15 MR. PEREZ: Okay? There are many other  
16 type of similar reactors that have interference  
17 between the cylinder with auxiliary buildings, waste  
18 buildings, et cetera.

19 So, from the dispersion --

20 CHAIRMAN BANERJEE: It gives them more  
21 dispersion, right? If there are more buildings, they  
22 sort of mix things up a little bit more.

23 MR. PEREZ: Well, it depends, again, where  
24 your release point is relative to your intake.

25 CHAIRMAN BANERJEE: Right. So, I am just

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 wondering, has the applicability of this code been  
2 sort of checked for your sort of geometry?

3 MR. PEREZ: I believe we have a very  
4 simple geometry because, from the base of the stack,  
5 as I just showed you on that slide -- and we can go  
6 back to it. Oops, I am going the wrong way.

7 From the base of the stack to this control  
8 room intake, you basically go around this circle.

9 CHAIRMAN BANERJEE: So, you get very  
10 little dispersion there?

11 MR. PEREZ: Yes. It is almost a straight  
12 line, except for that little curvature.

13 CHAIRMAN BANERJEE: So, what is the  
14 increase in dispersion due to this?

15 MR. PEREZ: Distance.

16 CHAIRMAN BANERJEE: Yes, but distance is,  
17 you know -- I mean, if you had nothing, you get  
18 certain chi factors --

19 MR. PEREZ: Okay.

20 CHAIRMAN BANERJEE: -- chi X, chi Y, chi  
21 Z, you know. And now that you have got this thing in  
22 the way, then you enhance these factors, depending on  
23 what is in the way, right? So, if you have got a wake  
24 or a building, then that tends to give you higher  
25 dispersions, so you get less material. It is more

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 dilute --

2 MR. PEREZ: Yes.

3 CHAIRMAN BANERJEE: -- by the time it gets  
4 to your intakes. And if you have a very uncomplicated  
5 path, the dilution is less. The more buildings you  
6 have around, things mix up better because of these  
7 wakes interacting and stuff like that.

8 MR. PEREZ: Okay. Now, remember, I say  
9 you take the taut-string approach.

10 CHAIRMAN BANERJEE: Yes.

11 MR. PEREZ: So, by doing that, you do not  
12 take the sort of circumferential distance to gain in a  
13 dispersion calculation. So, that is one thing you do.

14 The benefit of having a structure there to  
15 go into that control room intake, I cannot give you an  
16 absolute number. But, based on this geometry, I  
17 cannot imagine you are getting too much benefit  
18 because there is almost --

19 CHAIRMAN BANERJEE: A straight line, yes.

20 MR. PEREZ: Yes, a straight line.

21 CHAIRMAN BANERJEE: And depending on the  
22 direction the wind is blowing, if you get a very light  
23 wind between those two, of course, and, you know, a  
24 cold, clear night with inverted conditions, so nothing  
25 disperses --

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. PEREZ: Yes.

2 CHAIRMAN BANERJEE: -- Pascal F weather --

3 MR. PEREZ: Yes. Now, remember, in design  
4 certification, there is no site.

5 CHAIRMAN BANERJEE: Right, right.

6 MR. PEREZ: Right? So, some of these  
7 calculations, chi over q's were selected to allow a  
8 co-applicant to fall under.

9 CHAIRMAN BANERJEE: Sure. You have got  
10 an envelope --

11 MR. PEREZ: Right.

12 CHAIRMAN BANERJEE: -- which is pretty  
13 conservative probably?

14 MR. PEREZ: Yes.

15 CHAIRMAN BANERJEE: Yes.

16 MR. PEREZ: We hope. Exactly. We hope.

17 CHAIRMAN BANERJEE: Why are you laughing?

18 MEMBER STETKAR: Well, he said, "We hope."  
19 He qualified it.

20 (Laughter.)

21 CHAIRMAN BANERJEE: Well, I guess it is up  
22 to the COL applicant, whoever is the applicant, to  
23 show that. Otherwise, they have to redo it, right?

24 MR. PEREZ: Well, they will have to  
25 perform their own dose calculations --

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIRMAN BANERJEE: Yes.

2 MR. PEREZ: -- and take a departure from  
3 the DC.

4 CHAIRMAN BANERJEE: Sure.

5 MR. PEREZ: We selected these values, and  
6 I think I have another slide to talk about it in a  
7 second, but some of these values, like the  
8 exclusionary boundary, came out of the EPRI Utility  
9 Requirements Document for a half-mile exclusionary  
10 boundary, 1.0, 10 to the minus 3 seconds.

11 And from the COLAs that I have worked  
12 with, if you keep it to that half a mile, no problem.

13 If you get tighter, you are going to --

14 CHAIRMAN BANERJEE: The only reason I am  
15 going on about this is that there have been issues in  
16 other systems where we have got pretty close to  
17 certain limits, but with adequate margins, you know, I  
18 am talking about.

19 MR. PEREZ: But I think, are we speaking  
20 about control room habitability?

21 CHAIRMAN BANERJEE: Yes.

22 MR. PEREZ: I think we are speaking about  
23 unfiltered in leakage to the envelope, like your  
24 control room envelope is not tight, and you have to,  
25 for example, in operating plants, you have to do

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 testing of the envelope. And people have found  
2 problems. It wasn't really the dispersion factor that  
3 was giving them a problem. It was the leak tightness  
4 of the control room envelope.

5 CHAIRMAN BANERJEE: Well, I think there  
6 could be some special situations because it might have  
7 slightly offsite hazards with, you know, possibility  
8 of releases from those hazards, and they are not  
9 radiological issues. They are non-radiological  
10 issues. So, I stand --

11 MR. PEREZ: Okay.

12 CHAIRMAN BANERJEE: It is a different  
13 problem, but it is an issue which has come up. So, it  
14 depends where the site is.

15 MR. PEREZ: Yes.

16 CHAIRMAN BANERJEE: You have got to  
17 realign what is transporting, whether it has got  
18 chlorine in it, and that --

19 MR. PEREZ: Chemicals, yes.

20 CHAIRMAN BANERJEE: Okay. Go ahead.

21 MR. PEREZ: Okay. So, for the tube  
22 rupture, let's see, the initial for all other  
23 radionuclides we have the design bases concentration  
24 responding 0.25 percent failed fuel fraction.

25 This, by the way, is the same one that we

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 did for Chapter 12, Shielding, you know, and the other  
2 chapters.

3 And we also, something that came out of  
4 the NRC Regulatory Issue Summary 2000.604, the Steam  
5 Unit Releases, which includes the noble gases along  
6 with the alkalis, and all other nuclides are assumed  
7 to stay within the liquid phase. So, you get into the  
8 steam space, the iodines, the noble gases, and the  
9 alkalis.

10 The scenario that was chosen out of many,  
11 many cases that were run from the thermal hydraulic  
12 side, we looked at four events that maximized the  
13 break flow and flashing fraction. And the one that  
14 was selected corresponds to a case where the reactor  
15 trip is by operator action concurrent with the loss of  
16 offsite power at 30 minutes.

17 And I believe that is very conservative.  
18 Because if you have 60 microcuries per gram of iodine  
19 or a coincidence spike that is bringing you up, you  
20 are going to see that pretty quickly from plant  
21 monitoring, air rejectors, steam line monitors. You  
22 are going to have plenty of notification. But we will  
23 wait 30 minutes and then we will start the action.

24 MEMBER STETKAR: Pedro, this will bear on  
25 a question I will have later. I want to make sure I

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 understand that nominal scenario that is used. And if  
2 you are not the right person to answer, then,  
3 hopefully, somebody else is.

4 As I understand it, in terms of timing,  
5 the tube rupture event occurs at T=0, time T equals  
6 zero. Both charging pumps are assumed to be  
7 available. Letdown is isolated, so that you have  
8 maximum makeup capability, and a manual reactor trip,  
9 as you have noted, occurs at 30 minutes in combination  
10 with simultaneous loss of offsite power. It is  
11 assumed that offsite power is lost simultaneous with  
12 the reactor trip, and that the operators initiate  
13 their manual tube rupture responses 10 minutes later.

14 That's right. Yes, 10 minutes later. And that the  
15 main steam relief control valves on the ruptured steam  
16 generator sticks open at about the same time. It is  
17 actually about a minute later, 2450 seconds as opposed  
18 to 2400 seconds. And at that point, you start getting  
19 the direct offsite release.

20 And according to the timeline, at least as  
21 I can piece together, the partial cooldown of the  
22 intact steam generators is completed at 3600 seconds  
23 or about 20 minutes after the operators initiate their  
24 actions.

25 Now, from a release perspective, for the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 first 30 minutes, you are actually releasing into the  
2 main condenser. Does the radiological analysis  
3 account for the dilution within the main condenser?  
4 So, effectively, you don't get any releases?

5 MR. PEREZ: We apply a DF of 100. In  
6 reality, the DF is much, much higher.

7 MEMBER STETKAR: Okay, but you do apply  
8 the DF --

9 MR. PEREZ: Yes.

10 MEMBER STETKAR: -- for that first 30  
11 minutes?

12 MR. PEREZ: Yes.

13 MEMBER STETKAR: What is the duration of  
14 the actual unmitigated direct release from the stuck-  
15 open valve? It sounds like it is a maximum of about  
16 20 minutes, but it might be only 10 minutes, depending  
17 on what your presumptions are about isolating the  
18 steam generator and whether or not pressure in that  
19 steam generator increases enough so that you -- it is  
20 a timing issue of how rapidly they cool down versus  
21 increase in pressure in the ruptured steam generator.

22 Can you get up to the safety valve setpoints and  
23 still get a little more release?

24 After 3600 seconds, you know, I don't care  
25 how long you take it out, you're not getting any

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 measurable releases out of that thing. So, the  
2 question is, what release duration do you have,  
3 unmitigated, direct offsite release duration do you  
4 have from this nominal scenario, if I have  
5 characterized that correctly?

6 MR. COFFEY: This is Ken Coffey.

7 I think Paul Bergeron might have the  
8 answer for us.

9 There is actually, following the failure  
10 of the MSRT, the steam generator pressure of the  
11 affected steam generator decreases rapidly. So, we  
12 actually have an automatic isolation of the MSRIV, the  
13 main steam release isolation valve, approximately, I  
14 will say, within a couple hundred seconds after the  
15 failure of the MSRT.

16 MEMBER STETKAR: Yes, so you are  
17 accounting for that? Okay. So, you only have an  
18 actual release duration of two or three, three or four  
19 minutes perhaps?

20 MR. BERGERON: There is a table in the  
21 FSAR that gives the sequence of events.

22 MEMBER STETKAR: Yes, I was trying to find  
23 that.

24 MR. BERGERON: Yes, it is Table 15.6-6.

25 MEMBER STETKAR: 15.6-6? Thanks. I was

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 trying to listen and talk and find tables. There it  
2 is.

3 MR. BERGERON: Yes, you get the point  
4 where the steam generator reaches the MSRT setpoint.

5 MEMBER STETKAR: Okay. Yes.

6 MR. BERGERON: And, then, where the IV  
7 isolates.

8 MEMBER STETKAR: Yes. Yes. Okay. So,  
9 your release duration is only two minutes?

10 MR. BERGERON: Yes, in that order.

11 MEMBER STETKAR: In terms of measurable-  
12 type releases?

13 MR. BERGERON: Right.

14 MEMBER STETKAR: Okay.

15 MR. BERGERON: At least for that period,  
16 but then you have releases that continue through --

17 MEMBER STETKAR: Yes, but those releases,  
18 you know, they're --

19 MR. BERGERON: Those are direct.

20 MEMBER STETKAR: Hum?

21 MR. BERGERON: That is a direct release.

22 MEMBER STETKAR: This direct release --

23 MR. BERGERON: Right.

24 MEMBER STETKAR: -- is two minutes?

25 MR. BERGERON: Right.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER STETKAR: But the first 30 minutes  
2 is filtered through the main condenser.

3 MR. BERGERON: Correct.

4 MEMBER STETKAR: Then you get a direct  
5 release of a couple of minutes.

6 MR. BERGERON: And, then, you get a  
7 continued release through the intact generators --

8 MEMBER STETKAR: Right, but those are  
9 pretty doggone small.

10 MR. BERGERON: They are small compared to  
11 this one.

12 MEMBER STETKAR: Yes. You account for  
13 leakage. But you also get a DF through the water in  
14 the attacked steam generators and all that.

15 I just wanted to make sure that -- and it  
16 is only about two minutes --

17 MR. BERGERON: Okay.

18 MEMBER STETKAR: Because later this  
19 afternoon, I guess when we get into the mitigation  
20 systems, I want to understand whether that nominal  
21 scenario, in fact, is limiting from a release  
22 perspective compared to another one that I dreamed up.

23 But it is too long to get into it right now.

24 I just wanted to make sure I understood  
25 this one first, and I had even missed the two-minute

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 isolation. So, thanks.

2 MR. PEREZ: But I believe that in our  
3 analyses we said at 30 minutes a decision is made to  
4 trip the reactor --

5 MEMBER STETKAR: Yes.

6 MR. PEREZ: -- the operator action.

7 MEMBER STETKAR: Yes.

8 MR. PEREZ: An additional 10 minutes to  
9 isolate the ruptured steam generator. So, an action  
10 has not been performed after the reactor trip for 10  
11 minutes. So, you are releasing through the MSRT.

12 MEMBER STETKAR: No, that's not actually  
13 true because the MSRT doesn't stick open until  
14 pressure gets in the ruptured steam generator. It  
15 gets to the isolation valve opening setpoint, which,  
16 indeed, according to this timeline -- and thanks for  
17 the table -- is a minute after that 10 minutes. It is  
18 11 minutes into the event, 10 minutes and 50 seconds  
19 after the reactor trip.

20 MR. BERGERON: I think we are releasing  
21 through the intact generators, too, until the affected  
22 one is isolated.

23 MR. PARECE: No. This is Marty Parece  
24 again.

25 The key is the loss of offsite power.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 When you trip the reactor and then you get the loss of  
2 offsite power, all steaming to the condenser ends.

3 MEMBER STETKAR: That is correct.

4 MR. PARECE: And all four steam generators  
5 steam to the atmosphere through the MSRTs and remove  
6 decayed heat.

7 MEMBER STETKAR: According to this, not  
8 until 11 minutes later.

9 MR. PARECE: No, it happens, from reactor  
10 trip alone, it happens from all four.

11 MEMBER STETKAR: It says, "Affected steam  
12 generator pressure increases to MSRT setpoint. MSRCV  
13 fails open in fully open position at 2450 seconds."

14 MR. PARECE: That's what it says.

15 MEMBER STETKAR: That's what it says.

16 MR. PARECE: But I don't see how --  
17 well --

18 MEMBER STETKAR: That's what it says.

19 MR. PARECE: I know, but you have to  
20 release decayed heat.

21 MEMBER STETKAR: Yes, you do.

22 MR. PARECE: So, all four steam generators  
23 have to steam on reactor trip. They have to.

24 MEMBER STETKAR: Well, but --

25 MR. PARECE: So, during that time, you are

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 releasing --

2 MR. COFFEY: I don't know what's  
3 happening. One of my questions was, how --

4 MR. PARECE: Well, it is a good question.

5 MEMBER STETKAR: It is a minute after the  
6 guys start to bottle the thing up that it opens.

7 MR. PARECE: It is a very good question  
8 the way it is written because, physically, you have to  
9 get the decayed heat out.

10 MEMBER STETKAR: Yes. No.

11 MR. PARECE: So, all four generators in  
12 under 10 minutes.

13 MEMBER STETKAR: Right. Right.

14 MR. PARECE: Then, the operator decides to  
15 isolate, and that's when he finds out that -- that is  
16 really when his first chance to find out the valves,  
17 if there is a failure in the valve.

18 MEMBER STETKAR: Yes. Yes. But this  
19 seems to imply that the valve doesn't stick open until  
20 about, let's say, a minute after they decide that they  
21 have got a tube rupture. They know that they have a  
22 tube rupture from N16.

23 CHAIRMAN BANERJEE: It seems that we  
24 have --

25 MEMBER STETKAR: There seems to be a

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 timing question here.

2 CHAIRMAN BANERJEE: Yes, a question to be  
3 sort of clarified and answered. Maybe we can defer  
4 that until --

5 MS. SLOAN: Yes, I think we can handle  
6 that during the tube rupture session.

7 MR. COFFEY: And I could probably add an  
8 element to that discussion as well.

9 MEMBER STETKAR: Because I dreamed up a  
10 different scenario that might have a different timing,  
11 but this discussion helps me kind of over lunch to  
12 understand this scenario a little bit better, though.  
13 So, thanks.

14 CHAIRMAN BANERJEE: So, Derek, let's  
15 ensure that this gets discussed during the afternoon.

16 MEMBER STETKAR: Yes. Well, they have a  
17 presentation on the tube rupture.

18 CHAIRMAN BANERJEE: Yes. Yes. Sure. So,  
19 we are going to follow up on that. Okay.

20 Go ahead.

21 MR. PEREZ: And again, this slide may help  
22 or not. But atmospheric releases consist of the  
23 secondary-side activities, reactor coolant system  
24 leakage via the affected steam generator, and the  
25 normal leakage via the three intact steam generators.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 So, those are assumed to be leaking from the primary  
2 to the secondary at the tech spec limit.

3 And again, you have the condition of the  
4 either preexisting iodine spike or the accident-  
5 generated. So, you are putting in radioactivity into  
6 those steam generators. And there, you cool the plant  
7 down. For the duration of the eight hours that I  
8 mentioned, we track the inventory in the intact steam  
9 generators and release it through the plant cooldown.

10 So, the early releases are via the  
11 condenser until 30 minutes, when the operator trips  
12 the plant, and, then, via the main steam relief train.

13 And, then, iodine and alkali depletion due to  
14 deposition within the condenser is credited with a DF  
15 of 100.

16 CHAIRMAN BANERJEE: What is the pH in this  
17 condenser? Do you have a trapped behavior? I mean  
18 you say it is depletion, but I don't know what the pH  
19 is.

20 MR. PEREZ: No, no, no. The depletion is  
21 by condensation on the condenser tubes. So, it is not  
22 a chemical. It is just a condensation will deposit.  
23 It has an enormous surface area.

24 CHAIRMAN BANERJEE: Yes.

25 MR. PEREZ: But the pH, I would say, I

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 don't know, but we do not take credit for any  
2 speciation, any iodine speciation.

3 CHAIRMAN BANERJEE: What do you mean by  
4 alkali depletion?

5 MR. PEREZ: Both the iodines and the  
6 alkalines are being removed.

7 CHAIRMAN BANERJEE: What alkali are we  
8 talking about?

9 MR. PEREZ: The chemicals.

10 CHAIRMAN BANERJEE: Oh, okay, on the --

11 MR. PEREZ: So, from the reactor cooling  
12 system into the secondary system due to the leakage,  
13 transported to the condenser, the condenser is acting  
14 like a filter with a DF of 100 for these 30 minutes.

15 CHAIRMAN BANERJEE: I guess the condenser  
16 water you are saying is going to be a pH 7,  
17 essentially, or what?

18 MR. PEREZ: No, what I am saying is the  
19 process of condensation removes particulates. It  
20 removes radioactivity. Noble gases has a DF of 1. It  
21 doesn't do anything. But for the iodine and the  
22 alkalines that we are tracking, the condenser has an  
23 effective DF.

24 CHAIRMAN BANERJEE: Yes. I am just  
25 wondering where that 100 is coming from. Is that a DF

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 which is normally taken for things like this?

2 MR. PEREZ: Well, it has been taken in  
3 previous applications.

4 CHAIRMAN BANERJEE: I notice you reference  
5 a NUREG.

6 MR. PEREZ: Correct.

7 CHAIRMAN BANERJEE: Yes.

8 MR. PEREZ: It is much higher. The NUREG  
9 will tell you it's 10,000.

10 CHAIRMAN BANERJEE: Okay.

11 MR. PEREZ: It is much higher because,  
12 again, the big surface area plus the process of  
13 condensation does effective cleanup. We used 100.

14 CHAIRMAN BANERJEE: Dana probably knows  
15 this stuff. I don't follow this, but okay. That is  
16 where it comes from, just the condensation into a  
17 large surface area. Okay.

18 MR. PEREZ: Right. I mean I can give you  
19 an analogy. In firefighting, if you go into a  
20 heavily-suited room, you spray that air with water; it  
21 drops everything down. It cleans it. So, the effect  
22 of that water with the heat just scrubs out that air.

23 CHAIRMAN BANERJEE: Yes, but it is  
24 different. So, into your condenser is coming steam,  
25 right?

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 MR. PEREZ: Yes.

2 CHAIRMAN BANERJEE: And typically, what is  
3 happening is that you get film wires or drop wires  
4 condensation. This is film wires on your condenser  
5 tubes.

6 Then, it is not quite the same as spraying  
7 a room with water. So, what you are assuming is that  
8 iodine then transfers particulates by some mass  
9 transfer process from the steam to the liquid. Now I  
10 am sure this is treated in the NUREG. I'm just not  
11 familiar with it. But it is not the same process as  
12 spraying it. Unless there is some analogy, it is more  
13 a mass transfer process.

14 Now, if there is a mass transfer going on,  
15 then there has to be a driving force, and the driving  
16 force will be based on what is the pH of that water  
17 because the solubilities, and everything, are  
18 different. It is not quite the same thing, unless I  
19 am missing the mechanism.

20 Does Bill know this thing better than I  
21 do?

22 MR. PEREZ: There is a term. You know,  
23 when the steam is being condensed, you are getting the  
24 water droplets, if you would.

25 CHAIRMAN BANERJEE: So, let's take just a

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 liquid film. Okay? And it is condensing there,  
2 right? So, there are different mechanisms. So, the  
3 iodine might be also condensing on the film, or  
4 whatever. I just don't understand. It is not the  
5 same as spraying into a particulate system, or  
6 whatever, and then washing it down because this is  
7 just steam condensing on some form of a surface.

8 MR. PEREZ: Yes.

9 CHAIRMAN BANERJEE: There is a very large  
10 surface area. If it is a very large surface area, the  
11 mass transfer is good. Accessibility to this cold  
12 region is good.

13 Now, as the steam moves, it brings with it  
14 iodine as well, which is, let's say, uniformly  
15 dispersed in the steam.

16 MR. PEREZ: Yes.

17 CHAIRMAN BANERJEE: So, the mechanism is  
18 different, and I just don't know what the mechanism  
19 is. I'm just trying to figure it out. I guess  
20 experiments show that the decontamination is very high  
21 probably?

22 MR. PEREZ: Yes.

23 CHAIRMAN BANERJEE: That's good enough  
24 right now. Let's carry on, yes.

25 MR. PARECE: I was going to suggest that

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 we move ahead --

2 CHAIRMAN BANERJEE: Yes.

3 MR. PARECE: -- because this is not  
4 specific to EPR.

5 CHAIRMAN BANERJEE: No.

6 MR. PEREZ: This is true for all  
7 condensers and all plants.

8 Also, the first papers I remember on this  
9 go back to the seventies, I think, by Postma and Tam.

10 There is a NUREG where they tried to start the first  
11 models on figuring out how iodine is washed out in  
12 steam generators during a tube rupture. And in that,  
13 they reference a lot of data, and a lot of that is in  
14 the NUREG as well.

15 So, the real factor is that iodine in its  
16 particulate and in its gaseous forms wants to maintain  
17 an equilibrium in the vapor phase with the liquid  
18 phase.

19 CHAIRMAN BANERJEE: Yes.

20 MR. PARECE: So, if you have a lot of  
21 liquid with no iodine in it, the iodine runs to the  
22 liquid to maintain this relationship --

23 CHAIRMAN BANERJEE: Partition, yes.

24 MR. PARECE: -- this factor.

25 CHAIRMAN BANERJEE: Yes.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. PARECE: And it generally varies  
2 between 1,000 and 10,000, depending on the pH and the  
3 oxygen content. And the guys used 1,000.

4 So, there is a lot of information out  
5 there if we want to go for that.

6 CHAIRMAN BANERJEE: No, no. I don't  
7 particularly want to visit it. I just want to know  
8 that that is a secure number.

9 MR. PEREZ: I am confident that number is  
10 secure.

11 CHAIRMAN BANERJEE: Okay. Carry on.

12 MR. PARECE: This has been studied for --

13 CHAIRMAN BANERJEE: Decades.

14 MR. PARECE: -- at least 40 years now.

15 CHAIRMAN BANERJEE: Yes.

16 MR. PEREZ: Okay. The next, we decided to  
17 discuss the LOCA, primarily because we are going to  
18 use Dr. Powers' model.

19 (Laughter.)

20 So, I thought he would be asking --

21 CHAIRMAN BANERJEE: For this part of it,  
22 Powers should be here.

23 (Laughter.)

24 MR. PEREZ: Yes. Basically, we start out  
25 with --

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIRMAN BANERJEE: He can't say anything  
2 now.

3 (Laughter.)

4 MEMBER SHACK: It never stopped him  
5 before.

6 CHAIRMAN BANERJEE: It never stopped him  
7 before.

8 (Laughter.)

9 MR. PEREZ: We start with the bounding co-  
10 inventory. You have seen this before. We do a  
11 parametric set of cases using ORIGIN from 5- to 62-  
12 gigawatt based on metric ton in 5-gigawatt days per  
13 metric ton steps, looking at enrichments, 2 percent  
14 enrichment, 3.5, and 5 percent enrichment. And from  
15 there, we select a bounding core inventory.

16 CHAIRMAN BANERJEE: However, we can  
17 question Bob Henry's part of the model.

18 (Laughter.)

19 MR. PEREZ: The scenario is basically  
20 driven, once again, by Regulatory Guide 1.83. It will  
21 be Appendix A.

22 As you well know, it is a time-based  
23 release. The timing is provided by the guidance. We  
24 only credit natural deposition within the reactor  
25 building. We used the Powers 10 percentile natural

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 deposition model. That model ends at 22.2 hours, and  
2 we wanted it to continue using natural deposition. It  
3 would not be proper to keep a constant value at 22.2  
4 because the lambdas, the precision rates, keep going  
5 down.

6 Within the RADTRAD code, you have a choice  
7 of using Powers or Henry. We, then, extended the  
8 deposition with Henry. And what we did was we ran  
9 Henry and Powers together, okay, and then knew we had  
10 a good transition to continue with Henry.

11 Now these lambdas are quite natural  
12 deposition and quite small. You continue to have a  
13 high airborne concentration, but it is an effective  
14 way of reducing your airborne contamination.

15 We start the accident assuming we are  
16 actually purging the containment. Ten seconds of  
17 containment purge is assumed.

18 We have an allowable leakage rate of 0.25  
19 weight percent per day for the first 24 hours, reduced  
20 to 50 percent of that value thereafter for the  
21 duration of the 30-day calculations we performed for  
22 the LPZ and control room.

23 Any release, any containment leakage  
24 release, will be assumed to be through the steam  
25 generator three main steam relief train during the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 time it takes the annulus ventilation system and the  
2 safeguard building mechanical area filters to draw  
3 down to subatmospheric dose locations. Until we meet  
4 subatmospheric, we do not credit filtration.

5 CHAIRMAN BANERJEE: How long does that  
6 take?

7 MR. PEREZ: Three hundred and five seconds  
8 for the annulus drawdown system and 289 seconds for  
9 the safeguard building mechanical area.

10 CHAIRMAN BANERJEE: What buffers do you  
11 use? Trisodium phosphate?

12 MR. PEREZ: Trisodium phosphate.

13 CHAIRMAN BANERJEE: Yes.

14 MR. PEREZ: To buffer.

15 CHAIRMAN BANERJEE: Yes, for this plant,  
16 right?

17 MR. PEREZ: For this plant, yes.

18 CHAIRMAN BANERJEE: Okay. And how is that  
19 suspended? Does it dissolve?

20 MR. PEREZ: It dissolves by --

21 CHAIRMAN BANERJEE: Very quickly? How  
22 long does it take?

23 MR. PEREZ: It's 14,000 pounds in four  
24 baskets. It is very hygroscopic. It is absorbs water  
25 within hours, within hours.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIRMAN BANERJEE: So, in this period, it  
2 is all dissolved or not dissolved? Three hundred and  
3 five seconds, nothing has happened, right?

4 MR. PEREZ: Oh, no, but you are not  
5 producing -- remember, you start to develop acids due  
6 to radiolysis of water and cabling, and that is time-  
7 dependent.

8 CHAIRMAN BANERJEE: So, your pH is always  
9 staying around 7?

10 MR. PEREZ: Yes.

11 CHAIRMAN BANERJEE: Throughout? And you  
12 have done that calculation?

13 MR. PEREZ: Yes. Yes, we have done that  
14 calculation. That is how we determine 14,000 or so  
15 pounds of TSP.

16 What is happening during this time is the  
17 airborne contamination in the reactor building is  
18 leaving the building unfiltered. So, it has not even  
19 had a chance to make it to the RWST. So, it is an  
20 airborne through the penetrations that I showed  
21 bypassing --

22 CHAIRMAN BANERJEE: You just take  
23 deposition due to this Powers/Henry model?

24 MR. PEREZ: Yes.

25 CHAIRMAN BANERJEE: That's all you are

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 doing right now?

2 MR. PEREZ: That is all we are doing, yes.

3 CHAIRMAN BANERJEE: Okay. And that is  
4 roughly what? Not that much?

5 MR. PEREZ: The lambda, something like 0.2  
6 per hour. Compared to other methods, it is very, very  
7 low.

8 CHAIRMAN BANERJEE: Yes. So, why do you  
9 need to take it into account at all? Does it help?

10 MR. PEREZ: Oh, yes. Yes. Over 30 days,  
11 yes.

12 CHAIRMAN BANERJEE: Well, yes, over 30  
13 days, but in this early phase --

14 MR. PEREZ: You need to start it sometime.

15 CHAIRMAN BANERJEE: Okay. So, that is why  
16 you are doing it, right?

17 (Laughter.)

18 But it doesn't help you very much in the  
19 early phase, does it?

20 MR. PEREZ: No.

21 CHAIRMAN BANERJEE: No.

22 MR. PEREZ: No. No. No.

23 CHAIRMAN BANERJEE: It doesn't do much.  
24 Okay.

25 MR. PEREZ: As I mentioned, after we

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 finally have the drawdown of these rooms, then we have  
2 the release at the base of the stack. Because the  
3 alignment of these filters is to exhaust through the  
4 stack.

5 The environmental releases, 10 seconds on  
6 filter release during containment purge. Containment  
7 leakage via the annulus without holdup or depletion,  
8 and then, later, 99 percent exhaust filters,  
9 ventilation, filtration for the annulus and the  
10 mechanical areas of the safeguard building.

11 ESF component leakage is via the safeguard  
12 building without holdup or depletion. And again,  
13 within the safeguard building, there's 99 percent  
14 filtration following drawdown.

15 And there was another presentation that I  
16 remember the ACRS asking about. You know, how come  
17 the doses are high? I think a question was asked like  
18 that, and, basically, I had looked at other design  
19 centers, and our doses are comparable. And they  
20 should be because they are all using the same  
21 methodology. They are also using similar dispersion  
22 factors.

23 So, when you normalize things to power,  
24 when you look at a per a megawatt basis, we are not  
25 that different. If you are taking a passive system

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 with the lower deposition, you are going to be using  
2 the same models. You are going to be using the same  
3 depletion rates.

4 These are the calculated doses in design  
5 certification for the exclusionary boundary, the low-  
6 population zone, and the control room. All these  
7 doses here have been calculated using data from  
8 thermal hydraulic calculations and fuel performance  
9 calculations.

10 These last three -- and Jonathan had  
11 alluded to this -- these last three, we actually did  
12 it backwards. We calculated what would be the decay  
13 time for a fuel-handling accident that would give you  
14 90 percent of the dose acceptance criteria. So, if  
15 you divide these numbers, you would realize that all  
16 these are 90 percent of the acceptance criteria.

17 And again, that was done. Part of it was  
18 timing of when the calculations were done and, again,  
19 to provide a bigger umbrella for the COLA applicants,  
20 for the future when these applications come through.

21 And I believe this is my last slide.

22 CHAIRMAN BANERJEE: Right. Okay. So,  
23 does anybody have any questions, comments? John?  
24 Bill?

25 (No response.)

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1           So, in that case, what we will do is we  
2 will take a lunch break now. It was supposed to be  
3 from 12:15 to 1:15. What we will do is we will take  
4 it from 12:30 to, let's make it, 1:30. I think we can  
5 manage to keep it under control. Okay. So, we will  
6 start at 1:30 with the steam generator, I guess.

7           Thank you.

8           (Whereupon, the foregoing matter went off  
9 the record for lunch at 12:29 p.m. and resumed at 1:31  
10 p.m.)

11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

A-F-T-E-R-N-O-O-N S-E-S-S-I-O-N

1:31 p.m.

CHAIRMAN BANERJEE: We are going to go back into session, and our reporter is ready. So, back in session. Back on the record.

MR. COFFEY: Thank you.

Good afternoon, everyone.

My name is Ken Coffey, an Engineer IV with AREVA in the Engineering Integration Plant Operations Division.

A little background on myself: I received my bachelor's degree from the University of Illinois at Urbana-Champaign in nuclear engineering. I did a master's degree at L'Ecole des Mines de Nancy in Nancy, France in material science.

A little over nine years of engineering experience, the last seven of which have been spent developing shear action guidance and emergency procedure guidance for numerous projects, notably GALL Phase 2. The last two years, I have been working on the U.S. EPR. I am currently the Emergency Procedure Guidance Development Team Lead.

CHAIRMAN BANERJEE: You are the what?

MR. COFFEY: I am the lead for the Emergency Procedure Group.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 CHAIRMAN BANERJEE: Okay.

2 MR. COFFEY: The agenda for what I will  
3 present to you today. So, that is an overview of the  
4 steam generator tube rupture mitigation strategy and  
5 goals. We have broken down the mitigation into four  
6 main stages. I will cover those one at a time, and  
7 finish with the mitigation comparison, how we would  
8 use various systems, notably, with or without offsite  
9 power. That is one of the major differences into how  
10 one would mitigate a steam generator tube rupture.

11 I would like to start off by saying that  
12 the U.S. EPR, the mitigation of a steam generator tube  
13 rupture for the U.S. EPR is very similar to existing  
14 four-loop PWRs. We have the ability to mitigate them  
15 in essentially the same fashion that the existing  
16 fleet does today.

17 We have been able to incorporate the  
18 specificities, as Doug Brownson showed us earlier.  
19 Once we reset the MSRT setpoint to the high value of  
20 1436 psia, we can then mitigate an SGTR using ECCS  
21 systems and control our CS inventory without the risk  
22 of lifting the safety. This does help us greatly to  
23 minimize releases in the short-term and, also, prevent  
24 the risk of overfill due to high-pressure injection of  
25 the ECCS.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 We do utilize the extra borating system to  
2 provide a safety-related means to borate the RCS. So,  
3 the main goals in SGTR mitigation:

4 First, you want to achieve a controlled  
5 state to ensure RCS stability, a controlled state  
6 being a state in which the core is subcritical, being  
7 removed via the steam generators, and core water  
8 inventory is stable. And the RCS makeup compensates  
9 for the SGTR leak rate.

10 Next we move to terminate the releases  
11 from the affected steam generator as soon as practical  
12 and move to cancel the leak rate from the primary to  
13 the secondary, and, then, finally, reach safe  
14 shutdown. And I will go into detail on how we do each  
15 of those to meet those goals.

16 So, the four main stages of STGR  
17 mitigation:

18 First, you have to identify that you have  
19 a steam generator tube rupture.

20 Next, you need to shut down the reactor  
21 and isolate the steam generator as quickly as  
22 possible.

23 Next, again, you cancel the leak flow from  
24 the RCS to the affected steam generator.

25 And finally, cool down and depressurize

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 the RCS as well as the affected steam generator to an  
2 RHR connection.

3 So, first, SGTR identification. How do we  
4 know we have one? Primary means of SGTR  
5 identification are main steam line radiation monitors.

6 As noted earlier, we have four main steam line  
7 radiation monitors that are safety-related per train.

8 We also have non-safety-related steam generator  
9 blowdown line radiation monitors as well as condenser  
10 off-gas rad monitors.

11 For situations where we could have an SGTR  
12 at low power, we could utilize system response to help  
13 diagnose the SGTR. We have feed-flow/steam-flow  
14 mismatch as well as watching the pressurizer pressure  
15 and level decrease.

16 CHAIRMAN BANERJEE: Just go back one  
17 slide.

18 MR. COFFEY: Yes.

19 CHAIRMAN BANERJEE: Okay. Thanks.

20 MR. COFFEY: Okay. So, once we have  
21 identified the SGTR, we need to shut down the plant.  
22 Dr. Witter showed us earlier this morning all the  
23 automatic reactor trip functions. So, I am not going  
24 to go back into that detail right now.

25 What is worth noting is that for double-

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 ended guillotine steam generator tube rupture, the  
2 startup of the second CVCS charging pump does allow us  
3 to compensate for the leak. This is why the reactor  
4 trip may be manual on one of the credited actions we  
5 took in our FSAR analyses.

6 So, once we have tripped the reactor, then  
7 we move quickly to isolate it. Isolation of the  
8 affected steam generator involves closure of the main  
9 feedwater and emergency feedwater isolation valves  
10 that affect the steam generator; isolation of the  
11 steam generator blowdown lines; closure of the main  
12 steam isolation valve, the affected steam generator,  
13 and the reset of the MRST setpoint.

14 This isolation can be either automatic or  
15 manual. There is an automatic signal sent from the  
16 protection system to perform this isolation. If we  
17 have a partial cooldown signal with a concurrent  
18 either steam generator or high steam generator level  
19 or high activity in the main steam line, detected by  
20 the main steam line radiation monitors.

21 We also have the ability to do this  
22 manually. The manual isolation will be performed by a  
23 group command. So, essentially, the operator has one  
24 button to push, and all these actions will occur.

25 So, once we have shut down the plant and

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 isolated it, we have isolated this extra generator, we  
2 need to cancel the leak. Stages 3 and 4 can vary  
3 greatly depending on the equipment that we have  
4 available to mitigate the transient.

5 So, what I will start off by presenting  
6 here in the initial runthrough of stages 3 and 4 are  
7 the systems that we used for an SGTR with concurrent  
8 loss of offsite power in our FSAR.

9 In order to ensure RCS inventory, we need  
10 to initiate safety injection if we don't get an  
11 automatic safety injection signal. One of the outputs  
12 of the safety injection actuation is the initiation of  
13 the partial cooldown at 180 degrees F per hour, using  
14 only the unaffected steam generators.

15 We will feed the unaffected steam  
16 generators with emergency feedwater, which will be  
17 started manually, if necessary. And again, RCS  
18 inventory is maintained by the use of the safety  
19 injection system.

20 And at this point, we will allow the RCS  
21 pressure to be reduced to that of the affected steam  
22 generator. Essentially, we have no high-pressure  
23 injection means in the RCS. So, there is nothing  
24 keeping the RCS pressure hot. The RCS pressure will  
25 eventually fall to that of the shutoff head. And

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 while the RCS pressure is flowing down, the affected  
2 steam generator pressure will tend to rise until they  
3 reach a quasi-equilibrium.

4 CHAIRMAN BANERJEE: So, this 180 fan  
5 height is the same as if you didn't have the steam  
6 generator bottled up, right?

7 MR. COFFEY: That's correct.

8 CHAIRMAN BANERJEE: And that is possible  
9 with three steam generators?

10 MR. COFFEY: Right. That is correct.  
11 And, essentially, the cooldown rate, we did see in our  
12 analyses that we were able to achieve the 180 degrees  
13 per hour. The rate, in and of itself, is not that  
14 critical to the transient. Again, as I noted, since  
15 the steam generator is already isolated, our releases  
16 have been stopped from the affected steam generator.  
17 So, if it is 180 or 150, the overall impact is  
18 negligible. So, yes, but our analyses have shown that  
19 we are able to achieve the 180 degrees F with three  
20 steam generators.

21 CHAIRMAN BANERJEE: Okay. And how long  
22 does it take to get down to 870 then?

23 MR. COFFEY: Partial cooldown lasts about  
24 15 minutes. It lasts approximately 15 minutes. At  
25 that point, the secondary side is the side that gets

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 down to 870 psi. The primary side lags. I don't know  
2 exactly --

3 CHAIRMAN BANERJEE: But 870 is --

4 MR. COFFEY: Is the steam generator  
5 pressure of the unaffected steam generators.

6 CHAIRMAN BANERJEE: Okay. Right. Go  
7 ahead.

8 MEMBER SHACK: How long until you can do  
9 the medium head injection for high head injection?

10 CHAIRMAN BANERJEE: That's the secondary  
11 site, right?

12 MR. COFFEY: I want to say, I can look  
13 into it. We have the detailed results and  
14 calculations. I can get that information.

15 CHAIRMAN BANERJEE: So, 870 psi has a  
16 significance? John was saying that it allows the  
17 medium pressure injection.

18 MR. COFFEY: Right. So, theoretically, at  
19 the end of partial cooldown, we should have --

20 MEMBER SHACK: That is enough. Again, I  
21 didn't do the math, but on convey designs it is enough  
22 subcooling such that pressure in the primary system --

23 CHAIRMAN BANERJEE: Gets down to --

24 MEMBER SHACK: -- gets down below whatever  
25 the shutoff head of medium head safety injection is.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIRMAN BANERJEE: Which is somewhat  
2 above this?

3 MR. COFFEY: Right. The shutoff head is  
4 1405.

5 CHAIRMAN BANERJEE: Okay.

6 MR. COFFEY: So, again, stage 3, we acted  
7 to cancel the primary to the secondary leak. Now we  
8 need to cool down and depressurize the RCS to RHR  
9 connection conditions. A cooldown of the RCS is  
10 performed using the MSRTs at the unaffected steam  
11 generators at either 45 degrees an hour or 90 degrees  
12 F per hour, depending on the number of EBS trains we  
13 have in service. One train of EBS allows us to cool  
14 down at 45 degrees an hour to 90.

15 Medium-head safety injection will be  
16 managed in order to allow us to maintain adequate  
17 subcooling margin, keep RCS inventory in the desired  
18 range, at least within the pressurized level  
19 indication range, and, also, it will manage to allow  
20 for the depressurization of the RCS to the RHR  
21 connection condition pressures.

22 CHAIRMAN BANERJEE: Now, for the  
23 unaffected steam generators, do you basically take the  
24 steam to the condensers?

25 MR. COFFEY: No, this will be via the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MSRTs. Right now, this is an SGTR with loss of  
2 offsite power. So, the condenser is not available.  
3 So, in this case, the --

4 CHAIRMAN BANERJEE: Loss of volts?

5 MR. COFFEY: That is correct.

6 CHAIRMAN BANERJEE: All right. So, you  
7 just blow steam?

8 MR. COFFEY: Just blowing steam out the  
9 atmosphere, that is correct.

10 Okay. And the final depressurization of  
11 the RCS will be performed by cycling the PSIVs, again,  
12 while trying to maintain within a desired band of some  
13 clean margin. And finally, that will allow us to get  
14 down to RHR connection pressures and temperatures, 455  
15 psia and 350 degrees.

16 Okay. As we move forward to develop the  
17 detailed emergency procedure guidance, they will be  
18 developed to utilize all available systems, obviously.

19 We don't just do SGTR mitigation with loop.

20 Preference is given to systems that  
21 accomplish the task as effectively as possible and as  
22 close to normal operating conditions as the situation  
23 permits. And again, availability of offsite power is  
24 one of the biggest factors in determining what we can  
25 use, what systems will be available, and what

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 mitigation strategies are going to be put in place.

2 So, here is a side-by-side comparison,  
3 again, stage 3, which is our leak cancellation stage  
4 of the systems that we would be able to use if we did  
5 have offsite power available to us. The RCS inventory  
6 could be controlled with CVCS makeup and letdown. RCS  
7 pressure would be controlled using sprays and heaters.

8 SG inventory would be feeding the SGs with main  
9 feedwater. And obviously, anytime you have SGTR, you  
10 want a steam condenser, if it is available.

11 And again, on the right you saw the  
12 systems that we used without offsite power: MHSI and  
13 EBS injecting into the RCS, and the RCS pressure  
14 controls not nearly as fine as we would have if we did  
15 have offsite power available to us. And the EFW is  
16 used for the secondary side.

17 And again, for stage 4, our final  
18 depressurization, with offsite power, there is a good  
19 chance we will have reactor coolant pumps running. If  
20 that is the case, then we have a much different  
21 transient. We will have forced circulations through  
22 the tubes of the affected steam generator, which acts  
23 to cool and essentially depressurize the steam  
24 generator, essentially, back-cooling the steam  
25 generator with a cooler water.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1                   We       continue       our       cooldown       and  
2       depressurization just as we did in stage 3, the CVCS  
3       providing the makeup; sprays and heaters, chill  
4       pressure; MFW, and turbine bypass.

5                   Then, without offsite power, again, the  
6       RCS pressure is held up by the pressure of the  
7       affected generator, which essentially acts as a  
8       secondary pressurizer for the system. So, therefore,  
9       we need to depressurize the RCS and the affected  
10      generator as well.

11                  Again, the systems used in that case for  
12      the MHSI and the EBS on the primary side; EFW and  
13      MSRTs on the secondary, with our final  
14      depressurization done via the PSRVs.

15                  CHAIRMAN BANERJEE: So, does this just go  
16      into natural circulation?

17                  MR. COFFEY: Yes. We do observe natural  
18      circulation in the three loops where we continue to  
19      steam the steam generators.

20                  CHAIRMAN BANERJEE: And how much is the  
21      maximum void fraction that occurs in the system? Is  
22      there any? Because you now don't have pumps, right?

23                  MR. COFFEY: Right.

24                  CHAIRMAN BANERJEE: So, does the system  
25      void?

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. COFFEY: I can ask --

2 MR. SALM: Yes. This is Robert Salm.

3 You have the affected loop that has been  
4 isolated, and the secondary side is full of hot,  
5 saturated liquid, and you are cooling down with  
6 natural circulation in the three intact loops. The  
7 affected loop is idle, and you have that hot water  
8 bottled up in there.

9 So, when you start bringing down the  
10 primary side, you are going to tend to flash and void  
11 in the upper part of the primary tubes of that  
12 affected steam generator.

13 CHAIRMAN BANERJEE: Only there?

14 MR. SALM: Only there. You have more than  
15 enough makeup with the MHSI. So, it is just in that  
16 one loop.

17 And, then, when you depressurize it, you  
18 know, it just sort of flushes the saturated liquid out  
19 of there.

20 MR. COFFEY: That's my final slide, but  
21 just to recall three main points: the SGTR mitigation  
22 for the U.S. EPR is very similar to existing four-loop  
23 BWRs. Our additional safety features help us to  
24 minimize releases and prevent overfill. And  
25 obviously, our MPGs, our major procedure guides, will

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 be developed to utilize all available systems.

2 So, do you have questions?

3 MEMBER STETKAR: Yes. I understand now, I  
4 think, the sequence of events for the nominal tube  
5 rupture sequence that is used in the release analysis.

6 I thought about a different sequence of events. And  
7 I don't know what all the setpoints are, so I don't  
8 have a good sense of the timing. But if you can help  
9 me walk through it a bit, maybe I can understand it a  
10 bit better.

11 Suppose you had no charging. Okay? So  
12 take a lot of the safety analyses, assume that one  
13 train is out for maintenance and you have a single  
14 failure in the second train. Since you only have two  
15 charging pumps, I could have one charging pump out for  
16 maintenance and I will take my single failure to be  
17 that other charging pump.

18 So, at T=0, I have no charging.

19 MR. COFFEY: Even for this case, let me  
20 interject, since the charging is not a safety system,  
21 we can just assume -- we had to do a whole spectrum  
22 of --

23 MEMBER STETKAR: Let's do that. Let's do  
24 that then. I didn't even take another single failure,  
25 but I wanted to understand this.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1           So, let's do away with charging.  However  
2 you rationalize it, it is not there.

3           Under those conditions, you do not have  
4 any type of makeup to the primary system, right?

5           MR. COFFEY:  Not at the initial stages.

6           MEMBER STETKAR:  And I would assume, then,  
7 that you will have an automatic reactor trip --

8           MR. COFFEY:  Right.

9           MEMBER STETKAR:  -- from what?  I'm going  
10 to guess low pressurizer pressure, but --

11          MR. COFFEY:  Low pressurizer pressure, low  
12 pressurizer level, one of those two.

13          MEMBER STETKAR:  One of those two?

14          MR. COFFEY:  Correct.

15          MEMBER STETKAR:  I don't know when that  
16 occurs.  I don't know when that occurs in time.

17          MR. COFFEY:  Okay.

18          MEMBER STETKAR:  So, let's assume you have  
19 the tube rupture at time T=0.

20          MR. COFFEY:  Right.

21          MEMBER STETKAR:  The question is, when  
22 does that automatic trip occur?  If I, then, assume  
23 that offsite power is lost at the time that the  
24 reactor trip occurs, consistent with the manual trip  
25 assumption, at that time -- and I will call it "T

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 reactor trip" -- I now have no secondary steam relief.

2 The main condenser is now isolated. I have no  
3 turbine bypass. The pressure starts to go up in my  
4 ruptured steam generator.

5 At some time out, I have a competing  
6 concern now. Pressure is going up in my ruptured  
7 steam generator. So, it may trigger the MSRT system  
8 to open. And I have pressure in the primary system  
9 continuing to decrease that is heading me toward an  
10 SI. So, I have got those two things going on.

11 At some time after T reactor trip, I will  
12 now pop open the main steam relief train and I will  
13 take the single failure of stick open the main steam  
14 control valve. Okay? And at some time, I will get an  
15 SI which triggers the blowdown steam generators.

16 As I understand it, the blowdown steam  
17 generators will blow down the ruptured steam  
18 generator. I don't see anything that will prevent  
19 that from happening.

20 MR. COFFEY: Well, actually, as I point  
21 out right here, this automatic SG solution, in this  
22 case where we have safety injection, an output of the  
23 safety injection is a partial cooldown. Again, when  
24 you have partial cooldown in conjunction with either a  
25 high activity in the main steam line or a high SG

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 level, you will get this automatic isolation of the  
2 affected generator with a signal sent from the  
3 protection systems.

4 MEMBER STETKAR: Where precisely does that  
5 show up in the logic diagrams for main steam release  
6 isolation valve isolation? Because the only signal I  
7 can find for that is low pressure in the steam  
8 generator, at least in the FSAR, Figure 7.3-13. And  
9 that is the only one that is referred to in the text  
10 of the FSAR telling me how I get that main steam  
11 relief train isolated, the MSRIV.

12 MR. COFFEY: Okay.

13 MEMBER STETKAR: So, if there are other  
14 signals, I have been searching to try to find them.  
15 They might in there somewhere. I have tried Chapter  
16 7. I have tried Chapter 6, and I have tried Chapter  
17 10. I can't find anything that talks about high  
18 radiation as an input stream. Seven is the one I was  
19 looking at mostly, which shows the logics.

20 But it tends to show only the safety-  
21 related logic. So, if the other is a non-safety-  
22 related isolation signal, I don't know whether the N16  
23 monitors are considered safety-related or not.

24 Anyway, the concern here is I am trying to  
25 understand a scenario where the normal automatic

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 response of the plant initiates a reactor trip  
2 automatically that cascades into a loss of offsite  
3 power and you get a safety injection because I have no  
4 makeup to the primary system, which triggers a single  
5 to blow down --

6 MR. COFFEY: Right.

7 MEMBER STETKAR: -- the ruptures steam  
8 generator, and that that condition persists until 30  
9 minutes, at which time I can now start taking credit  
10 for operator actions to manually bottle up the  
11 ruptured steam generator.

12 And the question is, are releases under  
13 that scenario worse than releases under the nominal  
14 scenario that has, for all practical purposes, about a  
15 two-minute, depending on the relative timing that we  
16 were talking about before lunch, kind of a couple-of-  
17 minute release time through that open control valve.

18 And I was curious whether there is an  
19 analysis of that type of scenario done. Because I  
20 don't know the relative times. I have no idea when  
21 the reactor trip is going to come in. I have no idea  
22 when the pressure in the ruptured steam generator is  
23 going to get high enough to pop open the relief  
24 isolation valve. And I have no idea what time the  
25 safety injection is going to occur. I don't do those

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 kinds of analyses.

2 Any thoughts?

3 MR. BERGERON: The case without CVCS --

4 MEMBER STETKAR: Yes.

5 MR. BERGERON: -- we have analyzed.

6 MEMBER STETKAR: You have?

7 MR. BERGERON: Yes.

8 MEMBER STETKAR: All right.

9 MR. BERGERON: We have looked at both with  
10 CVCS and without CVCS.

11 MEMBER STETKAR: I know it talks about it  
12 in the FSAR, but there's no results presented for it.

13 MR. BERGERON: Yes, because that case was  
14 less limiting.

15 MEMBER STETKAR: I would be interested to  
16 see --

17 MR. BERGERON: The timing of the trip is  
18 somewhere on the order of 900 seconds.

19 MEMBER STETKAR: Nine hundred seconds?

20 MR. BERGERON: I mean you get an automatic  
21 trip and --

22 MEMBER STETKAR: Yes, you think you would  
23 get the automatic trip pretty soon.

24 MR. BERGERON: Right.

25 MEMBER STETKAR: I was guessing, the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 sooner it is, the worse you are --

2 MR. BERGERON: Right. I mean, as far as  
3 if you are going to wait 30 minutes to perform any  
4 manual action --

5 MEMBER STETKAR: Yes.

6 MR. BERGERON: -- correct.

7 MEMBER STETKAR: And that is a ground  
8 rule.

9 MR. BERGERON: Right.

10 MEMBER STETKAR: I mean the operators are  
11 hands-off until 30.

12 MR. BERGERON: Yes. Basically, we are  
13 hands-off for 30 minutes.

14 MEMBER STETKAR: I would be interested to  
15 see --

16 MR. BERGERON: We have looked at both  
17 cases.

18 MEMBER STETKAR: -- the results from that.  
19 Maybe, Derek, can you see if we can, if you have got  
20 it?

21 MR. BERGERON: Now what Ken was talking  
22 about on these --

23 MEMBER STETKAR: Unless there is an  
24 isolation signal that I couldn't find.

25 MR. BERGERON: Yes. I mean, if you look

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 at 15.08, Table 15.08 in the FSAR, there is a list of  
2 all the ESF functions. And among those functions are  
3 high-steam line activity with other signals that  
4 actually perform isolation functions.

5 MEMBER STETKAR: Table 15?

6 MR. BERGERON: Now in the analysis we have  
7 presented in the FSAR, we have not credited any  
8 automatic function that comes from steam line  
9 activity. We have only used the steam line activity  
10 as an indication that we have a tube rupture --

11 MEMBER STETKAR: Right.

12 MR. BERGERON: -- and which generator it  
13 is in.

14 MEMBER STETKAR: Yes.

15 MR. BERGERON: But there are automatic  
16 features on the U.S. EPR that perform isolation  
17 functions with a radiation signal in the steam line  
18 coincident with other signals. For example, if you  
19 have a partial cooldown initiated with the high  
20 activity, you would raise the setpoint in the MSRT.

21 MEMBER STETKAR: Do you have that table?  
22 I just pulled up the table. Where in the table is  
23 that isolation?

24 MR. BERGERON: It is on sheet 3 of 4.

25 MEMBER STETKAR: Sheet 3 of 4?

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. BERGERON: Yes.

2 MEMBER STETKAR: Of four? Fifteen --

3 MR. BERGERON: 15.08.

4 MEMBER STETKAR: This is --

5 MS. SLOAN: Which revision do you have,

6 John?

7 MEMBER STETKAR: Well, that could be the

8 problem.

9 MR. BERGERON: That could be the problem.

10 MEMBER STETKAR: That could be the

11 problem. Hold on. Yes, I have Rev. 2.

12 MS. SLOAN: Okay, yes.

13 MEMBER STETKAR: Because I only have three

14 sheets in that table. All right.

15 MR. BERGERON: That function hasn't

16 changed.

17 MEMBER STETKAR: Because my Table 15.08

18 only has --

19 MS. SLOAN: Paul is looking at our

20 snapshot, our internal live version of the FSAR.

21 MR. BERGERON: Rev. 2 looks the same to

22 me.

23 MEMBER STETKAR: 15.08, I have three

24 sheets. Let me just make sure I have pulled up the

25 right -- bear with me.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 MR. BERGERON: Yes, it is under the  
2 category of steam generator isolation.

3 MEMBER STETKAR: I'm sorry. I have Rev. 1  
4 of the DCD.

5 MS. SLOAN: Okay. Okay.

6 MR. BERGERON: That makes a difference.

7 MEMBER STETKAR: I have Rev. 1. I don't  
8 even have Rev. 2. How come we don't have Rev. 2?

9 MS. SLOAN: Rev. 2 is the latest docketed  
10 version.

11 MR. WIDMAYER: When was that docketed?

12 MR. TEFAYE: On August 31st.

13 MS. SLOAN: Yes.

14 MEMBER STETKAR: Maybe I lost mine.

15 MEMBER SHACK: I don't have one.

16 MEMBER STETKAR: If he doesn't have it, we  
17 don't have it. I trust Bill. Bill doesn't lose  
18 anything.

19 (Laughter.)

20 MR. BERGERON: Is that what Rev. 1 looked  
21 like?

22 MEMBER STETKAR: I swear to you, Rev. 1 --  
23 I have got two. I have got Rev. 0 and Rev. 1. I  
24 thought they were 1 and 2.

25 MR. BERGERON: I mean that wasn't a

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 feature that was added, so it should have been there.

2 MEMBER STETKAR: The only one I could see  
3 was to raise the setpoint on the high steam line, but  
4 that is not an isolation.

5 MR. BERGERON: Right.

6 MEMBER STETKAR: I mean, you know, your  
7 pressure will eventually get to that higher setpoint.

8 Well, that's okay. If we don't --

9 MR. BERGERON: Yes, the MSIV closure on  
10 high steam line with partial cooldown initiated is  
11 also an isolation feature.

12 MEMBER STETKAR: Yes, but that is just  
13 MSIV. That is not going to help me with the MSRs, the  
14 control valves.

15 MR. BERGERON: Right. Right. Yes, the  
16 setpoint has been reset on the MSRTs, so that is  
17 automatic.

18 MEMBER STETKAR: Yes, but that is just a  
19 higher setpoint, but I have nothing --

20 MR. BERGERON: If you pop it and it sticks  
21 open, then you have to wait until you get to the IV  
22 setpoint to close.

23 MEMBER STETKAR: And it is exacerbated by  
24 the fact that, if I get an SI, there is another signal  
25 coming in trying to drive the whole thing open, also.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. BERGERON: Right. Right.

2 MEMBER STETKAR: I mean, if it is stuck  
3 open, it doesn't make any difference. I was trying to  
4 get the single failure as just the charging pump  
5 failure and let auto take care of opening that valve.

6 MR. BERGERON: Yes. No, but because the  
7 CVCS is not a safety system --

8 MEMBER STETKAR: You can assume it has  
9 failed?

10 MR. BERGERON: -- we looked at both with  
11 and without.

12 MEMBER STETKAR: I would really like to  
13 see --

14 MR. BERGERON: And it turned out, I mean  
15 this was based on offsite doses.

16 MEMBER STETKAR: Yes.

17 MR. BERGERON: And it turns out that it  
18 was higher because you are keeping the pressure up on  
19 the primary and driving the leak, primary to  
20 secondary. So, you are transferring more over to the  
21 secondary side for it to be released.

22 MEMBER STETKAR: For the case of record?

23 MR. BERGERON: For the case, yes.

24 MR. PARECE: But the thing to remember --  
25 this is Marty Parece -- the thing to remember about

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 the steam generators when it comes to dose is that  
2 they are an iodine battery. So, if you don't steam it  
3 for 10 minutes and then you lift the valves for one  
4 minute, you might as well have steamed it all 10  
5 minutes. It is the same, the same thing.

6 MEMBER STETKAR: That might be the --

7 MR. PARECE: Okay. It acts like a battery  
8 because the half-life of the iodine is so long.

9 MEMBER STETKAR: That might be the answer.

10 I was just curious to see that --

11 MR. PARECE: So, if you have that drives  
12 the leak harder, even if there is some difference in  
13 how many minutes the total steaming is, if you have  
14 one that drives the leak harder, you drive more iodine  
15 into the generator. So, when it does lift, it just  
16 vents everything.

17 MEMBER STETKAR: I have to think about it.

18 Make sure we get Rev. 2, also.

19 Thank you.

20 MR. COFFEY: Any other questions?

21 (No response.)

22 Thank you very much.

23 CHAIRMAN BANERJEE: Okay. Thank you.

24 I guess now we are going to have a change.

25 The staff will come on.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 So, we don't visit this book again until  
2 tomorrow.

3 MS. SLOAN: Beg your pardon?

4 CHAIRMAN BANERJEE: We will reopen this  
5 tomorrow.

6 MS. SLOAN: Okay. Yes.

7 MR. TESFAYE: Are you ready for us?

8 CHAIRMAN BANERJEE: Yes, I think we can  
9 start.

10 MR. TESFAYE: Yes, Dr. Banerjee, Jason  
11 Carneal is the Chapter PM. He will be coordinating  
12 the staff's presentation.

13 CHAIRMAN BANERJEE: Okay.

14 MR. CARNEAL: Good afternoon.

15 My name is Jason Carneal. A little  
16 background: I received a bachelor's and master's in  
17 engineering science mechanics from Virginia Tech in  
18 2001 and 2004. For four years, before coming to the  
19 NRC, I worked at the Naval Surface Warfare Center,  
20 Carderock Division, performing hydrodynamic  
21 experimentation on hull forms and propulsors.

22 And since coming to the NRC, I have served  
23 as Chapter PM for Chapters 4, 6, 15, and 17 for the  
24 U.S. EPR design certification application review.

25 Today's presentation is going to cover the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 staff's Safety Evaluation Report with Open Items for  
2 Chapter 15, Group 1, of the U.S. EPR design  
3 certification application.

4 The technical staff that supported this  
5 review includes members from the Reactor Systems,  
6 Nuclear Performance, and Code Review Branch. They  
7 handled the majority of the review. For Section  
8 15.03, the review was handled by members from the  
9 Reactor Siting and Accident Consequence Branch and the  
10 Component Integrity Branch.

11 A quick overview of the results of our  
12 review: in Section 15.0.1 and 15.0.2, we issued a  
13 total of 10 questions, and there are three open items  
14 remaining, mostly dealing with the assumptions used in  
15 the analysis.

16 In Section 15.0.3, Radiological  
17 Consequences, we asked 38 questions. There were two  
18 open items in the SER, but since issuance of the SER,  
19 those two open items have been closed.

20 The remainder of the sections on this  
21 table, there are no open items with the exception of  
22 15.4, Reactivity and Power Distribution Anomalies.

23 Again, no other open items in the  
24 remaining sections. All tolled, we have issued 131  
25 RAIs in this review with six open items documented in

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 the SER and four of those items remain.

2 Just a quick note that the Phase 2 Safety  
3 Evaluation Report with Open Items for Section 15.6.5  
4 was not delivered with Group 1 and, as discussed  
5 earlier, we are working to deliver that in the late  
6 March or early April timeframe.

7 A quick description of the open items that  
8 remain open in the review:

9 RAI 415, Question 15-9, is focusing on  
10 site-specific EOPs to confirm that the assumptions  
11 used in the Safety Analysis remain valid.

12 We have a question in RAI 311, Question  
13 16-317, that is involved with technical  
14 specifications. That is a cross-cutting issue, and we  
15 are working with the Technical Specifications Branch  
16 on that issue.

17 We also have an open item concerning the  
18 .48 percent total power measurement uncertainty  
19 claimed by the applicant, including a description of  
20 how it will be verified and confirmed by the COL  
21 applicant.

22 And in Section 15.4.8, we have an open  
23 item that was also cross-listed in the Chapter 4  
24 review that tracks the review of Topical Report  
25 ANP-10286, the Rod Ejection Accident Methodology

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 Topical Report.

2 We have closed two open items in Section  
3 15.00.03. These open items were largely editorial in  
4 nature, but it was requesting, the first one was  
5 requesting that tables be added to the FSAR to  
6 demonstrate that the pH would be acceptable after the  
7 30-day timeframe.

8 The second one was requesting that the  
9 applicant include purity and density values for the  
10 commercially-purchased TSP and the FSAR.

11 Both of these items have been responded to  
12 with FSAR markups and RAI responses, and the item is  
13 now considered confirmatory by the staff.

14 And before we move on into Shanlai's  
15 presentation, there were a couple of discussion items  
16 earlier, Section 15.0.3. The staff did not have any  
17 dedicated slides on that section, but we had a  
18 discussion topic on confirmatory analysis and use of  
19 the ARCON-96 code. So, I would like to open up the  
20 floor for specific questions on Section 15.0.3, and we  
21 also have Michelle Hart to support this discussion.

22 MS. HART: I'm Michelle Hart from the  
23 Siting and Consequences Branch.

24 I understand earlier you had a question  
25 about whether we had done confirmatory analysis for

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 the Radiological Consequences Analysis. And, yes, we  
2 have. We have used our code RADTRAD, and we used the  
3 assumptions and inputs that the applicant gave us as  
4 long as they went along with our Regulatory Guide and  
5 our SRP, and they all have.

6 So, we did not model like the deposition  
7 and the containment differently or anything like that.

8 We used the values that they used once we determined  
9 that there were acceptable, that the models were  
10 acceptable.

11 All of our results came out to show that  
12 their results were reasonable and acceptable. And as  
13 the applicant had stated, some of their analyses were  
14 back-calculated to give them the highest chi over Q  
15 that they could, so they could put it on the most  
16 sites that they could.

17 Did you have any further specific  
18 questions about that admittedly short overview?

19 CHAIRMAN BANERJEE: No. I think we just  
20 wanted to know that you had done some confirmatory  
21 calculations.

22 MEMBER SHACK: Well, Professor Banerjee  
23 was asking about what was done to validate the  
24 ARCON-96. You know, what is the range of geometries  
25 for which you would consider it valid?

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MS. HART: Well, one of the first things  
2 to recognize is that that's reviewed more specifically  
3 in the context of the meteorological review which is  
4 done in Chapter 2. So, I personally had not done  
5 that. The reviewer that did that review is not here.

6 The models are not specific enough, is my  
7 understanding, to have to validate them in that sense.

8 Are there any specific questions?

9 I do have a meteorologist who can talk in  
10 generalities, but cannot talk about EPR reviews.

11 CHAIRMAN BANERJEE: I guess the question  
12 applied to the applicability of the code to this  
13 specific situation where it had been, you know,  
14 validated in some sense. Why didn't our geometries  
15 with, you know, conditions, and so on, to cover this  
16 as a subset of validation.

17 MS. HART: Right. We are talking about  
18 the releases from the containment of the air. It is  
19 not from outside --

20 CHAIRMAN BANERJEE: Right.

21 MS. HART: -- in this specific case, and  
22 it is for the control room habitability.

23 CHAIRMAN BANERJEE: So, from the outside  
24 is left for the COLA, whatever comes?

25 MS. HART: Well, yes, we also have to

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 recognize that this is for the design --

2 CHAIRMAN BANERJEE: Site-specific.

3 MS. HART: -- certification.

4 CHAIRMAN BANERJEE: Yes.

5 MS. HART: And so, there is a certain  
6 amount of back-calculation that can even be done in  
7 that case. So, when you come in as a COL applicant,  
8 you would to show specifically the use for your site.

9 Now is it true that everyone uses  
10 ARCON-96, the staff, the industry. For the purposes  
11 of the dose analysis in the control room, yes, they  
12 used ARCON-96.

13 My understanding is it is not a  
14 particularly detailed model. So that, it is not a 3D  
15 model.

16 CHAIRMAN BANERJEE: No.

17 MS. HART: It is not like a CFD or  
18 anything like that.

19 CHAIRMAN BANERJEE: That is fine. But it  
20 is, therefore, conservative.

21 MS. HART: Right.

22 CHAIRMAN BANERJEE: Yes.

23 MS. HART: Right.

24 CHAIRMAN BANERJEE: It takes into account  
25 some mixing, and so on, but not pushing it to the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 limits.

2 MS. HART: It is not pushing it to the  
3 limits.

4 CHAIRMAN BANERJEE: Right.

5 MS. HART: Right. And if there were  
6 specific questions about ARCON-96, it would have to  
7 be, you know, discussed with the developer of the  
8 code. Of course, '96 is the year that it came out,  
9 approximately, and it was based on an earlier version.

10 These models are nothing specifically new. They have  
11 been used in the industry for many, many years.

12 CHAIRMAN BANERJEE: I think it is a  
13 question of where we put our attention, and probably  
14 this is not going to be one of them.

15 MEMBER SHACK: There is enough  
16 conservatism built into the --

17 CHAIRMAN BANERJEE: Yes, that is probably  
18 good enough. Yes.

19 For different types of non-radiological  
20 release, of course, that is a whole new ballgame  
21 because --

22 MS. HART: Right. ARCON-96 is not used  
23 for those analyses.

24 CHAIRMAN BANERJEE: Not yet, yes. So, you  
25 would use, somebody would use ALOHA or something like

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 that.

2 MS. HART: ALOHA has been used. Of  
3 course, we have HABIT, and I know that that is a topic  
4 that will be discussed with the full Committee --

5 CHAIRMAN BANERJEE: Right.

6 MS. HART: -- coming up on the 10th in the  
7 context of the summer COL applications. So, specific  
8 questions may be more appropriate.

9 CHAIRMAN BANERJEE: Okay. So, I think we  
10 can just defer it to the full Committee meeting --

11 MS. HART: Okay.

12 CHAIRMAN BANERJEE: -- right now and take  
13 it up there.

14 MS. HART: Did I answer the questions  
15 closely enough?

16 CHAIRMAN BANERJEE: Yes, I think that is  
17 fine for now.

18 MS. HART: Thank you.

19 CHAIRMAN BANERJEE: Okay.

20 MR. CARNEAL: Okay. So, if there are no  
21 other questions on that topic, I will turn the  
22 presentation over to Shanlai Lu.

23 CHAIRMAN BANERJEE: Shanlai, of course,  
24 escaped from --

25 MR. LU: From GSI-191.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIRMAN BANERJEE: Yes.

2 (Laughter.)

3 Well, I hope he is going to look at  
4 GSI-191.

5 MR. LU: Yes, we are. We are. We are  
6 coming back on that one.

7 CHAIRMAN BANERJEE: All right.

8 MR. LU: Yes. So, my name is Shanlai Lu.  
9 I am the lead reviewer on U.S. EPR from the Reactor  
10 Systems Branch.

11 And in terms of a brief bio, I have been  
12 with the agency for 11 years and Research four and a  
13 half years, and joined NRR I think back in 2002, and  
14 then I worked in Power Uprate. I later worked with  
15 Mike Scott on the GSI-191.

16 Then, I thought the strainer issue could  
17 be resolved already back to 2007. So, I decided to  
18 join NRO to work on the EPR. So, ever since then, I  
19 have been working on the EPR.

20 So, as Jason mentioned, we issued 131 RAIs  
21 and related to these non-LOCA sections. And 121 were  
22 issued by the Reactor Systems Branch. So, we did a  
23 lot of work in this area.

24 Then, back to three years ago, we launched  
25 the audit to analyze this. A lot of work was done

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 since then.

2 So, when we were preparing the slides,  
3 developing the presentations, we decided to take an  
4 approach to give you first the punch line. What  
5 exactly are the results of our Phase 2 review?

6 Then, we will walk you through a detailed  
7 evaluation of the SPND, in-core SPND, using our own  
8 codes, which is not intended to validate AREVA's  
9 design. It is just for the staff to understand how  
10 the SPND works and what is the in-core setpoint  
11 methodology, the algorithm, how it really works. So  
12 that we can launch RAIs.

13 So, the purpose of that calculation was to  
14 help staff to understand the system and generate  
15 useful information, so that we can launch/write RAIs.

16 So, therefore, I am going to go into the first  
17 presentation about the punchline, Phase 2  
18 review/results. Okay?

19 We had a big team working on this because  
20 a significant amount of work during the reviews since  
21 three years ago. And Chu-yu Liang, actually, he was  
22 the staff working in this area, and then he was  
23 working on this until September. Last year he  
24 retired. So, as the lead, I fill in just to present  
25 his presentation.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1                   We have Jack Rosenthal as our consultant;  
2 Dave Caraher and Vesselin Palazov. And Jack's  
3 Technical Evaluation Report is in such a good quality,  
4 when we converted that into the staff Draft SER, OGC  
5 just told us there is no need for a Chapter meeting.

6                   CHAIRMAN BANERJEE: My thing seems to be  
7 missing some slides.

8                   MR. LU: Okay.

9                   MR. WIDMAYER: You gave me corrected --

10                  MR. LU: Okay, this is just a name.

11                  CHAIRMAN BANERJEE: Yes, it is okay,  
12 but --

13                  MR. WIDMAYER: Is that the only thing that  
14 is different, is the names?

15                  MR. LU: Just the names. I think we added  
16 the names there. Make sure.

17                  MR. CARNEAL: And in the second  
18 presentation, there is a table that is modified to add  
19 a couple of values.

20                  MR. LU: All right. The next slide, this  
21 basically is a summary. So, what have we really  
22 reviewed as part of Chapter 15 non-LOCA sections?  
23 Basically, it goes through that form of 15.1, increase  
24 in heat removal by the secondary systems; 15.2,  
25 decrease in heat removal by the secondary systems.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 All those were detailed or the descriptions were given  
2 by Doug Brownson this morning and very detailed. So,  
3 I do not intend to go through every single one of them  
4 and give you the examples.

5 So, the 15.3, decrease in reactor coolant  
6 system flow rate, and 15.4 will be presented tomorrow  
7 with the rod ejection topical report together, because  
8 that is coupled and that is the direct application of  
9 the topical report.

10 And the increase in reactor coolant  
11 inventory, 15.5; decrease in reactor coolant  
12 inventory, 15.6, and ATWS, 15.8.

13 And one thing very good and that helped  
14 the staff a lot was three years ago when we received a  
15 submittal. The submittal was in such good shape and  
16 high quality. So, it matched to this SRP very well.  
17 So, it saved us a lot of time to review that part.

18 Okay, let me move on. Okay.

19 All right. High-level, the acceptance  
20 criteria we used to evaluate each event under a  
21 different category, and then for AOOs, the events  
22 expected to occur during the lifetime of the plant.  
23 All those events are expected to happen during the  
24 normal operations, some of them in shutdown mode.

25 And the acceptance criteria here are

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 documenting the SRP and the pressures in the primary  
2 and the secondary systems not exceeding 110 percent of  
3 the design value. All those criteria are not unique  
4 to EPR. It is all across the board for the operating  
5 fleet and all the new reactor designs.

6 CHAIRMAN BANERJEE: Could you tell me why  
7 you have put 3 to 10 as your slide numbers, just to  
8 confuse us or?

9 MR. TEFAYE: The numbering is wrong.

10 MR. LU: Oh, okay.

11 CHAIRMAN BANERJEE: Only the numbering is  
12 wrong?

13 MR. TEFAYE: Yes.

14 CHAIRMAN BANERJEE: Okay. Nothing else?

15 MR. TEFAYE: There are no missing slides.

16 CHAIRMAN BANERJEE: There are no missing  
17 slides.

18 MR. LU: Well, we cut and pasted it, that  
19 slide. Okay?

20 CHAIRMAN BANERJEE: So, there were slides  
21 in between?

22 MEMBER SHACK: Well, yours is 3 to 10.  
23 Mine is 3 to 9.

24 (Laughter.)

25 CHAIRMAN BANERJEE: No, I have a new one

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 that is reflecting that. Okay. All right.

2 MR. LU: That is maybe at the last minute  
3 we were shuffling the slides and the page number may  
4 be off there.

5 Okay. The second criteria we used is the  
6 fuel cladding integrity shall be maintained by no DNBR  
7 during the transient.

8 And talking about DNBR, I think in the  
9 morning AREVA mentioned about the in-core trip system  
10 to protect most of the transient with DNBR trips and  
11 LPD trips. I think that is the methodology and, also,  
12 the design became the focus of our review for most of  
13 our transient because they did take the credit of the  
14 existence of such a system.

15 For AOs, the third criteria is they  
16 should not generate a postulated accident. Those are  
17 standard criteria for all the AOs.

18 Okay. Continuing on for the postulated  
19 accidents, events are not expected to occur during the  
20 lifetime of the plant design. However, it is  
21 postulated accidents.

22 And, then, also, we have three criteria.  
23 So, the pressure in primary and secondary systems not  
24 exceeding acceptable design limits, considering  
25 potential brittle as well as ductile failures. For

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 example, you could have cold water injection into the  
2 vessel and watch the PT curve. It needs to be  
3 evaluated there, too.

4 And the fuel failure may occur, but not  
5 result in offsite doses exceeding 10 CFR 100 limits.  
6 For example, rod ejection and, then, there is a  
7 possibility you have a certain percentage of rods  
8 fail. But the dose rate cannot exceed the limit.

9 Okay. A postulated accident cannot be  
10 developed in such a fashion that there is a  
11 consequential loss of function of systems needed for  
12 mitigation of the event. So, that is related to long-  
13 term mitigation there.

14 Okay. When we got this FSAR, and we found  
15 a lot of the information when we launched our audit  
16 back three years ago, and we found even more  
17 information in AREVA's site over in Lynchburg. So, we  
18 launched a one-week audit, and we found that for each  
19 transient, as Doug described in the morning, there are  
20 at least 40 or 30 different cases.

21 To answer John's question, in a lot of  
22 cases we are actually there, but we cannot just  
23 remember details over what is a trait and what is  
24 exactly the phenomenon there. There is tons of it  
25 because we have several cabinets of the information.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 So, we have 21 staff and they stayed there for one  
2 week, and the AREVA site had 45 people supporting our  
3 review, this part of it.

4 So, based on that audit, we launched our  
5 RAIs and then started a review process, Phase 1 and  
6 Phase 2 review, until today.

7 CHAIRMAN BANERJEE: So, you looked at the  
8 methodologies and the codes, and most of these or all  
9 of these had already been --

10 MR. LU: Approved.

11 CHAIRMAN BANERJEE: -- accepted or  
12 approved?

13 MR. LU: That's right. That's right. We,  
14 first, verified our analysis to make sure that all the  
15 analysis is documented in the record, based on the  
16 methodology approved or reviewed by staff before.

17 CHAIRMAN BANERJEE: Right. Now how did  
18 you determine the applicability to the U.S. EPR to  
19 that?

20 MR. LU: Okay. I think of that as sort of  
21 the typical question about that is we take a few  
22 limiting cases, a special limited case, and to verify  
23 what's the upper-bound and lower-bound parameters,  
24 especially some key parameters, but we cannot go over  
25 every single correlation, for example, of S-RELAP5,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 and then verify every single correlation is valid  
2 because that has been done as part of the review of  
3 the methodology.

4 CHAIRMAN BANERJEE: So, S-RELAP was  
5 approved before my time. Bill may remember. What was  
6 it applicable to? I mean I was a consultant on it.

7 MEMBER SHACK: Right. It was their large-  
8 break realistic LOCA analysis.

9 CHAIRMAN BANERJEE: But, I mean, it was  
10 for the --

11 MEMBER SHACK: Operating plants, yes.

12 CHAIRMAN BANERJEE: -- operating plants,  
13 right?

14 MEMBER SHACK: Right.

15 CHAIRMAN BANERJEE: So, this has some  
16 special features, clearly, compared to the operating  
17 plants, including not having a high-pressure ECCS  
18 system.

19 MR. LU: Yes.

20 MEMBER SHACK: So, it is a big change.

21 MR. LU: Yes. As a matter of fact, I  
22 think that we are trying to schedule in March, in the  
23 March ACRS meeting, talking about large-break LOCA for  
24 the EPR application using S-RELAP5.

25 But this part, the S-RELAP5 was approved

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 for transient analysis.

2 CHAIRMAN BANERJEE: Right.

3 MR. LU: So, for AOOs and postulated  
4 accidents.

5 CHAIRMAN BANERJEE: And it has also been  
6 approved for small-break LOCAs, I take it?

7 MR. LU: That's right.

8 CHAIRMAN BANERJEE: Or that is still open  
9 right now?

10 MR. LU: Yes, you're right. And that is  
11 the reason I think you asked for the application of  
12 that approval for the EPR small-break LOCA analysis,  
13 and I think AREVA is going to provide a presentation  
14 tomorrow specifically on a certain aspect. It is not  
15 the entire methodology.

16 CHAIRMAN BANERJEE: The staff is still  
17 considering the matter?

18 MR. LU: That specific application is  
19 still being considered, but the small-break LOCA  
20 methodology using S-RELAP5 was approved as part of the  
21 applicability report.

22 MR. TESHAYE: Yes, there was a topical  
23 report.

24 MR. LU: There was a topical report  
25 approved before even I joined NRO by, I think at that

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 time it was by the Reactor Systems Branch, NRR.

2 MEMBER SHACK: I mean that is standard for  
3 all these, is you have to have an applicability  
4 report.

5 MR. LU: Exactly.

6 CHAIRMAN BANERJEE: Yes, but  
7 applicability, for example, for other systems, we  
8 required, for example -- just take an example of  
9 TRACE, for example. We reviewed TRACE and the staff,  
10 of course, developed it. So, we looked at it, but it  
11 was applicable to, say, ESBWR or to some specific  
12 system for a certain range of things, not for ATWS,  
13 but for --

14 MR. LU: Right. I think for specific U.S.  
15 EPR, the TRACE was not submitted by the applicant as a  
16 licensing basis. And we did use TRACE to get some  
17 results for us, generated the useful information for  
18 us to launch RAIs.

19 CHAIRMAN BANERJEE: Okay. Well, we just  
20 need to get a picture of where we stand.

21 MR. LU: Okay.

22 CHAIRMAN BANERJEE: I can see that what  
23 you are saying here is for a very right now rather  
24 limited use of S-RELAP5 for non-LOCA systems --

25 MR. LU: That's right.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIRMAN BANERJEE: -- in the way that was  
2 sketched this morning, right, to us?

3 MR. LU: Right.

4 CHAIRMAN BANERJEE: For using it for the  
5 DNBR and the other things?

6 MR. LU: That's right. That's right.

7 CHAIRMAN BANERJEE: All right.

8 MR. LU: That is our basis. I think it is  
9 not only S-RELAP5. I think there is LYNXT.

10 CHAIRMAN BANERJEE: Oh, there is a whole  
11 bunch of --

12 MR. LU: We talk about the codes in there.  
13 They use it to generate the curves and, then, put it  
14 into the setpoint, I think, an in-core algorithm,  
15 burnt into chips, supposedly, down the road.

16 MR. TESHAYE: Dr. Banerjee, before even  
17 the application came in, there was a codes and methods  
18 topical report that was submitted by AREVA and  
19 reviewed and approved by the staff.

20 CHAIRMAN BANERJEE: Okay. And this was  
21 basically things they had used. It was mainly an  
22 applicability report?

23 MR. TESHAYE: Yes, for EPR.

24 MR. LU: For EPR, yes. But I think the  
25 NRR staff's conclusion is they consider they are

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 acceptable --

2 CHAIRMAN BANERJEE: Right.

3 MR. LU: -- to be used for AOO and  
4 postulated accident except LOCA. Small-break LOCA was  
5 included.

6 CHAIRMAN BANERJEE: Was included?

7 MR. LU: Was included as a part of  
8 applicability, but we did do additional review as part  
9 of the design cert of 15.6.5. So, by the time after  
10 the March presentation, once we are done with that  
11 one, we plan to give you a presentation on how we  
12 review that part.

13 CHAIRMAN BANERJEE: Okay. As long as we  
14 get a chance to look at it.

15 MR. LU: That's no problem.

16 CHAIRMAN BANERJEE: Right. Okay.

17 MR. LU: All right. The second bullet --

18 MR. TESFAYE: Excuse me. We can send you,  
19 I can point out the Safety Evaluation Report that we  
20 wrote on those codes and methods topical report. We  
21 can make that available before the next --

22 MR. LU: Before even the ACRS meeting,  
23 yes.

24 CHAIRMAN BANERJEE: Yes, that would be  
25 helpful.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. TESFAYE: Okay. I will take action to  
2 get you those copies.

3 MR. LU: Okay. So, the first item is the  
4 methodologies and the computer codes. And the second  
5 one, we did do the review of limiting conditions of  
6 operation which provided a bounding or box for Chapter  
7 15 AOO and the postulated accident analysis. So, we  
8 want to make sure what they used in the analysis was  
9 consistent with Chapter 15.1. This included the  
10 initial conditions and configurations, and all --

11 CHAIRMAN BANERJEE: So, what was the  
12 protocol here, whoever wants to answer it? There are  
13 certain things that we felt we want to be able to have  
14 comments on because we might have a point of view.  
15 So, clearly, for small-break LOCA, we are quite  
16 interested in this problem. Maybe for large-break  
17 LOCAs, we are not even so interested.

18 But it can be that we should -- what has  
19 been followed with EPR up to now? Because with, say,  
20 some of the other certifications we have been involved  
21 with, we have reviewed, at the request of the staff,  
22 some of these codes before they were accepted or  
23 approved, at least some of the most crucial ones, you  
24 know.

25 MR. TESFAYE: There is no set protocol.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 CHAIRMAN BANERJEE: Right.

2 MR. TESHAYE: The procedure doesn't  
3 require us to bring topical reports to ACRS. But what  
4 we do is, for the initial topical reports, we intended  
5 to bring them with the chapters that they were  
6 referred to. That would be the case with the codes  
7 and methods topical report. I think there was some  
8 other presentation, also, that was done by AREVA to  
9 discuss the codes and methods topical --

10 MR. WIDMAYER: November of 2009.

11 MS. SLOAN: Yes, we have presented to ACRS  
12 before, AREVA has, on our codes and methods  
13 applicability.

14 MR. TESHAYE: Jack, do you want to talk?

15 MR. ROSENTHAL: Yes, please.

16 CHAIRMAN BANERJEE: You have to identify  
17 yourself, Jack. Speak at a microphone.

18 MR. ROSENTHAL: Jack Rosenthal. I work  
19 for ISL as a consultant.

20 And I just wanted to call out that there  
21 is an AREVA codes and methods applicability report for  
22 the U.S. EPR, ANP-10263P-A, August 2007. It was both  
23 proprietary and it was previously approved. That was  
24 the basis for our review work in which the codes and  
25 methods were discussed.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1           An example is that the EPR steam  
2 generators have an economizer, and there were  
3 questions about the modeling of that economizer in  
4 RELAP. And so, you will find in our SER some  
5 questions and responses that are applicable.

6           MR. TESHAYE: Okay. Thank you.

7           And again, Sandra, he reminded me I think  
8 that was when we brought unique features of EPR. We  
9 did make a presentation to this Subcommittee. I think  
10 it was to the full Committee.

11          MR. WIDMAYER: No, it was this  
12 Subcommittee. November of 2009.

13          MR. TESHAYE: Yes.

14          MR. WIDMAYER: Yes. But that also  
15 postdated the SER, right? I mean it was just  
16 information. You could ask any questions you wanted.

17          MEMBER SHACK: Well, I mean, the only one  
18 that I can remember doing in great detail was the  
19 containment response. That one was sort of up in the  
20 air, and we have never come back to it.

21          MR. TESHAYE: We will come back to it when  
22 we get --

23          MEMBER SHACK: I assume we will come back  
24 to it for the large-break LOCA, yes.

25          MR. TESHAYE: Yes, it is coming soon.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIRMAN BANERJEE: Yes, there can be  
2 different codes for different things, right, that we  
3 want to look at?

4 MR. TESHAYE: Yes, that was a special  
5 presentation.

6 MEMBER SHACK: That was a special  
7 presentation, yes.

8 MR. TESHAYE: Yes, it was different. But  
9 we had unique EPR features presentation made to this  
10 Subcommittee, I guess, and as part of that, I think we  
11 did discuss the codes and methods topical report. And  
12 I don't bring it up every time we discuss every  
13 chapter and every section, like we are doing now.

14 CHAIRMAN BANERJEE: Right. So, I am just  
15 trying to get my head around this because we have been  
16 running so many of these in parallel, you know, these  
17 certifications. I am just looking for some  
18 consistency between how we did this.

19 For example, in some cases, we have to do  
20 TRACG applicability. We looked at in some depth, how  
21 it treated non-condensables and all this sort of  
22 stuff.

23 So, in the case of the EPR, what you are  
24 saying is you have made a general presentation to the  
25 Subcommittee about codes and methods. I am just

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 giving it back to you as I heard it. As each chapter  
2 comes up, depending on what codes and methods are  
3 being used, you are sort of revisiting these. And the  
4 ones which are probably of most interest to us, we  
5 would identify and say we want to look in a little bit  
6 more detail here. That is the sort of methodology  
7 that has been followed here.

8 MR. TESFAYE: Yes.

9 CHAIRMAN BANERJEE: Okay.

10 MR. TESFAYE: And for the topical reports,  
11 they have been resubmitted recently. I think we have  
12 made separate presentations, like we are doing  
13 tomorrow morning on rod ejection topical report. We  
14 will bring it up in that section. We are going to do  
15 the same thing on mechanical fuel design topical  
16 report. So, we are bringing in those topical reports  
17 when we discuss the chapters.

18 CHAIRMAN BANERJEE: Right. And we get a  
19 chance to review those, if you wish to, or we can ask  
20 you, that we would like to at that point.

21 MR. TESFAYE: Yes, all those topical  
22 reports are incorporated by reference to the FSAR.  
23 So, they are of the FSAR.

24 CHAIRMAN BANERJEE: Yes. I have the rod  
25 ejection one, right. Okay. Okay. Thanks.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 MR. CARNEAL: And looking ahead for the  
2 large-break LOCA, ANP-10278, I think we are having a  
3 dedicated meeting ahead of the Subcommittee meeting  
4 for Chapter 15, Group 2, which is Section 15.6.5. So,  
5 we will have a chance to interact before.

6 CHAIRMAN BANERJEE: And that will discuss  
7 containment response and everything.

8 MR. CARNEAL: Right.

9 CHAIRMAN BANERJEE: Okay. Go ahead,  
10 Shanlai.

11 MR. LU: If you want to make more  
12 comments, that is fine.

13 MR. CARNEAL: The containment response is  
14 going to be part of the Chapter 6 SER that we are  
15 giving because it is covered in a technical report in  
16 support of the FSAR. So, that should be coming to you  
17 soon.

18 CHAIRMAN BANERJEE: I'm sure Dana has got  
19 everything computerized in his mind.

20 MR. LU: All right. Continuing on with  
21 major review areas, we also reviewed the worst single  
22 failure, assuming that each event for all those cases  
23 analyzed, and we identified and evaluated whether the  
24 single failure was being assumed to give you the most  
25 challenging case.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1           So, all the cases on the category of 15.1,  
2 15.8, all of them, any cases related to the single  
3 failure assumption, we evaluated the worst case. And,  
4 then, as part of it, we also evaluated whether they  
5 considered it with or without offsite power.

6           Okay. That is very high-level. I will  
7 keep going now.

8           The sequence of the events analyzed, we  
9 also evaluated to make sure that they assumed operator  
10 actions, are reasonably achievable, and although we  
11 have an open item related to the EOPs, and I am going  
12 to talk about it right away after this one.

13           And, then, we also reviewed the analysis,  
14 including transient predictions, to assure that the  
15 consequence of each analyzed limiting case meet the  
16 specific acceptance criteria. Different cases may be  
17 limited by DNBR. Some are limited by the pressure.  
18 Some are limited by the RPD.

19           Okay. So, that is the different  
20 regulatory requirements there, too. Okay.

21           So, how we approach this, we launched  
22 many, many audits. And, then, as I mentioned right in  
23 the beginning, we launched a big audit three years  
24 ago, and after that, we reviewed their calculation  
25 onsite and, then, we also launched our own

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 confirmatory calculation using many, many different  
2 codes. Some codes are our codes developed by the  
3 Office of Research. Some codes, we even use AREVA's  
4 codes to change the deck and the performance  
5 sensitivity of the cases.

6 So, in this way, the confirmatory analyses  
7 are used to generate useful information, so that we  
8 can make sure we ask the right RAIs, instead of many  
9 numbers of RAIs.

10 MEMBER SHACK: Do you have access to all  
11 of AREVA's codes? I mean, if you want to --

12 MR. LU: AREVA is very cooperative.  
13 Whenever we ask them for codes, they say, "Okay, here  
14 you go. Run it."

15 And, then, actually, I am going to give  
16 you the examples of lots of codes we ran, as RELAP5 we  
17 actually ran, both transient and LOCA. Okay?

18 All right. That is the overall approach.  
19 Okay.

20 CHAIRMAN BANERJEE: Just let me ask AREVA,  
21 do you have a formalized V&V process in-house?

22 MS. SLOAN: Yes. Absolutely. Yes.  
23 Rigorous procedures written, and I think the staff in  
24 previous reviews has looked at our V&V procedures,  
25 absolutely. A whole software configuration management

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 program to go along with that, yes.

2 CHAIRMAN BANERJEE: Okay. And you have  
3 reviewed that?

4 MR. LU: Yes. Now, actually, right before  
5 we got into the official DCD review, we performed a QA  
6 review. As part of it, we reviewed that QA procedure,  
7 too. That is back to 2007, I think October 2007, pre-  
8 submittal, QA audit.

9 CHAIRMAN BANERJEE: So, for example, TRACE  
10 has a bunch of -- and maybe somebody here can comment  
11 on this from staff -- but they have a standard set of,  
12 let's say, benchmark data or analyses or whatever. So  
13 that every time some change is made in a quote, it has  
14 to be, you know, passed through this --

15 MR. LU: Right.

16 CHAIRMAN BANERJEE: -- sort of validation  
17 process.

18 MR. LU: Right.

19 CHAIRMAN BANERJEE: Does AREVA have some  
20 equivalent dataset against which they validate codes,  
21 like S-RELAP or whatever?

22 MR. LU: Okay. As part of a large-break  
23 LOCA, topical report review and the presentation we  
24 are going to give to you. And actually, we will tell  
25 you how we reviewed that part specifically. I think

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 it will be in the March timeframe.

2 But to specifically answer your question,  
3 we did learn a lot through our own TRACE experience,  
4 code development experience and validation and  
5 verification. And the staff has experience with that  
6 process. So, when we reviewed that, we actually  
7 reviewed similar process. We tried to identify if we  
8 have any questions here, too.

9 So, as a part of the S-RELAP5 LOCA topical  
10 report review, we did have a lot of thorough review of  
11 the code versions, updated the QA process, and  
12 validation and verification.

13 CHAIRMAN BANERJEE: And not just large-  
14 break LOCA, but --

15 MR. LU: No. Oh, yes.

16 CHAIRMAN BANERJEE: But also some small-  
17 break and --

18 MR. LU: Yes. We do. We do that.

19 CHAIRMAN BANERJEE: -- other things?  
20 Okay.

21 MR. LU: That is our job.

22 CHAIRMAN BANERJEE: Okay.

23 MR. LU: All right. Let me talk about the  
24 open items we have. We have three open items, and all  
25 of them are not unique to this design. It is just a

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 process, and then once you have the design cert, then  
2 there is always certain information cannot be  
3 developed as part of a DCD. So, this is not unique to  
4 EPR, and all the new designs may have similar issues.

5 For example, the first one is the open  
6 item related to the emergency operating procedures.  
7 If you go through the FSAR, 15.0.8, something like  
8 that, there is a list of the operator actions credited  
9 as part of the AOO analysis.

10 All those need to be verified through the  
11 COL action item and validated, the safety analysis  
12 assumptions used in Chapter 15 non-LOCA analysis, too.

13 The example here is 15.0.0.3.7, lists all  
14 those operator actions. And the examples can be  
15 feedwater line break, main steam line break, steam  
16 generator tube rupture. We just talked about that.  
17 And ECCS switchover during LOCA long-term cooling in  
18 design, like, for example, from cold leg to hot leg  
19 switchover.

20 So, this is an open item, the EOP.

21 CHAIRMAN BANERJEE: They are going to do  
22 this realignment switchover at some time during the  
23 long-term cooling phase?

24 MR. LU: That is being developed. It is  
25 not finalized yet, because it is specifically related

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 to the downstream effects; it has not been finalized  
2 yet. We may be able to talk about it during our  
3 presentation on 15.6.5 down the road sometime, but not  
4 now.

5 CHAIRMAN BANERJEE: Okay.

6 MR. LU: Okay. Let me see. Okay. At  
7 this point, there is no specific guidelines for the  
8 required verification and validation of EOPs to  
9 confirm operator actions credited in the safety  
10 analysis are achievable. And therefore, as part of a  
11 COL information item, we asked AREVA to provide this  
12 and, then, describe how they are going to collect all  
13 this information and develop this information as part  
14 of COL. And, then, what's the plan?

15 So, down the road, we would expect that  
16 the once COL applicant takes over, we need to work  
17 with AREVA to develop these EOPs and to verify the  
18 developed EOPs can support the Chapter 15 AOO  
19 analysis.

20 Okay. I think that is the last bullet  
21 related to the EOP verification.

22 Power measurement uncertainties, I think  
23 we discussed this morning.

24 CHAIRMAN BANERJEE: It's open.

25 MR. LU: Yes, it's open. And I think the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 reason is very simple. I think when we saw .48  
2 percent power measurement uncertainties, it was very  
3 small. So, we asked, what's the basis? We issued  
4 RAIs. And actually, AREVA provided two runs of RAI  
5 responses already. The first run was provided as part  
6 of a large-break LOCA topical report and told us the  
7 ultrasonic flow meter will be used.

8 And the second round of RAI responses was  
9 provided as part of 15.6.5 and told us what's the  
10 methodology they used, how did they do the uncertainty  
11 analysis, and came out with this number of 0.48. And  
12 we reviewed the RAI responses. We found they did have  
13 a good methodology which has been approved before by  
14 NRR staff.

15 However, the uncertainty input to that  
16 methodology, most of them are assumed; at the DCD  
17 stage, everybody would assume all those uncertainties  
18 because the equipment has not been ordered or a  
19 specification has not been given. So, therefore,  
20 there is no way to say, okay, down the road it will be  
21 0.48 uncertainty.

22 So, from that perspective, we decided to  
23 launch this RAI and to request additional information  
24 from them to verify what is the mechanism for them to  
25 achieve this .48 percent, which they have already told

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 us in the first round of RAI responses.

2 CHAIRMAN BANERJEE: But the other thing to  
3 remember, Shanlai, here is that, of course, the  
4 analysis is the initial conditions for the LOCA,  
5 right?

6 MR. LU: That's right. Actually, not only  
7 LOCA, but for all EOs.

8 CHAIRMAN BANERJEE: Yes. There are a  
9 number of other things.

10 MR. LU: Yes. That is the most important  
11 parameters for determining the starting point.

12 CHAIRMAN BANERJEE: Yes. And we have been  
13 through a very long discussion on this in a very much  
14 more applied situation where somebody is building a  
15 plant and they want to do this. We should seek  
16 consistency in some way because --

17 MR. LU: That's right.

18 CHAIRMAN BANERJEE: -- there is a history  
19 here --

20 MR. LU: That's right.

21 CHAIRMAN BANERJEE: -- which we have been  
22 through.

23 MR. LU: Yes. One of the reasons we  
24 issued this RAI was we defined this as an open item  
25 because we learned from the AP1000 presentation your

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 viewpoint, and we are considering it as part of an EPR  
2 review, too.

3 CHAIRMAN BANERJEE: Right.

4 MR. LU: So, that is the reason we also  
5 have this open item, too. So, it is not unique to  
6 EPR. It is for the AP1000 and other reactors using  
7 ultrasonic flow meters.

8 CHAIRMAN BANERJEE: Yes, we are not  
9 talking about MURs here. We are talking about a new  
10 reactor.

11 MR. LU: Right.

12 CHAIRMAN BANERJEE: Yes. Okay.

13 MR. LU: All right. There is a lot of  
14 technical specifications defined and reviewed, defined  
15 by AREVA and are currently under review by staff,  
16 particularly the Specification Branch. However, those  
17 technical specifications right now establish a  
18 boundary or an initial condition for an EPR AOO  
19 analysis or postulated accident analysis.

20 Therefore, we would like to have AREVA to  
21 provide the link between the technical specifications  
22 to the Chapter 15 analysis assumptions. That is what  
23 this open item is about.

24 Okay. All right. Those are three open  
25 items we have. Of course, right now we are just in

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 the Phase 2. This is a snapshot of the results we had  
2 at this point. Any new information will prompt staff  
3 to review or additional new information, where these  
4 conclusions may be subject to change.

5 And since the ACRS has brought up the  
6 steam generator tube rupture event, and I think we had  
7 a lot of discussion on this already, and to give you a  
8 high-level aspect of that one not related to the dose.

9 From the reactor system side, we have been focusing  
10 on three aspects, the thermal hydraulic aspect.

11 No. 1, to maximize break flow from one  
12 tube from the primary side to the secondary side,  
13 which provides a basis for the dose calculation.  
14 Then, we review that part.

15 We also reviewed a technical specification  
16 coolant activity, and, then, the operator actions  
17 beyond 30 minutes. And what is the offset power  
18 availability or not? And we reviewed that part, too.

19 We reviewed automatic secondary side  
20 partial cooldown, automatic emergency feedwater  
21 injection, and manual EBS. And we also particularly  
22 with this methodology, with this particular event, we  
23 reviewed the S-RELAP5 with its application to this  
24 steam generator tube rupture event.

25 And what we found was, to mitigate this

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 event, it requires quite significant operator actions,  
2 which were tied to one of the open items we have right  
3 at the beginning, the EOPs. So, this part of the  
4 closure needs to be done as part of COL, even for the  
5 tube rupture event.

6 Okay. So, that is a high-level summary.  
7 The punchline of the staff's Phase 2 review on the EPR  
8 non-LOCA events.

9 And, then, at this point, we finished  
10 15.0, 15.1, 15.2, .3, .5, .6, and .8 review. We  
11 launched a total of 131 RAIs, and there are four open  
12 items remaining. One more from the reactor system  
13 will be discussed tomorrow to track the rod ejection  
14 topical report.

15 And we did perform a lot of confirmatory  
16 analysis with the support from the Office of Research.

17 We got a lot of help from them. Since even before I  
18 started to work on the EPR, they were developing the  
19 base system models.

20 So, those confirmatory analyses did help  
21 staff to develop RAIs.

22 CHAIRMAN BANERJEE: So, did the Office of  
23 Research primarily use TRACE for this work?

24 MR. LU: Okay. Yes, at this point, the  
25 Office of Research's product to us is primarily based

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 on TRACE for AOOs and postulated accidents because it  
2 has the 3D kinetics capability, and RELAP5, RELAP I  
3 think Mod 3 does not have that 3D kinetics capability.

4 Therefore, we relied on the TRACE part, coupled 3D  
5 kinetics, to perform the transient analysis.

6 CHAIRMAN BANERJEE: So, have we seen a  
7 TRACE/PARCS applicability report for EPR? Is Chris  
8 Hoxie here?

9 All right. We will defer that question.

10 MR. BAJOREK: Sanjoy, this is Steve  
11 Bajorek.

12 CHAIRMAN BANERJEE: Go ahead.

13 MR. BAJOREK: Yes, we have done a TRACE  
14 applicability report. This was put together about the  
15 same time we were putting together the model. As part  
16 of that, we went through, did like a PIRT, compared  
17 what TRACE had been approved for or basically  
18 developed for compared to the EPR, looked at the  
19 differences in small-break. Large-break I don't  
20 recall there was much there.

21 Then, we accompanied our normal set of  
22 what I would call generic assessment with things that  
23 focused on phenomena that was more important to the  
24 EPR small-break. That report is together. We have  
25 completed that work. I don't think it has been

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 presented to you yet.

2 CHAIRMAN BANERJEE: Okay, but it is ready?

3 MR. BAJOREK: It is ready, yes.

4 CHAIRMAN BANERJEE: Okay.

5 MR. LU: But from our perspective, not  
6 only we are using TRACE, which in other cases we use  
7 different codes, too.

8 CHAIRMAN BANERJEE: Yes, but TRACE and  
9 PARCS are sort of the workhorse.

10 MR. LU: Yes, are unique to provide a 3D  
11 kinetics capability.

12 CHAIRMAN BANERJEE: Yes.

13 MR. LU: That is the reason we are going  
14 to give you the presentation about we use that  
15 TRACE/PARCS.

16 CHAIRMAN BANERJEE: Okay.

17 MR. LU: Okay? I think that finished this  
18 part.

19 MR. TESFAYE: I would like to make some  
20 clarification here. Two of the open items that are  
21 listed here, one of them belongs in Chapter 16, the  
22 other one in Chapter 4. So, there are only two open  
23 items left for Chapter 15, and those two open items  
24 are closed in those respective chapters. This will  
25 also be closed. So, this is kind of unusual for us to

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 present open items repeatedly here in this  
2 presentation.

3 MR. LU: Also, we have enough coverage for  
4 you.

5 CHAIRMAN BANERJEE: All right. You have  
6 to keep us interested, right?

7 MR. LU: Okay. All right. Should we  
8 proceed for the next one or do you want to take a  
9 break?

10 CHAIRMAN BANERJEE: No, we will start and  
11 then we will find the right time to take a break.

12 MR. LU: Okay.

13 CHAIRMAN BANERJEE: We finished a break at  
14 1:30, our lunch. So, we can continue for a while.

15 Now you have to tell us what is up-to-  
16 date. I have got so many of these pieces of paper now  
17 in front of me.

18 MR. LU: I think that since we are going  
19 to give you the presentation of confirmatory analysis,  
20 maybe we will ask the staff who worked on that  
21 analysis to come over. Somebody needs to call Tony  
22 Ulises. I will go over the overview for now.

23 As I mentioned right at the beginning of  
24 my presentation, we developed two sets of  
25 presentation. The intention of this set of

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 presentations is to give you the information about how  
2 staff performed the review and tried to use our system  
3 or a system code or analysis code to achieve an  
4 understanding of a very complicated design using SPND  
5 and trip setpoints. Okay. So, that is the intention.

6 But right at the beginning, I am going to  
7 give you some summary of who really contributed to  
8 this part of the work. From the Office of Research,  
9 we have Shawn Marshall. He is going to talk about the  
10 TRACE model. Bill Krotiuk, and they have continued to  
11 support us during the past three years. Steve, he has  
12 already provided a lot of input into our review. Ron  
13 Harrington, he actually initially developed the TRACE  
14 stack, ran the LOCA.

15 From the Reactor System Branch, NRR, Tony  
16 Ulses. When he was over Research, he ran this TRACE  
17 coupled with PARCS.

18 And our consultant, Randy Bells from Oak  
19 Ridge; Jose March-Leuba and Dave Caraher supporting us  
20 to perform this set of analysis.

21 Okay. I am going to cover the overall  
22 confirmatory analysis approach. I want to take this  
23 opportunity to not only just cover the AOOs and the  
24 postulated accident; I am going to cover overall  
25 related to the reactor system EPR review, what we have

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealgross.com](http://www.nealgross.com)

1 done. I will give you an overall picture there.

2 First of all, we cannot do every single  
3 transient that we saw that AREVA ran, all those  
4 different cases, when we performed the audit. So, we  
5 developed the criteria so that we can have a selected  
6 transient, most limiting case for us to perform the  
7 analysis.

8 No. 1 is really we are focused on the new  
9 design features, specifically for AOOs because they  
10 relied on the in-core setpoint and methodology, and  
11 then, of course, SPNDs to produce the protection  
12 system trip. That is one of the focuses.

13 And, then, we used this tool to identify  
14 RAIs related to margin evaluation. If some of the  
15 RAIs may sound reasonable, it is good to ask, but it  
16 is very hard to answer. And if there is not a whole  
17 lot of margin value, then we may not even ask those  
18 questions because we can ask tons of questions and  
19 make the process unbearable.

20 And the confirmatory analysis scope is  
21 specifically related to EPR. And for AOOs, we  
22 performed a loss of feedwater heater, controlled  
23 withdrawal using TRACE and PARCS.

24 For the postulated accident, large-break  
25 LOCA, small-break LOCA, rod ejections, we all ran the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 cases using our codes, AREVA's codes, and to perform  
2 the comparison and evaluate whether the RAIs are valid  
3 or not.

4 And, then, to evaluate specific features  
5 of the EPR design ex-core detector, because the EPR  
6 uses a heavy metal reflector which really reduced the  
7 dose and, then, also, its neutron exposure on the  
8 vessel. However, it also reduced the neutron flux out  
9 of the ex-core detector. So, we are actually right  
10 now in the process to perform an MCNP calculation to  
11 evaluate the ex-core detector. And the spent fuel  
12 pool design, we performed our own criticality  
13 analysis.

14 CHAIRMAN BANERJEE: The MCNP is being done  
15 by Oak Ridge?

16 MR. LU: Oak Ridge, yes.

17 CHAIRMAN BANERJEE: Who at Oak Ridge is  
18 doing that?

19 MR. LU: John Wagner's team.

20 CHAIRMAN BANERJEE: Okay.

21 MR. LU: Okay. As part of these three, we  
22 also ran many cases at this point, and we are in the  
23 process to finish this part of the confirmatory  
24 analysis and to verify whether we have valid RAIs or  
25 the RAI closure can be achieved, based on this

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 analysis. Sometimes we just run the S-RELAP5 code.

2 That is the overall scope. And, then, I  
3 will give you some detailed information about not only  
4 the scope, but also the approach and the tools.

5 As I mentioned, we ran RELAP5, Mod 3.  
6 That is RELAP5. We used AREVA code and then used  
7 their input deck, but we changed the model. We ran  
8 TRACE, PARCS, and then the TRACE/PARCS were supported  
9 by NRC Research when Tony was over there.

10 And ISL provided the confirmatory analysis  
11 support using RELAP5.

12 We also performed a fuel performance  
13 evaluation as an initial condition for LOCA. We used  
14 FRAPCON; FRAPTRAN; RODEX-4, AREVA code; and we have  
15 NRO staff in-house performed those calculations. And  
16 we also have PNNL, our consultant, performed the  
17 calculation using FRAPCON.

18 And in terms of AOOs and postulated  
19 accidents evaluation, we used TRACE/PARCS, and Tony is  
20 walking in. So, he is going to talk about that very  
21 soon.

22 And the TRITON to generate the cross-  
23 sections, and RELAP5, S-RELAP5, too.

24 And for ex-core neutron flux and the  
25 criticality evaluation, we used SCALE 6.0, MCNP, and

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 done by NRO staff in-house and, also, by Oak Ridge.

2 CHAIRMAN BANERJEE: Just go back to that.

3 Now, for something like rod ejection, the bunch of  
4 codes, Area 1, Area 2 --

5 MR. LU: Yes. Yes.

6 CHAIRMAN BANERJEE: For things like rod  
7 ejection --

8 MR. LU: Right.

9 CHAIRMAN BANERJEE: -- there is a whole  
10 suite of codes which AREVA is using, which they have  
11 the diagram of in their report.

12 MR. LU: That's right. They did.

13 CHAIRMAN BANERJEE: How did you sort of --  
14 did you run those codes or you just ran your own codes  
15 to validate that?

16 MR. LU: Particularly for rod ejection,  
17 tomorrow morning we are going to cover that.

18 CHAIRMAN BANERJEE: Yes.

19 MR. LU: So, there will be a specific  
20 section about the confirmatory analysis related to the  
21 rod ejection event.

22 CHAIRMAN BANERJEE: Okay.

23 MR. LU: And the answer to that question  
24 is short. We just used TRACE/PARCS.

25 CHAIRMAN BANERJEE: Right. I thought that

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 would be the answer. So, I just wanted you to say  
2 that. Okay. That's it.

3 MR. LU: Okay. All right.

4 CHAIRMAN BANERJEE: By the way, one other  
5 thing. So, in some of these situations where you  
6 might get a power pulse, how do you sort of -- which  
7 of your codes did you use to look at the enhanced  
8 release of radioactive materials during those pulses?

9 MR. LU: Specifically related to the  
10 material --

11 CHAIRMAN BANERJEE: Material, yes.

12 MR. LU: As part of a Reactor System  
13 Branch review scope, we have not touched too much upon  
14 material except for the fuel cladding, which, for  
15 example, we use FRAPTRAN/FRAPCON --

16 CHAIRMAN BANERJEE: Yes, sure.

17 MR. LU: -- to perform that part of the  
18 analysis, which those two codes were developed by the  
19 Office of Research, too, supported by --

20 CHAIRMAN BANERJEE: Yes, but when you get  
21 this power pulse or something, you get more stuff  
22 being released from the fuel, right, into the gap  
23 regions? And AREVA has some methodology to look at  
24 that, I think.

25 MR. LU: Yes. Right.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIRMAN BANERJEE: Or estimate that.

2 MR. LU: Yes. But I think the details  
3 will be provide tomorrow. I think it is specifically  
4 rod ejection. And, then, from my perspective, I think  
5 Tony is probably the best person to answer some  
6 questions about rod ejection confirmatory analysis  
7 or --

8 CHAIRMAN BANERJEE: We can wait until  
9 tomorrow. There's no rush.

10 MR. LU: Okay.

11 CHAIRMAN BANERJEE: We have time.

12 MR. LU: Yes. I think for rod ejections  
13 really -- okay. All right. That is the overall scope  
14 of the NRC's confirmatory analysis.

15 CHAIRMAN BANERJEE: Do you have your  
16 slides? Just as a general request, do we have the  
17 slides that are going to be presented tomorrow?

18 MR. WIDMAYER: Do you want to look at  
19 them?

20 CHAIRMAN BANERJEE: Yes, I don't have  
21 them.

22 MR. WIDMAYER: Okay, I will get them to  
23 you.

24 CHAIRMAN BANERJEE: So, I will get them.  
25 So, we have both the applicant's and the staff's,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 right?

2 MR. WIDMAYER: Yes.

3 MR. TESFAYE: We also will make a quality  
4 check. The numbers are correct.

5 (Laughter.)

6 CHAIRMAN BANERJEE: Sorry.

7 MR. TESFAYE: We will make sure the  
8 quality will be good in terms of numbering.

9 MEMBER SHACK: The V&V program.

10 (Laughter.)

11 MR. LU: Okay. So, the next one will be  
12 Shawn Marshall. He is going to talk about the TRACE  
13 model development for the U.S. EPR, which is the base  
14 model developed for not only AOO analysis coupled with  
15 PARCS to perform the rod ejection analysis, but it  
16 also has been used for large-break LOCA analysis, too.

17 CHAIRMAN BANERJEE: So, I think there is  
18 an issue as to whether we should take this before a  
19 little break or not. I am just looking at the slides.

20 This is probably going to take more than half an  
21 hour. So, I think what we should do is take a brief  
22 break. It is a quarter past 3:00 right now.

23 So, we will go off the record and then we  
24 will come on to this. Okay?

25 Thank you.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 (Whereupon, the foregoing matter went off  
2 the record at 3:05 p.m. and resumed at 3:17 p.m.)

3 CHAIRMAN BANERJEE: All right. So, we are  
4 going to go back in session, and, Shawn, it is in your  
5 hands now.

6 MR. LU: He's not Shanlai Lu, but we made  
7 the mistake in giving the names for the presenters.

8 CHAIRMAN BANERJEE: That's right.

9 MR. LU: So, his name tag was not made.  
10 We apologize again.

11 MR. MARSHALL: Well, my name is Shawn  
12 Marshall. I work in the Office of Research in the  
13 Reactor Systems Analysis Branch.

14 I have been with the agency almost nine  
15 years, starting as a nuclear safety intern, and spent  
16 that entire time in the Office of Research.

17 I have a bachelor's and master's in  
18 mechanical engineering from Tuskegee University.

19 This afternoon my presentation is on the  
20 development of the base TRACE model for the U.S. EPR.

21 My objective for this presentation is to provide you  
22 with a brief overview of what is in the model that we  
23 in Research developed to support NRO's confirmatory  
24 analyses.

25 In doing that, I will provide some general

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 descriptions of some of the major components in the  
2 model, components on the primary and secondary sides,  
3 as well as in the emergency core cooling system.

4 Then, as proof of the fidelity of the  
5 model, I will show some steady-state results that we  
6 got from TRACE in comparison with some results that  
7 were provided by AREVA.

8 Now our intent in designing this model was  
9 to incorporate as much plant-specific, EPR-specific  
10 detail as possible without unduly increasing the  
11 runtime of the simulations. And this includes  
12 simulating all of the basic operational and protection  
13 system functions, all of the primary and secondary  
14 system functions of the ECCS system and the reactor  
15 protection actuation signals.

16 The information for building the model was  
17 provided primarily by the RELAP5 model that was  
18 provided by AREVA and the EPR databank. We used our  
19 Symbolic Nuclear Analysis Package, or SNAP, GUI to  
20 construct the model.

21 And in summary, the model contains over  
22 185 hydraulic components, over 400 control system  
23 inputs, and over 150 different heat structures to  
24 simulate the heat transfer.

25 In this figure, I am showing the entire

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 nodalization of the TRACE EPR model. In the center is  
2 the reactor vessel immediately surrounded by a series  
3 of 1D pipe components which simulate vessel bypass  
4 flow. These bypass flows range from flows from the  
5 control rod guide tubes, guide assemblies, a flow path  
6 through the header reflector, and the downcomer upper  
7 head leakage flow path.

8 Branching out from the vessel are the four  
9 independent cooling loops, each with a steam  
10 generator, and attached to main steam line piping.

11 At the very bottom of the figure are the  
12 four accumulators and accumulator piping with a series  
13 of TRACE fields representing ECCS injection sites.

14 For the primary system, we used a TRACE 3D  
15 VESSEL component to model the reactor pressure vessel.

16 In the background I show how we actually nodalized  
17 the vessel.

18 In the foreground I show a cross-section  
19 of the vessel with eight azimuthal sectors, one sector  
20 for each hot leg and each cold leg. And there are  
21 four radial rings with the three innermost rings  
22 representing the core and the fourth representing the  
23 downcomer.

24 Staying with the primary system here, I  
25 show the pressurizer with four safety release valves

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 on top. The vessel has TRACE spray components used to  
2 provide pressurizer spray. Not shown are heat  
3 structures used to simulate pressurized heaters.  
4 Unlike what is stated here, we used the proportional  
5 integral differential controllers to control the spray  
6 and the heaters to regulate pressure. We used a much  
7 simpler control to simulate the letdown and charging  
8 of the chemical control system.

9           Proceeding from the bottom of the  
10 pressurizer is a surge line that we have modeled to  
11 maintain its length and to maintain the elevation  
12 change from the pressurizer to the hot leg. And below  
13 the surge line you see one of the independent coolant  
14 loops with the hot leg reactor coolant pump, cold leg,  
15 and crossover leg.

16           On the secondary side, as I said, we  
17 modeled each steam generator separately. The EPR has  
18 thousands of steam generator tubes, but we model the  
19 tubes with one effective tube, and we use a multiplier  
20 to capture, to simulate the surface area of the  
21 thousand tubes in the EPR.

22           We also use a series of 1D components to  
23 model the actual economizer in the EPR, to simulate  
24 the hot and cold side, downcomer and boiler regions of  
25 the steam generator.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 CHAIRMAN BANERJEE: Could you just point  
2 out the economizer?

3 MR. MARSHALL: Here is, well, it is a cold  
4 leg downcomer and a hot leg downcomer. Here is a  
5 separator, the steam dome.

6 The coolant is separated and it flows down  
7 to the boiler section into the downcomer. It is  
8 separated; the recirculated condensate falls from the  
9 separator to the boiler region, where it is parsed  
10 between the hot side and the cold side of the boiler  
11 region. But these are the 1D components that make up  
12 the economizer. And the feedwater injection injected  
13 into the cold side of the downcomer.

14 CHAIRMAN BANERJEE: So, in a physical  
15 load, not a computational load, what does this thing  
16 look like exactly? You have got a riser and --

17 MR. MARSHALL: Right. It is basically a  
18 sleeve that allows you to inject in one region and  
19 maintain different temperatures on the secondary side,  
20 and it allows you to have, I guess, increased steam  
21 pressure and improves the overall thermal efficiency  
22 of the steam generator.

23 CHAIRMAN BANERJEE: So, it is like a part  
24 of an annulus or there is a --

25 MR. MARSHALL: It is.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIRMAN BANERJEE: Okay.

2 MR. MARSHALL: I wish I had a more  
3 accurate representation of it.

4 CHAIRMAN BANERJEE: Yes. I think it is  
5 like part of an annulus and it comes in and it goes  
6 down and goes across the tube sheet at the bottom or  
7 something, but slow on the secondary side? Where does  
8 the feedwater come in?

9 MR. MARSHALL: Well, the feedwater --

10 CHAIRMAN BANERJEE: Do we have a picture?

11 MR. PARECE: We have a picture someplace  
12 we can dig up.

13 CHAIRMAN BANERJEE: Yes.

14 MR. PARECE: What it is is -- think of  
15 your typical wrapper a steam generator has, a wrapper  
16 where the bundles are inside. And, then, outside is  
17 the shell.

18 CHAIRMAN BANERJEE: Right.

19 MR. PARECE: So, the water comes down the  
20 downcomer.

21 CHAIRMAN BANERJEE: Right.

22 MR. PARECE: Well, on half of it, inside  
23 is now wrapper outside the wrapper. And the feedwater  
24 has J-nozzles that stick in that half, and it forces  
25 the feedwater down on the cold leg side.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1           So, 90 percent of the water coming up the  
2 cold side of the tubes on the secondary is at  
3 feedwater temperature and 10 percent is recirculated.

4           So, what that does is it gives you the benefits of  
5 pre-heater without all the trouble of the pre-heater.

6           Because in the past pre-heaters put the feedwater in  
7 low and cross-flow through the tubes and cause  
8 vibration. The water boxes collapse due to water  
9 hammer and condensation of steam. In this case, we  
10 are just directing the cold water up one side, and  
11 there is a divider plate between the two sides.

12           CHAIRMAN BANERJEE: Yes.

13           MR. PARECE: These steam generators are in  
14 operation right now at the N4s in France for more than  
15 the last 10 years. These are a slight upscale. And  
16 when I say "slight", the drum is stretched to allow  
17 more water, and the diameter is slightly increased to  
18 allow one or two hundred more tubes. But it is  
19 basically the same generator that is in operation at  
20 the N4s in France.

21           CHAIRMAN BANERJEE: Okay. Thank you.

22           MR. MARSHALL: On the main steam lines, we  
23 also modeled the main steam relief train which  
24 consists of the main steam relief isolation valve, the  
25 main steam relief control valve.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1           As far as the emergency core cooling  
2 system, as I said, we modeled the four accumulators.

3           CHAIRMAN BANERJEE: So, that economizer is  
4 a sort of new thing for TRACE, right? So, how did you  
5 validate TRACE, that it was doing okay with that?

6           MR. MARSHALL: We looked at it. We didn't  
7 see that it presented any new phenomena, I guess was  
8 our main conclusion. It is a new apparatus, but the  
9 phenomena was what we had seen before.

10          CHAIRMAN BANERJEE: Okay. Let me think  
11 about it. Carry on, yes.

12          MR. MARSHALL: Okay. Continuing with the  
13 ECCS injection system, we also modeled the medium and  
14 low head safety injections as well as the cross-  
15 connect between the low head loops 1 and 2 and 3 and  
16 4.

17                 Once we had the model well assembled, we  
18 did a number of shakedown tests and steady-state  
19 calculations as proof that the model could accurately  
20 simulate the plant at normal operating conditions.

21                 And in this table, I am showing some TRACE  
22 results compared to some results provided by AREVA for  
23 these specific parameters. And overall, the results  
24 look comparable and served as a good baseline case, I  
25 mean a lens through which the subsequent TRACE

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 calculations could be viewed.

2 So, with that, I have given you a glimpse  
3 into what is in the TRACE EPR model, starting with  
4 some of the components on the primary, secondary, and  
5 ECCS systems.

6 Based on the results that we have shown,  
7 TRACE results in comparison with some of the AREVA  
8 results, we feel that the model is solid and that it  
9 can provide useful information to the staff as a base  
10 model, and it can be modified to perform more specific  
11 calculations such as transients and AOOs.

12 CHAIRMAN BANERJEE: So, the main  
13 difference is just the economizer? It is not a  
14 difference, but it is the only thing which is  
15 significantly different from a --

16 MR. MARSHALL: Apart from the size.

17 CHAIRMAN BANERJEE: Yes, apart from the  
18 size, yes.

19 MR. MARSHALL: They have a reflector that  
20 is different. We modeled those flow paths, and it  
21 doesn't have high-pressure injection. It has a medium  
22 head.

23 CHAIRMAN BANERJEE: Right.

24 MR. MARSHALL: Yes. Those were the main  
25 differences that we saw.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIRMAN BANERJEE: So, how did you  
2 validate TRACE to ensure that it captured the  
3 secondary site behavior, so that you could get the  
4 cooldown and things like that correctly?

5 MR. MARSHALL: Well, about three years  
6 ago, three or four years ago, we did an extensive  
7 evaluation of TRACE looking at comparing TRACE with a  
8 number of results from some integral and separate  
9 effects tests, ROSA, PKL. We found TRACE to be  
10 acceptable for simulating large-break and small-break  
11 LOCAs in PWRs and BWRs. That was the foundational  
12 assessment.

13 CHAIRMAN BANERJEE: Right. But with  
14 regard to the controlled cooldown --

15 MR. MARSHALL: Well, I think Steve  
16 mentioned --

17 MR. BAJOREK: This is Steve Bajorek from  
18 Research.

19 Shawn, the other thing that you didn't  
20 have enough space for on your summary table is we also  
21 went around and we looked at the recirculation flow  
22 rate in the steam generator, the feedwater temperature  
23 in, the steam temperatures out, conditions around that  
24 steam generator circuit, and compared those to  
25 information that had been obtained from AREVA.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1                   CHAIRMAN BANERJEE:     So, what is the  
2 phenomena in the steam generator that is important  
3 during a controlled cooldown?

4                   MR. BAJOREK:     During a controlled -- I'm  
5 sorry?

6                   CHAIRMAN BANERJEE:     Cooldown.     Cooldown.  
7 I mean you are doing all sorts of things like blowing  
8 steam. What becomes the governing phenomena?

9                   MR. BAJOREK:     Well, I think our most  
10 interest is for a small-break where reflux  
11 condensation, CCFL, in the hot leg in the steam  
12 generator elbow are going to be the phenomena which  
13 will have the greatest impact on the transient.

14                   The modeling that Shawn used in setting up  
15 the EPR model is very similar to the modeling  
16 techniques that we used in tests like BETHSY, ROSA4,  
17 and in the applicability report, which you haven't  
18 seen yet, some additional ROSA tests, some steam  
19 generator tests that had been done at Oregon State,  
20 and also the flexset steam generator tests.

21                   CHAIRMAN BANERJEE:     All right.     The  
22 flexset in --

23                   MR. BAJOREK:     Flexset.     Yes, after they  
24 had done the reflood tests, they had modeled a steam  
25 generator, 1620 tubes, not a very large scale, a

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 simulated hot leg, and they completed the circuit and  
2 measured the amount of reflux condensation that they  
3 would get out of that partial size bundle.

4 So, what we used it for was a way of  
5 looking at flexset, BETHSY, and ROSA, of taking TRACE  
6 and trying to show that it was scale-independent, as  
7 you took a look at full height, which I think flexset  
8 was, to partial scale for Oregon State, full scale and  
9 height for ROSA. We tried to look at a wide range of  
10 geometries.

11 And those modeling aspects which were used  
12 for those tests were preserved in Shawn's model for  
13 the EPR.

14 Now, for the economizer and what goes on  
15 in the feedwater system, delivery of water to the  
16 bundle, I think we just looked at that primarily as an  
17 additional flow path, but not in the way that it was  
18 something that was introducing a lot of new phenomena  
19 that would have a major impact during either the  
20 large- or the small-breaks.

21 CHAIRMAN BANERJEE: And nothing new  
22 happened? There is a dependence here on the secondary  
23 site cooldown to get the pressure down.

24 MR. BAJOREK: Oh, it has been a while  
25 since I have looked at that report, but I believe

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 there is also one of the ROSA4 tests where they had a  
2 simulated rapid cooldown of the steam generator  
3 secondary side. That was part of the test matrix that  
4 they had done for ROSA4. It wasn't part of one of our  
5 initial assessments that was in the assessment report,  
6 but I think that was picked up in the applicability  
7 report.

8 CHAIRMAN BANERJEE: So, the secondary site  
9 of ROSA4 is pretty one-dimensional because it is just  
10 a long, thin thing, right? Whereas, this is a sort of  
11 fat, big thing? So, what happens in the secondary  
12 site?

13 MR. BAJOREK: Well, one of the other parts  
14 of that evaluation is we took a look at, was it  
15 necessary and important to model the steam generator  
16 with multiple paths through the primary side? You get  
17 some different phenomena that occurs in the short-  
18 length tubes, the medium-length and the large-length  
19 tubes.

20 We had set up a model that looked at those  
21 multiple paths. Again, I would have to go back and  
22 look at the report, but I think our conclusion there  
23 was modeling things with one single path was adequate  
24 for the various phenomena that went on in the multiple  
25 flow path model.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIRMAN BANERJEE: You know, the primary  
2 site, I can see that. I mean the height differences  
3 or some things, some may be actually naturally  
4 circulating and others might actually be refluxing.  
5 There are all sorts of things that can happen.

6 But maybe that doesn't matter, but I am  
7 just asking the question as to whether the multi-  
8 dimensionality of the secondary side -- the primary  
9 side, after all, is tubes. So, some are going to go  
10 and some are going to reflux maybe.

11 On the secondary side, though, it is  
12 inherently sort of a three-dimensional system, right?

13 MR. BAJOREK: Yes. I mean there's really  
14 nothing except for the divider plate on the hot and  
15 the cold side to prevent mixing from the flow. I  
16 guess we didn't do any kind of special modeling  
17 features to try to account for that.

18 MR. KROTIUK: This is Bill Krotiuk.

19 One thing I could say is that we have  
20 modeled, as Steve has said, you know, ROSA and PKL and  
21 all that. And when we modeled ROSA, I know quite  
22 intimately on that test we modeled them using the same  
23 methodology that is explained here.

24 And when we look at test data for both  
25 steady-state or the transient conditions, our results

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 pretty well match the test results.

2 CHAIRMAN BANERJEE: Which is what you  
3 would expect --

4 MR. KROTIUK: Right.

5 CHAIRMAN BANERJEE: -- because they are  
6 essentially one-dimensional.

7 MR. KROTIUK: ROSA has a lot of tubes  
8 in --

9 CHAIRMAN BANERJEE: Yes, but it is really  
10 fairly small compared to the real thing.

11 MR. KROTIUK: Yes, it is small compared to  
12 this.

13 CHAIRMAN BANERJEE: Right. Now EPRI had a  
14 program at one point, and I think it was Brian  
15 Spalding who was developing a code to take this into  
16 account. He called it URSULA for some reason. I'm  
17 not sure why. This goes back in history.

18 But there was strong three-dimensional  
19 effects, if I remember.

20 MR. BAJOREK: Which test was that? That  
21 wasn't MB2, was it?

22 CHAIRMAN BANERJEE: You know, my memory  
23 fades, but I can probably find out.

24 MR. BAJOREK: We would be interested in  
25 hearing that, but --

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 CHAIRMAN BANERJEE: Yes.

2 MR. BAJOREK: At least in looking at the  
3 other tests, I think as Bill pointed out, we seem to  
4 have matched the available data --

5 CHAIRMAN BANERJEE: Yes.

6 MR. BAJOREK: -- in looking at things like  
7 information that you can get from ROSA or MB2, we  
8 haven't noticed any large 3D-type behavior.

9 CHAIRMAN BANERJEE: So, is this sort of  
10 the first time we have encountered use of secondary  
11 site cooldown to depressurize within the PWR fleet?

12 MR. BAJOREK: Except if you consider Candu  
13 reactors.

14 CHAIRMAN BANERJEE: Yes. Candu, of  
15 course, have been doing it for --

16 MR. BAJOREK: But this is the first time  
17 for PWRs with U-tube-type steam generators.

18 CHAIRMAN BANERJEE: So, what have we  
19 learned from Candu's? The B&W steam generator is  
20 there. They must have been doing this for quite a  
21 while.

22 MR. BAJOREK: I'm really not sure.

23 CHAIRMAN BANERJEE: So, you didn't talk to  
24 these guys to find out what they have been doing?

25 MR. BAJOREK: Not for the Candu systems,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 no.

2 CHAIRMAN BANERJEE: There is somebody who  
3 wants to talk from the AREVA side.

4 MR. SALM: This is Robert Salm. I spent  
5 10 years in Germany with B&W's 205 plant, Mulheim  
6 Kaerlich. And Mulheim Kaerlich had the same type of  
7 medium head safety injection, four-train system, and  
8 cooldown of the secondary side. And we did extensive  
9 tests at Alliance Research Center with once-through  
10 steam generators using this approach and benchmarked  
11 our codes against those tests, and really didn't see  
12 anything different than we are seeing here.

13 CHAIRMAN BANERJEE: This is a pretty more  
14 complicated steam generator than the once-through,  
15 correct?

16 MR. SALM: Complicated hardware-wise, but  
17 not necessarily phenomenologically. I mean a once-  
18 through steam generator is pretty complicated from a  
19 phenomena standpoint.

20 CHAIRMAN BANERJEE: Yes.

21 MR. SALM: And we had subcooled water  
22 coming in the bottom, and then you go up to  
23 superheated steam.

24 CHAIRMAN BANERJEE: Yes. Yes. You had  
25 it --

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 MR. HARRINGTON: Yes, this is Ron  
2 Harrington with the Office of Research at NRC.

3 You still have a question of how we  
4 modeled the economizer?

5 CHAIRMAN BANERJEE: Well, I have a broader  
6 question. It is sort of this controlled cooldown here  
7 is a critical component of depressuring the system.  
8 So, okay. So, now, in addition, there is sort of  
9 maybe a complexity, maybe not associated with the  
10 economizer. These are pretty big steam generators.  
11 So, they are quite multi-dimensional.

12 Whether that is important or not, I don't  
13 know, but I was wondering how the multi-dimensional  
14 effects were assessed and how you sort of felt  
15 comfortable with taking essentially a one-dimensional  
16 representation of that.

17 MR. HARRINGTON: I can't speak to how it  
18 was assessed, but I can show you how we modeled it,  
19 how we set up the thing.

20 CHAIRMAN BANERJEE: Right. He showed us  
21 the pictures.

22 MR. HARRINGTON: It was basically that  
23 nodalization along with the way the heat structures  
24 are set up to go with that. That is how the  
25 economizer was modeled.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 CHAIRMAN BANERJEE: Right. So, if you had  
2 made a model which looked a little bit like a core or  
3 something, you know, for the secondary side, would you  
4 get the same answers?

5 MR. LU: Let me add something here. The  
6 intention for the AOO analysis right now is to run the  
7 feedwater heater trip and the feedwater temperature  
8 reduction cases, and, also, the rod withdrawal.

9 So, this phenomena you asked for for  
10 emergency feedwater injection for these particular  
11 cases, we are trying to study. Yes, it may be  
12 important for other transients, but specifically for  
13 these in-core trips is not that important. Now as the  
14 model can reach the heat balance, that should be fine.

15 CHAIRMAN BANERJEE: Yes. I think what you  
16 are saying is, if you limit it to the AOOs, I don't  
17 disagree.

18 MR. LU: Yes.

19 CHAIRMAN BANERJEE: In fact, I may not  
20 disagree for everything else, but I am just saying  
21 that for this, yes, but for the case where your  
22 controlled cooldown becomes a crucial aspect, and no  
23 doubt you can make a rough estimate of this based on  
24 the heat balance and stuff.

25 MR. LU: That's right.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. BAJOREK: Dr. Banerjee, I think I  
2 remember once where one of the reasons that the steam  
3 generators and the safety analysis were modeled in  
4 more of a 1D or crude fashion is, when you start to go  
5 from steady-state power to decayed heat, they are so  
6 massively oversized to remove that amount of  
7 decayed heat that most people have taken a more  
8 simplistic view.

9 CHAIRMAN BANERJEE: Sure. Yes.

10 MR. BAJOREK: Even it has much more  
11 surface area than it needs. So, there hasn't been a  
12 whole lot of work, at least not to my knowledge, on  
13 trying to get very detailed in how that energy gets  
14 out of the primary system.

15 CHAIRMAN BANERJEE: Yes, you are  
16 absolutely right, Steve. The main thing, though, is  
17 if you get into a refluxing mode, and if you are  
18 refluxing for, let's say, all the tubes -- let's take  
19 a scenario, okay, like that. Then, of course, you are  
20 using only a part of it. So, you get maldistributions  
21 in your heat load. So, you can see where I am coming  
22 from.

23 MR. BAJOREK: Yes, because I think that  
24 some of the ROSA tests, what they showed is you would  
25 condense in some of the tubes.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIRMAN BANERJEE: Yes.

2 MR. BAJOREK: And they would flood and  
3 drain while steam would start to flow into some of the  
4 other tubes --

5 CHAIRMAN BANERJEE: Other tubes, yes.

6 MR. BAJOREK: -- condense, and it would  
7 sort of chug with alternating tubes doing the  
8 condensation.

9 CHAIRMAN BANERJEE: And, then, if you are  
10 refluxing in all the tubes, then, of course, you have  
11 got another set of problems now at the elbow to go  
12 into the steam generator plenum.

13 MR. BAJOREK: Then you have the CFFL --

14 CHAIRMAN BANERJEE: Yes.

15 MR. BAJOREK: -- allowing that water to  
16 get back, yes.

17 CHAIRMAN BANERJEE: We will visit it when  
18 we come to the small-breaks. So, we will let you go  
19 right now, because, otherwise, we will be sitting here  
20 all evening.

21 And there is one additional item which  
22 AREVA would like to do which is the Chapter 11 certain  
23 points. So, we will try to make room.

24 MS. SLOAN: Thank you.

25 CHAIRMAN BANERJEE: So, thanks, Steve, and

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 thank you, Shawn.

2 MR. LU: I think this provides the  
3 information about how we developed the TRACE thermal  
4 hydraulics model, but the two simulated in-core trip  
5 setpoints and the algorithm and the trips itself,  
6 based on the SPND and the system, we need the 3D  
7 kinetics.

8 CHAIRMAN BANERJEE: Right.

9 MR. LU: Here is Tony Ulses.

10 CHAIRMAN BANERJEE: Tony is going to tell  
11 us.

12 MR. ULSES: Let's see if I can sit low  
13 enough here so you can see the screen behind me. I'm  
14 being challenged.

15 (Laughter.)

16 All right. So, good afternoon.

17 As Shawn said, my name is Anthony Ulses.  
18 I was in the Office of Research. Now I am with the  
19 Office of Nuclear Reactor Regulation.

20 And we were tasked with trying to develop  
21 a model to allow the Oak Ridge work, which we are  
22 going to talk about subsequent to this, to have access  
23 to actual information regarding what the in-core  
24 nuclear detectors would see, which is what those trip  
25 functions are using as their function.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1           So, obviously, if we had actual plant  
2 data, we would use that. But, lacking that, we needed  
3 to develop a three-dimensional PARCS model to allow us  
4 to do that simulation.

5           I am going to walk you through in a couple  
6 of slides here how we developed that model, and, then,  
7 I am going to hand it off to Randy Bells from Oak  
8 Ridge who will go through the details of how they  
9 actually simulated.

10           Shanlai is going to do that. Well, I  
11 apologize. It is a last-minute change, a last-minute  
12 game change here.

13           So, we started with the LOCA deck that you  
14 just heard which was described by Shawn. And, then,  
15 we overlaid the multi-dimensional neutronics model on  
16 it.

17           This is a pictorial representation of the  
18 model itself. This image here, basically -- does this  
19 mouse work? Yes. Oh, there we are.

20           This here is the layout of the core  
21 showing the different fuel types. This model here  
22 shows how we linked the individual fuel types to the  
23 TRACE radial and, also, azimuthal nodding. Because,  
24 obviously, we have to feed the information related to  
25 the moderator temperature, the moderator soluble

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 poison back to PARCS. And, then, for each one of the  
2 fuel assemblies, on the left-hand side here, we added  
3 one actual heat structure to individually model each  
4 of the fuel assemblies. So, we have a direct one-to-  
5 one relationship there.

6 And, then, again, this was laid into the  
7 TRACE model that you heard about from Shawn a minute  
8 ago.

9 CHAIRMAN BANERJEE: What did you mean by  
10 14-to-1 moderator coupling?

11 MR. ULSES: Well, that means that, if you  
12 estimate the number of assemblies which are included  
13 in each of these azimuthal and radial sectors, it is  
14 roughly about 14 assemblies in each assembly.

15 CHAIRMAN BANERJEE: Okay.

16 MR. ULSES: In each one of these larger  
17 nodes that we have from the TRACE model. And that is  
18 not exactly the representation. That is sort of an  
19 estimate based on looking at how they laid out.

20 We developed our own cross-sections. We  
21 used our SCALE/TRITON model to do that. This is a  
22 pictorial representation of one of the representative  
23 assemblies.

24 We looked at all the individual assembly  
25 types in the core. We actually depleted them

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 individually, looked at all the relevant branch cases  
2 in order to give us a modeling capability to do  
3 calculations full spectrum for all the AOO anticipated  
4 situations.

5 And this is also the model we used to do  
6 the RAA simulations, which we will talk about more  
7 tomorrow.

8 So, again, as I said, what we are trying  
9 to do here is we are trying to develop representative  
10 SPND information which we then use to follow on  
11 subsequently to evaluate the effectiveness of the  
12 system trips, I guess what you asked.

13 We looked at two individual transients.  
14 One was a bank withdrawal, and the other was a loss of  
15 feedwater heating. And we picked the points -- what  
16 is key here is that, if I can get back here, the point  
17 here, this is the point where the evaluation of the  
18 individual algorithm takes place. In other words,  
19 this will be talked about later in the subsequent  
20 presentation.

21 But as long as the power in the SPND, I  
22 should say the simulated SPND in this case from PARCS  
23 -- boy, this thing is giving me a fit -- here is used  
24 at the same point as I used it in the algorithm, there  
25 is a one-to-one relationship. So, that is the point

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 of what we are trying to achieve here.

2 And that is really about it that we have  
3 for the model demonstration. Again, we needed to have  
4 information from the representative detectors. And  
5 again, we would have ideally used actual plant data,  
6 but, of course, that doesn't exist.

7 And, then, we looked at the two  
8 transients. One was chosen to give us the radially-  
9 asymmetric conditions, in other words, the rod  
10 withdrawal, and the loss-of-feedwater transient is  
11 basically sort of the global power transient.

12 CHAIRMAN BANERJEE: You have calibrated  
13 the code against rod withdrawals and things, but  
14 against other plants, right?

15 MR. ULSES: Right. We looked at the PARCS  
16 code against multiple examples from the operating  
17 fleet.

18 CHAIRMAN BANERJEE: Sure.

19 MR. ULSES: And I wouldn't expect to see  
20 any real differences here in the EPR in the behavior  
21 of PARCS.

22 So, that's all I have. Okay?

23 CHAIRMAN BANERJEE: I'm glad this thing is  
24 going forward, TRACE and PARCS.

25 MR. LU: Okay. As I mentioned, the reason

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 we want to perform this assessment, to support it, to  
2 fully understand the in-core trips system and, then,  
3 how it really generated at the DNBR trips and the LPD  
4 trips.

5 And the EPR, it is so unique. It has a  
6 very large-sized core, you know, a large number of  
7 bundles, and 14 feet of the axial ends. And the ex-  
8 core detector outside could not really sense  
9 significant change of the inside of the core region,  
10 although you have a significant mandated change. So,  
11 that is the reason we wanted to use this one, as Tony  
12 mentioned.

13 We have realistic calculated three-  
14 dimensional neutron flux from the initial steady-state  
15 to the transient, and which are the two transients  
16 that we mention here. Then, we can calculate what is  
17 exactly happening with the neutron flux, what can be  
18 the simulated SPND responses, and use that neutron  
19 flux and the simulated SPND response to calculate the  
20 timing of the trip, and see whether at the expected  
21 timing of the trip the SPND trains will be able to  
22 produce that trip. And if it does, at least we would  
23 say, okay, we feel comfortable that that concept might  
24 work.

25 And, then, follow the support of all other

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 RAIs, and we will be able to evaluate it as part of  
2 the AOO analysis. Okay. So, that is the purpose of  
3 this part.

4 And actually, Randy Bells and Jose March-  
5 Leuba from Oak Ridge, they did this part of the work,  
6 and I was just being told the contractors were  
7 supporting staff's presentation. So, I am giving the  
8 presentation for them.

9 Okay. All right.

10 CHAIRMAN BANERJEE: They aren't here?  
11 They decided not to make the trip?

12 MR. LU: Well, we will see at the end  
13 point of what we will show you.

14 I think, since you asked that question, I  
15 want to focus on this number. Okay. For rod  
16 withdrawal accident, the expected trip is going to  
17 happen at 20 seconds, and that for loss of feedwater  
18 heater trip, they expected a trip to happen, expect it  
19 to happen at 50 seconds. So, we received other SPND,  
20 received that signal.

21 Okay. All right, a little bit more  
22 detailed information. I think Dr. Jonathan Witter, he  
23 went through this very detailed in the morning. So, I  
24 will just give a summary.

25 Then, there are 72 in-core and self-

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 powered neutron detectors which are going to be used  
2 to generate the trips, and, then, to generate the DNBR  
3 trip and the LPD trip.

4           There is an online algorithm, continuous  
5 running to monitor the hot rod DNBR. Every 100  
6 milliseconds, it performs an online calculation.

7           And that algorithm cannot be very  
8 sophisticated because you require so much computing,  
9 and then you cannot perform online and subchannel  
10 analysis. Therefore, that part of the algorithm was  
11 simplified with a 95/95 uncertainty band around that  
12 part.

13           And there are 12 strings of the DNBR  
14 string to calculate for release in the rod. So,  
15 therefore, what we want to see is let's see if we have  
16 actual can calculate the three-dimensional neutron  
17 flux. Those are from a steady-state to the transient.

18           Let's see how the aeroball system would generate the  
19 calibration factor using the steady-state, and during  
20 the transient what aspect it will give the responses,  
21 follow the same algorithm.

22           CHAIRMAN BANERJEE: So, going back to that  
23 slide, you say not enough computer power to perform a  
24 detailed sub-channel. What do you mean exactly?

25           MR. LU: Okay. Yes. What I mean is --

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIRMAN BANERJEE: Only online, yes.

2 MR. LU: -- for the sub-channel analysis,  
3 the code, into a trip to perform that on every --

4 CHAIRMAN BANERJEE: A hundred milliseconds  
5 is --

6 MR. LU: Yes, every 100 milliseconds. It  
7 is throughout the entire core. It is almost -- I have  
8 not seen that kind of a code. If it works, it would  
9 be good.

10 Okay. So, that is the reason, and they  
11 simplify that algorithm.

12 CHAIRMAN BANERJEE: But this is single  
13 failures.

14 MR. LU: Yes. I think you are right  
15 there.

16 CHAIRMAN BANERJEE: You can probably do it  
17 on a graphic --

18 MR. LU: Yes, but there is also --  
19 remember, you asked a question about a chi. There is  
20 a quality trip there.

21 CHAIRMAN BANERJEE: Yes.

22 MR. LU: So, once you exceed a certain  
23 limit, you are going to still hit the two phase, but  
24 because of the correlation, the limitations of the  
25 design, they do not want to see that. So, at a

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 certain point they --

2 CHAIRMAN BANERJEE: All bets are off.

3 MR. LU: Exactly.

4 CHAIRMAN BANERJEE: Okay.

5 MR. LU: Exactly.

6 CHAIRMAN BANERJEE: Okay.

7 MR. LU: All right, that is the  
8 background. Then, so what we are doing here, what's  
9 the reason for us to select the feedwater heater trip  
10 because that is a whole core global power check. We  
11 want to see if the entire core has the power going up.

12 Because once you have a feedwater heater trip, the  
13 steam generator, you know, you have different  
14 temperature going through the reactor coolant system.

15 And once the temperature of the coolant coming into  
16 the core, that changes the total power because of  
17 moderator feedback. And, then, that is expected to be  
18 a core-wide power change. Okay?

19 Rod withdrawal will give you localized  
20 neutron flux shape change. So, you see, if you have  
21 this kind of rod withdrawal situation, what is going  
22 to be the localized SPND responses?

23 So, those two transients were selected  
24 just to evaluate that. Okay.

25 The process we followed was Tony ran a

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 steady-state TRACE coupled with PARCS, and once it  
2 reached a steady-state, we used that neutron flux  
3 calculated by PARCS, every node -- I forgot how many  
4 nodes, maybe 23.

5 MR. ULSES: Twenty-four.

6 MR. LU: Twenty-four.

7 CHAIRMAN BANERJEE: What Tony showed as  
8 the map --

9 MR. LU: Yes, but actually there are 24.  
10 So, it is a huge three-dimensional core model. And  
11 with that one, we can calculate the actual aeroball  
12 system, the neutron flux will be assessed by the  
13 aeroball system.

14 And you use that neutron flux to determine  
15 the SPND calibration factor, what we call the C ij  
16 parameters. And more detail was actually given this  
17 morning.

18 And we use that one. And actually, Jose  
19 March-Leuba did this calculation, figured out this is  
20 the C ij number for each of the 72 SPNDs. And once  
21 that is fixed, then follow the TRACE three-dimensional  
22 power during the transient and calculated the SPND  
23 responses using the same algorithm defined by the  
24 setpoint and methodology, and using that one to see  
25 whether all 72 SPNDs would trigger the trip. That is

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 the calculation process.

2 So, what the endpoint is, we valued,  
3 calculated it for hot rod what's the DNBR and what's  
4 the maximum medium power density.

5 Okay. Here is the calculated number.  
6 Okay. There are 12 strings for DNBR calculation.  
7 Each string has six SPND axial directions. And you  
8 can see that the critical heat flux ratio is  
9 calculated based on we know the power, based on PARCS  
10 calculation, and we also applied the approved AREVA's,  
11 the CHF correlation for that bundle. And we  
12 calculated what is the limiting minimum DNBR.

13 CHAIRMAN BANERJEE: This is a loss of --

14 MR. LU: That is a loss-of-feedwater  
15 heater event.

16 CHAIRMAN BANERJEE: Feedwater --

17 MR. LU: Right.

18 CHAIRMAN BANERJEE: -- heater?

19 MR. LU: Yes. I think it was at 50  
20 seconds, right. At 50 seconds, you can see that,  
21 except for one string, all other strings predicted the  
22 DNBR less than what is actually for the hot boulder  
23 what it should be.

24 Because of that, if there is a trip  
25 setpoint set low enough at this point, all 12 strings

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 except one will start the generator trips.

2 So, this plot just confirmed that, based  
3 on TRACE/PARCS evaluation calculation, and, then, with  
4 SPND in-core, self-powered neutron detector, if the  
5 algorithm and the hardware works, the trip will be  
6 generated.

7 CHAIRMAN BANERJEE: Where is the setting  
8 there?

9 MR. LU: Okay. This is a snapshot --

10 CHAIRMAN BANERJEE: Yes.

11 MR. LU: -- of the calculated DNBR at 50  
12 seconds. So, that is expanded at a time the trip is  
13 supposed to come in. Because of all the calculated  
14 DNBR, at this point it is lower than the actual one.  
15 So, we know that the --

16 CHAIRMAN BANERJEE: The trip is supposed  
17 to come at this point.

18 MR. LU: Exactly.

19 CHAIRMAN BANERJEE: Yes. Okay.

20 MR. LU: Exactly. So, therefore, this  
21 algorithm itself we found, at least based on this  
22 simulation, appears to work. Of course, to make this  
23 algorithm and the in-core trips functional, and it  
24 still relies on the hardware, so the Division of  
25 Engineering and the Regional INCs are evaluating

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 whether we can really achieve the signal. However,  
2 from the reactor system perspective, the algorithm, we  
3 verified it looks like it appeared to work.

4 Okay. The next one, for rod withdrawal, a  
5 similar situation. Actually, this is much better than  
6 because all 12 strings show the DNBR are less than the  
7 calculated, the minimum DNBR.

8 And that means, at 20 seconds for this  
9 particular event --

10 CHAIRMAN BANERJEE: This is the 20  
11 seconds, right?

12 MR. LU: Yes, this is 20 seconds for a rod  
13 withdrawal event. Okay.

14 And, then, there is the calculated SPND  
15 power change. During rod withdrawal, for rod  
16 withdrawal, we were trying to catch the localized  
17 power peaking change. And you can see that each one  
18 is the string, a number, and then tells you at time  
19 zero it is blue. At 20 seconds, the trip, and the  
20 control is supposed to be dropped at that time. And  
21 you can see that the purple one, the power change for  
22 one of this string, you can see almost doubled. This  
23 one is increased, but the rest of the stuff --

24 CHAIRMAN BANERJEE: Going down.

25 MR. LU: Yes, going downward. What it

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 really gives us, the confidence here is, okay, with a  
2 significant localized power peaking factor change, the  
3 calculated DNBR still will trigger the trips. That  
4 verifies the algorithm for us to see whether for AOO  
5 application is that okay or not, when they take the  
6 credit of this --

7 CHAIRMAN BANERJEE: So, explain to me how  
8 that previous slide with those red and blue lines, the  
9 bar chart that you had --

10 MR. LU: The bar chart?

11 CHAIRMAN BANERJEE: Yes. That shows me  
12 which --

13 MR. LU: That is the radial power peaking  
14 factor.

15 CHAIRMAN BANERJEE: In D13, DO3 goes up,  
16 but --

17 MR. LU: Yes.

18 CHAIRMAN BANERJEE: -- how does it tell me  
19 that I'm okay?

20 MR. LU: Okay. What really it gives you,  
21 each SPND, certain neutron flux.

22 CHAIRMAN BANERJEE: Yes.

23 MR. LU: And this neutron flux was  
24 translated to how can it not be exactly the same  
25 magnitude. So, there is a calibration factor to

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 calibrate that neutron, measure in a sense the signal,  
2 to translate that to what is the exactly predicted hot  
3 rod power density, medium power density there and the  
4 neutron flux there.

5 And, then, the algorithm, based on these  
6 responses throughout the entire core -- so, the  
7 concept is just like R jump (Phonetic) function. You  
8 have the function, and it gives a certain contribution  
9 to a certain point. And from a certain point, you can  
10 look at every single assembly; the neutron flux level  
11 will give you a different weighting for your  
12 contribution for that power level at that particular  
13 point.

14 With that one, that demonstrates that this  
15 algorithm would function to graph the localized change  
16 in the power shape to produce the DNBR and the LPD.

17 CHAIRMAN BANERJEE: Yes, it sort of shows  
18 you what these SPNDs are seeing there.

19 MR. LU: Yes, the change. Yes.

20 CHAIRMAN BANERJEE: But it is really the  
21 previous graph that shows you that.

22 MR. LU: Exactly. Yes, yes. Actually,  
23 those two, the DNBR trip --

24 CHAIRMAN BANERJEE: Yes.

25 MR. LU: -- were calculated. But this

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 just shows you the power shape change.

2 CHAIRMAN BANERJEE: Yes.

3 MR. LU: So, that gives you, gave us a  
4 feeling of what is exactly the localized power change.

5 Otherwise, we would use three-dimensional graphics to  
6 show the core power change, but that is a little bit  
7 too hard. But maybe tomorrow you can see some  
8 pictures of it.

9 CHAIRMAN BANERJEE: Maybe some nice  
10 animation.

11 MR. LU: Yes. I think Tony generated  
12 that, right?

13 CHAIRMAN BANERJEE: If I give a talk to  
14 students, I have to show them animation or else they  
15 go to sleep.

16 (Laughter.)

17 MR. LU: I think we need to provide that  
18 one.

19 CHAIRMAN BANERJEE: Yes, to keep us awake.

20 MR. LU: But we have to double-check AREVA  
21 and make sure that is not proprietary information.

22 CHAIRMAN BANERJEE: We can always close  
23 the session.

24 (Laughter.)

25 MR. LU: Okay. All right, let's give you

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 this LPD confirmatory calculation for loss of  
2 feedwater heater event. And you can see the blue line  
3 is the actual, the measure calculated with PARCS,  
4 actual power shape. And not only just the power  
5 shape, but it is the actual megawatts for each node.

6 And, then, for all 12 strings, what is  
7 really calculated there, for each point, what is the  
8 calculated medium power density from all 12 strings,  
9 contributed to each axial node?

10 Okay. Then, what it really tells you is,  
11 at 50 seconds, the calculated, the algorithm itself  
12 would predict higher than actual the power density.  
13 Because of that, if the SPND started to trip, it would  
14 be conservative.

15 CHAIRMAN BANERJEE: So, D13 systematically  
16 shows --

17 MR. LU: Yes, D13 is a string of the  
18 SPNDs. There is core map there to show what is the  
19 range.

20 CHAIRMAN BANERJEE: Yes.

21 MR. LU: D13 there.

22 CHAIRMAN BANERJEE: D13 and P15.

23 MR. LU: Yes.

24 CHAIRMAN BANERJEE: Yes.

25 MR. LU: It is just there are a total of

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 12 strings. Each string of the SPND, inside the core  
2 there is six of them. And, then, with that one, that  
3 will give you a number. This plot, it just shows you  
4 how the SPND calculates the localized power peaking  
5 factor, the localized power density.

6 Because of that, there are so many numbers  
7 of the SPND strings; it predicts the higher power  
8 density. The demonstrated algorithm itself is  
9 conservative.

10 CHAIRMAN BANERJEE: Yes.

11 MR. LU: At least for this particular  
12 case, TRACE and PARCS.

13 The same situation for rod withdrawal  
14 event. Most of the strings would predict a higher  
15 medium power density. So, all those reach the actual  
16 setpoints. That means the actual power density is  
17 lower than the setpoints.

18 CHAIRMAN BANERJEE: Boy, that is a pretty  
19 big deviation.

20 MR. LU: Quite big. Quite big.

21 So, the way they developed this one,  
22 although even this, it is a big, but it still will be  
23 sufficient to protect the core, from our  
24 understanding. But, of course, it has to be realized  
25 by the hardware system itself.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1           So, what really we learned from here is we  
2 felt that the algorithm should work, but the actual  
3 configuration, the actual system hardware needs to be  
4 tested. So, based on this calculation, we actually  
5 requested an additional ITAAC item.

6           Not only just we are relying on the  
7 TRACE/PARCS to give us information, but we use this  
8 information to tell us how we are going to pursue this  
9 review and close this issue. As part of the ITAAC, we  
10 asked AREVA to demonstrate and test the entire system,  
11 once it is a completed design and installed, to verify  
12 that it can do this job it is supposed to do.

13           Okay. All right. So, that is the results  
14 evaluation. What we found is that the EPR protection  
15 system using signals from in-core SPNDs should be able  
16 to generate a reactor trip.

17           And as part of the topical report of  
18 setpoint methodology, we have issued a Draft SER. And  
19 I think a final will be issued sometime down the road.

20           At this point, we feel comfortable that this  
21 algorithm should work.

22           The conclusion, I just want to give this  
23 slide as a conclusion. We used confirmatory analysis  
24 to help us generate useful information, so that we can  
25 ask the right RAIs and quantify the margins, possible

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 margins, with certain RAIs, so that we can have  
2 targeted RAIs, that we focus on the issues which are  
3 significant safety issues, if we needed to evaluate  
4 that part.

5 I think this, the confirmatory analysis,  
6 developed by the tools, developed by the Office of  
7 Research, TRACE/PARCS, and the analysis done by Tony  
8 really helped us to move forward and focus on the  
9 right issue and the result. I think that is the  
10 conclusion related to the overall staff's review of  
11 the Chapter 15 anticipated occurrence of transient,  
12 operation occurs, and the postulated accidents, and  
13 how we concluded our Phase 2 review with this process  
14 to help us out.

15 And as I mentioned right at the beginning,  
16 our review is just Phase 2. We are giving you a  
17 status of Phase 2 review conclusions. It is not a  
18 final DCD conclusion yet. So, if there are any  
19 questions or there is any new information coming, we  
20 will process that in the review.

21 CHAIRMAN BANERJEE: Thank you. That was  
22 illuminating.

23 Bill, do you have any questions? Or John?

24 MEMBER STETKAR: No, sir.

25 CHAIRMAN BANERJEE: Okay. So, I think we

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 are probably finished for today with you, and we will  
2 have AREVA back now briefly. But thank you very much.

3 We really appreciate this and we look forward to  
4 seeing some subset of you tomorrow on the rod  
5 ejection.

6 So, tomorrow we are going to talk about  
7 rod ejection and just be briefed on certain topics by  
8 AREVA.

9 MS. SLOAN: Certain small-break LOCA  
10 topics.

11 CHAIRMAN BANERJEE: Yes. Some topics.  
12 But the staff won't say anything.

13 MR. TESHAYE: Not in the afternoon. In  
14 the morning, we will have our --

15 CHAIRMAN BANERJEE: No, only in the  
16 morning.

17 MR. TESHAYE: Yes.

18 CHAIRMAN BANERJEE: Yes. Okay.

19 So, thanks a lot. We will see you  
20 tomorrow.

21 So, it is back to you, Sandra, and we are  
22 actually running ahead of schedule, which I think is  
23 wonderful. I like that.

24 PARTICIPANT: This design center, we have  
25 been usually running ahead of schedule in the ACRS

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 meetings. And I don't have an explanation why, except  
2 maybe we have done a lot of work in preparation, the  
3 staff has.

4 CHAIRMAN BANERJEE: Right.

5 PARTICIPANT: So, we all, the NRC staff,  
6 will take credit for that.

7 (Laughter.)

8 CHAIRMAN BANERJEE: Yes. It is an  
9 efficient sort of operation.

10 So, Pedro, you are going to take off for  
11 some distant land, I understand.

12 MR. PEREZ: Correct.

13 CHAIRMAN BANERJEE: Tell us what you have  
14 to before you do that.

15 MR. PEREZ: This is Pedro Perez. I'm  
16 back, and now it is good afternoon.

17 Back in April, Getachew mentioned that  
18 AREVA took a set of homework questions concerning the  
19 radioactive waste cleanup system. The System Engineer  
20 at that time, Mr. Craig Schmiesing, went back to the  
21 office and researched everything. He is now working  
22 in Finland at the Olkiluoto site. So, he can really  
23 learn his system.

24 But he left behind the answers to those  
25 questions, and I would like to go over them for the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 record. And again, this goes back to April of 2010.

2 The following questions were asked:

3 "What is the reliability of the evaporator  
4 and centrifuge? How often is the equipment  
5 maintained?"

6 The major equipment of the evaporator is  
7 known to exist without major maintenance for roughly  
8 two to four years, depending on frequency of use.  
9 Minor maintenance, such as pump seal replacement, can  
10 be done while the system is online because of the  
11 infrequent flow through the system. This regular  
12 maintenance helps to prolong the life of the  
13 equipment.

14 MEMBER STETKAR: Pedro, I'm sorry. Could  
15 you repeat that? I was looking for -- I know I asked  
16 this question --

17 MR. PEREZ: Yes.

18 MEMBER STETKAR: -- but I couldn't find  
19 it. So, could you repeat that, so I can make a couple  
20 of notes here?

21 CHAIRMAN BANERJEE: You don't have it  
22 documented in a slide or something that we can have?

23 MR. PEREZ: We can do it tonight and have  
24 it ready for tomorrow.

25 CHAIRMAN BANERJEE: Yes, just for the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 record.

2 MS. SLOAN: We can get copies. We will  
3 send it to Derek.

4 CHAIRMAN BANERJEE: Yes. As long as we  
5 have it --

6 MS. SLOAN: This is an internal calc file.  
7 We will get the information available, and we will  
8 send it to Derek.

9 CHAIRMAN BANERJEE: I mean it goes into  
10 the record in the transcripts, but we may as well have  
11 it.

12 MS. SLOAN: Sure.

13 CHAIRMAN BANERJEE: Also, it is not my  
14 area of expertise. So, I am going to sort of need to  
15 give this to Dana.

16 MR. PEREZ: I'll repeat --

17 MEMBER STETKAR: Thanks.

18 MR. PEREZ: -- the answer to that question  
19 about the reliability of the evaporator and  
20 centrifuge.

21 And the answer was the major equipment of  
22 the evaporator is known to exist without major  
23 maintenance for roughly two to four years, depending  
24 on the frequency of use. Minor maintenance, such as  
25 pump seal replacement, can be done when the system is

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 online because of the infrequent flow through the  
2 system. This regular maintenance helps to prolong the  
3 life of the equipment.

4 And this was obtained by our office in  
5 Germany, talking to those users with that equipment.

6 The second question was: "What is the  
7 water content of the sludge coming out of the  
8 decanter?"

9 The water content of the sludge from the  
10 centrifuge is approximately 30 percent by volume. If  
11 the water content is less than 30 percent, the drum is  
12 sealed and brought to the drum storage area. If the  
13 water content is greater than 30 percent, the drum is  
14 brought to the drum drying station of the solid waste  
15 processing system to process prior to it being stored  
16 in the drum storage area.

17 The third question: "What storage  
18 capacity volume was generated using the 7.5-year  
19 storage value?"

20 The 7.5-year storage capacity was  
21 determined using the volumes documented in the FSAR  
22 Tier 2, Table 11.4-1.

23 "Is there a buried pipe in the run from  
24 the containment to the radioactive waste processing  
25 building?"

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1           The only system that may have buried pipe  
2           is the nuclear island drain and vent system. Any  
3           buried piping will be guard-piped with means to detect  
4           leakage or in trenches, such that it can be maintained  
5           or replaced as necessary. Radiation or leak detection  
6           monitors will be placed to aid in locating any  
7           leakages in the system.

8           "What are the hydrogen and oxygen  
9           concentrations prior to reaching the gaseous rad waste  
10          system?"

11          The normal expected concentrations of  
12          hydrogen and oxygen is dependent upon operational  
13          states of the connected system. For example, cooling  
14          treatment or cooling the gasification system. While  
15          one of these systems is in operation, the  
16          hydrogen/oxygen concentrations will vary depending on  
17          primary coolant chemistry and plant operational  
18          status. For example, typical hydrogen concentration  
19          during normal operation, while the coolant treatment  
20          system boric acid column is in operation, is  
21          approximately 1.5 percent by volume. Typical hydrogen  
22          concentration during outage preparation and while  
23          cooling the gasification system, the gasifier column  
24          is in operation, is approximately 2 percent by volume.

25          And, then, the final question was: "How

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 do the air-operated valves in the gaseous waste  
2 processing system fail on loss of compressed  
3 instrument air? And the main concern is the  
4 consequences of valve closure around the recombiner."

5 Two quick closing pneumatically-actuated  
6 valves mounted upstream and downstream of the  
7 recombiner provide for isolation of the recombiner. A  
8 third quick opening pneumatically-actuated valve  
9 allows for bypass of the recombiner. The isolation  
10 valves will fail closed on loss of air supply, and the  
11 bypass valve will fail open. There is a quick-closing  
12 pneumatically-actuated valve installed on the hydrogen  
13 and oxygen supply lines. Both valves will fail closed  
14 on loss of supply air.

15 Those are the six.

16 MEMBER STETKAR: So, if I lose air, I wind  
17 up isolating the -- I was writing notes. The hydrogen  
18 and oxygen supply lines fail closed on loss of air?

19 MR. PEREZ: Yes. There is a quick-closing  
20 pneumatically-actuated valve installed on the hydrogen  
21 and oxygen supply lines. Both valves will fail closed  
22 on loss of air supply.

23 MEMBER STETKAR: Okay. I will have to go.

24 Thanks.

25 MR. PEREZ: And, then, this morning while

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 we were talking about the steam generator tube  
2 rupture, I took two items with me. One was to confirm  
3 how long we were steaming the generator with a tube  
4 rupture.

5 FSAR Tier 2, Table 15.0.24, Revision 2,  
6 shows that we steam the generator for 13.8 minutes,  
7 13.8 minutes.

8 MEMBER STETKAR: Now, okay, and that is  
9 the time that you used in your radiological --

10 MR. PEREZ: Yes.

11 MEMBER STETKAR: -- calculation? That is  
12 the time from reactor trip until the MSR isolation  
13 valve is closed, accounting for the one-minute closure  
14 time?

15 MR. PEREZ: Yes. Yes.

16 MEMBER STETKAR: Okay, but does it make  
17 any difference to your radiological calculation  
18 whether you are steaming -- no, it shouldn't  
19 -- whether you are steaming or whether the control  
20 valve has failed open? No, it's flow rate.

21 MR. PEREZ: It is flow rate.

22 MEMBER STETKAR: So, it shouldn't.

23 MR. PEREZ: Right. We track the mass.

24 MEMBER STETKAR: Okay. I still have a  
25 question about it. So, your calculations uses 13.8

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 minutes for the atmospheric release?

2 MR. PEREZ: Directly from that generator.

3 MEMBER STETKAR: Yes. I still have a  
4 question for the scenario I developed, whether that  
5 13.8 minutes you used, which is longer than I thought  
6 you were using --

7 MR. PEREZ: Right.

8 MEMBER STETKAR: - whether that still  
9 bounds the release that might come from an earlier  
10 automatic reactor trip with normal operation of the  
11 safety injection system and the cooldown, later  
12 accounting for manual isolation of that steam  
13 generator, of the isolation valve on that steam  
14 generator.

15 I can see how the steam generator  
16 automatic isolation signal will come in to close the  
17 MSIV, but it is not clear to me that that is going to  
18 stop the release until 30 minutes. So, if for some  
19 reason we start the release more than, let's see,  
20 earlier than -- I can't do the math in my head -- 16.2  
21 minutes into the event, you might get a longer release  
22 from my scenario than yours.

23 MR. PEREZ: And your scenario was  
24 through --

25 MEMBER STETKAR: My scenario was no CVCS.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. PEREZ: Right.

2 MEMBER STETKAR: Say no makeup. Let the  
3 reactor trip automatically on low pressurizer  
4 pressure, whenever that occurs -- I don't know when  
5 that occurs. At that time, you lose offsite power, at  
6 which time you start steaming.

7 MR. PEREZ: Okay.

8 MEMBER STETKAR: And, then, the question  
9 is, do you remain steaming from that steam generator  
10 until the operators actively close the main steam  
11 relief isolation valve? I don't think it is that  
12 simple because I think in automatic the thing actually  
13 might cycle. You reset the setpoint higher. You will  
14 get to the setpoint at the same time you are trying to  
15 blow down the steam generator, which should  
16 depressurize it. I am assuming it is going to close;  
17 the pressure is going to go back up again.

18 So, I am not quite sure what the transient  
19 looks like. But if you start steaming early enough --  
20 it is getting late in the day for me to do the math in  
21 my head -- and if you don't positively isolate that  
22 steam generator to stop the steaming until 30 minutes  
23 plus whatever nominal time is when the operators can  
24 actively intervene, if that duration is longer than  
25 the 13.8 minutes that you used in your calculation,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 the actual offsite releases might be higher.

2 MR. PEREZ: Yes.

3 MEMBER STETKAR: That was my concern. I  
4 just don't have any sense whatsoever of what the  
5 timing of that other scenario looks like, but I think  
6 AREVA said you ran that scenario.

7 MS. SLOAN: Yes.

8 MEMBER STETKAR: So, it should be  
9 available somewhere.

10 MS. SLOAN: Yes. We will take a follow-  
11 up, John.

12 MEMBER STETKAR: Yes. But thanks. You  
13 have at least clarified they used 13.8 minutes instead  
14 of 2 minutes.

15 MR. PEREZ: Right. And, then, the last  
16 item that I took was concerning the letdown, whether  
17 we credited filtration or not. And we went back to  
18 our calculation, and it turns out it really doesn't  
19 matter because the water is cooled prior to leaving  
20 the reactor building. So, you do not have iodine  
21 flashing. You are basically releasing noble gases.

22 The other event with the sample line that  
23 is only a quarter inch, that receives no cooling and  
24 you get iodine flashing. That is why that becomes a  
25 limiting event.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 MEMBER STETKAR: So, in effect, what you  
2 are saying is, although at least the SER seems to  
3 place some emphasis on the purification system and the  
4 filtering, that is essentially irrelevant.

5 MR. PEREZ: Correct.

6 MEMBER STETKAR: It is all the temperature  
7 of the release.

8 MR. PEREZ: Correct.

9 MEMBER STETKAR: Okay.

10 MR. PEREZ: Correct.

11 MEMBER STETKAR: Thanks. That makes  
12 sense.

13 MR. PEREZ: Okay. That concludes what I  
14 had.

15 MS. SLOAN: Thank you.

16 MR. PEREZ: Okay. Thank you very much.

17 CHAIRMAN BANERJEE: Thank you very much.

18 I think what I will do now is to ask the  
19 members if they have any comments or questions that  
20 they would like to make today.

21 MEMBER STETKAR: No.

22 CHAIRMAN BANERJEE: Tomorrow I am sure we  
23 will.

24 John, do you have anything?

25 MEMBER STETKAR: No. Thank you.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIRMAN BANERJEE: So, I think we can  
2 probably break and we will reassemble tomorrow morning  
3 at 8:30 and take up the rod ejection.

4 Will you lead off that? Yes, I imagine,  
5 yes.

6 MS. SLOAN: Yes. Yes, AREVA leads, then  
7 the staff, and then we go to the small-break LOCA.

8 CHAIRMAN BANERJEE: Then we go back to the  
9 small-break after lunch.

10 MS. SLOAN: Yes.

11 CHAIRMAN BANERJEE: Okay. So, with that,  
12 we will break.

13 Thank you very much. They were very good  
14 presentations, very informative. Thanks.

15 (Whereupon, at 4:28 p.m., the foregoing  
16 matter was adjourned.)  
17  
18  
19  
20  
21  
22  
23  
24  
25

**NEAL R. GROSS**


COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)



**Presentation to ACRS  
U.S. EPR Subcommittee  
Design Certification  
Application  
FSAR Tier 2 Chapter 15  
(excluding Section 15.6.5)**




# Chapter 15 ACRS Meeting Agenda

- ▶ Overview of Unique U.S. EPR Features
- ▶ Trip Functions
- ▶ Overview of In-Core Transient Methodology
- ▶ Chapter 15 Event Evaluation
- ▶ Radiological Evaluation
- ▶ SGTR Mitigation Strategy

Douglas Brownson  
Jonathan Witter  
Jonathan Witter  
Douglas Brownson  
Pedro Perez  
Kenneth Coffey


# Overview of Unique U.S. EPR Design Features Important to Safety Analysis



Douglas Brownson  
Supervisory Engineer, Non-LOCA Analysis



# Reactor Coolant System




- ▶ Conventional 4-loop PWR design, proven by decades of design, licensing & operating experience
- ▶ NSSS component volumes larger compared to existing PWRs; increases operator grace period for many transients and accidents

# Plant Parameter Comparison

Parameter	Current US 4-Loop	Palo Verde	U.S. EPR
Thermal Power, MWth	3411	3998	4590
Electrical Power (Net), MWe	1120	1314	1600
Plant Efficiency, Percent	33	33	35
Number of Fuel Assemblies	193	241	241
Hot Leg Temperature, °F	616	620	624
Cold Leg Temperature, °F	559	558	564
Vessel Average Temperature, °F	588	589	594
Primary System Operating Pressure, psia	2250	2250	2250
Reactor Coolant Flow per Loop, gpm	100,500	111,000	125,000
Average Coolant Flow per Assembly, gpm	2083	1842	2075
Core Average Linear Heat Rate, kW/ft	5.6	5.6	5.2
Peak Linear Heat Rate, kW/ft	14.5	14.6	13.6

***Core design parameters similar to current operating plants***


# Unique Safety Related Systems and Features



- ▶ **Four train front line safety systems**
- ▶ **Automatic partial cooldown of steam generators (SGs) on safety injection system (SIS) actuation signal**
- ▶ **Automatic trip of reactor coolant pumps (RCPs) on coincident SIS actuation signal and low delta-pressure across the pumps**
- ▶ **Low DNBR and High Linear Power Density (LPD) trip functions using incore measurements of local core power distributions**
- ▶ **In-Containment Refueling Water Storage Tank (IRWST)**
  - ◆ **Source of emergency core cooling system (ECCS) water**
  - ◆ **No switchover needed to external water source**
- ▶ **Extra Borating System (EBS)**
- ▶ **Safety-related alarm on high activity in steam lines (SGTR)**
- ▶ **Steam generator blowdown / transfer line**

# Main Steam Relief Train (MSRT) Operation

- ▶ Four train, safety-related system (one per SG)
- ▶ MSRT provides two functions:
  - ◆ Overpressure protection
  - ◆ Depressurizes SGs automatically on SIS actuation signal
    - Depressurization rate equivalent to 180 F/hr ( $T_{sat}$ )
    - Ensures adequate medium head safety injection (MHSI) flow for SBLOCA & SGTR
    - For SGTR, re-set high in affected SG to prevent relief




# U.S. EPR Trip Functions

Jonathan Witter, Ph.D.  
Advisory Engineer, Core Thermal Hydraulics



# Protection System Functions - Instrumentation




I&C sensors used in the Protection System

# Protection System Functions – Core Related


▶ High Core Power Level (Loop TH enthalpy based)	105% ( 10.2%)
▶ Low Hot Leg Saturation Margin (Loop TH enthalpy based)	30 BTU/lbm
▶ High Neutron Flux Rate of Change (PRD)	11% ( 2%)
▶ High Neutron Flux (IRD)	25% ( 10%)
▶ Low Doubling Time (IRD)	20 s (±10 s)
▶ Linear Power Density (SPND)	
◆ Limiting Condition for Operation	385/350 W/cm
◆ High Linear Power Density RT ( 2 <sup>nd</sup> Max)	460 W/cm
▶ Low DNBR (SPND and Loop TH inputs)	
◆ Limiting Condition for Operation	2.50
◆ Symmetric RT (2 <sup>nd</sup> Min)	1.95
◆ Imbalance/Rod Drop ¼ Division (1 <sup>st</sup> Min)	2.10
◆ Rod Drop ≥2/4 Division (1 <sup>st</sup> Min)	3.30
▶ Anti Boron Dilution CVCS Isolation	
◆ At power condition	Function of burnup
◆ In standard shutdown states	Function of burnup and temperature
◆ In shutdown with no RCPs running	927 ppm (37 a/o B-10)

# Protection System Functions – RCS Related




▶ Low-Low RCS Flow Rate (one loop)	54% ( 4%)
▶ Low RCS Flow Rate ( $\geq$ two loops)	90% ( 4%)
▶ Low RCP Speed	93% ( 1%)
▶ Low Hot Leg Pressure	2005 psia ( 45 psi)
▶ High Pressurizer Water Level	75% ( 5.5%)
▶ High Pressurizer Pressure	2414.7 psia ( 25 psi)
▶ Low Pressurizer Pressure	2005 psia ( 25 psi)
▶ High Containment Pressure	4.0 psig ( $\pm$ 0.5 psi)

# Protection System Functions – Secondary System Related



- ▶ **Low Steam Generator Pressure**                      **724.7 psia ( $\pm$  30 psi)**
- ▶ **High Steam Generator Pressure**                      **1384.7 psia ( $\pm$  30 psi)**
- ▶ **Low Steam Generator Level**                      **20% ( $\pm$  3.5%)**
- ▶ **High Steam Generator Level**                      **69% ( $\pm$  9.5%)**
- ▶ **High Steam Generator Pressure Drop**
  - ◆ **{(-29 psi/min) .OR. (102 psi < steady state) .AND. (Maximum of 1088 psia)}**

# Principles of High Core Power Level and Low Saturation Margin Functions



## ▶ High Core Power Level (HCPL)

- ◆ Calculates a core power in each loop based on cold and hot leg temperatures and hot leg pressure
- ◆ Reactor trip (RT) initiated once 2/4 loops indicate power above the RT threshold
  - Main purpose is to serve as backup trip for overcooling and RCCA withdrawal events and to limit power to analyses inputs for the incore SPND based trips.

## ▶ Low Saturation Margin

- ◆ Calculates an enthalpy margin to saturated coolant conditions in each loop using the temperature and pressure of the hot leg
- ◆ RT initiated once 2/4 loops indicate margin less than the RT threshold
  - Main purpose is to protect the validity of the calculation of the HCPL


# Principles of Anti Boron Dilution CVCS Isolation Function

- ▶ Continuous boron concentration monitoring on charging line
- ▶ Mitigates boron dilution event by isolating the charging pump suction from the volume control tank

## ▶ Setpoints

- ◆ At Power is set for an inlet temperature and are updated at periodic burnups
- ◆ In Standard Shutdown is a function of temperature updated at periodic burnups
- ◆ In Shutdown with no RCPs running, fixed value based on IRWST concentration

Boron Concentration Setpoint for CVCS Isolation (Example)




**CVCS isolation stops boron dilutions with adequate time to maintain shutdown margin at power and prevent inadvertent criticality in shutdown conditions**

# Measuring, Instead of Inferring, the 3D Core Power Distribution

## ► Excoring neutron detectors

- ◆ Monitors periphery of core
- ◆ Coarse axial power shape resolution
- ◆ Use of control rod positions to provide inferred core internal power



## ► Incore detector system



- ◆ Monitors local power
- ◆ Directly measure radial and axial power distribution effects

Real time resolution of LPD distribution uses 3D array of the 72 SPND readings

# Principles of SPND Calibration for Low DNBR Function

## ► DNB Ratio Monitoring (one PS division)


- ◆ Each of the 12 SPND strings is calibrated to indicate the LPD axial distribution of the DNBR limiting “hot channel”
- ◆ Uses the 6 elevations to reconstruct the power shape/enthalpy rise
- ◆ DNBR estimated using reconstructed power distribution and thermal hydraulic boundary conditions from each RCS loop
- ◆ 12 readings ranked and compared to RT thresholds



**Single calibration gives conservative measure of non-limiting locations. Changes from the calibrated state are seen from the limiting location condition**

# Principles of SPND Calibration for High Linear Power Density (LPD) Function


- ▶ At the time of calibration with the AMS flux measurement, the “hot spot” in each axial zone is determined
- ▶ All 12 SPNDs in an axial elevation are calibrated to read the maximum heating rate in that coverage zone
- ▶ Conservative approach since zones away from hot spot will respond as if they were the hot spot
  - ◆ Global power, rod influence, xenon transient, etc.
- ▶ All SPNDs readings are ranked and compared to the RT threshold
  - ◆ RT setpoint is conservatively lowered based on the number of failed SPNDs to cover the reduced accuracy in the resolution of the LPD measurement




**Single point calibration is conservative and more tolerant to SPND failures and facilitates the resolution of power asymmetries**

# Results of the Ability to Directly Measure Power Shape Changes


- ▶ The array of SPNDs are used to respond to radial and axial shape redistributions regardless of event symmetry
- ▶ Can resolve movement of the incore hot spot induced from rods, flow, Xe, etc.
- ▶ If imbalance is significant enough, it will trigger use of a more conservative trip threshold for MDNBR Protection (Imbalance/RD(1/4) and RD(2/4) RTs)



Calibration  
State, 8.6 kW/ft



Rod J-09 Drop - Symmetric




Rod N-07 Drop - Asymmetric

# Overview of the U.S. EPR Incore Transient Methodology


Jonathan Witter, Ph.D.  
Advisory Engineer, Core Thermal Hydraulics



# Incore Monitoring Reactor Trip Evaluation




# MDNBR Undershoot Assessment from FSAR 15.1.3 Increase in Steam Flow Event



**Criterion for success is that the uncompensated static MDNBR does not violate the setpoint**


# LPD Overshoot Assessment from FSAR 15.4.2 Uncontrolled Bank Withdrawal Event



**Criterion for success is that the uncompensated static LPD does not violate the setpoint**


# Broad Spectrum of Trip Times Demonstrate Protection of SAFDLs and Plant Systems

## ▶ Example Transient Incore PS Simulation for Uncontrolled Bank Withdrawal from HFP



- ▶ Spectrum of S-RELAP5 simulations for reactivity addition
- ▶ Several thousand axial power shapes
- ▶ Multiple initial  $F\Delta H$ 's
- ▶ Validated all of the predicted incore trips


# Broad Spectrum of Trip Times Demonstrate Protection of SAFDLs and Plant



- ▶ Each event analyzed results in a spectrum of times for reactor trip based on incore SPND monitoring (thousands of renditions)
- ▶ The shortest time to trip and highest rate of signal change are most adverse for MDNBR undershoot and LPD overshoot
  - ◆ The LCO's for MDNBR and LPD are specified to protect the SAFDL in the events that are too fast or severe to be covered with the incore monitoring system
- ▶ Some combinations of 3D power shapes, initial conditions, and magnitude of the plant transient result in no trip demanded by the incore system
  - ◆ For cases not exceeding the incore reactor trip threshold, other plant trips will terminate the event if required

**All Chapter 15 non-LOCA AOO events demonstrate adequate protection**

# SAFDL Events Protected by the Incore SPND-based Reactor Trips



- ▶ SRP 15.1.1 Decrease in feedwater temperature (DNB)
- ▶ SRP 15.1.2 Increase in feedwater flow (DNB)
- ▶ SRP 15.1.3 Increase in steam flow (DNB/LPD)
- ▶ SRP 15.1.4 Inadvertent opening of a steam generator relief or safety valve (DNB)
- ▶ SRP 15.4.2 Uncontrolled control rod assembly withdrawal at power (DNB/LPD)
- ▶ SRP 15.4.3 Control rod misoperation (DNB/LPD)
- ▶ SRP 15.4.6 Inadvertent decrease in boron concentration in RCS (DNB/LPD)
- ▶ SRP 15.6.1 Inadvertent opening of a pressurizer relief or safety valve (DNB/LPD)

**All events demonstrate the adequacy of the dynamic compensation on the trips**

# SAFDL Events Protected by Other System Trips and the DNBR or LPD LCOs

- ▶ **SRP 15.1.3 Increase in steam flow (DNB/LPD)**
  - ◆ *High SG Pressure Drop*
- ▶ **SRP 15.3.1 Loss of forced reactor coolant flow (partial loss) (DNB)**
  - ◆ *Bounded by the full loss of forced RCP flow*
- ▶ **SRP 15.3.2 Loss of forced reactor coolant flow (full loss)**
  - ◆ *DNB event that sets the DNBR LCO to ensure adequate protection*
- ▶ **SRP 15.4.2 Uncontrolled control rod assembly withdrawal at power (DNB/LPD)**
  - ◆ *High Core Power Level Trip and LCO's*
- ▶ **SRP 15.4.1 Uncontrolled control rod assembly withdrawal from a subcritical or low power startup condition (DNB/LPD)**
  - ◆ *High Neutron Flux Rate of Change Trip terminates the event*
- ▶ **SRP 15.4.8 Spectrum of postulated rod ejection accidents (DNB/LPD)**
  - ◆ *Follows the SRP 15.4.8 and 4.2 Guidance for accident analysis and fuel failure as described in ANP-10286P*


**Events that evolve too quickly for incore trips are protected by combination of LCOs and/or other plant trips**

# **U.S. EPR Tier 2 FSAR Non-LOCA Chapter 15 Event Evaluation (excluding Section 15.6.5)**

Douglas Brownson  
Supervisory Engineer, Non-LOCA Analysis



# Non-LOCA Methodology



- ▶ **Conservative, deterministic methodology**
- ▶ **Follows the NUREG-0800 Standard Review Plan (SRP) and Regulatory Guide 1.206**
- ▶ **Methodology updated for U.S. EPR to obtain initial fuel conditions from COPERNIC code rather than RODEX2A**
- ▶ **S-RELAP5 provides system fluid boundary conditions for external DNBR, fuel centerline melt and radiological evaluations**
- ▶ **In accordance with regulatory guidelines**
  - ◆ **Non-safety related system functionality modeled only when detrimental to outcome**
  - ◆ **Key parameters, such as protection system setpoints and ECCS performance, are biased for conservatism and uncertainty in accordance with Regulatory Guide 1.105**
- ▶ **Methodology considerations:**
  - ◆ **Single failure**
  - ◆ **Loss-of-offsite power (LOOP)**
  - ◆ **Operator actions (after 30 minutes)**
  - ◆ **Axial and radial power distributions**
  - ◆ **Preventative maintenance**

# Tier 2 FSAR Chapter 15 Events

- ▶ Radiological Consequences of Design Basis Accidents
- ▶ 15.1 Increase in Heat Removal by the Secondary System
  - ◆ 15.1.1 Decrease in Feedwater Temperature (AOO)
  - ◆ 15.1.2 Increase in Feedwater Flow (AOO)
  - ◆ 15.1.3 Increase in Steam Flow (AOO)
  - ◆ 15.1.4 Inadvertent Opening of a Steam Generator Relief or Safety Valve (AOO)
  - ◆ 15.1.5 Steam System Piping Failures Inside and Outside Containment (PA)
- ▶ 15.2 Decrease in Heat Removal by the Secondary System
  - ◆ 15.2.1 Loss of External Load (AOO)
  - ◆ 15.2.2 Turbine Trip (AOO)
  - ◆ 15.2.3 Loss of Condenser Vacuum (AOO)
  - ◆ 15.2.4 Inadvertent Main Steam Isolation Valve Closure (AOO)
  - ◆ 15.2.6 Loss of Non-Emergency AC Power to the Station Auxiliaries (AOO)
  - ◆ 15.2.7 Loss of Normal Feedwater Flow (AOO)
  - ◆ 15.2.8 Feedwater Line Breaks Inside and Outside Containment (PA)
- ▶ 15.3 Decrease in RCS Flow Rate
  - ◆ 15.3.1 Partial Loss of Forced Reactor Coolant Flow (AOO)
  - ◆ 15.3.2 Complete Loss of Forced Reactor Coolant Flow (AOO)
  - ◆ 15.3.3 Reactor Coolant Pump Rotor Seizure (PA)
  - ◆ 15.3.4 Reactor Coolant Pump Shaft Break (PA)

# Tier 2 FSAR Chapter 15 Events (Cont'd)



## ▶ 15.4 Reactivity and Power Distribution Anomalies

- ◆ 15.4.1 Uncontrolled Control Rod Assembly Withdrawal from Subcritical or Low-Power Startup Condition (AOO)
- ◆ 15.4.2 Uncontrolled Control Rod Assembly Withdrawal at Power (AOO)
- ◆ 15.4.3 Control Rod Misoperation (System Malfunction or Operator Error) (AOO)
- ◆ 15.4.4 Startup of an Inactive Reactor Coolant Pump at an Incorrect Temperature (AOO)
- ◆ 15.4.6 Chemical and Volume Control System Malfunction that Results in a Decrease in the Boron Concentration in the Reactor Coolant (AOO)
- ◆ 15.4.7 Inadvertent Loading and Operation of a Fuel Assembly in an Improper Position (AOO)
- ◆ 15.4.8 Spectrum of Rod Ejection Accidents in a PWR (PA)

## ▶ 15.5 Increase in RCS Inventory

- ◆ 15.5.1 Inadvertent Operation of ECCS or EBS (AOO)
- ◆ 15.5.2 Chemical and Volume Control System Malfunction that Increases Reactor Coolant Inventory (AOO)

## ▶ 15.6 Decrease in RCS Inventory

- ◆ 15.6.1 Inadvertent Opening of a Pressurizer Safety Relief Valve (AOO)
- ◆ 15.6.3 Steam Generator Tube Rupture (PWR) (PA)
- ◆ 15.6.5 Loss of Coolant Accidents Resulting from Spectrum of Postulated Piping Breaks within the Reactor Coolant Pressure Boundary (PA)

## ▶ 15.8 Anticipated Transients Without Scram

# Increase in Heat Removal (15.1)


## ▶ Increase in Steam Flow (AOO)

- ◆ Includes a spectrum of events covering the range up to all 6 turbine bypass valves opening (60% full flow) at various initial powers
- ◆ Protected by Low DNBR trip

## ▶ Steam System Piping Failures (PA)

- ◆ Includes a spectrum (break size, initial power, for both pre- and post-RT conditions)
  - Pre-RT
    - FSAR break sizes considered 10%, 50%, and 100% of steam line area
    - RT occurs on High Core Power Level, Low DNBR, or High SG Pressure Drop
    - Timely RT occurs and acceptance criteria satisfied
  - Post-RT
    - FSAR considers spectrum of break sizes and initial power levels including HFP and HZP
    - Limiting case is HZP with a return to power with some fuel damage
    - Offsite doses are within acceptance criteria

# Decrease in Heat Removal (15.2)



## ▶ Turbine Trip (AOO)

### ◆ Single failure of MSRT to open

### ◆ Limiting RCS overpressure event

- Peak Calculated RCS Pressure = 2785 psia
- Acceptance Criteria = 110% Design = 2803 psia

## ▶ Inadvertent Single MSIV Closure (AOO)

### ◆ Single failure of MSRT to open; MSSV preventative maintenance

### ◆ Limiting Secondary overpressure event


- Peak Calculated Steam Generator Pressure = 1567 psia
- Acceptance Criteria = 110% Design = 1593 psia

## ▶ Feedwater Line Break (PA)

### ◆ Design Transient for EFW Capacity

- Spectrum of FWLB sizes considered
- Two EFW pumps to two intact SGs sufficient to satisfy acceptance criteria
- Assume operator realigns EFW flow from failed SG to an intact SG with an inoperable EFW train at 30 minutes and trips the RCPs to the affect SG and SG loop with the single failure.

# Decrease in RCS Flow Rate (15.3)




## ▶ Complete Loss of Forced Reactor Coolant Flow (AOO)

- ◆ Single failure of one PS division; preventative maintenance on a second PS division
- ◆ RT on low RCP speed signal
- ◆ Limiting  $\Delta$ DNBR event that does not trip on DNB
- ◆ Sets LCO on Initial DNBR

## ▶ Reactor Coolant Pump Rotor Seizure (PA)

- ◆ RT on low-low flow in affected loop
- ◆ Conservatively predicts 8% of fuel rods undergo DNB-induced failure
- ◆ Radiological dose less than 10CFR100 criteria assuming a bounding value of 9.5% fuel failure

# Reactivity and Power Distribution Anomalies (15.4)




## ▶ RCCA Drop (AOO)

- ◆ Single RCCA and complete bank drop analyzed
- ◆ RCCA drop results in rod withdrawal when average coolant temperature (ACT) control function active
- ◆ Low DNBR LCO and RT provides protection for DNB
- ◆ HLPD limits are not exceeded

## ▶ RCCA Ejection (PA)

- ◆ Analyzed for core response and RCS overpressure
- ◆ Core Analysis
  - Spectrum of ejected rod worths and initial power levels from HZP to HFP
  - Event acceptance criteria satisfied
- ◆ Overpressure Analysis
  - No opening in the RCS assumed
  - RCS pressure well below 120% of design
  - MSSVs do not open

# Increase in RCS Inventory (15.5)



## ▶ Inadvertent Operation of ECCS or EBS (AOO)

### ◆ ECCS Operation

- MHSI shut-off head (1405 psia) below operating pressure (2250 psia)
- Inconsequential for U. S. EPR

### ◆ EBS Operation

- Single failure of one MSRT to open
- RT on high pressurizer level
- EBS manually isolated at 30 minutes

### ◆ Event acceptance criteria satisfied

## ▶ CVCS Malfunction (AOO)


### ◆ Both charging pumps operate with letdown isolated

### ◆ Single failure of one MSRT to open

### ◆ RT an isolation of CVCS on high pressurizer level

### ◆ Event acceptance criteria satisfied

# Decrease in RCS Inventory (15.6)




## ▶ Inadvertent Opening of a PSRV (AOO)

- ◆ One PSRV (out of three) inadvertently opens and sticks open
- ◆ Limiting single failure is EDG fails to start (loss of SIS and EFW pumps); additional EDG assumed unavailable due to preventative maintenance (loss of second SIS and EFW pumps)
- ◆ RT on low pressurizer pressure
- ◆ Two MHSI pumps sufficient to offset RCS inventory loss
- ◆ Operator action at 30 minutes credited to align flow from two operational EFW trains to all four SGs
- ◆ Acceptance criteria satisfied and core adequately cooled throughout event


## ▶ Steam Generator Tube Rupture (PA)

- ◆ Limiting FSAR case is with LOOP
- ◆ Single failure of main feedwater full load control valve assumed
- ◆ Manual RT at 30 min
- ◆ Radiological and overflow acceptance criteria are satisfied

# Anticipated Transients Without Scram (15.8)



- ▶ **An ATWS occurs when the control rods fail to insert following an AOO as a result of:**
  - ◆ **A mechanical blockage of the control rods, or**
  - ◆ **An electrical or mechanical failure of the protection system (PS)**
- ▶ **Mechanical blockage of the control rods is determined to be an insignificant contributor to the probability of an ATWS**
- ▶ **In the event of PS failure an independent, diverse actuation system (DAS) initiates a RT, turbine trip, and other essential safety systems and functions**
- ▶ **The acceptance criteria of 10CFR50.62 are satisfied**



# **U.S. EPR FSAR**

## **Section 15.0.3**

### **Radiological**


# **Consequences of DBAs**

Pedro Perez, P.E.

Supervisory Engineer, Radiological Engineering



# Radiological Consequences of DBAs




## ► General

The U.S. EPR design basis accident (DBA) radiological evaluations are based on the following:

- ◆ SRP Section 15.0.3, other SRP sections related to specific aspects of a given evaluation, and SRP Section 4.2, *Interim Acceptance Criteria and Guidance for the Reactivity Initiated Events*
- ◆ Regulatory Guide 1.183 - alternative source term (AST) methodology
- ◆ Regulatory Issue Summary (RIS) 2006-04, *Experience with Implementation of Alternative Source Terms*
- ◆ AST radiological acceptance criteria (10CFR50 and 10CFR52)
- ◆ Regulatory Guide 1.145 (Offsite atmospheric dispersion factors)
- ◆ Regulatory Guide 1.194/ARCON-96 (Onsite dispersion factors)

# Radiological Consequences of DBAs (cont'd)



## ► Evaluated DBAs


The radiological consequences were evaluated for the following DBAs:

- ◆ Small Line Break (SLB) outside of the Reactor Building (RB)
- ◆ Steam Generator Tube Rupture (SGTR)
- ◆ Main Steam Line Break (MSLB) outside of the RB
- ◆ RCP Locked Rotor Accident (LRA)
- ◆ Rod Ejection Accident (REA)
- ◆ Fuel Handling Accident (FHA)
- ◆ Loss of Coolant Accident (LOCA)

The RCP Broken Shaft and the Feedwater Line Break (FWLB) radiological consequences are bounded by the LRA and MSLB, respectively.


# Radiological Consequences of DBAs (cont'd)

- ▶ Release points to atmosphere and main control room (MCR) filtered and unfiltered intakes




# Radiological Consequences of DBAs (cont'd)

## ► MCR HVAC Design (99% charcoal filtration system)




# Radiological Consequences of DBAs (cont'd)

- ▶ Example of DBA model – LOCA (after end of annulus and safeguard buildings draw down)



# Scenario for Radiological Evaluation of SGTR




## ▶ SGTR Source Terms (NRC RG 1.183, Appendix F)

- ◆ Pre-accident iodine spike case. RCS concentration to the maximum value of 60  $\mu\text{Ci/gm}$  DE I-131
- ◆ Accident-induced concurrent iodine spike case of 8-hour duration. The iodine spike corresponds to an increase in the design-basis iodine appearance rate into the primary coolant by a factor of 335
- ◆ RCS noble gas concentration corresponds to technical specifications 210  $\mu\text{Ci/gm}$  DE Xe-133.
- ◆ All other radionuclide concentrations correspond to the design basis 0.25% failed fuel assumption
- ◆ SGTR release iodines, noble gases and alkalis. All other radionuclides are assumed to remain within the liquid phase (RCS and secondary coolant) per NRC Regulatory Issue Summary 2006-04

## ▶ Scenario

- ◆ Scenario selected maximizes the break flow and flashing fraction, corresponding to reactor trip by operator action and concurrent LOOP at 30 minutes into the accident, an additional 10 minutes to isolate the ruptured SG

# Scenario for Radiological Evaluation of SGTR (cont'd)



## ► Environmental Releases

- ◆ Atmospheric releases consist of the secondary-side activities, RCS leakage via the affected SG, and normal leakage via the other three intact SGs
- ◆ Early releases are via the condenser evacuation system until RT (30 minutes into the accident by operator action), and via the MSRTs thereafter. Iodine and alkali depletion due to deposition within the condenser with a decontamination factor (DF) of 100 is credited (NRC NUREG-1228)

# Scenario for Radiological Evaluation of LOCA




## ▶ LOCA Source Terms (NRC RG 1.183, Appendix A)

- ◆ Bounding core inventory (4612 MWt, 5–62 GWD/MTU, 2-5% U-235)
- ◆ RCS noble gas concentration corresponding to technical specification limits of 210  $\mu\text{Ci/gm}$  DE Xe-133, iodines at 1  $\mu\text{Ci/gm}$  DE I-131, and alkalis at the design basis 0.25% failed fuel fraction

## ▶ Scenario

- ◆ Time-phased releases to primary containment; natural deposition of elemental iodines and other particulates (combined Powers/Henry models); no spray effects
- ◆ 10-sec containment purge at start of accident via main stack; 0.25% per day containment leakage for first 24 hrs, 50% reduction thereafter; release adjacent to SG-3 MSRT during 305-sec annulus draw-down time, and via annulus filtration system and stack thereafter
- ◆ ESF component leakage at 4 gpm (to safeguards buildings); release adjacent to SG-3 MSRT during 289-sec draw-down time, and via the safeguards building filtration system and stack thereafter
- ◆ Releases via the main stack are at the base of the stack


# Scenario for Radiological Evaluation of LOCA (cont'd)



## ▶ Environmental Releases

- ◆ 10-second unfiltered release during containment purge; containment leakage via annulus (without holdup or depletion) and 99% exhaust filters
- ◆ ESF component leakage via safeguards buildings (without holdup or depletion) and 99% filters

# DBA Radiological Consequences Summary



## ► DBA Doses (and Regulatory Limits)

Design Basis Accident		Offsite TEDE Dose (rem)		MCR Dose (rem)
		EAB	LPZ	
LOCA		12.2 (25)	11.1 (25)	4.0 (5)
SLB outside of Reactor Building		1.8 (2.5)	0.3 (2.5)	0.1 (5)
SGTR	Pre-incident spike	1.1 (25)	0.3 (25)	0.3 (5)
	Coincident spike	0.7 (2.5)	0.5 (2.5)	0.6 (5)
MSLB	Pre-incident spike	0.2 (25)	0.1 (25)	0.5 (5)
	Coincident spike	0.3 (2.5)	0.2 (2.5)	0.7 (5)
	Fuel rod clad failure (3.3%)	5.3 (25)	2.6 (25)	4.5 (5)
	Fuel overheating (0.58%)	5.8 (25)	2.8 (25)	4.5 (5)
LRA (with 9.5% clad failure)		2.3 (2.5)	0.9 (2.5)	1.3 (5)
REA (with 36.7% clad failure)		5.7 (6.3)	3.5 (6.3)	4.3 (5)
FHA (with 34 hr decay)		5.6 (6.3)	1.0 (6.3)	0.5 (5)

# U.S. EPR Steam Generator Tube Rupture Mitigation Strategy

Kenneth Coffey,  
Engineer IV, Plant Operations




# U.S. EPR Steam Generator Tube Rupture Mitigation Strategy Agenda

- ▶ **SGTR Mitigation Strategy and Goals**
- ▶ **4 Stages of SGTR Mitigation**
  - ◆ **Example of Stage 3 and 4 without offsite power**
- ▶ **Mitigation Comparison with and without offsite power**

# U.S. EPR SGTR Mitigation Strategy

- ▶ **Mitigation of SGTR events similar to existing 4- loop PWRs**
- ▶ **U.S. EPR Specific Mitigation Features**
  - ◆ MHSI shutoff head and resetting MSRT setpoint allows for RCS inventory control without lifting the main steam valves
  - ◆ EBS provides safety related boration source
- ▶ **Main SGTR Mitigation Goals:**
  - ◆ Achieve controlled state to ensure RCS stability
    - The core is sub-critical, decay heat removal via SGs
    - Core water inventory is stable (RCS makeup compensates SGTR leak rate)
  - ◆ Terminate releases from affected SG as soon as practical
  - ◆ Cancellation of leak flow ( $P_{RCS} \approx P_{SGa}$ )
  - ◆ Reach safe shutdown on residual heat removal (RHR)


# U.S. EPR SGTR Mitigation Strategy



## ▶ 4 main stages of SGTR mitigation

1. Identification of SGTR
2. Reactor trip and isolation of affected SG
3. Primary to secondary leak flow cancellation
4. Cooldown & depressurize RCS and affected SG to allow for RHR connection

# Stage 1 – SGTR Identification




## ▶ Radiation monitors:

- ◆ Main steam line
- ◆ SG blowdown lines
- ◆ Condenser off-gas

## ▶ System response:

- ◆ Feed flow-steam flow mismatch (at low power)
- ◆ Pressurizer pressure decreasing
- ◆ Pressurizer level decreasing

# Stage 2 – Reactor Trip and Affected SG Isolation




## ▶ Reactor Trip

- ◆ Manual RT if CVCS is capable of compensating the leak

## ▶ Affected SG Isolation

- ◆ Close MFW and EFW isolation valves of the affected SG
- ◆ Verify isolation of SG blowdown lines of affected SG
- ◆ Close the MSIV of the affected SG
- ◆ Reset the MSRT (isolation and control valves) to the high setpoint for the affected SG

# Stage 3 – Primary to Secondary Leak Flow Cancellation



- ▶ **Stage 3 differs depending on the available equipment**
- ▶ **With LOOP:**
  - ◆ **Cooldown RCS using unaffected SGs**
    - Partial cooldown (180 F/hr to 870 psia)
  - ◆ **Supply feedwater to unaffected SGs**
    - EFW
  - ◆ **Maintain adequate RCS inventory**
    - Safety Injection System
  - ◆ **Allow for the RCS pressure to be reduced to the affected SG pressure**

# Stage 4 – Cooldown and Depressurize RCS to RHR Connection Conditions

## ▶ RCS Cooldown with LOOP

- ◆ Cooldown the using MSRTs of the unaffected SGs

- ◆ Boration for cooldown

- 1 EBS train required for 45°F/hr
- 2 EBS trains required for 90°F/hr


- ◆ MHSI managed to

- Maintain adequate subcooling margin
- Maintain RCS inventory
- Allow for depressurization of RCS to RHR connection pressure

## ▶ RCS Depressurization to RHR connection pressure with LOOP


- ◆ Cycle PSRVs while maintaining subcooling margin

# LOOP vs. Non-LOOP Mitigation Comparison



- ▶ **Emergency Procedure Guidelines (EPG) developed to utilize all available systems**
- ▶ **Preference given to systems that accomplish the task as effectively as possible and as close to normal operating conditions as the situation permits**
- ▶ **Availability of off-site power is one of the biggest factors in determining what systems may be used to mitigate an accident**

# Stage 3 – Systems to Makeup RCS Inventory and Control RCS Pressure




## With Off-Site Power

- ▶ **RCS Inventory Control**
  - ◆ CVCS
- ▶ **RCS Pressure Control**
  - ◆ Normal spray / Auxiliary spray
  - ◆ PZR Heaters
- ▶ **SG Inventory Control**
  - ◆ MFW
- ▶ **SG Pressure Control**
  - ◆ Turbine bypass to condenser

## Without Off-Site Power

- ▶ **RCS Inventory Control**
  - ◆ MHSI
  - ◆ EBS
- ▶ **RCS Pressure Control**
  - ◆ RCS pressure imposed by MHSI pump shutoff head
- ▶ **SG Inventory Control**
  - ◆ EFW
- ▶ **SG Pressure Control**
  - ◆ MSRTs of unaffected SGs

# Stage 4 – Multiple Means to Depressurize RCS and Affected SG



## With Off-Site Power

- ▶ **With RCPs running**
  - ◆ Forced circulation through tubes of affected SG acts to cool and depressurize affected SG
- ▶ **Continued cooldown and depressurization**
  - ◆ CVCS
  - ◆ Normal / Auxiliary Spray
  - ◆ Heaters
  - ◆ MFW
  - ◆ Turbine Bypass

## Without Off-Site Power

- ▶ **RCPs not running**
  - ◆ Affected SG pressure holds RCS pressure above RHR connection conditions
- ▶ **Continued cooldown and depressurization**
  - ◆ MHSI
  - ◆ EBS
  - ◆ EFW
  - ◆ MSRTs of unaffected SGs
- ▶ **Final RCS and affected SG depressurization**
  - ◆ PSRVs

# Nomenclature

▶ ACT	Average Coolant Temperature [Control Function]	▶ MCR	Main Control Room
▶ AMS	Aeroball Measurement System	▶ MNDBR	Minimum Departure from Nucleate Boiling Ratio
▶ AO	Axial offset	▶ MFW	Main Feedwater
▶ AOO	Abnormal Operational Occurrence	▶ MHSI	Medium Head Injection System
▶ AST	Alternative Source Term	▶ MSIV	Main Steam Isolation Valve
▶ ATWS	Anticipated Transient Without Scram	▶ MSLB	Main Steam Line Break
▶ CVCS	Chemical and Volume Control System	▶ MSRT	Main Steam Relief Train
▶ DNB(R)	Departure from Nuclear Boiling (Ratio)	▶ MSSV	Main Steam Safety Valve
▶ DAS	Diverse Actuation System	▶ NSSS	Nuclear Steam Supply System
▶ DBA	Design Basis Accident	▶ PA	Postulated Accident
▶ DE	Dose Equivalent	▶ PRD	Power Range Neutron Detector
▶ DF	Decontamination Factor	▶ PS	Protection System
▶ EAB	Exclusion area boundary	▶ PSRV	Pressurizer Safety Relief Valve
▶ EBS	Extra Borating System	▶ PWR	Pressurizer Water Reactor
▶ ECCS	Emergency Core Cooling System	▶ PZR	Pressurizer
▶ EDG	Emergency Diesel Generator	▶ RB	Reactor Building
▶ EFW	Emergency Feedwater	▶ RCCA	Rod Cluster Control Assembly
▶ ESF	Engineered Safety Function	▶ RCP	Reactor Coolant Pump
▶ FDH	Axially Integrated Radial Power Peaking (Enthalpy Rise) Factor	▶ RCS	Reactor Coolant System
▶ FHA	Fuel Handling Accident	▶ RCSL	Reactor Control, Surveillance, and Limitation
▶ FWLB	Feedwater Line Break	▶ REA	Rod Ejection Accident
▶ HCPL	High Core Power Limit	▶ RD	Rod Drop
▶ HFP	Hot Full Power	▶ RHR	Residual Heat Removal [System]
▶ (H)LPD	(High) Linear Power Density (kW/ft)	▶ RIS	Regulatory Issue Summary
▶ HVAC	Heating and Ventilation	▶ RT	Reactor Trip
▶ HZP	Hot Zero Power	▶ RV	Reactor Vessel
▶ I&C	Instrumentation and Control	▶ SAFDL	Specified Acceptable Fuel Design Limit
▶ IRD	Intermediate Range Neutron Detector	▶ SBLOCA	Small Break LOCA
▶ IRWST	In-containment Refueling Water Storage Tank	▶ SDM	Shutdown Margin
▶ LCO	Limiting Condition for Operations	▶ SIS	Safety Injection System
▶ LOCA	Loss of Coolant Accident	▶ SG	Steam Generator
▶ LOFC	Loss of Flow	▶ SGTR	Steam Generator Tube Rupture
▶ LOOP	Loss of Offsite Power	▶ SLB	Small Line Break
▶ LPD	Linear Power Density	▶ SPND	Self-Powered Neutron Detector
▶ LPZ	Low Population Zone	▶ SRD	Source Range Neutron Detector
▶ LRA	Locked Rotor Accident	▶ SRP	Standard Review Plan
		▶ TEDE	Total Effective Dose Equivalent
		▶ TH	Thermal Hydraulic



# ***Presentation to the ACRS Subcommittee***

**AREVA U.S. EPR Design Certification Application Review**

**Safety Evaluation Report with Open Items**

**Chapter 15, Group 1: Transient and Accident Analyses**

February 7 and 8, 2011

# ***Staff Review Team***

- **Technical Staff**
  - ♦ **Shanlai Lu**  
Reactor Systems, Nuclear Performance, and Code Review Branch
  - ♦ **Christopher VanWert**  
Reactor Systems, Nuclear Performance, and Code Review Branch
  - ♦ **Michelle Hart**  
Reactor Siting and Accident Consequence Branch
  - ♦ **Eduardo Sastre**  
Component Integrity Branch
  
- **Project Managers**
  - Getachew Tesfaye**
  - Jason Carneal**

# Overview of DCA

<b>SRP Section/Application Section</b>		<b>No. of Questions</b>	<b>Number of OI</b>
15.0.1 and 15.0.2	Radiological Consequence Analysis and Computer Codes Used in Transient and Accident Analysis	10	3
15.0.3	Radiological Consequences of Design Basis Analysis	38	2 (closed)
15.1	Increase in Heat Removal by the Secondary System	25	0
15.2	Decrease in Heat Removal by the Secondary System	25	0
15.3	Decrease in Reactor Coolant System Flow Rate	9	0
15.4	Reactivity and Power Distribution Anomalies	15	1

# Overview of DCA (continued)

SRP Section/Application Section		No. of Questions	Number of OI
15.5	Increase in Reactor Coolant Inventory	2	0
15.6.1	Inadvertent Opening of a Pressurizer Safety Relief Valve	3	0
15.6.3	Steam Generator Tube Failure (PWR)	4	0
15.8	Anticipated Transients Without Scram	0	0
<b>Totals</b>		131	6 (4 open items remain)

\*The Phase 2 safety evaluation for Section 15.6.5, “Loss of Coolant Accidents Resulting from Spectrum of Postulated Piping Breaks Within the Reactor Coolant Pressure Boundary,” was not delivered in Group 1 and will not be covered in this presentation.

# ***Description of Open Items***

- RAI 415, Question 15-9: Requests that the applicant propose a combined license (COL) action item to require that the COL applicant perform verification and validation of its site-specific EOPs using plant simulators to assure that the operator action time assumed in the safety analyses documented in FSAR Tier 2, Chapter 15 are achievable to assure that the safety analyses of record remain valid.
- RAI 311, Question 16-317: Requests that the applicant provide an evaluation of all the proposed technical specification (TS) values in FSAR Tier 2, Chapter 16 to confirm that all assumptions in FSAR Tier 2, Chapter 15 safety analyses are within the limiting conditions for operation specified in the TS. This question originated in Chapter 16 of the review.
- RAI 432, Question 15.00.02-1: Requests that the applicant provide a description of the mechanism, such as an ITAAC or COL action item, by which the information will be provided to support the 0.48 percent total power measurement uncertainty claimed by the applicant, including a description of how it will be verified and confirmed.
- RAI 344, Question 04.03-28: Tracks topical report ANP-10286P as an open item until the final safety evaluation is produced.

# ***Closed Open Items***

- RAI 394, Question 15.00.03-37: Provide tables in the FSAR that demonstrate that the pH would be acceptable after the 30-day time frame with the added amounts of HCl and HNO<sub>3</sub> resulting from radiolytic reactions. **These tables have been included as FSAR markups in an RAI response and this item is considered confirmatory by the staff.**
- RAI 394, Question 15.00.03-38: Requests that the applicant include purity and density values for commercially purchased TSP in FSAR Tier 2, Section 15.0.3. **These values have been included as FSAR markups in an RAI response and this item is considered confirmatory by the staff.**



# ***Presentation to the ACRS Subcommittee***

**AREVA U.S. EPR Design Certification Application Review**

**Safety Evaluation Report with Open Items**

**Chapter 15, Group 1, Sections 15.0.2, 15.1, 15.2, 15.3,  
15.5, 15.6, 15.8**

February 7, 2011

# ***Staff Review Team***

- **NRC Technical Staff**

Reactor Systems, Nuclear Performance, and Code Review Branch

Chu-yu Liang (Retired)

Shanlai Lu

- **Consultants**

Jack Rosenthal, David Caraher, Vesselin Palazov (ISL)

- **Project Managers**

Getachew Tesfaye

Jason Carneal

# **U.S. EPR Chapter 15 Group 1**

## **Transient and Accident Analyses**

- Types of events considered in design basis safety analyses
  - ♦ Increase in heat removal by the secondary systems (15.1)
  - ♦ Decrease in heat removal by the secondary systems (15.2)
  - ♦ Decrease in RCS flow rate (15.3)
  - ♦ Reactivity and power distribution anomalies (15.4)
    - Will be covered in a separate presentation on February 8, 2011
  - ♦ Increase in reactor coolant inventory (15.5)
  - ♦ Decrease in reactor coolant inventory (15.6)
  - ♦ Anticipated Transient Without Scram (ATWS) (15.8)

# **U.S. EPR Chapter 15 Group 1** **Transient and Accident Analyses**

- Acceptance criteria for each category of events according to frequency of occurrence (Non-LOCA)
  - ♦ Anticipated operational occurrence (AOO) – Events expected to occur during the life time of the plant
    - 1) Pressures in primary and secondary systems not exceeding 110% of the design value
    - 2) Fuel cladding integrity shall be maintained by no DNB during the transient
    - 3) An AOO should not generate a postulated accident

# **U.S. EPR Chapter 15 Group 1** **Transient and Accident Analyses**

- Acceptance Criteria (continue)

Postulated accidents (PA)– Events not expected to occur during the life time of the plant design

- 1) Pressure in primary and secondary systems not exceeding acceptable design limits, considering potential brittle as well as ductile failures
- 2) Fuel failure may occur but not result in offsite doses exceeding 10 CFR 100 limits
- 3) A PA should not cause a consequential loss function of systems needed for mitigation of the event

# **U.S. EPR Chapter 15 Group 1** **Transient and Accident Analyses**

- Major review areas (Non-LOCA)
  - ◆ Review of methodologies and computer codes used in safety analyses to assure that they are approved by NRC and applicable to U.S. EPR design
  - ◆ Review of LCOs proposed in Chapter 16.1 to assure that they provide bounding conditions to support safe analyses assumptions including initial conditions, plant configurations, etc

# **U.S. EPR Chapter 15 Group 1** **Transient and Accident Analyses**

- Major review areas (continue)
  - Review of worst single failure assumed in each event scenario to assure the worst cases are analyzed with respect to each of the acceptance criteria (e.g. Peak pressures, DNB)
  - Review of events analyzed with and without offsite power available. Loss-of-Offsite-Power (LOOP) may occur following a turbine trip

# **U.S. EPR Chapter 15 Group 1** **Transient and Accident Analyses**

- Major review areas (continue)
  - Review of sequence of events for analyzed event scenario to evaluate the mitigation system and instrumentation responses and assumed operator actions to assure the transients are supported by the design of plant safety systems and future EOPs
  - Review of the analyses including transient predictions to assure that the consequences of each analyzed limiting case meet the specific acceptance criteria specified for each events and all the regulatory requirements

# **U.S. EPR Chapter 15 Group 1 Transient and Accident Analyses**

- Site Audits and Confirmatory Calculations
  - Staff conducted various audits of design files at AREVA offices to obtain additional information for detailed staff review
  - Staff performed confirmatory calculations using methods and computer codes available to NRC to establish sufficient confidence to the results of AREVA's analyses.

# **U.S. EPR Chapter 15 Group 1** **Transient and Accident Analyses**

- Open Items
  - 1) Emergency Operating Procedures (EOPs) verification –  
The staff request AREVA to add a COL Action Item for verification of plant specific EOPs to validate the safety analyses assumptions.
    - FSAR Section 15.0.0.3.7 states the operator actions are credited in various analyses to mitigate postulated accidents (e.g. FWLB, MSLB, SGTR, and ECCS switchover during LOCA long term cooling).

# **U.S. EPR Chapter 15 Group 1** **Transient and Accident Analyses**

- Open items – EOP verifications (continue)
  - ♦ FSAR Section 13.5 states that a COL applicant will provide site-specific EOPs. However, there was no specific guidelines for the required verification and validation of EOPs to confirm operator actions credited in safety analyses are achievable.
  - ♦ Staff requires AREVA propose a COL Action Item in EPR DCD for the above required verifications.

# **U.S. EPR Chapter 15 Group 1 Transient and Accident Analyses**

## **Power Measurement Uncertainties**

The staff request AREVA to provide sufficient information to support its claimed 0.48% power uncertainty assumed in Chapter 15 safety analyses

- ♦ FSAR Section 15.0.0.3.1 indicated that the heat balance measurement uncertainty of +/- 22 MWt is applicable to the rated thermal power of 4590 MWt (approximately 0.48% uncertainty) for the maximum core power assumed in Chapter 15 safety analyses.

# **U.S. EPR Chapter 15 Group 1 Transient and Accident Analyses**

- Open items – Power measurement uncertainties (continue)
  - ◆ The staff request AREVA to provide the following:
    - a) A description of an mechanism, such as the FSAR and ITAAC and/or COL Action Item by which the information will be provided to support claimed 0.48% power uncertainty.

# **U.S. EPR Chapter 15 Group 1** **Transient and Accident Analyses**

- Open items – Power measurement uncertainties (continue)
  - b) A description of the instrumentation and methodology used for the main feedwater measurement and calorimetric power flow measurement.
  - c) A description of more details regarding the methods of treating total uncertainties for the main feedwater flow rate and reactor thermal power, etc.

# **U.S. EPR Chapter 15 Group 1 Transient and Accident Analyses**

## **Verification of Technical Specifications**

Technical Specifications (TS) supporting safety analysis assumptions – The staff requests AREVA to verify and confirm that the plant TSs are consistent with assumptions applied in Chapter 15 safety analyses

- ◆ The staff requires AREVA to provide the results of an assessment to confirm that its proposed TS in FSAR Chapter 16 are consistent with the assumptions applied in the FSAR Chapter 15 safety analyses.

## ***U.S. EPR Steam Generator Tube Rupture Event***

- Offers direct path to environment
- Thermal-hydraulic analysis provides input to dose analysis
  - ◆ Maximize break flow, critical flow, MSRCV assumed stuck open
  - ◆ Technical Specification Coolant Activity
  - ◆ First 30 minutes no operator action
  - ◆ LOOP assumed

## ***U.S. EPR Steam Generator Tube Rupture Event***

- ◆ Automatic secondary side partial cooldown, automatic EFW, manual EBS
- ◆ Approved methods: S-RELAP5
- ◆ Meet criteria 10CFR 50.47, GDC 19
- ◆ EOP critical to ensure long term cooling to maintain shutdown margin, prevent overflow of steam line and backflow

# **US-EPR DCA – Chapter 15** **Transient and Accident** **Analyses**

## **Conclusions**

- Staff has completed the Phase 2 review on 15.0, 15.1, 15.2, 15.3, 15.5, 15.6, 15.8
- 131 RAIs were issued on Chapter 15, Group 1
- Four open items remain open in Phase 4
- Confirmatory analysis results supported staff conclusions

Section 15.4 will be presented on February 8, 2011.

- includes open item on ANP-10286P, “U.S. EPR Rod Ejection Accident Methodology Topical Report”



***NRC Staff Confirmatory Analysis  
Supporting Safety Evaluation of U.S. EPR  
Chapter 15, Group 1***

**AREVA U.S. EPR Design Certification Application Review**

**Safety Evaluation Report with Open Items**

**Chapter 15, Group 1: Transient and Accident Analyses**

February 7 and 8, 2011

# ***Staff Review Team***

- **NRC Staff**

Reactor Systems Branch, NRO

Shanlai Lu

Reactor Systems Safety Analysis Branch, RES

Shawn Marshall, Willams Krotiuk, Stephen Bajorek

Ronald Harrington

Reactor Systems Branch, NRR

Anthony Ulses

- **Consultants**

Randy Bells, Jose March-Leuba(ORNL), David Caraher (ISL)

# ***Contents***

- Overall Confirmatory Analysis Approach
- U.S. EPR System Model Development Using TRACE
- U.S. EPR Core Model Development Using PARCS
- Transient Analysis Results:
  - Feedwater Heater Trip Transient
  - Rod Withdrawal Transient
- Conclusion

# ***Overall Confirmatory Analysis Approach***

- Confirmatory Analysis Selection Criteria for Review of U.S. EPR Design Certification, Chapter 15, Group 1
  1. Support staff's review on new design features
  2. Identify RAIs related to margin evaluationGoal: Develop proper RAIs and review strategy
  
- Confirmatory Analysis Scope
  - AOOs: Loss of Feedwater Heater, Rod Withdrawal
  - Postulated Accident: LBLOCA, SBLOCA, Rod Ejection
  - Design Feature: Ex-core Detector, Spent Fuel Pool
  - D3: Increase in steam flow, MSIV closure, etc.

# ***NRC Confirmatory Analysis Approach And Tools***

## AREA 1. System Model Development

RELAP5, S-RELAP5 (AREVA)\*, TRACE, PARCS,  
NRC-RES, ISL

## AREA 2. Fuel Performance Analysis

FRAPCON, FRAPTRAN, RODEX-4 (AREVA)\*  
NRC-NRO, PNNL

## AREA 3. AOOs and Postulated Accidents Evaluation

TRACE, PARCS, TRITON, RELAP5, S-RELAP5 (AREVA)\*  
NRC-RES, ORNL, ISL

## AREA 4. Ex-core Neutron Flux and Criticality Evaluation

SCALE 6.0, MCNP  
NRC-NRO, ORNL

\* AREVA codes run by NRC staff



# ***Development of the TRACE Model for US EPR***

Shawn O. Marshall  
Office of Nuclear Regulatory Research (RES)  
U.S. NRC

February 7, 2011

# ***OBJECTIVE***

To provide an overview of the basic TRACE U.S. EPR model developed by RES to support NRO confirmatory analyses.

- Give general descriptions of some of the major component and control systems, to include the primary- and secondary-systems and the Emergency Core Cooling System (ECCS).
- As proof of the models general adequacy, show results from a TRACE steady-state calculation in comparison with initial conditions and steady-state results provided by AREVA.

# ***US EPR TRACE Model***

- ❑ Model was designed to incorporate as much plant-specific detail as possible without unduly increasing runtime.
  - simulates all basic operational and protection system functions
  
- ❑ Input based on information from SRELAP-5 model and EPR Databank
  
- ❑ Assembled using the Symbolic Nuclear Analysis Package (SNAP)
  
- ❑ Model summary:
  - Contains over 185 hydraulic components,
  - over 400 control- system inputs, and
  - over 150 different heat structures


Steam Generators

Vessel

Accumulators

Accumulators


**TRACE Model  
Nodalization Diagram**



# Primary System

## Reactor Vessel

- ❑ Modeled using TRACE 3-D VESSEL Component
- ❑ There are 8 azimuthal sectors, one sector for each hot leg and each cold leg.
- ❑ Vessel modeled with 4 radial rings:
  - Ring 1 contains the innermost 9 fuel assemblies;
  - ring 2 contains other 184 assemblies;
  - ring 3 contains outermost 48 assemblies and the thermal shield, and it extends to outer diameter of the core barrel;
  - ring 4 is the downcomer.




# Primary System (Cont.)

## □ **Pressurizer**


- **3 Safety Relief Valves**
- **Pressurizer Heaters**
- **Sprays**
  - Proportional-Integral-differential controllers (PIDs) modulate sprayers and heaters to control liquid level

## □ **Each of the four coolant loops is modeled independently**

- Reactor Coolant Pump (RCP)
- Steam Generator



# Secondary System





## □ 4 Steam Generators

- SG tubes modeled as 1 pipe
- Axial economizer modeled using 1-D pipes representing separate cold and hot downcomer and boiler regions
- Main Steam Relief Train (MSRT)
  - Main Steam Relief Isolation Valves
  - Main Steam Relief Control Valves

## □ Independent ECCS trains

- an accumulator
- injection sites for the safety systems
  - Low Head Safety Injection (LHSI)
    - Loops 1&2 and 3&4 connected by cross connection lines and valves
  - Medium Head Safety Injection (MHSI)



# Steady State Results



United States Nuclear Regulatory Commission

*Protecting People and the Environment*

Parameter (TRACE Plot Var)	AREVA Results	TRACE Results
Reactor Power, MW (rpower-5150)	4590.0	4590.0
Tavg , K (cb3020)	585.4	585.4
Pressurizer Pressure, MPa (pn-362A02)	15.51	15.51
Pressurizer Level, m (pn-362A02)	6.68	6.68
RCS Flow, kg/s (cb7205)	23182.	22920.
Bypass Flows, %, Total	4.75	4.99
DC to UH (cb7210)	0.4	0.42
CRGT (cb7211)	2.6	2.22
Baffle & DC/UP (cb7212)	2.5	2.35
Upper Head Temp., K	~585	586.
Pump Speed, rad/s (cb400)	124.6	134.1
Pump Head, m	106.4	133.6
Vessel dP, MPa (cb7301)	X	1.46X
SG tubes dP, Pa (cb7304)	X	1.05X

# ***Conclusion***

- ❑ An overview of the basic TRACE U.S. EPR model developed by RES has been provided, to include general descriptions of the primary- and secondary-systems and the Emergency Core Cooling System (ECCS).
- ❑ The TRACE steady-state results were comparable to the AREVA initial conditions and calculated results.
- ❑ TRACE model can be used to generate useful information to support staff review.



***U.S. EPR Transient Model  
Development and Analysis Using  
TRACE/PARCS***


Anthony Ulses

Chief of Reactor System Branch  
U.S. NRC / NRR



# Cross Section Development

- SCALE/TRITON  $\frac{1}{4}$  Assembly Model
- Parameter Branching Applicable for Hot Zero and Full Power Transients
- Each Fuel Type Modeled



# ***Transient Results***

- Used to prepare simulated “data” for subsequent analysis
- Evaluate that the DNBR and LPD trips would conservatively bound the actual plant response
- Two transients chosen
  - ◆ Rod Withdrawal Accident
    - Simulated trip at 20 seconds
  - ◆ Loss of Feedwater Heater
    - Simulated trip at 50 seconds

# ***Conclusion***

- NRC TRACE/PARCS code package has been used to develop EPR 3-D core model based on the cross-section library generated using SCALE/TRITON code package
- Two EPR transients have been simulated and the calculated 3-D neutron flux level throughout the core can be used to evaluate EPR SPND based protection system responses



# ***Evaluation of EPR DNBR and LPD Trip Timing Using TRACE/PARCS Results***

Shanlai Lu  
NRC/NRO

Randy Bells, Jose March-Leuba  
ORNL

February 7, 2011


# ***Background***

- EPR relies on 72 in-core self-powered neutron detectors to determine
  - ◆ departure from nucleate boiling (DNB), and
  - ◆ linear power density (LPD)
- DNBR trip requires an on-line algorithm
  - ◆ Must run in ~100 ms in qualified hardware
  - ◆ 12 estimates of MDNBR, one from each SPND string
  - ◆ Not enough computer power to perform a detailed sub-channel analysis


# ***In Core DNBR Calculation Using TRACE Output***

- Two calculations performed with TRACE to simulate SPND and EPR protection system response:
  - FW heater trip: core wide power change
  - Rod withdrawal: localized power peak
- Calculation Process
  - ◆ TRACE defines a steady state (3D power distribution)
  - ◆ SPNDs calibrated with a simulated AMS measurement
    - $C_{ij}$  parameters for DNBR and LPD are generated
  - ◆ TRACE calculates 3D power during transient
  - ◆ DNBR & LPD values calculated
    - From real 3D TRACE powers (“real” hot bundle) using the CHF correlation documented in ANP-10269PA
    - From simulated SPND  $C_{ij}$ ’s (“EPR” 12 hot bundles)


# ***DNBR Confirmatory Calculation (LOFWH Event)***




# ***DNBR Confirmatory Calculation (Rod Withdrawal Event)***




# Radial Power Shift (Rod Withdrawal Event)



# LPD Confirmatory Calculation (LOFWH Event)



# LPD Confirmatory Calculation (Rod Withdrawal Event)



# ***EPR DNBR Calculation Results Evaluation***

- Most SPND strings predict lower DNBR and higher LPD values than the real TRACE hot bundle during the transient
- The EPR protection system using signals from in-core SPNDs should be able to generate reactor trips in time during these two transients
- The methodology of predicting on-line DNBR and LPD is shown to be conservative

# ***Conclusions***

- Staff has made significant effort to perform independent confirmatory analyses as part of NRC U.S. EPR FSAR review
- The confirmatory analysis results support the staff conclusion documented in Chapter 15, Group 1, Phase 2 SER

# ***Acronyms***

- COL – combined license
- CRDM – Control Rod Drive Mechanism
- DNBR – Departure From Nucleate Boiling Ratio
- FSAR – Final Safety Analysis Report
- LPD – Linear Power Density
- SER – Safety Evaluation Report
- RAI – Request for additional information
- SAFDL - Specified Acceptable Fuel Design Limit
- SG – Steam Generator
- SPND – Self Powered Neutron Detector
- TS – Technical Specification