Enclosure (1)

2010 Annual Radioactive Effluent Release Report including Revision 26 of the Offsite Dose Calculation Manual




TABLE OF CONTENTS

1.0	Intro	duction	1
2.0	Supp	plemental Information	1
	2.1	Regulatory Limits	1
	2.2	Effluent Concentration Limits	3
	2.3	Release Rate Limits	3
	2.4	Measurements and Approximations of Total Radioactivity	3
	2.5	Batch Releases	4
	2.6	Abnormal Releases	. 4
3.0	Sum	mary of Gaseous Radioactive Effluents	5
4.0	Sum	mary of Liquid Radioactive Effluents	5
5.0	Solid	d Waste	5
6.0	Low	er Limit of Detection	6
7.0	Radi	ological Impact	6
8.0	Mete	eorological Data	7
9.0	Land	d Use Census Changes	7
10.0	Cha	nges to the Offsite Dose Calculation Manual	7
11.0	Cha	nges to the Process Control Program	8
12.0	Мајс	or Changes to Radwaste Treatment Systems	8
13.0	Inop	erable Monitors	9
14.0	Cha	nges to Previous Annual Effluent Reports	9
15.0	Gro	undwater Monitoring	9

LIST OF TABLES

)

Table 1A	Gaseous Effluents - Summation of all Releases1	0
Table 2A	Liquid Effluents - Summation of all Releases	12
Table 1B	Gaseous Effluents - Continuous and Batch Releases	14
Table 2B	Liquid Effluents - Continuous and Batch Releases	16
Table 3	Solid Waste and Irradiated Fuel Shipments	18
Table 4A	Radiation Dose to Nearest Individual Receptor from Gaseous Releases	19
Table 4B	Radiation Dose to Nearest Individual Receptor from Liquid Releases	23
Table 5	Groundwater Monitoring Well Results	.24
Table 6	Dose due to Carbon-14 in Effluents	25

(

1.0 INTRODUCTION

This Annual Radioactive Effluent Release Report is for the R.E. Ginna Nuclear Power Plant and is submitted in accordance with the requirements of Technical Specification Section 5.6.3. The report covers the period from January 1, 2010 through December 31, 2010.

This report includes a summary of the quantities of radioactive gaseous and liquid effluents and solid waste released from the plant presented in the format outlined in Appendix B of Regulatory Guide 1.21, Revision 1, June, 1974.

All gaseous and liquid effluents discharged during this reporting period were in compliance with the limits of the R.E. Ginna Technical Specifications as defined in the Offsite Dose Calculation Manual (ODCM).

2.0 SUPPLEMENTAL INFORMATION

2.1 <u>Regulatory Limits</u>

The ODCM limits applicable to the release of radioactive material in liquid and gaseous effluents are:

2.1.1 Fission and Activation Gases

The instantaneous dose rate, as calculated in the ODCM, due to noble gases released in gaseous effluents from the site shall be limited to a release rate which would yield \leq 500 mrem/yr to the total body and \leq 3000 mrem/yr to the skin if allowed to continue for a full year.

The air dose, as calculated in the ODCM, due to noble gases released in gaseous effluents from the site shall be limited to the following:

- (I) During any calendar quarter to ≤ 5 mrad for gamma radiation and to ≤ 10 mrad for beta radiation.
- (ii) During any calendar year to \leq 10 mrad for gamma radiation and to \leq 20 mrad for beta radiation.

2.1.2 Radioiodine, Tritium and Particulates

The instantaneous dose rate, as calculated in the ODCM, due to radioactive materials released in gaseous effluents from the site as radioiodines, radioactive materials in particulate form, and radionuclides other than noble gases with half-lives greater than 8 days shall be limited to a release rate which would yield \leq 1500 mrem/yr to any organ if allowed to continue for a full year.

The dose to an individual, as calculated in the ODCM, from radioiodine, radioactive materials in particulate form and radionuclides other than noble gases with half-lives greater than eight days released with gaseous effluents from the site shall be limited to the following:

- (i) During any calendar quarter to ≤ 7.5 mrem to any organ.
- (ii) During any calendar year to \leq 15 mrem to any organ.

2.1.3 Liquid Effluents

The release of radioactive liquid effluents shall be such that the concentration in the circulating water discharge does not exceed the limits specified in accordance with Appendix B, Table II, Column 2 and notes thereto of 10CFR20, as explained in Section 1 of the ODCM. For dissolved or entrained noble gases the total activity due to dissolved or entrained noble gases shall not exceed 2E-04 uCi/ml.

The dose or dose commitment to an individual as calculated in the ODCM from radioactive materials in liquid effluents released to unrestricted areas shall be limited:

- (i) During any calendar quarter to \leq 1.5 mrem to the total body and to \leq 5 mrem to any organ, and
- (ii) During any calendar year to ≤ 3 mrem to the total body and to ≤ 10 mrem to any organ.

2.2 Effluent Concentration Limit (ECL)

- 2.2.1 For gaseous effluents, effluent concentration limits are not directly used in release rate calculations since the applicable limits are stated in terms of dose rate at the unrestricted area boundary, in accordance with Technical Specification 5.5.4.g.
- 2.2.2 For liquid effluents, ten times the effluent concentration values specified in 10CFR20, Appendix B, Table II, column 2, are used to calculate release rates and permissible concentrations at the unrestricted area boundary as permitted by Technical Specification 5.5.4.b. A value of 2E-04 uCi/ml is used as the ECL for dissolved and entrained noble gases in liquid effluents.

2.3 Release Rate Limits Based on Average Nuclide Energy

The release rate limits for fission and activation gases from the R.E. Ginna Nuclear Power Plant are not based on the average energy of the radionuclide mixture in gaseous effluents; therefore, this value is not applicable. However the 2010 average beta/gamma energy of the radionuclide mixture in fission and activation gases released from Ginna is available for review upon request.

2.4 <u>Measurements and Approximations of Total Radioactivity</u>

Gamma spectroscopy was the primary analysis method used to determine the radionuclide composition and concentration of gaseous and liquid effluents. Composite samples were analyzed for Sr-89, Sr-90, and Fe-55 by a contract laboratory. Tritium and alpha analysis were performed using liquid scintillation and gas flow proportional counting respectively.

The total radioactivity in effluent releases was determined from the measured concentration of each radionuclide present and the total volume of effluents released.

2.5 <u>Batch Releases</u>

2.5.1 Liquid

.

1. Number of batch releases:	9.4E+01
2. Total time period for batch releases:	2.34 E+04 min
3. Maximum time period for a batch release:	8.78 E+03 min
4. Average time period for batch releases:	2.49 E+02 min
5. Minimum time period for a batch release:	5.0 E+00 min
 Average blowdown in liters per minute (LPM) during periods of effluent release into the discharge canal. 	4.57 E+02 LPM

2.5.2 Gaseous

1. Number of batch releases:	4.4 E+01
2. Total time period for batch releases:	5.36 E+05 min
3. Maximum time period for a batch release:	4.46 E+04 min
4. Average time period for batch releases:	1.22 E+04 min
5. Minimum time period for a batch release:	3.50 E+01 min

2.6 Abnormal Releases

No abnormal releases occurred during the reporting period.

3.0 SUMMARY OF GASEOUS RADIOACTIVE EFFLUENTS

The quantities of radioactive material released in gaseous effluents are summarized in Tables 1A and 1B. Plant Vent and Containment Vent releases are modeled as mixed mode and the Air Ejector is modeled as ground level release.

4.0 SUMMARY OF LIQUID RADIOACTIVE EFFLUENTS

The quantities of radioactive material released in liquid effluents are summarized in tables 2A and 2B.

5.0 SOLID WASTE

The quantities of radioactive material released in shipments of solid waste transported from the site during the reporting period are summarized in Table 3. Principal nuclides were determined by gamma spectroscopy and non-gamma emitters were calculated from scaling factors determined by an independent laboratory from representative samples of that waste type. The majority of Dry Active Waste is processed utilizing an off-site processor who reduces the volume and then sends the waste for burial.

6.0 LOWER LIMIT OF DETECTION

The required Lower Limit of Detection, (LLD), as defined in the ODCM, was met for all samples used in reporting effluent releases for 2010.

7.0 RADIOLOGICAL IMPACT

An assessment of doses to the hypothetical maximally exposed individual member of the public from gaseous and liquid effluents was performed for locations representing the maximum calculated dose in occupied sectors. Meteorological sectors from WNW through ENE are entirely over Lake Ontario. In all cases, doses were well below Technical Specification limits as defined in the ODCM. Doses were assessed based upon historical meteorological conditions considering the noble gas exposure, inhalation, ground plane exposure, and ingestion pathways. The ingestion pathways considered were the fruit, vegetable, fish, drinking water, goat's milk, cow's milk and cow meat pathways. Results of this assessment are presented in Tables 4A and 4B.

7.1 Total Dose

40CFR190 limits the total dose to members of the public due to radiation and radioactivity from uranium fuel cycle sources to:

 \leq 25 mrem total body or any organ and; \leq 75 mrem thyroid for a calendar year.

Using the maximum exposure and uptake pathways, the maximum liquid pathways, and the maximum direct radiation measurements at the site boundary, yield the following dose summaries to the hypothetical maximally exposed individual member of the public. Dose to any real member of the public should be conservatively bounded by this calculated dose.

10.4 mrem total body (10.4 mrem direct radiation plus 2.4E-2 mrem all other pathways).

1.5E-2 mrem maximum organ dose (Bone).

8.0 METEOROLOGICAL DATA

The annual summary of hourly meteorological data collected during 2010 is not included with this report, but can be made available at the R. E. Ginna Nuclear Power Plant.

9.0 LAND USE CENSUS CHANGES

There were no major changes in critical receptor location for dose calculations during the reporting period. Minor changes in critical receptor locations and distances came from utilizing updated mapping technologies (hand held global positioning system and Google Earth software). There were no large changes in land use within 5 miles of the plant. Additional new homes are being built at a rate comparable to recent years.

10.0 CHANGES TO THE OFFSITE DOSE CALCULATION MANUAL

There were two changes made to the ODCM during 2010. The first change went into effect on August 10, 2010. This change is summarized as follows.

The revisions to table 5-2 of the Offsite Dose Calculation Manual (ODCM) have been proposed to achieve the following:

- 1. Present the data in an easier to read format.
- 2. Provide latitude and longitude coordinates for the air, water, milk, and dosimeter environmental sampling locations. This information, while not provided in the current version of the ODCM, is intended to provide additional detail regarding the environmental sampling program.
- 3. Update the directions and distances for the various environmental sampling locations.
- Add two new dosimeters to Radiological Environmental Monitoring Program (REMP) for Independent Spent Fuel Storage Installation (ISFSI) direct dose monitoring.

The two new dosimeters have been located to monitor direct dose from the ISFSI in the western and south-southwestern meteorological sectors. ISFSI monitoring in the other meteorological sectors can be achieved using existing environmental sampling locations.

None of the existing sampling locations will be relocated as a result of this ODCM change. The compass directions and distances proposed in revision reflect more

The two new dosimeters have been located to monitor direct dose from the ISFSI in the western and south-southwestern meteorological sectors. ISFSI monitoring in the other meteorological sectors can be achieved using existing environmental sampling locations.

None of the existing sampling locations will be relocated as a result of this ODCM change. The compass directions and distances proposed in revision reflect more accurate measurements of the same locations, which were obtained using three independent technologies: a hand-held global position system (GPS), Google Earth software application, and mathematical equations

The second change went into effect on December 8, 2010. The constituents of this change:

- Definitions Section, page 3. Revising the definition of Dose Equivalent I-131 from the thyroid dose conversion factors outlined in Regulatory Guide 1.109 to those in ICRP 30, Supplement to Part 1, Pages 192-212, table entitled, "Committed Dose Equivalent in Target Organs or Tissues per Intake of Unit Activity", to align with definitions in the Technical Specifications.
- 2. Section 1.7, Liquid Effluent Dose, page 20, 21, and 22. Revising the average annual liquid dilution factor from 20 to 200. This was change was made as a result of a study performed by Hydroqual, titled "R.E. Ginna Nuclear Power Plant. Tracer Dilution Study for the Town of Ontario Municipal Drinking Water Intake." This study was published May 28, 2010. This liquid dilution study was performed as a result of Ontario Water district changing the location of their intake structure. The completed Hydroqual study is available upon request.
- 3. Section 2.0, Radioactive Gaseous Effluents, page 23. Correction to typographical error regarding 10 times 10CFR20 concentration limits at point of release.
- 4. Section 5.2, Table 5-2, page 79. Revised dosimeter sampling location 64 distance from the centerline of the reactor.

11.0 CHANGES TO THE PROCESS CONTROL PROGRAM

There were no changes to the Process Control Program during the reporting period.

12.0 MAJOR CHANGES TO RADWASTE TREATMENT SYSTEMS

There were no major changes to the Radwaste Treatment Systems during the reporting period.

13.0 INOPERABLE MONITORS

None

14.0 CHANGES TO PREVIOUS ANNUAL EFFLUENT OPERATING REPORTS

RPA-RW-PCP, "Process Control Program", was revised in 2007 under Procedure Change Request 2007-3427-001. These changes were to update titles, remove references that no longer existed, remove a configuration that is no longer utilized, and to remove the Green is Clean process that is no longer employed. The changes did not change the intent of the Procedure or the PCP. This change was not included in the 2007 Annual Radioactive Release report as required under Section 6.2 of the ODCM.

RPA-RW-PCP, "Process Control Program", was revised in 2008 under Procedure Change Request 2008-2107-001. This change provided clarification of when Ce-144 may be used to determine transuranics. The change does not change the intent of the PCP. This change was not included in the 2008 Annual Radioactive Release report as required under Section 6.2 of the ODCM.

15.0 GROUNDWATER MONITORING

In accordance with R. E. Ginna Nuclear Power Plant's Chemistry procedures, environmental groundwater monitoring wells are sampled quarterly. There are a total of 10 onsite groundwater monitoring wells:

- One located adjacent to the All Volatile Treatment (AVT) Building.
- Three located east of the Screenhouse, screened at 3 depths to include groundwater from top of the water table down to bedrock.
- Two located East of the Containment near the Technical Support Center (TSC)
- One southwest of the Administration Building.
- One to the west of the Screenhouse.
- One to the southeast of the Contaminated Storage Building (CSB).
- One located one-half mile southwest of the plant in the upgradient direction to serve as a control well.

Groundwater samples are analyzed for tritium to a detection limit of 500 pCi/L, and for gamma emitting radionuclides to the environmental LLDs. In 2010, no plant radioactivity was detected in groundwater samples.

Results of the groundwater monitoring well sampling are presented in Table 5.

Table 1A

EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT

GASEOUS EFFLUENTS - SUMMATION OF ALL RELEASES

January - June 2010

	Unit	Quarter	Quarter	Est. Total
A. Fission & Activation Gases		1st	2nd	Error, %
1. Total release	Ci	1.67E-01	2.92E-01	1.50E+01
2. Average release rate for period	uCi/sec	2.11E-02	3.70E-02	
3. Percent of technical specification limit	%	3.35E-06	5.87E-06	
B. lodines				
1. Total iodine-131	Ci	8.73E-09		1.50E+01
2. Average release rate for period	uCi/sec	1.11E-09		
3. Percent of technical specification limit	%	2.41E-06		
C. Particulates				
1. Particulates with half-lives > 8days	Ci			
2. Average release rate for period	uCi/sec			
3. Percent of technical specification limit	%			
4. Gross alpha radioactivity	Ci			
D. Tritium				-
1. Total release	Ci	1.62E+01	1.24E+01	9.20E+00
2. Average release rate for period	uCi/sec	2.05E+00	1.57E+00	
3. Percent of technical specification limit	%	2.40E-04	1.84E-04	<u> </u>

Table 1A EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT GASEOUS EFFLUENTS - SUMMATION OF ALL RELEASES International Content of the Content of t

July - December 2010

	Unit	Quarter	Quarter	Est. Total
A. Fission & Activation Gases		3rd	4th	Error, %
1. Total release	Ci	3.96E-01	3.01E-01	1.50E+02
2. Average release rate for period	uCi/sec	5.02E-02	3.81E-02	
3. Percent of technical specification limit	%	7.97E-06	6.05E-06	
B. lodines				
1. Total iodine-131	Ci		1.56E-06	1.50E+0
2. Average release rate for period	uCi/sec		1.97E-07	
3. Percent of technical specification limit	%		4.28E-04]
S. referre of reenhear specification inne		L]
C. Particulates	Ci	L		,
	Ci			
C. Particulates 1. Particulates with half-lives > 8days				
C. Particulates 1. Particulates with half-lives > 8days 2. Average release rate for period	Ci uCi/sec]
C. Particulates 1. Particulates with half-lives > 8days 2. Average release rate for period 3. Percent of technical specification limit	Ci uCi/sec %			
 C. Particulates 1. Particulates with half-lives > 8days 2. Average release rate for period 3. Percent of technical specification limit 4. Gross alpha radioactivity 	Ci uCi/sec %	1.62E+01	1.17E+01	9.20E+0
C. Particulates 1. Particulates with half-lives > 8days 2. Average release rate for period 3. Percent of technical specification limit 4. Gross alpha radioactivity D. Tritium	Ci uCi/sec % Ci	1.62E+01 2.06E+00		9.20E+0

Table 2A **EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT** LIQUID EFFLUENTS - SUMMATION OF ALL RELEASES January - June 2010

	Unit	Quarter	Quarter	Est.Total
	Unit			
A. Fission and activation products		1st	2nd	Error, %
1. Total release (not including tritium,	Ci	1.23E-03	6.97E-05	9.90E+00
gases, alpha)		1.202 00		5.502.00
2. Average diluted concentration	uCi/ml	3.03E-12	1.42E-13	
during period	uci/ini	5.05E-12	1.426-13	
3. Percent of applicable limit	%	3.03E-05	1.42E-06	
B. Tritium				
1. Total release	Ci	1.42E+02	3.28E+01	9.20E+00
2. Average diluted concentration	. Ci /mat	2 515 07	C 71F 00	
during period	uCi/ml	3.51E-07	6.71E-08	
3. Percent of applicable limit	%	3.51E-03	6.71E-04	
C. Dissolved and entrained gases				
1. Total release	Ci			
2. Average diluted concentration during period	uCi/ml			
3. Percent of applicable limit	%			-
D. Gross alpha radioactivity				
1. Total release	Ci			
	·		· · · · · · · · · · · · · · · · · · ·	-
E. Vol. of waste released (prior to dilution)	Liters	9.67E+07	1.00E+08]
				-
F. Vol. of dilution water used during period	Liters	4.04E+11	4.90E+11	

Table 2A EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT LIQUID EFFLUENTS - SUMMATION OF ALL RELEASES July - December 2010

	Unit	Quarter	Quarter	Est.Total
A. Fission and activation products		3rd	4th	Error, %
1. Total release (not including tritium,				
gases, alpha)	Ci			
2. Average diluted concentration	uCi/ml			
during period	ucijini			
3. Percent of applicable limit	%			
B. Tritium				
1. Total release	Ci	3.20E+01	5.00E+01	9.20E+00
2. Average diluted concentration	C:/ml	C 225 00	1.045.07	
during period	uCi/ml -	6.33E-08	1.04E-07	
3. Percent of applicable limit	%	6.33E-04	1.04E-03	1
C. Dissolved and entrained gases				
1. Total release	Ci			
2. Average diluted concentration	<u> </u>			
during period	uCi/ml			
3. Percent of applicable limit	%]
D. Gross alpha radioactivity	·····			-
1. Total release	Ci	L	L	-
E. Vol. of waste released (prior ro dilution)	Liters	1.00E+08	1.00E+08	1
		• • • • • • • • • • • • • • • • • • • •	· · · · · · · · · · · · · · · · · · ·]
F. Vol. of dilution water used during period	Liters	5.05E+11	4.81E+11	

Note: Isotopes for which no value is given were not identified in applicable releases.

ŀ

Table 1BEFFLUENT AND WASTE DISPOSAL ANNUAL REPORTGASEOUS EFFLUENTS - CONTINUOUS AND BATCH RELEASES

January		June	2010
---------	--	------	------

		Continuc	ous Mode	Batch	Mode
Nuclides released	Unit	Quarter	Quarter	Quarter	Quarter
		1st	2nd	1st	2nd
1. Fission gases					
argon-41	Ci			7.08E-02	7.12E-02
krypton-85	Ci				
krypton-85m	Ci				
krypton-87	Ci				
krypton-88	Ci				
xenon-131m	Ci				
xenon-133	Ci			9.46E-02	2.17E-01
xenon-133m	Ci				
xenon-135	Ci			1.26E-03	3.40E-03
xenon-135m	Ci				
xenon-138	Ci				
others (specify)	Ci				
	Ci				
Total for period	Ci			1.67E-01	2.92E-01

2. lodines

.

	4	
iodine-131	Ci	8.73E-09
iodine-132	Ci	
iodine-133	Ci	
iodine-135	Ci	
Total for period	Ci	8.73E-09

3. Particulates

strontium-89	Ci			
strontium-90	Ci	 	 	
cesium-134	Ci		 	 •
cesium-137	Ci	 	 	
cobalt-58	Ci	 	 	
unidentified	Ci	 	 	 <u> </u>
Total for period	Ci		 	

4. Tritium

Hydrogen-3	Ci	1.60E+01	1.23E+01	1.65E-01	6.86E-02

Table 1BEFFLUENT AND WASTE DISPOSAL ANNUAL REPORTGASEOUS EFFLUENTS - CONTINUOUS AND BATCH RELEASES

July - December 2010

		Continuous Mode		Batch Mode	
Nuclides released	Unit	Quarter	Quarter	Quarter	Quarter
		3rd	4th	3rd	4th
1. Fission gases			· · · · · · · · · · · · · · · · · · ·		
argon-41	Ci			6.87E-02	7.13E-02
krypton-85	Ci				
krypton-85m	Ci				
krypton-87	Ci				
krypton-88	Ci				
xenon-131m	Ci				
xenon-133	Ci			3.22E-01	2.26E-01
xenon-133m	Ci				
xenon-135	Ci			4.75E-03	3.47E-03
xenon-135m	Ci				
xenon-138	Ci				
others (specify)	Ci				
	Ci	1			
unidentified	Ci				
Total for period	Ci			3.95E-01	3.01E-01

2. lodines

Total for period	Ci	6.74E-06	
iodine-135	Ci		
iodine-133	Ci	5.18E-06	
iodine-131	Ci	1.56E-06	

3. Particulates

strontium-89	Ci				
strontium-90	Ci	 	 		
cesium-134	Ci		 		
cesium-137	Ci		 		
cobalt-58	Ci	 	 		
unidentified	Ci	 	 <u> </u>		
Total for period	Ci			_	•

4. Tritium

Hvdrogen-3	Ci	1.61E+01	1.16E+01	8.27E-02	2.95E-02
	L		11102.01	01272 02	2.552.02

Table 2B EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT Liquid Effluents January - June 2010

		Continuc	ous Mode	Batch Mode			
Nuclides Released	Unit	Quarter	Quarter	Quarter	Quarter		
		1st	2nd	1st	2nd		
chromium-51	Ci	· · · · · · · · · · · · · · · · · · ·					
manganese-54	Ci						
iron-55	Ci						
iron-59	Ci						
cobalt-58	Ci			1.22E-03	6.97E-05		
cobalt-60	Ci			1.94E-08			
zinc-65	Ci						
strontium-89	Ci						
strontium-90	Ci				••••••••••••••••••••••••••••••••••••••		
niobium-95	Ci						
molybdenum-99	Ci	· · · · · · · · · · · · · · · · · · ·			· · · · · · · · · · · · · · · · · · ·		
silver-110m	Ci			······································			
antimony-122	Ci	<u> </u>					
antimony-124	Ci				· · · · · · · · · · · · · · · · · · ·		
antimony-125	Ci						
iodine-131	Ci						
iodine-132	Ci						
iodine-135	Ci			**			
cesium-134	Ci						
cesium-136	Ci						
cesium-137	Ci	····					
barium/lanthanum-							
140	Ci				,		
cerium-141	Ci						
Te-123m	Ci			7.35E-06			
Zr-95	Ci						
Co-57	Ci	· · · · · · · · · · · · · · · · · · ·					
Total for period							
(above)	Ci		· · · · · · · · · · · · · · · · · · ·	1.23E-03	6.97E-05		
unidentified	Ci						
Tritium	Ci	6.42E-02	1.33E-01	1.42E+02	3.27E+01		
xenon-133	Ci						
xenon-135	Ci						

Table 2B EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT Liquid Effluents

July - December 2010

		Continuo	us Mode	Batch Mode			
Nuclides Released	Unit	Quarter	Quarter	Quarter	Quarter		
		3rd	4th	3rd	4th		
chromium-51	Ci						
manganese-54	Ci				· · · · · · · · · · · · · · · · · · ·		
iron-55	Ci				· · · · · · · · · · · · · · · · · · ·		
iron-59	Ci						
cobalt-58	Ci						
cobalt-60	Ci						
zinc-65	Ci						
strontium-89	Ci						
strontium-90	Ci						
niobium-95	Ci						
molybdenum-99	Ci						
silver-110m	Ci				<u> </u>		
antimony-122	Ci						
antimony-124	Ci						
antimony-125	Ci						
iodine-131	Ci				*		
iodine-132	Ci						
iodine-135	Ci						
cesium-134	Ci				· · · · · · · · · · · · · · · · · · ·		
cesium-136	Ci						
cesium-137	Ci						
barium/lanthanum-							
140	Ci						
cerium-141	Ci			· · · · · · · · · · · · · · · · · · ·			
Te-123m	Ci						
Zr-95	Ci	<u></u>					
Co-57	Ci						
Total for period (above)	Ci						
unidentified	Ci				······		
Tritium	Ci	1.81E-01	1.78E-01	3.18E+01	4.99E+01		
xenon-133	Ci						
xenon-135	Ci						

Table 3 **EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT** SOLID WASTE AND IRRADIATED FUEL SHIPMENTS January 1, 2009 - December 31, 2009

A. SOLID WASTE SHIPPED OFFSITE FOR BURIAL OR DISPOSAL- (Not irradiated fuel)

1. Type of waste	Unit	12 month period	Est. total Error %
a.Spent resins, filter sludges, evaporator bottoms, etc.	m³ Ci	8.55 20.2	7.0 E+00 1.4 E+01
b. Dry compressible waste, contaminated equip, etc.	m³ Ci	237.8 0.724	7.0 E+00 1.4 E+01
c.Irradiated components, control rods, etc.	m³ Ci	None	N/A N/A
d.Other: None	m³ Ci	None	N/A N/A

	2.Estimate of major nuclide composition (by type of waste)									
	а.			b.			С.			
Co-58	%	2.23	Co-58	%	8.35	None	%	None		
Ni-63	%	61.13	Fe-55	%	2.93		%	· · · · · · · · · · · · · · · · · · ·		
C-14	%	7.73	Sb-125	%	6.38		%			
Cs-137	%	2.5	Co-60	%	3.43		%			
Co-60	%	9.3	Ni-63	%	76.8		%			
Fe-55	%	8.18	Mn-54	%	0.68		%			
Mn-54	%	0.13	Ni-59	%	0.28		%			
Ni-59	%	4.68	Co-57	%	0.35		%			
H-3	%	2.16	Cs-137	%	0.03		%			
Sb-125	%	0.45	Ag-110m	%	0.27		%			
Nb-95	%	0.11		%			%			
Total		98.6%	Total		99.5	Total		0		

3. Solid Waste Disposition	n	
Number of Shipments	Mode of Transportation	Destination
4	Sole Use Truck	Energy Solutions
5	Sole Use Truck	Studsvic

B. IRRADIATED FUEL SHIPMENTS (Disposition)

Number of Shipments	Mode of Transportation	Destination
None		

Table 4A Radiation Dose to Maximum Individual Receptor First Quarter 2010 (Units In milliRem)

	All	All	Adult	Teen	Child	Infant
	Gamma Air	Beta Air	THYRD	THYRD	THYRD	THYRD
N	1.88E-06	9.08E-07	2.23E-04	2.45E-04	3.36E-04	1.47E-04
NNE	1.58E-06	7.61E-07	1.87E-04	2.05E-04	2.81E-04	1.23E-04
NE	1.82E-06	8.77E-07	2.16E-04	2.36E-04	3.24E-04	1.42E-04
ENE	2.31E-06	1.11E-06	2.74E-04	3.00E-04	4.12E-04	1.80E-04
E	4.21E-06	2.03E-06	4.98E-04	5.46E-04	7.50E-04	3.28E-04
ESE	5.35E-06	2.58E-06	6.34E-04	6.95E-04	9.54E-04	4.17E-04
SE	3.24E-06	1.56E-06	3.84E-04	4.20E-04	5.77E-04	2.52E-04
SSE	1.33E-06	6.42E-07	1.58E-04	1.73E-04	2.38E-04	1.04E-04
S	2.33E-06	1.12E-06	2.76E-04	3.03E-04	4.16E-04	1.82E-04
SSW	2.33E-06	1.12E-06	2.76E-04	3.03E-04	4.16E-04	1.82E-04
SW	2.33E-06	1.12E-06	2.76E-04	3.03E-04	4.16E-04	1.82E-04
WSW	2.49E-06	1.20E-06	2.95E-04	3.23E-04	4.44E-04	1.94E-04
W	1.58E-06	7.64E-07	1.88E-04	2.06E-04	2.82E-04	1.23E-04
WNW	1.34E-07	6.45E-08	1.59E-05	1.74E-05	2.39E-05	1.04E-05
NW	4.39E-07	2.12E-07	5.20E-05	5.70E-05	7.82E-05	3.42E-05
NNW	1.37E-06	6.60E-07	1.62E-04	1.78E-04	2.44E-04	1.07E-04
MAX.	5.35E-06	2.58E-06	6.34E-04	6.95E-04	9.54E-04	4.17E-04

19

,

Table 4A Radiation Dose to Maximum Individual Receptor Second Quarter 2010 (Units In milliRem)

	liA	All	Aduit	Teen	Child	Infant
	Gamma Air	Beta Air	THYRD	THYRD	THYRD	THYRD
N	2.02E-06	1.27E-06	1.55E-06	1.69E-04	2.33E-04	1.02E-04
NNE	1.70E-06	1.07E-06	1.30E-06	1.42E-04	1.95E-04	8.53E-05
NE	1.96E-06	1.23E-06	1.50E-06	1.64E-04	2.25E-04	9.83E-05
ENE	2.48E-06	1.56E-06	1.90E-06	2.08E-04	2.86E-04	1.25E-04
E	4.52E-06	2.85E-06	3.46E-06	3.78E-04	5.20E-04	2.27E-04
ESE	5.75E-06	3.62E-06	4.40E-06	4.81E-04	6.61E-04	2.89E-04
SE	3.48E-06	2.19E-06	2.66E-06	2.91E-04	4.00E-04	1.75E-04
SSE	1.43E-06	9.01E-07	1.10E-06	1.20E-04	1.65E-04	7.20E-05
S	2.51E-06	1.58E-06	1.92E-06	2.10E-04	2.88E-04	1.26E-04
SSW	2.51E-06	1.58E-06	1.92E-06	2.10E-04	2.88E-04	1.26E-04
SW	2.51E-06	1.58E-06	1.92E-06	2.10E-04	2.88E-04	1.26E-04
WSW	2.67E-06	1.68E-06	2.05E-06	2.24E-04	3.07E-04	1.34E-04
W	1.70E-06	1.07E-06	1.30E-06	1.42E-04	1.96E-04	8.55E-05
WNW	1.44E-07	9.05E-08	1.10E-07	1.20E-05	1.65E-05	7.23E-06
NW	4.72E-07	2.97E-07	3.61E-07	3.94E-05	5.42E-05	2.37E-05
NNW	1.47E-06	9.27E-07	1.13E-06	1.23E-04	1.69E-04	7.40E-05
MAX.	5.75E-06	3.62E-06	4.40E-06	4.81E-04	6.61E-04	2.89E-04

~

20

.

Table 4ARadiation Dose to Maximum Individual ReceptorThird Quarter 2010(Units In milliRem)

	All	All	Adult	Teen	Child	Infant
	Gamma Air	Beta Air	THYRD	THYRD	THYRD	THYRD
Ν	2.07E-06	1.56E-06	2.03E-04	2.22E-04	3.05E-04	1.33E-04
NNE	1.73E-06	1.31E-06	1.70E-04	1.86E-04	2.56E-04	1.12E-04
NE	2.00E-06	1.51E-06	1.96E-04	2.15E-04	2.95E-04	1.29E-04
ENE	2.54E-06	1.91E-06	2.49E-04	2.73E-04	3.75E-04	1.64E-04
E	4.61E-06	3.48E-06	4.54E-04	4.96E-04	6.81E-04	2.98E-04
ESE	5.87E-06	4.43E-06	5.77E-04	6.31E-04	8.67E-04	3.79E-04
SE	3.55E-06	2.68E-06	3.49E-04	3.82E-04	5.25E-04	2.29E-04
SSE	1.46E-06	1.10E-06	1.44E-04	1.57E-04	2.16E-04	9.44E-05
S	2.56E-06	1.93E-06	2.52E-04	2.75E-04	3.78E-04	1.65E-04
SSW	2.56E-06	1.93E-06	2.52E-04	2.75E-04	3.78E-04	1.65E-04
sw	2.56E-06	1.93E-06	2.52E-04	2.75E-04	3.78E-04	1.65E-04
WSW	2.73E-06	2.06E-06	2.68E-04	2.93E-04	4.03E-04	1.76E-04
w	1.74E-06	1.31E-06	1.71E-04	1.87E-04	2.57E-04	1.12E-04
WNW	1.47E-07	1.11E-07	1.44E-05	1.58E-05	2.17E-05	9.48E-06
NW	4.81E-07	3.63E-07	4.73E-05	5.17E-05	7.11E-05	3.11E-05
NNW	1.50E-06	1.13E-06	1.48E-04	1.62E-04	2.22E-04	9.70E-05
MAX.	5.87E-06	4.43E-06	5.77E-04	6.31E-04	8.67E-04	3.79E-04

21

.

Table 4ARadiation Dose to Maximum Individual ReceptorFourth Quarter 2010(Units In milliRem)

1

-

	Ali	All	Adult	Teen	Child	Infant
	Gamma Air	Beta Air	THYRD	THYRD	THYRD	THYRD
Ν	2.03E-06	1.30E-06	1.89E-04	2.07E-04	2.84E-04	1.24E-04
NNE	1.71E-06	1.09E-06	1.58E-04	1.73E-04	2.38E-04	1.04E-04
NE	1.97E-06	1.26E-06	1.83E-04	2.00E-04	2.75E-04	1.20E-04
ENE	2.50E-06	1.60E-06	2.32E-04	2.54E-04	3.49E-04	1.52E-04
E	4.54E-06	2.91E-06	4.22E-04	4.62E-04	6.35E-04	2.77E-04
ESE	5.78E-06	3.70E-06	5.37E-04	5.88E-04	8.08E-04	3.53E-04
SE	3.50E-06	2.24E-06	3.25E-04	3.56E-04	4.89E-04	2.14E-04
SSE	1.44E-06	9.21E-07	1.34E-04	1.46E-04	2.01E-04	8.79E-05
S	2.52E-06	1.61E-06	2.34E-04	2.56E-04	3.52E-04	1.54E-04
SSW	2.52E-06	1.61E-06	2.34E-04	2.56E-04	3.52E-04	1.54E-04
sw	2.52E-06	1.61E-06	2.34E-04	2.56E-04	3.52E-04	1.54E-04
WSW	2.69E-06	1.72E-06	2.50E-04	2.73E-04	3.76E-04	1.64E-04
W	1.71E-06	1.10E-06	1.59E-04	1.74E-04	2.39E-04	1.04E-04
WNW	1.45E-07	9.25E-08	1.34E-05	1.47E-05	2.02E-05	8.83E-06
NW	4.74E-07	3.03E-07	4.40E-05	4.82E-05	6.63E-05	2.89E-05
NNW	1.48E-06	9.47E-07	1.37E-04	1.51E-04	2.07E-04	9.04E-05
MAX.	5.78E-06	3.70E-06	5.37E-04	5.88E-04	8.08E-04	3.53E-04

22

Table 4B

.

Radiation Dose To Maximum Individual Receptor

From Liquid Release 2010

(Units in milliRem)

	Adult	Teen	Child	Infant		
First Quarter						
T. Body	1.61E-03	1.17E-03	1.78E-03	1.40E-03		
GI-LLI	1.64E-03	1.19E-03	1.78E-03	1.40E-03		
Thyroid	1.60E-03	1.16E-03	1.77E-03	1.40E-03		
		Second Quarter				
T. Body	2.89E-04	2.10E-04	3.20E-04	2.53E-04		
GI-LLI	2.91E-04	2.11E-04	3.20E-04	2.53E-04		
Thyroid	2.89E-04	2.10E-04	3.20E-04	2.53E-04		
	IT	nird Quarter				
T. Body	2.83E-04	2.06E-04	3.13E-04	2.47E-04		
GI-LLI	2.83E-04	2.06E-04	3.13E-04	2.47E-04		
Thyroid	2.83E-04	2.06E-04	3.13E-04	2.47E-04		
Fourth Quarter						
T. Body	3.64E-04	2.67E-04	3.79E-04	2.73E-04		
GI-LLI	3.64E-04	2.67E-04	3.79E-04	2.73E-04		
Thyroid	3.64E-04	2.67E-04	3.79E-04	2.73E-04		

TABLE 5

Groundwater Monitoring Wells

Location	Sample Date	Tritium
GW01: Warehouse Access Road (Control)	09/23/10	*
	12/10/10	*
GW02: Butler Building	03/17/10	*
	06/08/10	*
GW04: Screenhouse West, North Well	03/31/10	*
ing senger part of the sense of the	05/12/10	*
	06/08/10	*
nare activities and an	07/14/10	*
	09/23/10	*
мала мала на са става на става на става со става со става со става со става со става на става со става со става На става со става на става на става со с	10/15/10	*
	; 10/10/10	*
taran 1 minyamperinan manganan yang manganan i ka amba i mara ama ana ama ama ama ama ama ama a ama am	12/10/10	*
GW05: Screenhouse East, South (15.5')	03/17/10	*
	04/13/10	*
n serena musee and a serena and a serena serena and a serena serena serena serena serena serena serena serena s	06/08/10	*
ու առուղ լուծ է նուն առու ործ նանա առուղը է է 1011 ան առուղը տարոր որ դուրը է նախ տեսուլ այցի հետանաններութը հետաորադուրը է ենետաորադուրը և են	09/23/10	*
չությունը, որորդությունը, որորդությունը, որորդությունը, որոլ անդնարձնուրվությունը թրառու վորըներ, որորդությունը անդան	12/10/10	i *
GW06: Screenhouse East, Middle (20.0')	03/17/10	*
	04/13/10	*
	05/12/10	*
๚๚๚๚๚๚๚๚๚๚๚๚๚๚๚๚๚๚๚๚๚๚๚๚๚๚๚๚๚๚๚๚๚๚๚๚๚๚	06/08/10	*
	07/14/10	*
amarkenna mandaran ana mandaran ata ana da ma da ma da ka mata ana mandaran da mata ana da marka da da mandaran	08/17/10	*
	09/23/10	*
៱ៜ៰៹៘៹៴៹៹៹ៜ៳៳៳៳៳៳៳៳៹៳៹៹៹៹៹៳៳៳៳៳៳៳៹៳៹៹៹៹៹ ៷៹ ៳៳៳៳៹៹៷ៜ៹៸ៜ៰៰៱៹៹៹ៜៜ៹ៜ៰៰៳៳៳៹៹៷ៜ៷៹ៜ៳៳៳៳៳៳៳៳៳៳៳៳៳៳៳៳៳៳៳៳៳	12/10/10	*
GW07: Screenhouse East, North (24.0')	03/17/10	*
	04/13/10	*
੶੶੶੶₩₩₽₽₩₽₽₽₩₽₽₩₽₽₩₽₽₩₽₽₩₽₩₽₩₽₩₽₩₽₽₩₽₽₩₽	06/08/10	*
๛๚๛๚๛๛๛๛๛๛๛๛๛๛๛๛๛๛๛๛๛๛๛๛๛๛๛๛๛๛๛๛๛๛๛๛๛๛	09/23/10	ala ana amin'ny faratra amin'ny faratra dia dia dia dia dia dia dia dia dia di
֍ՠՠֈՠՠֈֈֈ֍֎ՠՠՠֈՠֈՠֈՠՠ֍ՠ֎ՠֈՠֈ֍֎ՠՠֈ֎֍ՠՠ֍֍ՠՠֈՠՠ֎ՠՠ֍ՠ֍ՠՠՠ֍ՠՠ		*
CNA(08: All Valatilas Treatment Ruilding	12/10/10	*
GW08: All Volatiles Treatment Building	09/23/10 10/15/10	*
		*
	11/10/10	*
OM/00 Taskainal Quanant Cantan Marth	12/10/10	*
GW09: Technical Support Center, North	09/24/10	*
OW(40) Technical Quenet Queter Quet	12/10/10	*
GW10: Technical Support Center, South	09/24/10	
	12/10/10	*
GW11: Contaminated Service Building, SE (24.0')	03/17/10	*
	06/08/10	*
	06/11/10	*
	06/19/10	*
	09/23/10	*
	12/10/10	*

* - Activity less than detectable (Tritium)

Table 6

2010 Offsite Dose Due to Carbon-14

R E Ginna Nuclear Power Plant

A study of Carbon-14 in effluent releases from Ginna was conducted in 1982 by Charles Kunz of New York State Department of Health, Center for Laboratories and Research. Results of this study are used as the basis for current Carbon-14 production and releases at Ginna. Using the Carbon-14 releases measured in the Kunz study at 4.3 Curies, adjusted for power uprate from 490 MWe to 580 MWe, and adjusted for increased capacity factor, leads to a conservative estimate of 6.8 Curies released in gaseous effluents in 2010. Kunz further determined the chemical form of the Carbon-14 at Ginna to be approximately 10% CO2.

As a cross-check, the EPRI Carbon-14 Source Term Calculator was used to estimate Carbon-14 releases from Ginna, using Ginna specific reactor core data and reactor coolant chemistry to estimate the products of the activation reactions. The resulting estimate of 6.9 Curies per EFPY agrees with the Kunz data.

Dose due to Carbon-14 in gaseous effluents was calculated using the following conditions:

- a. 6.8 Curies of C-14 released to atmosphere in 2010
- b. Release was consistent throughout the year. There was no outage in 2010.
- c. 10% of the C-14 was in the chemical form of CO2, which is the only dose contributor. The bulk of C-14 was in the chemical form of methane (CH4) which would exhibit high upward velocity due to its low density relative to air. In addition CH4 does not have an uptake pathway for humans.
- d. Meteorological dispersion factor, (X/Q), at the site boundary to the hypothetical maximally exposed member of the public is 2.43E-07 sec/m³.
- e. Dose calculations and dose factors are from Regulatory Guide 1.109 methodology.
- f. Pathways considered were inhalation and vegetation ingestion.
- g. Critical receptor is child at the site boundary in the ESE direction.

MAXIMUM DOSE VALUES DUE TO C-14 IN GASEOUS EFFLUENTS IN 2010

Organ	Age	mRem/yr
RG-1.109 Bone	Child	1.94E-02
RG-1.109 T.Body/Other	Child	3.86E-03

Dose due to Carbon-14 in liquid effluents was calculated using the following conditions:

- a. The liquid waste processing system at Ginna has not been evaluated for efficiency of removal of Carbon-14. Therefore no removal term was used in estimation of offsite dose.
- b. Average concentration of C-14 in waste water as measured in the Kunz study was adjusted for current operating conditions and was 6.0E-7 uCi/cc.
- c. 1.99E6 liters of liquid waste were released in 2010 with total dilution flow of 1.88E12 liters.
- d. Average diluted concentration of C-14 released was 6.35E-13 uCi/cc.
- e. Liquid effluent dilution factor for potable water pathway is 20.
- f. Liquid effluent dilution factor for fish pathway is 1.
- g. Dose calculations and dose factors are from Regulatory Guide 1.109 methodology.
- h. Critical receptor is teen for both potable water and fish pathways.

MAXIMUM DOSE VALUES DUE TO C-14 IN LIQUID EFFLUENTS IN 2010

Organ	Age	mRem/yr
RG-1.109 Bone	Teen	1.90E-04
RG-1.109 T.Body/Other	Teen	3.79E-05