

Pham, Bo

From: Pham, Bo
Sent: Wednesday, September 29, 2010 8:29 AM
To: Harris, Brian
Cc: Perkins, Leslie
Subject: Appendices for Salem & HCGS SAMA

Hi Brian,

Attached are the Appendices that go with Chapter 5 of the DSEIS. Leslie asked me to fwd them to you.
Thanks.



Appendix F
V.1.docx



Appendix
G.V.1.docx

Bo Pham
Chief, Projects Branch 1
Division of License Renewal
Office of Nuclear Reactor Regulation
U.S. Nuclear Regulatory Commission
301-415-8450

D-174

[Handwritten mark]

1
2
3
4
5
6

Appendix F
U.S. Nuclear Regulatory Commission Staff Evaluation of
Severe Accident Mitigation Alternatives for
Salem Nuclear Generating Station Units 1 and 2
In Support of License Renewal Application Review

This Page Intentionally Left Blank

F. U.S. Nuclear Regulatory Commission Staff Evaluation of Severe Accident Mitigation Alternatives for Salem Nuclear Generating Station Units 1 and 2 in Support of License Renewal Application Review

F.1 Introduction

PSEG Nuclear, LLC, (PSEG) submitted an assessment of severe accident mitigation alternatives (SAMAs) for the Salem Nuclear Generating Station (SGS) as part of the environmental report (ER) (PSEG 2009). This assessment was based on the most recent Salem probabilistic risk assessment (PRA) available at that time, a plant-specific offsite consequence analysis performed using the MELCOR Accident Consequence Code System 2 (MACCS2) computer code, and insights from the Salem individual plant examination (IPE) (PSEG 1993) and individual plant examination of external events (IPEEE) (PSEG 1996). In identifying and evaluating potential SAMAs, PSEG considered SAMAs that addressed the major contributors to core damage frequency (CDF) and release frequency at SGS, as well as SAMA candidates for other operating plants that have submitted license renewal applications. PSEG initially identified 27 potential SAMAs. This list was reduced to 25 unique SAMA candidates by eliminating SAMAs that are not applicable to Salem due to design differences, have already been implemented at SGS, would achieve the same risk reduction results that had already been achieved at SGS by other means, or have excessive implementation cost. PSEG assessed the costs and benefits associated with each of the potential SAMAs and concluded in the ER that several of the candidate SAMAs evaluated are potentially cost-beneficial.

Based on a review of the SAMA assessment, the U.S. Nuclear Regulatory Commission (NRC) staff issued a request for additional information (RAI) to PSEG by letter dated April 12, 2010 (NRC 2010a) and, based on a review of the RAI responses, a request for RAI response clarification by teleconference dated July 29, 2010 (NRC 2010b). Key questions concerned: discussing internal and external review comments on the PRA model, including the impact of the Pressurized Water Reactor (PWR) Owner's Group PRA peer review comments on the SAMA analysis results; clarifying the development bases and assumptions for the Level 2 PRA model; additional details on the quality and implementation status of the SGS fire risk model; the SAMA screening process and additional potential SAMAs not previously considered; and further information on the costs and benefits of several specific candidate SAMAs. PSEG submitted additional information by a letters dated May 24, 2010 (PSEG 2010a) and August 18, 2010 (PSEG 2010b). In the responses, PSEG provided: a listing of open gaps and "key findings" from the 2008 PRA peer review and an assessment of their impact on the SAMA analysis; clarification of Level 2 PRA modeling details and assumptions; further details on the SGS fire PRA model; analyses of additional SAMAs; and additional information regarding several specific SAMAs. The licensee's responses addressed the NRC staff's concerns.

1 An assessment of SAMAs for SGS is presented below.

2 **F.2 Estimate of Risk for Salem**

3 PSEG's estimates of offsite risk at SGS are summarized in Section F.2.1. The summary is
4 followed by the NRC staff's review of PSEG's risk estimates in Section F.2.2.

5 **F.2.1 PSEG's Risk Estimates**

6 Two distinct analyses are combined to form the basis for the risk estimates used in the SAMA
7 analysis: (1) the SGS Level 1 and 2 PRA model, which is an updated version of the IPE (PSEG
8 1993), and (2) a supplemental analysis of offsite consequences and economic impacts
9 (essentially a Level 3 PRA model) developed specifically for the SAMA analysis. The SAMA
10 analysis is based on the most recent SGS Level 1 and Level 2 PRA model available at the time
11 of the ER, referred to as the Salem PRA (Revision 4.1, September 2008 model of record
12 (MOR)). The scope of this Salem PRA does not include external events.

13 The SGS CDF is approximately 4.8×10^{-5} per year for internal events as determined from
14 quantification of the Level 1 PRA model at a truncation of 1×10^{-11} per year. When determined
15 from the sum of the containment event tree (CET) sequences, or Level 2 PSA model, the
16 release frequency (from all release categories, which consist of intact containment, late release,
17 and early release) is approximately 5.0×10^{-5} per year, also at a truncation of 1×10^{-11} per year.
18 The latter value was used as the baseline CDF in the SAMA evaluations (PSEG 2009). The
19 CDF is based on the risk assessment for internally initiated events, which includes internal
20 flooding. PSEG did not explicitly include the contribution from external events within the SGS
21 risk estimates; however, it did account for the potential risk reduction benefits associated with
22 external events by multiplying the estimated benefits for internal events by a factor of 2. This is
23 discussed further in Sections F.2.2 and F.6.2.

24 The breakdown of CDF by initiating event is provided in Table F-1. As shown in this table,
25 events initiated by loss of control area ventilation, loss of offsite power, and loss of service water
26 are the dominant contributors to the CDF. PSEG identified that Station Blackout (SBO)
27 contributes 8×10^{-6} per year, or 17 percent, to the total internal events CDF (PSEG 2010a).

28 **Table F-1. SGS Core Damage Frequency for Internal Events**

Initiating Event	CDF ¹ (per year)	% Contribution to CDF ²
Loss of Control Area Ventilation	1.8×10^{-5}	37
Loss of Off-site Power (LOOP)	8.1×10^{-6}	17
Loss of Service Water	6.6×10^{-6}	14
Internal Floods	4.5×10^{-6}	9

Transients	4.0×10^{-6}	8
Steam Generator Tube Rupture (SGTR)	2.7×10^{-6}	6
Loss of Component Cooling Water (CCW)	1.0×10^{-6}	2
Anticipated Transient Without Scram (ATWS)	7.4×10^{-7}	2
Loss of 125V DC Bus A	6.9×10^{-7}	1
Others (less than 1 percent each) ³	1.8×10^{-6}	4
Total CDF (internal events)	4.8×10^{-5}	100

¹Calculated from Fussel-Vesely risk reduction worth (RRW) provided in response to NRC staff RAI 1.e (PSEG 2010).

²Based on Internal Events CDF contribution and total Internal Events CDF.

³CDF value derived as the difference between the total Internal Events CDF and the sum of the individual internal events CDFs calculated from RRW.

1 The Level 2 Salem PRA model that forms the basis for the SAMA evaluation is essentially a
 2 complete revision of the original IPE Level 2 model and conforms to current industry guidance.
 3 The Level 2 model utilizes a single CET containing both phenomenological and systemic
 4 events. The Level 1 core damage sequences are binned into accident classes which provide
 5 the interface between the Level 1 and Level 2 CET analysis. The CET is linked directly to the
 6 Level 1 event trees and CET nodes are evaluated using supporting fault trees and logic rules.

7 The result of the Level 2 PRA is a set of 11 release or source term categories, with their
 8 respective frequency and release characteristics. The results of this analysis for SGS are
 9 provided in Table E.3-6 of ER Appendix E (PSEG 2009). The categories were defined based
 10 on the timing of the release, the initiating event, whether feedwater is available, and the
 11 containment failure mode. The frequency of each release category was obtained by summing
 12 the frequency of the individual accident progression CET endpoints binned into the release
 13 category. Source terms were developed for each of the 11 release categories using the results
 14 of Modular Accident Analysis Program (MAAP Version 4.0.6) computer code calculations
 15 (PSEG 2010a).

16 The offsite consequences and economic impact analyses use the MACCS2 code to determine
 17 the offsite risk impacts on the surrounding environment and public. Inputs for these analyses
 18 include plant-specific and site-specific input values for core radionuclide inventory, source term
 19 and release characteristics, site meteorological data, projected population distribution (within a
 20 50-mile radius) for the year 2040, emergency response evacuation modeling, and economic
 21 data. The core radionuclide inventory corresponds to the end-of-cycle values for SGS operating
 22 at 3632 MWt, which is five percent above the current licensed power level of 3,459 MWt. The
 23 magnitude of the onsite impacts (in terms of clean-up and decontamination costs and
 24 occupational dose) is based on information provided in NUREG/BR-0184 (NRC 1997a).

1 In the ER, PSEG estimated the dose to the population within 80-kilometers (50-miles) of the
 2 SGS site to be approximately 0.78 person-Sievert (Sv) (78 person-roentgen equivalent man
 3 (rem)) per year. The breakdown of the total population dose by containment release mode is
 4 summarized in Table F-2. Containment bypass events (such as SGTR-initiated large early
 5 release frequency (LERF) accidents) and late containment failures without feedwater dominate
 6 the population dose risk at SGS.

7
 8 **Table F-2. Breakdown of Population Dose by Containment Release Mode**
 9

Containment Release Mode	Population Dose (Person-Rem ¹ Per Year)	Percent Contribution ²
Containment over-pressure (late)	42.9	55
Steam generator rupture	31.9	41
Containment isolation failure	2.3	3
Containment intact	0.2	<1
Interfacing system LOCA	0.6	<1
Catastrophic isolation failure	0.4	<1
Basemat melt-through (late)	negligible	negligible
Total³	78.2	100

¹One person-rem = 0.01 person-Sv

²Derived from Table E.3-7 of the ER

³Column totals may be different due to round off.

10
 11 **F.2.2 Review of PSEG's Risk Estimates**

12 PSEG's determination of offsite risk at the SGS is based on the following three major elements
 13 of analysis:

- 14 • the Level 1 and 2 risk models that form the bases for the 1993 IPE submittal (PSEG
 15 1993), and the external event analyses of the 1996 IPEEE submittal (PSEG 1996),
- 16 • the major modifications to the IPE model that have been incorporated in the SGS PRA,
 17 including a complete revision of the Level 2 risk model, and
- 18 • the MACCS2 analyses performed to translate fission product source terms and release
 19 frequencies from the Level 2 PRA model into offsite consequence measures.

1 Each of these analyses was reviewed to determine the acceptability of the SGS's risk estimates
2 for the SAMA analysis, as summarized below.

3 The NRC staff's review of the SGS IPE is described in an NRC report dated March 21, 1996
4 (NRC 1996). Based on a review of the original IPE submittal, responses to RAIs, and a revised
5 IPE submittal, the NRC staff concluded that the IPE submittal met the intent of GL 88-20
6 (NRC 1988); that is, the licensee's IPE process is capable of identifying the most likely severe
7 accidents and severe accident vulnerabilities. Although no vulnerabilities were identified in the
8 IPE, three improvements to plant and procedures were identified. Two of the improvements
9 were revising SGS procedures related to interfacing systems loss of coolant accidents
10 (ISLOCA) and the third was to install an isolation valve in the demineralized water line to be
11 used to prevent flooding in the relay and switchgear rooms. All of these improvements are
12 stated to have been implemented (PSEG 2009).

13 There have been eight revisions to the IPE model since the 1993 IPE submittal. A listing of the
14 major changes made to the SGS PRA since the original IPE submittal was provided in the ER
15 (PSEG 2009) and in response to an RAI (PSEG 2010a) and is summarized in Table F-3. A
16 comparison of the internal events CDF between the 1993 IPE and the current PRA model
17 indicates an increase of about 25 percent in the total CDF (from 6.4×10^{-5} per year to 4.8×10^{-5}
18 per year).

19 **Table F-3. SGS PRA Historical Summary**

PRA Version	Summary of Changes from Prior Model ²	CDF ¹ (per year)
1993	IPE Submittal	6.4×10^{-5}
Model 1.0 8/1996	- Updated plant and common cause data	5.1×10^{-5}
Model 2.0 8/1998	- Enhanced the service water system and reactor coolant pump (RCP) seal models - Added anticipated transients without trip (ATWT) mitigation system actuation circuitry (AMSAC) and valves for containment isolation system - Eliminated switchgear ventilation as a support system - Added ISLOCA logic	5.2×10^{-5}
Model 3.0 6/2002	- Incorporated resolution of 2001 Westinghouse Owner's Group (WOG) PRA certification comments - Added switchgear ventilation as a support system - Addressed HRA dependency issues, updated common-cause calculations, and adjusted initiating event fault tree logic - Modified how recovery actions were credited	5.2×10^{-5}
Model 3.1 7/2003	- Revised system models for charging pumps, emergency diesel generator (EDG), and AMSAC	4.1×10^{-5}

	<ul style="list-style-type: none"> - Revised models for feedwater line break and steam-line break initiators - Added human actions to close the service water turbine header isolation valve(s) 	
Model 3.2 3/2005	<ul style="list-style-type: none"> - Enhanced the internal flooding and offsite power recovery models - Revised models for the switchyard and service water crosstie between units - Revised common cause failure data - Adjusted the auxiliary feedwater (AFW) pump failure rate 	2.5×10^{-5}
Model 3.2a ³ 3/2006	<ul style="list-style-type: none"> - Removed recovery from loss of switchgear ventilation and for loss of primary coolant system (PCS) when the initiator causes loss of PCS - Removed credit for 1) cross-tying the Unit 2 positive displacement pump (PDP) with Unit 1, 2) cross-tying DC power supplies to power-operated relief valves (PORVs), 3) cross-tying power to diesel fuel oil transfer pumps, and 4) repair of failed EDGs - Updated the split fraction for a seal LOCA after loss of cooling - Reduced credit for 1) use of the gas turbine generator in several sequences, 2) use of a condensate pump for steam generator makeup, 3) an action to preserve service water availability, and 3) switching from the volume control tank (VCT) to the refueling water storage tank (RWST) - Removed unavailability of both trains of residual heat removal (RHR) - Revised operator actions for maintaining AFW suction source - Changed the loss of DC power initiator - Revised numerous human error probabilities - Added new failure mode for component cooling system (CCS) - Revised modeling of stuck open PORV for SBO and very small LOCA (VSLOCA) sequences - Revised model to require recovery following loss of CCW and failure to swap charging suction to the RWST - Changed split fractions in service water logic 	6.2×10^{-5}
Model 4.0 ³ 3/2008	<ul style="list-style-type: none"> - Completely revised and updated the human reliability analysis (HRA) - Updated failure and common-cause data - Updated model to better reflect post small LOCA operator actions - Updated model for loss of control area ventilation (CAV) initiator - Corrected model to have EDG C fail when EDGs A and B or their associated fuel oil transfer pumps fail - Updated the service water system and reactor coolant pump (RCP) seal system models - Reduced credit for use of GTG during grid-related LOOPS - Updated modeling of DC dependencies 	4.5×10^{-5}
Model 4.1 9/2008	<ul style="list-style-type: none"> - Completely revised the SGS internal flooding analysis - Updated model for charging pump upon failure to operate minimum flow valves - Refined the HRA analyses for SGTR events 	4.8×10^{-5}

¹The IPE, Model 1.0, and Model 2.0 SGS PRAs were performed for both Units 1 and 2; the CDF values shown for these PRA versions are for the SGS unit having the highest internal events and internal flooding CDFs. Starting with Model 3.0, the SGS PRA was performed for Unit 1 only.

²Summarized from information provided in the ER and a response a NRC staff RAI (PSEG 2010).

³The internal flooding contribution is not included in the reported CDF.

1
2 The CDF values from the 1993 IPE (6.4×10^{-5} per year for Unit 1 and 6.0×10^{-5} per year for Unit
3 2) are in the middle range of the CDF values reported in the IPEs for Westinghouse four-loop
4 plants. Figure 11.6 of NUREG-1560 shows that the IPE-based total internal events CDF for
5 Westinghouse four-loop plants ranges from 2×10^{-6} per year to 2×10^{-4} per year, with an
6 average CDF for the group of 6×10^{-5} per year (NRC 1997b). It is recognized that other plants
7 have updated the values for CDF subsequent to the IPE submittals to reflect modeling and
8 hardware changes. The current internal events CDF results for SGS (4.8×10^{-5} per year) are
9 comparable to that for other plants of similar vintage and characteristics.

10 PSEG explained in the ER that the Salem PRA model is representative of Unit 1, that
11 differences in system configuration and success criteria between Units 1 and 2 are minimal, and
12 that plant-specific data are averaged between the two units. In response to an NRC staff RAI
13 (PSEG 2010a), PSEG further clarified that there are currently no differences between Units 1
14 and 2 that are believed to be important from a risk perspective. The specific design differences
15 are 1) the recirculation switchover on unit 1 is strictly manual whereas on Unit 2 it is semi-
16 automatic and 2) one component cooling heat exchanger on Unit 1 is of a different design than
17 its counterpart on Unit 2. PSEG also stated that future plant modifications that make the risk
18 profile significantly different between the two units will be addressed by the PRA maintenance
19 and update process. The NRC staff concurs that the design differences between Units 1 and 2
20 are not likely to impact the results of the SAMA evaluation and that use of Revision 4.1 of the
21 Salem PRA model to represent Unit 2 is reasonable.

22 The NRC staff considered the peer reviews performed for the SGS PRA, and the potential
23 impact of the review findings on the SAMA evaluation. In the ER (PSEG 2009) and in response
24 to an NRC staff RAI (PSEG 2010a), PSEG described two industry peer reviews of the SGS
25 PRA. The first, conducted by the Westinghouse Owners Group in February 2002, reviewed
26 PRA Model Revision 3.2a. The second, conducted by the PWR Owners Group in November
27 2008, reviewed PRA Model Revision 4.1.

28 PSEG stated in the ER that all Level A and B (extremely important and important, respectively)
29 facts and observations (F&Os) from the Westinghouse Owners Group peer review have been
30 addressed (PSEG 2009).

31 The 2008 peer review of Model Revision 4.1 was performed using the Nuclear Energy Institute
32 peer review process (NEI 2007) and the ASME PRA Standard (ASME 2005) as endorsed by the
33 NRC in Regulatory Guide 1.200, Rev. 1 (NRC 2007). The final report for this peer review had
34 not been completed when the SAMA analysis was performed. In response to an NRC staff RAI,
35 PSEG provided a listing and discussion of eight "key" findings from the 2008 PWR Owners
36 Group peer review (PSEG 2010a). A finding is an observation that is necessary to address to
37 ensure 1) the technical adequacy of the PRA, 2) the capability/robustness of the PRA update
38 process, and 3) the process for evaluating the necessary capability of the PRA technical

1 elements (NEI 2007). Four of the findings were determined to have no impact on the SAMA
2 analysis because it was either a documentation issue (one finding), the current treatment in the
3 PRA model was determined to be conservative (one finding), the finding was determined to be
4 in conflict with other requirements in the PRA standard which were met by the PRA (one
5 finding), or no change to the model was determined to be necessary based on additional
6 analysis (one finding). The other four findings were determined to have a non-significant impact
7 on the SAMA analysis for the following reasons:

- 8 • Component availability did not include a contribution from surveillance testing. PSEG
9 explained that component availability is based on Mitigating Systems Performance
10 Index (MSPI) and Maintenance Rule data, which is believed to be accurate, and that
11 any changes in failure rates resulting from a comparison of this data with expected
12 unavailability due to test procedures and maintenance is expected to be non-significant.
- 13 • Events that occurred at conditions other than at-power operation or which resulted in
14 controlled shutdown were not considered. PSEG explained that identification of
15 initiating events did include a review of events other than at-power operations and that
16 events occurring during shutdowns and non-power conditions which could have
17 occurred at power were not excluded from the review.
- 18 • The SBO success paths following offsite power recovery do not address recovery and
19 operation of required safety systems. PSEG explained that the likelihood of LOOP,
20 followed by SBO, followed by successful recovery of offsite power, and then followed by
21 multiple equipment failures preventing long-term safe shutdown is very small and that,
22 therefore, the current treatment of SBO is sufficient for the SAMA analysis.
- 23 • Omission of failure modes for the EDGs due to the use of only MSPI data and not all
24 plant-specific data. PSEG explained that component availability is based on MSPI and
25 Maintenance Rule data, which is believed to be reliable, and that any changes in failure
26 rates resulting from a validation with other plant-specific data is expected to be non-
27 significant.

28 In response to another NRC staff RAI, PSEG provided a listing and discussion of the resolution
29 of the 72 supporting requirements (SRs) that did not meet Capability Category II or higher and
30 that remain open in SGS PRA MOR Revision 4.3 (PSEG 2010b). Capability Category II is
31 described as follows (ASME 2005): 1) the scope and level of detail has resolution and
32 specificity sufficient to identify the relative importance of significant contributors at the
33 component level including human actions, as necessary, 2) plant-specific data/models used for
34 significant contributors, and 3) departures from realism will have small impact on the
35 conclusions and risk insights as supported by good practices. PSEG evaluated each of the 72
36 SRs for impact on the SAMA evaluation and concluded the following:

- 1 • PSEG determined that 63 SRs were documentation issues and have no impact on the
2 SAMA analysis.
- 3 • Three issues were determined to have no impact on the SAMA analysis because: 1) the
4 finding is principally a documentation issue and the one event cited by the peer reviewer
5 as being mis-classified was determined by PSEG to be appropriately classified (SR IE-
6 A3), 2) PSEG determined that they made appropriate approximations for certain
7 component/failure models where data were lacking (SR SY-A21), and 3) the finding has
8 to do with a conservative modeling issue that does not impact the SAMA analysis (SR
9 IE-C3).
- 10 • Six issues were determined to have minimal impact on the SAMA analysis because: 1)
11 the referenced event is bounded by the current PRA model (SR IE-A1), 2) the issue
12 relates to how initiating events are grouped (SRs IE-B3 and AS-A5), 3) the issue impacts
13 only one specific human failure event (HFE) (SR SY-A16), or 4) the un-modeled pre-
14 initiator human errors are viewed as having a low risk contribution (SRs HR-C3 and SY-
15 B16).

16 PSEG further states that, overall, resolution of the SRs will have a minimal impact on the SAMA
17 evaluation and is well within the uncertainty analysis discussed in Section F.6.2, and that all of
18 the identified SRs that did not meet Capability Category II or higher will be reviewed for
19 consideration during the next periodic update of the PRA model.

20 The NRC staff considers PSEG's disposition of the peer review findings to be reasonable and
21 that final resolution of the findings is not likely to impact the results of the SAMA analysis.

22 PSEG also stated that there have not been any further reviews of the SGS internal events PRA
23 since the 2008 peer review of PRA Model Revision 4.1.

24 The NRC staff asked PSEG to identify any changes to the plant, including physical and
25 procedural modifications, since Revision 4.1 of the Salem PRA model that could have a
26 significant impact on the results of the SAMA analysis (NRC 2010). In response to the RAI
27 (PSEG 2010a), PSEG explained that one design change and one procedural change have been
28 made since PRA Model Revision 4.1 that have the potential to significantly change the PRA
29 results. The design change was to allow use of two small non-engineered safety feature (ESF)
30 diesel generators to provide power for control and operation of switchyard breakers and to
31 provide a backup source of power to station battery chargers. The procedure change included
32 new procedural steps to provide forced flow of large quantities of outside air to areas supplied
33 by the control area ventilation system. These plant changes resulted in a reduction in the SGS
34 CDF. While the CDF for the updated SGS PRA model, designated as model of record Revision
35 4.3, was not provided in the RAI response, PSEG did provide the updated SGS release
36 frequency of 2.2×10^{-5} per year, which is more than a 50 percent reduction from the 5.0×10^{-5}

1 per year used in the SAMA analysis. The impact of this change on the SAMA analysis is
2 discussed in Sections F.3.2 and F.6.2.

3 In the ER, PSEG explains that, in addition to peer reviews, other measures to ensure, validate,
4 and maintain the quality of the SGS PRA include a formal qualification program for PRA staff,
5 use of procedural guidance to perform PRA tasks, and a program to control PRA models and
6 software. PSEG concludes that based on this quality control process, use of PRA Model
7 Revision 4.1 for the SAMA evaluation was deemed appropriate.

8 Given that the PSEG internal events PRA model has been peer-reviewed and the peer review
9 findings were judged to have minimal impact on the results of the SAMA analysis, and that
10 PSEG has satisfactorily addressed NRC staff questions regarding the PRA, the NRC staff
11 concludes that the internal events Level 1 PRA model is of sufficient quality to support the
12 SAMA evaluation.

13 As indicated above, the current SGS PRA does not include external events. In the absence of
14 such an analysis, PSEG used the SGS IPEEE to identify the highest risk accident sequences
15 and the potential means of reducing the risk posed by those sequences, as discussed below
16 and in Section F.3.2.

17 The SGS IPEEE was submitted in November 1995 (PSEG 1996), in response to Supplement 4
18 of Generic Letter 88-20 (NRC 1991a). The submittal included a seismic PRA, a fire PRA, and a
19 screening analysis for other external events. While no fundamental weaknesses or
20 vulnerabilities to severe accident risk in regard to the external events were identified, several
21 potential enhancements were identified as discussed below. In a letter dated May 21, 1999,
22 (NRC 1999) NRC staff concluded that the submittal met the intent of Supplement 4 to Generic
23 Letter 88-20, and that the licensee's IPEEE process is capable of identifying the most likely
24 severe accidents and severe accident vulnerabilities.

25 The SGS IPEEE seismic analysis utilized a seismic PRA following NRC guidance (NRC 1991a).
26 The seismic PRA included: a seismic hazard analysis, a seismic fragility assessment, a seismic
27 systems analysis, and quantification of seismic CDF.

28 The seismic hazard analysis estimated the annual frequency of exceeding different levels of
29 ground motion. Seismic CDFs were determined for both the EPRI (EPRI 1989) and the
30 Lawrence Livermore National Laboratory (LLNL) (NRC 1994) hazard assessments. The seismic
31 fragility assessment utilized the walkdown and screening procedures in EPRI's seismic margin
32 assessment methodology (EPRI 1991). Fragility calculations were made for about 100
33 components and, using a screening criteria of median peak ground acceleration (pga) of 1.5 g
34 which corresponds to a 0.5 pga high confidence low probability of failure (HCLPF) capacity, a
35 total of 27 components remained after screening. The seismic systems analysis defined the
36 potential seismic induced structure and equipment failure scenarios that could occur after a
37 seismic event and lead to core damage. The SGS IPE event tree and fault tree models were

1 used as the starting point for the seismic analysis but an explicit seismic event tree (SET) was
 2 used to delineate the potential successes and failures that could occur due to a seismic event.
 3 Quantification of the seismic models consisted of considering the seismic hazard curve with the
 4 appropriate structural and equipment seismic fragility curves to obtain the frequency of the
 5 seismic damage state. The conditional probability of core damage given each seismic damage
 6 state was then obtained from the IPE models with appropriate changes to reflect the seismic
 7 damage state. The CDF was then given by the product of the seismic damage state probability
 8 and the conditional core damage probability.

9 The seismic CDF resulting from the SGS IPEEE was calculated to be 9.5×10^{-6} per year using
 10 the LLNL seismic hazard curve and 4.7×10^{-6} per year using the EPRI seismic hazard curve.
 11 Both utilized the IPE internal events PRA, with a CDF of 6.4×10^{-5} per year for quantification of
 12 non-seismic failures. While the IPEEE indicated that the EPRI results were believed to be more
 13 realistic PSEG assumed a seismic CDF of 9.5×10^{-6} per year based on the LLNL seismic
 14 hazard curve in the development of the external events multiplier for purposes of the SAMA
 15 evaluation (PSEG 2009). In the ER, PSEG provided a listing and description of the top seven
 16 seismic core damage contributors. The dominant seismic core damage contributors for the
 17 LLNL seismic hazard curve, representing about 95 percent of the seismic CDF, are listed in
 18 Table F-4. The largest contributors to seismic CDF are seismic-induced LOOP caused by
 19 failure of the switchyard ceramic insulators combined with random failure of the EDGs and
 20 seismic-induced LOOP and failure of battery trains A and B caused by failure of the masonry
 21 block walls around the batteries. The NRC staff agrees that the seismic CDF of 9.5×10^{-6} per
 22 year is reasonable for the SAMA analysis.

23 **Table F-4. Dominant Contributors to the Seismic CDF**

Sequence ID	Seismic Sequence Description	CDF (per year)	% Contribution to Seismic CDF
17	OP: Seismically-Induced LOOP caused by failure of the switchyard ceramic insulators	2.9×10^{-6}	31
33	OP-DAB: Seismically-Induced LOOP and failure of battery trains A and B	2.0×10^{-6}	21
31	OP-SW: Seismically-Induced LOOP and failure of the service water system	1.3×10^{-6}	14
35	OP-IC: Seismically-Induced LOOP and failure of instrumentation and control capability and equipment in the main control room	1.2×10^{-6}	13
34	OP-DAB-DG: Same as 33 OP-DAB and failure of battery train C	7.7×10^{-7}	8

17F	OP-FW: Same as 17 OP and failure of containment fan coolers	5.4×10^{-7}	6
21F	OP-FW-FC: Same as 17F OP-FW and failure of auxiliary feed water (AFW)	2.9×10^{-7}	3

1

2 The SGS IPEEE did not identify any vulnerabilities due to seismic events but did identify three
3 improvements to reduce seismic risk. These improvements are 1) procedural change to ensure
4 long term alternate ventilation for the Auxiliary Building, 2) replacement of identified low
5 ruggedness relays with higher seismic capacity relays, and 3) reinforcement of an 8-foot
6 masonry wall in the 4kV switchgear room. PSEG clarified in response to an NRC staff RAI that
7 the first two improvements have been implemented (PSEG 2010a). The third improvement is
8 discussed further in Section F.3.2.

9 The SGS IPEEE fire analysis employed EPRI's fire-induced vulnerability evaluation (FIVE)
10 methodology (EPRI 1993) followed by a PRA quantification of the unscreened compartments.
11 The fire evaluation was performed on the basis of fire areas which are plant locations
12 completely enclosed by 2-hour rated fire barriers and meeting the FIVE fire barrier criterion
13 related to preventing propagation. Stage 1 consisted of qualitative screening of all plant fire
14 areas to determine whether a fire could cause a plant shutdown or trip, or lead to loss of safe
15 shutdown equipment. Stage 1 also consisted of quantitative screening performed by estimating
16 whether an area's associated fire frequency in combination with the conditional core damage
17 probability given by the loss of functions potentially impacted by the fire was less than the $1 \times$
18 10^{-6} per year. Based on qualitative and quantitative screening all but 38 fire areas were
19 screened out. Stage 2 was to evaluate the remaining fire areas by modeling fire growth and
20 propagation to determine the fire damage state for each fire area. Stage 3 was an evaluation of
21 Sandia Fire Risk Scoping Study issues (NRC 1989) using the tailored walkdown approach
22 provided in the FIVE methodology. Containment performance was also examined to evaluate
23 the performance of containment systems and equipment following core damage resulting from a
24 fire. The final stage was assessment of the functional effects on the plant for each fire damage
25 state by developing explicit fire event trees to probabilistically assess unscreened areas.
26 Probabilistic credit was given for automatic and manual fire suppression systems. Final
27 quantification utilized FIVE fire data and refined conditional core damage probabilities (CCDPs)
28 from the IPE internal events PRA. The resulting fire induced CDF was calculated to be $2.3 \times 10^{-}$
29 5 per year.

30 In the ER, PSEG provided a listing and description of the top ten fire core damage contributors.
31 The dominant fire core damage contributors, representing about 99 percent of the fire CDF, are
32 listed in Table F-5. The largest contributors to fire CDF are fires in the 460V Switchgear
33 Rooms, Relay Room, and Control Rooms.

34 Subsequent to the IPEEE, SGS replaced the CO₂ suppression systems with water sprinkler
35 systems in the 460V Switchgear Rooms, 4160V Switchgears Rooms, and Lower Electrical

1 Penetration Area. In addition, the results of cable wrap tests suggested that the cable wrap
 2 would not perform as expected in some areas of the plant and, subsequent to the IPEEE, was
 3 removed and replaced. Because of the suppression system changes made to the three areas
 4 identified, PSEG did not consider the IPEEE results for these areas valid. PSEG reassessed
 5 the fire CDF for these areas using PRA insights from an interim SGS fire model. If the interim
 6 SGS fire model showed a higher CDF for any of these three areas, the higher CDF was used for
 7 the SAMA analysis. This was the case for the 460V Switchgear Rooms and the Lower
 8 Electrical Penetration Area. The fire CDF from the interim SGS fire model for these two fire
 9 areas are provided in Table F-5. These insights increased the total fire CDF to 3.8×10^{-5} per
 10 year, which was used in the SAMA analysis.

11 The NRC staff asked PSEG to provide additional information about the interim SGS fire model
 12 and, specifically, why it was not used for the SAMA analysis beyond the three areas discussed
 13 (NRC 2010a). In response to the RAI, PSEG explained that after the completion of the IPEEE,
 14 there was an effort made to develop a fire PRA. This resulted in a partially complete "interim
 15 SGS fire model." However, the interim SGS fire model was never integrated into the internal
 16 events PRA model of record (which at the time was Revision 3) and was essentially abandoned
 17 because of the forthcoming NUREG/CR-6850 fire PRA development guidance that would
 18 render the SGS fire modeling methodology obsolete.

19 **Table F-5. Important Fire Areas and Their Contribution to Fire CDF**

Fire Area Description	CDF ¹ (per year)	% Contribution to Fire CDF
460V Switchgear Rooms	1.3×10^{-5}	34
Relay Room	7.2×10^{-6}	19
Control Rooms, Peripheral Room, and Ventilation Rooms	7.0×10^{-6}	18
4160V Switchgear Room	3.4×10^{-6}	9
Lower Electrical Penetration Area	3.2×10^{-6}	8
Upper Electrical and Piping Penetration Areas	1.3×10^{-6}	3
Reactor Plant Auxiliary Equipment Area (84B)	1.1×10^{-6}	3
Turbine and Service Buildings	6.4×10^{-7}	2
Service Water Intake	4.2×10^{-7}	1
Reactor Plant Auxiliary Equipment Area (100C)	2.9×10^{-7}	1

¹CDF reported for the 460V Switchgear Rooms and 4160V Switchgear Rooms is from the interim SGS fire model. All other CDFs are from the IPEEE.

20

1 The SGS IPEEE did not identify any vulnerabilities due to fire events but did identify two
2 improvements to reduce fire risk. These improvements are 1) procedural change to enhance
3 cooling in the switchgear and control areas in the event of a fire and 2) procedural change for
4 the control of transient combustibles in the turbine building. PSEG clarified in response to an
5 NRC staff RAI that the two suggested improvements have been implemented (PSEG 2010a).

6 As discussed previously, PSEG identified in the ER that SGS has replaced CO₂ fire suppression
7 systems with water sprinkler systems in three areas of the plant since the IPEEE and that cable
8 wrap has been removed and replaced in several areas of the plant since the IPEEE. The NRC
9 staff asked PSEG if any other fire-related improvements have been made since the IPEEE
10 (NRC 2010a). In response to the RAI, PSEG indicated that the following improvements had
11 been made since the IPEEE: 1) the ventilation system and strategy for maintaining viable
12 working conditions was revised for the 4160 Switchgear Room and the Upper Electrical and
13 Piping Penetration Areas and 2) the maintenance shop was eliminated in the Turbine and
14 Service Buildings in order to reduce the initiating event frequency of fires that would damage the
15 cables for the emergency 4kV buses.

16 In the ER, PSEG states that an effective comparison between the internal events PRA results
17 and the fire analysis results is not possible because neither the plant response model or the fire
18 modeling methodology used in the IPEEE is up-to-date. PSEG also identified areas where fire
19 CDF quantification may introduce different levels of uncertainty than expected in the internal
20 events PRA and identified a number of conservatisms in the IPEEE fire analysis, including:

- 21 • A revised NRC fire events database indicates a trend toward lower frequency and less
22 severe fires than assumed in the SGS IPEEE.
- 23 • Bounding fire modeling assumptions are used for many fire scenarios. For example, all
24 equipment in a cabinet is damaged for any fire within a cabinet, regardless of whether it
25 is suppressed. Other examples are provided in the ER.
- 26 • Because of a lack of industry experience with regard to crew performance during the
27 types of fires modeled in the fire PRA, the characterization of crew actions in the fire
28 PRA is generally conservative.

29 PSEG's conclusion is that while there are both conservative and potentially non-conservative
30 factors included in the IPEEE fire model, the IPEEE is judged to have more conservative bias
31 than the internal events model.

32 Although the arguments regarding the conservatisms in the fire analysis are presented in the
33 ER, PSEG used the modified IPEEE fire CDF of 3.8×10^{-5} per year in the SAMA analysis rather
34 than some reduced value. Considering the above discussion, the conservatisms in the IPEEE
35 fire analysis as currently understood, and the response to the NRC staff RAIs, the NRC staff
36 concludes that the fire CDF of 3.8×10^{-5} per year is reasonable for the SAMA analysis.

1 The SGS IPEEE analysis of high winds, floods, and other external (HFO) events followed the
2 progressive screening method defined in NUREG-1407 (NRC 1991b). While SGS is not
3 considered a 1975 Standard Review Plan (SRP) plant, aspects of its licensing basis do conform
4 to the 1975 SRP criteria because SGS is co-located with Hope Creek Generating Station
5 (HCGS), which does meet the 1975 SRP criteria (PSEG 1996). For those events that are
6 based on the location of the site, and not plant-specific features, the 1975 SRP criteria was
7 used for the HFO screening analysis. Progressively more quantitatively based methods were
8 employed for those events that could not be shown to conform to the 1975 SRP criteria. The
9 IPEEE concluded that all HFO events either complied with the 1975 SRP criteria or that their
10 predicted CDF was below the IPEEE screening criteria (i.e. $< 1 \times 10^{-6}$ per year). For the SAMA
11 analysis, PSEG assumed a CDF contribution of 1×10^{-6} per year for each of high winds,
12 external floods, transportation and nearby facilities, detritus, and chemical releases for a total
13 HFO CDF contribution of 5×10^{-6} per year (PSEG 2009).

14 Although the SGS IPEEE did not identify any vulnerabilities due to HFO events, three
15 improvements to reduce risk were identified. These improvements are 1) modify the circulating
16 water intake structure to protect against detritus (blockage), 2) make improvements to protect
17 against water ingress pathways for external flooding events, and 3) improve the hold downs for
18 hydrogen tanks to protect against tornados. PSEG clarified in response to an NRC staff RAI
19 that the first two suggested improvements have been implemented (PSEG 2010a). The third
20 improvement is discussed further in Section F.3.2.

21 The NRC staff asked about the status and potential impact on the SAMA analysis of a liquefied
22 natural gas (LNG) terminal planned for Logan Township, New Jersey, upstream on the
23 Delaware River from the SGS site (NRC 2010a). In response to the RAI, PSEG discussed the
24 current status of the LNG terminal as well as the regulatory controls for LNG marine traffic and
25 LNG ship design and the safety record of LNG shipping (PSEG 2010a). The LNG terminal
26 remains in the planning stage and no construction has begun. Further, the state of Delaware
27 has denied applications for several required environmental permits and approvals. PSEG
28 concluded that based on the regulatory process and controls for assuring the safety and
29 security of LNG ships, the safety record of LNG ships, and the uncertainty of the planned
30 terminal, consideration of potential SAMAs associated with the possible future terminal is not
31 warranted. The NRC staff agrees with this conclusion.

32 Based on the aforementioned results, the external events CDF is approximately equal to the
33 internal events CDF (based on a seismic CDF of 9.5×10^{-6} per year, a fire CDF of 3.8×10^{-5} per
34 year, an HFO CDF of 5.0×10^{-6} per year, and an internal events CDF of 5.0×10^{-5} per year
35 used in the SAMA analysis). Accordingly, the NRC staff concurred with SGS's conclusion that
36 the total CDF (from internal and external events) would be approximately 2 times the internal
37 events CDF. In the SAMA analysis submitted in the ER, PSEG doubled the benefit that was
38 derived from the internal events model to account for the combined contribution from internal
39 and external events. The NRC staff agrees with the licensee's overall conclusion concerning
40 the multiplier used to represent the impact of external events and concludes that the licensee's

1 use of a multiplier of 2 to account for external events is reasonable for the purposes of the
2 SAMA evaluation. This is discussed further in Section F.6.2.

3 The NRC staff reviewed the general process used by PSEG to translate the results of the Level
4 1 PRA into containment releases, as well as the results of the Level 2 analysis, as described in
5 the ER and in response to NRC staff RAIs (PSEG 2010a). The current Level 2 model is
6 essentially a complete revision of the IPE Level 2 model. In response to an NRC staff RAI,
7 PSEG stated that the IPE Level 2 model was abandoned, with the exception of LERF, with
8 Revision 3 of the SGS PRA model and that the Level 2 model was recreated incorporating
9 current industry guidance as part of the transition from Revision 3 to Revision 4 of the PRA
10 model (PSEG 2010a).

11 The current SGS Level 2 model utilizes a single CET containing both phenomenological and
12 systemic events. The Level 1 core damage sequences are grouped into core damage accident
13 classes, or plant damage states (PDSs), with similar characteristics. The PDSs are defined
14 based on the following attributes: (1) RCS pressure (high or low), (2) containment isolation
15 status, (3) containment bypass status, (4) containment bypass via an unisolated SGTR, (5)
16 containment bypass via an unisolated, large ISLOCA, (6) containment spray operation mode,
17 (7) containment fan cooler operation, and (8) RWST injection. All of the sequences in an
18 accident class are then input to the CET by linking the level 1 event tree sequences with the
19 level 2 CET. The CET is analyzed by the linking of fault trees that represent each CET node.
20 Whenever possible the fault trees utilized in the Level 1 analysis are utilized in the CET to
21 propagate dependencies. In response to an NRC staff RAI, PSEG states that the Level 1 and
22 Level 2 models are integrated in that the Level 1 sequences are directly passed to the Level 2
23 model in the software through the Level 1 sequence fault trees (PSEG 2010a). Twenty-three
24 distinct CET end states or sequences result.

25 Section E.2.2.3 of the ER describes each of the top events of the CET and states that branch
26 point probabilities for each top event are based on previous SGS Level 2 analyses, recent
27 accident progression research, and similar analyses for other nuclear plants. The NRC staff
28 requested that PSEG describe how the branch point probabilities were developed specifically
29 for top events RCS Depressurization and Containment Heat Removal (NRC 2010a). In
30 response to the RAI, PSEG clarified that top event RCS Depressurization consists of the
31 combination of an existing human action from the HRA and the fault tree for PORV operation
32 (PSEG 2010a). The Containment Heat Removal top event is determined by specific Level 2
33 system models for containment fan cooler units (CFCUs) and containment spray (CS), either of
34 which can be used for containment heat removal at SGS.

35 Each CET end state represents a radionuclide release to the environment and is assigned to a
36 release category based on timing of release, the initiating event, whether feedwater is available,
37 and the containment failure mode. Three general release categories are defined: intact
38 containment, late release, and early release. These are further divided into eleven detailed
39 release categories based on the above attributes, as defined in Section E.2.2.6 of the ER.

1 The frequency of each release category was obtained by summing the frequency of the
2 contributing CET end states. The release characteristics for each release category were
3 developed by using the results of Modular Accident Analysis Program (MAAP Version 4.0.6)
4 computer code calculations (PSEG 2010a). Representative MAAP cases for each release
5 category were chosen to either represent the most likely initiators in the release category (intact
6 containment and late release categories) or to conservatively bound the consequences of the
7 release (early release categories). The NRC questioned why PSEG did not also use
8 representative cases that bound the consequences for the late release categories (NRC 2010a).
9 In response to the RAI, PSEG stated that, because the late release categories take more time
10 to evolve than the early release categories, the late release categories are less affected by the
11 initial accident conditions and so result in more uniform consequences than the early release
12 categories (PSEG 2010a). Since the accident sequences assigned to the late release
13 categories yielded similar consequences, PSEG selected representative MAAP cases that
14 represented the most likely initiators within those release categories. The release categories,
15 their frequencies, and release characteristics are presented in Tables E.3-5 and E.3-6 of
16 Appendix E to the ER (PSEG 2009).

17 The total Level 2 release frequency is of 5.0×10^{-5} per year, which is about 4 percent higher
18 than the internal events CDF of 4.8×10^{-5} per year. The ER states that this difference is due to
19 truncation of low probability sequences and inclusion of non-minimal Level 1 sequences. The
20 NRC staff considers that use of the release frequency rather than the Level 1 CDF will have a
21 negligible impact on the results of the SAMA evaluation because the external event multiplier
22 and uncertainty multiplier used in the SAMA analysis (discussed in Section F.6.2) have a much
23 greater impact on the SAMA evaluation results than the small error arising from the model
24 quantification approach.

25 The revised SGS Level 2 PRA model was included in the 2008 PWR Owner's Group peer
26 review discussed above. While none of the eight key findings had to do with the Level 2
27 analysis, eight LERF analysis SRs did not meet Capability Category II or higher and remain
28 open in SGS PRA MOR Revision 4.3 (PSEG 2010b). PSEG determined that all eight of these
29 findings were documentation issues that did not impact the SAMA analysis.

30 Based on the NRC staff's review of the Level 2 methodology, that PSEG has adequately
31 addressed NRC staff RAIs, and that the Level 2 model was reviewed in more detail as part of
32 the 2008 PWR Owners Group peer review and there were no findings that impacted the SAMA
33 analysis, the NRC staff concludes that the Level 2 PRA provides an acceptable basis for
34 evaluating the benefits associated with various SAMAs.

35 The NRC staff reviewed the process used by PSEG to extend the containment performance
36 (Level 2) portion of the PRA to an assessment of offsite consequences (essentially a Level 3
37 PRA). This included consideration of the source terms used to characterize fission product
38 releases for the applicable containment release categories and the major input assumptions
39 used in the offsite consequence analyses. The MACCS2 code was utilized to estimate offsite

1 consequences. Plant-specific input to the code includes the source terms for each source term
2 category and the reactor core radionuclide inventory (both discussed above), site-specific
3 meteorological data, projected population distribution within an 80-kilometer (50-mile) radius for
4 the year 2040, emergency evacuation modeling, and economic data. This information is
5 provided in Section E.3 of Appendix E to the ER (PSEG 2009).

6 PSEG used the MACCS2 code and a core inventory from a plant specific calculation at end of
7 cycle to determine the offsite consequences of activity release. In response to an NRC staff
8 RAI, PSEG stated that the MACCS2 analysis was based on the core inventory used in the
9 February 2006 NRC-approved Alternate Source Term for SGS (PSEG 2010a). As indicated in
10 the ER, the reactor core radionuclide inventory used in the consequence analysis was based on
11 a thermal power of 3632 MWt, which is 5 percent higher than the current licensed thermal
12 power of 3459 MWt for SGS. In response to an NRC staff RAI, PSEG stated that the higher
13 thermal power was used to provide margin for a future power uprate (PSEG 2010a).

14 All releases were modeled as being from the top of the reactor containment building and at low
15 thermal content (ambient). Sensitivity studies were performed on these assumptions and
16 indicated little or no change in population dose or offsite economic cost. Assuming a ground
17 level release decreased dose risk and cost risk by 8 percent and 7 percent, respectively.
18 Assuming a buoyant plume decreased dose risk and cost risk by 1 percent or less. Based on
19 the information provided, the staff concludes that the release parameters utilized are acceptable
20 for the purposes of the SAMA evaluation.

21 PSEG used site-specific meteorological data for the 2004 calendar year as input to the
22 MACCS2 code. The development of the meteorological data is discussed in Section E.3.7 of
23 Appendix E to the ER. The data were collected from onsite and local meteorological monitoring
24 systems. Sensitivity analyses using MACCS2 and the meteorological data for the years 2005
25 through 2007 show that use of data for the year 2004 results in the largest dose and economic
26 cost risk. Missing meteorological data was filled by (in order of preference): using data from the
27 backup met pole instruments (10-meter), using corresponding data from another level of the
28 main met tower, interpolation (if the data gap was less than 6 hours), or using data from the
29 same hour and a nearby day (substitution technique). The 10-meter wind speed and direction
30 were combined with precipitation and atmospheric stability (derived from the vertical
31 temperature gradient) to create the hourly data file for use by MACCS2. The NRC staff notes
32 that previous SAMA analyses results have shown little sensitivity to year-to-year differences in
33 meteorological data and concludes that the use of the 2004 meteorological data in the SAMA
34 analysis is reasonable.

35 The population distribution the licensee used as input to the MACCS2 analysis was estimated
36 for the year 2040 using year 1990 and year 2000 census data as accessed by SECPOP2000
37 (NRC 2003) as a starting point. In response to an NRC staff RAI, PSEG stated that the
38 transient population was included in the 10-mile EPZ, and in the population projection (PSEG
39 2010a). A ten year population growth rate was estimated using the year 1990 to year 2000

1 SECPOP2000 data and applied to obtain the distribution in 2040. The baseline population was
2 determined for each of 160 sectors, consisting of sixteen directions for each of ten concentric
3 distance rings to a radius of 50 miles surrounding the site. The SECPOP2000 census data from
4 1990 and 2000 were used to determine a ten year population growth factor for each of the
5 concentric rings. The population growth was averaged over each ring and applied uniformly to
6 all sectors within each ring. The NRC staff requested PSEG provide an assessment of the
7 impact on the SAMA analysis if a wind-direction weighted population estimate for each sector
8 were used (NRC 2010a). In response to the RAI, PSEG stated that the impacts associated with
9 angular population growth rates on population dose risk and offsite economic cost risk are
10 minimal and bounded by the 30 percent population sensitivity case (PSEG 2010a). This is
11 based on the relatively even wind distribution profile surrounding the site, the tendency for
12 lateral dispersion between sectors, and the use of mean values in the analysis. A sensitivity
13 study was performed for the population growth at year 2040. A 30 percent increase in
14 population resulted in a 30 percent increase in dose risk and a 29 percent increase in cost risk.
15 In response to an NRC staff RAI, PSEG stated that the radial growth rates used in the MACCS2
16 analysis provides a more conservative population growth estimate than using 'whole county'
17 data for averaging (PSEG 2010a). PSEG also identified that the population sensitivity case of
18 30 percent growth was approximately equivalent to adding 6.8 percent to the 10-year growth
19 rate. The NRC staff considers the methods and assumptions for estimating population
20 reasonable and acceptable for purposes of the SAMA evaluation.

21 The emergency evacuation model was modeled as a single evacuation zone extending out 16
22 kilometers (10 miles) from the plant (the emergency planning zone – EPZ). PSEG assumed
23 that 95 percent of the population would evacuate. This assumption is conservative relative to
24 the NUREG-1150 study (NRC 1990), which assumed evacuation of 99.5 percent of the
25 population within the emergency planning zone. The evacuated population was assumed to
26 move at an average radial speed of approximately 2.8 meters per second (6.3 miles per hour)
27 with a delayed start time of 65 minutes after declaration of a general emergency (KLD 2004). A
28 general emergency declaration was assumed to occur at the onset of core damage. The
29 evacuation speed is a time-weighted average value accounting for season, day of week, time of
30 day, and weather conditions. It is noted that the longest evacuation time presented in the study
31 (i.e., full 10 mile EPZ, winter snow conditions, 99th percentile evacuation) is 4 hours (from the
32 issuance of the advisory to evacuate). Sensitivity studies on these assumptions indicate that
33 there is minor impact to the population dose or offsite economic cost by the assumed variations.
34 The sensitivity study reduced the evacuation speed by 50 percent to 1.4 m/s. This change
35 resulted in a 4 percent increase in population dose risk and no change in offsite economic cost
36 risk. The NRC staff concludes that the evacuation assumptions and analysis are reasonable
37 and acceptable for the purposes of the SAMA evaluation.

38 Site specific agriculture and economic parameters were developed manually using data in the
39 2002 National Census of Agriculture (USDA 2004) and from the Bureau of Economic Analysis
40 (BEA 2008) for each of the 23 counties surrounding SGS, to a distance of 50 miles. Therefore,
41 recently discovered problems in SECPOP2000 do not impact the SGS analysis. The values

1 used for each of the 160 sectors were the data from each of the surrounding counties multiplied
2 by the fraction of that county's area that lies within that sector. Region-wide wealth data (i.e.,
3 farm wealth and non-farm wealth) were based on county-weighted averages for the region
4 within 50-miles of the site using data in the 2002 National Census of Agriculture (USDA 2004)
5 and the Bureau of Economic Analysis (BEA 2008). Food ingestion was modeled using the new
6 MACCS2 ingestion pathway model COMIDA2 (NRC 1998). For SGS, less than one percent of
7 the total population dose risk is due to food ingestion.

8 In addition, generic economic data that is applied to the region as a whole were revised from the
9 MACCS2 sample problem input in order to account for cost escalation since 1986, the year that
10 input was first specified. A factor of 1.96, representing cost escalation from 1986 to April 2008
11 was applied to parameters describing cost of evacuating and relocating people, land
12 decontamination, and property condemnation.

13 The NRC staff concludes that the methodology used by PSEG to estimate the offsite
14 consequences for SGS provides an acceptable basis from which to proceed with an
15 assessment of risk reduction potential for candidate SAMAs. Accordingly, the NRC staff based
16 its assessment of offsite risk on the CDF and offsite doses reported by PSEG.

17 **F.3 Potential Plant Improvements**

18 The process for identifying potential plant improvements, an evaluation of that process, and the
19 improvements evaluated in detail by PSEG are discussed in this section.

20 **F.3.1 Process for Identifying Potential Plant Improvements**

21 PSEG's process for identifying potential plant improvements (SAMAs) consisted of the following
22 elements:

- 23 • Review of the most significant basic events from the current, plant-specific PRA and
24 insights from the SGS PRA group,
- 25 • Review of potential plant improvements identified in, and original results of, the SGS IPE
26 and IPEEE,
- 27 • Review of SAMA candidates identified for license renewal applications for six other U.S.
28 nuclear sites, and
- 29 • Review of generic SAMA candidates from NEI 05-01 (NEI 2005) to identify SAMAs that
30 might address areas of concern identified in the SGS PRA.

31 Based on this process, an initial set of 27 candidate SAMAs, referred to as Phase I SAMAs, was
32 identified. In Phase I of the evaluation, PSEG performed a qualitative screening of the initial list
33 of SAMAs and eliminated SAMAs from further consideration using the following criteria:

- 1 • The SAMA is not applicable to SGS due to design differences
- 2 • The SAMA has already been implemented at SGS,
- 3 • The SAMA would achieve results that have already been achieved at SGS by other
4 means, or
- 5 • The SAMA has estimated implementation costs that would exceed the dollar value
6 associated with completely eliminating all severe accident risk at SGS.

7 Based on this screening, two SAMAs were eliminated leaving 25 for further evaluation. The
8 results of the Phase I screening analysis is given in Table E.5-3 of Appendix E to the ER. The
9 remaining SAMAs, referred to as Phase II SAMAs, are listed in Table E.6-1 of Appendix E to the
10 ER. In Phase II, a detailed evaluation was performed for each of the 25 remaining SAMA
11 candidates, as discussed in Sections F.4 and F.6 below. To account for the potential impact of
12 external events, the estimated benefits based on internal events were multiplied by a factor of 2,
13 as previously discussed.

14 **F.3.2 Review of PSEG's Process**

15 PSEG's efforts to identify potential SAMAs focused primarily on areas associated with internal
16 initiating events, but also included explicit consideration of potential SAMAs for important fire
17 and seismic initiated core damage sequences. The initial list of SAMAs generally addressed the
18 accident sequences considered to be important to CDF from risk reduction worth (RRW)
19 perspectives at SGS, and included selected SAMAs from prior SAMA analyses for other plants.

20 PSEG provided a tabular listing of the Level 1 PRA basic events sorted according to their RRW
21 (PSEG 2009). SAMAs impacting these basic events would have the greatest potential for
22 reducing risk. PSEG used a RRW cutoff of 1.01, which corresponds to about a one percent
23 change in CDF given 100-percent reliability of the SAMA. This equates to a benefit of
24 approximately \$164,000 (after the benefits have been multiplied by a factor of 2 to account for
25 external events). PSEG also provided and reviewed the Level 2 PRA basic events, down to a
26 RRW of 1.01, for the release categories contributing over 94 percent of the population dose-risk.
27 The Level 2 basic events for the remainder of the release categories were not included in the
28 review so as to prevent high frequency-low consequence events from biasing the importance
29 listing. All of the basic events on the Level 1 and 2 importance lists were addressed by one or
30 more of the SAMAs (PSEG 2009). As a result of the review of the Level 1 and Level 2 basic
31 events, 19 SAMAs were identified.

32 The NRC staff requested PSEG to extend the review of the Level 1 and 2 basic events down to
33 a RRW threshold of 1.003, which equates to a benefit of approximately \$50,000, the assumed
34 cost of a procedural change at SGS (NRC 2010a). In response to the RAI, PSEG provided
35 revised Level 1 and Level 2 importance lists using SGS PRA model of record Revision 4.3,
36 which was discussed in Section F.2.2, and extended the review of the basic events down to an

1 RRW of 1.006, which equates to a benefit of about \$47,000 using PRA Revision 4.3. The
2 review identified the following three additional SAMAs associated with new basic events added
3 to the importance lists (PSEG 2010a):

- 4 • SAMA 30 – Automatic Start of Diesel-Powered Air Compressor
- 5 • SAMA 31 – Fully Automate Swapover to Sump Recirculation
- 6 • SAMA 32 – Enhance Flood Detection for 100-foot Auxiliary Building and Enhance
7 Procedural Guidance for Responding to Internal Floods

8 A Phase II detailed evaluation was performed for each of these additional SAMAs, which is
9 discussed in Section F.6.2.

10 The NRC staff asked PSEG to clarify the appropriateness of determining importance factors,
11 and SAMAs, for initiators that are identified as flag events having an assigned probability of 1.0
12 (NRC 2010a). PSEG explained in response to the RAI that fault trees were developed for
13 several loss of support system initiating events (PSEG 2010a). Those events that lead to the
14 loss of a support system and are responsible for causing the modeled initiating event were
15 identified as flag events. These events are representative of that initiating event's contribution
16 to CDF and were therefore considered appropriate by PSEG for risk ranking. PSEG further
17 clarified that events whose failure leads to the occurrence of the modeled initiating event will
18 also be listed in the importance list ranking and that the flag probability was therefore set to 1.0
19 to determine the appropriate CDF contribution of the cutsets. The RRW calculated for these
20 flag events therefore correctly measures the risk significance of the initiating event modeled in
21 this manner.

22 The NRC staff also asked PSEG to clarify the significance of determining importance factors,
23 and SAMAs, for two split fraction events identified in the importance listing: "RCS-SLOCA-
24 SPLIT" and "MFI-UNAVAILABLE" (NRC 2010a). PSEG explained in response to the RAI that
25 the first event, "RCS-SLOCA-SPLIT," is a flag event that indicates those cutsets in which an
26 RCP seal LOCA has occurred and that the second event, "MFI-UNAVAILABLE," is the
27 conditional probability that the main feedwater system is unavailable given that a reactor trip
28 signal has been generated, irrespective of whether an ATWS condition exists (PSEG 2010a).
29 Because the first event is a flag event, it was assigned a probability of 1.0. SAMA 6, "Enhance
30 Flood Detection for 84' Auxiliary Building and Enhance Procedural Guidance for Responding to
31 Service Water Flooding," was identified because isolating a service water rupture early could
32 help prevent the conditions that can lead to an RCP seal LOCA. The second event was
33 assigned a conditional probability of 0.3. SAMA 14, "Expand ATWS Mitigation System
34 Actuation Circuitry (AMSAC) Function to Include Backup Breaker Trip on Reactor Protection
35 System (RPS) Failure," was identified to use the AMSAC system to provide a redundant trip
36 signal to help mitigate ATWS events. In over 60 percent of the scenarios in which MFI-

1 UNAVAILABLE is a contributor, AMSAC maintenance is also a contributor. By mitigating ATWS
2 events, SAMA 14 also mitigates scenarios having this combination of events.

3 PSEG reviewed the cost-beneficial Phase II SAMAs from prior SAMA analyses for five
4 Westinghouse PWR and one General Electric BWR sites. PSEG's review determined that all of
5 the Phase II SAMAs reviewed were either already represented by a SAMA identified from the
6 Level 1 and 2 importance list reviews, are already addressed by other means, have low
7 potential for risk reduction at SGS, or were not applicable to the SGS design. This review
8 resulted in no additional SAMAs being identified.

9 The NRC staff noted that PSEG's review of these other analyses appeared to have overlooked
10 additional cost-beneficial SAMAs identified during the staff's review of these same SAMA
11 analyses and requested PSEG provide an assessment any additional cost-beneficial SAMAs
12 identified during these reviews for applicability to SGS (NRC 2010a). In response to the RAI,
13 PSEG reviewed the cost-beneficial SAMAs identified in the NRC-issued NUREG-1437 reports
14 for each of the six nuclear sites and concluded the cost-beneficial SAMA either 1) was already
15 identified and evaluated in the ER, 2) was already implemented at SGS, or 3) would not reduce
16 SGS risk (PSEG 2010a). No additional SAMAs were identified from this review.

17 PSEG considered the potential plant improvements described in the IPE in the identification of
18 plant-specific candidate SAMAs for internal events. Review of the IPE lead to no additional
19 SAMA candidates since the three improvements identified in the IPE have already been
20 implemented at SGS (PSEG 2009).

21 As a sensitivity case to SAMA 5, PSEG identified and evaluated SAMA 5A, "Install Portable
22 Diesel Generators to Charge Station Battery and Circulating Water Batteries." This SAMA only
23 addresses cases in which RCP seals remain intact, which occurs in a majority of the SBO
24 scenarios. PSEG performed a Phase II evaluation of SAMA 5A, which is in addition to the
25 Phase II evaluations performed for the 25 SAMAs discussed above that were not screened
26 during the Phase I evaluation.

27 Based on this information, the NRC staff concludes that the set of SAMAs evaluated in the ER,
28 together with those identified in response to NRC staff RAIs, addresses the major contributors
29 to internal event CDF.

30 Although the IPEEE did not identify any fundamental vulnerabilities or weaknesses related to
31 external events, the ER identified three improvements related to external events (PSEG 2009).
32 The NRC staff noted that the IPEEE safety evaluation report (NRC 1999) identified five total
33 improvements related to external events and requested PSEG review these improvements for
34 potentially additional SAMAs (NRC 2010a). In response to the RAI, PSEG reviewed the five
35 suggested improvements and reassessed the three improvements originally evaluated in the ER
36 (PSEG 2010a). As a result of this review, two improvements related to fire events, three
37 improvements related to seismic events, and three improvements related to HFO events were

1 identified. The two suggested fire-related improvements have been implemented, two of the
2 seismic-related improvements have been implemented, and two of the HFO-related
3 improvements have been implemented. The remaining two improvements that have not been
4 implemented are as follows:

- 5 • Seismic-related improvement – reinforcement of an 8-foot masonry wall in the 4kV
6 switchgear room. PSEG described the results of an evaluation that determined there
7 was no interaction between the wall and the switchgear bus during a seismic event and
8 subsequent implementation of a corrective action to revise the associated calculation to
9 clarify the lack of interaction. Based on this, PSEG concluded that reinforcement of the
10 masonry wall was not necessary and no SAMA is suggested (PSEG 2010a).
- 11 • HFO-related improvement – improve hold downs for the hydrogen tanks to protect
12 against tornados. In response to the RAI, PSEG performed a walk down of the
13 hydrogen racks and determined that the IPEEE suggested improvements to the Unit 2
14 racks to make the design consistent with the Unit 1 racks was not implemented as
15 indicated in the ER. PSEG further noted that the IPEEE states that these hydrogen
16 tanks “will not have any significant impact on safety structures.” Based on this, PSEG
17 concluded that, while the suggested change was prudent, it would not reduce plant risk
18 and no SAMA is suggested.

19 In the ER PSEG also identified three post IPEEE site changes to determine if they could impact
20 the IPEEE results and possibly lead to a SAMA. From this review, one plant change to replace
21 CO₂ fire suppression with water sprinkler systems was determined to have an impact on fire
22 CDF, which was discussed in Section F.2.2. No additional SAMAs were identified from this
23 review.

24 In a further effort to identify external event SAMAs, PSEG reviewed the top 10 fire areas
25 contributing to fire CDF based on the results of the IPEEE and interim SGS fire PRA models.
26 These areas are all of the SGS fire areas having a maximum benefit equal to or greater than
27 approximately \$50,000, which is the approximate value of implementing a procedure change at
28 a single unit at SGS. The maximum benefit for a fire area is the dollar value associated with
29 completely eliminating the fire risk in that fire area, which is discussed in Section F.6.2. SAMAs
30 having an implementation cost of less than that of a procedure change, or \$50,000, are unlikely.
31 As a result of this review, PSEG identified five Phase I SAMAs to reduce fire risk. The SAMAs
32 identified included both procedural and hardware alternatives (PSEG 2009). The NRC staff
33 concludes that the opportunity for fire-related SAMAs has been adequately explored and that it
34 is unlikely that there are additional potentially cost-beneficial, fire-related SAMA candidates.

35 For seismic events, PSEG reviewed the top seven seismic sequences contributing to seismic
36 CDF based on the results of the IPEEE seismic PRA model. These areas are all of the SGS
37 seismic sequences having a benefit equal to or greater than approximately \$50,000, which is
38 the approximate value of implementing a procedure change at a single unit at SGS. The

1 maximum benefit for a seismic sequence is the dollar value associated with completely
2 eliminating the seismic risk for that sequence, which is discussed in Section F.6.2. SAMAs
3 having an implementation cost of less than that of a procedure change, or \$50,000, are unlikely.
4 As a result of this review, PSEG identified three additional Phase I SAMAs to reduce seismic
5 risk (PSEG 2009). The NRC staff concludes that the opportunity for seismic-related SAMAs has
6 been adequately explored and that it is unlikely that there are additional potentially cost-
7 beneficial, seismic-related SAMA candidates.

8 As stated earlier, other external hazards (high winds, external floods, transportation and nearby
9 facility accidents, release of on-site chemicals, and detritus) are below the IPEEE threshold
10 screening frequency, or met the 1975 SRP design criteria, and are not expected to represent
11 vulnerabilities. Nevertheless, PSEG reviewed the IPEEE results and subsequent plant changes
12 for each of these external hazards and determined that either 1) the maximum benefit from
13 eliminating all associated risk was less than approximately \$50,000, which is the approximate
14 value of implementing a procedure change at a single unit at SGS, or 2) only hardware
15 enhancements that would significantly exceed the maximum value of any potential risk
16 reduction were available. As a result of this review, PSEG identified no additional Phase I
17 SAMAs to reduce HFO risk (PSEG 2009). The NRC staff concludes that the licensee's
18 rationale for eliminating other external hazards enhancements from further consideration is
19 reasonable.

20 The NRC staff noted that, while the generic SAMA list from NEI 05-01 (NEI 2005) was stated to
21 have been used in the identification of SAMAs for SGS, it was not specifically reviewed to
22 identify SAMAs that might be applicable to SGS but rather was used to identify SAMAs that
23 might address areas of concern identified in the SGS PRA (NRC 2010a). The NRC staff asked
24 PSEG to provide further information to justify that this approach produced a comprehensive set
25 of SAMAs for consideration. In response to the RAI, PSEG explained that, based on the early
26 SAMA reviews, both the industry and NRC came to realize that a review of the generic SAMA
27 list was of limited benefit because they were consistently found to not be cost-beneficial and that
28 the real benefit was considered to be in the development of SAMAs generated based on plant
29 specific risk insights from the PRA models (PSEG 2010a).

30 Furthermore, while the generic list does include potential plant improvements for plants having a
31 similar design to SGS, plant designs are sufficiently different that the specific plant
32 improvements identified in the generic list are generally not directly applicable to SGS, and
33 require alteration to specifically address the SGS design and risk contributors or otherwise
34 would be screened as not applicable to the SGS design. For these reasons, PSEG concludes
35 that the real value of the NEI 05-01 generic SAMA list is as an idea source to generate SAMAs
36 that address important contributors to SGS risk. The NRC staff accepts PSEG's conclusion.

37 The NRC staff questioned PSEG about potentially lower cost alternatives to some of the SAMAs
38 evaluated (NRC 2010a), including:

- 1 • Operating the AFW AF11/21 valves closed.
- 2 • Install improved fire barriers in the 460V switchgear rooms to provide separation
3 between the three power divisions.
- 4 • Install improved fire barriers to provide separation between the AFW pumps.

5 In response to the RAIs, PSEG addressed the suggested lower cost alternatives and
6 determined that they were either not feasible or were not cost-beneficial (PSEG 2010a). This is
7 discussed further in Section F.6.2.

8 The NRC staff notes that the set of SAMAs submitted is not all-inclusive, since additional,
9 possibly even less expensive, design alternatives can always be postulated. However, the NRC
10 staff concludes that the benefits of any additional modifications are unlikely to exceed the
11 benefits of the modifications evaluated and that the alternative improvements would not likely
12 cost less than the least expensive alternatives evaluated, when the subsidiary costs associated
13 with maintenance, procedures, and training are considered.

14 The NRC staff concludes that PSEG used a systematic and comprehensive process for
15 identifying potential plant improvements for SGS, and that the set of potential plant
16 improvements identified by PSEG is reasonably comprehensive and, therefore, acceptable.
17 This search included reviewing insights from the plant-specific risk studies, and reviewing plant
18 improvements considered in previous SAMA analyses. While explicit treatment of external
19 events in the SAMA identification process was limited, it is recognized that the prior
20 implementation of plant modifications for fire and seismic risks and the absence of external
21 event vulnerabilities reasonably justifies examining primarily the internal events risk results for
22 this purpose.

23 **F.4 Risk Reduction Potential of Plant Improvements**

24 PSEG evaluated the risk-reduction potential of the 25 remaining SAMAs and one sensitivity
25 case SAMA that were applicable to SGS. The SAMA evaluations were performed using realistic
26 assumptions with some conservatism. On balance, such calculations overestimate the benefit
27 and are conservative.

28 PSEG used model re-quantification to determine the potential benefits. The CDF, population
29 dose reductions, and offsite economic cost reductions were estimated using the SGS PRA
30 model. The changes made to the model to quantify the impact of SAMAs are detailed in
31 Section E.6 of Appendix E to the ER (PSEG 2009). Table F-6 lists the assumptions considered
32 to estimate the risk reduction for each of the evaluated SAMAs, the estimated risk reduction in
33 terms of percent reduction in CDF and population dose, and the estimated total benefit (present
34 value) of the averted risk. The estimated benefits reported in Table F-6 reflect the combined
35 benefit in both internal and external events. The determination of the benefits for the various
36 SAMAs is further discussed in Section F.6.

1 The NRC staff questioned the assumptions used in evaluating the benefit or risk reduction
2 estimate of SAMA 24, "provide procedural guidance to cross-tie Salem 1 and 2 service water
3 systems" (NRC 2010a). The ER assumed this SAMA did not benefit from a reduction in fire risk
4 yet indicates that this SAMA was identified based on a review of the SGS IPEEE fire PRA
5 model results. In response to an NRC staff RAI, PSEG clarified that this SAMA was actually
6 identified from the review of the internal events importance list, that the procedural guidance
7 suggested in this SAMA to perform the inter-unit service water cross-tie is already in place for
8 fire events and that, therefore, implementation of this SAMA would have no additional benefits
9 in fire events (PSEG 2010a). Based on this, PSEG concluded that this SAMA has been
10 appropriately evaluated.

11 The NRC staff noted that the total of the risk reduction results calculated by summing the
12 individual results for each release category for SAMAs 2, 4, 5A, 18, and 19 was different than
13 the summary results that were used in the SAMA evaluation (NRC 2010a). In response to the
14 RAI, PSEG explained that the release category results provided in the ER for these SAMAs
15 were incorrect, due to typographical errors, and the correct results were provided (PSEG
16 2010a). PSEG further explained that the SAMA evaluation reported in the ER used the correct
17 release category results and therefore no re-evaluation of the SAMAs was necessary. The
18 NRC staff accepts PSEG's explanation.

19 For SAMAs that specifically addressed fire events (i.e., SAMA 21, "Seal the Category II and III
20 Cabinets in the Relay Room," SAMA 22, "Install Fire Barriers between the 1CC1, 1CC2, and
21 1CC3 Consoles in the Control Room Enclosure (CRE)," and SAMA 23, "Install Fire Barriers and
22 Cable Wrap to Maintain Divisional Separation in the 4160V AC Switchgear Room."), the
23 reduction in fire CDF and population dose was not directly calculated (in Table F-5 this is noted
24 as "Not Estimated"). For these SAMAs, an estimate of the impact was made based on general
25 assumptions regarding: the approximate contribution to total risk from external events relative to
26 that from internal events; the fraction of the external event risk attributable to fire events; the
27 fraction of the fire risk affected by the SAMA (based on information from the IPEEE and interim
28 SGS Fire Model results); and the assumption that SAMAs 21 and 22 completely eliminate the
29 fire risk affected by the SAMA and that SAMA 23 eliminates 95 percent of the fire risk affected
30 by the SAMA. Specifically, it is assumed that the contribution to risk from external events is
31 approximately equal to that from internal events, and that internal fires contribute 72 percent of
32 this external events risk. The fire areas impacted by the SAMA are identified and the portion of
33 the total fire risk contributed by each of these fire areas determined. For SAMAs 21 and 22, the
34 benefit or averted cost risk from reducing the fire risk affected by the SAMA is then calculated
35 by multiplying the ratio of the fire risk affected by the SAMA to the internal events CDF by the
36 total present dollar value equivalent associated with completely eliminating severe accidents
37 from internal events at SGS. For SAMA 23, the benefit or averted cost risk from reducing the
38 fire risk affected by the SAMA is then calculated by multiplying the ratio of 95 percent of the fire
39 risk affected by the SAMA to the internal events CDF by the total present dollar value equivalent
40 associated with completely eliminating severe accidents from internal events at SGS. These
41 SAMAs were assumed to have no additional benefits in internal events.

1 In addition to those SAMAs that only addressed fire events, PSEG evaluated the additional
2 benefits from reducing fire risk for the following SAMAs that also had internal events benefits:
3 SAMA 1, "Enhance Procedures and Provide Additional Equipment to Respond to Loss of
4 Control Area Ventilation," SAMA 8, "Install High Pressure Pump Powered with Portable Diesel
5 Generator and Long-term Suction Source to Supply the AFW Header," and SAMA 20, "Fire
6 Protection System to Provide Make-up to RCS and Steam Generators." The benefit or averted
7 cost risk from reducing the fire risk affected by these SAMAs was calculated similar to the
8 method described above with the exception that the fire risk affected by each of these SAMAs
9 were assumed to be reduced based on the same failure probability as was assumed for internal
10 events (i.e., 2.0E-02 for SAMA 1, 1.0E-02 for SAMA 8, and 1.0E-01 for SAMA 20). In other
11 words, SAMA 1 was assumed to eliminate 98 percent, SAMA 8 was assumed to eliminate 99
12 percent, and SAMA 20 was assumed to eliminate 90 percent of the fire risk affected by these
13 SAMAs. The benefit or averted cost risk from reducing the fire risk affected by SAMA 1 is then
14 calculated by multiplying the ratio of 98 percent of the fire risk affected by the SAMA to the
15 internal events CDF by the total present dollar value equivalent associated with completely
16 eliminating severe accidents from internal events at SGS. The benefit from reducing fire risk
17 was calculated similarly for SAMAs 8 and 20. For SAMAs 1 and 8, PSEG added the calculated
18 benefit from reducing fire risk to the benefit from internal events, which was doubled to account
19 for all external events, to obtain the total benefit from internal and external events. This is
20 discussed further in Section F.6.2.

21 PSEG also evaluated the additional benefits from reducing seismic risk for the following SAMAs
22 that also had internal events benefits: SAMA 5, "Enhance Procedures and Provide Additional
23 Equipment to Respond to Loss of Control Area Ventilation," SAMA 5A, "Install Portable Diesel
24 Generators to Charge Station Battery and Circulating Water Batteries," SAMA 20, "Fire
25 Protection System to Provide Make-up to RCS and Steam Generators," and SAMA 27, "In
26 addition to the Equipment Installed for SAMA 5, Install Permanently Piped Seismically Qualified
27 Connections to Alternate AFW Water Sources." For these SAMAs, an estimate of the seismic
28 impact was made based on general assumptions regarding: the approximate contribution to
29 total risk from external events relative to that from internal events; the fraction of the external
30 event risk attributable to seismic events; the fraction of the seismic risk affected by the SAMA
31 (based on information from the IPEEE); and the assumption that these SAMAs would reduce
32 the contribution to the seismic CDF from the impacted seismic sequences by 90 percent.
33 Specifically, it is assumed that the contribution to risk from external events is approximately
34 equal to that from internal events, and that seismic events contribute 18 percent of this external
35 events risk. The seismic sequences impacted by the SAMA are identified and the portion of the
36 total seismic risk contributed by each of these seismic sequences determined. The benefit or
37 averted cost risk from reducing the seismic risk affected by the SAMA is then calculated by
38 multiplying the ratio of 90 percent of the seismic risk affected by the SAMA to the internal events
39 CDF by the total present dollar value equivalent associated with completely eliminating severe
40 accidents from internal events at SGS. For SAMAs 5, 5A, and 27, PSEG added the calculated
41 benefit from reducing seismic risk to the benefit from internal events, which was doubled to

1 account for all external events, to obtain the total benefit from internal and external events. This
2 is discussed further in Section F.6.2.

3 For SAMA 20, PSEG multiplied the benefit from internal events by a factor of 1.1 to account for
4 other (non-fire/non-seismic) events and added this to the benefits or averted cost risk from
5 reducing fire risk and seismic risk to obtain the total benefit from internal and external events.
6 This is discussed further in Section F.6.2.

7 The NRC staff has reviewed PSEG's bases for calculating the risk reduction for the various
8 plant improvements and concludes, with the above clarifications, that the rationale and
9 assumptions for estimating risk reduction are reasonable and generally conservative (i.e., the
10 estimated risk reduction is higher than what would actually be realized). Accordingly, the NRC
11 staff based its estimates of averted risk for the various SAMAs on PSEG's risk reduction
12 estimates.

Table F-6. SAMA Cost/Benefit Screening Analysis for SGS^(a)

SAMA	Assumptions	% Risk Reduction		Total Benefit (\$)		Cost (\$)
		CDF	Population Dose	Baseline (Internal + External)	Baseline With Uncertainty ^(e)	
1 – Enhance Procedures and Provide Additional Equipment to Respond to Loss of Control Area Ventilation	Modify fault tree to include a new HEP event, having a failure probability of 2.0E-02, representing failure of the operator to open doors and align fans. In addition, reduce the fire CDF contribution from fires in Fire Area 1FA-EP-100G/1F1-PP-100H assuming the same failure probability.	34	30	4.8M	12M	475K
2 – Re-configure SGS 3 to Provide a More Expedient Backup AC Power Source for SGS 1 and 2	SGS 3 (gas turbine) credited for weather-related and switchyard LOOPs.	10	10	1.6M	4.0M	875K
3 – Install Limited EDG Cross-Tie Capability Between SGS 1 and 2	Modify fault tree to include a new basic event, having a failure probability of 5.0E-02, representing failure to cross-tie.	16	15	2.4M	6.0M	4.2M
4 – Install Fuel Oil Transfer Pump on “C” EDG & Provide Procedural Guidance for Using “C” EDG to Power Selected “A” and “B” Loads	Modify fault tree to include a new basic event, having a failure probability of 1.0E-02, representing failure of all three fuel oil transfer pumps. Also modify fault tree to cross-tie Train A, B, and C engineered safety feature (ESF) buses.	16	15	2.4M	6.0M	585K

Table F-6. SAMA Cost/Benefit Screening Analysis for SGS^(a)

SAMA	Assumptions	% Risk Reduction		Total Benefit (\$)		Cost (\$)
		CDF	Population Dose	Baseline (Internal + External)	Baseline With Uncertainty ^(e)	
5 – Install Portable Diesel Generators to Charge Station Battery and Circulating Water Batteries and Replace PDP with Air-Cooled Pump	Modify fault tree to include a new basic event, having a failure probability of 1.0E-01, representing hardware and operator failure of new charging pump. Also, as provided in response to an NRC staff RAI, likelihood of offsite power nonrecovery changed to 1.0E-02 from 2.4E-01 for grid and from 1.0E-01 for site/switchyard-related causes and to 3.0E-02 from 2.4E-01 for weather-related causes.	16	11	3.1M	7.6M	3.3M
5A ^(b) – Install Portable Diesel Generators to Charge Station Battery and Circulating Water Batteries	As provided in response to an NRC staff RAI, likelihood of offsite power nonrecovery changed to 1.0E-02 from 2.4E-01 for grid and from 1.0E-01 for site/switchyard-related causes and to 3.0E-02 from 2.4E-01 for weather-related causes.	10	10	2.4M	6.0M ^(d)	770K
6 – Enhance Flood Detection for 84' Auxiliary Building and Enhance Procedural Guidance for Responding to Service Water Flooding	The failure probabilities of existing operator actions to detect and isolate floods successfully were multiplied by a factor of 0.1.	6	1	300K	750K	250K
7 – Install "B" Train Auxiliary Feedwater Storage Tank (AFWST) Makeup Including Alternate Water Source	Modify fault tree to include a new basic event, having a failure probability of 1.0E-03, representing failure of the alternate water source.	7	1	410K	1.0M	470K
8 – Install High Pressure Pump Powered with Portable Diesel	Modify fault tree to include a new basic event, having a failure	15	6	1.6M	4.1M	2.5M

Table F-6. SAMA Cost/Benefit Screening Analysis for SGS^(a)

SAMA	Assumptions	% Risk Reduction		Total Benefit (\$)		Cost (\$)
		CDF	Population Dose	Baseline (Internal + External)	Baseline With Uncertainty ^(e)	
Generator and Long-term Suction Source to Supply the AFW Header	probability of 1.0E-02, representing failure of the new pump. In addition, reduce the fire CDF contribution from fires in Fire Areas 12FA-SB-100/1FA-TGA-88 and 1FA-AB-84B assuming the same failure probability.					
9 – Connect Hope Creek Cooling Tower Basin to SGS Service Water System as Alternate Service Water Supply	Reduce failure probabilities for all service water fouling events by a factor of 10.	13	11	1.7M	4.3M	1.2M
10 – Provide Procedural Guidance for Faster Cooldown Loss of RCP Seal Cooling	The probability that operators would fail to reduce reactor coolant system (RCS) pressure was reduced to 0.1 from 1.0.	1	<1	110K	280K	100K
11 – Modify Plant Procedures to Make use of Other Unit's PDP for RCP Seal Cooling	The probability that operators would fail to respond short/long-term seal injection demand was reduced to 0.1 from 1.0.	13	12	2.0M	5.0M	100K
12 – Improve Flood Barriers Outside of 220/440VAC Switchgear Rooms	Reduce likelihood that the drains would fail to remove the volume of water assumed in the flooding analysis from 1.0E-01 to 1.0E-03.	3	3	550K	1.4M	475K
13 – Install Primary Side Isolation Valves on the Steam Generators	Reduce likelihood of a SGTR in each steam generator from 1.75E-03 to 1.75E-05.	6	30	5.2M	13M	18M

Table F-6. SAMA Cost/Benefit Screening Analysis for SGS^(a)

SAMA	Assumptions	% Risk Reduction		Total Benefit (\$)		Cost (\$)
		CDF	Population Dose	Baseline (Internal + External)	Baseline With Uncertainty ^(e)	
14 – Expand AMSAC Function to Include Backup Breaker Trip on Reactor Protection System (RPS) Failure	Modify fault tree to AND the current event for electrical RPS trip failure with the top gate for AMSAC.	19	<1	530K	1.3M	485K
15 – Automate RCP Seal Injection Realignment upon Loss of Component Cooling Water (CCW)	Reduce likelihood of failure to isolate letdown and realign suction source to the refueling water storage tank (RWST) from 1.0E-02 to 1.0E-03.	1	<1	42K	69K	210K
16 – Install Additional Train of Switchgear Room Cooling	Reduce likelihood of operator failure to open doors and establish alternate switchgear room cooling from 5.90E-03 to 5.90E-05.	1	1	180K	450K	2.5M
17 – Enhance Procedures and Provide Additional Equipment to Respond to Loss of EDG Control Room Ventilation	As provided in response to an NRC staff RAI, reduce likelihood of failure of EDG control room HVAC fans from 4.80E-03 to 4.8E-04 for two fans and 2.3E-06 for the third fan.	3	3	510K	1.3M	200K
18 – Redundant Service Water (SW) Turbine Header Isolation Valve	Reduce failure probability for the operator action to close the SW turbine header valves from 2.20E-02 to 1.0E-03.	<1	<1	140K	350K	635K
19 – Install Spray Shields on Residual Heat Removal (RHR) Pumps	Reduce initiating event frequency for the 45' elevation Auxiliary Building spray scenario from 7.60E-04 to 7.60E-06.	1	0	34K	84K	350K

Table F-6. SAMA Cost/Benefit Screening Analysis for SGS^(a)

SAMA	Assumptions	% Risk Reduction		Total Benefit (\$)		Cost (\$)
		CDF	Population Dose	Baseline (Internal + External)	Baseline With Uncertainty ^(e)	
20 – Fire Protection System to Provide Make-up to RCS and Steam Generators (SGs)	Modify fault tree to include two new basic events, having failure probabilities of 1.0E-02 and 1.0E-01, representing failure of the new AFW pump and independently-powered charging pump, respectively. In addition, reduce the fire CDF contribution from fires in Fire Areas 1FA-AB-84A, 1FA-EP-78C, 1FA-AB-64A, 1FA-AB-84B, and 12FA-SB-100/1FA-TGA-88 assuming the same failure probability of 1.0E-01.	21	7	5.1M	12.7M	13M
21 – Seal the Category II and III Cabinets in the Relay Room	Eliminate the fire CDF contribution from fire damage state 1RE2.	NOT ESTIMATED		870K	2.2M	3.2M
22 – Install Fire Barriers between the 1CC1, 1CC2, and 1CC3 Consoles in the CRE	Eliminate the fire CDF contribution from Fire Damage State CR16.	NOT ESTIMATED		330K	830K	1.6M
23 – Install Fire Barriers and Cable Wrap to Maintain Divisional Separation in the 4160V AC Switchgear Room	Reduce the fire CDF contribution from transient combustible fires in Fire Area 1FA-AB-64A, 4160 Switchgear Room, by 95 percent.	NOT ESTIMATED		300K	750K	975K
24 – Provide Procedural Guidance to Cross-tie SGS 1 and 2 Service Water Systems	Modify fault tree to prevent a complete loss of service water event for events which can affect service water supply to one unit only.	9	4	700K	1.8M	175K

Table F-6. SAMA Cost/Benefit Screening Analysis for SGS^(a)

SAMA	Assumptions	% Risk Reduction		Total Benefit (\$)		Cost (\$)
		CDF	Population Dose	Baseline (Internal + External)	Baseline With Uncertainty ^(e)	
27 – In addition to the Equipment Installed for SAMA 5, Install Permanently Piped Seismically Qualified Connections to Alternate AFW Water Sources	Modify fault tree to include a new basic event, having a failure probability of 1.0E-01, representing hardware and operator failure of new charging pump. Also, as provided in response to an NRC staff RAI, likelihood of offsite power nonrecovery changed to 1.0E-02 from 2.4E-01 for grid and from 1.0E-01 for site/switchyard-related causes and to 3.0E-02 from 2.4E-01 for weather-related causes.	16	11	3.1M	7.7M	4.2M
30 ^(c) – Automatic Start of Diesel-Powered Air Compressor	The failure probability for the operator action to start the diesel-powered air compressor was reduced by a factor of 100 to 6.3E-04 from 6.3E-02.	1	<1	40K	83K	100K
31 ^(c) – Fully Automate Swapover to Sump Recirculation	The failure probability for the operator action to swapover to sump recirculation was reduced by a factor of 100 to 5.3E-05 from 5.3E-03.	1	<1	27K	56K	100K
32 ^(c) – Enhance Flood Detection for 100-foot Auxiliary Building and Enhance Procedural Guidance for Responding to Internal Floods	The failure probability for the operator action to isolate the flood source was reduced by a factor of 100 to 1.0E-03 from 1.0E-01.	1	<1	50K	100K	250K

Table F-6. SAMA Cost/Benefit Screening Analysis for SGS^(a)

SAMA	Assumptions	% Risk Reduction		Total Benefit (\$)		Cost (\$)
		CDF	Population Dose	Baseline (Internal + External)	Baseline With Uncertainty ^(e)	

- (a) SAMAs in bold are potentially cost-beneficial.
- (b) SAMA 5A added as a sensitivity case to SAMA 5 to provide a comprehensive, long term mitigation strategy for SBO scenarios.
- (c) SAMAs 30, 31, and 32 were identified and evaluated in response to an NRC staff RAI (PSEG 2010a). The RAI response stated that the percent risk reduction was developed using SGS PRA Model Version 4.3 and that the implementation costs for SAMAs 30 and 31 are expected to be significantly greater than the \$100K assumed in the SAMA evaluation.
- (d) Value estimated by NRC staff using information provided in the ER.
- (e) Using a factor of 2.5.

1 **F.5 Cost Impacts of Candidate Plant Improvements**

2 PSEG estimated the costs of implementing the 25 candidate SAMAs through the development
3 of site-specific cost estimates. The cost estimates conservatively did not include the cost of
4 replacement power during extended outages required to implement the modifications (PSEG
5 2009).

6 The NRC staff reviewed the bases for the applicant's cost estimates (presented in Table E.5-3
7 of Attachment E to the ER). For certain improvements, the NRC staff also compared the cost
8 estimates to estimates developed elsewhere for similar improvements, including estimates
9 developed as part of other licensees' analyses of SAMAs for operating reactors.

10 The ER stated that plant personnel developed SGS-specific costs to implement each of the
11 SAMAs. The NRC staff requested more information on the process PSEG used to develop the
12 SAMA cost estimates (NRC 2010a). PSEG responded to the RAI by explaining that the cost
13 estimates were developed in a series of meetings involving personnel responsible for
14 development of the SAMA analysis and the two PSEG license renewal site leads who are
15 engineering managers each having over 25 years of plant experience, including project
16 management, operations, plant engineering, design engineering, procedure support, simulators,
17 and training (PSEG 2010a). During these meetings, each SAMA was validated against the
18 plant configuration, a budget-level estimate of its implementation cost was developed, and, in
19 some instances, lower cost approaches that would achieve the same objective were developed.
20 The SAMA implementation costs were then reviewed by the Design Engineering Manager for
21 both technical and cost perspectives and revised accordingly. PSEG further explained that
22 seven general cost categories were used in development of the budget-level cost estimates:
23 engineering, material, installation, licensing, critical path impact, simulator modification, and
24 procedures and training. For costs that could be shared between the two SGS units, the total
25 estimated cost was evenly divided between the two units to develop a per unit cost. Based on
26 the use of personnel having significant nuclear plant engineering and operating experience, the
27 NRC staff considers the process PSEG used to develop budget-level cost estimates
28 reasonable.

29 In response to an RAI requesting a more detailed description of the changes associated with
30 SAMAs 3, 5, 8, 13, 20, and 23, PSEG provided additional information detailing the analysis and
31 plant modifications included in the cost estimate of each improvement (PSEG 2010a). The staff
32 reviewed the costs and found them to be reasonable, and generally consistent with estimates
33 provided in support of other plants' analyses.

34 The NRC staff also noted that the ER reported an implementation cost for SAMA 3, "Install
35 Limited EDG Cross-Tie Capability Between SGS 1 and 2," of \$4.175M in Section E.6.3 and
36 \$525K in Section E.5-3 and requested clarification on which was the correct value (NRC

1 2010a). SEG responded that \$4.175K was the correct value and stated that this value was
2 used in the SAMA evaluation (PSEG 2010a).

3 The NRC staff requested PSEG provide justification for the differences in the cost estimates for
4 SAMA 1, "Enhance Procedures and Provide Additional Equipment to Respond to Loss of
5 Control Area Ventilation," having a cost of \$475K, and SAMA 17, "Enhance Procedures and
6 Provide Additional Equipment to Respond to Loss of Emergency Diesel Generator (EDG)
7 Control Room Ventilation," having a cost of \$200K, which are similar in that each involves
8 opening doors to provide ventilation and using portable fans to enhance natural circulation
9 (NRC 2010a). In response to the RAI, PSEG stated that SAMA 1 has a higher cost because it
10 is a more complicated modification involving three rooms having differing requirements while
11 SAMA 17 involves four rooms that are basically identical (PSEG 2010a). The NRC staff
12 considers the basis for the differences in cost estimates reasonable.

13 The NRC staff noted that SAMA 21, "Seal the Category II and III Cabinets in the Relay Room,"
14 and SAMA 22, "Install Fire Barriers between the 1CC1, 1CC2, and 1CC3 Consoles in the CRE,"
15 are similar in that each involves installing fire barriers to prevent the propagation of a fire
16 between cabinets and requested an explanation for why the estimated cost of \$3.23M for SAMA
17 21 to modify 48 cabinets is similar to the estimated cost of \$1.6M for SAMA 22 to modify just
18 three consoles (NRC 2010a). PSEG responded that the cost per console (\$400K) in SAMA 22,
19 is much higher than the cost per cabinet (\$35K - \$70K) in SAMA 21 because making the
20 modifications to the Control Room consoles is more complicated than making the modifications
21 to the Relay Room cabinets (PSEG 2010a). Specifically, SAMA 22 requires making ventilation
22 modifications due to the significant heat loads in addition to adding fire barrier materials. The
23 NRC staff considers the basis for the differences in cost estimates reasonable.

24 The NRC asked PSEG to justify the estimated cost of \$100K for SAMA 10, "Provide Procedural
25 Guidance for Faster Cooldown Loss of RCP Seal Cooling," and SAMA 11, "Modify Plant
26 Procedures to Make use of Other Unit's Positive Displacement Pump (PDP) for RCP Seal
27 Cooling," in light of the statement made in the ER that the minimum expected implementation
28 cost is assumed to be a procedure change at \$50K at \$100K for the site (NRC 2010a). In
29 response to the RAI, PSEG explained that the cost for SAMA 10 includes 1) \$50K to perform a
30 feasibility study to confirm that there is no technical basis preventing implementation of a more
31 rapid cooldown on loss of RCP seal cooling and 2) \$150K to revise the emergency operating
32 procedures (EOPs), which are more expensive to revise and require more extensive training
33 than other plant procedures (PSEG 2010a). PSEG also explained that the cost for SAMA 11
34 includes 1) \$50K to perform a feasibility study to confirm that there is no technical basis
35 preventing PDP cross-tie when RCP seal cooling is lost, 2) \$50K to revise the plant procedures,
36 and 3) \$50K for each unit to involve plant licensing staff. The total of \$200K for both SAMAs is
37 divided evenly between the two units. The NRC staff considers the bases for the estimated
38 costs for these SAMAs reasonable.

39

1
2 The NRC staff concludes that the cost estimates provided by PSEG are sufficient and
3 appropriate for use in the SAMA evaluation.
4

5 6 **F.6 Cost-Benefit Comparison**

7
8 PSEG's cost-benefit analysis and the NRC staff's review are described in the following sections.
9

10 **F.6.1 PSEG's Evaluation**

11
12 The methodology used by PSEG was based primarily on NRC's guidance for performing cost-
13 benefit analysis, i.e., NUREG/BR-0184, *Regulatory Analysis Technical Evaluation Handbook*
14 (NRC 1997a). The guidance involves determining the net value for each SAMA according to
15 the following formula:
16

17 Net Value = (APE + AOC + AOE + AOOSC) – COE, where

18 APE = present value of averted public exposure (\$)

19 AOC = present value of averted offsite property damage costs (\$)

20 AOE = present value of averted occupational exposure costs (\$)

21 AOOSC = present value of averted onsite costs (\$)

22 COE = cost of enhancement (\$)
23
24

25 If the net value of a SAMA is negative, the cost of implementing the SAMA is larger than the
26 benefit associated with the SAMA and it is not considered cost-beneficial. PSEG's derivation of
27 each of the associated costs is summarized below.
28

29 NUREG/BR-0058 has recently been revised to reflect the agency's policy on discount rates.
30 Revision 4 of NUREG/BR-0058 states that two sets of estimates should be developed, one at
31 3 percent and one at 7 percent (NRC 2004). PSEG provided a base set of results using the 3
32 percent discount rate and a sensitivity study using the 7 percent discount rate (PSEG 2009).
33

34 Averted Public Exposure (APE) Costs

35
36 The APE costs were calculated using the following formula:
37

38 APE = Annual reduction in public exposure (Δ person-rem/year)
39 \times monetary equivalent of unit dose (\$2,000 per person-rem)
40 \times present value conversion factor (15.04 based on a 20-year period with a
41 3-percent discount rate)

1 As stated in NUREG/BR-0184 (NRC 1997a), it is important to note that the monetary value of
 2 the public health risk after discounting does not represent the expected reduction in public
 3 health risk due to a single accident. Rather, it is the present value of a stream of potential
 4 losses extending over the remaining lifetime (in this case, the renewal period) of the facility.
 5 Thus, it reflects the expected annual loss due to a single accident, the possibility that such an
 6 accident could occur at any time over the renewal period, and the effect of discounting these
 7 potential future losses to present value. For the purposes of initial screening, which assumes
 8 elimination of all severe accidents, PSEG calculated an APE of approximately \$2,350,000 for
 9 the 20-year license renewal period (PSEG 2009).

10 11 1.1.1.1 **Averted Offsite Property Damage Costs (AOC)**

12
13 The AOCs were calculated using the following formula:

$$14 \quad \text{AOC} = \text{Annual CDF reduction} \\ 15 \quad \quad \times \text{offsite economic costs associated with a severe accident (on a per-event basis)} \\ 16 \quad \quad \times \text{present value conversion factor.} \\ 17$$

18 This term represents the sum of the frequency-weighted offsite economic costs for each release
 19 category, as obtained for the Level 3 risk analysis. For the purposes of initial screening, which
 20 assumes elimination of all severe accidents caused by internal events, PSEG calculated an
 21 AOC of about \$306,000 based on the Level 3 risk analysis. This results in a discounted value of
 22 approximately \$4,600,000 for the 20-year license renewal period.

23 24 1.1.1.2 **Averted Occupational Exposure (AOE) Costs**

25
26 The AOE costs were calculated using the following formula:

$$27 \quad \text{AOE} = \text{Annual CDF reduction} \\ 28 \quad \quad \times \text{occupational exposure per core damage event} \\ 29 \quad \quad \times \text{monetary equivalent of unit dose} \\ 30 \quad \quad \times \text{present value conversion factor} \\ 31$$

32 PSEG derived the values for averted occupational exposure from information provided in
 33 Section 5.7.3 of the regulatory analysis handbook (NRC 1997a). Best estimate values provided
 34 for immediate occupational dose (3,300 person-rem) and long-term occupational dose (20,000
 35 person-rem over a 10-year cleanup period) were used. The present value of these doses was
 36 calculated using the equations provided in the handbook in conjunction with a monetary
 37 equivalent of unit dose of \$2,000 per person-rem, a real discount rate of 3 percent, and a time
 38 period of 20 years to represent the license renewal period. For the purposes of initial screening,
 39 which assumes elimination of all severe accidents caused by internal events, PSEG calculated
 40 an AOE of approximately \$31,000 for the 20-year license renewal period (PSEG 2009).

41 42 **Averted Onsite Costs**

1
2 Averted onsite costs (AOSC) include averted cleanup and decontamination costs and averted
3 power replacement costs. Repair and refurbishment costs are considered for recoverable
4 accidents only and not for severe accidents. PSEG derived the values for AOSC based on
5 information provided in Section 5.7.6 of NUREG/BR-0184, the regulatory analysis handbook
6 (NRC 1997a).

7
8 PSEG divided this cost element into two parts – the onsite cleanup and decontamination cost,
9 also commonly referred to as averted cleanup and decontamination costs (ACC), and the
10 replacement power cost (RPC).

11
12 ACCs were calculated using the following formula:
13

$$\begin{aligned} \text{ACC} &= \text{Annual CDF reduction} \\ &\quad \times \text{present value of cleanup costs per core damage event} \\ &\quad \times \text{present value conversion factor} \end{aligned}$$

14
15
16
17 The total cost of cleanup and decontamination subsequent to a severe accident is estimated in
18 NUREG/BR-0184 to be $\$1.5 \times 10^9$ (undiscounted). This value was converted to present costs
19 over a 10-year cleanup period and integrated over the term of the proposed license extension.
20 For the purposes of initial screening, which assumes elimination of all severe accidents caused
21 by internal events, PSEG calculated an ACC of approximately \$965,000 for the 20-year license
22 renewal period.
23

24 Long-term RPCs were calculated using the following formula:
25

$$\begin{aligned} \text{RPC} &= \text{Annual CDF reduction} \\ &\quad \times \text{present value of replacement power for a single event} \\ &\quad \times \text{factor to account for remaining service years for which replacement power is} \\ &\quad \quad \text{required} \\ &\quad \times \text{reactor power scaling factor} \end{aligned}$$

26
27
28
29
30
31
32 PSEG based its calculations on a SGS net output of 1115 megawatt electric (MWe) and scaled
33 up from the 910 MWe reference plant in NUREG/BR-0184 (NRC 1997a). Therefore PSEG
34 applied a power scaling factor of 1115/910 to determine the replacement power costs. For the
35 purposes of initial screening, which assumes elimination of all severe accidents caused by
36 internal events, PSEG calculated an RPC of approximately \$335,000 and an AOSC of
37 approximately \$1,300,000 for the 20-year license renewal period.
38

39 Using the above equations, PSEG estimated the total present dollar value equivalent associated
40 with completely eliminating severe accidents from internal events at SGS to be about \$8.28M.
41 Use of a multiplier of 2 to account for external events increases the value to \$16.56M and
42 represents the dollar value associated with completely eliminating all internal and external event
43 severe accident risk for a single unit at SGS, also referred to as the Single Unit Maximum
44 Averted Cost Risk (MACR).

1
2 1.1.1.3 **PSEG's Results**
3

4 If the implementation costs for a candidate SAMA exceeded the calculated benefit, the SAMA
5 was considered not to be cost-beneficial. In the baseline analysis contained in the ER (using a
6 3 percent discount rate and considering the impact of external events), PSEG identified 11
7 potentially cost-beneficial SAMAs. PSEG performed additional analyses to evaluate the impact
8 of parameter choices (alternative discount rates and variations in MACCS2 input parameters)
9 and uncertainties on the results of the SAMA assessment and, as a result of this analysis,
10 identified five additional potentially cost-beneficial SAMAs. PSEG also performed an analysis
11 on a less costly alternative to SAMA 5 (SAMA 5A) and found it to be potentially cost-beneficial.
12

13 The potentially cost-beneficial SAMAs for SGS are the following:
14

- 15 • SAMA 1 – Enhance Procedures and Provide Additional Equipment to Respond to Loss
16 of Control Area Ventilation
- 17 • SAMA 2 – Re-configure Salem 3 to Provide a More Expedient Backup AC Power Source
18 for Salem 1 and 2
- 19 • SAMA 3 – Install Limited EDG Cross-tie Capability Between Salem 1 and 2
- 20 • SAMA 4 – Install Fuel Oil Transfer Pump on “C” EDG & Provide Procedural Guidance for
21 Using “C” EDG to Power Selected “A” and “B” Loads
- 22 • SAMA 5 – Install Portable Diesel Generators to Charge Station Battery and Circulating
23 Water Batteries & Replace PDP with Air-Cooled Pump
- 24 • SAMA 5A – Install Portable Diesel Generators to Charge Station Battery and Circulating
25 Water Batteries
- 26 • SAMA 6 – Enhance Flood Detection for 84’ Aux Building and Enhance Procedural
27 Guidance for Responding to Service Water Flooding
- 28 • SAMA 7 – Install “B” Train AFWST Makeup Including Alternate Water Source
- 29 • SAMA 8 – Install High Pressure Pump Powered with Portable Diesel Generator and
30 Long-term Suction Source to Supply the AFW Header
- 31 • SAMA 9 – Connect Hope Creek Cooling Tower Basin to Salem Service Water System
32 as Alternate Service Water Supply

- 1 • SAMA 10 – Provide Procedural Guidance for Faster Cooldown on Loss of RCP Seal
2 Cooling
- 3 • SAMA 11 – Modify Plant Procedures to Make Use of Other Unit's PDP for RCP Seal
4 Cooling
- 5 • SAMA 12 – Improve Flood Barriers Outside of 220/440VAC Switchgear Rooms
- 6 • SAMA 14 – Expand AMSAC Function to Include Backup Breaker Trip on RPS Failure
- 7 • SAMA 17 – Enhance Procedures and Provide Additional Equipment to Respond to Loss
8 of EDG Control Room Ventilation
- 9 • SAMA 24 – Provide Procedural Guidance to Cross-tie Salem 1 and 2 Service Water
10 Systems
- 11 • SAMA 27 –In Addition to the Equipment Installed for SAMA 5, Install Permanently Piped
12 Seismically Qualified Connections to Alternate AFW Water Sources

13 PSEG indicated that they plan to further evaluate these SAMAs for possible implementation
14 using existing action-tracking and design change processes (PSEG 2009).

15
16 The potentially cost-beneficial SAMAs, and PSEG's plans for further evaluation of these
17 SAMAs, are discussed in detail in Section F.6.2.

18 19 **F.6.2 Review of PSEG's Cost-Benefit Evaluation**

20 The cost-benefit analysis performed by PSEG was based primarily on NUREG/BR-0184
21 (NRC 1997a) and discount rate guidelines in NUREG/BR-0058 (NRC 2004) and was executed
22 consistent with this guidance.

23 SAMAs identified primarily on the basis of the internal events analysis could provide benefits in
24 certain external events, in addition to their benefits in internal events. To account for the
25 additional benefits in external events, PSEG multiplied the internal event benefits for all but one
26 internal event SAMA (SAMA 20, discussed further below) by a factor of 2, which is
27 approximately the ratio of the total CDF from internal and external events to the internal event
28 CDF (PSEG 2009). As discussed in Section F.2.2, this factor was based on a seismic CDF of
29 9.5×10^{-6} per year, plus a fire CDF of 3.8×10^{-5} per year, plus the screening values for high
30 winds, external flooding, transportation, detritus, and chemical release events (1×10^{-6} per year
31 for each). The external event CDF of 5.3×10^{-5} per year is thus about 110 percent of the
32 internal events CDF used in the SAMA analysis (5.0×10^{-5} per year). The total CDF is 2.1 times
33 the internal events CDF and this was rounded to 2. Eleven SAMAs were determined to be cost-

1 beneficial in PSEG's analysis (SAMAs 1, 2, 4, 6, 9, 10, 11, 12, 14, 17, and 24 as described
2 above).

3 PSEG did not multiply the internal event benefits by the factor of 2 for three SAMAs that
4 specifically address fire risk (SAMAs 21, 22, and 23). Doubling the internal event estimate for
5 SAMAs 21, 22, and 23 would not be appropriate because these SAMAs are specific to fire risks
6 and would not have a corresponding benefit on the risk from internal events.

7 For all but one internal event SAMA also having benefits in fire and seismic risk (i.e., SAMAs 1,
8 and 8 for fire and SAMAs 5, 5A, and 27 for seismic), PSEG separately quantified the benefits for
9 fire and seismic events and added these results to the benefits from internal events and external
10 events developed from applying the factor of 2 (as discussed in Section F.4 above). The NRC
11 staff noted that this process appeared to be double counting the benefits from external events
12 and requested clarification (NRC 2010a). In response to the RAI, PSEG acknowledged that this
13 process results in "double counting" of some external event contributions to the total averted
14 cost risk and stated that this approach was retained, unless it resulted in a gross
15 misrepresentation of a SAMA's benefit, in order to avoid underestimating the external events
16 averted cost risk (PSEG 2010a). PSEG further concluded that this process does not impact the
17 conclusions of the SAMA analysis. Since the process that PSEG used over-estimates the
18 benefits from external events and therefore results in conservative estimates of the SAMA
19 benefits, the NRC staff considers the process PSEG used acceptable for the SAMA evaluation.

20 For SAMA 20, "Fire Protection System to Provide Make-up to RCS and Steam Generators,"
21 PSEG multiplied the estimated benefits for internal events by a factor of 2.0 to account for
22 external events in the Phase I analysis. In the Phase II analysis, PSEG separately quantified
23 the internal event, fire event, and seismic event benefits, as described in Section F.4 above, and
24 to account for the additional benefits in other (non-fire/non-seismic) external events, PSEG
25 multiplied the internal event benefits by a factor of 1.1, which is the ratio of the total CDF from
26 internal and other external events to the internal event CDF (based on an HFO CDF of 5.0×10^{-6}
27 per year and an internal events CDF of 5.0×10^{-5} per year used in the SAMA analysis). The
28 estimated SAMA benefits for internal events with the factor of 1.1 applied to account for other
29 external events, fire events, and seismic events were then summed to provide an overall
30 benefit. Since the methodology PSEG used accounts for both internal events and external
31 events, the NRC staff considers the methodology PSEG used for SAMA 20 acceptable for the
32 SAMA evaluation.

33 PSEG considered the impact that possible increases in benefits from analysis uncertainties
34 would have on the results of the SAMA assessment. In the ER, PSEG presents the results of
35 an uncertainty analysis of the internal events CDF which indicates that the 95th percentile value
36 is a factor of 1.64 times the point estimate CDF for SGS. Since the one Phase I SAMA that was
37 screened based on qualitative criteria was screened due to not being applicable to SGS, a re-
38 examination of the Phase I SAMAs based on the upper bound benefits was not necessary.
39 PSEG considered the impact on the Phase II screening if the estimated benefits were increased

1 by a factor of 1.64 (in addition to the multiplier of 2 for external events). Four additional SAMAs
2 became cost-beneficial in PSEG's analysis (SAMAs 5, 7, 8, and 27 as described above).

3 PSEG noted that the 95th percentile value for CDF may be underestimated because uncertainty
4 distributions are not applied to all basic events in the SGS PRA model. Based on this, PSEG
5 used a factor of 2.5 times the point estimate CDF to represent the 95th percentile value, which is
6 stated to be typical of most light water reactor CDF uncertainty analyses. PSEG considered the
7 impact on the Phase II screening if the estimated benefits were increased by a factor of 2.5 (in
8 addition to the multiplier of 2 for external events). One additional SAMA became cost-beneficial
9 (SAMA 3). The NRC staff notes that while the factor of 2.5 does not represent an upper bound,
10 it is typical of factors used in prior SAMA analyses, is higher than the factor calculated for other
11 Westinghouse 4-loop plants and used in prior SAMA analysis, and is therefore considered by
12 the NRC staff to be appropriate for use in the SAMA sensitivity analyses.

13 PSEG provided the results of additional sensitivity analyses in the ER, including use of a 7
14 percent discount rate and variations in MACCS2 input parameters. These analyses did not
15 identify any additional potentially cost-beneficial SAMAs (PSEG 2009).

16 The NRC staff noted that the ER reported that the licensed thermal power for SGS Unit 1 is
17 3,459 MWt, which equates to a net electrical output of 1,195 MWe when operating at 100
18 percent power, while 1,115 MWe was used to calculate long-term replacement power costs for
19 the SAMA analysis (NRC 2010a). In response to the RAI, PSEG clarified that 1,115 MWe used
20 in the SAMA analysis was incorrect and provided a revised replacement power cost estimate of
21 \$359,000 using the correct 1,195 MWe, which is an approximately 7 percent increase over that
22 used in the SAMA analysis (PSEG 2010a). PSEG also provided a revised MACR of \$16.61M,
23 which is an increase of about 0.3 percent over the MACR used in the SAMA analysis and
24 concluded that the small error would have a negligible impact on the conclusions of the SAMA
25 analysis. The NRC staff agrees with this assessment.

26 As indicated in Section F.3.2, in response to an NRC staff RAI, PSEG extended the review of
27 Level 1 and Level 2 basic events down to an RRW of 1.006, which equates to a benefit of about
28 \$47,000, using SGS PRA MOR Revision 4.3 (PSEG 2010a). The review identified the following
29 three additional SAMAs associated with new basic events added to the importance lists: 1)
30 SAMA 30, "Automatic Start of Diesel-Powered Air Compressor," 2) SAMA 31, "Fully Automate
31 Swapover to Sump Recirculation," and 3) SAMA 32, "Enhance Flood Detection for 100-foot
32 Auxiliary Building and Enhance Procedural Guidance for Responding to Internal Floods." Each
33 of these new SAMAs is included in Table F-6. PSEG performed a Phase II evaluation using
34 results for SGS PRA MOR Revision 4.3 and the process described above. PSEG stated that
35 the release frequency for MOR Revision 4.3 is 2.2×10^{-5} per year, a decrease of over 50
36 percent from MOR Revision 4.1, and that the 95th percentile value for CDF is a factor of 2.1
37 times the point estimate CDF. Based on information provided in the RAI response, the NRC
38 staff estimated, for the MOR Revision 4.3 results, the total present dollar value equivalent
39 associated with completely eliminating severe accidents from internal events at SGS to be

1 about \$2.3M, a revised external event multiplier of about 3.4, and a revised MACR of about
2 \$7.9M. These results represent a decrease of more than 50 percent compared to the SGS PRA
3 MOR 4.1 results reported in the ER. PSEG's analysis determined that none of the three SAMA
4 candidates was cost-beneficial in either the baseline analysis or the uncertainty analysis.

5 Based on these results for MOR Revision 4.3 and the changes in the importance lists, the NRC
6 staff asked PSEG to assess the impact on the SAMA evaluation of the PRA model changes
7 made since MOR Revision 4.1 (NRC 2010b). In response to the RAI, PSEG re-evaluated each
8 potentially cost-beneficial SAMA using MOR Revision 4.3 and determined that SAMA benefits
9 both increased (up to 42 percent) and decreased (up to 99 percent) from the results using MOR
10 Revision 4.1 and that five SAMA candidates (SAMA 3, 5, 11, 14, and 27) would no longer be
11 cost-beneficial (PSEG 2010b). PSEG also qualitatively evaluated each SAMA determined to
12 not be cost-beneficial and concluded that none would become cost-beneficial using MOR
13 Revision 4.3 based on the following:

- 14 • The implementation cost is greater than the revised MACR even after accounting for
15 uncertainty (SAMA 13).
- 16 • For SAMAs that address fire events only, the maximum averted cost risk for external
17 events decreased, which would result in a corresponding decrease in the maximum
18 calculated benefit for these SAMAs (SAMAs 21, 22, and 23).
- 19 • The cost of implementation was sufficiently greater than the MOR Revision 4.1 benefit
20 that changes in MOR Revision 4.3 would not be expected to overcome the difference
21 (SAMAs 15, 16, 18, and 19). The NRC staff notes that this difference, even after
22 accounting for uncertainty, is on the order of 50 percent or more for all of these SAMAs
23 and agrees that it is unlikely that a revised evaluation would result in a change to the
24 cost-beneficial status for these SAMAs.
- 25 • The cost of implementation is greater than the revised MACR (SAMA 20). The NRC
26 staff notes that MOR Revision 4.1 results indicate that the fire and seismic events
27 contributors to the MACR are four times the internal events contribution and, since the
28 maximum averted cost risk for external events has decreased with MOR Revision 4.3,
29 agrees that it is unlikely that a revised evaluation would result in a change to cost-
30 beneficial status for this SAMA.

31 As indicated in Section F.3.2, the NRC staff asked the licensee to evaluate several potentially
32 lower cost alternatives to the SAMAs considered in the ER (NRC 2010a), as summarized below:

- 33 • Operating the AFW AF11/21 valves closed in lieu of SAMA 8, "Install High Pressure
34 Pump Powered with Portable Diesel Generator and Long-term Suction Source to Supply
35 the AFW Header." In response to the RAI, PSEG stated that the AF11 valves on the
36 discharge side of the motor-driven AFW pumps are already operated closed, leaving

1 only the AF21 valves on the discharge side of the turbine-driven AFW pump operating
2 open (PSEG 2010a). Steam binding of the common suction line to all three AFW pumps
3 could therefore only occur as a result of high temperature water leaks through three
4 check valves in series on the discharge to the turbine-driven AFW pump. PSEG
5 concluded that the proposed improvement would not be feasible because 1) industry
6 data used to represent common-cause steam binding of all three AFW pumps appears
7 to be conservative relative to the SGS configuration, thereby overstating the risk
8 significance of this failure at SGS, 2) operating all of the AF11/21 valves closed could
9 actually provide a negative risk benefit based on a new failure event to represent
10 common-cause failure of the valves to open, and 3) operating all of the AF11/21 valves
11 closed could have a potentially adverse effect on the SGS design basis because design-
12 basis calculations and assumptions would need to be modified to reflect this change in
13 AFW strategy.

- 14 • Install improved fire barriers in the 460V switchgear rooms to provide separation
15 between the three power divisions in lieu of SAMA 20, "Fire Protection System to
16 Provide Make-up to RCS and Steam Generators." In response to the RAI, PSEG
17 explained that the configuration of Fire Area 1FA-AB-84A, addressed by SAMA 20, is
18 significantly more complex than Fire Area 1FA-AB-64A, addressed by SAMA 23, "Install
19 Fire Barriers and Cable Wrap to Maintain Divisional Separation in the 4160V AC
20 Switchgear Room" (PSEG 2010a). The SAMA 23 estimated implementation cost of
21 \$975K only addresses the risk associated with preventing the spread of transient fires
22 between divisions and did not address the entire fire risk in the fire area, which would
23 include protecting the overhead cables. PSEG estimates that the cost of addressing the
24 entire fire risk in Fire Area 1FA-AB-64A would be at least an order of magnitude greater
25 than the estimated implementation cost for SAMA 23. PSEG further estimates that the
26 cost of addressing the fire risk in Fire Area 1FA-AB-84A could be double that for Fire
27 Area 1FA-AB-64A. The maximum benefit of the proposed SAMA, which assumes
28 elimination of all fire risk for Fire Area 1FA-AB-84A, is estimated to be \$2.0M in the
29 baseline analysis, or \$5.1M accounting for uncertainties, using the MOR Rev. 4.1 PRA
30 model. Furthermore, PSEG determined that the maximum benefit would be about 30
31 percent lower if the MOR Rev. 4.3 PRA model were used. Because the estimated
32 implementation cost is significantly greater than the maximum potential benefit, PSEG
33 concluded that the proposed SAMA would not be cost-beneficial.
- 34 • Install improved fire barriers to provide separation between the AFW pumps in lieu of
35 SAMA 8, "Install High Pressure Pump Powered with Portable Diesel Generator and
36 Long-term Suction Source to Supply the AFW Header." In response to the RAI, PSEG
37 estimated the cost to implement the proposed SAMA to be \$750K (PSEG 2010a).
38 Failure of multiple AFW pumps accounted for about 67 percent of the Fire Area 1FA-AB-
39 84B fire risk. The maximum benefit of the proposed SAMA, which assumes elimination
40 of all of this fire risk, is estimated to be \$120K in the baseline analysis, or \$290K
41 accounting for uncertainties, using the MOR Rev. 4.1 PRA model. Furthermore, PSEG

1 determined that the maximum benefit would be about 30 percent lower if the MOR Rev.
2 4.3 PRA model were used. Because the estimated implementation cost is significantly
3 greater than the maximum potential benefit, PSEG concluded that the proposed SAMA
4 would not be cost-beneficial.

5 PSEG indicated that the 17 potentially cost-beneficial SAMAs (SAMAs 1, 2, 3, 4, 5, 5A, 6, 7, 8,
6 9, 10, 11, 12, 14, 17, 24, and 27) will be considered for implementation through the established
7 Salem Plant Health Committee (PHC) process (PSEG 2009). In response to an NRC staff RAI,
8 PSEG described the PHC as being chaired by the Plant Manager and includes as members the
9 Plant Engineering Manager and the Directors of Operations, Engineering, Maintenance, and
10 Work Management (PSEG 2010a). The PHC is chartered with reviewing issues that require
11 special plant management attention to ensure effective resolution and, with respect to each of
12 the potentially cost-beneficial SAMAs, will decide on one of the following courses of actions: 1)
13 approve for implementation, 2) conditionally approved for implementation pending the results of
14 requested evaluations, 3) not approved for implementation, or 4) tabled until additional
15 information needed to make a final decision is provided to the PHC. Additional information
16 requested may include 1) making corrections to the original SAMA analysis, 2) examining an
17 alternate solution, 3) performing sensitivity studies to determine the effect of implementing a
18 sub-set of SAMAs, already approved SAMAs, or already approved non-SAMA design changes
19 on the SAMA, or 4) coordinating the SAMA with related Mitigating System Performance Index
20 (MSPI) margin recovery activities. If approved or conditionally approved for implementation,
21 the SAMA will be ranked with respect to priority and assigned target years for implementation.

22 The NRC staff concludes that, with the exception of the potentially cost-beneficial SAMAs
23 discussed above, the costs of the other SAMAs evaluated would be higher than the associated
24 benefits.

25 **F.7 Conclusions**

26 PSEG compiled a list of 27 SAMAs based on a review of: the most significant basic events from
27 the plant-specific PRA and insights from the SGS PRA group, insights from the plant-specific
28 IPE and IPEEE, Phase II SAMAs from license renewal applications for other plants, and the
29 generic SAMA candidates from NEI 05-01. A qualitative screening removed SAMA candidates
30 that: (1) are not applicable to SGS due to design differences, (2) have already been
31 implemented at SGS, (3) would achieve results that have already been achieved at SGS by
32 other means, and (4) have estimated implementation costs that would exceed the dollar value
33 associated with completely eliminating all severe accident risk at SGS. Based on this
34 screening, 2 SAMAs were eliminated leaving 25 candidate SAMAs for evaluation. One
35 additional SAMA candidate was identified and evaluated as a sensitivity case. Three additional
36 SAMA candidates were identified and evaluated in response to an NRC staff RAI.

37 For the remaining SAMA candidates, including the sensitivity case SAMA and three SAMAs
38 added in response to the NRC staff RAI, a more detailed design and cost estimate were

1 developed as shown in Table F-6. The cost-benefit analyses in the ER and RAI response
2 showed that 11 of the SAMA candidates were potentially cost-beneficial in the baseline analysis
3 (Phase II SAMAs 1, 2, 4, 6, 9, 10, 11, 12, 14, 17, and 24). PSEG performed additional analyses
4 to evaluate the impact of parameter choices and uncertainties on the results of the SAMA
5 assessment. As a result, five additional SAMA candidates (SAMA 3, 5, 7, 8, and 27) were
6 identified as potentially cost-beneficial in the ER. The ER also showed that the sensitivity case
7 SAMA (SAMA 5A) was potentially cost-beneficial. PSEG has indicated that all 17 potentially
8 cost-beneficial SAMAs will be considered for implementation through the established Salem
9 Plant Health Committee process.

10 The NRC staff reviewed the PSEG analysis and concludes that the methods used and the
11 implementation of those methods was sound. The treatment of SAMA benefits and costs
12 support the general conclusion that the SAMA evaluations performed by PSEG are reasonable
13 and sufficient for the license renewal submittal. Although the treatment of SAMAs for external
14 events was somewhat limited, the likelihood of there being cost-beneficial enhancements in this
15 area was minimized by improvements that have been realized as a result of the IPEEE process,
16 and inclusion of a multiplier to account for external events.

17 The NRC staff concurs with PSEG's identification of areas in which risk can be further reduced
18 in a cost-beneficial manner through the implementation of the identified, potentially cost-
19 beneficial SAMAs. Given the potential for cost-beneficial risk reduction, the NRC staff agrees
20 that further evaluation of these SAMAs by PSEG is warranted. However, these SAMAs do not
21 relate to adequately managing the effects of aging during the period of extended operation.
22 Therefore, they need not be implemented as part of license renewal pursuant to Title 10 of the
23 *Code of Federal Regulations*, Part 54.

24 **F.8 References**

25 American Society of Mechanical Engineers (ASME). 2005. "Addenda to ASME RA-S-2002,
26 Standard for Probabilistic Risk Assessment for Nuclear Power Plant Applications." ASME RA-
27 Sb-2005, December 2005.

28 BEA (Bureau of Economic Analysis). 2008. Regional Economic Accounts, accessed June 20 at
29 <http://www.bea.gov/regional/reis/>.

30 Electric Power Research Institute (EPRI). 1989. "Probabilistic Seismic Hazard Evaluations at
31 Nuclear Plant Sites in the Central and Eastern United States; Resolution of the Charleston
32 Earthquake Issues." EPRI NP-6395-D, EPRI Project P101-53. Palo Alto, CA. April 1989.

33 Electric Power Research Institute (EPRI). 1991. "A Methodology for Assessment of Nuclear
34 Power Plant Seismic Margin," Implementation Guide NP-6041, Revision 1. Palo Alto, CA.
35 August 1991.

- 1 Electric Power Research Institute (EPRI). 1993. "Fire Induced Vulnerability Evaluation (FIVE)
2 Methodology." TR-100370, Revision 1, Palo Alto, CA. September 19, 1993.
- 3 KLD Associates, Inc. (KLD). 2004. *Salem / Hope Creek Nuclear Generating Stations*
4 *Development of Evacuation Time Estimates*. KLD TR-356. February 2004.
5
- 6 Nuclear Energy Institute (NEI). 2005. "Severe Accident Mitigation Alternative (SAMA) Analysis
7 Guidance Document." NEI 05-01 (Rev. A), Washington, D.C. November 2005.
- 8 Nuclear Energy Institute (NEI). 2007. "Process for Performing Follow-on PRA Peer Reviews
9 using the ASME PRA Standard (Internal Events)." NEI 05-04, Rev. 1, Washington, D.C.
10 December 2007.
- 11 Public Service Electric and Gas Company (PSEG). 1993. Letter from Stanley LaBruna, PSEG,
12 to NRC Document Control Desk. Subject: "Generic Letter 88-20; Individual Plant Examination
13 (IPE) Report, Salem Generating Station, Unit Nos. 1 and 2, Docket Nos. 50-272 and 50-311,"
14 Hancocks Bridge, New Jersey. July 30, 1993. Accessible at ML080100047.
- 15 Public Service Electric and Gas Company (PSEG). 1995. Letter from E. Simpson, PSEG, to
16 NRC Document Control Desk. Subject: "Response to Generic Letter 88-20 Individual Plant
17 Examination for Sever Accident Vulnerabilities – 10CFR50.54 (f) Request for Additional
18 Information Salem Generating Station, Unit Nos. 1 and 2 Facility Operating License Nos. DRR-
19 70 and DPR-75 Docket Nos. 50-272 and 50-311," Hancocks Bridge, New Jersey. August 01,
20 1995. Accessible at ML080100021.
- 21 Public Service Electric and Gas Company (PSEG). 1996. Letter from E. C. Simpson, PSEG, to
22 NRC Document Control Desk. Subject: "Response to Generic Letter No. 88-20, Supplement 4,
23 Individual Plant Examination of External Events (IPEEE) for Severe Accident Vulnerabilities,
24 Salem Generating Station Units Nos. 1 and 2, Facility Operating License Nos. DPR-70 and
25 DPR-75, Docket Nos. 50-272 and 50-311," Hancocks Bridge, New Jersey. January 29, 1996.
26 Accessible at ML080100023.
- 27 PSEG Nuclear, LLC (PSEG). 2009. *Salem Nuclear Generating Station --- License Renewal*
28 *Application, Appendix E: Applicant's Environmental Report; Operating License Renewal Stage*.
29 Hancocks Bridge, New Jersey. August 18, 2009. Accessible at ML092400532.
- 30 PSEG Nuclear, LLC (PSEG). 2010a. Letter from Paul. J. Davison, PSEG, to NRC Document
31 Control Desk. Subject: "Response to NRC Request for Additional Information dated April 12,
32 2010, related to the Severe Accident Mitigation Alternatives (SAMA) review of the Salem
33 Nuclear Generating Station, Units 1 and2," Hancocks Bridge, New Jersey. May 24, 2010.
34 Accessible at ML101520326.
- 35 PSEG Nuclear, LLC (PSEG). 2010b. Letter from Christine T. Neely, PSEG, to NRC Document
36 Control Desk. Subject: "Supplement to RAI responses submitted in PSEG Letter LR-N10-0164

- 1 dated May 24, 2010, related to the Severe Accident Mitigation Alternatives (SAMA) review of
2 the Salem Nuclear Generating Station, Units 1 and 2," Hancocks Bridge, New Jersey. August
3 18, 2010. Accessible at ML102320211.
- 4 U.S. Department of Agriculture (USDA). 2004. 2002 Census of Agriculture - Volume 1,
5 Geographic Area Series, Part 8 (Delaware), Part 20 (Maryland), Part 30.
- 6 U.S. Nuclear Regulatory Commission (NRC). 1988. Generic Letter 88-20, "Individual Plant
7 Examination for Severe Accident Vulnerabilities." November 23, 1988. Washington, D.C.
- 8 U.S. Nuclear Regulatory Commission (NRC). 1989. *Fire Risk Scoping Study*. NUREG/CR-
9 5088. January 1989. Washington, D.C.
- 10 U.S. Nuclear Regulatory Commission (NRC). 1990. *Severe Accident Risks: An Assessment*
11 *for Five U.S. Nuclear Power Plants*. NUREG-1150. Washington, D.C.
- 12 U.S. Nuclear Regulatory Commission (NRC). 1991a. Generic Letter No. 88-20, Supplement 4,
13 "Individual Plant Examination of External Events for Severe Accident Vulnerabilities." NUREG-
14 1407. Washington, D.C. June 28, 1991.
- 15 U.S. Nuclear Regulatory Commission (NRC). 1991b. "Procedural and Submittal Guidance for
16 the Individual Plant Examination of External Events (IPEEE) for Severe Accident
17 Vulnerabilities." NUREG-1407. Washington, D.C. June 1991.
- 18 U.S. Nuclear Regulatory Commission (NRC). 1994. *Revised Livermore Seismic Hazard*
19 *Estimates for Sixty-Nine Nuclear Plant Sites East of the Rocky Mountains*. NUREG-1488, April
20 1994. Washington, D.C.
- 21 U.S. Nuclear Regulatory Commission (NRC). 1996. Letter from Leonard Olshan, U.S. NRC, to
22 Leon Eliason, PSEG. Subject: Individual Plant Examination (IPE) Submittal - Internal Events,
23 Salem Nuclear Generating Station, Units 1 and 2 (TAC No. M74461). March 21, 1996.
- 24 U.S. Nuclear Regulatory Commission (NRC). 1997a. *Regulatory Analysis Technical Evaluation*
25 *Handbook*. NUREG/BR-0184. Washington, D.C.
- 26 U.S. Nuclear Regulatory Commission (NRC). 1997b. *Individual Plant Examination Program:*
27 *Perspectives on Reactor Safety and Plant Performance*. NUREG-1560. Washington, D.C.
- 28 U.S. Nuclear Regulatory Commission (NRC). 1998. *Code Manual for MACCS2: User's-Guide*.
29 NUREG/CR-6613, Volume 1, May 1998. Washington, D.C.
- 30 U.S. Nuclear Regulatory Commission (NRC). 1999. Letter from Patrick D. Milano, U.S. NRC to
31 Harold W. Keiser, PSEG. Subject: Generic Letter 88-20, Supplement 4, "Individual Plant

- 1 Examination for External Events for Severe Accident Vulnerabilities,” Salem Nuclear Generating
2 Station, Unit Nos. 1 and 2 (TAC Nos. M83669 and M83670). May 21, 1999.
- 3 U.S. Nuclear Regulatory Commission (NRC). 2003. *SECPOP2000: Sector Population, Land*
4 *Fraction, and Economic Estimation Program*. NUREG/CR-6525, Rev. 1. Sandia National
5 Laboratories. August 2003.
- 6 U.S. Nuclear Regulatory Commission (NRC). 2004. *Regulatory Analysis Guidelines of the U.S.*
7 *Nuclear Regulatory Commission*. NUREG/BR-0058, Rev. 4. Washington, D.C.
- 8 U.S. Nuclear Regulatory Commission (NRC). 2007. “An Approach for Determining the
9 Technical Adequacy of Probabilistic Risk Assessment Results for Risk-Informed Activities.”
10 Regulatory Guide 1.200, Revision 1. January 2007.
- 11 U.S. Nuclear Regulatory Commission (NRC). 2010a. Letter from Charles Eccleston, U.S. NRC,
12 to Thomas Joyce, PSEG. Subject: Request for Additional Information, Regarding Severe
13 Accident Mitigation Alternatives for the Salem Nuclear Generating Station, Units 1 and 2. April
14 12, 2010. Accessible at ML100910252.
- 15 U.S. Nuclear Regulatory Commission (NRC). 2010b. Teleconference held on July 29, 2010
16 between NRC staff and PSEG Nuclear, LLC staff regarding clarifications to the RAI responses
17 provided by PSEG via letter dated April 12, 2010. Accessible at ML102220012.

18

1
2
3
4
5
6

Appendix G
U.S. Nuclear Regulatory Commission Staff Evaluation of
Severe Accident Mitigation Alternatives for
Hope Creek Nuclear Generating Station
In Support of License Renewal Application Review

This Page Intentionally Left Blank

G. U.S. Nuclear Regulatory Commission Staff Evaluation of Severe Accident Mitigation Alternatives for Hope Creek Nuclear Generating Station in Support of License Renewal Application Review

G.1 Introduction

PSEG Nuclear, LLC, (PSEG) submitted an assessment of severe accident mitigation alternatives (SAMAs) for the Hope Creek Generating Station (HCGS) as part of the environmental report (ER) (PSEG 2009). This assessment was based on the most recent HCGS probabilistic risk assessment (PRA) available at that time, a plant-specific offsite consequence analysis performed using the MELCOR Accident Consequence Code System 2 (MACCS2) computer code, and insights from the HCGS individual plant examination (IPE) (PSEG 1994) and individual plant examination of external events (IPEEE) (PSEG 1997). In identifying and evaluating potential SAMAs, PSEG considered SAMAs that addressed the major contributors to core damage frequency (CDF) and release frequency at HCGS, as well as SAMA candidates for other operating plants that have submitted license renewal applications. PSEG initially identified 23 potential SAMAs. This list was reduced to 21 unique SAMA candidates by eliminating SAMAs that are not applicable to HCGS due to design differences, have already been implemented at HCGS, would achieve the same risk reduction results that had already been achieved at HCGS by other means, have excessive implementation cost or could be combined with another SAMA candidate. PSEG assessed the costs and benefits associated with each of the potential SAMAs, and concluded in the ER that several of the candidate SAMAs evaluated are potentially cost-beneficial.

Based on a review of the SAMA assessment, the U.S. Nuclear Regulatory Commission (NRC) issued a request for additional information (RAI) to PSEG by letter dated May 20, 2010 (NRC 2010a) and, based on a review of the RAI responses, a request for RAI response clarification by teleconference dated July 29, 2010 (NRC 2010b). Key questions concerned: discussing internal and external review comments on the PRA model, including the impact of the 2008 PRA peer review comments on the SAMA analysis results; the process and criteria used to assign containment event tree (CET) end states to release categories; additional details on the seismic analysis; the SAMA screening process and additional potential SAMAs not previously considered; and further information on the costs and benefits of several specific candidate SAMAs and low cost alternatives. PSEG submitted additional information by a letters dated June 1, 2010 (PSEG 2010a) and August 18, 2010 (PSEG 2010b). In the responses, PSEG provided: a listing of open gaps and findings from the 2008 PRA peer review and an assessment of their impact on the SAMA analysis; additional description of how CET end states were assigned to release categories and how representative sequences were selected for each release category; clarification of certain elements of the seismic analysis and an assessment of the impact of seismic assumptions on the external events multiplier; analyses of additional SAMAs; and additional information regarding several specific SAMAs. PSEG's responses

1 addressed the NRC staff's concerns, and resulted in the identification of additional potentially
2 cost-beneficial SAMAs.

3 An assessment of SAMAs for HCGS is presented below.

4 5 **G.2 Estimate of Risk for HCGS**

6
7 PSEG's estimates of offsite risk at HCGS are summarized in Section G.2.1. The summary is
8 followed by the NRC staff's review of PSEG's risk estimates in Section G.2.2.

9 **G.2.1 PSEG's Risk Estimates**

10
11 Two distinct analyses are combined to form the basis for the risk estimates used in the SAMA
12 analysis: (1) the HCGS Level 1 and Level 2 PRA model, which is an updated version of the IPE
13 (PSEG 1994), and (2) a supplemental analysis of offsite consequences and economic impacts
14 (essentially a Level 3 PRA model) developed specifically for the SAMA analysis. The SAMA
15 analysis is based on the most recent HCGS Level 1 and Level 2 PRA model available at the
16 time of the ER, referred to as the HC108B update. The scope of this HCGS PRA does not
17 include external events.

18 The HCGS CDF is approximately 5.1×10^{-6} per year as determined from quantification of the
19 Level 1 PRA model at a truncation of 1×10^{-12} per year. When determining the frequency of the
20 source term categories from the sum of the containment event tree (CET) sequences, or Level 2
21 PRA model, a higher truncation of 5×10^{-11} per year was used and the resulting release
22 frequency (from all release categories, which consist of intact containment, late release, and
23 early release) is approximately 4.4×10^{-6} per year. The latter value was used as the baseline
24 CDF in the SAMA evaluations (PSEG 2009). The CDF is based on the risk assessment for
25 internally-initiated events, which includes internal flooding. PSEG did not explicitly include the
26 contribution from external events within the HCGS risk estimates; however, it did account for the
27 potential risk reduction benefits associated with external events by multiplying the estimated
28 benefits for internal events by a factor of 6.3. This is discussed further in Sections G.2.2 and
29 G.6.2.

30 The breakdown of CDF by initiating event is provided in Table G-1 (PSEG 2009). As shown in
31 this table, events initiated by loss of offsite power, loss of service water and other transients
32 (manual shutdown and turbine trip with bypass) are the dominant contributors to the CDF.
33 Anticipated transient without scram (ATWS) sequences account for 3% of the CDF, station
34 blackout accounts for 12% of the CDF (PSEG 2010a).

35 **Table G-1. HCGS Core Damage Frequency for Internal Events**

Initiating Event	CDF (per year)	% Contribution to CDF ¹
Loss of Offsite Power	9.3×10^{-7}	18
Loss of Service Water (SW)	8.1×10^{-7}	15
Manual Shutdown	7.7×10^{-7}	15

Turbine Trip with Bypass	6.2×10^{-7}	12
Small Loss of Coolant Accident (LOCA) – Water (Below Top of Active Fuel)	2.8×10^{-7}	5
Small LOCA – Steam (Above Top of Active Fuel)	2.3×10^{-7}	4
Loss of Condenser Vacuum	2.0×10^{-7}	4
Fire Protection System Rupture Outside Control Room	1.9×10^{-7}	4
Isolation LOCA in Emergency Core Cooling System (ECCS) Discharge Paths	1.1×10^{-7}	2
Main Steam Isolation Valve (MSIV) Closure	1.1×10^{-7}	2
Internal Flood Outside Lower Relay Room	9.7×10^{-8}	2
Loss of Feedwater	8.8×10^{-8}	2
Loss of Safety Auxiliaries Cooling System	7.9×10^{-8}	2
Reactor Auxiliaries Cooling System (RACS) Common Header Unisolable Rupture	7.6×10^{-8}	1
Unisolable SW A Pipe Rupture in RACS Room	5.7×10^{-8}	1
Unisolable SW B Pipe Rupture in RACS Room	5.7×10^{-8}	1
Others (less than 1% each)	4.1×10^{-7}	8
Total CDF (internal events)	5.1×10^{-6}	100

¹Column totals may be different due to round off.

1 The Level 2 HCGS PRA model that forms the basis for the SAMA evaluation is essentially a
2 complete revision to the IPE model. The Level 2 model utilizes three containment event trees
3 (CETs) containing both phenomenological and systemic events. The Level 1 core damage
4 sequences are binned into accident classes that provide the interface between the Level 1 and
5 Level 2 CET analysis. The CETs are linked directly to the Level 1 event trees and CET nodes
6 are evaluated using supporting fault trees.

7 The result of the Level 2 PRA is a set of 11 release or source term categories, with their
8 respective frequency and release characteristics. The results of this analysis for HCGS are
9 provided in Table E.3-6 of ER Appendix E (PSEG 2009). The categories were defined based
10 on the timing of the release, the magnitude of the release, and whether or not the containment
11 remains intact or fails. The frequency of each release category was obtained by summing the
12 frequency of the individual accident progression CET endpoints binned into the release
13 category. Source terms were developed for each of the 11 release categories using the results
14 of Modular Accident Analysis Program (MAAP 4.0.6) computer code calculations.

15 The offsite consequences and economic impact analyses use the MACCS2 code to determine
16 the offsite risk impacts on the surrounding environment and public. Inputs for these analyses
17 include plant-specific and site-specific input values for core radionuclide inventory, source term
18 and release characteristics, site meteorological data, projected population distribution (within a

1 50-mile radius) for the year 2046, emergency response evacuation modeling, and economic
 2 data. The core radionuclide inventory corresponds to the end-of-cycle values for HCGS
 3 operating at 3917 MWt, which is two percent above the current extended power uprate (EPU)
 4 licensed power level of 3,840 MWt. The magnitude of the onsite impacts (in terms of clean-up
 5 and decontamination costs and occupational dose) is based on information provided in
 6 NUREG/BR-0184 (NRC 1997a).

7 In the ER, PSEG estimated the dose to the population within 80-kilometers (50-miles) of the
 8 HCGS site to be approximately 0.23 person-Sievert (Sv) (22.9 person-roentgen equivalent man
 9 [rem]) per year. The breakdown of the total population dose by containment release mode is
 10 summarized in Table G-2. Releases from the containment within the early time frame (0 to less
 11 than 4 hours following event initiation) and intermediate time frame (4 to less than 24 hours
 12 following event initiation) dominate the population dose risk at HCGS.

13 **Table G-2. Breakdown of Population Dose by Containment Release Mode**
 14

Containment Release Mode	Population Dose (Person-Rem ¹ Per Year)	Percent Contribution
Early Releases (< 4hrs)	11.9	52
Intermediate Releases (4 to <24 hrs)	9.9	43
Late Releases (≥24 hrs)	1.1	5
Intact Containment	<0.1	negligible
Total	22.9	100

¹One person-rem = 0.01 person-Sv

16 G.2.2 Review of PSEG's Risk Estimates

17 PSEG's determination of offsite risk at HCGS is based on the following three major elements of
 18 analysis:

- 19 • The Level 1 and 2 risk models that form the bases for the 1994 IPE submittal
 20 (PSEG1994), and the external event analyses of the 1997 IPEEE submittal (PSEG
 21 1997),
- 22 • The major modifications to the IPE model that have been incorporated in the HCGS
 23 PRA, and
- 24 • The MACCS2 analyses performed to translate fission product source terms and release
 25 frequencies from the Level 2 PRA model into offsite consequence measures.

26 Each of these analyses was reviewed to determine the acceptability of PSEG's risk estimates
 27 for the SAMA analysis, as summarized below.

1 The NRC staff's review of the HCGS IPE is described in an NRC report dated April 23, 1996
 2 (NRC 1996). Based on a review of the IPE submittal and responses to RAIs, the NRC staff
 3 concluded that the IPE process is capable of identifying the most likely severe accidents and
 4 severe accident vulnerabilities, and therefore, that the HCGS IPE has met the intent of GL 88-
 5 20 (NRC 1988).

6 During the performance of the IPE, transients involving heating, ventilation, and air conditioning
 7 (HVAC) failure were determined to contribute inordinately to the CDF. This was labeled a
 8 vulnerability and a procedure to provide alternate ventilation was developed. The
 9 implementation of this procedure removed this vulnerability. Credit for this procedure was taken
 10 in the HCGS IPE submittal. No other vulnerabilities were identified. In the ER, PSEG indicated
 11 that there were three improvements identified in the process of performing the IPE. Two of the
 12 improvements were performing refined calculations to allow increased credit for existing plant
 13 design features. The third was developing a procedure for operation of the Safety Auxiliaries
 14 Cooling System in severe accident conditions. All of these improvements are stated to have
 15 been implemented (PSEG 2009).

16 There have been twelve revisions to the IPE model since the 1994 IPE submittal. A listing of
 17 the changes made to the HCGS PRA since the original IPE submittal was provided in the ER
 18 (PSEG 2009) and in response to an RAI (PSEG 2010a) and is summarized in Table G-3. A
 19 comparison of internal events CDF between the 1994 IPE and the current PRA model indicates
 20 a decrease of about a factor of ten in the total CDF (from 4.7×10^{-5} per year to 5.1×10^{-6} per
 21 year). This reduction can be attributed to significant changes in success criteria, modeling
 22 details and removal of conservatism.

23 **Table G-3. HCGS PRA Historical Summary**

PRA Version	Summary of Changes from Prior Model	Total CDF ¹ (per year)
1994	IPE Submittal	4.7×10^{-5}
Model 0 9/1994	- Credit taken for beyond design basis performance of Safety Auxiliaries Cooling System (SACS) and Station Service Water System (SSWS) based on updated success criteria calculations.	1.3×10^{-5}
Model 1.0 7/1999	- Integrated the Level I and II models - Updated the database - Further developed sequence end states - Developed fault trees for special initiators - Reviewed dependent operator actions	1.9×10^{-5}
Model 1.3 ² 10/2000	- Requantified two important human error probabilities - Revised treatment of disallowed maintenance to credit plant procedures and operating practices. - Revised common cause failure assessment - Eliminated core spray room cooling dependency on SACS based on review of room heat up calculations - Added models for breaks outside containment and manual shutdown - Updated ATWS analysis	9.3×10^{-6}

PRA Version	Summary of Changes from Prior Model	Total CDF ¹ (per year)
Model 2003A 8/2003	<ul style="list-style-type: none"> - Incorporated resolution of 1999 BWROG peer review Facts and Observations (Attachment 14 to PSEG 2005) - Converted from NUPRA to CAFTA software - Performed completely new human reliability assessment - Revised accident sequence definitions - Performed new MAAP calculations for extended power uprate (EPU) conditions - Updated data - Modified system models - Updated common cause failure analysis - Added internal flood accident sequences 	3.1×10^{-5}
Rev. 2.0 10/2004	<ul style="list-style-type: none"> - Modified 480 VAC dependencies - Modified SACS success criteria - Modified SACS-SW Human Error Probabilities 	1.7×10^{-5}
Model 2005C ³ 2/2006	<ul style="list-style-type: none"> - Removed conservatism in the SACS-SW success criteria - Included more detailed logic for AC power supplies - Removed conservatism in operator action human error probabilities (HEPs) - Reduced turbine trip initiating event frequency 	9.8×10^{-6}
HC108A 8/2008	<p>BWROG Peer Reviewed</p> <ul style="list-style-type: none"> - Incorporated seasonal success criteria for SACS and SSWS - Updated internal flooding scenarios and initiating event frequencies to be consistent with ASME PRA standard - Credited use of portable battery charger for Station Blackout scenarios - Reassessed human error probabilities using Electric Power Research Institute (EPRI) human reliability analysis (HRA) calculator - Updated evaluation of dependent operator actions 	7.6×10^{-6}
HC108B ⁴ 12/2008	<ul style="list-style-type: none"> - Credited procedure changes for local manual manipulation of SSWS valves under LOOP conditions - Removed conservatism in modeling of 120 VAC inverter room cooling logic - Updated SACS pump failure probabilities to be consistent with Bayesian update values 	5.1×10^{-6} (4.4×10^{-6})

¹Total CDF includes internal floods. Prior to Model 2003A, IPE internal flood analysis was retained.

²Changes for Model 1.3 includes those for prior intermediate Models 1.1 and 1.2. All changes were considered minor.

³Changes for Model 2005C includes those for prior intermediate Models 2005A and 2005B. All changes to Models 2005A and 2005B were considered minor.

⁴Model HC108B truncation limit was decreased to 1×10^{-12} per year from 5×10^{-11} per year utilized for the HC108A and 2005 models. The CDF in parentheses is the result based on the higher truncation limit.

1
2
3
4

The CDF value from the 1994 IPE (4.7×10^{-5} per year) is in the upper third of the values reported for other BWR 3/4 plants. Figure 11.2 of NUREG-1560 shows that the IPE-based total

1 internal events CDF for BWR 3/4 plants ranges from 9×10^{-8} per year to 8×10^{-5} per year, with
2 an average CDF for the group of 2×10^{-5} per year (NRC 1997b). It is recognized that other
3 plants have updated the values for CDF subsequent to the IPE submittals to reflect modeling
4 and hardware changes. The current internal events CDF results for HCGS (5.1×10^{-6} per year)
5 are comparable to that for other plants of similar vintage and characteristics.

6 The NRC staff considered the peer reviews performed for the HCGS PRA, and the potential
7 impact of the review findings on the SAMA evaluation. In the ER (PSEG 2009) and in response
8 to an NRC staff RAI (PSEG 2010a) and in other unrelated submittals (PSEG 2005), PSEG
9 described three BWROG Peer Reviews for the HCGS PRA. The first was a pilot of the BWROG
10 peer review process conducted in 1996 of PRA Model 0. The second, conducted in 1999,
11 reviewed PRA Model 1.0. The third, conducted in 2008, reviewed the HC108A Model.

12 The 1999 peer review identified no Level A (extremely important) and 80 Level B (important)
13 Facts and Observations (F&Os). It was stated that these F&Os were resolved and incorporated
14 in the 2003A PRA Model (PSEG 2005).

15 The 2008 peer review of the HC108A model was requested by PSEG because of the significant
16 changes in PRA methods since the prior peer review. This peer review was performed using
17 the Nuclear Energy Institute peer review process (NEI 2007) and the ASME PRA Standard
18 (ASME 2005) as endorsed by the NRC in Regulatory Guide 1.200, Rev. 1 (NRC 2007). In the
19 ER PSEG summarizes the results of the peer review by reporting the number of ASME
20 Standard's supporting requirements (SRs) that were assessed to meet each of the standard's
21 Capability Categories. Of the 301 SRs applicable to HCGS, 286 were found to meet the
22 requirements for Capability Category II or higher, seven met Capability Category I and eight did
23 not meet any Capability Category. Capability Category II is described as follows (ASME 2005):
24 1) the scope and level of detail has resolution and specificity sufficient to identify the relative
25 importance of significant contributors at the component level including human actions, as
26 necessary, 2) plant-specific data/models are used for significant contributors, and 3) departures
27 from realism will have small impact on the conclusions and risk insights as supported by good
28 practices.

29 In the ER, PSEG indicated that the SRs identified as "not met" were addressed in the HC108B
30 model. In response to an NRC staff RAI, PSEG provided a listing and discussion of the
31 resolution of the SRs that only met Capability Category I and of other Peer Review Finding-level
32 F&Os (PSEG 2010a). It should be noted that a Finding-level F&O is essentially equivalent to
33 and replaces the previously used Level A and B F&Os and is defined as an observation that is
34 necessary to address to ensure 1) the technical adequacy of the PRA, 2) the
35 capability/robustness of the PRA update process, and 3) the process for evaluating the
36 necessary capability of the PRA technical elements (NEI 2007).

37 Of the seventeen identified SRs and findings, thirteen were stated to have been resolved as part
38 of the HC108B PRA update and re-assessed as meeting Capability Category II at a minimum as
39 a result of additional investigation, analysis and/or documentation. Four of the SRs and findings
40 remain open. In the discussion of the status and impact of these open items, PSEG concluded
41 that the resolution of each would not impact the conclusions of the SAMA risk assessment. Two
42 of the open items were documentation issues. One issue was related to the need for additional
43 plant-specific data for important events. PSEG indicated that a review of HCGS recent

1 experience indicates "no anomalous behavior" and that minor changes to component
2 unavailability and unreliability values would not change the conclusions of the SAMA risk
3 evaluation. The fourth issue was related to the identification, characterization and
4 documentation of model uncertainties. PSEG indicated that a number of sensitivity evaluations
5 were performed and that other areas of the HCGS PRA were investigated for potential impact
6 on the PRA results but none were found to rise to the level of being candidates for modeling
7 uncertainty. PSEG concluded that the resolution of this open item would not impact the
8 conclusions of the SAMA evaluation (PSEG 2010a). PSEG further states that the HCGS PRA
9 treatment of model uncertainty is considered to meet the requirements of the latest NRC
10 guidance on model uncertainty, NUREG-1855 (NRC 2009).

11 In the initial response to the NRC staff RAIs (PSEG 2010a) PSEG's discussion of the resolution
12 of the supporting requirements that were not met addressed only six items whereas the initial
13 listing in the ER indicated that there were eight SRs that were not met. In response to the
14 request for clarification PSEG pointed out that the draft peer review report identified eight SRs
15 as not met, while the final review report identified only six SRs as not being met (PSEG 2010b).

16 The NRC staff considers PSEG's disposition of the peer review findings to be reasonable and
17 that final resolution of the findings is not likely to impact the results of the SAMA analysis.

18 The Revision HC108B model reflects the current (as of the date of the ER submittal) HCGS
19 configuration and design. The licensee states that HCGS risk management personnel have
20 reviewed plant modifications and procedure changes since the HC108B model freeze date. No
21 changes were identified that required PRA model updates and therefore the licensee concluded
22 that none of the plant modifications and procedure changes since the HC108B PRA update
23 would impact the conclusions of the SAMA analysis. (PSEG 2010a, PSEG 2010b)

24 In response to an RAI, PSEG described the overall quality assurance program applicable to the
25 HCGS PRA and its updates by providing descriptions of significant governing PSEG
26 procedures. These procedures address the overall risk management program, risk
27 management documentation including quality requirements for preparation, review and
28 approval, configuration control and PRA model updates. The procedures appear to address the
29 appropriate requirements.

30 Given that the HCGS internal events PRA model has been peer-reviewed and the peer review
31 findings were all addressed, and that PSEG has satisfactorily addressed NRC staff questions
32 regarding the PRA, the NRC staff concludes that the internal events Level 1 PRA model is of
33 sufficient quality to support the SAMA evaluation.

34 As indicated above, PSEG does not maintain a current HCGS external events PRA that
35 explicitly models seismic and fire initiated core damage accidents that can be linked with the
36 current Level 2 and 3 PRA. However, the models developed for seismic and fire events in the
37 IPEEE were partially updated in 2003 to utilize revised initiating event frequencies and
38 conditional core damage probabilities based on the 2003A internal events PRA Model. These
39 results were used to identify SAMAs that address important fire and seismic risk contributors, as
40 discussed below in Section G.3.2. The updated seismic and fire core damage results are
41 described in ER Section E.5.1.7

42 The HCGS IPEEE was submitted in July 1997 (PSEG 1997), in response to Supplement 4 of
43 Generic Letter 88-20 (NRC 1991a). The submittal included a seismic PRA, an internal fire PRA,

1 and an evaluation of high winds, external flooding, and other hazards. While no fundamental
2 weaknesses or vulnerabilities to severe accident risk in regard to the external events were
3 identified, two potential enhancements were identified as discussed below. In a letter dated July
4 26, 1999 (NRC 1999), the NRC staff concluded that PSEGs IPEEE process is capable of
5 identifying the most likely severe accidents and severe accident vulnerabilities, and therefore,
6 that the HCGS IPEEE has met the intent of Supplement 4 to Generic Letter 88-20.

7 The HCGS IPEEE seismic analysis utilized a seismic PRA following NRC guidance (NRC
8 1991a). The seismic PRA included: a seismic hazard analysis, a seismic fragility assessment, a
9 seismic systems analysis, and quantification of seismic CDF.

10 The seismic hazard analysis estimated the annual frequency of exceeding different levels of
11 ground motion. Seismic CDFs were determined for both the EPRI (EPRI 1989) and the
12 Lawrence Livermore National Laboratory (LLNL) (NRC 1994) hazard assessments. The seismic
13 fragility assessment utilized the walkdown procedures and screening caveats in EPRI's seismic
14 margin assessment methodology (EPRI 1991). Fragility calculations were made for about 90
15 components and, using a screening criterion of median peak ground acceleration (pga) of 1.5 g
16 which corresponds to a 0.5 pga high confidence low probability of failure (HCLPF) capacity, a
17 total of 17 components were screened in. The seismic systems analysis defined the potential
18 seismic induced structure and equipment failure scenarios that could occur after a seismic event
19 and lead to core damage. The HCGS IPE event tree and fault tree models were used as the
20 starting point for the seismic analysis. Quantification of the seismic models consisted of
21 convoluting the seismic hazard curve with the appropriate structural and equipment seismic
22 fragility curves to obtain the frequency of the seismic damage state. The conditional probability
23 of core damage given each seismic damage state was then obtained from the IPE models with
24 appropriate changes to reflect the seismic damage state. The CDF was then given by the
25 product of the seismic damage state probability and the conditional core damage probability.

26 The seismic CDF resulting from the HCGS IPEEE was calculated to be 3.6×10^{-6} per year using
27 the LLNL seismic hazard curve and 1.0×10^{-6} per year using the EPRI seismic hazard curve.
28 Both utilized the HCGS Model 0 internal events PRA, with a CDF of 1.3×10^{-5} per year for
29 quantification of non-seismic failures.

30 The HCGS IPEEE did not identify any vulnerability due to seismic events or any potential
31 improvements to reduce seismic risk. The IPEEE noted, however, that fire water tanks are not
32 seismically robust and hence no credit was taken for the fire protection system in the seismic
33 PRA. This is discussed further in Section G.3.2.

34 Subsequent to the IPEEE, PSEG updated the seismic PRA utilizing conditional core damage
35 probabilities from the 2003A PRA model modified to reflect the seismic human reliability
36 assessment that was performed to support the IPEEE, referred to as the HCGS 2003 External
37 Events Update (PSEG 2009). The resulting seismic CDF using the EPRI seismic hazard curves
38 is 1.1×10^{-6} per year. In the ER, PSEG provided a listing and description of the top ten seismic
39 core damage contributors. The dominant seismic core damage contributors with a CDF of
40 1×10^{-8} per year or more are listed in Table G-4. In response to an NRC staff RAI, PSEG also
41 determined the updated seismic CDF using the LLNL seismic hazard curve and the total
42 seismic CDF was determined to be 3.6×10^{-6} per year. The seismic CDF utilizing the LLNL
43 hazard curves for dominant seismic core damage contributors are also listed in Table G-4.

1 **Table G-4. Dominant Contributors to the Seismic CDF**

Basic Event ID	Seismic Sequence Description	Based on EPRI Seismic Hazard Curves	Based on LLNL Seismic Hazard Curves
		CDF (per year)	% Contribution to Seismic CDF
%IE-SET36	Seismic-Induced Equipment Damage State SET-36 (Impacts – 120V PNL481)	6.7×10^{-7}	60
%IE-SET18	Seismic-Induced Equipment Damage State SET-18 (Impacts – LOOP)	3.1×10^{-7}	27
%IE-SET37	Seismic-Induced Equipment Damage State SET-37 (Impacts – 125V)	$6.8 \times 10^{-8*}$	6
%IE-SET35	Seismic-Induced Equipment Damage State SET-35 (Impacts – 120V PNL482, RSP)	4.6×10^{-8}	4
%IE-SET38	Seismic-Induced Equipment Damage State SET-38 (Impacts – 1E panel room Ventil.)	2.1×10^{-8}	2

* In response to an RAI, PSEG indicated that the value reported in the ER page E-99 for this contributor was in error and should be that given in the IPEEE - 6.8×10^{-8} per year (PSEG 2010a).

2

3 For both hazard curves, the largest contributor to seismic CDF is a seismic-induced loss of all
4 four divisions of 1E 120 VAC instrumentation distribution panels that leads directly to core
5 damage. Other significant contributors are: for the EPRI hazard curves, a seismic-induced loss
6 of offsite power which together with non-seismic random failures leads to core damage and, for
7 the LLNL hazard curves, a seismic induced failure of all 125 VDC 1E power to loads that lead
8 directly to core damage. The failure of all four 1E 120 VAC divisions and failure of all 125 VDC
9 occur at a relatively high ground acceleration (a median failure at 1.08g and 1.47g, respectively)
10 while the loss of offsite power occurs at a relatively low ground acceleration (a median failure of
11 0.31g) (PSEG 1997).

12 The NRC staff requested the applicant assess the impact the higher seismic CDF resulting from
13 the use of the LLNL hazard curves would have on the external events multiplier and the results
14 of the SAMA analysis as well as the impact of the increased CDF for important seismic
15 sequences on the identification and evaluation of SAMAs for these sequences. This is
16 discussed further below and in Sections G.3.2 and G.6.2.

17 The HCGS IPEEE fire analysis employed EPRI's fire-induced vulnerability evaluation (FIVE)
18 methodology (EPRI 1993) to perform a fire compartment interaction analysis (FCIA) and a

1 quantitative screening analysis. This was then followed by a PRA quantification of the
2 unscreened compartments.

3 The FCIA identified 209 fire compartments meeting the FIVE criteria for the entire plant. The
4 quantitative screening utilized a threshold fire ignition frequency obtained using the FIVE
5 methodology and the assumptions that all fires resulted in a reactor trip or more severe transient
6 and that any fire in a compartment damaged all the equipment and cables in the compartment.
7 Using the assessed screening fire frequency and conservatively determined screening
8 conditional core damage probabilities (CCDPs) from the Model 0 internal events PRA resulted
9 in screening out (at a CDF of less than 1×10^{-6} per year) of all but 38 fire compartments.

10 The analysis for the unscreened areas employed a detailed probabilistic assessment of each
11 possible fire initiator/target combination including intermediate fire growth stages. Fire damage
12 calculations used a modified version of the FIVE fire propagation methodology. No explicit
13 credit was taken for manual or automatic fire suppression. Final quantification utilized FIVE fire
14 data and refined CCDPs from the Model 0 internal events PRA. The resulting fire induced CDF
15 was calculated to be 8.1×10^{-5} per year. A walkdown and verification process was employed to
16 verify that the assumptions and calculations were supported by the physical condition of the
17 plant.

18 The HCGS IPEEE did not identify any vulnerabilities due to internal fires or any potential
19 improvements to reduce internal fire risk.

20 Subsequent to the IPEEE, PSEG updated the fire PRA to incorporate more recent fire initiating
21 event frequencies based on information in the 2002 NRC fire database and conditional core
22 damage probabilities from the 2003A PRA model, referred to as the 2003 HCGS External
23 Events Update. The resulting fire CDF is 1.7×10^{-5} per year.

24 In the ER, PSEG provided a listing and description of the top ten fire core damage contributors.
25 The important fire core damage contributors with a CDF of 1×10^{-7} per year or more are listed in
26 Table G-5. As can be seen from these results the fire risk at HCGS is dominated by panel fires
27 in the control room.

28 **Table G-5. Important Contributors to Fire CDF**

Basic Event ID	Fire Area Description	CDF per year	% Contribution to Fire CDF
%IE-FIRE03	Control Room Fire Scenario Small Cab_3 (Loss of Emer. Bat.)	5.3×10^{-6}	31
%IE-FIRE02	Control Room Fire Scenario Small Cab_2 (Loss of SSWS)	4.4×10^{-6}	25
%IE-FIRE01	Control Room Fire Scenario Small Cab_1 (Loss of SACS)	3.8×10^{-6}	22
%IE-FIRE28	Compartment 5339 Fire Scenario 5339_2	7.5×10^{-7}	4
%IE-FIRE37	DG room (D) Fire Scenario 5304_2	7.0×10^{-7}	4
%IE-FIRE20	DG room (C) Fire Scenario 5306_2	6.7×10^{-7}	4

%IE-FIRE38	Compartment 3425/5401 Fire Scenario 5401_1	5.9×10^{-7}	3
%IE-FIRE06	Control Room Fire Scenario Large Cab_1 (MSIV Closure)	5.1×10^{-7}	3

1
2 In the ER, PSEG states that an effective comparison between the internal events PRA results
3 and the fire analysis results is not possible because neither the plant response model or the fire
4 modeling methodology used in the updated fire model is current. PSEG identified in the ER
5 areas where fire CDF quantification may introduce levels of uncertainty different from those
6 expected in the internal events PRA, including a number of conservatisms in the fire modeling,
7 as follows:

- 8 • Several system models assume the systems are unavailable or are unrecoverable in a
9 fire. For example, any fire is assumed to result in a plant trip, even if it is not severe.
10 Other examples are provided in the ER.
- 11 • Bounding fire modeling assumptions are used for many fire scenarios. For example, all
12 cables are damaged in a fire even if they are enclosed in cable trays or conduit. Other
13 examples are provided in the ER.
- 14 • Because of a lack of industry experience with regard to crew performance during the
15 types of fires modeled in the fire PRA, the characterization of crew actions in the fire
16 PRA is generally conservative.

17 PSEG's conclusion is that while some of the conservatisms have been addressed in the
18 updated fire model, the result is still believed to be conservative.

19 Considering the above discussion, the conservatisms in the updated fire PRA model as
20 currently understood, and the response to the NRC staff RAIs, the NRC staff concludes that the
21 fire CDF of 1.7×10^{-5} per year is reasonable for the SAMA analysis.

22 The IPEEE analysis of high winds, floods and other (HFO) external events indicated that each
23 of the events identified in NUREG-1407 (NRC 1991b) had a core damage contribution of less
24 than the screening criterion of 1×10^{-6} per year. This was done by either showing compliance
25 with the 1975 Standard Review Plan criteria or by a bounding analysis that demonstrated that
26 the CDF contribution was less than the screening criterion. For the SAMA analysis, PSEG
27 assumed a CDF contribution of 1×10^{-6} per year for each of high winds, external floods,
28 transportation and nearby facilities, detritus, and chemical releases, for a total HFO CDF
29 contribution of 5×10^{-6} per year (PSEG 2009).

30 Although the HCGS IPEEE did not identify any vulnerabilities due to HFO events, two
31 improvements to reduce risk were identified as described below.

32 For high winds, the HCGS design was compared to the SRP criteria and found to have a CDF
33 contribution less than the screening criterion. A walkdown was performed to evaluate high wind
34 hazards and as a result work was initiated to install a missile shield in front of a door into the
35 Technical Support Center. This improvement has been implemented.

1 For external floods the HCGS was found to be adequately protected from the postulated
2 occurrence of the probable maximum hurricane surge with wave run-up coincident with the 10%
3 exceedance high tide. HCGS was also found to comply with the latest probable maximum
4 precipitation criteria. A walkdown confirmed that there were no severe accident vulnerabilities
5 due to external floods.

6 A review of transportation and nearby facility accidents confirmed that there were no severe
7 accident vulnerabilities from these accidents. During the review it was discovered that in a
8 single year there had been some unauthorized shipments of explosives on the Delaware River
9 in the vicinity of the HCGS. The U.S. Coast Guard (USCG), which controls such shipments,
10 was contacted and procedures were put in place to prevent such shipments in the future. This
11 improvement has been implemented.

12 The NRC staff asked about the status and potential impact on the SAMA analysis of a liquefied
13 natural gas (LNG) terminal planned for Logan Township, New Jersey, upstream on the
14 Delaware River from the HCGS site (NRC 2010a). In response to the RAI, PSEG discussed the
15 current status of the LNG terminal as well as the regulatory controls for LNG marine traffic and
16 LNG ship design and the safety record for LNG shipping (PSEG 2010a). The LNG terminal
17 remains in the planning stage and no construction has begun. Further, the state of Delaware
18 has denied applications for several required environmental permits and approvals. PSEG
19 concluded that based on the regulatory process and controls for assuring the safety and
20 security of LNG ships, the safety record of LNG ships and the uncertainty of the planned
21 terminal, consideration of potential SAMAs associated with the possible future terminal is not
22 warranted. The NRC staff agrees with this conclusion.

23 As indicated in the ER (PSEG 2009), a multiplier of 6.3 was used to adjust the internal event
24 risk benefit associated with a SAMA to account for external events. This multiplier was based
25 on a total external event CDF of 2.3×10^{-5} per year. This CDF is the sum of the updated fire
26 CDF of 1.7×10^{-5} per year, the updated seismic CDF of 1.1×10^{-6} per year, and the HFO CDF
27 of 5×10^{-6} per year. The external event CDF is thus approximately 5.3 times the internal events
28 CDF of 4.4×10^{-6} per year used in the SAMA analysis at a truncation of 5×10^{-11} per year. The
29 higher truncation used for determining the multiplier is to be consistent with that used to
30 determine the release category frequencies and that used to evaluate the fire and seismic
31 CDFs. The total CDF is thus 6.3 times the internal events CDF (PSEG 2009).

32 As indicated above, in response to an NRC staff RAI, PSEG determined the seismic CDF based
33 on the LLNL hazard curve to be 3.6×10^{-6} per year (PSEG 2010a). If this is utilized instead of
34 the value using the EPRI hazard curve, the total external events CDF is 2.6×10^{-5} per year and
35 the external events multiplier is 6.8. The impact of this revised multiplier on the SAMA
36 assessment is discussed further in Section G.3.2 and Section G.6.2.

37 The NRC staff reviewed the general process used by PSEG to translate the results of the Level
38 1 PRA into containment releases, as well as the results of the Level 2 analysis, as described in
39 the ER and in response to NRC staff requests for additional information (PSEG 2010a, PSEG
40 2010b). The HCGS Level 2 PRA model is essentially a complete revision of the IPE Level 2
41 model, including completely revised containment event trees and system fault trees and
42 completely updated thermal hydraulic analyses, incorporating the latest emergency operating
43 procedures (EOPs), severe accident guidelines (SAGs), and emergency action level (EAL) and
44 implementation using the CAFTA software.

1 The current Level 2 model utilizes a set of three containment event trees (CETs) containing both
2 phenomenological and systemic events. The Level 1 core damage sequences are grouped into
3 core damage accident classes with similar characteristics. All the sequences in an accident
4 class are then input to one of the three CETs by linking the level 1 event tree sequences with
5 the level 2 CET. The CETs are analyzed by the linking of fault trees that represent each CET
6 node. These fault trees are based on the Level 1 models for the system or function as modified
7 for Level 2 considerations of timing, procedures, access or dependencies including recovery
8 actions as documented in the HCGS emergency Operating Procedures and Severe Accident
9 Management Guidelines.

10 Each CET end state represents a radionuclide release to the environment and is characterized
11 by one of thirteen release bins based on magnitude and timing of release. Magnitude is given
12 by Csl release fraction: High (H) > 10%, Moderate (M) 1% to 10%, Low (L) 0.1% to 1%, Low-
13 Low (LL) <0.1% and negligible or no release << 0.1%. Timing is given by time of initial release
14 from the time of declaration of a General Emergency: Early (E) < 4 hours, Intermediate (I), 4 to
15 24 hours and Late (L) > 24 hours. The assignment of each end state to a given release bin is
16 made on the basis of a MAAP calculation for the accident sequence or a similar MAAP
17 calculated sequence. The thirteen release bins were subsequently refined into eleven release
18 categories for input to the MACCS consequence calculations by dividing the high early release
19 bin into three release categories (high pressure, low pressure and breaks outside containment)
20 and combining several of the end states with Low and Low-Low release magnitudes.

21 The frequency of each release category was obtained by summing the frequency of the
22 contributing CET end states. The release characteristics for each release category were
23 developed by using the results of Modular Accident Analysis Program (MAAP 4.0.6) computer
24 code calculations. A representative MAAP case for each of the release categories was chosen
25 based on a review of the Level 2 cutsets and the dominant types of scenarios that contribute to
26 the results. The MAAP case chosen for each release category was generally the case with the
27 highest consequence (PSEG 2010a). A description of the representative MAAP case for each
28 release or source term category is provided in Table E.3-5 of the ER. The release categories,
29 their frequencies, and release characteristics are presented in Table E.3-6 of the ER (PSEG
30 2009).

31 It is noted for the SAMA analysis the CET end state and release category frequencies were
32 determined using a truncation value of 5×10^{-11} per year. This results in a total CDF of
33 approximately 4.4×10^{-6} per year, which is about 16 percent less than the internal events CDF of
34 5.1×10^{-6} per year obtained when a truncation of 1×10^{-12} per year. The NRC staff considers
35 that use of the release frequency rather than the Level 1 CDF will have a negligible impact on
36 the results of the SAMA evaluation because the external event multiplier and uncertainty
37 multiplier used in the SAMA analysis (discussed in Section G.6.2) have a much greater impact
38 on the SAMA evaluation results than the small error arising from the model quantification
39 approach.

40 The NRC staff review of release category information noted an apparent discrepancy in the
41 release magnitude and release timing assigned for ST5 and ST7 and requested the applicant to
42 clarify the reasons for these discrepancies (NRC 2010a). Both these release categories involve
43 loss of containment heat removal with subsequent containment failure, core damage and fission
44 product release. For ST5 the containment failure is in the wet well while for ST7 the

1 containment failure is in the drywell. While the drywell failure would be expected to result in a
2 higher release than a wet well failure, the reverse is true for the results provided in the ER.
3 Further, the release timings were found to be slightly different even though the core damage
4 times were the same. In response to the RAI, PSEG pointed out that the wet well failure for
5 ST5 occurred below the water level and, due to the loss of suppression pool water inventory,
6 resulted in significantly less cesium iodide removal from the safety relief valve (SRV) flow to the
7 suppression pool for ST5 than for the drywell failure case ST7 (PSEG 2010a). The differing
8 release pathways resulted in the slightly different times for the initiation of release to the
9 environment.

10 Based on the NRC staff's review of the Level 2 methodology, the applicant's responses to RAIs
11 and the fact that the Level 2 model was reviewed in more detail as part of the 2008 BWROG
12 peer review and found to be acceptable (except for two documentation related findings which
13 would not impact the SAMA analysis), the NRC staff concludes that the Level 2 PRA provides
14 an acceptable basis for evaluating the benefits associated with various SAMAs.

15 The NRC staff reviewed the process used by PSEG to extend the containment performance
16 (Level 2) portion of the PRA to an assessment of offsite consequences (essentially a Level 3
17 PRA). This included consideration of the source terms used to characterize fission product
18 releases for the applicable containment release categories and the major input assumptions
19 used in the offsite consequence analyses. The MACCS2 code was utilized to estimate offsite
20 consequences. Plant-specific input to the code includes the source terms for each category and
21 the reactor core radionuclide inventory (both discussed above), site-specific meteorological
22 data, projected population distribution within an 80-kilometer (50-mile) radius for the year 2046,
23 emergency evacuation modeling, and economic data. This information is provided in Section
24 E.3 of Appendix E to the ER (PSEG 2009).

25 PSEG used the MACCS2 code and a core inventory from a plant specific calculation at end of
26 cycle to determine the offsite consequences of activity release. In response to an NRC staff
27 RAI, PSEG stated that the MACCS2 analysis was based on the core inventory used in the
28 NRC-approved Alternate Source Term for HCGS (PSEG 2010a).

29 All releases were modeled as being from the top of the reactor containment building and at low
30 thermal content (ambient). Sensitivity studies were performed on these assumptions and
31 indicated little or no change in population dose or offsite economic cost. Assuming a ground
32 level release decreased dose risk and cost risk by 6 percent and 7 percent, respectively.
33 Assuming a buoyant plume decreased dose risk and cost risk by 1 percent. Based on the
34 information provided, the staff concludes that the release parameters utilized are acceptable for
35 the purposes of the SAMA evaluation.

36 PSEG used site-specific meteorological data for the 2004 calendar year as input to the
37 MACCS2 code. The development of the meteorological data is discussed in Section E.3.7 of
38 Appendix E to the ER. The data were collected from onsite and local meteorological monitoring
39 systems. Sensitivity analyses using MACCS2 and the meteorological data for the years 2005
40 through 2007 show that use of data for the year 2004 results in the largest dose and economic
41 cost risk. Missing meteorological data was filled by (in order of preference): using data from the
42 backup met pole instruments (10-meter), using corresponding data from another level of the
43 main met tower, interpolation (if the data gap was less than 6 hours), or using data from the
44 same hour and a nearby day (substitution technique). The 10-meter wind speed and direction

1 were combined with precipitation and atmospheric stability (derived from the vertical
2 temperature gradient) to create the hourly data file for use by MACCS2. The NRC staff notes
3 that previous SAMA analyses results have shown little sensitivity to year-to-year differences in
4 meteorological data and concludes that the use of the 2004 meteorological data in the SAMA
5 analysis is reasonable.

6 The population distribution the licensee used as input to the MACCS2 analysis was estimated
7 for the year 2046 using year 1990 and year 2000 census data as accessed by SECPOP2000
8 (NRC 2003) as a starting point. In response to an NRC staff RAI, PSEG stated that the
9 transient population was included in the 10-mile EPZ, and included prior to the population
10 projection (PSEG 2010a). A ten year population growth rate was estimated using the year 1990
11 to year 2000 SECPOP2000 data and applied to obtain the distribution in 2046. The baseline
12 population was determined for each of 160 sectors, consisting of sixteen directions for each of
13 ten concentric distance rings to a radius of 50 miles surrounding the site. The SECPOP2000
14 census data from 1990 and 2000 were used to determine a ten year population growth factor for
15 each of the concentric rings. The population growth was averaged over each ring and applied
16 uniformly to all sectors within each ring. The NRC staff requested PSEG provide an
17 assessment of the impact on the SAMA analysis if a wind-direction weighted population
18 estimate for each sector were used (NRC 2010a). In response to the RAI, PSEG stated that the
19 impacts associated with angular population growth rates on PDR and OECR are minimal and
20 bounded by the 30% population sensitivity case (PSEG 2010a). This is based on the relatively
21 even wind distribution profile surrounding the site, the tendency for lateral dispersion between
22 sectors, and the use of mean values in the analysis. A sensitivity study was performed for the
23 population growth at year 2040. A 30 percent increase in population resulted in a 29 percent
24 increase in dose risk and a 30 percent increase in cost risk. In response to an NRC staff RAI,
25 PSEG stated that the radial growth rates used in the MACCS2 analysis provides a more
26 conservative population growth estimate than using 'whole county' data for averaging (PSEG
27 2010a). PSEG also identified that the population sensitivity case of 30 percent growth was
28 approximately equivalent to adding 5.9 percent to the 10-year growth rate. The NRC staff
29 considers the methods and assumptions for estimating population reasonable and acceptable
30 for purposes of the SAMA evaluation.

31 The emergency evacuation model was modeled as a single evacuation zone extending out 16
32 kilometers (10 miles) from the plant (the emergency planning zone – EPZ). PSEG assumed
33 that 95 percent of the population would evacuate. This assumption is conservative relative to
34 the NUREG-1150 study (NRC 1990), which assumed evacuation of 99.5 percent of the
35 population within the emergency planning zone. The evacuated population was assumed to
36 move at an average radial speed of approximately 2.8 meters per second (6.3 miles per hour)
37 with a delayed start time of 65 minutes after declaration of a general emergency (KLD 2004). A
38 general emergency declaration was assumed to occur at the onset of core damage. The
39 evacuation speed is a time-weighted average value accounting for season, day of week, time of
40 day, and weather conditions. It is noted that the longest evacuation time presented in the study
41 (i.e., full 10 mile EPZ, winter snow conditions, 99th percentile evacuation) is 4 hours (from the
42 issuance of the advisory to evacuate). Sensitivity studies on these assumptions indicate that
43 there is minor impact to the population dose or offsite economic cost by the assumed variations.
44 The sensitivity study reduced the evacuation speed by 50 percent to 1.4 m/s. This change
45 resulted in a 2 percent increase in population dose risk and no change in offsite economic cost

1 risk. The NRC staff concludes that the evacuation assumptions and analysis are reasonable
2 and acceptable for the purposes of the SAMA evaluation.

3 Site specific agriculture and economic parameters were developed manually using data in the
4 2002 National Census of Agriculture (USDA 2004) and from the Bureau of Economic Analysis
5 (BEA 2008) for each of the 23 counties surrounding HCGS, to a distance of 50 miles.
6 Therefore, recently discovered problems in SECPOP2000 do not impact the HCGS analysis.
7 The values used for each of the 160 sectors were the data from each of the surrounding
8 counties multiplied by the fraction of that county's area that lies within that sector. Region-wide
9 wealth data (i.e., farm wealth and non-farm wealth) were based on county-weighted averages
10 for the region within 50-miles of the site using data in the 2002 National Census of Agriculture
11 (USDA 2004) and the Bureau of Economic Analysis (BEA 2008). Food ingestion was modeled
12 using the new MACCS2 ingestion pathway model COMIDA2 (NRC 1998a). For HCGS, less
13 than one percent of the total population dose risk is due to food ingestion.

14 In addition, generic economic data that is applied to the region as a whole were revised from the
15 MACCS2 sample problem input in order to account for cost escalation since 1986, the year that
16 input was first specified. A factor of 1.96, representing cost escalation from 1986 to April 2008
17 was applied to parameters describing cost of evacuating and relocating people, land
18 decontamination, and property condemnation.

19 The NRC staff concludes that the methodology used by PSEG to estimate the offsite
20 consequences for HCGS provides an acceptable basis from which to proceed with an
21 assessment of risk reduction potential for candidate SAMAs. Accordingly, the NRC staff based
22 its assessment of offsite risk on the CDF and offsite doses reported by PSEG.

23 **G.3 Potential Plant Improvements**

24
25 The process for identifying potential plant improvements, an evaluation of that process, and the
26 improvements evaluated in detail by PSEG are discussed in this section.

27 **G.3.1 Process for Identifying Potential Plant Improvements**

28
29 PSEG's process for identifying potential plant improvements (SAMAs) consisted of the following
30 elements:

- 31 • Review of the most significant basic events from the current, plant-specific PRA and
32 insights from the HCGS PRA Group,
- 33 • Review of potential plant improvements identified in, and original results of, the HCGS
34 IPE and IPEEE,
- 35 • Review of SAMA candidates identified for license renewal applications for six other U.S.
36 nuclear sites, and
- 37 • Review of generic SAMA candidates from NEI 05-01 (NEI 2005) to identify SAMAs that
38 might address areas of concern identified in the HCGS PRA.

1 Based on this process, an initial set of 23 candidate SAMAs, referred to as Phase I SAMAs, was
2 identified. In this Phase I evaluation, PSEG performed a qualitative screening of the initial list of
3 SAMAs and eliminated SAMAs from further consideration using the following criteria:

- 4 • The SAMA is not applicable at HCGS due to design differences,
- 5 • The SAMA has already been implemented at HCGS,
- 6 • The SAMA would achieve results that have already been achieved at HCGS by other
7 means, or
- 8 • The SAMA has estimated implementation costs that would exceed the dollar value
9 associated with completely eliminating all severe accident risk at HCGS.

10 Based on this screening, one SAMA was eliminated, and one additional SAMA was eliminated
11 by subsuming it into another SAMA, leaving 21 SAMAs for further evaluation. The results of the
12 Phase I screening analysis is given in Table E.5-3 of Appendix E to the ER. The remaining
13 SAMAs, referred to as Phase II SAMAs, are listed in Table E.6-1 of Appendix E to the ER. In
14 Phase II a detailed evaluation was performed for each of the 21 remaining SAMA candidates,
15 as discussed in Sections G.4 and G.6 below. To account for the potential impact of external
16 events, the estimated benefits based on internal events were multiplied by a factor of 6.3, as
17 previously discussed.

18 **G.3.2 Review of PSEG's Process**

19 PSEG's efforts to identify potential SAMAs focused primarily on areas associated with internal
20 initiating events, but also included explicit consideration of potential SAMAs for important fire
21 and seismic initiated core damage sequences. The initial list of SAMAs generally addressed the
22 accident sequences considered to be important to CDF from risk reduction worth (RRW)
23 perspectives at HCGS, and included selected SAMAs from prior SAMA analyses for other
24 plants.

25 PSEG provided a tabular listing of the Level 1 PRA basic events sorted according to their RRW
26 (PSEG 2009). SAMAs impacting these basic events would have the greatest potential for
27 reducing risk. PSEG used a RRW cutoff of 1.006, which corresponds to about a 0.6 percent
28 change in CDF given 100-percent reliability of the SAMA. This equates to a benefit of
29 approximately \$100,000 (after the benefits have been multiplied by a factor of 6.3 to account for
30 external events), which is the minimum implementation cost associated with a procedure
31 change. As a result of this review, 11 SAMAs were identified.

32 In the level 1 importance review, PSEG stated for the important initiating events that "This
33 initiator event is a compilation of industry and plant specific data. (No specific SAMA identified)."
34 The NRC staff requested that PSEG provide assurance that for each of these initiating events
35 there is not a dominant contributor for which a potential SAMA to reduce the initiating event
36 frequency or mitigate the impact of the initiator would be viable. In response to this RAI, PSEG
37 discussed each of the initiators and the previously identified SAMAs that would reduce the
38 importance of the initiator by mitigating other failures in the core damage sequences associated
39 with these initiators (PSEG 2010a). In response to a request for clarification PSEG indicated

1 that HCGS specific failures that are contributors to the initiating event frequencies that pose a
2 unique vulnerability are typically captured and corrected within existing procedures, e.g., the
3 corrective action program, and can result in procedure changes, plant modifications and training
4 enhancements aimed at reducing further recurrence (PSEG 2010b). Based on this discussion
5 and a review of the latest ten years of HCGS Licensee Event Reports, the NRC staff concludes
6 that it is unlikely that further HCGS data review will identify any additional cost beneficial SAMAs
7 beyond those already identified.

8 The PSEG response to the NRC staff request for clarification provided additional information on
9 initiators modeled utilizing a fault tree approach rather than being based on initiating event data.
10 For the loss of station auxiliaries cooling system initiating event (%IE-SACS), PSEG identified
11 and evaluated SAMA 42, "Installation of SACS Standby Diesel-Powered Pump" (PSEG 2010b).

12 For an event involving the station service water system (NR-IE-SWS, "Nonrecovery of %IE-
13 SWS"), the importance review identified two SAMAs as potentially mitigating this event: SAMA
14 3, "Install Back-up Air Compressor to Supply Air-Operated Valves (AOVs)," and SAMA 4,
15 "Provide Procedural Guidance to Cross-Tie Residual Heat Removal (RHR) Trains." In response
16 to an NRC staff RAI to clarify the source and applicability of these SAMAs to this event, PSEG
17 discussed the modeling involving the NR-IE-SWS event and the applicability of the SAMAs in
18 terms of the more general loss of decay heat removal function of which the event is associated
19 and other SAMAs that would mitigate this event (PSEG 2010a). Based on this discussion, the
20 NRC staff concludes that this event is adequately addressed in the SAMA analysis.

21 For a significant number of the Level 1 events reviewed no SAMAs were identified with the
22 reason stated to be that "...based on low contribution to L[evel] 1 risk and engineering
23 judgment, the anticipated implementation costs of hardware mods associated with mitigating
24 this event would likely exceed the expected cost-risk benefit" (PSEG 2009). In response to an
25 NRC staff RAI, PSEG provided a revised assessment of each of these events that showed that
26 each was either already addressed by an existing SAMA or that no effective SAMAs could be
27 identified (PSEG 2010a).

28 The NRC staff also requested PSEG to specifically consider the following proposed SAMAs to
29 address basic events on the Level 1 importance list for which no SAMA was identified (NRC
30 2010a):

- 31 • Install a diverse redundant temperature controller to address basic event SAC-XHE-MC-
32 DF01, "dependent failure of miscalibration of temperature controller HV-2457S." In
33 response to the RAI, PSEG explained that this SAMA is not warranted since 1)
34 procedures are already in place to manually control the affected system which, if
35 credited using a failure probability of 0.1, would reduce the RRW for this basic event to
36 1.005, the review threshold, and 2) controller miscalibration would be observed during
37 normal operation (PSEG 2010a).
- 38 • Install flood barriers to address basic event %FL-FPS-5302, "internal flood outside lower
39 relay room." In response to the RAI, PSEG clarified that the ER incorrectly did not
40 identify SAMA 8, "Convert Selected Fire Protection Piping from Wet Pipe to Dry Pipe
41 System," to address this event and further explained that the proposed SAMA is not
42 necessary because the conversion to a dry pipe system was considered preferable to

1 developing flood barriers considering the multiple doors that exist in the corridor outside
2 the relay room (PSEG 2010a).

- 3 • Install a spray shield to address basic event SWS-MOV-VF-SPRAY, "flood – spray
4 causes motor-operated valve (MOV) failure in reactor auxiliaries cooling system (RACS)
5 compartment." In response to the RAI, PSEG explained that the proposed SAMA is not
6 required because the PRA conservatively assumes that all relevant spray events cause
7 failure of the MOVs and that an assumption of 1 in 10 events causing failure would
8 reduce the RRW for this basic event to below the 1.005 review threshold (PSEG
9 2010a).
- 10 • Installation of a passive containment vent to address basic event NR-RHRVENT-INT,
11 "fail to initiate vent given failure to initiate residual heat removal (RHR) in suppression
12 pool cooling (SPC)." This proposed SAMA would also be an alternative to SAMA 4,
13 "Provide Procedural Guidance to Cross-tie RHR Trains." In response to the RAI, PSEG
14 indicated that changing the existing hard pipe venting system to a passive vent design is
15 not considered feasible due to the loss in response flexibility provided by the existing
16 hard pipe venting system and the potential for premature opening of the rupture disks in
17 the passive design (PSEG 2010a). In response to a request for clarification PSEG
18 identified and evaluated SAMA 41, "Installation of Passive Hardened Containment
19 Ventilation Pathway" (PSEG 2010b).

20 *In summary, as a result of PSEG's reconsideration of basic events for which no SAMA had*
21 *been identified in the ER, two new SAMAs were identified: SAMA 41, "Installation of Passive*
22 *Hardened Containment Ventilation Pathway," and SAMA 42, "Installation of SACS Standby*
23 *Diesel-Powered Pump." A Phase II cost-benefit evaluation was performed for each of these*
24 *additional SAMAs, which is discussed in Section G.6.2.*

25 *In response to an NRC staff RAI, PSEG extended the review down to a RRW of 1.005 to*
26 *account for a revised external events multiplier of 6.8, which was discussed in Section G.2.2.*
27 *This extended review identified one additional SAMA as follows: SAMA RAI 5.j-IE1, "Install a*
28 *Key Lock Switch for Bypass of the MSIV Low Level Isolation Logic" (PSEG 2010a, PSEG*
29 *2010b). The Phase II cost-benefit evaluation of this SAMA is discussed in Section G.6.2.*

30 *PSEG also provided and reviewed the Level 2 PRA basic events, down to a RRW of 1.006, for*
31 *cutsets stated to contribute to large early release. This review did not identify any additional*
32 *SAMAs. In response to an NRC staff RAI, PSEG revisited this review using only the cutsets*
33 *from the high and moderate release categories, which contribute over 99 percent of the*
34 *population dose-risk and offsite economic cost risk (PSEG 2010a). The Level 2 basic events for*
35 *the remainder of the release categories were not included in the review so as to prevent high*
36 *frequency-low consequence events from biasing the importance listing. In addition the review*
37 *was extended down to a RRW of 1.005 to account for a revised external events multiplier of 6.8.*
38 *The revisited review identified one additional SAMA, not identified in the extended Level 1*
39 *review discussed above, as follows: SAMA RAI 5p-1, "Install an Independent Boron Injection*
40 *System." The Phase II cost-benefit evaluation of this SAMA is discussed in Section G.6.2.*

1 The NRC staff also requested PSEG to specifically consider the following proposed SAMAs
2 (NRC 2010a):

- 3 1. Installation of a curb or barrier inside the drywell to prevent early failure of the drywell
4 shell due to shell melt-through. This proposed SAMA addresses basic event CNT-DWV-
5 FF-MLTFL, "drywell (DW) shell melt-through failure due to containment failure," for which
6 no SAMA was identified. In response to the RAI, PSEG explained that this proposed
7 SAMA would not be effective in reducing risk because 1) injection is not available and,
8 without cooling, the core debris would degrade the barrier to the point of failure, and 2)
9 an early unscrubbed release pathway is already available as a result of pre-existing
10 containment failures resulting from loss of decay heat removal (PSEG 2010a).
- 11 2. Replacement of the normally open floor and equipment drain MOVs with fail-closed air-
12 operated valves (AOVs). While this proposed SAMA is stated in the ER to be a more
13 costly alternative to SAMA 5, "restore AC power with onsite gas turbine generator," the
14 NRC staff noted in the RAI that it might also be more effective and therefore have a
15 larger benefit. In response to the RAI, PSEG provided a Phase II cost-benefit evaluation
16 of this proposed SAMA, which is discussed in Section G.6.2.

17 One additional SAMA, SAMA 18, "replace a return fan with a different design in service water
18 pump room," was identified in the ER based on a review of PRA insights from the HCGS PRA
19 Group and was identified to address two basic events on the Level 1 basic events importance
20 list.

21 PSEG reviewed the cost-beneficial Phase II SAMAs from prior SAMA analyses for five General
22 Electric BWR and one Westinghouse PWR sites. PSEG's review determined that all but two of
23 the Phase II SAMAs reviewed were either already represented by an existing SAMA, are
24 already implemented at HCGS, have low potential for risk reduction at HCGS, or were not
25 applicable to the HCGS design. This review resulted in two SAMAs being identified by PSEG
26 for HCGS.

27 PSEG's disposition of industry SAMA "auto align 480V AC portable station generator" is stated
28 to be addressed by SAMA 5, "restore AC power with onsite gas turbine generator." The NRC
29 staff noted that the industry SAMA could mitigate events other than those addressed by SAMA
30 5 and requested PSEG to evaluate the industry SAMA (NRC 2010a). In response to an NRC
31 staff RAI PSEG identified and evaluated an additional SAMA to automate the alignment of the
32 portable 480V AC generator (PSEG 2010a, PSEG 2010b). The cost-benefit evaluation of this
33 additional SAMA is discussed in Section G.6.2.

34 The ER states that an industry SAMA to "develop a procedure to open the door of the EDG
35 buildings upon the higher temperature alarm" was included in the HCGS SAMA analysis. The
36 NRC staff noted that no such SAMA was evaluated and asked PSEG to clarify this discrepancy
37 (NRC 2010a). In response to the RAI, PSEG explained that this SAMA would not reduce HCGS
38 risk since EDG room cooling issues are small contributors to risk at HCGS and that the
39 statement in the ER is incorrect (PSEG 2010a).

40 The NRC asked PSEG to address a SAMA to "increase boron concentration or enrichment in
41 the SLC system," which was determined to be potentially cost-beneficial in the Duane Arnold

1 SAMA analysis (NRC 2010a). In response to the RAI, PSEG explained that this SAMA would
2 have a negligible benefit at HCGS because SLC is automatically initiated at HCGS and the
3 basic events the SAMA addresses (related to manual SLC initiation) are not on the importance
4 lists (PSEG 2010a).

5 PSEG considered the potential plant improvements described in the IPE in the identification of
6 plant-specific candidate SAMAs for internal events. Review of the IPE led to no additional
7 SAMA candidates since the three improvements identified in the IPE have already been
8 implemented at HCGS. (PSEG 2009)

9 Based on this information, the NRC staff concludes that the set of SAMAs evaluated in the ER,
10 together with those identified in response to NRC staff RAIs, addresses the major contributors
11 to internal event CDF.

12 Although the IPEEE did not identify any fundamental vulnerabilities or weaknesses related to
13 external events, two improvements related to HFO events were identified. The two
14 improvements have been implemented at HCGS (PSEG 2009). In the ER PSEG also identified
15 three post IPEEE site changes to determine if they could impact the IPEEE results and possibly
16 lead to a SAMA. From this review no additional SAMAs were identified.

17
18 In a further effort to identify external event SAMAs, PSEG identified the top 10 fire scenarios
19 contributing to fire CDF based on the results of the updated HCGS fire PRA model and
20 reviewed the top 8 fire scenarios for potential SAMAs. These 8 scenarios are the only HCGS
21 fire scenarios having a benefit equal to or greater than approximately \$100,000, which is the
22 approximate value of implementing a procedure change at a single unit at HCGS. The
23 maximum benefit for a fire area is the dollar value associated with completely eliminating the fire
24 risk in that fire area. SAMAs having an implementation cost of less than that of a procedure
25 change, or \$100,000, are unlikely. As a result of this review, PSEG identified six Phase I
26 SAMAs to reduce fire risk. The SAMAs identified included both procedural and hardware
27 alternatives (PSEG 2009). The NRC staff concludes that the opportunity for fire-related SAMAs
28 has been adequately explored and that it is unlikely that there are additional potentially cost-
29 beneficial, fire-related SAMA candidates.

30
31 For seismic events, PSEG reviewed the top 10 seismic sequences contributing to seismic CDF
32 based on the results of the 2003 HCGS seismic analysis and initially reviewed the top 2 seismic
33 sequences for potential SAMAs. These two sequences are the only HCGS seismic sequences
34 having a benefit equal to or greater than approximately \$100,000, which is the approximate
35 value of implementing a procedure change at a single unit at HCGS. The maximum benefit for
36 a seismic sequence is the dollar value associated with completely eliminating the seismic risk
37 for that sequence. SAMAs having an implementation cost of less than that of a procedure
38 change, or \$100,000, are unlikely. As a result of this review, PSEG identified three Phase I
39 SAMAs to reduce seismic risk (PSEG 2009).

40 In response to an NRC staff RAI, PSEG revised the review of seismic sequences to account for
41 the increased maximum benefit of each sequence resulting from the use of the LLNL seismic
42 hazard curve instead of the EPRI curve used initially, as discussed in Section G.2.2. This
43 resulted in two additional seismic sequences having a benefit equal to or greater than the

1 \$100,000 threshold. As a result of the review of these sequences three additional SAMAs were
2 identified: 1) reinforce 1E 125V DC distribution panels 1A/B/C/D-D-417, 2) reinforce 1E 120V
3 AC distribution panels 1A/B/C/DJ482, and 3) reinforce the 1E 120V AC 481 distribution panels
4 to 1.0g Seismic Rating (PSEG 2010a, PSEG 2010b). The cost-benefit evaluation of these
5 additional SAMAs is discussed in Section G.6.2.

6 The NRC staff concludes that the opportunity for seismic-related SAMAs has been adequately
7 explored and that it is unlikely that there are additional potentially cost-beneficial, seismic-
8 related SAMA candidates.

9 As stated earlier, other external hazards (high winds, external floods, transportation and nearby
10 facility accidents, release of on-site chemicals, and detritus) are below the IPEEE threshold
11 screening frequency, or met the 1975 SRP design criteria, and are not expected to represent
12 vulnerabilities. Nevertheless, PSEG reviewed the IPEEE results and subsequent plant changes
13 for each of these external hazards and determined that either 1) the maximum benefit from
14 eliminating all associated risk was less than approximately \$100,000, which is the approximate
15 value of implementing a procedure change at a single unit at HCGS, or 2) only hardware
16 enhancements that would significantly exceed the maximum value of any potential risk
17 reduction were available. As a result of this review, PSEG identified no additional Phase I
18 SAMAs to reduce HFO risk (PSEG 2009). The NRC staff concludes that the licensee's
19 rationale for eliminating other external hazards enhancements from further consideration is
20 reasonable.

21 The NRC staff noted that, while the generic SAMA list from NEI 05-01 (NEI 2005) was stated to
22 have been used in the identification of SAMAs for HCGS, it was not specifically reviewed to
23 identify SAMAs that might be applicable to HCGS but rather was used to identify SAMAs that
24 might address areas of concern identified in the HCGS PRA (NRC 2010a). The NRC staff
25 asked PSEG to provide further information to justify that this approach produced a
26 comprehensive set of SAMAs for consideration. In response to the RAI, PSEG explained that,
27 based on the early SAMA reviews, both the industry and NRC came to realize that a review of
28 the generic SAMA list was of limited benefit because they were consistently found to not be
29 cost-beneficial and that the real benefit was considered to be in the development of SAMAs
30 generated based on plant specific risk insights from the PRA models (PSEG 2010a).
31 Furthermore, while the generic list does include potential plant improvements for plants having a
32 similar design to HCGS, plant designs are sufficiently different that the specific plant
33 improvements identified in the generic list are generally not directly applicable to HCGS, and
34 require alteration to specifically address the HCGS design and risk contributors or otherwise
35 would be screened as not applicable to the HCGS design. For these reasons, PSEG concludes
36 that the real value of the NEI 05-01 generic SAMA list is as an idea source to generate SAMAs
37 that address important contributors to HCGS risk. The NRC staff accepts PSEG's conclusion.

38 The NRC staff noted that the 23 Phase I SAMA numbers were not consecutive from 1 to 23, but
39 rather were intermittently numbered between 1 and 40 and requested clarification on the
40 process used to develop the Phase I SAMA list (NRC 2010a). In response to the RAI, PSEG
41 clarified that the original SAMA list was generated from an importance list using the HC108A
42 PRA model, and that review of the subsequent importance list developed using the HC108B

1 PRA model determined that certain SAMAs were either no longer applicable or were subsumed
2 into other existing SAMAs (PSEG 2010a). PSEG further clarified that the resulting set of Phase
3 I SAMAs was not renumbered to be consecutive so as to avoid configuration management
4 errors that could occur when working with other documentation and supplemental files. Also,
5 SAMAs identified from the review of external events were given a starting number of 30 so as to
6 avoid overlap with SAMAs developed for internal events.

7 As indicated above two Phase 1 SAMAs were screened out. SAMA 38, "Enhance Fire Water
8 System (FWS) and Automatic Depressurization System (ADS) for Long-term Injection," was
9 screened out on the basis that a procedure has been implemented to address the actions
10 associated with this SAMA. However, as discussed in ER Section E.5.1.7.2.2, this SAMA
11 requires enhancement to the FWS, including strengthening the fire water tanks. In response to
12 an NRC staff RAI, PSEG provided an additional discussion regarding this SAMA and how
13 enhancements to the FWS have been addressed as part of the implementation of the current
14 procedure (PSEG 2010a). The additional discussion indicated that the seismic sequence from
15 which this SAMA originated was a low magnitude earthquake for which there would be a
16 relatively small chance for failure of the FWS. Consequently, strengthening the FWS would
17 have little impact on the sequence and, upon reevaluation, is not needed as part of SAMA 38.
18 PSEG therefore concluded that the procedure implements the remaining requirements of this
19 SAMA.

20 SAMA 14, "Alternate Room Cooling for Service Water (SW) Rooms," was screened out on the
21 basis that it was subsumed into SAMA 4, "cross-tie RHR pump trains." It is described as
22 providing an alternate means of opening Torus Vent Valves, but no basic event in the
23 importance lists is identified as being addressed by this SAMA. In response to an NRC staff
24 RAI, PSEG provided a further discussion of this SAMA and its disposition (PSEG 2010a).
25 SAMA 14 was originally developed to address important containment venting failure events.
26 The importance of these events would be reduced if the need to vent containment is reduced by
27 addressing failure of SW room cooling which leads to loss of containment heat removal. It was
28 subsequently determined that SAMA 4 was the most viable SAMA to address the loss of
29 containment heat removal and SAMA 14 was subsumed into SAMA 4. PSEG also indicated
30 that a loss of SW room cooling could also be addressed by a new SAMA that provides an
31 alternate room cooling strategy for the SW room using procedures and portable fans. A Phase
32 II detailed evaluation was performed for this new SAMA, referred to as SAMA RAI 7.a-1,
33 "enhance procedures and provide additional equipment to respond to loss of all service water
34 pump room supply or return fans" (PSEG 2010a).

35 The NRC staff questioned PSEG about lower cost alternatives to some of the SAMAs evaluated
36 (NRC 2010a), including:

- 37 • Establishing procedures for opening doors and/or using portable fans for sequences
38 involving room cooling failures.
- 39 • Extending the procedure for using the B.5.b low pressure pump for non-security
40 events to include all applicable scenarios, not just SBOs.
- 41 • Utilizing a portable independently powered pump to inject into containment.

1 In response to the RAIs, PSEG addressed the suggested lower cost alternatives (PSEG 2010a).
2 A new SAMA, SAMA RAI 7.a-1 discussed above, was assessed in a Phase II detailed
3 evaluation for the first item while the other two items are effectively covered by existing
4 procedures. This is discussed further in Section G.6.2.

5 The NRC staff notes that the set of SAMAs submitted is not all-inclusive, since additional,
6 possibly even less expensive, design alternatives can always be postulated. However, the NRC
7 staff concludes that the benefits of any additional modifications are unlikely to exceed the
8 benefits of the modifications evaluated and that the alternative improvements would not likely
9 cost less than the least expensive alternatives evaluated, when the subsidiary costs associated
10 with maintenance, procedures, and training are considered.

11 The NRC staff concludes that PSEG used a systematic and comprehensive process for
12 identifying potential plant improvements for HCGS, and that the set of potential plant
13 improvements identified by PSEG is reasonably comprehensive and, therefore, acceptable.
14 This search included reviewing insights from the plant-specific risk studies, and reviewing plant
15 improvements considered in previous SAMA analyses. While explicit treatment of external
16 events in the SAMA identification process was limited, it is recognized that the prior
17 implementation of plant modifications for fire and seismic risks and the absence of external
18 event vulnerabilities reasonably justifies examining primarily the internal events risk results for
19 this purpose.

20 **G.4 Risk Reduction Potential of Plant Improvements**

21
22 PSEG evaluated the risk-reduction potential of the 21 remaining SAMAs that were applicable to
23 HCGS, and additional SAMAs identified in response to NRC staff RAIs. The SAMA evaluations
24 were performed using realistic assumptions with some conservatism. On balance, such
25 calculations overestimate the benefit and are, therefore, conservative.

26 PSEG used model re-quantification to determine the potential benefits. The CDF, population
27 dose reductions, and offsite economic cost reductions were estimated using the HCGS PRA
28 model. The changes made to the model to quantify the impact of SAMAs are detailed in
29 Section E.6 of Appendix E to the ER (PSEG 2009). Table G-6 lists the assumptions considered
30 to estimate the risk reduction for each of the evaluated SAMAs, the estimated risk reduction in
31 terms of percent reduction in CDF and population dose, and the estimated total benefit (present
32 value) of the averted risk. The estimated benefits reported in Table G-6 reflect the combined
33 benefit in both internal and external events. The determination of the benefits for the various
34 SAMAs is further discussed in Section G.6.

35 The NRC staff questioned the assumptions used in evaluating the benefit or risk reduction
36 estimate of SAMA 5, "Restore AC Power with Onsite Gas Turbine Generator." The assessment
37 of this SAMA assumed this was equivalent to reducing the probability of failure to cross tie the
38 HCGS emergency diesel generators. This assumption does not provide credit for the gas
39 turbine generator (GTG) in the situation where all the emergency generators are unavailable
40 (NRC 20010a). In response to the RAIs, PSEG provided the results of a sensitivity study which
41 the NRC staff subsequently noted did not appear to include credit for the hardware changes
42 included in the cost estimate (NRC 2010b). In response to the request for clarification, PSEG
43 provide the results of a re-evaluation of SAMA 5 that incorporated the additional capability for

1 mitigating a more complete set of loss of offsite power initiators consistent with the hardware
2 changes proposed (PSEG 2010b). The revised results are provided in Table G-6.

3 For SAMAs that specifically addressed fire events (i.e., SAMA 30, "Provide Procedural
4 Guidance for Partial Transfer of Control Functions from Control Room to the Remote Shutdown
5 Panel," SAMA 31, "Install Improved Fire Barriers in the Main Control Room (MCR) Control
6 Cabinets Containing the Primary Main Steam Isolation Valve (MSIV) Control Circuits," SAMA
7 32, "Install Additional Physical Barriers to Limit Dispersion of Fuel Oil from Diesel Generator
8 (DG) Rooms," SAMA 33, "Install Division II 480V AC Bus Cross-ties," SAMA 34, "Install Division
9 I 480V AC Bus Cross-ties," and SAMA 35, "Relocate, Minimize and/or Eliminate Electrical
10 Heaters in Electrical Access Room"), the reduction in fire CDF and population dose was not
11 directly calculated (in Table G-6 this is noted as "Not Estimated"). For these SAMAs, an
12 estimate of the impact was made based on general assumptions regarding: the approximate
13 contribution to total risk from external events relative to that from internal events; the fraction of
14 the external event risk attributable to fire events; the fraction of the fire risk affected by the
15 SAMA (based on information from the 2003 HCGS External Events Update); and the
16 assumption that the SAMA eliminates 90 percent (SAMAs 30, 32, 33, and 34), 99 percent
17 (SAMA 35), or all (SAMA 31) of the fire risk affected by the SAMA. Specifically, it is assumed
18 that the contribution to risk from external events is approximately 5.3 times that from internal
19 events, and that internal fires contribute 74 percent of this external events risk. The fire basic
20 events impacted by the SAMA are identified and the portion of the total fire risk contributed by
21 each of these fire basic events determined. For SAMA 31, the benefit or averted cost risk from
22 reducing the fire risk affected by the SAMA is then calculated by multiplying the ratio of the fire
23 risk affected by the SAMA to the internal events CDF by the total present dollar value equivalent
24 associated with completely eliminating severe accidents from internal events at HCGS. For the
25 other fire SAMAs, the benefit or averted cost risk from reducing the fire risk affected by the
26 SAMA is then calculated by multiplying the ratio of 90 percent, or 99 percent (SAMA 35), of the
27 fire risk affected by the SAMA to the internal events CDF by the total present dollar value
28 equivalent associated with completely eliminating severe accidents from internal events at
29 HCGS. These SAMAs were assumed to have no additional benefits in internal events.
30

31 The NRC staff questioned the calculated impact for SAMA 35 which assumed that 90 percent of
32 the fire risk affected by the SAMA was eliminated rather than the 99 percent stated in the ER
33 (NRC 2010a). In response to the RAI, PSEG provided a revised evaluation using 99 percent
34 (PSEG 2010a). The revised results are provided in Table G-6.
35

36 For SAMAs that specifically addressed seismic events (i.e., SAMA 36, "Provide Procedural
37 Guidance for Loss of All 1E 120V AC Power," and SAMA 37, "Reinforce 1E 120V AC
38 Distribution Panels") the reduction in seismic CDF and population dose also was not directly
39 calculated. As was done for fire SAMAs, an estimate of the impact of seismic SAMAs was
40 made based on general assumptions regarding: the approximate contribution to total risk from
41 external events relative to that from internal events; the fraction of the external event risk
42 attributable to seismic events; the fraction of the seismic risk affected by the SAMA (based on

1 information from the 2003 HCGS External Events Update); and the assumption that the SAMA
2 eliminates 50 percent (SAMA 36) or 90 percent (SAMA 37) of the seismic risk affected by the
3 SAMA. Specifically, it is assumed that the contribution to risk from external events is
4 approximately 5.3 times that from internal events, and that seismic events contribute 5 percent
5 of this external events risk. The seismic basic events impacted by the SAMA are identified and
6 the portion of the total seismic risk contributed by each of these seismic basic events
7 determined. The benefit or averted cost risk from reducing the seismic risk affected by the
8 SAMA is then calculated by multiplying the ratio of 50 percent (SAMA 36), or 90 percent (SAMA
9 37), of the seismic risk affected by the SAMA to the internal events CDF by the total present
10 dollar value equivalent associated with completely eliminating severe accidents from internal
11 events at HCGS. These SAMAs were assumed to have no additional benefits in internal
12 events.

13
14 The NRC staff has reviewed PSEG's bases for calculating the risk reduction for the various
15 plant improvements and concludes, with the above clarifications, that the rationale and
16 assumptions for estimating risk reduction are reasonable and generally conservative (i.e., the
17 estimated risk reduction is higher than what would actually be realized). Accordingly, the NRC
18 staff based its estimates of averted risk for the various SAMAs on PSEG's risk reduction
19 estimates.

Table G-6. SAMA Cost/Benefit Screening Analysis for HCGS^(a)

SAMA	Assumptions	% Risk Reduction		Total Benefit (\$)		Cost (\$)
		CDF	Population Dose	Baseline (Internal + External)	Baseline With Uncertainty ^(e)	
1 – Remove Automatic Depressurization System (ADS) Inhibit from Non-ATWS Emergency Operating Procedures	The probability that operators fail to inhibit ADS was reduced to 0.1 from 1.0.	26	29	5.3M	14.9M	200K
3 – Install Back-up Air Compressor to Supply AOVs	The probability that operators fail to restore service water was reduced to 0.5 from 1.0.	16	16	3.3M	9.4M	700K
4 – Provide Procedural Guidance to Cross-Tie RHR Trains	The probability that operators fail to recover RHR was reduced to 0.1 from 0.35.	12	21	4.4M	12.4M	100K
5 ^(b) – Restore AC Power with Onsite Gas Turbine Generator	The probability that operators fail to cross-tie the emergency diesel generators (EDGs) was reduced to 0.1 from 1.0. In response to an NRC staff RAI, the GTG failure probability, maintenance unavailability, and human error probability were set to 0.	9	11	2.2M	6.3M	2.05M
7 – Install Better Flood Protection Instrumentation for Reactor Auxiliaries Cooling System (RACS) Compartment	The probability that operators fail to isolate locally a service water rupture in the RACS compartment was reduced to 0.1 from 1.0.	4	2	330K	930K	3.07M
8 – Convert Selected Fire Protection Piping from Wet to Dry Pipe System	The probability that operators fail to isolate a fire protection header leak was reduced to 0.1 from 1.0.	4	1	300K	860K	600K

Table G-6. SAMA Cost/Benefit Screening Analysis for HCGS^(a)

SAMA	Assumptions	% Risk Reduction		Total Benefit (\$)		Cost (\$)
		CDF	Population Dose	Baseline (Internal + External)	Baseline With Uncertainty ^(e)	
10 – Provide Procedural Guidance to use B.5.b Low Pressure Pump for Non-Security Events	The probability that operators fail to align residual heat removal service water (RHRSW) for injection into the reactor pressure vessel (RPV) was reduced to 1.0E-02 from 1.0E-01.	1	1	200K	570K	100K
15 – Alternate Design of Core Spray System (CSS) Suction Strainer to Mitigate Plugging	The probability that operators fail to locally open each of the service water valves was reduced to 8.36E-04 from 8.36E-03.	2	1	130K	360K	1.0M
16 – Use of Different Designs for Switchgear Room Cooling Fans	The probability that FANS AVH401 through DVH400 fail-to-start and fail-to-run was set to 0.	2	1	130K	370K	400K
17 – Replace a Supply Fan with a Different Design in Service Water Pump Room	The probability that FANS AV503 through DV503 fail-to-start and fail-to-run was set to 0.	5	5	960K	2.7M	600K
18 – Replace a Return Fan with a Different Design in Service Water Pump Room	The probability that FANS AV504 through DV504 fail-to-start and fail-to-run was set to 0.	5	5	960K	2.7M	600K
30 – Provide Procedural Guidance for Partial Transfer of Control Functions from Control Room to the Remote Shutdown Panel	Reduce the fire CDF contribution from Fire Basic Events %IE-FIRE03, %IE-FIRE02, and %IE-FIRE01 by 90 percent.	NOT ESTIMATED		8.6M	24M	100K
31 – Install Improved Fire Barriers in the Main Control Room (MCR) Control Cabinets Containing the Primary Main Steam Isolation Valve (MSIV) Control Circuits	Eliminate the fire CDF contribution from Fire Basic Event %IE-FIRE06.	NOT ESTIMATED		360K	1.0M	1.2M

Table G-6. SAMA Cost/Benefit Screening Analysis for HCGS^(a)

SAMA	Assumptions	% Risk Reduction		Total Benefit (\$)		Cost (\$)
		CDF	Population Dose	Baseline (Internal + External)	Baseline With Uncertainty ^(e)	
32 – Install Additional Physical Barriers to Limit Dispersion of Fuel Oil from Diesel Generator (DG) Rooms	Reduce the fire CDF contribution from Fire Basic Event %IE-FIRE28 by 90 percent.	NOT ESTIMATED		480K	1.4M	800K
33 – Install Division II 480V AC Bus Cross-ties	Reduce the fire CDF contribution from Fire Basic Event %IE-FIRE37 by 90 percent.	NOT ESTIMATED		450K	1.3M	1.32M
34 – Install Division I 480V AC Bus Cross-ties	Reduce the fire CDF contribution from Fire Basic Event %IE-FIRE20 by 90 percent.	NOT ESTIMATED		430K	1.2M	1.32M
35 – Relocate, Minimize and/or Eliminate Electrical Heaters in Electrical Access Room	Reduce the fire CDF contribution from Fire Basic Event %IE-FIRE38 by 99 percent.	NOT ESTIMATED		410K ^(c)	1.2M ^(c)	270K
36 – Provide Procedural Guidance for Loss of All 1E 120V AC Power	Reduce the seismic CDF contribution from Seismic Basic Event %IE-SET36 by 50 percent.	NOT ESTIMATED		240K	680K	270K
37 – Reinforce 1E 120V AC Distribution Panels	Reduce the seismic CDF contribution from Seismic Basic Event %IE-SET36 by 90 percent.	NOT ESTIMATED		430K	1.2M	500K
39 – Provide Procedural Guidance to Bypass Reactor Core Isolation Cooling (RCIC) Turbine Exhaust Pressure Trip	As provided in response to an NRC staff RAI, modify fault tree to include a new operator action, having a failure probability of 1.0E-02, representing failure of the operator to defeat the HPCI/RCIC back pressure permissive .	10	<1	130K	380K	120K

Table G-6. SAMA Cost/Benefit Screening Analysis for HCGS^(a)

SAMA	Assumptions	% Risk Reduction		Total Benefit (\$)		Cost (\$)
		CDF	Population Dose	Baseline (Internal + External)	Baseline With Uncertainty ^(e)	
40 – Increase Reliability/Install Manual Bypass of Low Pressure (LP) Permissive	As provided in response to an NRC staff RAI, the probability of common cause mis-calibration of all ECCS pressure transmitters was reduced to 8.0E-06 from 8.0E-05.	1	1	210K	610K	620K
41 ^(d) – Installation of Passive Hardened Containment Ventilation Pathway	A completely passive containment vent system requiring no operator actions is assumed.	15	30	6.2M	18M	>25M
42 ^(d) – Installation of SACS Standby Diesel-Powered Pump	Reduce the probability of initiating event %IE-SACS to 1.16E-05 per year from 1.16E-04 per year.	2	1	270K	760K	6.2M

(a) SAMAs in bold are potentially cost-beneficial.

(b) SAMA 5A added as a sensitivity case to SAMA 5 to provide a comprehensive, long term mitigation strategy for SBO scenarios.

(c) SAMAs 30, 31, and 32 were identified and evaluated in response to an NRC staff RAI (PSEG 2010a). The RAI response stated that the percent risk reduction was developed using SGS PRA Model Version 4.3 and that the implementation costs for SAMAs 30 and 31 are expected to be significantly greater than the \$100K assumed in the SAMA evaluation.

(d) Value estimated by NRC staff using information provided in the ER.

(e) Using a factor of 2.5.

1 **G.5 Cost Impacts of Candidate Plant Improvements**

2
3 PSEG estimated the costs of implementing the 21 candidate SAMAs through the development
4 of site-specific cost estimates. The cost estimates conservatively did not include the cost of
5 replacement power during extended outages required to implement the modifications, nor did
6 they include contingency costs for unforeseen difficulties (PSEG 2010a). The cost estimates
7 provided in the ER did not account for inflation, which is considered another conservatism.

8 The NRC staff reviewed the bases for the applicant's cost estimates (presented in Table E.5-3
9 of Attachment E to the ER). For certain improvements, the NRC staff also compared the cost
10 estimates to estimates developed elsewhere for similar improvements, including estimates
11 developed as part of other licensees' analyses of SAMAs for operating reactors.

12
13 The ER stated that plant personnel developed HCGS-specific costs to implement each of the
14 SAMAs. The NRC staff requested more information on the process PSEG used to develop the
15 SAMA cost estimates (NRC 2010a). PSEG responded to the RAI by explaining that the cost
16 estimates were developed in a series of meetings involving personnel responsible for
17 development of the SAMA analysis and the two PSEG license renewal site leads who are
18 engineering managers each having over 25 years of plant experience, including project
19 management, operations, plant engineering, design engineering, procedure support, simulators,
20 and training (PSEG 2010a). During these meetings, each SAMA was validated against the
21 plant configuration, a budget-level estimate of its implementation cost was developed, and, in
22 some instances, lower cost approaches that would achieve the same objective were developed.
23 The SAMA implementation costs were then reviewed by the Design Engineering Manager for
24 both technical and cost perspectives and revised accordingly. PSEG further explained that
25 seven general cost categories were used in development of the budget-level cost estimates:
26 engineering, material, installation, licensing, critical path impact, simulator modification, and
27 procedures and training. Based on the use of personnel having significant nuclear plant
28 engineering and operating experience, the NRC staff considers the process PSEG used to
29 develop budget-level cost estimates reasonable.

30
31 The NRC staff requested additional clarification on the estimated cost of \$2.05M for
32 implementation of SAMA 5, "Restore AC Power with Onsite Gas Turbine Generator," and on the
33 implementation cost of \$270K for implementation of SAMA 36, "Provide Procedural Guidance
34 for Loss of All 1E 120V AC Power," which are high for what are described as procedure
35 changes and operator training (NRC 2010a). In response to an RAI, PSEG further described
36 the SAMA 5 modification as providing the necessary equipment to connect a dedicated
37 transformer at Salem Unit 3 to HCGS, which is significantly more costly than, and is in addition
38 to, the procedure changes (PSEG 2010a). It was also explained that the SAMA 5 modification
39 assumes that Salem Generating Station (SGS) SAMA 2 to install the dedicated transformer is
40 already implemented and that SAMA 5 is a safety-related permanent plant modification. In
41 response to a different RAI, PSEG explained that the SAMA 36 modification involves the

1 development of a group of procedures, not just the revision of existing procedures or the
2 development of a single procedure. In addition, there is a significant effort involved with
3 determining a success path to achieve safe shutdown, to update the simulator to include all
4 necessary components to implement the success path, to test the success path, and to
5 implement the new procedures. Based on this additional information, the NRC staff considers
6 the estimated cost to be reasonable and acceptable for purposes of the SAMA evaluation.
7

8 The NRC staff asked PSEG to justify the estimated cost of \$100K for SAMA 10, "Provide
9 Procedural Guidance to use B.5.b Low Pressure Pump for Non-Security Events," for what is
10 described as including a new pump when \$100K is the estimated cost of a procedure change
11 used in the SAMA analysis (NRC 2010a). PSEG responded that the cost estimate for SAMA 10
12 assumes that an existing pump already installed at HCGS will be made available to implement
13 this SAMA (PSEG 2010a). Based on this additional information, the NRC staff considers the
14 estimated cost to be reasonable and acceptable for purposes of the SAMA evaluation.
15

16 In response to an RAI requesting a more detailed description of the changes associated with
17 SAMA 16, "Use of Different Designs for Switchgear Room Cooling Fans," PSEG provided
18 additional information detailing the cost estimate of this improvement (PSEG 2010a). The staff
19 reviewed the cost estimate and found it to be reasonable, and generally consistent with
20 estimates provided in support of other plants' analyses.
21

22 The NRC staff noted that SAMA 31, "Install Improved Fire Barriers in the Main Control Room
23 (MCR) Control Cabinets Containing the Primary Main Steam Isolation Valve (MSIV) Control
24 Circuits," is similar to SGS SAMAs 21 and 22 in that each involves installing fire barriers to
25 prevent the propagation of a fire between cabinets and requested an explanation for why the
26 estimated cost of \$1.2M for SAMA 31 to modify one cabinet is similar to the estimated cost of
27 \$1.6M for SGS SAMA 22 to modify three Control Room consoles and is more than one-third of
28 the \$3.23M cost for SGS SAMA 21 to modify 48 Relay Room cabinets (NRC 2010a). PSEG
29 responded that making the modifications to the SAMA 31 Control Room console, which is
30 estimated to be \$400K for materials and installation, is more complicated than making
31 modifications to the SGS SAMA 21 Relay Room cabinets, which is estimated to be \$35K to
32 \$70K for materials and maintenance (PSEG 2010a). Specifically, SAMA 31 requires making
33 ventilation modifications due to the significant heat loads in addition to adding fire barrier
34 materials. PSEG also explained that both SAMA 31 and SGS SAMA 22 assumed the same
35 material and installation cost per console (\$400K) and the same engineering cost (\$800K) but
36 that the engineering cost was evenly divided between the two units at SGS to arrive at a cost
37 per unit. The NRC staff considers the basis for the differences in cost estimates reasonable.
38

39 The NRC staff noted that the estimated cost of \$620K for SAMA 40, "Increase Reliability/Install
40 Manual Bypass of Low Pressure (LP) Permissive," is significantly higher than the estimated cost
41 of \$250K for a similar improvement evaluated for the Duane Arnold nuclear power plant license
42 renewal application (NRC 2010a). In response to the RAI, PSEG clarified that SAMA 40

1 involves the installation of six key-lock switches to bypass various low pressure submissives
 2 (PSEG 2010a). Key-lock switches are used rather than jumpers, as was assumed in the Duane
 3 Arnold application, because the benefit of this SAMA cannot be obtained otherwise due to the
 4 effort required to install six jumpers, which is a more time intensive action than the time required
 5 to operate key-lock switches. Based on this additional information, the NRC staff considers the
 6 estimated cost for HCGS to be reasonable and acceptable for purposes of the SAMA
 7 evaluation.

8
 9 The NRC staff also noted that the estimated cost of \$1.32M each for SAMA 33, "Install Division
 10 II 480V AC Bus Cross-ties," and SAMA 34, "Install Division I 480V AC Bus Cross-ties," is
 11 significantly higher than the estimated cost of \$328K to \$656K for a similar improvement
 12 evaluated for other nuclear power plant license renewal applications, i.e., Wolf Creek and
 13 Susquehanna (NRC 2010a). In response to the RAI, PSEG described these modifications as
 14 involving the installation of new tie-breakers and cables for the 480V AC bus cross-ties, having
 15 a material and installation cost of \$400K (PSEG 2010a). The most significant cost was for
 16 engineering, which was estimated to be \$800K due to the electrical load analysis required to
 17 support the cross-ties. Based on this additional information, the NRC staff considers the basis
 18 for the estimated cost to be reasonable.

19
 20 The NRC staff concludes that the cost estimates provided by PSEG are sufficient and
 21 appropriate for use in the SAMA evaluation.

22 **G.6 Cost-Benefit Comparison**

23
 24 PSEG's cost-benefit analysis and the NRC staff's review are described in the following sections.

25 **G.6.1 PSEG's Evaluation**

26
 27
 28 The methodology used by PSEG was based primarily on NRC's guidance for performing cost-
 29 benefit analysis, i.e., NUREG/BR-0184, *Regulatory Analysis Technical Evaluation Handbook*
 30 (NRC 1997a). The guidance involves determining the net value for each SAMA according to
 31 the following formula:

32 Net Value = (APE + AOC + AOE + AOSC) – COE, where
 33 APE = present value of averted public exposure (\$)
 34 AOC = present value of averted offsite property damage costs (\$)
 35 AOE = present value of averted occupational exposure costs (\$)
 36 AOSC = present value of averted onsite costs (\$)
 37 COE = cost of enhancement (\$)

38
 39 If the net value of a SAMA is negative, the cost of implementing the SAMA is larger than the
 40 benefit associated with the SAMA and it is not considered cost-beneficial. PSEG's derivation of
 41 each of the associated costs is summarized below.

1 NUREG/BR-0058 has recently been revised to reflect the agency's policy on discount rates.
 2 Revision 4 of NUREG/BR-0058 states that two sets of estimates should be developed, one at
 3 3 percent and one at 7 percent (NRC 2004). PSEG performed the SAMA analysis using the
 4 3 percent discount rate and a sensitivity study using the 7 percent discount rate (PSEG 2009).

5 Averted Public Exposure (APE) Costs

6 The APE costs were calculated using the following formula:

$$\begin{aligned}
 7 \quad & \text{APE} = \text{Annual reduction in public exposure } (\Delta \text{person-rem/year}) \\
 8 \quad & \quad \times \text{monetary equivalent of unit dose } (\$2,000 \text{ per person-rem}) \\
 9 \quad & \quad \times \text{present value conversion factor } (15.04 \text{ based on a 20-year period with a} \\
 10 \quad & \quad \text{3-percent discount rate})
 \end{aligned}$$

11 As stated in NUREG/BR-0184 (NRC 1997a), it is important to note that the monetary value of
 12 the public health risk after discounting does not represent the expected reduction in public
 13 health risk due to a single accident. Rather, it is the present value of a stream of potential
 14 losses extending over the remaining lifetime (in this case, the renewal period) of the facility.
 15 Thus, it reflects the expected annual loss due to a single accident, the possibility that such an
 16 accident could occur at any time over the renewal period, and the effect of discounting these
 17 potential future losses to present value. For the purposes of initial screening, which assumes
 18 elimination of all severe accidents, PSEG calculated an APE of approximately \$688,000 for the
 19 20-year license renewal period.

20 Averted Offsite Property Damage Costs (AOC)

21 The AOCs were calculated using the following formula:

$$\begin{aligned}
 23 \quad & \text{AOC} = \text{Annual CDF reduction} \\
 24 \quad & \quad \times \text{offsite economic costs associated with a severe accident (on a per-event basis)} \\
 25 \quad & \quad \times \text{present value conversion factor.}
 \end{aligned}$$

26 This term represents the sum of the frequency-weighted offsite economic costs for each release
 27 category, as obtained for the Level 3 risk analysis. For the purposes of initial screening, which
 28 assumes elimination of all severe accidents caused by internal events, PSEG calculated an
 29 AOC of about \$155,000 based on the Level 3 risk analysis. This results in a discounted value of
 30 approximately \$2,332,000 for the 20-year license renewal period.

31 Averted Occupational Exposure (AOE) Costs

32 The AOE costs were calculated using the following formula:

$$\begin{aligned}
 34 \quad & \text{AOE} = \text{Annual CDF reduction} \\
 35 \quad & \quad \times \text{occupational exposure per core damage event} \\
 36 \quad & \quad \times \text{monetary equivalent of unit dose} \\
 37 \quad & \quad \times \text{present value conversion factor}
 \end{aligned}$$

1 PSEG derived the values for averted occupational exposure from information provided in
 2 Section 5.7.3 of the regulatory analysis handbook (NRC 1997a). Best estimate values provided
 3 for immediate occupational dose (3,300 person-rem) and long-term occupational dose (20,000
 4 person-rem over a 10-year cleanup period) were used. The present value of these doses was
 5 calculated using the equations provided in the handbook in conjunction with a monetary
 6 equivalent of unit dose of \$2,000 per person-rem, a real discount rate of 3 percent, and a time
 7 period of 20 years to represent the license renewal period. For the purposes of initial screening,
 8 which assumes elimination of all severe accidents caused by internal events, PSEG calculated
 9 an AOE of approximately \$2,700 for the 20-year license renewal period (PSEG 2009).

10 Averted Onsite Costs

11
 12 Averted onsite costs (AOSC) include averted cleanup and decontamination costs and averted
 13 power replacement costs. Repair and refurbishment costs are considered for recoverable
 14 accidents only and not for severe accidents. PSEG derived the values for AOSC based on
 15 information provided in Section 5.7.6 of NUREG/BR-0184, the regulatory analysis handbook
 16 (NRC 1997a).

17 PSEG divided this cost element into two parts – the onsite cleanup and decontamination cost,
 18 also commonly referred to as averted cleanup and decontamination costs (ACC), and the
 19 replacement power cost (RPC).

20 ACCs were calculated using the following formula:

$$\begin{aligned} 21 \quad \text{ACC} &= \text{Annual CDF reduction} \\ 22 &\quad \times \text{present value of cleanup costs per core damage event} \\ 23 &\quad \times \text{present value conversion factor} \end{aligned}$$

24
 25 The total cost of cleanup and decontamination subsequent to a severe accident is estimated in
 26 NUREG/BR-0184 to be 1.5×10^9 (undiscounted). This value was converted to present costs
 27 over a 10-year cleanup period and integrated over the term of the proposed license extension.
 28 For the purposes of initial screening, which assumes elimination of all severe accidents caused
 29 by internal events, PSEG calculated an ACC of approximately \$87,000 for the 20-year license
 30 renewal period.

31
 32 Long-term RPCs were calculated using the following formula:

$$\begin{aligned} 33 \quad \text{RPC} &= \text{Annual CDF reduction} \\ 34 &\quad \times \text{present value of replacement power for a single event} \\ 35 &\quad \times \text{factor to account for remaining service years for which replacement power is} \\ 36 &\quad \text{required} \\ 37 &\quad \times \text{reactor power scaling factor} \end{aligned}$$

38
 39
 40 PSEG based its calculations on a HCGS net output of 1287 megawatt electric (MWe) and
 41 scaled up from the 910 MWe reference plant in NUREG/BR-0184 (NRC 1997a). Therefore
 42 PSEG applied a power scaling factor of 1287/910 to determine the replacement power costs.
 43 For the purposes of initial screening, which assumes elimination of all severe accidents caused

1 by internal events, PSEG calculated an RPC of approximately \$35,000 and an AOSC of
2 approximately \$122,000 for the 20-year license renewal period.

3
4 Using the above equations, PSEG estimated the total present dollar value equivalent associated
5 with completely eliminating severe accidents from internal events at HCGS to be about \$3.14M.
6 Use of a multiplier of 6.3 to account for external events increases the value to \$19.8M and
7 represents the dollar value associated with completely eliminating all internal and external event
8 severe accident risk for a single unit at HCGS, also referred to as the Maximum Averted Cost
9 Risk (MACR).

10 PSEG's Results

11
12
13 If the implementation costs for a candidate SAMA exceeded the calculated benefit, the SAMA
14 was considered not to be cost-beneficial. In the baseline analysis contained in the ER (using a
15 3 percent discount rate, and considering the impact of external events), PSEG identified nine
16 potentially cost-beneficial SAMAs. PSEG performed additional analyses to evaluate the impact
17 of parameter choices (alternative discount rates and variations in MACCS2 input parameters)
18 and uncertainties on the results of the SAMA assessment and, as a result of this analysis,
19 identified four additional potentially cost-beneficial SAMAs.

20
21 The potentially cost-beneficial SAMAs are:

- 22 • SAMA 1 – remove ADS Inhibit from Non-ATWS Emergency Operating Procedures
- 23
- 24 • SAMA 3 – Install Back-Up Air Compressor to Supply AOVs
- 25
- 26 • SAMA 4 – Provide Procedural Guidance to Cross-Tie RHR Trains
- 27
- 28 • SAMA 8 – Convert Selected Fire Protection Piping from Wet to Dry Pipe System
- 29
- 30 • SAMA 10 – Provide Procedural Guidance to Use B.5.b Low Pressure Pump for Non-
Security Events
- 31
- 32 • SAMA 17 – Replace a Supply Fan with a Different Design in Service Water Pump Room
- 33
- 34 • SAMA 18 – Replace a Return Fan with a Different Design in Service Water Pump Room
- 35
- 36 • SAMA 30 – Provide Procedural Guidance for Partial Transfer of Control Functions from
the Control Room to the Remote Shutdown Panel
- 37
- 38 • SAMA 32 – Install Additional Physical Barriers to Limit Dispersion of Fuel Oil from DG
Rooms

- 1 • SAMA 35 – Relocate, Minimize, and/or Eliminate Electrical Heaters in Electrical Access
2 Room
- 3 • SAMA 36 – Provide Procedural Guidance for Loss of All 1E 120V AC Power
- 4 • SAMA 37 – Reinforce 1E 120V AC Distribution Panels
- 5 • SAMA 39 – Provide Procedural Guidance to Bypass RCIC Turbine Exhaust Pressure
6 Trip

7 PSEG indicated that they plan to further evaluate these SAMAs for possible implementation
8 using existing HCGS Plant Heal Committee processes (PSEG 2009).

9
10 The potentially cost-beneficial SAMAs, and PSEG's plans for further evaluation of these
11 SAMAs, are discussed in detail in Section G.6.2.

12 **G.6.2 Review of PSEG's Cost-Benefit Evaluation**

13
14
15 The cost-benefit analysis performed by PSEG was based primarily on NUREG/BR-0184
16 (NRC 1997a) and discount rate guidelines in NUREG/BR-0058 (NRC 2004) and was executed
17 consistent with this guidance.

18 SAMAs identified primarily on the basis of the internal events analysis could provide benefits in
19 certain external events, in addition to their benefits in internal events. To account for the
20 additional benefits in external events, PSEG multiplied the internal event benefits for each
21 internal event SAMA by a factor of 6.3, which is the ratio of the total CDF from internal and
22 external events to the internal event CDF. As discussed in Section G.2.2, this factor was based
23 on a seismic CDF of 1.1×10^{-6} per year, plus a fire CDF of 1.7×10^{-5} per year, plus the
24 screening values for high winds, external flooding, transportation, detritus, and chemical release
25 events (1×10^{-6} per year for each). The external event CDF of 2.3×10^{-5} per year is thus 5.3
26 times the internal events release frequency CDF of 4.4×10^{-6} per year. The total CDF is thus
27 $6.3 [(2.3 \times 10^{-5} + 4.4 \times 10^{-6}) / 4.4 \times 10^{-6}]$ times the internal events release frequency CDF (PSEG
28 2009). Seven SAMAs were determined to be cost-beneficial in PSEG's analysis (SAMAs 1, 3,
29 4, 10, 17, 18, and 39 as described above).

30 PSEG did not multiply the internal event benefits by the factor of 6.3 for eight SAMAs that
31 specifically address fire and seismic risk (SAMAs 30, 31, 32, 33, 34, 35, 36, and 37).
32 Multiplying the internal event benefits by 6.3 for these SAMAs would not be appropriate
33 because these SAMAs are specific to fire or seismic risks and would not have a corresponding
34 benefit on the risk from internal events. Two of these SAMAs were found to be cost-beneficial in
35 PSEG's analysis (SAMAs 30 and 35, as described above).

36 PSEG considered the impact that possible increases in benefits from analysis uncertainties
37 would have on the results of the SAMA assessment. In the ER, PSEG presents the results of

1 an uncertainty analysis of the internal events CDF which indicates that the 95th percentile value
2 is a factor of 2.84 times the point estimate CDF for HCGS. Since the two Phase I SAMAs that
3 were screened based on qualitative criteria were screened due to one being subsumed into
4 another SAMA or one having already been implemented at HCGS, a re-examination of the
5 Phase I SAMAs based on the upper bound benefits was not necessary. PSEG considered the
6 impact on the Phase II analysis if the estimated benefits were increased by a factor of 2.84 (in
7 addition to the multiplier of 6.3 for external events). Four additional SAMAs became cost-
8 beneficial in PSEG's analysis (SAMAs 8, 32, 36, and 37 as described above).

9 PSEG provided the results of additional sensitivity analyses in the ER, including use of a 7
10 percent discount rate and variations in MACCS2 input parameters. These analyses did not
11 identify any additional potentially cost-beneficial SAMAs (PSEG 2009).

12 PSEG indicated that the 13 potentially cost-beneficial SAMAs (SAMAs 1, 3, 4, 8, 10, 17, 18, 30,
13 32, 35, 36, 37, and 39) will be considered for implementation through the established HCGS
14 Plant Health Committee process (PSEG 2009).

15 As indicated in Section G.3.2, in response to NRC staff RAIs, PSEG considered additional plant
16 improvements to address basic events for which no SAMAs had been identified in the ER.
17 PSEG determined that of the plant improvements considered, two additional SAMAs warrant
18 further consideration: 1) SAMA 41, "Installation of Passive Hardened Containment Ventilation
19 Pathway," and 2) SAMA 42, "Installation of SACS Standby Diesel-Powered Pump." Each of
20 these new SAMAs is included in Table G-6 and were evaluated as described above. PSEG's
21 analysis determined that neither of these SAMA candidates was cost-beneficial in either the
22 baseline analysis or the uncertainty analysis.

23 As indicated in Section G.2.2, PSEG determined that the external events multiplier would be 6.8
24 if the higher seismic CDF obtained using the LLNL hazard curves were used rather than the
25 EPRI hazard curves. As discussed in Section G.3.2, PSEG then reviewed the Level 1 and
26 Level 2 basic events down to an RRW of 1.005 to account for the revised external events
27 multiplier of 6.8. In addition, since the maximum benefit of each seismic sequence increased as
28 a result of using the LLNL hazard curves, PSEG reviewed two additional seismic sequences
29 having a benefit equal to or greater than \$100,000, the minimum expected SAMA
30 implementation cost at HCGS. These reviews resulted in the identification and evaluation of
31 five additional SAMAs, as summarized below:

- 32 • SAMA RAI 5.j-IE1, "Install a Key Lock Switch for Bypass of the Main Steam Isolation
33 Valve (MSIV) Low Level Isolation Logic." PSEG estimated the implementation cost for
34 this SAMA to be the same as SAMA 40, "Increase Reliability/Install Manual Bypass of
35 Low Pressure (LP) Permissive," or \$620K, which also involved installation of key lock
36 bypass switches (PSEG 2010a). The maximum benefit was estimated to be \$110K in
37 the baseline analysis, and \$300K after accounting for uncertainties, which assumed that
38 the risk of the basic event addressed by this SAMA was completely eliminated. Since

1 the implementation cost was greater than the estimated benefit accounting for
2 uncertainties, PSEG concluded that SAMA RAI 5.j-IE1 was not cost-beneficial.

- 3 • SAMA RAI 5p-1, "Install an Independent Boron Injection System." PSEG estimated the
4 implementation cost of this SAMA to be \$1.5M based on the estimate for a similar SAMA
5 to install a redundant system evaluated in the Browns Ferry nuclear power plant license
6 renewal application and the estimated cost to install an additional tank (PSEG 2010a).
7 To estimate the risk reduction, PSEG modified the HCGS PRA model fault tree to
8 include a new basic event, having a failure probability of 1.0E-03, representing failure of
9 the redundant system. The benefit was estimated to be \$390K in the baseline analysis,
10 and \$1.1M after accounting for uncertainties. Since the implementation cost was greater
11 than the estimated benefit accounting for uncertainties, PSEG concluded that SAMA RAI
12 5p-1 was not cost-beneficial.
- 13 • Reinforce 1E 125V DC distribution panels 1A/B/C/D-D-417. PSEG estimated the
14 minimum implementation cost for this SAMA to be the same as SAMA 37, "Reinforce 1E
15 120V AC Distribution Panels," or \$500K, but expects the cost to be higher because
16 these panels have a much higher HCLPF value than the SAMA 37 120V AC panels
17 (PSEG 2010a). To estimate the risk reduction, PSEG assumed that the contribution to
18 risk from external events is approximately 5.8 times that from internal events (based on
19 a revised seismic CDF of 3.58×10^{-6} per year using the LLNL hazard curves), that
20 seismic events contribute 14 percent of this external events risk, and that 50 percent of
21 the fire risk affected by the SAMA is eliminated. The benefit was estimated to be \$155K
22 in the baseline analysis, and \$440K after accounting for uncertainties. Since the
23 implementation cost was greater than the estimated benefit accounting for uncertainties,
24 PSEG concluded that this SAMA was not cost-beneficial.
- 25 • Reinforce 1E 120V AC distribution panels 1A/B/C/DJ482. PSEG estimated the
26 implementation cost for this SAMA to be the same as SAMA 37, or \$500K, which also
27 addresses 120V AC panels (PSEG 2010a). To estimate the risk reduction, PSEG
28 assumed that the contribution to risk from external events is approximately 5.8 times that
29 from internal events (based on a revised seismic CDF of 3.58×10^{-6} per year using the
30 LLNL hazard curves), that seismic events contribute 14 percent of this external events
31 risk, and that all of the seismic risk affected by the SAMA is eliminated. The benefit was
32 estimated to be \$110K in the baseline analysis, and \$320K after accounting for
33 uncertainties. Since the implementation cost was greater than the estimated benefit
34 accounting for uncertainties, PSEG concluded that this SAMA was not cost-beneficial.
- 35 • Reinforce 1E 120V AC distribution panels to 1.0g Seismic Rating. This SAMA assumes
36 that 1) SAMA 37 is implemented, 2) the HCLPF values for the 120V AC panels are
37 further increased to 1 g as a result of the implementation, 3) the above SAMA to
38 reinforce the 125V DC panels is implemented, and 4) the HCLPF values for the panels
39 are increased from the current 0.57g to 1.0g as a result of the implementation (PSEG

1 2010b). SAMA 37 originally was assumed to reduce the risk of seismic basic event %IE-
2 SET36, "seismic-induced equipment damage state SET-36 (impacts – 120V PNL481,"
3 by 90 percent while the proposed SAMA to reinforce the 125V DC panels, by itself was
4 originally assumed to reduce the risk of seismic basic event %IE-SET37, seismic-
5 induced equipment damage state (impacts – 125V)," by 50 percent. The synergistic
6 benefit of this new proposed SAMA to reinforce the 120V AC panels to a HCLPF value
7 of 1.0g is assumed to be the sum of the benefit to eliminate the remaining 10 percent of
8 the risk of event %IE-SET36 (\$176K) and the remaining 50 percent of the risk of event
9 %IE-SET37 (\$155K), for a total benefit of \$330K in the baseline analysis, and \$940K
10 after accounting for uncertainties. PSEG estimated the implementation cost for this
11 SAMA to be \$900K, which assumes the panels can be modified and not have to be
12 replaced. Since the estimated benefit is greater than the implementation cost, PSEG
13 determined that this proposed SAMA was potentially cost-beneficial. PSEG stated that
14 this proposed SAMA will be considered for implementation through the established
15 HCGS Plant Health Committee process.

16 The NRC staff notes that SAMA 37 was determined to be cost-beneficial and will be
17 considered by PSEG for implementation through the established HCGS Plant Health
18 Committee process. PSEG concluded, however, that the above originally proposed
19 SAMA to reinforce the 125V DC panels was, by itself, not cost-beneficial, yet it was
20 assumed to be implemented in the evaluation of this new proposed combined SAMA.
21 Because the risk reduction from this new proposed SAMA to reinforce the 120V AC
22 panels to a HCLPF value of 1.0g cannot be obtained without implementation of the
23 proposed SAMA to reinforce the 125V DC panels, the NRC staff concludes that both
24 SAMAs (SAMA 37 and the combined SAMA of reinforcing both the 120 VAC and 125
25 VDC panels) should be considered for implementation.

26 As indicated in Section G.3.2, two plant improvements were identified in the ER but not included
27 in the SAMA evaluation because they were higher cost than the SAMA selected for evaluation.
28 The NRC staff noted however that the two improvements could have larger benefits than the
29 SAMAs evaluated because they could be more effective or could mitigate additional events
30 (PSEG 2010a). In response to the RAIs, PSEG evaluated the two improvements, as
31 summarized below:

- 32 • Replace the normally open floor and equipment drain MOVs with fail-closed AOVs.
33 PSEG estimated the implementation cost of this SAMA to be \$2.05M, which is half the
34 estimate for a similar SAMA to replace cooling water system MOVs, which are larger
35 than drain MOVs, with fail-closed AOVs evaluated in the TMI-1 nuclear power plant
36 license renewal application (PSEG 2010a). To estimate the risk reduction, PSEG
37 assumed that the entire release frequency associated with basic event CIS-DRAN-L2-
38 OPEN, "valves open automatically for drainage normally open," after adjustment to
39 account for existing procedures that are not credited, was eliminated. The benefit,
40 assuming an external multiplier of 6.8, was estimated to be \$710K in the baseline

1 analysis, and \$2.0M after accounting for uncertainties. Since the implementation cost
2 was greater than the estimated benefit accounting for uncertainties, PSEG concluded
3 the proposed improvement was not cost-beneficial.

- 4 • Auto align 480V AC portable station generator. For HCGS, this improvement is
5 described as requiring permanent installation of an existing portable generator and
6 adding the logic to perform the auto start and load function. PSEG estimated the
7 implementation cost of this SAMA to be at least \$1.0M based on an estimate of \$1.0M
8 from the Shearon Harris nuclear power plant license renewal application to permanently
9 install a 480V AC generator and pump and an estimate of \$3.1M from the TMI-1 nuclear
10 power plant license renewal application to automate the start and load of an existing,
11 permanently installed 4KV AC generator (PSEG 2010a, PSEG 2010b). To estimate the
12 risk reduction, PSEG set the failure probabilities of existing operator actions to align the
13 portable generator, and associated joint human error probabilities, to zero. The benefit,
14 assuming an external multiplier of 6.8, was estimated to be \$210K in the baseline
15 analysis, and \$600K after accounting for uncertainties. Since the implementation cost
16 was greater than the estimated benefit accounting for uncertainties, PSEG concluded
17 the proposed improvement was not cost-beneficial.

18 As indicated in Section G.3.2, for certain SAMAs considered in the ER, there may be
19 alternatives that could achieve much of the risk reduction at a lower cost. The NRC staff asked
20 the applicant to evaluate additional lower cost alternatives to the SAMAs considered in the ER,
21 as summarized below (NRC 2010a):

- 22 • Establishing procedures for opening doors and/or using portable fans for sequences
23 involving room cooling failures. In response to the NRC staff RAI, PSEG stated that
24 HCGS already has procedures to implement the suggested alternative on loss of normal
25 Switchgear Room HVAC and that this event is credited in the PRA model (PSEG
26 2010a). However, PSEG did provide an evaluation to implement the suggested
27 alternative in the Service Water Pump Room, which is considered a more practical and
28 cost effective change than SAMA 17, "Replace a Supply Fan with a Different Design in
29 Service Water Pump Room," and SAMA 18, "Replace a Return Fan with a Different
30 Design in Service Water Pump Room," which involve permanent hardware
31 modifications. The cost of implementing an alternate room cooling strategy for this
32 room, identified as SAMA RAI 7.a-1, was estimated to be \$150K. The baseline benefit
33 was assumed to be the sum of the estimated benefits for SAMAs 17 and 18, or \$1.9M.
34 Accounting for the revised multiplier of 6.8 and uncertainties increases the benefit to
35 \$5.9M. Since the estimated benefit is greater than the implementation cost, PSEG
36 determined that SAMA RAI 7.a-1 was potentially cost-beneficial. PSEG also stated that
37 this SAMA will be further evaluated in parallel with cost-beneficial SAMAs 17 and 18
38 since there may be some benefit associated with the permanent hardware modifications
39 considered in these SAMAs.

- 1 • Extending the procedure for using the B.5.b low pressure pump for non-security events
2 to include all applicable scenarios, not just SBOs. In response to the NRC staff RAI,
3 PSEG stated that the estimated benefit for SAMA 10, "Provide Procedural Guidance to
4 use B.5.b Low Pressure Pump for Non-Security Events," already includes the risk
5 reduction for all applicable scenarios (PSEG 2010a). The NRC staff concludes that the
6 suggested alternative has already been addressed.
- 7 • Utilizing a portable independently powered pump to inject into containment. In response
8 to the NRC staff RAI, PSEG explained that the HCGS PRA model already credits use of
9 the diesel fire pump to inject into the RPV and containment and that the addition of
10 another independently powered pump to provide injection would have limited benefit
11 (PSEG 2010a). PSEG further noted that SAMA 10 already evaluated aligning the B.5.b
12 low pressure pump with RHRSW to provide an alternate source of injection. The NRC
13 staff concludes that the suggested alternative has already been addressed.
- 14 As indicated in Section G.4, the NRC staff questioned PSEG on the risk reduction potential for
15 certain SAMAs (NRC 2010a, NRC 2010b), as summarized below.
- 16 • For SAMA 5, "Restore AC Power with Onsite Gas Turbine Generator," PSEG provided a
17 revised estimate of the benefit that included credit for the additional capability for
18 mitigating a more complete set of loss of offsite power initiators that is consistent with
19 the hardware changes proposed (PSEG 2010a, PSEG 2010b). This SAMA was
20 determined to be potentially cost-beneficial in PSEG's revised analysis. PSEG stated
21 that SAMA 5 will be considered for implementation through the established HCGS Plant
22 Health Committee process.
- 23 • For SAMA 35, "Relocate, Minimize and/or Eliminate Electrical Heaters in Electrical
24 Access Room", PSEG provided a revised estimate of the benefit assuming 99 percent of
25 the fire risk affected by the SAMA was eliminated (PSEG 2010a). This SAMA was
26 determined to remain cost-beneficial in PSEG's revised analysis.

27 The NRC staff notes that the 13 cost-beneficial SAMAs (SAMAs 1, 3, 4, 8, 10, 17, 18, 30, 32,
28 35, 36, 37, and 39) identified in PSEG's original baseline and uncertainty analysis, and the three
29 SAMAs and plant improvements determined to be cost-beneficial in response to NRC staff RAIs
30 ("establishing procedures for opening doors and/or using portable fans for sequences involving
31 Service Water Pump Room cooling failures," SAMA 5, and "reinforce 1E 120V AC distribution
32 panels to 1.0g Seismic Rating"), are included within the set of SAMAs that PSEG plans to
33 further consider for implementation through the established Salem Plant Health Committee
34 (PHC) process. The NRC staff suggests that the proposed SAMA to "reinforce the 120V DC
35 panels" also be considered for implementation since it must be implemented to obtain the risk
36 reduction benefits of the SAMA to "reinforce 1E 120V AC distribution panels to 1.0g Seismic
37 Rating."

1 In response to an NRC staff RAI, PSEG described the PHC as being chaired by the Plant
2 Manager and includes as members the Plant Engineering Manager and the Directors of
3 Operations, Engineering, Maintenance, and Work Management (PSEG 2010a). The PHC is
4 chartered with reviewing issues that require special plant management attention to ensure
5 effective resolution and, with respect to each of the potentially cost-beneficial SAMAs, will
6 decide on one of the following courses of actions: 1) approve for implementation, 2)
7 conditionally approved for implementation pending the results of requested evaluations, 3) not
8 approved for implementation, or 4) table until additional information needed to make a final
9 decision is provided to the PHC. Additional information requested may include 1) making
10 corrections to the original SAMA analysis, 2) examining an alternate solution, 3) performing
11 sensitivity studies to determine the effect of implementing a sub-set of SAMAs, already
12 approved SAMAs, or already approved non-SAMA design changes on the SAMA, or 4)
13 coordinating the SAMA with related Mitigating System Performance Index (MSPI) margin
14 recovery activities. If approved or conditionally approved for implementation, the SAMA will be
15 ranked with respect to priority and assigned target years for implementation.

16 The NRC staff concludes that, with the exception of the potentially cost-beneficial SAMAs
17 discussed above, the costs of the other SAMAs evaluated would be higher than the associated
18 benefits.

19 **G.7 Conclusions**

20
21 PSEG compiled a list of 23 SAMAs based on a review of: the most significant basic events from
22 the plant-specific PRA and insights from the HCGS PRA group, insights from the plant-specific
23 IPE and IPEEE, Phase II SAMAs from license renewal applications for other plants, and the
24 generic SAMA candidates from NEI 05-01. A qualitative screening removed SAMA candidates
25 that: (1) are not applicable to HCGS due to design differences, (2) have already been
26 implemented at HCGS, (3) would achieve results that have already been achieved at HCGS by
27 other means, and (4) have estimated implementation costs that would exceed the dollar value
28 associated with completely eliminating all severe accident risk at HCGS. Based on this
29 screening, 2 SAMAs were eliminated leaving 21 candidate SAMAs for evaluation. Nine
30 additional SAMA candidates or plant improvements were identified and evaluated in response to
31 NRC staff RAIs.

32 For the remaining 21 SAMA candidates, a more detailed design and cost estimate were
33 developed as shown in Table G-6. The cost-benefit analyses in the ER and RAI response
34 showed that 9 of the SAMA candidates were potentially cost-beneficial in the baseline analysis
35 (Phase II SAMAs 1, 3, 4, 10, 17, 18, 30, 35, and 39). PSEG performed additional analyses to
36 evaluate the impact of parameter choices and uncertainties on the results of the SAMA
37 assessment. Four additional SAMA candidates (SAMAs 8, 32, 36, and 37) were identified as
38 potentially cost-beneficial in the ER. In response to an NRC staff RAI regarding the
39 assumptions used to estimate the risk reduction potential of certain SAMAs, PSEG identified
40 one additional potentially cost-beneficial SAMA (SAMA 5). In response to NRC staff RAIs
41 regarding the seismic CDF and potential lower cost alternatives, PSEG further identified
42 "establishing procedures for opening doors and/or using portable fans for sequences involving

1 Service Water Pump Room cooling failures” and “reinforce 1E 120V AC distribution panels to
2 1.0g Seismic Rating” as being potentially cost-beneficial enhancements. PSEG has indicated
3 that all 14 potentially cost-beneficial SAMAs, as well as the enhancements “establishing
4 procedures for opening doors and/or using portable fans for sequences involving Service Water
5 Pump Room cooling failures” and “reinforce 1E 120V AC distribution panels to 1.0g Seismic
6 Rating,” will be considered for implementation through the established HCGS Plant Health
7 Committee process. In addition, it is suggested that the plant improvement to “reinforce the
8 120V DC panels” be included in the set of SAMAs to be considered for implementation since it
9 must be implemented to obtain the risk reduction benefits of the plant improvement to “reinforce
10 1E 120V AC distribution panels to 1.0g Seismic Rating.”

11 The NRC staff reviewed the PSEG analysis and concludes that the methods used and the
12 implementation of those methods was sound. The treatment of SAMA benefits and costs
13 support the general conclusion that the SAMA evaluations performed by PSEG are reasonable
14 and sufficient for the license renewal submittal. Although the treatment of SAMAs for external
15 events was somewhat limited, the likelihood of there being cost-beneficial enhancements in this
16 area was minimized by improvements that have been realized as a result of the IPEEE process,
17 and inclusion of a multiplier to account for external events.

18 The NRC staff concurs with PSEG’s identification of areas in which risk can be further reduced
19 in a cost-beneficial manner through the implementation of the identified, potentially cost-
20 beneficial SAMAs. Given the potential for cost-beneficial risk reduction, the NRC staff agrees
21 that further evaluation of these SAMAs by PSEG is warranted. However, these SAMAs do not
22 relate to adequately managing the effects of aging during the period of extended operation.
23 Therefore, they need not be implemented as part of license renewal pursuant to Title 10 of the
24 *Code of Federal Regulations*, Part 54.

25 **G.8 References**

- 26
27 American Society of Mechanical Engineers (ASME). 2005. “Addenda to ASME RA-S-2002,
28 Standard for Probabilistic Risk Assessment for Nuclear Power Plant Applications.” ASME RA-
29 Sb-2005, December 2005.
- 30 BEA (Bureau of Economic Analysis). 2008. Regional Economic Accounts, accessed June 20 at
31 <http://www.bea.gov/regional/reis/>.
- 32 Electric Power Research Institute (EPRI). 1989. “Probabilistic Seismic Hazard Evaluations at
33 Nuclear Plant Sites in the Central and Eastern United States; Resolution of the Charleston
34 Earthquake Issues.” EPRI NP-6395-D, EPRI Project P101-53. Palo Alto, CA. April 1989.
- 35 Electric Power Research Institute (EPRI). 1991. “A Methodology for Assessment of Nuclear
36 Power Plant Seismic Margin,” EPRI NP-6041. Palo Alto, CA. August 1991.
- 37 Electric Power Research Institute (EPRI). 1993. “Fire Induced Vulnerability Evaluation (FIVE)
38 Methodology.” TR-100370, Revision 1, Palo Alto, CA. September 19, 1993.
- 39 KLD Associates, Inc. (KLD). 2004. *Salem / Hope Creek Nuclear Generating Stations*
40 *Development of Evacuation Time Estimates*. KLD TR-356. February 2004.
- 41 Nuclear Energy Institute (NEI). 2005. “Severe Accident Mitigation Alternative (SAMA) Analysis
42 Guidance Document.” NEI 05-01 (Rev. A), Washington, D.C. November 2005.

- 1 Nuclear Energy Institute (NEI). 2007. "Process for Performing Follow-on PRA Peer Reviews
2 using the ASME PRA Standard (Internal Events)." NEI 05-04, Rev. 1, Washington, D.C.
3 December 2007.
- 4 Public Service Electric and Gas Company (PSEG). 1994. "Hope Creek Generating Station.
5 Individual Plant Examination." April 1994. Accessible at ML080160331.
- 6 Public Service Electric and Gas Company. (PSEG). 1997. "Hope Creek Generating Station
7 Individual Plant Examination of External Events (IPEEE) for Severe Accident Vulnerabilities."
8 July 1997. Accessible at ML080160320.
- 9 Public Service Electric and Gas Company (PSEG). 2005. Letter from George P. Barnes,
10 PSEG, to NRC Document Control Desk. Subject: "Request for License Amendment Extended
11 Power Uprate Hope Creek Generating Station Facility Operating License NPF-57 Docket No:
12 50-354," Hancocks Bridge, New Jersey. Nov. 7, 2005. Accessible at ML053200202.
- 13 PSEG Nuclear, LLC (PSEG). 2009. *Hope Creek Generating Station - License Renewal*
14 *Application, Applicant's Environmental Report, Operating License Renewal Stage*, August 2009.
15 Accessible at ML092430484.
- 16 PSEG Nuclear, LLC (PSEG). 2010a. Letter from Paul J. Davison, PSEG, to NRC Document
17 Control Desk. Subject: "Response to NRC Request for Additional Information dated April 20,
18 2010, related to the Severe Accident Mitigation Alternatives (SAMA) review associated with the
19 Hope Creek Generating Station License Renewal Application," Hancocks Bridge, New Jersey.
20 June 1, 2010. Accessible at ML101550149.
- 21 PSEG Nuclear, LLC (PSEG). 2010b. Letter from Christine T. Neely, PSEG, to NRC Document
22 Control Desk. Subject: "Supplement to RAI responses submitted in PSEG Letter LR-N10-0181
23 dated June 1, 2010, related to the Severe Accident Mitigation Alternatives (SAMA) review of the
24 Hope Creek Generating Station," Hancocks Bridge, New Jersey. August 18, 2010. Accessible
25 at ML102320212.
- 26 U.S. Department of Agriculture (USDA). 2002. "2002 Census of Agriculture - Volume 1,
27 Geographic Area Series, Part 8 (Delaware), Part 20 (Maryland), Part 30.
- 28 U.S. Nuclear Regulatory Commission (NRC). 1988. Generic Letter 88-20, "Individual Plant
29 Examination for Severe Accident Vulnerabilities." November 23, 1988.
- 30 U.S. Nuclear Regulatory Commission (NRC). 1990. *Severe Accident Risks: An Assessment*
31 *for Five U.S. Nuclear Power Plants*. NUREG-1150. Washington, D.C.
- 32 U.S. Nuclear Regulatory Commission (NRC). 1991b. "Procedural and Submittal Guidance for
33 the Individual Plant Examination of External Events (IPEEE) for Severe Accident
34 Vulnerabilities." NUREG-1407. Washington, D.C. May 1991.
- 35 U.S. Nuclear Regulatory Commission (NRC). 1991a. "Individual Plant Examination of External
36 Events (IPEEE) for Severe Accident Vulnerabilities." Generic Letter No. 88-20, Supplement 4.
37 Washington, D.C. June 28, 1991.
- 38 U.S. Nuclear Regulatory Commission (NRC). 1994. *Revised Livermore Seismic Hazard*
39 *Estimates for Sixty-Nine Nuclear Plant Sites East of the Rocky Mountains*. NUREG-1488, April
40 1994. Washington, D.C.

- 1 U.S. Nuclear Regulatory Commission (NRC). 1996. Letter from David H. Jaffe, U.S. NRC, to
2 Leon R. Eliason, PSEG. Subject: "NRC Staff's Evaluation of the Individual Plant Examination
3 (IPE) Submittal (NLR-N94070) Hope Creek Generating Station (TAC No. M74421)." April 23,
4 1996.
- 5 U.S. Nuclear Regulatory Commission (NRC). 1997a. *Regulatory Analysis Technical Evaluation*
6 *Handbook*. NUREG/BR-0184. Washington, D.C.
- 7 U.S. Nuclear Regulatory Commission (NRC). 1997b. *Individual Plant Examination Program:*
8 *Perspectives on Reactor Safety and Plant Performance*. NUREG-1560. Washington, D.C.
- 9 U.S. Nuclear Regulatory Commission (NRC). 1998. *Code Manual for MACCS2: User's-Guide*.
10 NUREG/CR-6613, Volume 1, May 1998. Washington, D.C.
- 11 U.S. Nuclear Regulatory Commission (NRC). 1999. Letter from Richard B. Ennis, U.S. NRC, to
12 Harold W. Keiser, PSEG. Subject: "Review of Individual Plant Examination of External Events
13 (IPEEE) Submittal for Hope Creek Generating Station (TAC No. M83630)". April 26, 1999.
- 14 U.S. Nuclear Regulatory Commission (NRC). 2003. *SECPOP2000: Sector Population, Land*
15 *Fraction, and Economic Estimation Program*. NUREG/CR-6525, Rev. 1. Sandia National
16 Laboratories. August 2003
- 17 U.S. Nuclear Regulatory Commission (NRC). 2004. *Regulatory Analysis Guidelines of the U.S.*
18 *Nuclear Regulatory Commission*. NUREG/BR-0058, Rev. 4. Washington, D.C.
- 19 U.S. Nuclear Regulatory Commission (NRC). 2007. "An Approach for Determining the
20 Technical Adequacy of Probabilistic Risk Assessment Results for Risk-Informed Activities."
21 Regulatory Guide 1.200, Revision 1. January 2007.
- 22 U.S. Nuclear Regulatory Commission (NRC). 2009. *Guidance on the Treatment of*
23 *Uncertainties Associated with PRAs in Risk-Informed Decision Making*. NUREG-1855,
24 Washington, D.C.
- 25 U.S. Nuclear Regulatory Commission (NRC). 2010a. Letter from Charles Eccleston, U.S. NRC,
26 to Thomas Joyce, PSEG. Subject: Revised Request for Additional Information Regarding
27 Severe Accident Mitigation Alternatives for Hope Creek Generating Station. May 20, 2010.
28 Accessible at ML101310058.
- 29 U.S. Nuclear Regulatory Commission (NRC). 2010b. Subject: Summary of Telephone
30 Conference Held on July 29, 2010 between the U.S. Nuclear Regulatory Commission and
31 PSEG Nuclear LLC, Concerning Follow-up Questions Pertaining to the Salem Nuclear
32 Generating Station, Units 1 and 2, and Hope Creek Generating Stations License Renewal
33 Environmental Review. August 13, 2010. Accessible at ML102220012.
- 34