VIRGINIA ELECTRIC AND POWER COMPANY RICHMOND, VIRGINIA 23261

10 CFR 50.54(f)

December 15, 2011

U.S. Nuclear Regulatory Commission

Attention: Document Control Desk

11555 Rockville Pike Rockville, Maryland 20852 Serial No.:

11-664

NL&OS/GDM

R0

Docket Nos.: License Nos.: 50-280/281 DPR-32/37

VIRGINIA ELECTRIC AND POWER COMPANY (DOMINION)
SURRY POWER STATION (SPS) UNITS 1 AND 2
NRC BULLETIN 2011-01 MITIGATING STRATEGIES
RESPONSE TO REQUEST FOR ADDITIONAL INFORMATION

On May 11, 2011, the U.S. Nuclear Regulatory Commission (NRC) issued Bulletin 2011-01, "Mitigating Strategies". The bulletin requested two separate licensee submittals in response to the Bulletin as follows: 1) within 30-days from the date of the Bulletin confirm continued compliance with 10 CFR 50.54(hh)(2), and 2) within 60-days from the date of the Bulletin provide requested information associated with their mitigation strategies programs for 10 CFR 50.54(hh)(2). The Dominion 30-day and 60-day responses for Surry Power Station (SPS) Units 1 and 2 were submitted to the NRC on June 10, 2011 (Serial No. 11-290D) and July 8, 2011 (Serial No. 11-290H), respectively. By letter dated November 17, 2011 the NRC requested additional information describing how SPS ensures the availability of air bottles used to manually depressurize the steam generators. This is accomplished every refueling outage by aligning the manual system and cycling each of the steam generator pressure operated relief valves (PORVs) fully open then fully closed. The air bottles are isolated after the test.

If there are any questions concerning this letter, please contact Mr. Gary D. Miller at (804) 273-2771.

Sincerely.

Gerald T. Bischof Site Vice President

COMMONWEALTH OF VIRGINIA

COUNTY OF SURRY

The foregoing document was acknowledged before me, in and for the County and Commonwealth aforesaid, today by Gerald T. Bischof, who is Site Vice President – Surry Power Station Units 1 and 2, of Virginia Electric and Power Company. He has affirmed before me that he is duly authorized to execute and file the foregoing document in behalf of that Company, and that the statements in the document are true to the best of his knowledge and belief.

Acknowledged before me this 15th

day of HOLMOLY, 2011.

My Commission Expires:

Noton, Publid

Notary Publid

Notary Public
Commonwealth of Virginia
My Commission Expires October 31, 2015
Commission ID# 150293

HILL

Commitments made by this letter: None.

cc: U.S. Nuclear Regulatory Commission – Region II Marquis One Tower, NE Suite 1200 Atlanta, Georgia 30303-1257

NRC Senior Resident Inspector Surry Power Station

K. R. Cotton NRC Project Manager U. S. Nuclear Regulatory Commission One White Flint North Mail Stop 08 G-9A 11555 Rockville Pike Rockville, MD 20852-2738