

RAIs on Capsule Withdrawal Schedule Approval Request (ME7615)

**RAI - 01**

**Issue:** The ASTM E 185-70 standard practice describes the withdrawal schedule in terms of the target fluence. The requested revision is written in terms of effective full power years (EFPY) instead of target fluence.

**Request:** Describe the withdrawal schedule (mark-up of FSARU Table 5.2-22) in terms of the fast neutron fluence ( $E > 1\text{MeV}$ ).

**RAI - 02**

Provide a list of all materials included in Capsule B that the licensee plans to withdraw during the 23<sup>rd</sup> refueling outage for Unit 1 along with the participating integrated surveillance program plant that will use the test results.