

COMBUSTION ENGINEERING, INC.  
ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

NUMBER 5-218-P | A178

SHEET 6 OF 80

CHARGE NO. \_\_\_\_\_

DATE 4-22-68 BY CEPP/LL


DESCRIPTION STRUCTURAL AND FATIGUE EVALUATION  
OF OUTLET NOZZLE - VESSEL SUMMITS

CHECK DATE 4-22-68 BY HEILNER

5. DETAILED ANALYSIS:

1. SYSTEM GEOMETRY:

NOZZLE MATL. SA-336 Gr F1  
PIPING MATL. SA-182-F316



## COMBUSTION ENGINEERING, INC.

ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

NUMBER 5-712-P | A179SHEET 7 OF 82DATE 4-27-68 BY D. CARROLLCHARGE NO. \_\_\_\_\_  
DESCRIPTION STRUCTURAL AND FATIGUE EVALUATION  
OF DUCT NOZZLE - VESSEL SUPPORTS CHECK DATE 1-22-69 BY HEILGER5. DETAILED ANALYSIS:b. SYSTEM ALLOWABLES:

1. THE STRESS INTENSITY IN THE REINFORCEMENT PORTION OF THE NOZZLE RESULTING FROM DESIGN PRESSURE AND FROM EXTERNAL LOAD OR MOMENT SHALL NOT EXCEED  $S_m$  AT DESIGN TEMP.
2. THE STRESS INTENSITY DERIVED FROM THE AVERAGE PRIMARY PLUS THE LOCAL PRIMARY STRESS SHALL NOT EXCEED  $1.5 S_m$  AT DESIGN TEMP.
3. THE STRESS INTENSITY AROUND THE NOZZLE TO SHELL JUNCTURE RESULTING FROM INTERNAL PRESSURE, PIPE LOADS, WEIGHT OF VESSEL AND REACTIONS FROM EXTERNAL LOADS SHALL NOT EXCEED  $1.5 S_m$  AT DESIGN TEMP.
4. THE STRESS INTENSITY IN THE NOZZLE OUTSIDE OF THE REINFORCEMENT PORTION OF THE NOZZLE AND THE SAFE END RESULTING FROM DESIGN PRESSURE AND FROM DESIGN SEISMIC LOAD OR MOMENT SHALL NOT EXCEED  $1.5 S_m$  AT DESIGN TEMP.
5. THE RANGE OF PRIMARY PLUS SECONDARY STRESS INTENSITY RESULTING FROM MECHANICAL OR THERMAL LOADS SHALL NOT EXCEED  $3 S_m$  AT OPERATING PRESSURE AND TEMP.
6. SHOW THAT EACH POINT MEETS THE REQUIREMENTS FOR PEAK STRESS INTENSITY GIVEN IN N-414.5 OF THE ASME CODE. THE PROCEDURE WILL BE AS OUTLINED IN N-415.2 OF SECT. III.

NOTE THAT FOR THE CONSIDERATION OF "NO LOSS OF FUNCTION" SEISMIC NOZZLE LOADS, THE ABOVE ALLOWABLES (WHERE APPLICABLE) WILL BE INCREASED BY A FACTOR OF 1.2.

## COMBUSTION ENGINEERING, INC.

ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

NUMBER 5-212-P

A180

SHEET 8 OF 80

CHARGE NO. \_\_\_\_\_

DATE 4-27-69BY SMYRELLDESCRIPTION STRUCTURAL AND FATIGUE EVALUATION  
OF OUTLET NOZZLE - VESSEL SUPPORTSCHECK DATE 4-21-69 BY WILKER5- DETAILED ANALYSIS:1. SYSTEM LOADING:1. INTERNAL PRESSURE:

THE OUTLET NOZZLE AND THE VESSEL WALL IN THE VICINITY OF THE NOZZLE WILL BE INVESTIGATED FOR THE DESIGN PRESSURE WHERE APPLICABLE AND THE OPERATING PRESSURES DURING THE TRANSIENTS LISTED IN 5.C.2. THE STRESSES RESULTING FROM INTERNAL PRESSURE ARE DETERMINED FROM AN INTERACTION ANALYSIS AND ARE PRESENTED IN 5.C. THE PEAK STRESSES DUE TO INTERNAL PRESSURE AT THE JUNCTURE OF THE NOZZLE TO VESSEL SHELL WILL BE TAKEN AS GIVEN IN I-610 OF THE ASME CODE SECT. III.

2. THERMAL TRANSIENTS:

THE OUTLET NOZZLE AND THE VESSEL WALL WILL BE ANALYZED FOR THE FOLLOWING TRANSIENT CONDITIONS.

<u>TRANSIENT</u>	<u>NUMBER OF OCCURRENCES</u>
a. PLANT HEATUP AT 100°F PER HOUR	200
b. PLANT COOLDOWN AT 100°F PER HOUR	200
c. PLANT LOADING AT 5% OF FULL POWER PER MIN.	14500
d. PLANT UNLOADING AT 5% OF FULL POWER PER MIN.	14500
e. STEP LOAD INCREASE OF 10% OF FULL POWER BUT NOT TO EXCEED FULL POWER	2000
f. STEP LOAD DECREASE OF 10% OF FULL POWER FROM 100% POWER	2000
g. STEP LOAD REDUCTION FROM 100% TO 50% FULL POWER	200
h. REACTOR TRIP FROM FULL POWER	400
i. PLANT HYDROSTATIC TEST OF 3125 PSIA AT ROOM TEMP.	5
j. PLANT HYDROSTATIC TEST OF 2500 PSIA UP TO 400°F.	5
k. STEADY STATE FLUCTUATIONS OF $\pm 6^\circ\text{F}$ AND $\pm 100\text{PSI}$ PER MIN.	00
l. LOSS OF FLOW, ONE PUMP	80
m. LOSS OF LOAD	80
n. STEAM BREAK	5

## COMBUSTION ENGINEERING, INC.


ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

NUMBER 5-212-D | A181SHEET 9 OF 80

CHARGE NO. \_\_\_\_\_

DATE 6-27-69 BY CONNELLDESCRIPTION STRUCTURAL AND FATIGUE EVALUATION  
OF OUTLET NOZZLE - VESSEL SUPPORTSCHECK DATE 3-27-69 BY HELVOR5. DETAILED ANALYSIS:C. SYSTEM LOADING:3. THERMAL INDUCED PIPE REACTIONS:

THE FOLLOWING FIGURE SHOWS THE OUTLET NOZZLE WITH THE POSITIVE DIRECTIONS. THE PIPE REACTIONS ARE APPLIED AT THE SUPPORT END OF THE NOZZLES:



$$F_y = 26.2 \text{ KIPS}$$

$$F_y = -230 \text{ KIPS}$$

$$F_z = -10 \text{ KIPS}$$

$$M_y = -2010 \text{ IN-KIPS}$$

$$M_y = -1930 \text{ IN-KIPS}$$

$$M_z = 2708.4 \text{ IN-KIPS}$$

4. SEISMIC PIPE REACTIONS:

THE FOLLOWING PIPE REACTIONS DUE TO SEISMIC CONDITIONS WILL BE COMBINED WITH THE THERMAL PIPE REACTIONS IN THE WORST POSSIBLE COMBINATION WHEN ANALYZING THE NOZZLE AND SUPPORTS. TO DETERMINE THE MAXIMUM EFFECT OF THE SEISMIC PIPE REACTIONS ON THE NOZZLE TO VESSEL JUNCTURE AND THE SUPPORT PAD, IT IS NECESSARY TO DETERMINE THE WORSE COMBINATION OF FORCES. THIS HAS BEEN DONE AND THE FORCES RESULTING ARE LABELED H AND V. NOTE THAT THE EFFECT OF TWO OF THE INLET AND OUTLET NOZZLE SEISMIC REACTIONS MUST BE TAKEN BY THE INLET AND OUTLET NOZZLES WHICH SUPPORT THE VESSEL. THE FOLLOWING ARE THE PIPE REACTIONS

DESIGN SEISMIC LOADINGS

$$F_x = \pm 122 \text{ KIPS}$$

$$F_y = \pm 90 \text{ KIPS}$$

$$F_z = \pm 71 \text{ KIPS}$$

$$M_x = \pm 572 \text{ IN-KIPS}$$

$$M_y = \pm 1209 \text{ IN-KIPS}$$

$$M_z = \pm 7202 \text{ IN-KIPS}$$

NO LOSS OF FUNCTION SEISMIC LOADINGS

$$F_x = \pm 122 \text{ KIPS}$$

$$F_y = \pm 162 \text{ KIPS}$$

$$F_z = \pm 124 \text{ KIPS}$$

$$M_x = \pm 2930 \text{ IN-KIPS}$$

$$M_y = \pm 19569 \text{ IN-KIPS}$$

$$M_z = \pm 13200 \text{ IN-KIPS}$$

COMBUSTION ENGINEERING, INC.  
 ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

NUMBER 5-211-P | A182  
 SHEET 10 OF 00  
 DATE 4-22-68 BY CUMMEL  
 CHECK DATE 4-22-69 BY HEILVER

CHARGE NO. \_\_\_\_\_  
 DESCRIPTION STRUCTURAL AND FATIGUE EVALUATION  
OF OUTLET NOZZLE - VESSEL SUPPORT


DETAILED ANALYSIS:

1. SYSTEM LOADING:

4. SEISMIC PIPE REACTIONS:

AS CAN BE SEEN FROM THE TABLE ON SHEET 9, THERE ARE MANY COMBINATIONS OF FORCES. SINCE THE SEISMIC FORCES CAN ALTERNATE, IT WILL BE NECESSARY TO DETERMINE THE COMBINATION OF FORCES WHICH PRODUCE THE MAXIMUM AND MINIMUM STRESSES AT CUT-4. THIS WILL OCCUR WHEN THE VALUES FOR  $F_x, F_y, F_z, M_x, M_y,$  AND  $M_z$  AS GIVEN ON SHEETS 47-52 ARE SOLVED TO GIVE MAXIMUM AND MINIMUM VALUES. THE METHOD USED TO DETERMINE THIS IS AS FOLLOWS:

- (1) THE LOADS ON THE INDIVIDUAL NOZZLES ARE TRANSFERRED TO THE C.G. OF THE REACTOR VESSEL;
- (2) THE FORCES H AND V ARE DETERMINED IN RELATION TO THE LOADS AT THE  $\epsilon$  OF THE VESSEL, AND
- (3) TAKING THE COMBINATION OF SEISMIC LOADS GIVEN ON SHEET 9 TO GIVE THE MAXIMUM AND MINIMUM VALUES OF H & V.



**COMBUSTION ENGINEERING, INC.**

ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

CHARGE NO. \_\_\_\_\_

DESCRIPTION STRUCTURAL AND FATIGUE EVALUATION  
OF OUTLET NOZZLES - VESSEL SUPPORTS

NUMBER S-212-P | A/83

SHEET 11 OF 80

DATE 4-22-68 BY COCKRELL

CHECK DATE 3-22-69 BY HELMER

5- DETAILED ANALYSIS:

RC SYSTEM LOADING:

4- SEISMIC PIPE REACTIONS:

(1) FORCES AT & OF VESSEL:

SEE SHEET 11 OF S-211-P

(2) FORCES ON SUPPORTS:

$$H = \frac{F_x}{2} - \frac{\bar{M}_y}{4(109.400)}$$

$$V = -\frac{F_y}{4} \pm \frac{\bar{M}_x}{2(1109.400)}$$

NOTE HERE THAT THE TOP SIGN IS FOR OUTLET NOZZLE #2 AND THE BOTTOM SIGN IS FOR OUTLET NOZZLE #4. HOWEVER WITH INDEFINITE SIGN FORMULAS FOR  $\bar{F}_x, \bar{F}_y$  &  $\bar{M}_y$ , AND  $\bar{M}_x$  AND SOLUTIONS WILL YIELD THE SAME RESULTS.

(3) VALUES OF FORCES ON SUPPORTS:

WITH THE ABOVE EXPRESSIONS FOR H & V AND THE EXPRESSIONS FOR  $\bar{F}_x, \bar{F}_y, \bar{M}_x$ , AND  $\bar{M}_y$  GIVEN ON SHEET 11 OF S-211-P, WE GET THE FOLLOWING:

$$H = -0.5(F_{x,IN01} - F_{x,IN02}) + 0.34733(F_{x,IN02} - F_{x,IN03}) - 0.28956(F_{x,IN01} + F_{x,IN03}) - 0.69923 F_{x,IN02}$$

$$+ 0.07011 F_{x,IN03} - 0.34733(F_{x,OUT01} - F_{x,OUT03}) - 0.63059 F_{x,OUT01} - 0.77092 F_{x,OUT02}$$

$$+ 0.08975 F_{x,OUT03} + 0.22849 F_{x,OUT04} - 0.002295(M_{y,IN01} + M_{y,IN02} + M_{y,IN03} + M_{y,IN04})$$

$$- 0.002295(M_{y,OUT01} + M_{y,OUT02} + M_{y,OUT03} + M_{y,OUT04})$$

$$V = -0.25(F_{y,IN01} + F_{y,IN02}) - 0.66659 F_{y,IN03} + 0.16659 F_{y,IN04} - 0.63977 F_{y,OUT01} - 0.79184 F_{y,OUT02} + 0.13777 F_{y,OUT03}$$

$$+ 0.29144 F_{y,OUT04} + 0.002295(M_{x,IN01} - M_{x,IN02}) - 0.002295(M_{x,IN02} - M_{x,IN04}) + 0.002295(M_{x,IN02} - M_{x,OUT04})$$

$$+ 0.002295(M_{x,OUT01} - M_{x,OUT03}) + 0.00329(M_{x,OUT01} - M_{x,OUT03}) + 0.000457(M_{x,OUT02} - M_{x,OUT04})$$

**COMBUSTION ENGINEERING, INC.**  
ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

NUMBER 5-212-P | A184

SHEET 12 OF 80

DATE 4-22-68 BY LOCKE

CHECK DATE 4-22-69 BY HOLKER

CHARGE NO. \_\_\_\_\_

DESCRIPTION STRUCTURAL AND FATIGUE EVALUATION  
OF BUTLER NOZZLES - VESSEL SUPPORTS

DETAILED ANALYSIS:

PIPE SYSTEM LOADING:

SEISMIC PIPE REACTIONS:

WITH THE ABOVE EQUATIONS AND THE FOLLOWING VALUES FOR THE SEISMIC PIPE REACTIONS, THE VALUES FOR H & V ARE DETERMINED THAT WILL GIVE THE MAXIMUM AND MINIMUM STRESSES AT CUT-4

FOR DESIGN SEISMIC:

NOZZLE	PIPE REACTION						
	F <sub>x</sub>	F <sub>y</sub>	F <sub>z</sub>	M <sub>x</sub>	M <sub>y</sub>	M <sub>z</sub>	
INLET #1	57.9	67	132.9	-982	12972		H = -538.5 KIPS V = -252.8 KIPS
2	-57.9	67	132.9	982	12972	-9910	
3	-57.9	67	132.9	982	12972		
4	57.9	-67	-132.9	-982	12972	9910	
OUTLET #1	122	90	-71	-1572	11248	-7282	REVERSING SIGNS GIVES, H = 538.5 KIPS V = 252.8 KIPS
2	-122	-90	-71	-1572	-11248	7282	
3	-122	-90	71	1572	11248	7282	
4		-90	71		11248	7282	

FOR NO LOSS OF FUNCTION SEISMIC:

NOZZLE	PIPE REACTION						
	F <sub>x</sub>	F <sub>y</sub>	F <sub>z</sub>	M <sub>x</sub>	M <sub>y</sub>	M <sub>z</sub>	
INLET #1	91.9	91.9	262	-2900	23655		H = -892.2 K V = -407.2 K
2	-91.9	91.9	262	2900	23655	-10005	
3	-91.9	91.9	262	2900	23655		
4	91.9	-91.9	-262	-2900	23655	10005	
OUTLET #1	122	162	-124	-2930	19569	-13200	REVERSING SIGNS GIVES, H = 892.2 K V = 407.2 K
2	-122	-162	-124	-2930	-19569	13200	
3	-122	-162	124	2930	19569	13200	
4		-162	124		19569	13200	

COMBUSTION ENGINEERING, INC.  
 ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

NUMBER 5-212-D | A185  
 SHEET 13 OF 80  
 DATE 4-22-58 BY CEMBER  
 CHECK DATE 4-22-68 BY HELMER

CHARGE NO. \_\_\_\_\_  
 DESCRIPTION STRUCTURAL AND FATIGUE EVALUATION  
OF OUTLET NOZZLES - VESSEL SUPPORTS

5- DETAILED ANALYSIS:


C. SYSTEM LOADING:

5- STATIC LOADING THROUGH SUPPORTS:

THE STATIC LOAD PER SUPPORT WAS FOUND TO BE 561.1 KIPS, SEE SHEET 1A OF 5-211-P.

6- EARTHQUAKE LOADING THROUGH SUPPORTS:

DURING AN EARTHQUAKE, THE SUPPORTS MUST RESIST THE VERTICAL AND HORIZONTAL FORCES APPLIED THROUGH THE C.G. OF THE VESSEL DUE TO THE EARTHQUAKE SHOCK FORCES. SINCE THE BOTTOM OF THE VESSEL SUPPORTS IS AT A DIFFERENT ELEVATION THAN THE C.G. OF THE VESSEL, AN OVERTURNING MOMENT DUE TO THE HORIZONTAL SHOCK FORCE RESULTS AND MUST BE RESISTED BY THE SUPPORTS. THE FOLLOWING FIGURE ILLUSTRATES THE METHOD FOR DETERMINING THE FORCES IN THE PROS.



$$V = \pm \frac{\bar{V}}{4} \pm \frac{H}{2(109.400)}$$

$$H = \pm \frac{H}{2}$$

DIRECTION	EARTHQUAKE FACTORS	
	DESIGN	NO LOSS OF FUNCTION
HORIZONTAL	0.34	0.04
VERTICAL	0.29	0.04

FORCE	DESIGN	NO LOSS OF FUNCTION
H	± 336.7	± 673.4
V	± 132.5	± 265.1

NOTE THAT THE ABOVE SEISMIC SHOCK FACTORS ARE LOWER THAN THOSE LISTED IN REF 10. THE ABOVE FACTORS WILL BE USED UNLESS CALCULATIVE STRESSES; HOWEVER, THE SPECIFIED SEISMIC SHOCK FACTORS GROUP 1 IN REF 10, WILL BE USED WHEN DETERMINING THE MAX. FORCES ON THE PROS, SEE SHEET 6B.



**COMBUSTION ENGINEERING, INC.**

ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

NUMBER S-212-P | A186

SHEET 14 OF 30

CHARGE NO. \_\_\_\_\_

DATE 4-22-68 BY B. P. FELL

DESCRIPTION STRUCTURAL AND FATIGUE EVALUATION  
OF OULET NOZZLE - VESSEL SUPPORTS

CHECK DATE 4-22-68 BY HEURCK

5. DETAILED ANALYSIS:


5.1 SYSTEM LOADINGS:

NET DUE TO THERMAL EXPANSION & CONTRACTION

THE FRICTIONAL FORCE DUE TO EXPANSION AND CONTRACTION WAS FOUND TO BE 168.3 KIIPS, SEE SHEET 16 OF S-211-P.

5.2 PRESSURE AND THERMAL INTERACTION:

5.2.1 ANALYTICAL MODEL:



THE ACTUAL STRUCTURE AS SHOWN ON SHEET 6 IS DIVIDED INTO THE ANALYTICAL MODEL AS SHOWN TO FACILITATE THE ANALYSIS. THE ASSUMED DIRECTIONS OF THE REDUNDANT FIXES ARE ILLUSTRATED.

- ① LONG CYLINDER
- ② SHORT CYLINDER
- ③ SHORT TAPERED CYLINDER
- ④ SHORT CYLINDER
- ⑤ LONG SPHERE

**COMBUSTION ENGINEERING, INC.**  
 ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

NUMBER S-212-P | A187

SHEET 15 OF 80

CHARGE NO. \_\_\_\_\_

DATE 4-22-69 BY COOPER

DESCRIPTION: STRUCTURAL AND FATIGUE EVALUATION  
OF OUTLET NOZZLE - VESSEL SUPPORTS


CHECK DATE 2-27-69 BY HEUSER

5. DETAILED ANALYSIS:

(d) PRESSURE & THERMAL INTERACTION:

1- DEFLECTIONS:

Body-1:



$R_1 = 15.766''$   
 $b = 14.5'$   
 $H_1 = 2.531'$   
 $R_2 = 15.375''$   
 $e = 0.109''$

$B^2 = \frac{3(1-\nu^2)}{R_1^2 E^2}$   
 $B = 0.20349$   
 $D = \frac{E E_2}{15(1-\nu)} = 1.49475E$   
 $\frac{E_{210}}{E_{216}} = 1$

DISPLACEMENTS DUE TO REDUNDANT FORCES:

$$E\Delta_{11} = -\frac{E}{24^3 D} \left[ \frac{1}{B} H_1 - M_1 \right] \frac{R_1}{R_2} \frac{E_{210}}{E_{216}} = -40.2444 H_1 + 8.1892 M_1$$

$$E\Delta_{11}^* = -\frac{E}{24^3 D} \left[ H_1 - 2BM_1 \right] \frac{R_2}{R_1} \frac{E_{210}}{E_{216}} = -9.1892 H_1 + 3.3323 M_1$$

DISPLACEMENTS DUE TO APPLIED FORCES:

$$E\delta_{11} = \frac{D^2}{E} \left( \frac{R_2}{R_1} - \frac{\nu}{e} \right) P \frac{E_{210}}{E_{216}} - \frac{E}{24^3 D} (Ve) \frac{R_2}{R_1} \frac{E_{210}}{E_{216}} = 71.9513P$$

$$E\delta_{11}^* = -\frac{E}{24^3 D} (Ve) \frac{R_2}{R_1} \frac{E_{210}}{E_{216}} = -2.4056P$$

DISPLACEMENTS DUE TO THERMAL EFFECTS:

FOR RANGE OF STRESS	FOR PEAK STRESS
$E\delta_{11T} = R_2 E d_m (T_{11} - 100) \frac{E_{210}}{E_{216}}$ $= 15.975 E d_m (T_{11} - 100)$	$= R_2 E d_m (T_{11} - 100) \frac{E_{210}}{E_{216}} + \frac{E}{24^3 D} \frac{R_2}{R_1} \frac{E_{210}}{E_{216}} M_{1T}$ $= 15.975 E d_m (T_{11} - 100) + 6.1892 M_{1T}$
$E\delta_{11}^* = R_1 E d_m \left( \frac{\Delta T}{\Delta T_{11}} \right) \frac{E_{210}}{E_{216}}$ $= 15.766 E d_m \left( \frac{\Delta T}{\Delta T_{11}} \right)$	$= R_1 E d_m \left( \frac{\Delta T}{\Delta T_{11}} \right) \frac{E_{210}}{E_{216}} + \frac{E}{24^3 D} \frac{R_1}{R_1} \frac{E_{210}}{E_{216}} M_{1T}$ $= 15.766 E d_m \left( \frac{\Delta T}{\Delta T_{11}} \right) + 3.3323 M_{1T}$

**COMBUSTION ENGINEERING, INC.**  
 ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

NUMBER 5-212-P | A188  
 SHEET 16 OF 90

CHARGE NO. \_\_\_\_\_

DATE 4-22-69 BY CKRRELL

DESCRIPTION STRUCTURAL AND FATIGUE EVALUATION  
OF OUTLET NOZZLE - VESSEL SUPPORTS


CHECK DATE 4-22-69 BY HELPER

5. DETAILED ANALYSIS:

1.1. PRESSURE AND THERMAL INTERACTION:

2. DEFLECTIONS:

BODY-2:



$R_2 = 15.975"$   
 $b_2 = 14.500"$   
 $l_2 = 2.312"$   
 $l_2 = 4.0625"$

$$\beta^2 = \frac{5(1-\nu^2)}{24l^2}$$

$$\beta = 0.21217$$

$$D = \frac{Ee^3}{12(1-\nu^2)} = 1.13172E$$

FOR  $\beta C = 0.462$

$B_{11} = 7.3326$	$G_{11} = -1.1511$
$B_{12} = 4.1158$	$G_{12} = 3.9924$
$B_{21} = 10.0093$	$G_{21} = -9.1500$

DISPLACEMENTS DUE TO REDUNDANT FORCES:

$$ED_{21} = \frac{E}{240D} \left[ \frac{1}{\beta} B_{11} H_1 + B_{12} M_1 - \frac{1}{\beta} G_{11} H_2 + G_{12} M_2 \right]$$

$$= 107.8952 H_1 + 40.3930 M_1 + 53.2445 H_2 - 39.1819 M_2$$

$$ED_{21}^* = \frac{E}{240D} \left[ -B_{12} H_1 - \beta B_{21} M_1 + G_{12} H_2 - \beta G_{21} M_2 \right]$$

$$= -40.3930 H_1 - 20.4423 M_1 - 39.1819 H_2 + 19.0519 M_2$$

$$ED_{22} = \frac{E}{240D} \left[ \frac{1}{\beta} G_{11} H_1 + G_{12} M_1 - \frac{1}{\beta} B_{11} H_2 + B_{12} M_2 \right]$$

$$= -53.2445 H_1 - 39.1819 M_1 - 107.8952 H_2 + 40.3930 M_2$$

$$ED_{22}^* = \frac{E}{240D} \left[ G_{12} H_1 + \beta G_{21} M_1 - B_{12} H_2 + \beta B_{21} M_2 \right]$$

$$= -39.1819 H_1 - 19.0519 M_1 - 40.3930 H_2 + 20.4423 M_2$$

## COMBUSTION ENGINEERING, INC.

ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

CHARGE NO. \_\_\_\_\_

NUMBER S-212-D | A189SHEET 17 OF 80DATE 4-27-69 BY CASSELLDESCRIPTION STRUCTURAL AND FATIGUE EVALUATION  
OF ORBIT NOZZLE - VERICAL SUPPORTSCHECK DATE 4-27-69 BY HELFER5- DETAILED ANALYSIS:1. PRESSURE AND THERMAL INTERACTION:2. DEFLECTIONS:DISPLACEMENTS DUE TO APPLIED FORCES:

$$E\delta_{21} = E\delta_{22} = \frac{b_2^3}{E_2} \left( \frac{R_2}{b_2} - \frac{\nu}{2} \right) P = \underline{35.9213P}$$

$$E\delta_{21}^* = E\delta_{21}^* = 0$$

DISPLACEMENTS DUE TO THERMAL EFFECTS:

FOR RANGE OF STRESS

FOR PEAK STRESS

$$E\delta_{21T} = R_2 E d_m (T_{21} - 100) = R_2 E d_m (T_{21} - 100) + \frac{E}{20^2 D} [B_{12} M_{1T} + G_{12} M_{2T}]$$

$$= 15.875 E d_m (T_{21} - 100) = 15.875 E d_m (T_{21} - 100) + 40.3930 M_{1T} - 39.1819 M_{2T}$$

$$E\delta_{21T}^* = R_2 E d_m \left( \frac{\Delta T}{\Delta X} \right)_{21} = R_2 E d_m \left( \frac{\Delta T}{\Delta X} \right)_{21} + \frac{E}{20^2 D} [-\beta B_{22} M_{1T} - \beta G_{22} M_{2T}]$$

$$= 15.875 E d_m \left( \frac{\Delta T}{\Delta X} \right)_{21} = 15.875 E d_m \left( \frac{\Delta T}{\Delta X} \right)_{21} - 20.9423 M_{1T} + 19.0519 M_{2T}$$

$$E\delta_{21T} = R_2 E d_m (T_{22} - 100) = R_2 E d_m (T_{22} - 100) + \frac{E}{20^2 D} [G_{12} M_{1T} + B_{12} M_{2T}]$$

$$= 15.875 E d_m (T_{22} - 100) = 15.875 E d_m (T_{22} - 100) - 39.1819 M_{1T} + 40.3930 M_{2T}$$

$$E\delta_{21T}^* = R_2 E d_m \left( \frac{\Delta T}{\Delta X} \right)_{22} = R_2 E d_m \left( \frac{\Delta T}{\Delta X} \right)_{22} + \frac{E}{20^2 D} [\beta G_{22} M_{1T} + \beta B_{22} M_{2T}]$$

$$= 15.875 E d_m \left( \frac{\Delta T}{\Delta X} \right)_{22} = 15.875 E d_m \left( \frac{\Delta T}{\Delta X} \right)_{22} - 19.0519 M_{1T} + 20.9423 M_{2T}$$

**COMBUSTION ENGINEERING, INC.**

ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

CHARGE NO. \_\_\_\_\_

DESCRIPTION: STRUCTURAL AND FATIGUE EVALUATION  
OF OUTLET NOZZLE - VESSEL SUPPORTS

NUMBER 5-218-P

A190

SHEET 18 OF 80

DATE 4-22-69 BY COOPER


CHECK DATE 4-27-69 BY HEUSER

1. DETAILED ANALYSIS:

1.1 PRESSURE AND THERMAL INTERACTION:

2. DEFLECTIONS:

BODY-3:



$R_2 = 15.875$

$L_0 = 2.312$

$R_3 = 17.928$

$L_1 = 10.281$

$R_4 = 19.980$

$L_2 = 8.219$

$a_2 = 14.500$

$e_1 = 2.053$

$e_2 = 2.052$

$\lambda = \frac{1}{L_3}(L_1 - L_0)$

$\delta_{s0} = 0.46958$



THE INFLUENCE COEFFICIENTS FOR A SHORT TAPERED CYLINDER ARE CALCULATED BY THE METHOD OUTLINED ON PAGES 488-492 OF REF. 7 AND ARE PRINTED OUT ON C.E.'S COMPUTER PROGRAM AS FOLLOWS.

DISPLACEMENTS DUE TO REDUNDANT FORCES:

$$ED_{33} = \phi_{11} H_2 \frac{R_1}{R_3} + \phi_{12} M_2 \frac{R_2}{R_3} + \phi_{13} H_3 \frac{R_4}{R_3} + \phi_{14} M_3 \frac{R_4}{R_3}$$

$$= 34.1884 H_2 + 6.1893 M_2 + 15.7490 H_3 - 6.9346 M_3$$

$$ED_{32} = \phi_{21} H_2 \frac{R_1}{R_3} - \phi_{22} M_2 \frac{R_2}{R_3} + \phi_{23} H_3 \frac{R_4}{R_3} + \phi_{24} M_3 \frac{R_4}{R_3}$$

$$= -6.1847 H_2 - 1.9617 M_2 - 4.4781 H_3 + 1.3550 M_3$$

$$ED_{31} = \phi_{31} H_1 \frac{R_1}{R_3} + \phi_{32} M_1 \frac{R_2}{R_3} + \phi_{33} H_3 \frac{R_4}{R_3} + \phi_{34} M_3 \frac{R_4}{R_3}$$

$$= -12.5173 H_2 - 3.5424 M_2 - 21.9623 H_3 + 4.6783 M_3$$

$$ED_{23} = \phi_{41} H_2 \frac{R_1}{R_3} + \phi_{42} M_2 \frac{R_2}{R_3} + \phi_{43} H_3 \frac{R_4}{R_3} + \phi_{44} M_3 \frac{R_4}{R_3}$$

$$= -5.5112 H_2 - 1.0776 M_2 - 4.6773 H_3 + 1.4794 M_3$$

## COMBUSTION ENGINEERING, INC.

ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

CHARGE NO. \_\_\_\_\_

NUMBER 5-212-P | A191SHEET 19 OF 60DATE 4-22-68 BY CGRELLDESCRIPTION STRUCTURAL AND FATIGUE EVALUATION  
OF OUTLET NOZZLE - VESSEL SUPPORTSCHECK DATE 4-22-68 BY HLVSP5. DETAILED ANALYSIS:d. PRESSURE AND THERMAL INTERACTION:2. DEFLECTIONS:DISPLACEMENTS DUE TO APPLIED FORCES:

$$E\delta_{32} = P_2 \left( \frac{R_2}{a_2} - \frac{v}{2} \right) \left[ (\phi_{12} + \phi_{10}) \frac{-\lambda^2}{4(1-\nu^2)} + \frac{1}{E_0} \right] + \phi_{12} V_2 e_1 \frac{R_1}{R_2} - \phi_{10} V_3 e_2 \frac{R_1}{R_2} = \underline{227.6294 P}$$

$$E\delta_{32}^R = P_2 \left( \frac{R_2}{a_2} - \frac{v}{2} \right) \left[ (\phi_{12} + \phi_{20}) \frac{-\lambda^2}{4(1-\nu^2)} - \frac{\lambda}{E_0} \right] + \phi_{12} V_2 e_1 \frac{R_2}{R_3} - \phi_{20} V_3 e_1 \frac{R_1}{R_2} = \underline{-46.4974 P}$$

$$E\delta_{31} = P_2 \left( \frac{R_2}{a_2} - \frac{v}{2} \right) \left[ (\phi_{12} + \phi_{30}) \frac{-\lambda^2}{4(1-\nu^2)} + \frac{1}{E_1} \right] + \phi_{12} V_2 e_1 \frac{R_1}{R_3} - \phi_{30} V_3 e_2 \frac{R_1}{R_3} = \underline{-93.5960 P}$$

$$E\delta_{33} = P_2 \left( \frac{R_2}{a_2} - \frac{v}{2} \right) \left[ (\phi_{12} + \phi_{40}) \frac{-\lambda^2}{4(1-\nu^2)} - \frac{\lambda}{E_1} \right] + \phi_{12} V_2 e_1 \frac{R_1}{R_3} - \phi_{40} V_3 e_2 \frac{R_1}{R_3} = \underline{-37.0640 P}$$

DISPLACEMENTS DUE TO THERMAL EFFECTS:

<u>FOR RANGE OF STRESS</u>	<u>FOR PEAK STRESS</u>
$E\delta_{32T} = R_2 E d_m (T_{32} - 100)$	$= R_2 E d_m (T_{32} - 100) + \phi_{12} M_{2T} \frac{R_1}{R_2} + \phi_{10} M_{3T} \frac{R_1}{R_2}$
$= 15.875 E d_m (T_{32} - 100)$	$= 15.875 E d_m (T_{32} - 100) + 6.1993 M_{2T} - 6.9346 M_{3T}$
$E\delta_{32}^R = R_3 E d_m \left( \frac{\Delta T}{\Delta X} \right)_{32}$	$= R_3 E d_m \left( \frac{\Delta T}{\Delta X} \right)_{32} + \phi_{22} M_{2T} \frac{R_1}{R_3} + \phi_{20} M_{3T} \frac{R_1}{R_3}$
$= 17.928 E d_m \left( \frac{\Delta T}{\Delta X} \right)_{32}$	$= 17.928 E d_m \left( \frac{\Delta T}{\Delta X} \right)_{32} - 1.867 M_{2T} + 1.3550 M_{3T}$
$E\delta_{31T} = R_4 E d_m (T_{33} - 100)$	$= R_4 E d_m (T_{33} - 100) + \phi_{12} M_{2T} \frac{R_1}{R_3} + \phi_{30} M_{3T} \frac{R_1}{R_3}$
$= 19.980 E d_m (T_{33} - 100)$	$= 19.980 E d_m (T_{33} - 100) - 3.5624 M_{2T} + 4.6783 M_{3T}$
$E\delta_{31}^R = R_3 E d_m \left( \frac{\Delta T}{\Delta X} \right)_{31}$	$= R_3 E d_m \left( \frac{\Delta T}{\Delta X} \right)_{31} + \phi_{12} M_{2T} \frac{R_1}{R_3} + \phi_{40} M_{3T} \frac{R_1}{R_3}$
$= 17.928 E d_m \left( \frac{\Delta T}{\Delta X} \right)_{31}$	$= 17.928 E d_m \left( \frac{\Delta T}{\Delta X} \right)_{31} - 1.0776 M_{2T} + 1.4794 M_{3T}$

COMBUSTION ENGINEERING, INC.  
ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

NUMBER 5-212-P | A192  
SHEET 20 OF 80

CHARGE NO. \_\_\_\_\_

DATE 4-22-69 BY ROSELL

DESCRIPTION STRUCTURAL AND FATIGUE EVALUATION  
OF OUTLET NOZZLE - VESSEL SUPPORTS


CHECK DATE 4-22-69 BY J. L. K.

E- DETAILED ANALYSIS:

1. PRESSURE AND THERMAL INTERACTION:

1.1. DEFLECTIONS:

Body-4:



$R_o = 19.980"$   
 $b_o = 14.739"$   
 $t_o = 10.042"$   
 $L_o = 15.25"$

$$\beta = \frac{(1-\nu^2)}{R_o^3 E}$$

$$\beta = 0.09075$$

$$D = \frac{E t_o^3}{12(1-\nu^2)} = 92.7338 E$$

FOR  $\beta L = 1.384$

$B_{11} = 1.4944$	$G_{11} = -0.6859$
$B_{12} = 1.7630$	$G_{12} = -1.4519$
$B_{22} = 3.2777$	$G_{22} = -1.9212$

DISPLACEMENTS DUE TO REDUNDANT FORCES:

$$E \Delta_{13} = \frac{E}{2\beta^2 D} \left[ \frac{1}{\beta} B_{11} H_3 + B_{12} M_3 - \frac{1}{\beta} G_{11} H_4 + G_{12} M_4 \right]$$

$$= \underline{10.7821 H_3 + 1.1543 M_3 + 4.9488 H_4 - 0.9506 M_4}$$

$$E \Delta_{23} = \frac{E}{2\beta^2 D} \left[ -B_{12} H_3 - \beta B_{22} M_3 + G_{12} H_4 - \beta G_{22} M_4 \right]$$

$$= \underline{-1.1543 H_3 - 0.1948 M_3 - 0.9506 H_4 + 0.1142 M_4}$$

$$E \Delta_{24} = \frac{E}{2\beta^2 D} \left[ \frac{1}{\beta} G_{11} H_3 + G_{12} M_3 - \frac{1}{\beta} B_{11} H_4 + B_{12} M_4 \right]$$

$$= \underline{-4.9488 H_3 - 0.9506 M_3 - 10.7821 H_4 + 1.1543 M_4}$$

$$E \Delta_{44} = \frac{E}{2\beta^2 D} \left[ G_{12} H_3 + \beta G_{22} M_3 - B_{12} H_4 + \beta B_{22} M_4 \right]$$

$$= \underline{-0.9506 H_3 - 0.1142 M_3 - 1.1543 H_4 + 0.1948 M_4}$$

## COMBUSTION ENGINEERING, INC.

ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

CHARGE NO. \_\_\_\_\_

NUMBER S-212-P A193SHEET 21 OF 80DATE 8-22-69 BY COCKRILLCHECK DATE 8-22-69 BY HEILIGDESCRIPTION STRUCTURAL AND FATIGUE EVALUATION  
OF OUTLET NOZZLE - VERMIL SUPPORTS5. DETAILED ANALYSIS1. PRESSURE AND THERMAL INTERACTION:2. DEFLECTIONS:DISPLACEMENTS DUE TO APPLIED FORCES:

$$ES_{13} - ES_{14} = \frac{b_1}{2a} \left( \frac{R_1}{b_1} - \frac{r}{2} \right) P = 26.0903P$$

$$ES_{13}^* - ES_{14}^* = 0$$

DISPLACEMENTS DUE TO THERMAL EFFECTS:FOR RANGE OF STRESS

$$ED_{13T} = R_1 Ed_m (T_{13} - 100)$$

$$= 19.980 Ed_m (T_{13} - 100)$$

$$ES_{13T}^* = R_1 Ed_m \left( \frac{\Delta T}{\Delta X} \right)_{13}$$

$$= 19.980 Ed_m \left( \frac{\Delta T}{\Delta X} \right)_{13}$$

$$ED_{14T} = R_1 Ed_m (T_{14} - 100)$$

$$= 19.980 Ed_m (T_{14} - 100)$$

$$ES_{14T}^* = R_1 Ed_m \left( \frac{\Delta T}{\Delta X} \right)_{14}$$

$$= 19.980 Ed_m \left( \frac{\Delta T}{\Delta X} \right)_{14}$$

FOR PEAK STRESS

$$= R_1 Ed_m (T_{13} - 100) + \frac{E}{2B^2 D} [B_{12} M_{3T} + G_{12} M_{4T}]$$

$$= 19.980 Ed_m (T_{13} - 100) + 1.1543 M_{3T} - 0.9506 M_{4T}$$

$$= R_1 Ed_m \left( \frac{\Delta T}{\Delta X} \right)_{13} + \frac{E}{2B^2 D} [-AB_{22} M_{3T} - \beta G_{22} M_{4T}]$$

$$= 19.980 Ed_m \left( \frac{\Delta T}{\Delta X} \right)_{13} - 0.1949 M_{3T} + 0.1192 M_{4T}$$

$$= R_1 Ed_m (T_{14} - 100) + \frac{E}{2B^2 D} [G_{12} M_{3T} + B_{12} M_{4T}]$$

$$= 19.980 Ed_m (T_{14} - 100) - 0.9506 M_{3T} + 1.1543 M_{4T}$$

$$= R_1 Ed_m \left( \frac{\Delta T}{\Delta X} \right)_{14} + \frac{E}{2B^2 D} [\beta G_{22} M_{3T} + \beta B_{22} M_{4T}]$$

$$= 19.980 Ed_m \left( \frac{\Delta T}{\Delta X} \right)_{14} - 0.1192 M_{3T} + 0.1949 M_{4T}$$



**COMBUSTION ENGINEERING, INC.**

ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

NUMBER 5-212-P

A199

SHEET 22 OF 80

CHARGE NO. \_\_\_\_\_

DATE 4-22-69 BY CBR/ML

DESCRIPTION STRUCTURAL AND FATIGUE EVALUATION  
OF OUTLET NOZZLE - VESSEL SUPPORTS


CHECK DATE 4-22-69 BY HEILYER

DETAILED ANALYSIS:

1. PRESSURE AND THERMAL INTERACTION:

2. DEFLECTIONS:

BODY-5:



$R_3 = 136.546"$   
 $a_3 = 130.952"$   
 $t_3 = 10.750"$   
 $\phi_3 = 9.4136"$

For  $\phi \sqrt{\frac{R}{t}} = 29.982$   
 $P_{11} = 0.5387$   
 $P_{12} = 0.4851$   
 $P_{22} = 2.7734$

NOTE THAT THE VESSEL SHELL IS IDEALIZED AS A SPHERICAL SEGMENT OF THE SAME THICKNESS AS THE VESSEL AND WITH A MID-RADIUS 1.5 TIMES THAT OF THE VESSEL. THIS YIELDS A MODEL WITH MEMBRANE STRESS EQUAL TO THE AVERAGE OF THAT IN THE LONGITUDINAL AND CIRCUMFERENTIAL DIRECTIONS OF THE VESSEL.

DISPLACEMENTS DUE TO REDUNDANT FORCES:

$$ED_{30} = \frac{180}{\pi t_3 \phi_3} [t_3^2 P_{11} M_0 + t_3 P_{12} M_0] = 3.6684 M_0 + 0.3073 M_0$$

$$ED_{30}^* = -\frac{180}{\pi t_3 \phi_3} [t_3 P_{11} M_0 + P_{12} M_0] = -0.3073 M_0 - 0.1634 M_0$$

DISPLACEMENTS DUE TO APPLIED FORCES:

$$ES_{30}^* = \frac{3^2}{2} \left[ \frac{180 \cos \phi}{\pi R_3 \phi} P_{11} + \frac{\sin \phi}{t_3} (1-\nu) \right] P = 309.5691 P$$

$$ES_{30}^* = -\frac{90 \sin \phi \cos \phi}{\pi R_3 t_3 \phi} P_{12} P = -19.0824 P$$

DISPLACEMENTS DUE TO THERMAL EFFECTS:

FOR RANGE OF STRESS

FOR PEAK STRESS

$$ED_{30} = R_3 \sin \phi E_{th} (\Delta T / 100) = R_3 \sin \phi E_{th} (\Delta T / 100) + \frac{180}{\pi t_3 \phi} P_{12} M_0 T$$

$$= 19,980 E_{th} (\Delta T / 100) = 19,980 E_{th} (\Delta T / 100) + 0.3073 M_0 T$$

$$ED_{30}^* = R_3 \sin \phi E_{th} \left( \frac{\Delta T}{100} \right) = R_3 \sin \phi E_{th} \left( \frac{\Delta T}{100} \right) - \frac{180}{\pi t_3 \phi} P_{12} M_0 T$$

$$= 19,980 E_{th} \left( \frac{\Delta T}{100} \right) = 19,980 E_{th} \left( \frac{\Delta T}{100} \right) - 0.1634 M_0 T$$

**COMBUSTION ENGINEERING, INC.**  
ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

NUMBER 5-212-P | A195  
SHEET 23 OF 80  
DATE 4-22-69 BY CHERRILL  
CHECK DATE 4-22-69 BY HELFER

CHARGE NO. \_\_\_\_\_  
DESCRIPTION STRUCTURAL AND FATIGUE EVALUATION  
OF OUTLET NOZZLE - VESSEL SUPPORTS

5- DETAILED ANALYSIS:

1. PRESSURE AND THERMAL INTERACTION:

2. DEFLECTIONS:

THE FOLLOWING TABLES GIVE THE MEAN TEMPERATURE, SLOPE OF THE AXIAL GRADIENT, AND THE THERMAL MOMENT DUE TO THE RADIAL GRADIENT FOR EACH CUT. THESE VALUES ARE USED TO CALCULATE THE DEFLECTIONS OF EACH CUT DUE TO THE THERMAL EFFECTS AS PRESENTED ON SHEETS 15-22.

TRANSIENT	$T_{11}$ & $T_{12}$	$T_{22}$ & $T_{23}$	$T_{33}$ & $T_{34}$	$T_{44}$	$T_{54}$	$(\frac{\Delta T}{\Delta X})_1$	$(\frac{\Delta T}{\Delta X})_2$ & $(\frac{\Delta T}{\Delta X})_3$	$(\frac{\Delta T}{\Delta X})_4$ & $(\frac{\Delta T}{\Delta X})_5$	
Heating	4.00 hrs	492	498	440	433	435	1.000	-0.985	-4.668
	4.25	517	513	465	458	460	↓	↓	↓
	4.35	527	523	475	468	470	↓	↓	↓
	4.47	539	535	487	480	481	↓	↓	↓
	5.00	547	544	521	516	516	0	-0.738	-2.237
No Load Steady State	547	547	547	547	547	0	0	0	
Cooling	6.00 hrs	155	159	207	214	212	-1.000	0.985	4.668
	4.25	130	134	182	189	187	↓	↓	↓
	4.35	120	124	172	179	177	↓	↓	↓
	4.47	108	112	160	167	166	↓	↓	↓
	5.00	100	103	126	131	131	0	0.738	2.237
Plant Loading	10 min	568	568	553	552	548	0.666	0	-1.459
	5	593	592	558	556	549	1.333	-0.246	-2.334
	20	599	597	565	562	550	1.444	-0.492	-3.112
	25	608	609	571	567	552	1.000	-0.738	-3.307
	30	610	608	576	571	555	0.666	-0.492	-3.112
Full Load Steady State	613	613	607	598	574	0	0	-0.584	
Hour Unloading	10 min	592	592	602	593	573	-1.000	0	0.973
	5	577	577	596	589	572	-1.333	0	1.948
	20	561	562	590	583	570	-1.666	0.246	2.723
	25	552	554	584	578	568	-1.333	0.492	2.918
	30	549	552	578	574	566	-0.666	0.738	2.589

**COMBUSTION ENGINEERING, INC.**

ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

NUMBER 5-212P | A196

SHEET 24 OF 80

CHARGE NO. \_\_\_\_\_

DATE 4-22-64 BY COCKRILL

DESCRIPTION STRUCTURAL AND FATIGUE EVALUATION  
OF OUTLET NOZZLE - VESSEL SUMMIT

CHECK DATE 2-27-64 BY HANFORD

5. DETAILED ANALYSIS:

1. PRESSURE AND THERMAL INTERACTIONS:

2. DEFLECTIONS:

IRADIANT	$T_{11} \& T_{21}$	$T_{22} \& T_{32}$	$T_{33} \& T_{43}$	$T_{54}$	$T_{64}$	$(\Delta T)_{21,11}$	$(\Delta T)_{22,21}$ & $(\Delta T)_{32,22}$	$(\Delta T)_{33,32}$ & $(\Delta T)_{43,33}$
2.5 F	584	526	584	584	584	0	0	-0.584
3.5 MIN	620	520	609	575	575	↓	↓	↓
11 MIN	624	624	606	575	575	↓	↓	↓
15.5 MIN	591	591	602	574	574	↓	↓	↓
10 SEC	612	612	607	574	574	↓	↓	↓
90 SEC	593	593	603	573	573	↓	↓	↓
100	100	100	100	100	100	0	0	0
1.0	392	388	340	333	334	1.0	-0.985	-4.668
3.0	400	400	400	400	400	0	0	0
5.0	108	112	160	167	166	-1.0	0.985	4.668
3.0	613	613	613	574	574	0	0	-0.584
12 SEC	613	613	607	573	573	↓	↓	↓
3.5 SEC	629	609	606	573	573	↓	↓	↓
12 SEC	616	616	603	574	574	↓	↓	↓
26 CH	618	618	608	575	575	↓	↓	↓
144 SEC	595	595	603	575	575	↓	↓	↓
100	547	547	547	547	547	↓	↓	↓

**COMBUSTION ENGINEERING, INC.**

ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

CHARGE NO. \_\_\_\_\_

NUMBER 5-212-P A197

SHEET 75 OF 80

DATE 4-22-68 BY COCKRILL

DESCRIPTION STRUCTURAL AND FATIGUE EVALUATION  
OF OUTLET NOZZLE - VESSEL SUPPORTS

CHECK DATE 4-22-68 BY HEILNER

5. DETAILED ANALYSIS:

1. PRESSURE & THERMAL INTERACTION:

2. DEFLECTIONS:

TRANSIENT	$\frac{\Delta T}{\Delta T_{0.5}}$ & $\frac{\Delta T}{\Delta T_{1.0}}$	$\frac{\Delta T}{\Delta T_{1.0}}$	M <sub>1T</sub>	M <sub>2T</sub>	M <sub>3T</sub>	M <sub>4T</sub>	M <sub>5T</sub>	
Heating	4.00 HRS	-0.433	0.250	1.432	2.296	201.261	259.971	320.808
	4.25	-0.433	-0.250	1.439	2.307	202.228	262.483	322.358
	4.35	-0.433	-0.250	1.446	2.318	203.196	263.739	323.908
	4.47	-0.433	0	1.453	2.328	204.164	264.995	325.458
	5.00	-0.667	0	0	2.677	98.958	136.549	174.296
NO LOAD STEADY STATE	0	0	0	0	0	0	0	
Cooling	4.00 HRS	0.433	-0.250	-1.432	-2.296	-201.261	-259.971	-320.808
	4.25	0.433	-0.250	-1.439	-2.307	-202.228	-262.483	-322.358
	4.35	0.433	-0.250	-1.446	-2.318	-203.196	-263.739	-323.908
	4.47	0.433	0	-1.453	-2.328	-204.164	-264.995	-325.458
	5.00	0.667	0	0	-0.677	-98.958	-136.549	-174.296
Plant Loading	10 MIN	-0.133	0	2.219	2.199	67.384	78.067	11.623
	15	-0.267	-0.100	2.511	2.571	107.043	123.200	16.178
	20	-0.400	-0.400	2.825	2.946	142.450	169.119	22.245
	25	-0.533	-0.700	1.070	1.655	145.947	150.557	18.706
	30	-0.667	-1.050	0.646	1.090	134.611	178.923	15.167
FULL LOAD STEADY STATE	-1.200	-0.500	0	0	23.488	95.758	-108.694	
Plant Unloading	10 MIN	-1.200	-2.750	-2.300	-2.129	-42.350	7.834	-120.431
	15	-0.933	-2.750	-2.531	-2.601	-82.208	-40.630	-125.024
	20	-0.933	-2.500	-2.619	-2.739	-118.670	-82.080	-150.637
	25	-0.800	-2.000	-1.020	-1.460	-120.442	-100.958	-128.000
	30	-0.533	-1.750	-0.420	-1.040	-111.940	-94.772	-121.397

**COMBUSTION ENGINEERING, INC.**

ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

NUMBER 5-212-P

A198

SHEET 26 OF 80

DATE 4-22-68 BY SMYRELL

CHARGE NO. \_\_\_\_\_

CHECK DATE 4-22-69 BY HELMER

DESCRIPTION STRUCTURAL AND FATIGUE EVALUATION  
OF OUTLET NOZZLE - VESSEL SUPPORT

DETAILED ANALYSIS:

1. PRESSURE AND THERMAL INTERACTION:

2. DEFLECTIONS:

DISPLACEMENT	$(\Delta T) \frac{E}{\Delta T} \frac{(\Delta T)}{\Delta T}$	$(\Delta T) \frac{E}{\Delta T} \frac{(\Delta T)}{\Delta T}$	$M_{1T}$	$M_{2T}$	$M_{3T}$	$M_{4T}$	$M_{5T}$
10 sec	-1.200	-4.500	0	0	23.488	35.758	-108.694
3.5 min							
11 min							
15.5 min							
10 sec							
90 sec							
0	0	0	0	0	0	0	0
H.U. 3.0415	-0.933	0	1.453	2.328	204.164	264.995	325.458
55	0	0	0	0	0	0	0
60 3.0415	0.933	0	-1.453	-2.328	-204.164	-264.995	-325.458
2	-1.200	-4.500	0	0	23.488	35.758	-108.694
12.5 sec							
18.5 sec							
12.5 sec							
26.5 sec							
140 sec							
n							

WITH THE EXPRESSIONS FOR DISPLACEMENTS AS PRESENTED ON SHEETS 15 THRU 22 AND THE VALUES GIVEN ON SHEETS 23 - 25, THE FOLLOWING VALUES FOR DISPLACEMENT WERE DETERMINED.

**COMBUSTION ENGINEERING, INC.**

ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

CHARGE NO. \_\_\_\_\_

NUMBER 5-212-P

A199

SHEET 27 OF 30

DATE 4-22-63 BY COBBETT

DESCRIPTION STRUCTURAL AND FATIGUE EVALUATION OF OUTLET NOZZLE - VESSEL SUPPORTS

CHECK DATE 4-22-69 BY HEUER

5. DETAILED ANALYSIS:

d. PRESSURE & THERMAL INTERACTION:

2. DEFLECTIONS:

FOR RANGE OF STRESS

TRANSIENT	$E_{S17}$	$E_{S17}^*$	$E_{S217}$	$E_{S217}^*$	$E_{S227}$	$E_{S227}^*$	$E_{S227}$	$E_{S227}^*$	
HEATING	1.00 HRS	1550.1	3.927	1158.4	-2.911	1146.5	-2.911	1146.5	-15.577
	4.25	1649.4	3.926	1232.7	-2.911	1220.4	-2.911	1220.4	-15.578
	4.35	1697.5	3.925	1261.5	-2.910	1249.8	-2.910	1249.8	-15.575
	4.47	1734.2	3.923	1296.4	-2.909	1284.3	-2.909	1284.8	-15.570
	5.00	1765.3	0.0	1319.6	-2.179	1310.9	-2.179	1310.9	-7.459
NO LOAD STRESS STATE	1765.3	0.0	1319.6	0.0	1319.6	0.0	1319.6	0.0	
Cool down	1.00 HRS	213.2	-3.950	157.0	2.811	168.5	2.912	168.5	15.052
	4.25	116.0	-3.841	95.3	2.800	96.7	2.802	96.7	14.997
	4.35	77.3	-3.838	56.7	2.795	68.2	2.797	68.2	14.970
	4.47	30.9	-3.838	22.6	2.787	34.0	2.790	34.0	14.932
	5.00	0.0	0.0	0.0	0.0	8.5	0.0	9.5	7.140
Plant Loading	10 MIN	1846.4	2.610	1380.3	0.0	1380.3	0.0	1380.3	-4.860
	15	1903.9	5.219	1423.5	-0.725	1420.6	-0.725	1420.6	-7.769
	20	1964.8	5.647	1469.6	-1.449	1463.8	-1.449	1463.8	-10.351
	25	1998.9	3.908	1495.6	-2.173	1486.9	-2.173	1486.9	-10.996
	30	2006.4	2.602	1501.4	-1.448	1495.6	-1.449	1495.6	-10.347
Full Load STRESS STATE	2017.7	2.0	1510.1	0.0	1510.1	0.0	1510.1	-1.941	
Plant Unloading	10 MIN	1938.2	-3.912	1449.4	0.0	1449.4	0.0	1449.4	3.237
	15	1880.9	-5.720	1406.2	0.725	1406.2	0.725	1406.2	6.152
	20	1819.4	-6.530	1360.1	1.452	1363.0	1.451	1363.0	9.072
	25	1784.7	-5.227	1334.1	2.178	1339.9	2.178	1339.9	9.726
	30	1773.0	-2.612	1325.4	0.0	1334.1	0.0	1334.1	9.426

**COMBUSTION ENGINEERING, INC.**

ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

NUMBER 5-212-P

A200

SHEET 29 OF 30

CHARGE NO. \_\_\_\_\_

DATE 4-22-68 BY COCKRELL

DESCRIPTION STRUCTURAL AND FATIGUE EVALUATION

CHECK DATE 4-22-68 BY HELMER

OF OUTLET NOZZLE - VESSEL SUPPORTS

5. DETAILED ANALYSIS:

1. PRESSURE & THERMAL INTERACTION:

2. DEFLECTIONS:

FOR RANGE OF STRESS

PAUSEMENT	$E_{s1}$	$E_{s1}^*$	$E_{s1T}$	$E_{s1T}^*$	$E_{s2T}$	$E_{s2T}^*$	$E_{s3T}$	$E_{s3T}^*$
$\rightarrow f$	1907.7	0	1426.3	0	1426.3	0	1426.3	-1.944
5.5 min	2044.1		1530.6		1530.6		1530.6	-1.941
11 min	1983.8		1484.0		1484.0		1484.0	-1.942
15.5 min	1934.4		1446.5		1446.5		1446.5	-1.943
10 sec	2014.0		1507.2		1507.2		1507.2	-1.942
40 sec	1942.0		1452.3		1452.3		1452.3	-1.943
	0		0		0		0	0
N.O. 3.0 hrs	1152.4	3.919	857.1	-2.891	944.9	-2.890	944.9	-15.466
5.5 6.0 hrs	1184.4	0	891.3	0	901.3	0	901.3	0
2.0 hrs	30.9	-3.833	22.6	2.787	34.0	2.790	34.0	14.996
	2017.7	0	1510.1	0	1510.1	0	1510.1	-1.941
12 sec	2017.7		1510.1		1510.1		1510.1	-1.941
18.5 sec	2002.7		1498.5		1498.5		1498.5	-1.942
12 sec	2029.0		1518.9		1518.9		1518.9	-1.941
26 sec	2036.5		1524.7		1524.7		1524.7	-1.941
144 sec	1949.6		1458.0		1458.0		1458.0	-1.943
	1765.3		1319.6		1319.6		1319.6	-1.947

**COMBUSTION ENGINEERING, INC.**

ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

CHARGE NO. \_\_\_\_\_

NUMBER 5-212-P

A201

SHEET 29 OF 80

DATE 4-22-68 BY COOPER

DESCRIPTION STRUCTURAL AND FATIGUE EVALUATION  
OF OUTLET NOZZLE - VESSEL SUPPORTS

CHECK DATE 11-27-68 BY HEINKE

5- DETAILED ANALYSIS:

1. PRESSURE & THERMAL INTERACTIONS:

2. DEFLECTIONS:

FOR RANGE OF STRESS

TRANSIENT	$E_{337}$	$E_{337}^*$	$E_{427}$	$E_{427}^*$	$E_{447}$	$E_{447}^*$	$E_{547}$	$E_{547}^*$	
Nozzle	4.00 HRS	1261.7	-15.544	1261.7	-3.462	1235.1	-3.461	1242.7	3.927
	4.25	1356.5	-15.567	1356.5	-3.467	1330.0	-3.466	1327.6	2.929
	4.35	1394.2	-15.572	1394.2	-3.469	1367.8	-3.468	1375.4	2.929
	4.47	1439.2	-15.577	1439.2	-3.470	1413.0	-3.469	1416.7	0
	5.00	1565.5	-7.464	1565.5	-2.480	1547.1	-2.481	1547.1	0
No Load STRESS STATE	1660.9	0	1660.9	0	1660.9	0	1660.9	0	
Core Case	4.00 HRS	386.5	15.131	386.5	3.371	412.1	3.373	404.8	-0.904
	4.25	295.5	15.092	295.5	3.362	320.9	3.364	313.6	-0.901
	4.35	259.1	15.076	259.1	3.358	284.6	3.361	277.3	-0.900
	4.47	215.6	15.054	215.6	3.353	241.0	3.356	237.4	0
	5.00	93.0	7.177	93.0	2.385	110.9	2.387	110.9	0
Plant Loading	10 MIN	1682.7	-4.863	1682.7	-0.494	1679.1	-0.494	1664.5	0
	15	1700.9	-7.778	1700.9	-0.492	1693.6	-0.492	1668.2	-0.372
	20	1726.3	-10.267	1726.3	-1.485	1715.4	-1.485	1671.8	-1.486
	25	1749.1	-11.013	1749.1	-1.978	1733.6	-1.979	1679.1	-2.600
	30	1766.2	-10.361	1766.2	-2.475	1748.1	-2.476	1690.0	-3.900
Full Load STRESS STATE	1878.7	-1.942	1878.7	-4.447	1845.9	-4.448	1758.9	-16.699	
Plant Unloading	10 MIN	1860.5	3.236	1860.5	-4.447	1827.8	-4.447	1755.3	-10.205
	15	1838.7	6.147	1838.7	-3.459	1813.3	-3.460	1751.7	-10.206
	20	1816.9	9.060	1816.9	-3.460	1791.5	-3.461	1744.4	-9.279
	25	1795.2	9.711	1795.2	-2.967	1773.4	-2.968	1737.2	-7.424
	30	1773.4	8.416	1773.4	-1.977	1758.9	-1.978	1722.9	-6.497



COMBUSTION ENGINEERING, INC.  
 ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

NUMBER 5-212-P | A202  
 SHEET 30 OF 80

CHARGE NO. \_\_\_\_\_ DATE 4-22-68 BY COCKRELL

DESCRIPTION STRUCTURAL AND FATIGUE EVALUATION CHECK DATE 4-22-68 BY WILLIAMS  
OF OUTLET NOZZLE - VESSEL SUPPORTS

3. DETAILED ANALYSIS:  
1. PRESSURE & THERMAL INTERACTION:  
2. DEFLECTIONS:

FOR RANGE OF STRESS

TRANSIENT	$E_{ST}$	$E_{ST}^*$	$E_{DS}$	$E_{DST}^*$	$E_{DNT}$	$E_{DNT}^*$	$E_{DST}$	$E_{DST}^*$
$\sigma \rightarrow f$	1795.2	-1.944	1795.2	-4.451	1795.2	-4.451	1795.2	-16.691
3.5 MIN	1886.0	-1.942	1886.0	-4.446	1762.6	-4.453	1762.6	-16.698
11 MIN	1875.1		1875.1	-4.447	1762.6		1762.6	-16.698
155 MIN	1860.5		1860.5		1758.9		1758.9	-16.699
10 SEC	1878.7		1878.7		1758.9		1758.9	-16.699
90 SEC	1864.1		1864.1		1755.3		1755.3	-16.700
	0	0	0	0	0	0	0	0
H.O 3.0 HRS	980.9	-15.372	980.9	-3.424	854.3	-3.421	958.1	0
S.S.	1109.2	0	1109.2	0	1109.2	0	1109.2	0
C.O 3.0 HRS	215.6	15.119	215.6	3.353	241.0	3.356	237.4	0
	1900.6	-1.941	1900.6	-4.446	1758.9	-4.453	1758.9	-16.699
12 SEC	1878.7	-1.942	1878.7	-4.447	1755.3		1755.3	-16.700
185 SEC	1875.1		1875.1		1755.3		1755.3	-16.700
12 SEC	1882.4		1882.4		1758.9		1758.9	-16.699
26 SEC	1882.4		1882.4		1762.6		1762.6	-16.698
144 SEC	1864.1		1864.1		1762.6		1762.6	-16.698
	1660.9	-1.947	1660.9	-4.459	1660.9	-4.459	1660.9	-16.720

**COMBUSTION ENGINEERING, INC.**

ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

NUMBER S-212-P | A 203

SHEET 31 OF 80

CHARGE NO. \_\_\_\_\_

DATE 8-22-68 BY LOCKER

DESCRIPTION STRUCTURAL AND FATIGUE EVALUATION

CHECK DATE 4-22-69 BY HEILNER

OF OUTLET NOZZLE - VESSEL SUPPORTS

5- DETAILED ANALYSIS:

1.1. PRESSURE AND THERMAL INTERACTION:

2. DEFLECTIONS:

FOR PEAK STRESS

TRANSIENT		$E_{11}^*$	$E_{22}^*$	$E_{33}^*$	$E_{44}^*$	$E_{55}^*$	$E_{66}^*$	$E_{77}^*$	$E_{88}^*$
HEATING	4.0011P	561.0	9.707	1126.3	10.986	1193.1	17.661	-235.0	252.957
	4.25	1660.1	9.722	1199.9	11.050	1257.2	17.757	-167.7	251.146
	4.35	1699.3	9.744	1229.0	11.114	1296.7	17.853	-145.0	255.485
	4.47	1745.1	9.766	1263.9	11.160	1321.9	17.929	-116.6	256.738
	5.00	1765.3	0.0	1293.1	10.719	1331.3	11.931	679.6	125.233
NO LOAD STRESS STATE		1765.3	0.0	1319.6	0.0	1319.6	0.0	1719.6	2.0
COOLING	4.0011P	201.5	-9.623	189.1	-11.086	131.8	-17.759	1549.3	-253.382
	4.25	104.3	-9.637	117.6	-11.160	59.9	-17.965	1494.8	-254.727
	4.35	65.4	-9.657	99.2	-11.229	31.2	-17.966	1462.9	-256.045
	4.47	19.0	-9.676	55.2	-11.292	-5.1	-18.048	1435.4	-257.376
	5.00	0.0	0.0	26.5	-12.878	-18.9	-14.110	619.8	-125.552
PLATE LOADING	10 MIN	1964.6	10.005	1393.3	-4.354	1392.2	3.556	206.6	81.352
	15	1924.5	13.587	1424.2	-4.078	1426.0	5.021	694.2	132.488
	20	1987.9	15.062	1469.3	-4.202	1472.1	6.131	494.2	177.184
	25	2007.6	7.474	1474.0	7.057	1511.9	11.936	385.1	182.681
	30	2011.8	4.788	1485.2	5.646	1513.9	3.772	568.9	170.222
FULL LOAD STRESS STATE		2017.7	0.0	1510.1	0.0	1510.1	0.0	1847.3	29.885
PLATE UNLOADING	10 MIN	1919.4	-11.578	1439.9	7.376	1453.5	-0.554	1774.9	-50.184
	15	1460.2	-13.656	1405.9	3.923	1400.3	-5.265	1960.2	-100.397
	20	1798.0	-15.259	1361.6	3.854	1355.0	-5.739	2169.0	-146.626
	25	1776.3	-9.626	1350.1	-4.379	1320.9	-8.819	2166.1	-150.755
	30	1769.6	-4.012	1349.2	-11.060	1308.6	-13.674	2103.9	-141.316

**COMBUSTION ENGINEERING, INC.**  
 ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

NUMBER E-212-P | A204

SHEET 32 OF 80

CHARGE NO. \_\_\_\_\_

DATE 4-22-69 BY CHICKARL

DESCRIPTION: STRUCTURAL AND FATIGUE EVALUATION  
OF OUTLET NOZZLE - VESSEL SUPPORT

CHECK DATE 4-22-69 BY HEITZ

5. DETAILED ANALYSIS:

1. PRESSURE AND THERMAL INTERACTION:

2. DEFLECTIONS:

FOR PEAK STRESS

COMPONENT	$E_{011}$	$F_{011}$	$E_{027}$	$E_{017}$	$E_{027}$	$E_{027}$	$E_{027}$	$E_{027}$
1.8	1907.7	0.0	1426.3	0.0	1426.3	0.0	1263.5	29.883
3.5 MIN	2044.1		1532.6		1532.6		1367.7	29.985
11 MIN	1983.8		1494.0		1494.0		1321.1	29.984
155 MIN	1934.4		1446.5		1446.5		1283.6	29.983
10 SEC	2014.0		1507.2		1507.2		1344.4	29.985
90 SEC	1942.0		1452.3		1452.3		1299.4	29.983
	0.0		0.0		0.0		0.0	0.0
N.O.	1164.1	9.662	823.3	11.803	893.2	19.520	-556.4	256.842
5.0 MP	1194.4	0.0	921.3	0	921.3	0.0	991.3	0.0
5.5 C.D.	19.2	-9.576	56.4	-17.482	-4.3	-24.200	1435.4	-287.304
3.0 HRS	2017.7	0.0	1510.1	0.0	1510.1	0.0	1347.3	29.895
12 SEC	2017.7		1510.1		1510.1		1347.3	
195 SEC	2002.7		1498.5		1498.5		1335.6	
12 SEC	2029.7		1519.9		1519.9		1356.0	
26 SEC	2036.5		1524.7		1524.7		1361.8	
164 SEC	1949.6		1458.0		1458.0		1295.2	29.894
	1765.3		1319.6		1319.6		1156.7	29.879

**COMBUSTION ENGINEERING, INC.**

ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

NUMBER 5212-0

A 205

SHEET 33 of 36

CHARGE NO. \_\_\_\_\_

DATE 4-27-85 BY DOHERTY

DESCRIPTION STRUCTURAL AND FATIGUE EVALUATION  
OF OUTLET NOZZLE - VESSEL SUPPORTS

CHECK DATE 4-22-89 BY HEILGER

5. DETAILED ANALYSIS:

H. PRESSURE AND THERMAL INTERACTIONS:

2. DEFLECTIONS:

FOR PENN STRESS

COMBIBARY	$E_{11}^*$	$E_{22}^*$	$E_{33}^*$	$E_{44}^*$	$E_{55}^*$	$E_{66}^*$	$E_{77}^*$	$E_{88}^*$
Vertical	4.00-05	2190.1	229.757	1246.9	-12.979	1343.9	24.235	1741.3
	4.25	2234.4	241.124	1349.4	-12.886	1440.3	24.608	1456.7
	4.35	2326.5	232.541	1278.0	-12.933	1479.1	24.740	1574.9
	4.47	2295.1	243.955	1423.0	-12.978	1524.8	24.873	1516.7
	5.00	2025.6	138.057	1549.9	-6.144	1610.7	12.930	1602.7
1/10 Load STRESS STATE	1660.9	0.0	1660.9	0.0	1660.9	0.0	1660.9	0.0
Circumferential	4.00HRS	-546.3	-220.140	401.4	12.887	303.4	-24.295	306.2
	4.25	-672.4	-221.598	311.5	12.780	210.2	-24.673	214.6
	4.35	-643.2	-243.025	275.3	12.822	173.3	-24.811	177.8
	4.47	-712	-244.478	231.9	12.862	129.2	-24.949	157.4
	5.00	-367.1	-128.244	108.7	6.048	47.3	-12.923	57.4
Radial Longitudinal	10 MIN	1792.1	92.455	1686.3	-4.705	1705.1	7.018	1668.1
	15	2142.5	147.811	1707.3	-7.774	1734.1	10.783	1673.1
	20	2385.2	197.199	1730.0	-9.921	1775.2	15.191	1678.6
	25	2425.0	203.117	1744.9	-9.789	1803.2	16.527	1684.8
	30	2397.1	187.608	1750.5	-6.150	1827.8	17.201	154.7
Full Load STRESS STATE	1918.6	32.826	1824.3	0.771	1922.6	9.575	1725.5	1.062
Radial Circumferential	4.00 HRS	1670.0	-57.123	1104.2	4.697	1877.1	1.913	1718.3
	4.25	1465.4	-112.669	1782.4	7.916	1844.5	-1.916	1713.3
	4.35	1271.5	-165.549	1753.0	10.284	1809.6	-5.898	1704.3
	4.47	1236.9	-166.897	1752.1	8.965	1771.4	-9.980	1697.9
	5.00	1253.4	-156.067	1734.3	9.005	1756.0	-7.656	1692.6

**COMBUSTION ENGINEERING, INC.**

ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

CHARGE NO. \_\_\_\_\_

NUMBER 5-212-P

A 206

SHEET 34 OF 80

DATE 4-22-69 BY C. J. ...

DESCRIPTION STRUCTURAL AND FATIGUE EVALUATION  
DE OUTLET NOZZLE - VESSEL SUMMITS

CHECK DATE 4-22-69 BY W. H. ...

5. DETAILED ANALYSIS:

1. PRESSURE AND THERMAL INTERACTIONS:

2. DEFLECTIONS:

FOR PEAK STRESS

PARAMETER	$E_{DST}$	$E_{DST}^*$	$E_{DST}$	$E_{DST}^*$	$E_{DST}$	$E_{DST}^*$	$E_{DST}$	$E_{DST}^*$
$E_{DST}$	1905.1	32.805	1740.8	0.767	1871.8	9.572	1761.8	1.070
3.5 min	1995.9	32.806	1831.6	0.772	1839.2	9.571	1729.2	1.063
11 min	1984.9		1820.7	0.771	1839.2	9.571	1729.2	1.063
155 min	1970.4		1806.1		1835.6	9.571	1725.5	1.062
1050 cc	1988.6		1824.3		1835.6	9.570	1725.5	1.062
90 cc	1974.0		1809.7		1832.0	9.570	1721.9	1.061
	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
30 hrs	1027.7	244.159	464.6	-12.933	966.1	24.884	953.1	-53.180
55 CD	1109.2	0.0	1109.2	0.0	1109.2	0.0	1109.2	0.0
30 hrs	-731.2	-314.650	231.9	12.962	129.2	-24.449	137.4	53.180
K	2010.5	32.806	1846.2	0.772	1835.6	9.570	1725.5	1.062
12 sec	1988.6		1824.3	0.771	1832.0		1721.9	1.061
18.5 sec	1984.9		1813.9	0.771	1832.0		1721.9	1.061
12 sec	1992.2		1828.0	0.772	1835.6		1725.5	1.062
26 sec	1992.2		1828.0	0.772	1839.2	9.571	1729.2	1.063
148 sec	1974.0		1809.7	0.771	1839.2	9.571	1729.2	1.063
	1770.7	32.805	1606.5	0.759	1737.5	9.565	1627.2	1.041

**COMBUSTION ENGINEERING, INC.**

ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

NUMBER 5-212-P | A207

SHEET 35 OF 81

CHARGE NO. \_\_\_\_\_

DATE 5-2-49 BY POSTER

DESCRIPTION STRUCTURAL AND FATIGUE EVALUATION  
OF GULLET NOZZLE - VESSEL SUPPORTS

CHECK DATE 1-21-49 BY HEWITT

5. DETAILED ANALYSIS:

J. PRESSURE AND THERMAL INTERACTION:

3. CONTINUITY MATRIX AND LOADING VECTORS

WRITING THE COMPATIBILITY EQUATIONS IN MATRIX FORM

-149.1216	-32.2032	-53.2445	39.1819	0	0	0	0	0	U <sub>1</sub>
32.2032	24.1750	39.1819	-19.0519	0	0	0	0	0	M
-53.2445	39.1819	-142.0856	34.2037	-15.7440	6.9346	0	0	0	H <sub>1</sub>
-39.1819	-19.0519	-34.2083	22.7039	4.4781	-1.3550	0	0	0	M <sub>1</sub>
0	0	-12.5173	-3.5624	-32.7443	3.5240	-4.4438	2.9506	0	H <sub>3</sub>
0	0	-5.5112	-1.0776	-5.5230	1.6742	2.9506	-0.1142	0	H <sub>2</sub>
0	0	0	0	-4.9488	-0.9506	-12.4505	0.1470	0	H <sub>4</sub>
0	0	0	0	-0.9506	-0.1142	-0.5470	0.2582	0	M <sub>0</sub>

RANGE OF STRESS

PRESSURE	HEATUP					NO LOAD STRESS STATE	COLDOWN	
	T=6.0MS	T=9.25	T=135	T=147	T=500		T=1.00MS	T=1.25
13.36905	-391.7	-416.2	-426.0	-437.8	-445.7	-445.7	-54.3	-30.8
24.0550	-6.838	-6.836	-6.835	-6.832	-2.179	0	3.231	2.642
141.44742	0	0	0	0	0	0	0	0
46.44742	-12.667	-12.667	-12.665	-12.661	-5.290	0	12.240	12.195
109.67643	0	0	0	0	0	0	0	0
37.06395	12.082	12.099	12.104	12.107	4.984	0	-11.761	-11.730
243.4444	7.6	7.6	7.5	3.8	0	0	-7.3	-7.3
-19.08840	4.382	4.395	4.397	3.469	2.481	0	-4.277	-4.266

RANGE OF STRESS

COLD DOWN	PLANT LOADING						Full Load Stress State	
	T=135	T=147	T=500	T=1044	T=15	T=30		T=25
-20.5	-8.2	0	-466.1	-480.4	-495.2	-503.2	-505.0	-507.6
6.633	6.621	0	-2.610	-5.943	-7.096	-6.081	-4.051	0
0	0	0	0	0	0	0	0	0
11.173	2.142	7.140	-4.860	-7.044	-9.902	-8.923	-9.898	-1.941
0	0	0	0	0	0	0	0	0
-11.717	-11.701	-5.792	4.369	6.786	8.882	9.035	7.876	-2.505
-7.3	-3.16	0	-14.6	-25.3	-42.6	-54.5	-54.1	-87.0
-4.261	-3.356	-2.377	0.994	0.620	-0.001	-0.822	-1.424	-12.257

**COMBUSTION ENGINEERING, INC.**

ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

NUMBER 5-212-P | A 208

SHEET 36 OF 80

CHARGE NO. \_\_\_\_\_

DATE 4-22-68 BY LOCKRILL

DESCRIPTION STRUCTURAL AND FATIGUE EVALUATION

CHECK DATE 4-22-68 BY HEILOR

GE OUTLET NOZZLE - VESSEL SUPPORTS

5. DETAILED ANALYSIS:

1. PRESSURE AND THERMAL INTERACTIONS:

2. CONTINUITY MATRIX AND LOADING VECTORS:

RANGE OF STRESS

PLANT UNLOADING									
T-10MM	T-15	T-20	T-25	T-30	e	f	T-35MM	T-11	T-15.5
-489.8	-474.7	-459.3	-450.6	-447.6	-441.4		-513.5	-499.7	-497.9
3.912	5.945	7.972	7.405	2.612	0		0	0	0
0	0	0	0	0	0		0	0	0
3.257	5.427	7.621	7.549	9.426	-1.944		-1.941	-1.942	-1.943
0	0	0	0	0	0		0	0	0
-7.693	-9.606	-13.519	-12.679	-10.393	-2.507		-2.505	-2.505	2.505
-72.5	-61.6	-47.1	-36.2	-29.0	0		0	0	0
-5.756	-6.746	-5.819	-4.456	-4.519	-12.240		-12.245	-12.245	-12.246

RANGE OF STRESS

PLANT UNLOADING									
T-15.5	T-90	L	T-211.5	S.S.	T-2.000	K	T-12.5	T-18.5	
-506.7	-499.8	0	-295.3	-309.0	-9.2	-507.6	-507.6	-506.1	
0	0	0	-6.811	0	6.620	0	0	0	
0	0	0	0	0	0	0	0	0	
-1.942	-1.943	0	-12576	0	12.206	-1.941	-1.941	-1.942	
0	0	0	0	0	0	0	0	0	
-2.505	-2.505	0	11.948	0	-11.765	-2.504	-2.505	-2.505	
0	0	0	0	0	0	0	0	0	
-12.246	-12.246	0	3.421	0	-3.356	-12.246	-12.246	-12.246	

RANGE OF STRESS

PEAK STRESS

PLANT UNLOADING									
T-15.5	T-26	T-114	R	T-6MM	T-6.25	T-6.85	T-6.47	T-6.00	
-510.1	-511.8	-491.6	-445.7	-435.6	-440.2	-470.3	-472.2	-472.2	
0	0	0	0	2.287	2.328	2.370	2.394	10.719	
0	0	0	0	-1418.1	-1424.9	-1431.7	-1438.5	-708.7	
-1.941	-1.941	-1.949	-1.947	235.196	236.389	237.589	238.789	113.302	
0	0	0	0	-949.2	-953.9	-958.5	-963.1	-475.8	
-2.505	-2.505	-2.505	-2.512	-292.707	-294.009	-295.474	-296.933	-144.201	
0	0	0	0	-2.6	-4.1	-4.2	-8.0	-10.1	
-12.246	-12.245	-12.245	-12.241	-75.728	-76.353	-76.738	-77.053	-41.310	

**COMBUSTION ENGINEERING, INC.**  
 ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

NUMBER 5-210-P | A209

SHEET 37 OF 80

CHARGE NO. \_\_\_\_\_

DATE 4-22-68 BY COOPER

DESCRIPTION STRUCTURAL AND FATIGUE EVALUATION  
OF OUTLET NOZZLE - VESSEL SUPPORT

CHECK DATE 4-22-68 BY HEILNER

5- DETAILED ANALYSIS:

1. PRESSURE AND THERMAL INTERACTION:

3. CONTINUITY MATRIX AND LOADING VECTORS:

PEAK STRESS

NO. LOAD STRESSORS	COL. MAN					PLANT LOADING		
	T-225	T-225	T-225	T-225	T-225	T-1000	T-15	T-20
-445.7	-12.4	12.3	23.7	36.2	26.5	-492.8	-500.3	-513.7
0.0	-2.455	-2.528	-2.578	-2.606	-12.771	-14.357	-17.1665	-19.263
	1419.1	1424.9	1431.7	1438.5	708.7	-455.6	-731.9	-977.9
	-235.627	-236.862	-238.079	-239.329	-111.442	79.796	127.467	171.053
	949.2	953.9	959.5	962.1	475.3	-308.8	-495.2	-652.3
	293.02	294.378	295.856	297.340	144.393	-97.160	-155.585	-207.120
	5.9	4.4	4.5	9.2	10.1	-37.1	-61.0	-96.6
	75.812	76.445	76.837	78.129	41.403	-9.912	-12.792	-22.312

PEAK STRESS

PLANT LOADING			FULL LOAD			PLANT UNLOADING			e	f
T-25	T-20	TEMPERATURE	T-1000	T-15	T-20	T-25	T-20			
-533.6	-526.6	-507.6	-479.5	-454.3	-436.4	-426.2	-470.4	-491.4		
-9.417	0.857	0.0	18.954	17.579	19.113	4.248	-7.049	0.0		
-1026.8	-745.1	-162.9	276.4	559.9	814.0	945.2	795.4	-162.9		
171.745	161.250	29.895	-49.630	-95.132	-140.888	-161.936	-127.642	29.893		
-680.1	-641.5	-164.3	134.2	319.1	496.5	515.2	490.9	-164.3		
-212.907	-195.758	-52.035	61.820	120.584	173.833	175.863	165.073	-32.037		
-118.4	-133.1	-197.1	-158.8	-131.3	-105.3	-73.5	-65.3	-110.1		
-22.184	-22.579	-9.513	7.560	12.209	17.965	22.372	20.996	-9.503		

PEAK STRESS

g					j				
T-3500	T-11	T-55	T-1000	T-15	T-3500	S.S.	T-3500		
-513.5	-499.7	-497.9	-506.7	-499.8	0.0	-349.7	-303.0	37.1	
0.0	0.0	0.0	0.0	0.0		3.141	0.0	-8.906	
-162.9	-162.9	-162.9	-162.9	-162.9		-1439.7		1439.7	
29.895	29.884	29.893	29.895	29.893		238322		-263.104	
-164.3	-164.3	-164.3	-164.3	-164.3		-963.1		963.1	
-32.035	-32.035	-32.035	-32.035	-32.035		-297.092		327.512	
-110.1	-110.1	-110.1	-110.1	-110.1		-8.0		82	
-9.508	-9.508	-9.509	-9.509	-9.509		-78.064		79.129	