



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D.C. 20555-0001

January 17, 2012

Mr. Michael J. Annacone, Vice President  
Brunswick Steam Electric Plant  
Carolina Power & Light Company  
Post Office Box 10429  
Southport, North Carolina 28461

SUBJECT: BRUNSWICK STEAM ELECTRIC PLANT, UNITS 1 AND 2 – WITHDRAWAL OF  
AMENDMENT REQUESTS (TAC NOS. ME7669 AND ME7670)

Dear Mr. Annacone:

By letter dated December 5, 2011, Carolina Power & Light Company (the licensee) applied for amendments to the Brunswick Steam Electric Plant, Units 1 and 2, Renewed Operating License Nos. DPR-71 and DPR-62. The proposed change would have modified the facility technical specifications (TS) pertaining to TS 3.8.1, "AC Sources – Operating," to extend the Completion Time of TS 3.8.1 required Action D.4 for an inoperable diesel generator. Subsequently, by letter dated January 5, 2012, the licensee withdrew the amendment request.

The purpose of this letter is to advise that the above application is being treated as withdrawn. A notice of consideration of issuance of the proposed amendments had not been published in the *Federal Register*.

If you have any questions regarding this matter, please contact me at (301) 415-1447.

Sincerely,

A handwritten signature in cursive script that reads "Farideh E. Saba".

Farideh E. Saba, Senior Project Manager  
Plant Licensing Branch II-2  
Division of Operating Reactor Licensing  
Office of Nuclear Reactor Regulation

Docket Nos. 50-325 and 50-324

cc w/enclosure: Distribution via ListServ

January 17, 2012

Mr. Michael J. Annacone, Vice President  
Brunswick Steam Electric Plant  
Carolina Power & Light Company  
Post Office Box 10429  
Southport, North Carolina 28461

SUBJECT: BRUNSWICK STEAM ELECTRIC PLANT, UNITS 1 AND 2 – WITHDRAWAL OF AMENDMENT REQUESTS (TAC NOS. ME7669 AND ME7670)

Dear Mr. Annacone:

By letter dated December 5, 2011, Carolina Power & Light Company (the licensee) applied for amendments to the Brunswick Steam Electric Plant, Units 1 and 2, Renewed Operating License Nos. DPR-71 and DPR-62. The proposed change would have modified the facility technical specifications (TS) pertaining to TS 3.8.1, "AC Sources – Operating," to extend the Completion Time of TS 3.8.1 required Action D.4 for an inoperable diesel generator. Subsequently, by letter dated January 5, 2012, the licensee withdrew the amendment request.

The purpose of this letter is to advise that the above application is being treated as withdrawn. A notice of consideration of issuance of the proposed amendments had not been published in the *Federal Register*.

If you have any questions regarding this matter, please contact me at (301) 415-1447.

Sincerely,

/RA/

Farideh E. Saba, Senior Project Manager  
Plant Licensing Branch II-2  
Division of Operating Reactor Licensing  
Office of Nuclear Reactor Regulation

Docket Nos. 50-325 and 50-324

cc w/enclosure: Distribution via ListServ

DISTRIBUTION:

Public LPL2-2 r/f RidsNrrLACSola RidsNrrDorlLpl2-2  
RidsNrrPMBrunswick RidsOgcMailCenter RidsAcrsAcnw\_MailCTR RidsRgn2MailCenter  
RidsNrrDorlDpr Resource

ADAMS Accession No: ML12006A112

OFFICE	LPL2-2/PM	LPL2-2/LA	LPL2-2/BC	LPL2-2/PM
NAME	FSaba	CSola	DBroaddus	FSaba
DATE	1/6/12	1/6/12	1/12/12	1/17/12

OFFICIAL RECORD COPY