



**UNITED STATES  
NUCLEAR REGULATORY COMMISSION**  
REGION II  
245 PEACHTREE CENTER AVENUE NE, SUITE 1200  
ATLANTA, GEORGIA 30303-1257

January 11, 2012

Mr. William R. Gideon  
Vice President  
Progress Energy  
H. B. Robinson Steam Electric Plant, Unit 2  
3581 West Entrance Rd  
Hartsville, SC 29550

**SUBJECT: ROBINSON UNIT 2 - NOTIFICATION OF INSPECTION AND REQUEST FOR INFORMATION**

Dear Mr. Gideon:

From February 6-10, 2012, the NRC will perform the baseline in-service inspection (ISI) at the Robinson Unit 2 (NRC Inspection Procedure 71111.08). Experience has shown that this inspection is resource intensive both for the NRC inspectors and your staff. In order to minimize the impact to your on-site resources and to ensure a productive inspection, we have enclosed a request for documents needed for this inspection. These documents have been divided into two groups. The first group (section A of the enclosure) identifies information to be provided prior to the inspection to ensure that the inspectors are adequately prepared. The second group (section B of the enclosure) identifies the information the inspectors will need upon arrival at the site. It is important that all of these documents are up to date and complete in order to minimize the number of additional documents requested during the preparation and/or the onsite portions of the inspection.

We have discussed the schedule for these inspection activities with your staff and understand that our regulatory contact for this inspection will be Michael Pastva of your organization. Our inspection dates are subject to change based on your updated schedule of outage activities. If there are any questions about this inspection or the material requested, please contact the lead inspector Louis Lake at (404) 997-4683 (Louis.Lake@nrc.gov).

In accordance with 10 CFR 2.390 of the NRC's "Rules of Practice," a copy of this letter and its enclosure will be available electronically for public inspection in the NRC Public Document

Progress Energy

Room or from the Publicly Available Records (PARS) component of NRC's document system (ADAMS). ADAMS is accessible from the NRC Web site at <http://www.nrc.gov/reading-rm/adams.html> (the Public Electronic Reading Room).

Sincerely,

**/RA by Joel Rivera-Ortiz Acting For/**

Steven J. Vias, Chief  
Engineering Branch 3  
Division of Reactor Safety

Docket No. 50-261  
License No. DPR-23

Enclosure: Pre-Inspection Document Request

cc w/encl.: (See page 3 and 4)

Progress Energy

Room or from the Publicly Available Records (PARS) component of NRC's document system (ADAMS). ADAMS is accessible from the NRC Web site at <http://www.nrc.gov/reading-rm/adams.html> (the Public Electronic Reading Room).

Sincerely,

**/RA by Joel Rivera-Ortiz Acting For/**

Steven J. Vias, Chief  
Engineering Branch 3  
Division of Reactor Safety

Docket No. 50-261  
License No. DPR-23

Enclosure: Pre-Inspection Document Request

cc w/encl.: (See page 3 and 4)

Distribution w/encl:

R. Musser, RII, DRP  
J. Worosillo, RII, DRP  
J. Dodson, RII, DRP  
RIDSNRRDIRS  
PUBLIC  
RidsNrrPMRobinson Resource

PUBLICLY AVAILABLE     NON-PUBLICLY AVAILABLE     SENSITIVE     NON-SENSITIVE  
ADAMS:  Yes    ACCESSION NUMBER: ML# 120110278     SUNSI REVIEW COMPLETE     FORM 665 ATTACHED

OFFICE	RII: DRS/EB3	RII:L DRS/EB3						
SIGNATURE	/RA/	/RA by Joel Rivera-Ortiz Acting For/						
NAME	L.Lake	S. Vias						
DATE	1/ 11 /2012	1/ 11 /2012						
E-MAIL COPY	<b>YES</b> NO	<b>YES</b> NO	<b>YES</b> NO	YES NO	YES NO	YES NO	YES NO	YES NO

OFFICIAL RECORD COPY    DOCUMENT NAME: \SHAREPOINT\RII\DRS\EB3\INSPECTION RFI\ROB ISI RFI\_2012.DOCX

## Progress Energy

cc w/encl:

Division of Radiological Health  
TN Dept. of Environment & Conservation  
401 Church Street  
Nashville, TN 37243-1532

Donald W. Barker  
Manager, Nuclear Oversight  
H. B. Robinson Steam Electric Plant, Unit 2  
Progress Energy  
Electronic Mail Distribution

Robert J. Duncan II  
Vice President  
Nuclear Operations  
Progress Energy  
Electronic Mail Distribution

Sandra Threatt, Manager  
Nuclear Response and Emergency  
Environmental Surveillance  
Bureau of Land and Waste Management  
Department of Health and Environmental  
Control  
Electronic Mail Distribution

Brian C. McCabe  
Manager, Nuclear Oversight  
Shearon Harris Nuclear Power Plant  
Progress Energy  
Electronic Mail Distribution

Richard Hightower  
Supervisor  
Licensing/Regulatory Programs  
Progress Energy  
Electronic Mail Distribution

Scott D. West  
Superintendent Security  
H. B. Robinson Steam Electric Plant  
Progress Energy  
Electronic Mail Distribution

Joseph W. Donahue  
Vice President  
Nuclear Oversight  
Progress Energy  
Electronic Mail Distribution

David T. Conley  
Senior Counsel  
Legal Department  
Progress Energy  
Electronic Mail Distribution

John H. O'Neill, Jr.  
Shaw, Pittman, Potts & Trowbridge  
2300 N. Street, NW  
Washington, DC 20037-1128

Richard Haynes  
Director, Division of Waste Management  
Bureau of Land and Waste Management  
S.C. Department of Health and  
Environmental Control  
Electronic Mail Distribution

Kelvin Henderson  
General Manager  
Nuclear Fleet Operations  
Progress Energy  
Electronic Mail Distribution

Thomas Cosgrove  
Plant General Manager  
H.B. Robinson Steam Electric Plant, Unit 2  
Progress Energy  
Electronic Mail Distribution

Donna B. Alexander  
Manager, Nuclear Regulatory Affairs  
(interim)  
Progress Energy  
Electronic Mail Distribution

Robert P. Gruber  
Executive Director  
Public Staff - NCUC  
4326 Mail Service Center  
Raleigh, NC 27699-4326

W. Lee Cox, III  
Section Chief  
Radiation Protection Section  
N.C. Department of Environmental  
Commerce & Natural Resources  
Electronic Mail Distribution

(cc w/encl: continued on page 4)

## Progress Energy

(cc w/encl: continued from page 3)

Greg Kilpatrick  
Operations Manager  
H.B. Robinson Steam Electric Plant, Unit 2  
Progress Energy  
Electronic Mail Distribution

Mark Yeager  
Division of Radioactive Waste Mgmt.  
S.C. Department of Health and  
Environmental Control  
Electronic Mail Distribution

Public Service Commission  
State of South Carolina  
P.O. Box 11649  
Columbia, SC 29211

Chairman  
North Carolina Utilities Commission  
Electronic Mail Distribution

Henry Curry  
Training Manager  
H.B. Robinson Steam Electric Plant, Unit 2  
Progress Energy  
Electronic Mail Distribution

Senior Resident Inspector  
U.S. Nuclear Regulatory Commission  
H. B. Robinson Steam Electric Plant  
2112 Old Camden Rd  
Hartsville, SC 29550

Christos Kamilaris  
Manager, Support Services  
H.B. Robinson Steam Electric Plant, Unit 2  
Progress Energy  
Electronic Mail Distribution

John W. Flitter  
Director of Electric & Gas Regulation  
South Carolina Office of Regulatory Staff  
Electronic Mail Distribution

## INSERVICE INSPECTION DOCUMENT REQUEST

Inspection Dates: February 6-10, 2012

Inspection Procedures: IP 71111.08 "Inservice Inspection (ISI) Activities"

Inspectors: Louis Lake, Senior Reactor Inspector (Lead Inspector - ISI)

### A. Information Requested for the In-Office Preparation Week

The following information should be sent to the Region II office in hard copy or electronic format (CD preferred), in care of Louis Lake by January 27, 2012, to facilitate the selection of specific items that will be reviewed during the onsite inspection week. The inspector will select specific items from the information requested below and then request from your staff additional documents needed during the onsite inspection week (section B of this enclosure). We ask that the specific items selected from the lists be available and ready for review on the first day of inspection. \*Please provide requested documentation electronically if possible. If requested documents are large and only hard copy formats are available, please inform the inspector, and provide subject documentation during the first day of the onsite inspection. If you have any questions regarding this information request, please call the inspector as soon as possible.

#### A.1 ISI / Welding Programs and Schedule Information

- a) A detailed schedule (including preliminary dates) of:
  - i) Nondestructive examinations (NDEs) planned for Class 1 & 2 systems and containment, performed as part of your ASME Section XI, Risk Informed (if applicable), and augmented ISI Programs during the upcoming outage.  
  
Provide a status summary of the NDE inspection activities vs. the required inspection period percentages for this Interval by category per ASME Section XI, IWX-2400. (Do not provide separately if other documentation requested contains this information)
  - ii) Reactor pressure vessel head (RPVH) examinations planned for the upcoming outage.
  - iii) Examinations planned for Alloy 82/182/600 components that are not included in the Section XI scope. (If applicable)
  - iv) Examinations planned as part of your Boric Acid Corrosion Control Program. (Mode 3 walkdowns, bolted connection walkdowns, etc.)
  - v) Welding activities that are scheduled to be completed during the upcoming outage. (ASME Class 1, 2, or 3 structures, systems, or components (SSCs))

Enclosure

- b) A copy of ASME Section XI Code Relief Requests and associated NRC Safety Evaluations applicable to the examinations identified above.
- c) A list of NDE reports (ultrasonic, radiography, magnetic particle, and dye penetrant) which have identified surface or volumetric indications that were analytically evaluated and accepted for continued service on Code Class 1, 2, & 3 systems since the beginning of the last refueling outage. This should include the previous Section XI pressure test(s) conducted during start up and any evaluations associated with the results of the pressure tests.
- d) A list with a brief description (e.g. system, material, pipe size, weld number, and NDE performed) of the welds in Code Class 1, 2, and 3 systems which have been fabricated due to component repair/replacement activities since the beginning of the last refueling outage, or are planned to be fabricated this refueling outage. Also, please indicate which of those welds are risk significant.
- e) If reactor vessel shell weld examinations required by the ASME Code are scheduled to occur during the upcoming outage, provide a detailed description of the welds to be examined, and the extent of the planned examination. Please also provide reference numbers for applicable procedures that will be used to conduct these examinations.
- f) Copy of any 10 CFR Part 21 reports applicable to your SSCs within the scope of Section XI of the ASME Code that have been identified since the beginning of the last refueling outage.
- g) A list of any temporary non-code repairs in service (e.g. pinhole leaks).
- h) Please provide copies of the most recent self assessments for the ISI, Welding, and Alloy 600 Programs.

A.2 Reactor Pressure Vessel Head (RPVH): If this inspection will not be performed, this outage provide when the last inspection was performed and what type of inspection was performed.

- a) Provide the detailed scope of the planned NDE of the reactor vessel head which identifies the types of NDE methods to be used on each specific part of the vessel head to meet the augmented inspection requirements of 10CFR50.55a(g)(6)(ii)(D). Also, include examination scope expansion criteria and planned expansion sample sizes if relevant indications are identified. (If applicable)
- b) List the NDE reports with identified surface or volumetric indications in the RPVH penetration nozzles, which have been analytically evaluated and accepted for continued service. The list of NDE reports should include a brief description of the SSC where the recordable indication was identified.

A.3 Boric Acid Corrosion Control Program (BACCP)

- a) Copy of the procedures that govern the scope, equipment, and implementation of the inspections required to identify boric acid leakage and the procedures for boric acid leakage/corrosion evaluation.
- b) Please provide a list of leaks (including code class of the components) that have been identified since the last refueling outage and associated corrective action documentation. If during the last cycle, the Unit was shutdown, please provide documentation of containment walk-down inspections performed as part of the BACCP.
- c) Please provide a copy of the most recent self-assessment performed for the BACCP.

A.4 Steam Generator (SG) Inspections

- a) Please include a copy of the Operational Assessment from last outage, and a copy of the following documents as they become available:
  - i) Degradation Assessment
  - ii) Condition Monitoring Assessment

A.5 Additional information related to all ISI activities

- a) A list with a brief description of ISI, BACCP, and SG ISI related issues (e.g., condition reports) entered into your corrective action program since the beginning of the last refueling outage (for Units 3 and 4). For example, a list based upon data base searches using key words related to piping or SG tube degradation such as: ISI, ASME Code, Section XI, NDE, cracks, wear, thinning, leakage, rust, corrosion, boric acid, or errors in piping/SG tube examinations.
- b) Please provide names and phone numbers for the following program leads:
  - i) ISI contacts (Examination, planning)
  - ii) Containment Exams
  - iii) PVH Exams
  - iv) Snubbers and Supports
  - v) Repair and Replacement Program Manager
  - vi) Licensing Contact
  - vii) Site Welding Engineer
  - viii) Boric Acid Corrosion Control Program
  - ix) SG Inspection Activities (site lead and vendor contact)



**B. Information to be provided on-site to the inspector at the entrance meeting (February 6, 2012):**

**B.1 ISI / Welding Programs and Schedule Information**

- a) Updated schedules for ISI/NDE activities, including SG ISI, planned welding activities, and schedule showing contingency repair plans, if available.
- b) For ASME Class 1, 2, and 3 welds selected by the inspector from the lists provided from section A of this enclosure, please provide copies of the following documentation for each subject weld:
  - i) Weld data sheet (traveler)
  - ii) Weld configuration and system location
  - iii) Applicable Code Edition and Addenda for weldment
  - iv) Applicable Code Edition and Addenda for welding procedures
  - v) Applicable weld procedures (WPS) used to fabricate the welds
  - vi) Copies of procedure qualification records (PQRs) supporting the WPS from B.1.b.v
  - vii) Copies of mechanical test reports identified in the PQRs above
  - viii) Copies of the nonconformance reports for the selected welds (If Applicable)
  - ix) Radiographs of the selected welds and access to equipment to allow viewing radiographs (If RT was performed)
  - x) Copies of the pre-service examination records for the selected welds.
  - xi) Copies of welder performance qualifications records applicable to WPS, including documentation that welder maintained proficiency in the applicable welding processes specified in the WPS (At least six months prior to date subject work)
  - xii) Copies of NDE personnel qualifications (VT, PT, UT, RT) *As applicable*
- c) For the ISI related corrective action issues selected by the inspector from section A of this enclosure, provide a copy of the corrective actions and supporting documentation.
- d) For the NDE reports with relevant indications on Code Class 1, 2, & 3 systems selected by the inspector from section A above, provide a copy of the examination records, examiner qualification records, and associated corrective action documents.
- e) A copy of (or ready access to) most current revision of the ISI Program Manual and Plan for the current Interval.
- f) For the NDEs selected by the inspector from section A of this enclosure, provide copy of the NDE procedures used to perform the examinations (including calibration and flaw characterization/sizing procedures). For ultrasonic examination procedures qualified in accordance with ASME Code, Section XI, Appendix VIII, provide documentation supporting the procedure qualification

(e.g., the EPRI performance demonstration qualification summary sheets). Also, include documentation of the specific equipment to be used (e.g., ultrasonic unit, cables, and transducers including serial numbers) and NDE personnel qualification records.

## B.2 Reactor Pressure Vessel Head (RPVH)

- a) Provide the NDE personnel qualification records for the examiners who will perform examinations of the RPVH.
- b) Provide drawings showing the following: (If a visual examination is planned for the upcoming refueling outage)
  - i) RPVH and CRDM nozzle configurations
  - ii) RPVH insulation configuration

The drawings listed above should include fabrication drawings for the nozzle attachment welds as applicable.

- c) Copy of NDE reports from the last RPVH examination.
- d) Copy of evaluation or calculation demonstrating that the scope of the visual examination of the upper head will meet the 95% minimum coverage required by ASME Code Case N-729-1 (If a visual examination is planned for the upcoming refueling outage).
- e) Provide a copy of the procedures that will be used to identify the source of any boric acid deposits identified on the RPVH. If no explicit procedures exist which govern this activity, provide a description of the process to be followed including personnel responsibilities and expectations.
- f) Provide a copy of the updated calculation of effective degradation years (EDY) and re-inspection years (RIY) for the RPVH crack initiation and propagation susceptibility parameters.
- g) Provide copy of the vendor qualification report(s) that demonstrates the detection capability of the NDE equipment used for the RPVH examinations. Also, identify any changes in equipment configurations used for the RPVH examinations which differ from that used in the vendor qualification or demonstration report(s).

## B.3 Boric Acid Corrosion Control Program (BACCP)

- a) Please provide boric acid walk down inspection results, an updated list of boric acid leaks identified so far this outage, associated corrective action documentation, and overall status of planned boric acid inspections.
- b) Please provide any engineering evaluations completed for boric acid leaks identified since the end of the last refueling outage. Please include a status of corrective actions to repair and/or clean these boric acid leaks. Please specify which known leaks, if any, have remained in service, or will remain in service as active leaks.

- c) In accordance with NRC inspection procedure 71111.08, the inspector would like to conduct an independent boric acid walk down of the Reactor Building early in the inspection week. Please have knowledgeable BACCP staff available to accompany the inspector during the walk down.

B.4 Codes and Standards

- a) Ready access to: (i.e. copies provided to the inspector to use for the duration of the inspection at the on-site inspection location, or room number and location where available)
  - i) Applicable editions of the ASME Code (Sections V, IX and XI) for the in-service inspection program and the repair/replacement program.

Inspector Contact Information:

Louis Lake.  
Senior Reactor Inspector  
404-997-4683  
Louis.Lake@nrc.gov

Mailing Address:

U.S. Nuclear Regulatory Commission  
Region II  
Attn: Louis Lake  
245 Peachtree Center Ave NE  
Suite 1200  
Atlanta, GA 30303