



January 5, 2012

SBK-L-12002

Docket No. 50-443

U. S. Nuclear Regulatory Commission  
ATTN: Document Control Desk  
Washington, DC 20555-0001

Seabrook Station

Withdrawal of License Amendment Request 11-05 Regarding Cold Leg Injection Permissive

Reference

NextEra Energy Seabrook, LLC letter SBK-L-11181, "License Amendment Request 11-05, License Amendment Request Regarding Cold Leg Injection Permissive," September 30, 2011

NextEra Energy Seabrook, LLC (NextEra) submitted License Amendment Request (LAR) 11-05 for an amendment to the Technical Specifications (TS) for Seabrook Station. The proposed change would add to the TS a new permissive (Cold Leg Injection Permissive) that would delay opening of the high head safety injection valves until reactor coolant system pressure decreased to the low pressure reactor trip setpoint.

Following submittal of the LAR, NextEra identified technical issues with the setpoint selected for the new permissive. As a result, NextEra is withdrawing the LAR from NRC review. NextEra expects to resolve the technical issues and submit a revised LAR by March 2012.

Should you have any questions regarding this letter, please contact Mr. Michael O'Keefe, Licensing Manager, at (603) 773-7745.

Sincerely,

NextEra Energy Seabrook, LLC

A handwritten signature in black ink, appearing to read "Paul Freeman".

Paul Freeman  
Site Vice President

A001  
MR

cc: NRC Region I Administrator  
J. G. Lamb, NRC Project Manager  
W. J. Raymond, NRC Senior Resident Inspector

Mr. Christopher M. Pope, Director Homeland Security and Emergency Management  
New Hampshire Department of Safety  
Division of Homeland Security and Emergency Management  
Bureau of Emergency Management  
33 Hazen Drive  
Concord, NH 03305

Mr. John Giarrusso, Jr., Nuclear Preparedness Manager  
The Commonwealth of Massachusetts  
Emergency Management Agency  
400 Worcester Road  
Framingham, MA 01702-5399