



Westinghouse Electric Company LLC
Hematite Decommissioning Project
3300 State Road P
Festus, MO 63028
USA

U.S. Nuclear Regulatory Commission	Direct tel: 314-810-3382
ATTN: Document Control Desk	Direct fax: 636-937-6380
Director, Office of Nuclear Material Safety and Safeguards	Email: roodgj@westinghouse.com
Washington, DC 20555-0001	Our ref: HEM-12-2
	Date: January 16, 2012

Subject: Request for Additional Alternate Disposal Approval and Exemptions for Specific Hematite Decommissioning Project Waste at US Ecology Idaho (License No. SNM-00033, Docket No. 070-00036)

- Reference:
- 1) Westinghouse (G. F. Couture) letter to NRC Document Control Desk HEM-09-52, dated May 21, 2009, "Request for Alternate Disposal Approval and Exemptions for Specific Hematite Decommissioning Project Waste" (ADAMS Accession No. ML091480071)
 - 2) Westinghouse (E. K. Hackmann) letter to Document Control Desk (NRC), HEM-09-146, dated December 29, 2009, "Response to Request for Additional Information - Alternate Waste Disposal" (ADAMS Accession No. ML100320540)
 - 3) Westinghouse (E. K. Hackmann) letter to NRC Document Control Desk, HEM-10-6, dated January 20, 2010, "Additional Information Concerning Alternate Waste Disposal" (ADAMS Accession No. ML100221416)
 - 4) Westinghouse (E. K. Hackmann) letter to NRC Document Control Desk, HEM-10-38, dated March 31, 2010, "Additional Information for Alternate Waste Disposal Authorization and Exemption" (ADAMS Accession No. ML100950386)
 - 5) Westinghouse (E. K. Hackmann) letter to Document Control Desk (NRC), HEM-10-46, dated May 24, 2010, "Additional Information and Clarifications Concerning 10 CFR 20.2002 Alternate Waste Disposal Authorization and Exemption for Specific Hematite Decommissioning Project Waste" (ADAMS Accession No. ML101450240)
 - 6) Westinghouse (E. K. Hackmann) letter to Document Control Desk (NRC), HEM-11-16, dated February 18, 2011, "Revised Technical Basis for Characterization of Decommissioning Soils Waste That is Subject to the Alternate Disposal Request for U.S. Ecology Idaho, Inc" (ADAMS Accession No. ML110530155)
 - 7) USNRC (Keith I. McConnell) letter to Westinghouse (E. K. Hackmann), dated October 27, 2011, Issuance of Hematite Amendment No. 58 Approving

Westinghouse Hematite Request for Alternate Disposal of Soil and Debris and Granting Exemptions to 10 CFR 30.3 and 10 CFR 70.3, (ADAMS Accession No. ML112560105)

- 8) Humboldt Bay, Unit 3 – Request for 10 CFR 20.2002 Alternate Disposal Approval and 10 CFR 30.11 Exemption of Waste For Disposal at US Ecology Idaho (ADAMS Accession No. ML101170554)

Dear Sirs:

Pursuant to 10 CFR 20.2002, Westinghouse Electric Company LLC (Westinghouse) requests that the U.S. Nuclear Regulatory Commission (NRC) approve alternate disposal of specified low-activity radioactive materials from our Hematite Decommissioning Project (HDP), License No. SNM-0033, for certain waste containing source material, byproduct material and Special Nuclear Material (SNM). The authority of 10 CFR 20.2002, and the requested exemptions from 10 CFR 30.3 and §70.3 licensing requirements for byproduct material and SNM would allow Westinghouse to transfer the specific waste for disposal at the US Ecology Idaho, Inc. (USEI) RCRA Subtitle C disposal facility near Grand View, Idaho. Idaho is not an NRC Agreement State; however, Idaho regulations and the Grand View facility permit provide for the acceptance of this material based on the exemptions requested.

Enclosure 1 is a Safety Assessment for Additional Hematite Project Waste at USEI, which was developed in coordination with USEI. This document summarizes the characteristics of the candidate waste material; the proposed manner and conditions of disposal; the nature of the disposal environment; the nature and location of other potentially affected facilities; projected doses to members of the public during transport operations and to USEI workers during railcar receipt, unloading, transport and disposal; and assessment of the potential post-closure doses, including cumulative impacts with the Reference 1 request.

The Safety Assessment projects that the proposed alternate disposal would contribute less than 0.8 millirem per year to any individual, meeting the standard in NUREG 1757 of generally limiting alternate disposal exposures to not more than “a few millirem per year” to any member of the public. When added to the prior HDP alternate disposal request (Reference 1), the dose to any individual post closure is 2.7 millirem per year.

The attached Safety Assessment also projects that the candidate waste will be several orders of magnitude below both concentrations that would present a criticality concern and U.S. Department of Transportation criteria for fissile material.

HDP’s additional request in this letter is similar to the request submitted in Reference 1, as augmented by responses to NRC requests for additional information in References 2 through 6. Reference 7 approved the Reference 1 request. This additional request is based on References 1 through 7 (as applicable).

Two major differences exist between this additional request and the previous request: 1) The volume in this request, while essentially the same approximate value as Reference 1, is composed of a mixture of concrete/asphalt, piping, soil, and miscellaneous equipment; 2) the total quantity of radionuclides is lower (0.3 Ci of Tc-99 as compared to 1 Ci; 2 Ci of U-234 as compared to 5 Ci; 0.1 Ci of U-235 as compared to 0.2; and 0.4 Ci of U-238 as compared to 0.8 Ci).

Because this request is similar in nature to the Reference 1 request and addresses the elements in the NRC Safety Evaluation Report that accompanied Reference 7, Westinghouse requests expedited review and approval of this request by July 2012.

Please contact me at 314-810-3382, or Kevin Davis at 314-810-3348, should you have questions or need additional information.

Sincerely,



Gerald J. Rood
Interim Director, Hematite Decommissioning Project

Enclosure: 1) Safety Assessment for Additional Hematite Project Waste at USEI

cc: w/o Enclosure
J. J. Hayes, NRC/FSME/DWMEP/DURLD
J. W. Smetanka, Westinghouse
M. M. LaFranzo, NRC Region III/DNMS/MCID
L. W. Camper, NRC/FSME/DWMEP
J. E. Kennedy, NRC/FSME/DWMEP/EPPAD/LL
Chad Hyslop, US Ecology Idaho, Inc.

Enclosure 1 to HEM-12-2

Safety Assessment for Additional Hematite Project Waste at USEI

**Westinghouse Electric Company LLC
US Ecology Idaho, Inc.**

(15 pages)

Westinghouse Electric Company LLC, Hematite Decommissioning Project

Docket No. 070-00036

**Safety Assessment for Additional Hematite Project Waste at USEI
Westinghouse Electric Company, LLC
US Ecology Idaho, Inc.**

1.	EXECUTIVE SUMMARY	2
2.	USEI FACILITY OPERATING HISTORY	2
3.	DISPOSAL FACILITY CHARACTERISTICS	3
4.	USEI WASTE ACCEPTANCE CRITERIA	3
5.	MATERIAL DESCRIPTION & SUITABILITY	4
6.	TRANSPORT AND DISPOSAL RADIOLOGICAL ASSESSMENTS	6
6.1	Dose Assessment Methodology	6
6.2	Gondola surveyor	7
6.3	Excavator operator	7
6.4	Gondola Cleanout	7
6.5	Truck Surveyor	8
6.6	Truck Driver	8
6.7	Stabilization Operator	8
6.8	Cell Operator	8
7.	POST-CLOSURE DOSE TO THE GENERAL PUBLIC	11
8.	CRITICALITY	13
9.	RECORDS OF TRANSFER	14
10.	REQUESTED NRC ACTIONS	15

Attachments

- 1) Characterization Data Summary in Support of Additional USEI Alternate Disposal Request, HDP-TBD-WM-906
- 2) Input Parameters, Microshield®¹ Software 7.02, Westinghouse Electric Company LLC, (08-MSD-7.02-1424).
- 3) Case Files, Microshield® Software 7.02, Westinghouse Electric Company LLC, (08-MSD-7.02-1424).
- 4) RESRAD Input Parameters
- 5) RESRAD Case Files
- 6) Intruder Dose Calculations – Construction Scenario
- 7) Intruder Dose Calculations – Intruder Well Drilling Scenario
- 8) Intruder Dose Calculations – Chronic Exposure for Intruder Well Drilling Scenario
- 9) HDP and USEI Occupational Injury and Illness Data
- 10) Nuclear Criticality Safety Assessment of the US Ecology Idaho (USEI) Site for Land Fill Disposal of Decontamination and Decommissioning Waste from the Hematite Site.

¹ MicroShield® is a registered trademark of Yale Security Inc., an ASSA ABLOY Group company

1 EXECUTIVE SUMMARY

This information and radiological safety assessment was developed in coordination with USEI's health physics staff. This document addresses the characteristics of the candidate waste material; the proposed manner and conditions of disposal; the nature of the disposal environment; the nature and location of other potentially affected facilities; projects doses to members of the public during transport operations and to USEI workers during railcar receipt, unloading, transport and disposal; and provides an assessment of the potential post-closure doses.

This Safety Assessment also demonstrates that the candidate waste will be several orders of magnitude below the U.S. Department of Transportation's criteria for fissile material and orders of magnitude below concentrations that would present a criticality concern.

The candidate waste comprises approximately 23,000 m³ of solid materials consisting of a mixture of concrete/asphalt, piping, soil, and miscellaneous equipment. Miscellaneous equipment includes ventilation equipment removed from the former process building as well as contaminated decommissioning equipment. These materials contain low concentrations of both special nuclear material (SNM) and byproduct material contaminants. A description of the waste to be disposed is included in Section 5 and includes physical and chemical properties of the waste required to conservatively assess risk under the proposed disposal conditions. Attachment 1 contains a detailed discussion of the characterization data available for the materials associated with this request. Westinghouse's proposed documentation of waste transfer is also discussed.

Projected alternate disposal would contribute approximately 0.8 mrem per year to any member of the public, well within the several mrem exposure standard set forth in NUREG 1757 for alternate disposal approvals. These findings support NRC approval of alternate disposal in accordance with 10 CFR 20.2002.

This Safety Assessment also supports an NRC concurrence that US Ecology can be exempted from byproduct material and SNM license requirements of 10 CFR 30.3 and §70.3, as allowed in §30.11 and §70.17. Such exemptions from regulation under the Atomic Energy Act for disposal purposes are consistent with the diffuse, low concentrations of contaminants in the waste and with such exemptions issued by NRC for managing equivalent or higher concentration wastes.

2 USEI FACILITY OPERATING HISTORY

USEI's operating history is described extensively in Reference 1. There have been no significant changes to USEI's operating permit, radioactive materials acceptance limits, or regulatory status since the date of Reference 1. USEI's operating history from Reference 1 is incorporated in this request by reference instead of duplication of Reference 1 (ML091480071).

Since May of 2009, USEI has received approval to dispose 200,000 cubic feet of low-activity decommissioning waste from the Pacific Gas & Electric Humboldt Bay nuclear power plant near Eureka, California (Reference 8). In addition, NRC has approved Westinghouse to dispose approximately 23,000 m³ of HDP decommissioning waste at USEI (Reference 7). NRC held two public meetings at Rimrock High School (Grand View, ID) to provide information to the local community and solicit public comments during review of exemption requests submitted by Westinghouse. USEI remains in compliance with its operating permit and has maintained VPP “Star” status with the OSHA Voluntary Protection Program. Information on occupational illness and injuries for the past 5 years for both USEI and HDP are provided in Attachment 9.

3 DISPOSAL FACILITY CHARACTERISTICS

A description of the USEI facility and waste placement practices is found in References 1, 2, and 3. Key documents contained in these previous submittals include:

- General Description (IDAPA 58.01.05.012 & 40 CFR 270.14(B)(1)) (Reference 1).
- Hazardous Waste Facility Siting License Application for Cell 16 (Reference 2).
- USEI Radiological Sampling – Air and Soil (Reference 2).
- Summary of Hydrogeologic Conditions and Groundwater Flow Model for US Ecology Idaho Facility, Grand View, Idaho (Reference 3).

The description of USEI from References 1 through 3 is incorporated in this request by reference instead of duplication of the referenced documents (ML091480071, ML100320540, ML100221416).

4 USEI WASTE ACCEPTANCE CRITERIA

USEI’s waste acceptance criteria are maintained on their website, nominally at: usecology.com/downloads/grand_view_forms/USEI_WAC.pdf

Idaho rules regulating radioactive materials are maintained on their website, nominally at: adm.idaho.gov/adminrules/rules/idapa58/0110.pdf

In summary, USEI is authorized to accept low concentration SNM and byproduct material if:

- The NRC specifically exempts the material under 10 CFR 30.11 §70.17 and
- The sum of all activity within the material is less than 3,000 pCi/g, and
- IDEQ reviews and concurs with the NRC exemption and USEI Safety Assessment.

5 MATERIAL DESCRIPTION & SUITABILITY

5.1 Summary

Westinghouse estimates the volume of the excavated waste that is a candidate for disposal at USEI to be approximately 23,000 cubic meters at an average waste density of 1.5 g/cm³ (e.g., approximately 38,700 tons). The waste consists of a mixture of solid materials (e.g., concrete/asphalt, piping, soil, and miscellaneous equipment) with low levels of SNM, source material, and byproduct material, specifically uranium enriched in U-235 at levels averaging below 10 percent, elevated levels of Tc-99 and trace concentrations of Pu-239, Am-241, and Np-237. The amounts of radionuclides are shown in Table 1 below. The technical basis for the radionuclide data contained in this Table is provided in Attachment 1. Material volumes and activity values presented in Table 1 already include an uncertainty multiplier of 1.5 to account for the potential to encounter more material than estimated based on existing data.

Table 1, Expected Radionuclides in Westinghouse Hematite Waste

Shipped Volume (m ³)	U-234 (Ci)	U-235 (Ci)	U-238 (Ci)	Tc-99 (Ci)
22848	2.2	0.1	0.4	0.3

The average total activity concentration (sum of all nuclides and progeny) for this waste is approximately 110 pCi/g or approximately 4 percent of USEI's 3,000 pCi/g total activity concentration limit. Less than 5% of the waste from Westinghouse is expected to contain concentrations of hazardous constituents identified in 40 CFR 261.24, including tetrachloroethylene, trichloroethylene, vinyl chloride, arsenic, mercury, or lead.

5.2 Waste Characterization Plan

Detailed characterization data and an accompanying analysis is contained in Attachment 1. Based on the analysis contained in that document, additional characterization will be performed prior to shipment of soils and piping covered under this request. No further characterization will be performed on the concrete/asphalt materials as discussed in Attachment 1. Attachment 1 also identifies that no additional sampling will be performed on the specific miscellaneous equipment identified in it. Additional equipment which may be identified as candidate material for USEI, e.g., water treatment system equipment, will be surveyed by health physics personnel using existing site procedures. Such equipment will have superficial surface contamination as a result of exposure to contaminated remediation materials during the course of the project. The results of these surveys will be used to determine the associated radionuclide inventory.

5.2.1 Soils

Westinghouse will subject soils associated with this request to the same sampling plan that was detailed in Reference 6 and will use the same radiological controls and programmatic elements detailed in Reference 2. The Tc-99 soil concentrations and variability associated with this request are lower than in the Reference 7 approval. The mean Tc-99 concentration and standard deviation associated with soils considered in this request are 13 pCi/g and 36 pCi/g respectively (Attachment 1). The mean Tc-99 concentration and

standard deviation used to develop the sampling approach approved by Reference 7 are 27 pCi/g and 225 pCi/g respectively (Reference 6).

The approach used to sample soils associated with this request will be identical to that approved by Reference 7, subject to the following changes to reflect the lower quantities of Tc-99 in this request:

1. The first two rows of the contingency plan tabulation (Reference 6, Attachment 1, Section 10) are revised as follows:

Parameter	Action Level	How Monitored	Actions
Total Quantity of Tc-99 shipped to USEI (mean)	<u>>0.21 Ci</u>	Running total activity (<u>both shipped and pending shipment</u>), based on laboratory sample results prior to shipment	<ul style="list-style-type: none"> • Reanalyze composite sample and/or analyze individual aliquots used to create the composite sample • Resample stockpile and re-evaluate • Ship material to alternate facility
95% Upper Confidence Level of the mean Tc-99 shipped to USEI (UCL(0.95))	<u>>0.32 Ci</u>	Running confidence interval (<u>both shipped and pending shipment</u>), based on laboratory sample results prior to shipment	<ul style="list-style-type: none"> • Reanalyze composite sample and/or analyze individual aliquots used to create the composite sample • Resample stockpile and re-evaluate • Ship material to alternate facility

2. Section 13.4 of Reference 6, Appendix A, is revised as follows

13.4 If it is determined that the updated mean Tc-99 activity and 95% UCL are within established limits (i.e., mean of 0.21 Ci and 95% UCL of 0.32 Ci), the material will be authorized for shipment.

5.2.2 Piping

As indicated in Attachment 1, piping from under Building 240 and 260 will be excluded from this request. Table 2, below, provides a summary of the sampling data for the remainder of the piping. Note that the samples represent concentrations in materials contained within the piping and does not consider the overall mass of the piping walls.

Parameter	Tc-99	U-234	U-235	U-238
No. Samples	10	10	10	10
Average	33	1479	57	209
Minimum	2	0	0	0
Maximum	174	6944	258	766
St. Dev.	52	2225	84	292

The sampling approach for the site piping was developed considering that a batch of piping would consist of approximately 100 m³ of material. This volume is equivalent to that of a rail car. The material in a single rail car was considered an appropriate batch of material since that is the unit of volume upon which waste management decisions are based. Accordingly, the number of samples required to ensure that the median concentration within that batch is less than the maximum observed value was determined using Visual Sampling Plan (True Average vs. Fixed Threshold, where the data is neither considered normal nor symmetrical). This analysis was performed for each of the four nuclides Tc-99, U-234, U-235, and U-238. The resultant number of samples required was 14 or one sample per 7.1 m³. This is equivalent to 1 sample per 250 ft³. Based on this analysis, HDP will collect a minimum of one sample per 250 ft³ of piping and will analyze each sample by gamma spectroscopy and for Tc-99.

6 TRANSPORT AND DISPOSAL RADIOLOGICAL ASSESSMENTS

Using multiple conservative exposure scenarios, the dose equivalent was calculated for the Maximally Exposed Individual (MEI). In all cases the MEI receives less than 1 mrem per year which is consistent with NUREG 1737's Vol.1, Rev.2, Consolidated Decommissioning Guidance - Decommissioning Guidance for Materials Licensees, Final Report, p. 15-31 criteria of a "few millirem/yr" to a member of the public. The transportation workers and workers at the USEI facility are treated as members of the public since the USEI facility is not licensed under the Atomic Energy Act.

Evaluations of both potential external and internal doses to workers are discussed below. Based on the conservatively projected length of time of exposure and proximity to waste, the MEI for transportation and disposal is a USEI excavation operator.

6.1 Dose Assessment Methodology

External dose rates were modeled for applicable source / receptor geometries using Microshield® Software, version 7.02 with the radionuclide concentrations based on Table 1, above. Microshield® Software input parameters are provided in Attachment 2. Results of these calculations are provided in Attachment 3.

In order to estimate potential internal dose during material handling, an airborne dust study was conducted for representative job categories and work locations at the rail unloading facility and disposal site. In the study, measurements were made of the workers' exposure rates to total and respirable dust. This study indicated that respirable dust levels ranged from 0.17 to 0.23 mg/m³ with an average of 0.2 mg/m³. Details of the dust study are contained in Attachment 2 to Reference 2.

Internal dose for all job functions was modeled using the maximum respirable dust loading observed, the dose conversion factors contained in Federal Guidance Report 11, and the radionuclide concentrations based on Table 1, above. The use of respiratory protection is noted in the narrative below; however, no correction is taken for the applicable protection factor.

Gondola railcars will be received at USEI's rail transfer facility (RTF). Based on the anticipated volume of material to be shipped, it is assumed that about 352 gondola cars will be received and that this volume of material will be transferred to the final disposal cell in approximately 1056 truckloads. The project is expected to ship over an 18 month timeframe. No adjustments were made for USEI's respiratory protection program.

Evaluations of both potential external and internal doses to USEI and transportation workers are discussed below. The results for USEI workers are summarized in Table 2. Even with the conservative assumptions used in this assessment, calculated doses (maximum value of 0.18 mrem) are extremely low and well within the USNRC's "few millirem" criteria for alternate disposal. The excavator operators, truck drivers, stabilization operators and cell operators at the USEI disposal facility do not share job functions.

Dose to transportation workers is presented in Section 6.9.

6.2 Gondola Railcar surveyor

Prior to being off-loaded, each gondola railcar will be surveyed. This work is shared between 8 personnel. The survey normally takes an operator 20 minutes to complete. The operator will stand approximately one meter from the gondola railcar when conducting the survey. The estimated radiation field, internal and external dose rates per gondola railcar and per surveyor are provided in Table 2. Internal dose is not assigned for this position since the waste in the gondola railcar remains covered during the survey.

6.3 Excavator operator

All unloading operations are conducted within a containment building employing a 24,000 cubic feet per minute (cfm) high efficiency particulate air (HEPA) filtration system. An excavator positioned on a bridge platform above the railcar will transfer the waste into waiting end-dump trucks. Two persons occupy the RTF during trans-loading: the excavator operator and the truck driver. Both remain in the cabs of their vehicles. The cab of each vehicle is air conditioned, with all air drawn through commercial HEPA filtration systems. The excavator operator is also equipped with respiratory protection during all active transload activities. Non-essential personnel are not permitted to enter the RTF building during waste trans-loading to minimize physical hazards.

An excavator operator removes the material from the gondola railcar and loads it into dump trucks for transport to the disposal site. It normally takes the excavator operator up to 45 minutes to unload a gondola railcar. The operator occupies a position approximately 2 meters from the material. Four excavator operators share the unloading job. The estimated radiation field, internal and external dose rates per gondola railcar and per operator are provided in Table 2.

6.4 Gondola Railcar Cleanout

After unloading, USEI personnel manually remove any residual material in each gondola railcar using shovels and brooms. The operation normally takes 10 minutes to complete. The eight personnel sharing this task stand inside an effectively empty gondola railcar. For

the purposes of dose modeling, the dose rate at 30 cm from a 1/2 inch layer of waste material is used. The estimated radiation field, internal and external dose rates per gondola railcar and per person are provided in Table 2.

6.5 Truck Surveyor

After each truck and its trailer are loaded, both are surveyed prior to driving to the disposal site. The survey usually requires five minutes to perform and the task is shared among eight personnel. The surveyor will stand an average of one meter from the exterior of the truck. The estimated radiation field and external dose rates per truck and per surveyor are provided in Table 2. Internal dose is not assigned for this position since the truck bed is covered prior to the survey step.

6.6 Truck Driver

The trip to the disposal site takes 45 minutes. The truck transport work is shared between 14 truck drivers. The estimated radiation field and external dose rates per truck and per surveyor are provided in Table 2. Internal dose is not assigned for this position since the truck bed remains covered during the survey.

6.7 Stabilization Operator

Less than 5 percent of the waste from Westinghouse is expected to contain constituents identified in 40 CFR 261.24 Tetrachloroethylene (D039), Trichloroethylene (D040), Vinyl Chloride (D043), Arsenic (D004), Mercury (D009), and Lead (D008). USEI's RCRA Part B permit allows the facility to accept this waste, treat it to meet USEPA Land Disposal Restrictions and dispose it in the facility's disposal cell. Treating the waste for hazardous metals or organics will require wetting the waste and mixing it with the appropriate reagents in a below-grade, RCRA-compliant treatment tank. All treatment activities will be conducted inside a containment building, with 50,000 cfm of negative airflow. The waste will be mixed by a stabilization operator. Six stabilization operators share this task. It normally takes the stabilization operator up to 45 minutes to perform this operation. The operator occupies a position approximately 2 meters from the material. The estimated radiation field, internal and external dose rates per gondola railcar and per operator are provided in Table 2 (based on 5 percent of the 352 gondola cars containing waste with constituents requiring stabilization).

6.8 Cell Operator

Some dose will also be accrued by the two disposal cell workers who will spread and compact the material once it has been deposited in the cell. For this exposure scenario, a dose rate from the deposited material was calculated based on the amount of material contained in one gondola railcar. Assuming 15 minutes to spread and compact each gondola railcar's contents, the total dose to each of those workers for the project was calculated. The estimated radiation field, internal and external dose rates per gondola railcar and per operator are provided in Table 2.

6.9 Transport Dose to Public

Transportation will be by gondola railcar. The contents of each gondola railcar will be entirely enclosed in form-fitting, sift-proof, and closable wrappers meeting U.S.

Department of Transportation (DOT) Industrial Type-1 Package (IP-1) requirements. The IP-1 package precludes dispersal of waste to the air or loss of material during transport.

The dose rate at 1m from a loaded gondola railcar is 0.18 $\mu\text{R/hr}$. The dose rate at 1 foot would be 0.25 $\mu\text{R/hr}$ based on Microshield® Software calculations (Attachment 3). The maximum dose to a site worker is 190 μR as shown in Table 2, below. In order for the dose to a bystander during transportation to exceed that of the site worker and therefore be bounding, the individual would have to spend 1007 hr at 1 meter from the gondola or 793 hr at 1 foot, which are not credible external exposure scenarios during transportation. Since the waste within the gondola railcars is contained during transport, no internal dose would be assigned to a by-stander. Information on transportation exposure times previously submitted (Response to Question 4 in Reference 4) demonstrates that the exposure times indicated above are orders of magnitude greater than the expected exposure times of less than 20 hours.

Table 2, Summary of Doses to USEI Workers during Transport, Treatment and Disposal of Westinghouse Hematite Waste

	Input Parameters				External dose rate (mrem/hr)	Dose (mrem/conveyance)		Individual Dose (mrem/worker)		
	No. of Workers	Minutes to perform task ¹	Distance from object (meters)	Type of conveyance modeled (count) ²		Internal ³	External ⁴	Internal ⁵	External ⁶	Total ⁷
Gondola surveyor	8	20	1	Gondola (352)	1.8E-04	9.3E-04	6.1E-05	NA ⁸	2.7E-03	2.7E-03
Excavator operator	4	45	2	Gondola (352)	1.4E-05	2.1E-03	1.1E-05	1.8E-01	9.4E-04	1.8E-01
Gondola Cleanout	8	10	1	Gondola (352)	2.3E-04	4.6E-04	3.8E-05	2.0E-02	1.7E-03	2.2E-02
Truck Surveyor	8	5	1	Truck (1056)	1.9E-04	2.3E-04	1.6E-05	NA ⁸	2.1E-03	2.1E-03
Truck Driver	14	45	0.6	Truck (1056)	2.2E-04	2.1E-03	1.6E-04	NA ⁸	1.2E-02	1.2E-02
Stabilization Operator	6	45	2	Gondola (18)	1.4E-05	2.1E-03	1.1E-05	6.1E-03	3.1E-05	6.1E-03
Cell Operator	2	15	1	Gondola (352)	1.8E-04	6.9E-04	4.4E-05	1.2E-01	7.8E-03	1.3E-01

1 The minutes assigned for each job function listed in Table 2 are the times estimated by knowledgeable and experienced site personnel for one person to perform each function one time.

2 Calculations based on volume of material in a gondola railcar.

3. Internal dose per conveyance calculated based on the product of the intake quantity of 0.23 mg/m³ of respirable dust, 1.2 m³/hr inhalation rate, individual radionuclide concentrations based on Table 1, dose conversion factors from FGR 11, and the handling times shown.

4 External dose per conveyance calculated based on the product of the external dose rate and handling time indicated.

5 Internal dose per individual worker calculated based on the internal dose per conveyance times the number of conveyances per year and divided by the total number of workers.

6 External dose per individual worker calculated based on the external dose per conveyance times the number of conveyances per year and divided by the total number of workers.

7 Total dose per individual worker is the sum of the internal dose per individual and external dose per individual.

8 Internal dose is not applicable for this job function because waste remains in the conveyance and is covered.

7 POST-CLOSURE DOSE TO THE GENERAL PUBLIC

7.1 Post Closure Analysis

The USEI disposal permit requires the operator to demonstrate that no person will receive a dose in excess of 15 millirem for 1,000 years after closure of the facility. The RESRAD code is used to establish post closure dose estimates. Most of the site-specific parameters are explained in the 2005 report titled "Site-specific RESRAD Water Pathway Parameters for the Contaminated Soil, Vadose Zone, and Saturated Zone" provided in Attachment 5 to Reference 2. For those parameters not described in the 2005 report, justification was provided in Reference 4. A technical basis for the long-term stability of the USEI site is also provided in Reference 4.

For purposes of its permit, USEI must demonstrate compliance with this limit where all radionuclides are assumed to be distributed homogeneously over the volume of the contaminated zone. In response to the NRC's comments in Reference 2, an additional model with more consolidated waste placement was generated for this analysis.

Westinghouse estimates that the waste material referenced in this submittal will be entirely removed and disposed of at USEI within an 18 month time period. Because Westinghouse's waste will be comingled with all other waste receipts at USEI over this time period, the consolidated placement is based on the average volume of waste received over the duration of the project. Over the past 5 years USEI has received an average of 725,000 tons of waste per year, so this analysis assumes the shipped materials from Westinghouse will be evenly distributed over 725,000 tons total waste.

In the RESRAD model, all waste is modeled as uniformly contaminated soil, rather than volumes of concrete and metal. The density of the contaminated zone is adjusted, however, to the average density of the materials received, including concrete rubble, soil, asphalt, piping and other metal debris (e.g., HEPA units and associated ductwork). The site-specific RESRAD model approved by the State of Idaho and incorporated into USEI's operating permit designates the Contaminated Zone Surface Area as 88,221 m². This area was established based on planned disposal cell construction and assumes disposal of radiological material across the entire aerial extent of the Contaminated Zone Surface Area. USEI estimates that the majority of the Hematite waste would most likely be disposed across approximately 40,468 m² based on the majority of disposal activities are occurring within two construction phases of the currently active disposal cell with a surface area of approximately 10 acres or roughly half of the cell (which is 88,221 m²).

For the purpose of the RESRAD model specific to Hematite waste, the height of the waste material in the disposal cell was calculated by dividing volume of waste disposed by the cell area. In a similar manner, the radionuclide concentration within the disposal cell was adjusted to account for dilution when mixed with non-Hematite waste. This dilution factor was determined by dividing the mass of Hematite waste by the total mass of waste received during this same time period. The only nuclide contributing to the post closure dose was determined to be Tc-99, resulting in a dose of 0.8 mrem at 247 years. The dose

contributions from Uranium 234, 235, and 238 are 1.4E-22 mrem, 5.1E-30 mrem, and 5.7E-26 mrem, respectively. Attachment 4 contains a detailed explanation of the RESRAD input parameters. Attachment 5 contains the RESRAD Case Files.

When combined with the post closure dose of 1.9 mrem associated with the previous HDP Submittal (Reference 5) the total dose from both applications is 2.7 mrem.

7.2 Intruder Construction Scenario

The intruder construction scenario performed for this request is based on the same methodology used in the prior request (Reference 4). This scenario is partly based on NUREG-0782 in which the inadvertent intruder is assumed to excavate or construct a building on a disposal site following a breakdown in institutional controls. The intruder is exposed to dust particles through the inhalation pathway, and may also be exposed to direct gamma radiation resulting from airborne particulates and from working directly in the waste-soil mixture.

For the Average Cell Concentration scenario, the waste is diluted by a factor of 0.053 to account for mixing within the USEI cell with 725,000 tons total waste. The 0.053 factor is calculated by taking the ratio of Hematite waste to total waste received (38,710 tons / 725,000 tons). For the One-Foot Layer scenario, the concentration is diluted by a factor of 0.31 (12 in/39 in) to account for USEI's practice of layering materials into pits in 1-ft layers and an assumption of 1 meter (39 in) of waste at the time of intrusion. The dose from the inhalation and from external gamma exposure is evaluated for a duration of 500 working hours, or a construction period of 3 months.

In the analysis supporting the Reference 1 request, an additional dilution factor of 0.5 was applied based on placement of non-containerized waste. This factor was not applied in the analysis performed for this request.

The intruder construction scenario performed for this request did not assume any credit for the mixing of the waste with the cover material, which ranges from 0.76 m (2.5 ft.) across the top to 6.10 m (20 ft.) down the side slopes (Reference 2). Since USEI restricts the emplacement of any radioactive waste to within 3.6 meters of the surface of the finished cap of the cell, the construction scenario could be disregarded as not being feasible. Furthermore, no credit was assumed for decay up to the intrusion event, or for waste form. The bounding dose for the construction intruder that Westinghouse calculates is 15 mrem, and assumes waste shipped at the WAC values is encountered in a one-ft layer.

Attachment 6 to this request contains the detailed assessment associated with the Intruder Construction Scenario.

7.3 Intruder Well Drilling Scenario

The inadvertent intruder analysis for this request is the same as that submitted with the prior request (Reference 4). The scenarios evaluated are based on the intruder construction scenario and the intruder well drilling scenario described in Appendix G of NUREG0782,

“Draft Environmental Impact Statement on 10 CFR Part 61 Licensing Requirements for Land Disposal of Radioactive Waste”. The Pathway Dose Conversion Factors (PDCFs) applied are taken from NUREG/CR– 4370, Volume 1.

In all intruder analyses two different assumptions for the concentration shipped from Hematite to USEI were applied. The first assumption utilized average concentration values based on Table 1. The second assumed that the total sum of radionuclide material shipped is at the USEI Waste Acceptance Criteria (WAC). Two dilution scenarios were also applied for the waste that the intruder contacts. One scenario, the Average Cell Concentration scenario, assumes waste is uniformly mixed within the USEI cell. The second, the One-Foot Layer scenario, assumes the intruder contacts a one-foot layer of waste at its shipping concentration. The Average Cell Concentration scenario was not evaluated for material received at the WAC since it would not be possible for Hematite to ship all of its waste under this request at the WAC. Regardless, this excluded scenario is not bounding (based on calculations submitted in Reference 4).

Two intruder well-driller scenarios were considered by Westinghouse. One was the acute well-driller. The other was the chronic well-driller.

The acute well-driller scenario assumes that the intruder digs a well by drilling through the waste disposal cell to reach the underlying aquifer at a depth of 93.1 m. The total period of exposure is 40 hours, 8 of which occur during the drilling through the contaminated layer. Therefore, for 8 hours, the driller is exposed to undiluted drill cuttings, and for the remaining 32 hours, the driller is exposed to the cuttings diluted by the ratio $(0.31/93.1$ or $3.3E-3)$ of the 1-ft contaminated layer (0.31 m) to the total well depth of 93.1 m. This dilution ratio is multiplied by the average cell concentration or the WAC concentrations. Westinghouse calculated a dose to the acute well-driller of 2.7 mrem based upon the intruder drilling through a 1-ft layer at the WAC concentrations.

The chronic well-driller scenario assumes that the intruder spreads the exhumed drill cuttings around the residence and grows a garden in soil containing the drill cuttings. The dose to the chronic well-driller calculated by Westinghouse was 0.5 mrem/yr based upon exposure to material exhumed during well drilling through 1 foot of waste at the WAC concentration (this scenario results in the maximum concentration for the exhumed material).

Attachments 7 and 8 this request contain the detailed assessment associated with Intruder Well Drilling Scenario.


7.4 Sensitivity Analysis

A sensitivity analysis was performed to evaluate the impact of project duration and average waste concentration on the post closure dose.

Variation in project duration results in a change in the volume of non-Hematite waste that is available for mixing and subsequently impacts the waste height and dilution factor. The results of this sensitivity analysis are contained in Figure 1, below. Input factors used in

the RESRAD analysis are contained in Attachment 4. As shown in this Figure, the post closure dose increases only slightly as the shipment time decreases, remaining below 1.6 mrem for a 13 week duration.

Figure 1, Sensitivity Analysis – Shipping Rate versus Post-Closure Dose.



A scenario was also evaluated in which all waste would be shipped at the USEI WAC containing Uranium at the same mixture as observed on average and containing no Tc-99. Since the Tc-99 exposure is entirely based on post closure dose and is inventory based, evaluation of shipment at higher concentration is not necessary as the exposure in the case of Tc-99 scales linearly with the total quantity of Tc-99 shipped. For the case of Uranium, increases in both worker and intruder dose would be seen. The maximally exposure on-site worker would remain the excavator operator with an annual exposure of 5.4 mrem. Post-closure intruder dose would be 2.9, 3.0, and 16 mrem for the Acute Well Driller, Chronic Well Driller, and Construction scenarios, respectively.

8 NUCLEAR CRITICALITY SAFETY

A criticality safety assessment (Attachment 10) demonstrates that the disposal of Hematite decommissioning waste at the USEI site can be safely performed. The assessment has determined that there are very large margins of safety under normal (i.e., expected) conditions and that there is considerable tolerance to abnormal conditions. Under all foreseen abnormal conditions a criticality event is considered either not credible or is precluded by controls in place at the Hematite site.

This analysis applies to disposal of Hematite decommissioning wastes with a maximum average fissile nuclide concentration of 0.1g ²³⁵U/L at the USEI site. The scope of this assessment is limited to wastes with the following attributes:

1. Debris generated from the demolition of the remaining auxiliary buildings/structures at the Hematite site; and
2. Subterranean structures such as subterranean piping, underground utilities, sewage, and soil in the vicinity of the aforementioned subsurface structures; and
3. Concrete and asphalt removed to gain access to underground utilities, piping and contaminated soil, and the septic drain field; and
4. Miscellaneous items/components generated from the demolition of the former process buildings; and
5. Miscellaneous contaminated equipment generated during Decontamination and Decommissioning operations.

9 RECORDS OF TRANSFER

10 CFR 70.42 (d)(2) requires a written certification by the transferee that the recipient is authorized by license or registration certificate to receive the type, form, and quantity of SNM to be transferred, specifying the license or registration certificate number, issuing agency, and expiration date. Since USEI would be exempted from the 10 CFR 70.3 requirement of an NRC licensee to possess SNM, the §70.42 requirement would not apply. However, Westinghouse will maintain as an alternative written registration certificate a copy of the permit issued to USEI by the State of Idaho and NRC approval of this additional alternate disposal request for specific HDP wastes. DOE/NRC Form 741, *Nuclear Material Transaction Report*, would be used by Westinghouse to document transfers of SNM to the disposal facility. USEI will report SNM receipts using its existing account with the Nuclear Materials Management & Safeguards System.

10 REQUESTED NRC ACTIONS

For the reasons noted above, Westinghouse requests that NRC take the following actions:

1. Approve 10 CFR 20.2002 alternate disposal of the specific HDP waste at USEI.
2. Issue 10 CFR 30.11 and 10 CFR 70.17 exemptions from the 10 CFR 30.3 and §70.3 license requirements for USEI to possess byproduct material and SNM for the specific waste disposal.

Attachment 1 to Enclosure 1 to HEM-12-2

**Characterization Data Summary In Support Of
Additional USEI Alternate Disposal Request**

(HDP-TBD-WM-906)

(62 pages)



Hematite Decommissioning Project

Technical Basis Document

NUMBER: HDP-TBD-WM-906

TITLE: Characterization Data Summary In Support Of
Additional USEI Alternate Disposal Request

REVISION: 0

EFFECTIVE DATE: See Final Approved Date Below

Approvals:

Author: Joseph S. Guido*

Owner: Joseph S. Guido*

** Electronically approved records are authenticated in the electronic document management system. This record was final approved on Jan-17-2012. (This statement was added by the EDMS system to the quality record upon its validation.)*

REVISION LOG

Revision No	Change(s)
0 See Cover Page	This is a new technical basis document.

1.0 PURPOSE

The purpose of this Technical Basis Document (TBD) is to document the basis that defines the radionuclide concentrations in Concrete and Asphalt Slabs, Miscellaneous Equipment, piping, and Soil.

2.0 APPLICABILITY

This document is applicable to the buildings slabs, miscellaneous equipment, piping, soil and soil-like waste generated by site decommissioning. Examples of these types of waste include:

- Slabs and subsurface footings associated with:
 - 115, Fire/Diesel Pump House
 - 235, West Vault
 - 245, Pump house
 - 252, South Vault
 - 101, Tile Barn
 - 120, Wood Barn
 - Sewage Treatment Shed
 - 240, Process Building
 - 253, Process Building
 - 254, Process Building
 - 255, Process Building
 - 256, Process Building
 - 260, Process Building
 - Limestone Building
 - Cistern Burn Pit
 - Site Dam
 - Head Wall
 - Exterior (outside process building) concrete pads and sidewalks
 - Site Asphalt
- Miscellaneous equipment such as process building HEPA units and associated ductwork
- Subsurface piping both under the process building and site wide
- Soil and soil-like waste

3.0 REFERENCES

- 3.1 HDP-TBD-WM-901, Scaling Factors for Radioactive Waste Associated with the Above Slab Portion of the Process Buildings

4.0 SUMMARY

This document provides the technical basis for the calculation of total volume and radionuclide activity contained in candidate materials for disposal at USEI. This material consists of approximately 2 million cubic feet of materials such as concrete, soil, asphalt, underground piping, and assorted bulk materials (such as HEPA units and associated ductwork).

The total activity and volume associated with each of these waste streams is summarized in Table 4-1, below. Note that the values in this table reflect a multiplier of 1.5 to account for uncertainty inherent in the excavation and removal of material during remediation. Exact volumes for each category are an estimate; disposal will be limited to the total volume shown below.

Table 4-1, Summary of material volume and concentration

Material	Shipped Volume (m ³)	U-234 (Ci)	U-235 (Ci)	U-238 (Ci)	Tc-99 (Ci)	wt % U-235
Concrete / Asphalt	8249	1.4E+00	6.3E-02	2.9E-01	4.0E-02	3.3
Piping	348	1.1E-01	3.9E-03	1.2E-02	2.6E-03	5.0
Miscellaneous Equipment	39	3.0E-03	1.7E-04	5.4E-04	3.8E-05	4.5
Soil	14212	6.2E-01	3.2E-02	1.4E-01	2.1E-01	3.4
Total / weighted Average	22848	2.2E+00	9.9E-02	4.4E-01	2.5E-01	3.4

5.0 VOLUME ESTIMATES – CONCRETE AND ASPHALT

The volume and weight of materials as installed associated with the structures defined above are based on visual inspection and physical measurement of the buildings.

Weight estimates for these materials were made based on the following assumptions.

- Concrete walls have an installed density of 75 pounds per cubic foot.
- Poured concrete has an installed density of 150 pounds per cubic foot.
- Asphalt has an installed density of 120 pounds per cubic foot.

The basic formula for calculating weight is:

$$\text{Weight} = (\text{Installed Volume})(\text{Installed Density})$$

Based on these assumptions, the weight and volume of material associated with the buildings to be demolished is summarized in Appendices A through C.

6.0 ACTIVITY ESTIMATES – BUILDING MATERIALS

Characterization of the process building slab (and outlying former process areas) was conducted between 2010 and 2011. During this time period, 21 sample cores were collected and sub sampled into top ¼ inch, next ½ inch and remainder. Another 29

sample locations (number 31 to 59) were collected in a second phase of sampling, aimed at bounding areas of elevated activity identified in the first round of sampling. Samples collected during the second phase were either analyzed as whole cores (locations 36 – 55), where divided into a top 3 inch and remainder (locations 31 – 35, located in the ‘red room’) or consisted of a top ¼ inch and next ½ inch portion only (locations 56 – 59). The final four samples (locations 56 - 59) were collected to provide additional bounding data and were not sampled below ¾ inch based on existing information indicating that contamination was limited to the top concrete layer only (i.e., there were no cracks and/or seems evident in the sampling locations). Sample analysis included isotopic uranium, Tc-99, Am-241, Np-237, Pu-239, Ra-226, and Th-232.

Following building demolition, a second walkover survey was conducted with readings being logged via global positioning system (GPS). This final walkover survey was used to guide the interpretation of sampling results in order to determine the total activity present in the material sampled. A detailed depiction of the process building slab gamma walkover survey as well as the associated sampling data is contained in Appendix D.

6.1. Evaluation of Trace Radionuclides

The top ¼ inch from the initial 21 sampling locations and the two ¼ inch samples taken beneath the concrete cap in Building 240 were analyzed for Am-241, Np-237 and Pu-239 by alpha spectroscopy (see appendix D, Table 2 for sample results). A summary of these sample results is provided in table 6-1, below.

Table 6-1, Concentration of Transuranic Nuclides in Process Building Slab Samples

Radionuclide	Samples Analyzed	Sample Results Exceeding MDC (pCi/g)	MDC (pCi/g)	U-total (pCi/g)
Am-241	23	0	0.14 – 0.27	NA
Np-237	23	Location 01: 0.08	0.03	193
		Location 07: 0.29	0.28	4,522
		Location 17: 0.13	0.12	1,461
Pu-239	23	Location 01: 0.11	0.10	193
		Location 09: 0.03	0.03	13,851
		Location 21: 0.14	0.08	200,048

As indicated in Table 6-1, above, the concentration of transuranic radionuclides is at or only slightly above the MDA of the analytical method. Considering the concentration of uranium at these sample locations (also shown in Table 6-1, above), these radionuclides are considered to be only present at trace levels and are not carried forward into subsequent inventory calculations.

6.2. Evaluation of Ra-226 in Building Materials.


The top ¼ inch and bottom portion (from ¾ inch to the bottom of the core sample) from the top ¼ inch samples were analyzed for Ra-226 (by gamma counting of radium progeny after ingrowth). Sample results are detailed in Appendix D, Table 3.

In order to evaluate the presence of Ra-226 in excess of that naturally present in building materials, the concentration within the top ¼ inch was compared to that in the bottom

portion. The basis for this methodology is the observation that the majority of the sample activity identified in the sampling effort indicated penetration of between ¼ to ¾ inch.

Review of this data indicates that the Ra-226 concentration observed in the top ¼ inch samples tends to fluctuate along with the corresponding U-234 concentration. The highest three Ra-226 sample results (3.1, 1.6, and 1.5 pCi/g) were obtained from locations containing the three highest U-234 concentration values (170,561, 37,544 and 36,426 pCi/g, respectively). Based on this observation, the Ra-226 concentration was adjusted by subtracting the product of the lowest observed Ra-226 to U-234 ratio (1.8 E-5) and the corresponding U-234 concentration from each Ra-226 result. The resulting concentration profile is shown in Figure 6-1, below. This figure demonstrates the similarity of the upper and lower core sample concentrations once this adjustment is performed. A detailed analysis of the two sample populations (upper and lower) is contained in Appendix E, the conclusion of which is that the upper sample population (adjusted) is less than or equal to the lower one. Since the Ra-226 contribution within the upper portion of the core samples is at least a factor of 1.8 E-5 times the corresponding U-234 concentration and is otherwise equal to the background concentration; Ra-226 is not considered further in this evaluation.

Figure 6-1, Ra-226 Concentration Profile - Upper, Adjusted Upper and Lower Core Samples




6.3. Evaluation of Th-232 in Building Materials.

The top ¼ inch and bottom portion (from ¾ inch to the bottom of the core sample) from the initial 21 sample locations were analyzed for Th-232 by alpha spectroscopy. Sample results are detailed in Appendix D, Table 3.

The relative Th-232 concentration in the upper ¼ inch building slab samples as compared to the concentrations in the remaining core material is shown in Figure 6-2. As indicated by this figure, the top ¼ inch sample portion appears contain elevated levels of Th-232 at some locations. Th-232 concentrations in the top ¼ inch sample portions range from non-detect to 1.4 pCi/g, as compared to an upper bound of 0.75 pCi/g for the lower sample portions. The ratio of Th-232 activity to U-234 in the top ¼ inch sample portions that were greater than the MDC ranged from 4.1 E-3 to 3.7 E-6 and averaged 5.2 E-4.

Considering the concentration of uranium at these sample locations, Th-232 is considered to be only present at trace levels, and Th-232 is not carried forward into subsequent inventory calculations.

Figure 6-2, Th-232 Concentration Profile - Upper, Adjusted Upper and Lower Core Samples




6.4. Evaluation of Tc-99 and Uranium Series Concentrations in Building Materials

As indicated earlier, a detailed gamma walkover survey was performed after the completion of most of the sampling effort (albeit prior to the collection of samples at locations 56 – 59) and buildings were dismantled. A detailed map showing the gamma walkover data is contained in Appendix D, Figure 1. An earlier 100 percent walkover survey was conducted in conjunction with the first round of sampling (locations 1 – 21). However, since the process buildings were still standing, a GPS guided map of the gamma results could not be generated.

The gamma walkover data was used in the interpretation of sample results. Specifically, the gamma walkover data was used to delineate the area associated with elevated sample measurements and to separate areas of elevated activity from those that are relatively clean. Figure 6-3, below, provides a depiction of the relative magnitude of the observed gamma results. As indicated on this figure and further contained with the detailed information in Appendix D, six areas of elevated activity were identified within the slabs of the process buildings and Building 252.

Figure 6-3, Histogram of Gamma Walkover Data - Designation of Elevated Areas




Radionuclide concentrations for each of these 6 areas were determined using data from sample locations from each respective area. Appendix D, Figure 1 shows individual sample locations and delineates these six areas. The corresponding sample data is contained in Appendix D, Tables 1 – 4.

The northeast portion of Area 1 and the entire Area 5 shown in Appendix D, Figure 1, will be excluded from disposal at USEI (see section 6.5, below). Samples which were collected from the northeast portion of Area 1 and Area 5 that will be excluded from disposal at USEI are not included in the following analysis for the weighted average concentration of activity in the slab since they are not representative of the concentration profile generally present in the building slabs.

- In order to account for small areas of elevated activity that are not identified as one of the six identified areas, a cumulative probability distribution was

constructed using the one square meter average readings from the remaining slab areas. As shown in Figure 6-4, below, 82 percent of the floor space outside the six identified areas exhibited a count rate less than 4400 cpm. This value (4,400 cpm) was conservatively selected to separate the slab data into two groups since it was twice the minimum average value for each one square meter.

Figure 6-4, Cumulative Probability Distribution, Building Slab



- For the total slab area, a weighted average of samples collected from elevated areas (18%) and those from the general areas (82%) was used to determine the average concentration. Tables 6-2 and 6-3 provide details on the calculation of these two activity components.

Table 6-2, Determination of Average Activity in Elevated Areas*

Location	Concentration (pCi/g)			
	Tc-99	U-234	U-235	U-238
1	0.1	81	3.9	8.8
4	4.0	2837	146	1010
5	1.8	1909	92	563
6	2.7	1053	58	308
7	0.2	145	6.4	47
8	15	178	6.1	24
10	0.2	1374	48	221
13	1.0	394	15	46
14	0.4	282	13	7.1
16	13	565	22	140
17	1.3	748	29	158
18	0.3	293	15	156
56	1.6	2103	90	165

Location	Concentration (pCi/g)			
	Tc-99	U-234	U-235	U-238
57	3.4	1603	69	2.3
58	0.78	961	39	147
59	2.1	2687	116	423
Average	3.0	1076	48	214

*Sample locations excluded since in areas that will not be shipped to USEI: 2, 3, 20, 21 and 35.

**Table 6-3, Determination of Average Activity for Remaining Slab Area that is Not
Included in the Six Identified Areas**

Location	Concentration, pCi/g			
	Tc-99	U-234	U-235	U-238
9	0.6	585	20	78
11	-0.3	120	4.7	23
12	0.3	127	4.7	19
15	1.6	38	1.7	7
19	0.7	189	7.4	46
31	1.7	1.1	0.1	0.2
32	1.9	0.4	0.0	0.2
33	1.8	1.2	0.1	0.3
34	2.2	9.7	0.5	0.8
36	2.0	0.4	0.0	0.2
38	3.7	13	0.7	2.8
39	2.7	11	0.6	2.8
40	10.9	44	2.4	12
41	7.6	39	2.2	9.3
42	5.0	12	0.6	3.2
43	1.7	1.1	0.1	0.5
44	1.7	5.4	0.3	1.7
45	2.5	2.7	0.1	1.9
46	1.7	15	0.8	6.2
47	1.7	1.4	0.1	0.4
48	2.5	3.0	0.2	0.7
49	1.7	0.2	0.0	0.1
50	1.8	0.3	0.0	0.2
51	1.7	0.2	0.0	0.2
52	8.4	51	2.8	10
53	3.0	40	2.2	4.4
54	1.8	9.2	0.5	0.8
55	2.0	34	1.7	1.0
Average	2.7	48	1.9	8.3

In order to determine the concentration within Area 3, it was necessary to determine the average contribution from below the top ¾-inch section of concrete since the two samples

collected in this area were collected only in the 0 – ¾-inch range. As show in Table 6-4, below, sample results from the lower (below ¾ inch) portion from areas not associated with cracks, seams and wall joints were used to determine the contribution below ¾ inch in Area 3.

Table 6-4, Determination of Average Activity below ¾ inch in Elevated Area 3*

Station ID	Sample Mass (g)	Tc-99 (pCi/g)			U-234 (pCi/g)			U-235 (pCi/g)			U-238 (pCi/g)		
		Conc.	±2σ	MDC	Conc.	±2σ	MDC	Conc.	±2σ	MDC	Conc.	±2σ	MDC
2	1366	0.46	0.86	2.1	4.7	-	-	0.2	0.2	0.1	0.3	3.0	1.8
3	1301	2.8	1.1	2.2	4.6	-	-	0.2	0.2	0.1	3.8	3.4	1.7
5	1620	0.45	0.85	1.9	12.0	-	-	0.6	0.3	0.2	4.5	4.0	2.1
7	1250	0.041	0.79	2.1	4.7	-	-	0.3	0.1	0.1	0.9	2.8	1.6
8	1090	1.8	0.93	2.2	10.0	-	-	0.3	0.2	0.1	-0.4	9.6	2.1
9	1340	0.57	0.79	2.1	2.4	-	-	0.1	0.1	0.1	1.4	2.5	1.3
10	1780	0.073	0.83	1.9	29.0	-	-	1.6	0.4	0.1	13.2	4.0	0.6
11	1110	-0.40	0.78	2.0	39.0	-	-	2.1	0.4	0.1	13.8	4.1	0.9
12	2050	0.31	0.33	1.2	0.5	-	-	0.0	0.1	0.1	0.3	2.7	1.6
15	1190	1.6	0.39	1.2	15.0	-	-	0.8	0.2	0.1	2.9	3.0	1.5
19	3040	0.32	0.36	0.90	8.9	-	-	0.5	0.2	0.1	4.8	3.9	1.8
Maximum		2.8			39			2.1			14		
Average		0.64			11			0.59			4.2		

* Sample Locations Excluded since in areas that will not be shipped to USEI: 1, 4, 6, 13, 14, 16, 17, 18, 20, 21

Review of concentration data in Areas 1 and 5 indicated concentrations of Tc-99 (Area 1) and Uranium (Area 5) such that a large fraction of the total radionuclide inventory would come from a small area. In each of these areas, it was determined that the 3000 pCi/g limit on average railcar radionuclide activity could be obtained from an area of such small size (less than 500 ft³) as to require operational restrictions to ensure that such a contiguous area be prevented from being placed in a single railcar. Accordingly, the northeast portion of Area 1, which consists of the 3 inch upper cap, and Area 5 will be excluded from disposal at USEI. Based on this determination, the concentration in these areas presented in this document excludes samples from these areas.

The radionuclide activity for areas outside the process building and vaults was conservatively estimated using the data presented in Table 6-4, above. Use of this data is valid based on existing gamma survey data indicating an absence of areas of elevated contamination in these materials such as those present in the process building and vaults.

Table 6-5, below provides a summary of the activity assigned to the materials discussed.

Table 6-5, Summary of Radionuclide Concentration in Building Slabs

Location	Waste Volume (m ³)	Tc-99		U-234		U-235		U-238	
		pCi/g	Ci	pCi/g	Ci	pCi/g	Ci	pCi/g	Ci
Elevated Area 1 - Bldg 240, Red Room	64	2	0.000	574	0.064	30	0.003	204	0.02
Elevated Area 2 - Bldg 240, Green Room	56	6.1	0.001	459	0.045	23	0.002	126	0.01
Elevated Area 3 - Bldg 254	8.8	2.6	0.000	262	0.004	12	0.000	48	0.00
Elevated Area 4 -Bldg 266 / 260	21	4.9	0.000	295	0.011	12	0.000	51	0.00
Elevated Area 6 - Bldg 232 (South Vault)	40	4.2	0.000	156	0.011	7.1	0.000	15	0.00

Location	Waste Volume (m ³)	Tc-99		U-234		U-235		U-238	
		pCi/g	Ci	pCi/g	Ci	pCi/g	Ci	pCi/g	Ci
Bldg 235 (West Vault)	12	1.9	0.000	22	0.000	1.9	0.000	2.7	0.00
Total - Elevated Areas	200	3.9	0.0014	385	0.14	19	0.007	110	0.039

Balance of Process Buildings Excluding: Areas (1-4), area 1 cap, area 5 and Vaults	1152	2.7	0.0055	233	0.47	10	0.021	45	0.09
--	------	-----	--------	-----	------	----	-------	----	------

Building Total 1353 2.9 0.0069 256 0.610 11.5 0.028 55 0.13

Concrete outside process buildings	3035	2.7	0.014	48	0.26	1.94	0.010	8.3	0.04
Asphalt	1112	2.7	0.005	48	0.095	1.94	0.004	8.3	0.016


Total for Site 5499 2.7 0.026 99 0.96 4.3 0.042 19.8 0.19

6.5. Evaluation of Characterization Data

Data from 50 sample locations has been obtained during sampling efforts. Of these 50 samples, 33 were targeted in and around areas of elevated activity. The remaining 17 locations were dispersed throughout the remainder of the building. A GPS logged gamma walkover survey was conducted. This survey demonstrates that areas with elevated activity were sampled. This fact is clearly evident upon inspection of Figure 6-3 and Appendix D, Figure 1.

The suitability of the GPS walkover data to identifying elevated uranium activity can be seen in Figure 6-5, below, in which the gamma count rate and total uranium activity at each sample location is plotted.

Figure 6-5, Graph of Surface Activity (count rate) versus Total Uranium Activity



The axis for the plot in Figure 6-5 was selected to indicate 0.4 pCi/g total uranium at a gamma count rate of 4400 cpm. These values were selected to represent ambient conditions based on the baseline gamma response within the building and on the total uranium activity at locations 49, 50, and 51, which are away from any area of elevated activity. Sample locations with known subsurface activity were excluded, since these are accounted for in the samples within each elevated area.

Areas in which Tc-99 was present (based on historical information) were included in the targeted sampling within Buildings 240 and 260. Specifically, Tc-99 was present in materials handled in Areas 1, 2, and 6. The concentration of Tc-99 inside and outside these areas is presented below in Table 6-6. As indicated by this tabulation, the concentration of Tc-99 within the concrete material outside of the areas with a history of Tc-99 use is negligible in comparison to that within areas with such a history. Areas with a history of Tc-99 were targeted for sampling. Outside of these areas, the variation in the Tc-99 is low by comparison such that the remaining samples provide effective characterization without the need for use of a surrogate to identify Tc-99.

Table 6-6, Comparison of Tc-99 and Total Uranium Concentrations Inside and Outside Areas with History of Tc-99

Location	No. of Samples	Tc-99 (pCi/g)			U total (pCi/g)		
		Min	Max	Avg	Min	Max	Avg
Inside areas with history of Tc-99 (Bldg 240 and 260)	18	0.2	2041	198	0.7	6659	1125

Outside areas with history of Tc-99.	32	-0.3	12.6	2.4	0.3	3226	455
--------------------------------------	----	------	------	-----	-----	------	-----

Exclusion of portions of the concrete in Building 240 and 260 drastically reduces the variability of Tc-99 concentration within the remaining material. These two areas combined contain 88 percent of the Tc-99 inventory within the process building yet comprise only 3 percent of the material volume. The mean Tc-99 concentration at all sample locations is 73 ± 326 (at 1 sigma). Table 6-7, below, shows a summary of sample results divided into those that fall within the areas to be excluded and those that do not. Removing the two areas mentioned above reduces the mean Tc-99 concentration to 2.5 ± 3.2 (at 1 sigma).

Table 6-7, Comparison of Tc-99 and Total Uranium Concentrations Inside and Outside Areas That Will Be Excluded from Disposal at USEI

Location	#	Tc-99, pCi/g			U total, pCi/g		
		Min	Max	Avg	Min	Max	Avg
Inside Areas that will be excluded from disposal	8	3.4	3663	828	12	6659	1788
Outside Areas that will be excluded from disposal	46	-0.3	15.4	2.5	0.3	3993	500

Based on nature and extent of characterization data available for this material, it is concluded that the data are of sufficient quality to be used as both an estimate of the total activity present in these materials, and to serve as the basis for determining the radionuclide concentration in materials shipped. Therefore, no additional characterization is planned.

7.0 VOLUME / WEIGHT /ACTIVITY ESTIMATES – UNDERGROUND PIPING

The volume and weight of underground piping was calculated based on information on the inside and outside pipe diameter and installed pipe length obtained from engineering drawings.

Weight estimates for the underground piping was based on the assumptions listed in Tables 7-1 and 7-2, below. The data in Table 7-1 was obtained from an in-pipe inspection survey effort performed in 2010. Data on individual piping segments is presented in Appendix F. Radionuclide concentrations and inventory estimates are presented below in Table 7-3 and are based on radiological sampling data collected during the 2010 in-pipe inspection program which is summarized in Appendix G.

Table 7-1, Piping Debris Content Expressed as Percent of Total Available Volume

Bldg / Area	Assumed Fill
110	10%
230	40%
240	40%
255	40%
254	40%
253	40%
O/S	10%

Table 7-2, Material Density Used in Weight Calculations

Material	Density
Cast Iron	7.2
Debris	1.5
HDPE	1.5
PVC	1.36
RCP	2.5
RFCP	2.5
Vitrified Clay	1.5

Table 7-3, Summary of Underground Piping Radionuclide Concentration and Inventory

Location	Wall Mass (g)	Debris Mass (g)	Total Mass (g)	Tc-99 (pCi/g)	U-234 (pCi/g)	U-235 (pCi/g)	U-238 (pCi/g)
Building 240 Northernmost System	3.3E+06	7.1E+05	4.0E+06	6.3E+03	4.7E+04	1.6E+03	3.3E+03
Building 240 Middle System	3.9E+06	7.8E+05	4.7E+06	6.3E+03	4.7E+04	1.6E+03	3.3E+03
Building 240 Southernmost System	2.2E+06	3.2E+05	2.6E+06	6.3E+03	4.7E+04	1.6E+03	3.3E+03
Building 260	2.7E+05	4.3E+04	3.1E+05	1.4E+02	5.5E+04	2.3E+03	8.2E+03
Building 255 Northernmost Process System	2.9E+06	4.6E+05	3.4E+06	1.7E+02	6.9E+03	2.6E+02	7.7E+02
Building 255 Southernmost Process System	3.7E+06	3.2E+05	4.0E+06	1.7E+02	6.9E+03	2.6E+02	7.7E+02
Building 255 Sanitary Lines	1.2E+05	1.9E+05	3.1E+05	1.7E+02	6.9E+03	2.6E+02	7.7E+02
Building 255 Sanitary and Grey Water lines	2.3E+05	6.0E+05	8.3E+05	1.7E+02	6.9E+03	2.6E+02	7.7E+02
Building 254	1.9E+07	2.3E+06	2.1E+07	1.7E+02	6.9E+03	2.6E+02	7.7E+02
Building 253	2.3E+05	2.3E+05	4.6E+05	1.7E+02	6.9E+03	2.6E+02	7.7E+02
Building 253 Sanitary and Grey Water lines	1.9E+04	3.1E+04	5.0E+04	1.7E+02	6.9E+03	2.6E+02	7.7E+02
Building 253 Storm Water Lines	4.5E+05	7.9E+05	1.2E+06	1.7E+02	6.9E+03	2.6E+02	7.7E+02
Outside	1.9E+07	5.2E+06	2.4E+07	1.7E+02	6.9E+03	2.6E+02	7.7E+02

7.1. Evaluation of Characterization Data

Activity estimates for this material are based on radiological analysis of swipe and scale/sediment samples collected during an extensive in-pipe survey effort that was conducted in 2010 to assist in quantifying the residual mass of ²³⁵U in underground piping that reside mainly beneath the former process buildings. Samples collected during these surveys were generally targeted at areas with either elevated gamma radiation

measurements (as determined by a GM detector attached to a remote camera) or from areas with debris buildup. Accordingly, uranium sample results are likely to be biased in the upward direction due to the tendency to sample areas with higher photon activity. While these measurements would not be indicative of Tc-99 activity, the bias toward sample areas with debris buildup would tend to bias both uranium and Tc-99 inventory estimates in the upward direction as well.

In order to investigate potential actions to reduce the uncertainty associated with the radionuclide content in the site piping, an analysis was performed comparing the radionuclide inventory associated with Buildings 240 and 260 versus the balance of the site. Tables 7-4 and 7-5 contains the summary data associated with these two datasets.

Table 7-4, Radionuclide Inventory for Underground Piping Buildings 240 and 260

Location	Piping Volume (m ³)	Tc-99 (Ci)	U-234 (Ci)	U-235 (Ci)	U-238 (Ci)
Building 240 Northernmost System	1.7E+01	4.5E-03	3.3E-02	1.1E-03	2.3E-03
Building 240 Middle System	2.0E+01	5.0E-03	3.6E-02	1.2E-03	2.6E-03
Building 240 Southernmost System	1.1E+01	2.0E-03	1.5E-02	5.0E-04	1.0E-03
Building 260	1.3E+00	5.9E-06	2.4E-03	9.7E-05	3.5E-04
Total	4.8E+01	1.1E-02	8.7E-02	2.9E-03	6.3E-03

Table 7-5, Radionuclide Inventory for Underground Piping, Excluding Buildings 240 and 260

Location	Piping Volume (m ³)	Tc-99 (Ci)	U-234 (Ci)	U-235 (Ci)	U-238 (Ci)
Building 255 Northernmost Process System	1.4E+01	8.0E-05	3.2E-03	1.2E-04	3.5E-04
Building 255 Southernmost Process System	1.7E+01	5.5E-05	2.2E-03	8.2E-05	2.4E-04
Building 255 Sanitary Lines	1.3E+00	3.3E-05	1.3E-03	4.9E-05	1.5E-04
Building 255 Sanitary and Grey Water lines	3.4E+00	1.0E-04	4.2E-03	1.6E-04	4.6E-04
Building 254	8.8E+01	4.0E-04	1.6E-02	5.9E-04	1.7E-03
Building 253	1.9E+00	4.0E-05	1.6E-03	6.0E-05	1.8E-04
Building 253 Sanitary and Grey Water lines	2.1E-01	5.4E-06	2.2E-04	8.0E-06	2.4E-05
Building 253 Storm Water Lines	5.2E+00	1.4E-04	5.5E-03	2.0E-04	6.1E-04
Outside	1.0E+02	9.1E-04	3.6E-02	1.3E-03	4.0E-03
Total	2.3E+02	1.8E-03	7.0E-02	2.6E-03	7.8E-03

As indicated by these two tables, 87 percent of the Tc-99 within the site piping (based on available sample data) is contained within buildings 240 and 260 while these two

locations contain only 17 percent of the volume. Additionally when all of the available sample data is pooled, the resultant mean Tc-99 concentration is 403 pCi/g with a standard deviation of 1261 pCi/g. Removal of Buildings 240 and 260 piping results in a mean concentration of 16 pCi/g with a standard deviation of 39 pCi/g.

Based on this analysis, the piping from these two areas will be excluded from disposal at USEI; the location of this piping is shown on Figure 1 of Appendix G. This will result in a significant reduction in the average concentration and its associated uncertainty. Because of the limited data available for the building piping and due to the inability to perform direct measurements until the time of removal, additional characterization of this material will be performed prior to shipment. Details of the planned characterization are contained in the Additional Alternate Disposal Request associated with this TBD.

8.0 VOLUME / WEIGHT / ACTIVITY ESTIMATES – MISCELLANEOUS EQUIPMENT

During the process building demolition, HEPA units and associated ducting were categorized as: 1) materials with sufficiently low specific activity to be disposed at Bulk Survey for Release (BSFR); 2) materials that exceed the BSFR criteria but which are suitable for disposal at USEI, and 3) materials that are unacceptable for disposal at USEI. Table 8-1 provides a summary of the characterization data for each component.

Concentrations of U-234, U-238 and Tc-99 (Table 8-2) as well as other trace radionuclides (Table 7-3) were determined using scaling factors contained in HDP-TBD-WM-901, *Scaling Factors for Radioactive Waste Associated with the Above Slab Portion of the Process Buildings* (Reference 3.1), and enrichment of 4.5 percent. Use of the scaling data is justified since the scaling factors were derived from equipment equivalent to that under consideration. The HEPA units were installed and used during the period of commercial work at Hematite (post 1974) and as such were not exposed to uranium with an enrichment of greater than 4.5 percent.

Table 8-1, Summary of HEPA Unit and Associated Ducting Characterization Data – Total U-235 and Material Dimensions

Item	Item U-235 (grams)	Weight (lb)	volume (ft ³)
HEPA 1 240-12	8.03	2,580	6.45E+01
HEPA 2 240-12	7.08	2,580	6.45E+01
HEPA 3 253-26	7.08	2,580	6.45E+01
HEPA 7 254-35	13.88	2,580	6.45E+01
HEPA 18 255-51	9.25	2,580	6.45E+01
HEPA exhaust duct 240-12; y-duct at blower 240-12	1.68	450	1.13E+01
240-4 stack duct	1.68	134	3.35E+00
stack flange-240	1.33	450	1.13E+01
Total	50	13,934	348

Table 8-2, Uranium and Tc-99 Concentrations in HEPA Units and Associated Ducting

Item	U-234 (pCi)	U-235 (pCi)	U-238 (pCi)	Tc-99 (pCi)
HEPA 1 240-12	3.2E+08	1.8E+07	5.8E+07	8.05E+06
HEPA 2 240-12	2.8E+08	1.6E+07	5.1E+07	7.10E+06
HEPA 3 253-26	2.8E+08	1.6E+07	5.1E+07	1.59E+06
HEPA 7 254-35	5.5E+08	3.1E+07	1.0E+08	2.45E+06
HEPA 18 255-51	3.7E+08	2.0E+07	6.7E+07	1.63E+06
hepa exhaust duct 240-12; y-duct at blower 240-12	6.7E+07	3.7E+06	1.2E+07	1.69E+06
240-4 stack duct	6.7E+07	3.7E+06	1.2E+07	1.68E+06
stack flange-240	5.3E+07	2.9E+06	9.6E+06	1.33E+06
Total Activity (Ci)	2.0E-03	1.1E-04	3.6E-04	2.6E-05

As indicated in Table 8-3, below, the contribution from these trace radionuclides is of such a low concentration relative to the associated uranium also present (2.6 E-5 to 6.7 E-4) as to be considered to be present only at trace levels and are not carried forward into subsequent inventory calculations.

Table 8-3, Trace Element Concentrations in HEPA Units and Associated Ducting

Item	U-total (pCi)	Th-230 (pCi)	Th-232 (pCi)	Np-237 (pCi)
HEPA 1 240-12	4.0E+08	8.94E+04	1.04E+04	1.38E+04
HEPA 2 240-12	3.5E+08	7.88E+04	9.17E+03	1.21E+04
HEPA 3 253-26	3.5E+08	7.88E+04	9.17E+03	1.21E+04
HEPA 7 254-35	6.8E+08	1.55E+05	1.80E+04	2.38E+04
HEPA 18 255-51	4.6E+08	1.03E+05	1.20E+04	1.59E+04
HEPA exhaust duct 240-12; y- duct at blower 240-12	8.3E+07	1.87E+04	2.18E+03	2.89E+03
240-4 stack duct	8.3E+07	1.87E+04	2.18E+03	2.88E+03
stack flange-240	6.5E+07	1.48E+04	1.72E+03	2.27E+03
Total Activity (Ci)	2.5E-03	5.6E-07	6.5E-08	8.6E-08

8.1. Evaluation of Characterization Data

Activity estimates for the HEPA units that is described above are based on measurements of gamma radiation levels performed during the characterization of remaining equipment in 2008. The gamma radiation levels were subsequently interpreted using the MNCP code to determine the amount and enrichment of U-235, and the amount of total uranium in each component. The total uranium activity within the items ranged from 400 to 800 pCi/g, with the exception of one low mass item (130 lb) that showed total uranium activity at 1,800 pCi/g. It is likely that all of these materials will be shipped in a single package, and as such the average concentration of the package would be approximately 520 pCi/g, or 17 percent of the 3,000 pCi/g limit.

The overall amount of Tc-99 activity was determined based on waste scaling factors derived from the laboratory analytical data obtained during the initial characterization surveys and sampling performed in 2008, and subsequently published in HDP-TBD-WM-901, *Scaling Factors for Radioactive Waste Associated with the Above Slab Portion of the Process Buildings* (Reference 3.1). The waste scaling factors for Tc-99 to U-235 described in this document are appropriate since they were based on samples obtained from the surfaces that were exposed to the same radionuclide mixture. The Tc-99 concentrations within the individual items ranged from 1.4 to 28 pCi/g; and averaged 4 pCi/g (standard deviation was 8.6pCi/g). Consistent with process history that indicated that this equipment was not directly involved in processes that would have involved Tc-99, the concentration of Tc-99 contributed only a small fraction of the total activity in the source term.

Accordingly, based on the low contribution of these materials to the total evaluated dose, it is concluded that the data are of sufficient quality to be used as both an estimate of the total activity present in these materials, and to serve as the basis for determining the radionuclide concentration in materials shipped. Therefore, no additional characterization of this miscellaneous equipment is planned.

9.0 VOLUME / WEIGHT /ACTIVITY ESTIMATES ASSOCIATED WITH SUB-SLAB SOILS

Conceptual excavation contours for soils (including limestone backfill) beneath the former process buildings are shown on Figure H-1. These contours are based on soil sample results exceeding the DCGLs or exceeding the chemical Remediation Goals (RGs), and includes a projected average excavation depth of 2 feet within the footprint of the former Process Buildings.

The soils beneath the process building slabs were initially characterized during the site remedial investigation. Additional samples were collected during the 2010 and 2011 concrete slab characterization efforts. Finally, a series of core samples available from the earlier remedial investigation report were analyzed. Analysis of these samples provided data for soils down to the 16.5 ft below the surface. Sample locations are shown on Figure H-2. Note that different symbols are used to discern samples collected immediately under the building slab (e.g., initial 6 inches), versus samples collected subsurface, and the samples collected from archived cores (e.g., 4 foot composite samples down to 16.5 ft)

This combined data was used to develop an estimate of the radionuclide concentration within the sub-slab soil that is likely to be excavated. Analytical results for samples obtained from the areas within the excavation contours shown in Figure H-1 are presented in Tables H-1 through H-12. Data presented in Appendix H is summarized below in Table 9-1.

Table 9-1, Concentration Summary for Soil Beneath the Process Building Slab

Area	Volume Shipped	Tc-99	U-234	U-235	U-238
	m ³	Ci	Ci	Ci	Ci
Excluding Beneath Building 253					
0 - 0.5 ft	1,408	0.0055	0.21	0.011	0.065
0.5 - 5 ft	4,573	0.022	0.13	0.0064	0.018
5 ft - 20 ft	1,684	0.00045	0.0073	0.0004	0.004
Under Building 253					
0 - 0.5 ft	159	0.033	0.0070	0.00037	0.0010
0.5 - 5 ft	997	0.067	0.054	0.0030	0.0079
5 ft - 20 ft	653	0.012	0.0040	0.0002	0.0015
Total					
total - (0 - 20 ft)	9,474	0.14	0.41	0.022	0.10

9.1. **Evaluation of Characterization Data**

A total of 94 samples were collected from the area immediately beneath the former process building to a depth of 16.5 ft. The results of these samples are shown in Table 9-2, below. Included in this group are 48 samples collected in the surface material immediately beneath the building slab. Samples taken beneath Building 253 were analyzed separately from the rest of the sample data. The reason for this separation is that this area contains the majority of the Tc-99 activity within the sub-slab soil. Outside of the area immediately below Building 253, the maximum Tc-99 concentration is 30 pCi/g. The weighted average concentration in this area is 3 pCi/g. This is compared to a maximum concentration of 168 pCi/g in the area beneath Building 253 and a weighted average concentration of 43 pCi/g. The highest average concentration is found in the soils immediately below the Building 253 slab. A total of 5 samples were collected in this area (shown in Figure H-2). The sample results all fell within a concentration range of 109 pCi/g to 168 pCi/g, with a standard deviation of 30 pCi/g.

Table 9-2, Tc-99 results summary

Location	Volume Shipped (m ³)	No. Samples	Min (pCi/g)	Max (pCi/g)	Arithmetic Mean (pCi/g)	Std Dev. (pCi/g)
Excluding Beneath Building 253						
0 - 0.5 ft	1,408	43	-0.40	12	3	3
0.5 - 5 ft	4,573	12	-0.3	30	3	9
5 ft - 20 ft	1,684	22	-0.3	1	0.2	0.4
Under Building 253						
0 - 0.5 ft	159	5	109	168	143	30
0.5 - 5 ft	997	5	7.50	151	47	60
5 ft - 20 ft	653	7	5.22	28	13	8
Total						
Total: 9,474 m ³		Total # Samples: 94		Weighted Mean: 10 pCi/g		

Taken as a single dataset, the average Tc-99 concentration is 13 pCi/g with a standard deviation of 36 pCi/g. This data was input into Visual Sample Plan¹ Software (Appendix I) to determine the number of samples required to construct a UCL95 with a width of 6.5 pCi/g. Based on this analysis, it was determined that 85 samples would have to be collected. As indicated above, there are a total of 96 samples from this area already analyzed. Although it is apparent that an appropriate sample set is available for the sub-slab soil, additional characterization is planned based on the inaccessibility of the material prior to remediation of the slabs. Details of the planned characterization are contained in the Additional Alternate Disposal Request associated with this TBD.

10.0 APPENDICES

Appendix A, Volume Estimates for Process Buildings Slabs

Appendix B, Volume Estimates for Concrete Not Including Process Building Slabs

Appendix C, Volume Estimates for Asphalt Surfaces

Appendix D, Process Building Slab – Sampling data and Gamma Walkover Survey
(GWS)

Appendix E, Process Building Slab –Radium 226 Data, Two Sample t-test

Appendix F, Volume Estimates for Underground Piping

Appendix G, Radiological Sampling Results – Underground Piping

Appendix H, Sub-Slab Sample Data Summary

Appendix I, Visual Sample Plan¹ Software Evaluation

¹ Software copyright (c) 2011 Battelle Memorial Institute. All rights reserved.

**Appendix A
Volume Estimates for Process Buildings Slabs**

	Item	Quantity	L (ft)	W (ft)	H (ft)	Volume (ft³)	Weight (lb)	Area (ft²)
Building Slabs	Bldg. 240	1	60	83.08	0.5	2,492	373,860	4,985
		1	60.16	83	0.5	2,497	374,496	4,993
		1	40	83.08	0.75	2,492	373,860	3,323
		1	40.5	83.16	0.5	1,684	252,599	3,368
	Bldg. 253	1	69	131.5	0.5	4,537	680,513	9,074
	Bldg. 254	1	83	161.25	0.5	6,692	1,003,781	13,384
	Men And Women Locker Rooms	1	166	18	0.5	1,494	224,100	2,988
	Bldg. 255	1	159.5	83.08	0.5	6,626	993,845	13,251
	Bldg. 256-1 - Slab	1	70	50	0.5	1,750	262,500	3,500
	Bldg 256-1 Thickend slab	1	27	2	1	54	8,100	54
	Bldg. 256-2	1	81	50	0.5	2,025	303,750	4,050
	Bldg. 256-2	1	29.6	17.5	0.42	218	32,634	518
	Bldg. 256-2	1	37.6	31.67	0.67	798	119,675	1,191
	Bldg. 256-2	1	36	31.67	0.67	764	114,582	1,140
	Bldg. 256-2 Sump	1	5.5	7.5	3	124	18,563	41
	Limestone Bldg.	1	36.5	38	0.58	804	120,669	1,387
	Bldg. 252	1	41	50	0.5	1,025	153,750	2,050
	Bldg. 235	1	35.08	17	0.5	298	44,727	596
Total Processing Buildings Slabs						36,373	5,456,002	69,893
Total Processing Buildings Slabs Available for Disposal						35,031	5,254,627	67,833

Appendix B
Volume Estimates for Concrete Not Including Process Building Slabs

	Item	Quantity	L (ft)	W (ft)	H (ft)	Volume (ft ³)	Weight (lb)	
Building 240	Interior Footings	18	4.25	4.25	1	325	48,769	
	piers	18	1	1	2.6	47	7,020	
	Footing Base	5	83.08	1.5	1	623	93,465	
	Footing	2	161.5	1.5	1	485	72,675	
Bldg 253	Interior footings	1	9.5	9.5	1.75	158	23,691	
	Interior footings	1	12	12	2	288	43,200	
	Interior footings	1	10	10	1.75	175	26,250	
	Interior footings	1	7.5	7.5	1.25	70	10,547	
	Interior footings	1	9	5	1.5	68	10,125	
	Interior footings	2	8	6	2	192	28,800	
	Interior footings	1	9.5	9.5	1.75	158	23,691	
	Interior footings	1	12	12	2	288	43,200	
	Interior footings	1	10	10	1.75	175	26,250	
	Interior footings	1	7.5	7.5	1.25	70	10,547	
	Interior footings	2	5.5	5.5	1	61	9,075	
	Interior footings	1	12	5	2	120	18,000	
	Interior footings	1	8	5	1	40	6,000	
	Interior footings	1	16.83	4	2	135	20,196	
	Interior footings	1	7	4	1	28	4,200	
	Interior footings	1	4	35	1	140	21,000	
	piers	23	2	2	1.25	115	17,250	
	Footin Base	1	40	3.7	0.83	123	18,426	
	footing pier	1	40	1	3	120	18,000	
	Footing base	1	61.5	3.7	0.8	182	27,306	
	footing pier	1	61.5	3	1	185	27,675	
	Bldg 254	A-2 footing	1	27	6	2	324	48,600
		A-2 pier	1	2	2	1.25	5	750
b-2 footing		1	44	6	2	528	79,200	
B-2 pier		1	2	2	1.25	5	750	
c2 footing		1	34	6	2	408	61,200	
C2 pier		1	2	2	1.25	5	750	
D2 Footing		1	6.67	9.67	2	129	19,350	
E2 footing		2	13	13	2	676	101,400	
E2 pier		2	3	4	1.25	30	4,500	
F2 footin		2	4	4	1.25	40	6,000	
G-3 footing		8	8	8	1.25	640	96,000	
G-3 pier		8	2	2	1.25	40	6,000	
H-3 footing		4	5	5	1.25	125	18,750	
H-3 pier		4	2	2	1.25	20	3,000	
I-3 footing		1	27	7	2	378	56,700	
J-3 footing		1	11	11	2	242	36,300	
J-3 footing part 2		1	2	2	1.67	7	1,002	
J-3 footing part 3		1	1.5	1.5	1.67	4	564	
K-3		1	9	9	1.5	122	18,225	
K-3 pier		1	2	2	1.25	5	750	
N/s Block Wall footing		3	161	1	1	483	72,450	
EW block wall footing		6	83	1	1	498	74,700	
EW Footing		2	83	3	1	498	74,700	
EW footing pier		2	83	2.5	1	415	62,250	
NS footing		1	161.25	3	1	484	72,563	

**Appendix B
Volume Estimates for Concrete Not Including Process Building Slabs**

	Item	Quantity	L (ft)	W (ft)	H (ft)	Volume (ft ³)	Weight (lb)
	NS footing pier	1	161.25	1	2.5	403	60,469
Men and Women Locker Rooms	Footing	2	101	3.5	3.5	2,475	371,175
	footing pier	2	101	1.25	2	505	75,750
Building 255	Interior footing	10	7	7	1.25	613	91,875
	pier	10	1.17	1.17	2.25	31	4,620
	pilaster footing	10	6	6	1	360	54,000
	Pilaster pier	10	2.5	1.75	1.42	62	9,319
	E/W footing	2	83.08	2.5	1	415	62,310
	EW piers	2	83.08	2.5	1	415	62,310
	NS footing	2	159.5	2.25	1	718	107,663
	NS footing piers	2	159.5	0.75	2.5	598	89,719
Building 256-1	Loading Dock Floor	1	46	65	0.67	2,003	300,495
	Sump location	1	65	15	0.67	653	97,988
	Dock Wall base	1	4	46	1	184	27,600
	Dock Wall base	1	47	0.83	5.83	227	34,114
	Dock Sides2	2	46	0.83	65	4,963	744,510
	Footings A-6	2	6.5	6.5	1	85	12,675
	Footing A6 pier	2	70	2	3.7	1,036	155,400
	Footing B-6	2	7.5	7.5	1	113	16,875
	Footing B-6 pier	2	50	2	2	400	60,000
	Footing C-6	1	5	7.5	1	38	5,625
	Footing C-6 pier	1	2	2	2	8	1,200
	D-6 footing	1	6.83	1.25	1	9	1,281
	Building 256-2	A6 footing base	3	6.5	6.5	1	127
A6-pier		3	2.16	2.16	81	1,134	170,061
B-6 Base		2	7.5	7.5	1	113	16,875
B-6 pier		2	2	2	2	16	2,400
Building 260	Interior footings	3	8	8	1.5	288	43,200
	Interior piers	3	1.6	1.5	3.16	23	3,413
	center footings	1	35	6	3.16	664	99,540
	center piers	1	35	5	1.67	292	43,838
	s. footing	1	31	6	5.67	1,055	158,193
	pier 4 base	4	3	3	1.16	42	6,264
	pier 4 pier	4	3.67	1	1	15	2,202
	pier 3 bases	5	4	7	1.5	210	31,500
	pier 3 piers	5	1	1	2.16	11	1,620
	modified pier 3	1	7	9	1.6	101	15,120
	mod. Pier 3 pier	1	1	1	2.16	2	324
	footing	1	112	1.5	1.67	281	42,084
	Limestone Building	Pier 1	4	1.16	1.16	3.16	17
Pier 2		1	1.16	1.75	3.16	6	962
Footing		4	5	5	1	100	15,000
Footing		1	38	3.16	0.67	80	12,068
Footing		1	5.5	17	0.67	63	9,397
footing		1	5.5	15	0.67	55	8,291
interior footing		1	14.5	1	0.67	10	1,457
interior footing		1	12	1	0.67	8	1,206
interior footing		1	22	1	0.67	15	2,211
Building 252		Footings base	2	41	2	1	164

Appendix B
Volume Estimates for Concrete Not Including Process Building Slabs


	Item	Quantity	L (ft)	W (ft)	H (ft)	Volume (ft ³)	Weight (lb)
	footing piers	2	41	1.25	1	103	15,375
	footing base	2	50	2	1	200	30,000
	footing piers	2	50	2	1	200	30,000
Building 235	Footing Base	1	106	1	1.5	159	23,850
	Footing Pier	1	106	1	2	212	31,800
	Walls	1	106	15	0.67	1,065	79,898
	Interior walls	4	30	10	0.67	804	60,300
Septic Tank	Walls	2	24	0.5	8.5	204	30,600
	walls	3	6	0.5	8.5	77	11,475
	Top and Bottom	2	24	6	0.5	144	21,600
Other Areas	Site Dam	1	39	4	7	1,092	163,800
	Head Wall	1	70	3	0.67	141	21,105
	Cistern Burn Pit	1	50	5	0.5	125	18,750
	Tile Barn Ramp	1	38	8	0.5	152	22,800
	Tile Barn Slab	1	124	37	2	9,176	1,376,400
	Wood Barn Footings	1	220	4	0.67	590	88,440
	Slab N of 260	1	95	54	0.5	2,565	384,750
	Tank base N of Lime	1	34	34	1	1,156	173,400
	Slab N of 255	1	79	11	0.5	435	65,175
	S of 253 basin	1	11	11	1	121	18,150
	basin s of 240	1	22	8	1	176	26,400
	Piers S of 240	2	2	5	3	60	9,000
	Office w of 240	1	41	13	1	533	79,950
	Vent room w of 240	1	28	73	1	2,044	306,600
	Side Walks	1	300	8	0.5	1,200	180,000
	230 Pad	1	250	150	0.67	25,125	3,768,750
Total Concrete outside except processing building Slabs						79,538	11,790,538
Concrete total volume =						1.16E+05 ft3	
Concrete total Weight =						1.72E+07 lb	
Concrete total Weight =						7.83E+09 g	

**Appendix C
Volume Estimates for Asphalt Surfaces**

	Item	Quantity	L (ft)	W (ft)	H (ft)	Volume (ft ³)	Weight (lb)
Asphalt	Asphalt	1	52	15	0.5	390	46,800
		1	9	150	0.5	675	81,000
		1	38	10	0.5	190	22,800
	Asphalt around plant	1	1700	24	0.6	24,480	2,937,600
	Asphalt pads	1	100	100	0.6	6,000	720,000
	Cushman road	1	500	10	0.6	3,000	360,000
	L Debbie pad	1	50	50	0.5	1,250	150,000
Total Asphalt						35,985	4,318,200
		Asphalt total volume = 3.60E+04 ft³					
		Asphalt total Weight, lb = 4.32E+06 lb					
		Asphalt total Weight, g = 1.96E+09 g					

Appendix D
Process Building Slab – Sampling Data and Gamma Walkover Survey (GWS)

Figure 1, Gamma Walkover Data and Sampling Locations



Appendix D
Process Building Slab – Sampling Data and Gamma Walkover Survey (GWS)

Table 1, Sample Results, Stations 1 – 21 (Tc-99, U-234, U-235, and U-238)

Station ID	Sample ID	Description	Sample Type				Sample Mass (g)	Radionuclide Concentration												Notes
			Resurfaced Concrete Region	Expansion Joint, Crack, Seam, Near Wall	Identified as a Hot Spot	Representative of General Area		Tc-99			U-234			U-235			U-238			
								(pCi/g)			(pCi/g)			(pCi/g)			(pCi/g)			
								Conc.	±2s	MDC	Conc.	±2s	MDC	Conc.	±2s	MDC	Conc.	±2s	MDC	
1	991-MS-100413-13-1	Concrete sample from Station # 1 - top 1/4 "	-	x	-	-	62	0.58	0.88	2.1	178	26	0.23	5.1	1.2	0.13	9.8	1.9	0.23	
	991-MS-100413-13-2	Concrete sample from Station # 1 - middle 1/2 "					125	-0.13	0.83	1.8	176	28	0.28	6.1	1.4	0.21	8.4	1.7	0.28	
	991-MS-100413-13-3	Concrete sample from Station # 1 - remainder of core					1160	0.068	0.84	1.9	66	-	-	3.7	0.55	0.16	8.8	3.2	0.83	
							-	0.073	-	-	81	-	-	3.9	-	-	8.8	-	-	1
2	992-MS-100413-13-1	Concrete sample from Station # 2 - top 1/4 "	x	-	x	-	60	42738	2950	3.7	34384	4986	95	1255	280	61	5051	834	26	
	992-MS-100413-13-2	Concrete sample from Station # 2 - middle 1/2 "					106	4.5	1.1	2.8	15	2.7	0.097	0.29	0.20	0.097	2.5	0.70	0.19	
	992-MS-100413-13-3a	Concrete sample from Station # 2 - remainder of core A					534	0.72	0.91	2.8	9.1	-	-	0.41	0.050	0.16	11	7.0	4.3	
	992-MS-100413-13-5	1/4 inch Subfloor wafer					85	-0.13	0.88	2.3	123	18	0.29	3.3	0.92	0.13	2.0	0.67	0.13	
	992-MS-100413-13-6	1/2 inch Subfloor wafer					136	-0.17	0.88	1.9	1.4	0.51	0.26	0.063	0.11	0.19	0.95	0.40	0.19	
	992-MS-100413-13-3b	Concrete sample from Station # 2 - remainder of core B					1366	0.46	0.86	2.1	4.7	-	-	0.25	0.24	0.15	0.27	3.0	1.8	
							-	1122	-	-	912	-	-	33	-	-	136	-	-	1
3	993-MS-100413-13-1	Concrete sample from Station # 3 - top 1/4 "	x	x	-	-	59	22646	547	2.6	15232	4884	5.6	544	181	3.1	2364	764	6.7	
	993-MS-100413-13-2	Concrete sample from Station # 3 - middle 1/2 "					119	122	14	2.3	6109	2122	2.7	206	74	1.4	904	316	2.7	
	993-MS-100413-13-3a	Concrete sample from Station # 3 - remainder of core A					509	101	13	1.9	1183	-	-	65	2.8	0.77	265	43	9.1	
	993-MS-100413-13-5	1/4 inch Subfloor wafer					75	19	2.9	2.0	107	16	0.27	3.8	0.98	0.23	21	3.6	0.23	
	993-MS-100413-13-6	1/2 inch Subfloor wafer					113	2.5	1.1	1.9	4.2	0.97	0.20	0.13	0.13	0.086	1.3	0.45	0.086	
	993-MS-100413-13-3b	Concrete sample from Station # 3 - remainder of core B					1301	2.8	1.1	2.2	4.6	-	-	0.23	0.21	0.13	3.8	3.4	1.7	
							-	647	-	-	1030	-	-	42	-	-	179	-	-	1
							-	3.6	-	-	9.7	-	-	0.40	-	-	4.5	-	-	2
4	997-MS-100414-13-1	Concrete sample from Station # 4 - top 1/4 "	-	x	-	-	113	18	2.6	2.2	1439	262	1.3	56	12	0.57	311	58	1.1	
	997-MS-100414-13-2	Concrete sample from Station # 4 - middle 1/2 "					122	5.7	0.88	0.85	4661	980	1.9	179	40	1.9	1011	215	1.9	
	997-MS-100414-13-3	Concrete sample from Station # 4 - remainder of core					1290	2.6	0.51	1.0	2787	-	-	151	21	0.57	1071	144	2.9	
							-	4.0	-	-	2837	-	-	146	-	-	1010	-	-	1
5	998-MS-100414-13-1	Concrete sample from Station # 5 - top 1/4 "	-	-	x	-	96	24	1.8	1.4	37544	6057	145	1805	471	101	11035	1947	56	
	998-MS-100414-13-2	Concrete sample from Station # 5 - middle 1/2 "					187	2.1	0.99	2.5	50	8.3	0.24	3.0	0.81	0.20	21	3.7	0.20	
	998-MS-100414-13-3	Concrete sample from Station # 5 - remainder of core					1620	0.45	0.85	1.9	12	-	-	0.63	0.29	0.18	4.5	4.0	2.1	
							-	1.8	-	-	1909	-	-	92	-	-	563	-	-	1
6	1008-MS-100415-13-1	Concrete sample from Station # 6 - top 1/4 "	-	x	-	-	66	16	1.3	1.5	20166	3281	104	1101	312	79	5896	1086	79	
	1008-MS-100415-13-2	Concrete sample from Station # 6 - middle 1/2 "					120	2.9	1.0	2.1	1.4	0.46	0.20	0.095	0.11	0.086	0.64	0.30	0.17	
	1008-MS-100415-13-3	Concrete sample from Station # 6 - remainder of core					1080	1.9	0.91	2.1	2.2	-	-	0.12	0.19	0.11	0.93	2.9	1.6	
							-	2.7	-	-	1053	-	-	58	-	-	308	-	-	1
7	1000-MS-100415-13-1	Concrete sample from Station # 7 - top 1/4 "	-	-	x	-	61	1.5	0.46	0.78	3304	868	5.6	145	43	1.9	1074	286	3.6	
	1000-MS-100415-13-2	Concrete sample from Station # 7 - middle 1/2 "					118	0.64	0.85	2.2	2.7	0.68	0.21	0.12	0.12	0.079	1.4	0.44	0.15	
	1000-MS-100415-13-3	Concrete sample from Station # 7 - remainder of core					1250	0.041	0.79	2.1	4.7	-	-	0.26	0.14	0.13	0.89	2.8	1.6	
							-	0.15	-	-	145	-	-	6.4	-	-	47	-	-	1

Appendix D
Process Building Slab – Sampling Data and Gamma Walkover Survey (GWS)

Table 1, Sample Results, Stations 1 – 21 (Tc-99, U-234, U-235, and U-238)

Station ID	Sample ID	Description	Sample Type				Sample Mass (g)	Radionuclide Concentration												Notes
			Resurfaced Concrete Region	Expansion Joint, Crack, Seam, Near Wall	Identified as a Hot Spot	Representative of General Area		Tc-99			U-234			U-235			U-238			
								(pCi/g)			(pCi/g)			(pCi/g)			(pCi/g)			
								Conc.	±2s	MDC	Conc.	±2s	MDC	Conc.	±2s	MDC	Conc.	±2s	MDC	
8	999-MS-100414-13-1	Concrete sample from Station #8 - top 1/4 "					85	163	4.1	4.1	2599	463	1.7	89	18	1.1	370	68	1.1	
	999-MS-100414-13-2	Concrete sample from Station # 8- middle 1/2 "	-	-	x	-	125	34	1.5	8.2	0.73	0.31	0.19	0.029	0.058	0.080	0.29	0.19	0.15	
	999-MS-100414-13-3	Concrete sample from Station # 8 - remainder of core					1090	1.8	0.93	2.2	10	-	-	0.31	0.21	0.12	-0.40	9.6	2.1	
							-	15	-	-	178	-	-	6.1	-	-	24	-	-	1
9	1009-MS-100415-13-1	Concrete sample from Station # 9 - top 1/4 "					75	0.54	0.39	0.81	11874	2919	4.8	403	103	1.6	1574	391	1.6	
	1009-MS-100415-13-2	Concrete sample from Station # 9 middle 1/2 "	-	x	-	x	114	0.77	0.88	2.0	0.70	0.33	0.25	0.069	0.11	0.22	0.38	0.25	0.25	
	1009-MS-100415-13-3	Concrete sample from Station # 9 - remainder of core					1340	0.57	0.79	2.1	2.4	-	-	0.12	0.11	0.057	1.4	2.5	1.3	
							-	0.58	-	-	585	-	-	20	-	-	78	-	-	1
10	1010-MS-100415-13-1	Concrete sample from Station # 10- top 1/4 "					73	0.97	0.41	0.88	36426	5775	82	1267	346	82	5657	1056	46	
	1010-MS-100415-13-2	Concrete sample from Station # 10- middle 1/2 "	-	-	x	-	120	1.0	0.82	1.8	1.6	0.53	0.28	0.033	0.066	0.091	0.33	0.21	0.091	
	1010-MS-100415-13-3	Concrete sample from Station # 10 - remainder of core					1780	0.073	0.83	1.9	29	-	-	1.6	0.37	0.11	13	4.0	0.63	
							-	0.16	-	-	1374	-	-	48	-	-	221	-	-	1
11	1011-MS-100415-13-1	Concrete sample from Station # 11 - top 1/4 "					73	-0.12	0.35	1.2	1523	257	1.1	50	9.9	0.39	205	36	0.61	
	1011-MS-100415-13-2	Concrete sample from Station # 11 - middle 1/2 "	-	-	-	x	118	0.80	0.87	2.0	8.6	1.6	0.28	0.34	0.20	0.15	1.5	0.46	0.20	
	1011-MS-100415-13-3	Concrete sample from Station # 11 - remainder of core					1110	-0.40	0.78	2.0	39	-	-	2.1	0.41	0.15	14	4.1	0.87	
							-	-0.27	-	-	120	-	-	4.7	-	-	23	-	-	1
12	1017-MS-100416-13-1	Concrete sample from Station # 12 - top 1/4 "					63	-0.11	0.34	1.3	4481	949	2.2	165	38	1.0	650	141	2.2	
	1017-MS-100416-13-2	Concrete sample from Station # 12 middle 1/2 "	-	-	-	x	120	1.1	0.84	1.7	0.60	0.29	0.17	0.032	0.062	0.086	0.19	0.16	0.20	
	1017-MS-100416-13-3	Concrete sample from Station # 12 - remainder of core					2050	0.31	0.33	1.2	0.53	-	-	0.028	0.14	0.077	0.32	2.7	1.6	
							-	0.34	-	-	127	-	-	4.7	-	-	19	-	-	1
13	1018-MS-100416-13-1	Concrete sample from Station # 13- top 1/4 "					102	3.8	0.59	0.92	2154	378	1.1	74	15	0.48	259	47	0.89	
	1018-MS-100416-13-2	Concrete sample from Station # 13- middle 1/2 "	-	x	-	-	137	0.37	0.34	0.90	585	92	0.30	15	2.7	0.096	2.8	0.76	0.19	
	1018-MS-100416-13-3	Concrete sample from Station # 13 - remainder of core					870	0.78	0.36	0.82	158	-	-	8.7	1.3	0.19	28	6.1	0.70	
							-	1.0	-	-	394	-	-	15	-	-	46	-	-	1
14	1019-MS-100416-13-1	Concrete sample from Station # 14 - top 1/4 "					53	5.0	0.48	1.9	534	79	0.38	16	3.1	0.16	46	7.5	0.29	
	1019-MS-100416-13-2	Concrete sample from Station # 14 - middle 1/2 "	-	x	-	-	138	1.2	0.41	0.74	407	65	0.33	13	2.4	0.22	40	6.7	0.22	
	1019-MS-100416-13-3	Concrete sample from Station # 14 - remainder of core					2530	0.29	0.34	0.72	270	-	-	13	1.8	0.23	4.5	3.4	1.6	
							-	0.43	-	-	282	-	-	13	-	-	7.1	-	-	1
15	1025-MS-100419-13-1	Concrete sample from Station # 15 - top 1/4 "					70	2.8	0.55	0.74	495	76	0.50	18	3.6	0.45	85	14	0.50	
	1025-MS-100419-13-2	Concrete sample from Station # 15 middle 1/2 "	-	-	-	x	125	1.2	0.41	0.75	0.78	0.31	0.22	0.049	0.068	0.066	0.39	0.20	0.066	
	1025-MS-100419-13-3	Concrete sample from Station # 15 - remainder of core					1190	1.6	0.39	1.2	15	-	-	0.84	0.24	0.11	2.9	3.0	1.5	
							-	1.6	-	-	38	-	-	1.7	-	-	6.8	-	-	1
16	1026-MS-100419-13-1	Concrete sample from Station # 16- top 1/4 "					104	125	6.3	2.1	10714	3817	8.5	415	155	6.8	2572	922	9.0	
	1026-MS-100419-13-2	Concrete sample from Station # 16- middle 1/2 "	-	x	x	-	133	2.4	0.49	0.87	1.2	0.40	0.20	0.18	0.14	0.071	0.47	0.23	0.12	
	1026-MS-100419-13-3	Concrete sample from Station # 16 - remainder of core					1750	6.7	0.91	0.86	5.0	-	-	0.23	0.16	0.078	5.8	2.9	0.77	
							-	13	-	-	565	-	-	22	-	-	140	-	-	1

Appendix D
Process Building Slab – Sampling Data and Gamma Walkover Survey (GWS)

Table 1, Sample Results, Stations 1 – 21 (Tc-99, U-234, U-235, and U-238)

Station ID	Sample ID	Description	Sample Type				Sample Mass (g)	Radionuclide Concentration												Notes
			Resurfaced Concrete Region	Expansion Joint, Crack, Seam, Near Wall	Identified as a Hot Spot	Representative of General Area		Tc-99			U-234			U-235			U-238			
								(pCi/g)			(pCi/g)			(pCi/g)			(pCi/g)			
								Conc.	±2s	MDC	Conc.	±2s	MDC	Conc.	±2s	MDC	Conc.	±2s	MDC	
17	1027-MS-100419-13-1	Concrete sample from Station # 17 - top 1/4 "	-	x	x	-	147	5.8	0.71	1.2	1125	199	1.2	39	8.6	0.47	297	54	1.4	
	1027-MS-100419-13-2	Concrete sample from Station # 17 - middle 1/2 "					230	2.4	0.54	0.85	4494	982	4.5	172	43	1.9	841	189	1.9	
	1027-MS-100419-13-3	Concrete sample from Station # 17 - remainder of core					1290	0.53	0.36	0.72	37	-	-	1.9	0.41	0.14	21	5.5	1.1	
							-	1.3	-	-	748	-	-	29	-	-	158	-	-	1
18	1028-MS-100419-13-1	Concrete sample from Station # 18 - top 1/4 "	-	x	-	-	90	1.8	0.41	1.1	629	108	1.2	23	5.4	0.42	222	39	0.42	
	1028-MS-100419-13-2	Concrete sample from Station # 18 - middle 1/2 "					138	0.60	0.39	0.77	793	189	1.2	41	11	0.52	327	79	1.2	
	1028-MS-100419-13-3	Concrete sample from Station # 18 - remainder of core					1100	0.094	0.35	0.84	203	-	-	11	1.6	0.25	129	20	1.4	
							-	0.26	-	-	293	-	-	15	-	-	156	-	-	1
19	1031-MS-100420-13-1	Concrete sample from Station # 19- top 1/4 "	-	-	-	x	73	7.1	0.73	1.4	3925	857	3.8	142	34	2.1	797	177	2.8	
	1031-MS-100420-13-2	Concrete sample from Station # 19- middle 1/2 "					124	7.5	1.3	0.70	2409	742	2.4	98	32	1.9	618	192	2.6	
	1031-MS-100420-13-3	Concrete sample from Station # 19 - remainder of core					3040	0.32	0.36	0.90	8.9	-	-	0.47	0.24	0.099	4.8	3.9	1.8	
							-	0.75	-	-	189	-	-	7.4	-	-	46	-	-	1
20	1032-MS-100420-13-1	Concrete sample from Station # 20 - top 1/4 "	-	x	-	-	82	643	32	2.1	1929	560	0.88	73	22	0.48	322	95	0.48	
	1032-MS-100420-13-2	Concrete sample from Station # 20 - middle 1/2 "					120	52	6.1	0.87	3.6	0.96	0.32	0.14	0.15	0.12	1.4	0.53	0.24	
	1032-MS-100420-13-3	Concrete sample from Station # 20 - remainder of core					2450	16	1.9	0.88	2.0	-	-	0.083	0.15	0.083	3.0	3.0	1.5	
							-	37	-	-	62	-	-	2.3	-	-	13	-	-	1
21	1033-MS-100420-13-1	Concrete sample from Station # 21 - top 1/4 "	-	-	x	-	74	750	37	2.1	170561	26694	389	5692	1488	328	24175	4433	181	
	1033-MS-100420-13-2	Concrete sample from Station # 21 - middle 1/2 "					124	2086	35	6.0	64	10	0.29	2.4	0.72	0.11	12	2.3	0.34	
	1033-MS-100420-13-3	Concrete sample from Station # 21 - remainder of core					2400	22	1.9	1.3	773	-	-	43	6.0	0.39	209	31	2.3	
							-	141	-	-	5575	-	-	202	-	-	882	-	-	1

Notes: 1 - weighted average over entire core

2 - weighted average over core,excluding top 3 inches

Appendix D
Process Building Slab – Sampling Data and Gamma Walkover Survey (GWS)

Table 2, Sample Results, stations 1 – 21 (Am-241, Np-237, and Pu-239)

Station ID	Description	Am-241 (pCi/g)			Np-237 (pCi/g)			Pu-239/240 (pCi/g)		
		Conc.	±2s	MDC	Conc.	±2s	MDC	Conc.	±2s	MDC
1	Concrete sample from Station # 1 - top 1/4 "	0.023	0.075	0.18	0.077	0.054	0.026	0.11	0.079	0.10
2a	Concrete sample from Station # 2 - top 1/4 "	0.045	0.078	0.15	0.099	0.12	0.18	0.067	0.063	0.088
2b	Concrete sample from Station # 2 - top 1/4" Subfloor	-0.022	0.0080	0.15	0.010	0.044	0.093	-0.040	0.056	0.14
3a	Concrete sample from Station # 3 - top 1/4 "	-0.025	0.0080	0.16	0.000	0.11	0.32	0.010	0.077	0.15
3b	Concrete sample from Station # 3 - top 1/4" Subfloor	-0.023	0.037	0.18	0.027	0.040	0.066	-0.018	0.058	0.13
4	Concrete sample from Station # 4 - top 1/4 "	0.000	0.048	0.16	0.071	0.11	0.19	0.010	0.045	0.095
5	Concrete sample from Station # 5 - top 1/4 "	0.024	0.059	0.14	0.085	0.10	0.16	0.010	0.093	0.18
6	Concrete sample from Station # 6 - top 1/4 "	0.062	0.11	0.23	0.041	0.14	0.34	-0.040	0.072	0.16
7	Concrete sample from Station # 7 - top 1/4 "	-0.023	0.038	0.18	0.29	0.21	0.28	-0.045	0.069	0.16
8	Concrete sample from Station #8 - top 1/4 "	-0.031	0.093	0.26	-0.030	0.057	0.25	0	0.059	0.13
9	Concrete sample from Station # 9 - top 1/4 "	0.00	0.092	0.24	0.037	0.13	0.31	0.032	0.036	0.029
10	Concrete sample from Station # 10- top 1/4 "	0.011	0.086	0.21	0.000	0.040	0.16	0.049	0.064	0.11
11	Concrete sample from Station # 11 - top 1/4 "	0.011	0.10	0.25	0.067	0.11	0.22	0.0090	0.038	0.081
12	Concrete sample from Station # 12 - top 1/4 "	0.021	0.066	0.16	0.098	0.30	0.74	-0.029	0.056	0.14
13	Concrete sample from Station # 13- top 1/4 "	0.053	0.11	0.23	0.070	0.098	0.095	-0.020	0.062	0.14
14	Concrete sample from Station # 14 - top 1/4 "	-0.019	0.042	0.16	0.000	0.069	0.22	0.021	0.041	0.078
15	Concrete sample from Station # 15 - top 1/4 "	0.00	0.064	0.18	0.015	0.055	0.11	-0.0070	0.030	0.076
16	Concrete sample from Station # 16- top 1/4 "	0.078	0.12	0.22	-0.028	0.038	0.21	-0.029	0.060	0.14
17	Concrete sample from Station # 17 - top 1/4 "	-0.096	0.064	0.27	0.13	0.095	0.12	0.072	0.062	0.076
18	Concrete sample from Station # 18 - top 1/4 "	0.046	0.087	0.18	0.076	0.13	0.25	0.0090	0.054	0.11
19	Concrete sample from Station # 19- top 1/4 "	-0.023	0.084	0.25	0.067	0.10	0.19	0.019	0.054	0.10
20	Concrete sample from Station # 20 - top 1/4 "	0.11	0.13	0.24	0.033	0.065	0.090	0.040	0.051	0.083
21	Concrete sample from Station # 21 - top 1/4 "	0.056	0.11	0.23	0.032	0.064	0.088	0.14	0.082	0.098

Note: Highlighted results (underlined /bold) indicates results > MDC.

Appendix D
Process Building Slab – Sampling Data and Gamma Walkover Survey (GWS)

Table 3, Sample Results, stations 1 – 21 (Ra-226, Th-232, and U-234)

Station ID	Description	Ra-226			Th-232			U-234		
		(pCi/g)			(pCi/g)			(pCi/g)		
		Conc.	±2s	MDC	Conc.	±2s	MDC	Conc.	±2s	MDC
1	Concrete sample from Station # 1 - top 1/4 "	0.76	0.29	0.068	0.19	0.16	0.20	178	26	0.23
	Concrete sample from Station # 1 - remainder of core	0.64	0.11	0.026	0.46	0.12	0.060	66	-	-
2	Concrete sample from Station # 2 - top 1/4 "	0.95	2.0	1.2	0.068	0.095	0.092	34384	4986	95
	Concrete sample from Station # 2 - remainder of core A	0.23	0.054	0.067	0.14	0.11	0.20	9.1	-	-
	1/4 inch Subfloor wafer	0.42	0.26	0.11	0.51	0.27	0.21	123	18	0.29
	Concrete sample from Station # 2 - remainder of core B	0.73	0.13	0.030	0.57	0.13	0.051	4.7	-	-
3	Concrete sample from Station # 3 - top 1/4 "	0.45	0.65	0.36	0.12	0.14	0.23	15232	4884	5.6
	Concrete sample from Station # 3 - remainder of core A	0.23	0.097	0.13	0.055	0.15	0.26	1183	-	-
	1/4 inch Subfloor wafer	0.78	0.30	0.090	0.20	0.17	0.22	107	16	0.27
	Concrete sample from Station # 3 - remainder of core B	0.59	0.094	0.031	0.38	0.11	0.10	4.6	-	-
4	Concrete sample from Station # 4 - top 1/4 "	0.69	0.30	0.12	0.39	0.23	0.088	1439	262	1.3
	Concrete sample from Station # 4 - remainder of core	0.53	0.15	0.049	0.51	0.13	0.065	2787	-	-
5	Concrete sample from Station # 5 - top 1/4 "	1.5	0.64	0.64	0.50	0.25	0.16	37544	6057	145
	Concrete sample from Station # 5 - remainder of core	0.73	0.12	0.034	0.75	0.14	0.067	12	-	-
6	Concrete sample from Station # 6 - top 1/4 "	0.87	1.1	1.3	1.1	0.41	0.24	20166	3281	104
	Concrete sample from Station # 6 - remainder of core	0.72	0.13	0.024	0.60	0.12	0.049	2.2	-	-
7	Concrete sample from Station # 7 - top 1/4 "	1.0	0.65	0.23	0.87	0.38	0.24	3304	868	5.6
	Concrete sample from Station # 7 - remainder of core	0.68	0.12	0.031	0.56	0.11	0.048	4.7	-	-
8	Concrete sample from Station #8 - top 1/4 "	0.35	0.21	0.27	0.0090	0.070	0.21	2599	463	1.7
	Concrete sample from Station # 8 - remainder of core	0.41	0.093	0.028	0.16	0.10	0.089	10	-	-
9	Concrete sample from Station # 9 - top 1/4 "	0.71	0.87	0.48	0.18	0.15	0.082	11874	2919	4.8
	Concrete sample from Station # 9 - remainder of core	0.28	0.077	0.023	0.093	0.065	0.070	2.4	-	-
10	Concrete sample from Station # 10- top 1/4 "	1.6	0.95	0.39	0.19	0.18	0.24	36426	5775	82
	Concrete sample from Station # 10 - remainder of core	0.38	0.096	0.025	0.11	0.065	0.073	29	-	-
11	Concrete sample from Station # 11 - top 1/4 "	0.33	0.29	0.16	0.24	0.21	0.28	1523	257	1.1
	Concrete sample from Station # 11 - remainder of core	0.33	0.077	0.021	0.32	0.098	0.052	39	-	-
12	Concrete sample from Station # 12 - top 1/4 "	0.20	0.25	0.68	1.4	0.50	0.10	4481	949	2.2
	Concrete sample from Station # 12 - remainder of core	0.35	0.083	0.025	0.18	0.096	0.073	0.53	-	-
13	Concrete sample from Station # 13- top 1/4 "	0.31	0.39	0.26	0.34	0.24	0.28	2154	378	1.1
	Concrete sample from Station # 13 - remainder of core	0.47	0.10	0.025	0.15	0.078	0.068	158	-	-
14	Concrete sample from Station # 14 - top 1/4 "	0.026	0.34	0.20	0.011	0.086	0.26	534	79	0.38
	Concrete sample from Station # 14 - remainder of core	0.52	0.11	0.023	0.16	0.11	0.073	270	-	-
15	Concrete sample from Station # 15 - top 1/4 "	1.1	0.31	0.14	0.22	0.18	0.23	495	76	0.50
	Concrete sample from Station # 15 - remainder of core	0.61	0.12	0.025	0.14	0.076	0.072	15	-	-

**Appendix D
Process Building Slab – Sampling Data and Gamma Walkover Survey (GWS)**

Table 3, Sample Results, stations 1 – 21 (Ra-226, Th-232, and U-234)

Station ID	Description	Ra-226			Th-232			U-234		
		(pCi/g)			(pCi/g)			(pCi/g)		
		Conc.	±2s	MDC	Conc.	±2s	MDC	Conc.	±2s	MDC
16	Concrete sample from Station # 16- top 1/4 "	0.82	0.51	0.24	1.2	0.47	0.27	10714	3817	8.5
	Concrete sample from Station # 16 - remainder of core	0.62	0.13	0.026	0.077	0.040	0.090	5.0	-	-
17	Concrete sample from Station # 17 - top 1/4 "	0.80	0.33	0.093	0.13	0.15	0.24	1125	199	1.2
	Concrete sample from Station # 17 - remainder of core	0.67	0.13	0.036	0.17	0.078	0.074	37	-	-
18	Concrete sample from Station # 18 - top 1/4 "	0.51	0.26	0.25	0.51	0.27	0.092	629	108	1.2
	Concrete sample from Station # 18 - remainder of core	0.55	0.13	0.034	0.21	0.090	0.077	203	-	-
19	Concrete sample from Station # 19- top 1/4 "	0.85	0.42	0.15	0.30	0.24	0.27	3925	857	3.8
	Concrete sample from Station # 19 - remainder of core	0.59	0.13	0.030	0.17	0.077	0.077	8.9	-	-
20	Concrete sample from Station # 20 - top 1/4 "	0.91	1.0	0.58	0.093	0.14	0.24	1929	560	0.88
	Concrete sample from Station # 20 - remainder of core	0.53	0.11	0.024	0.10	0.078	0.069	2.0	-	-
21	Concrete sample from Station # 21 - top 1/4 "	3.1	0.96	1.1	0.64	0.33	0.11	170561	26694	389
	Concrete sample from Station # 21 - remainder of core	0.53	0.13	0.034	0.30	0.11	0.057	773	-	-

Appendix D
Process Building Slab – Sampling Data and Gamma Walkover Survey (GWS)

Table 4, Sample Results, stations 31 – 59 (Tc-99, U-234, U-235, and U-238)

Station ID	Sample ID	Sample Depth	Building / Room	Tc-99			U-234			U-235			U-238			Notes
				(pCi/g)			(pCi/g)			(pCi/g)			(pCi/g)			
				Conc.	±2s	MDC	Conc.	±2s	MDC	Conc.	±2s	MDC	Conc.	±2s	MDC	
31	1855-MS-110621-9-1	0" - 3.5"	240-11 Red Room	0.0	0.11	1.7	0.38			0.020	0.0019	0.0044	0.20	0.018	0.0001	
	1869-MS-110621-9-1	3.5" - 10.5"		0.0	0.11	1.7	1.4			0.078	0.0083	0.0044	0.21	0.020	0.0001	
				1.7			1.1			0.1			0.2			1
32	1852-MS-110620-9-1a	0" - 3"	240-11 Red Room	2.3	0.26	1.7	0.56			0.030	0.0042	0.0044	0.23	0.021	0.0001	
	1868-MS-110620-9-1	3" - 11.5"		0.0	0.032	1.7	0.38			0.020	0.0025	0.0044	0.22	0.020	0.0001	
				1.9			0.43			0.02			0.22			1
33	1855-MS-110621-9-3	0" - 3"	240-11 Red Room	0.0	0.18	2.0	0.92			0.050	0.0052	0.0044	0.34	0.031	0.0001	
	1869-MS-110621-9-2	3" - 9.5"		0.0	0.019	1.7	1.4			0.075	0.0091	0.0044	0.30	0.028	0.0001	
				1.8			1.2			0.1			0.3			1
34	1855-MS-110621-9-5	0" - 3"	240-11 Red Room	3.4	0.38	2.0	9.3			0.51	0.051	0.0040	2.2	0.20	0.0001	
	1869-MS-110621-9-3	3" - 10.5"		0.0	0.13	1.7	9.8			0.48	0.044	0.0040	0.26	0.024	0.0001	
				2.2			9.7			0.5			0.8			1
35	1855-MS-110621-9-6	0" - 2.5"	240-11 Red Room	725	66	2.0	46			2.5	0.23	0.0040	10.0	0.95	0.0001	
	1869-MS-110621-9-4	2.5" - 10"		1.8	0.16	1.7	1.1			0.061	0.0063	0.0044	0.25	0.023	0.0001	
				183			12			1			3			1
36	1856-MS-110622-9-7	0" - 6"	253-26 Ring Storage	0.0	0.15	2.0	0.39			0.021	0.0034	0.0044	0.19	0.018	0.0001	
37	1856-MS-110622-9-9	0" - 6"	253-26 Ring Storage	2.5	0.26	2.2	2.8			0.16	0.015	0.0040	0.66	0.063	0.0001	
38	1856-MS-110622-9-15	0" - 6"	260-65 UF6 Vapor	3.7	0.35	1.7	13			0.69	0.065	0.0040	2.8	0.30	0.0001	
39	1866-MS-110623-9-1	0" - 11.75"	260-65 UF6 Vapor	2.7	0.26	2.3	11			0.63	0.058	0.0040	2.8	0.27	0.0001	
40	1866-MS-110623-9-3	0" - 11.25"	260-65 UF6 Vapor	11	1.2	2.0	44			2.4	0.22	0.0040	12	1.1	0.0000	
41	1866-MS-110623-9-5	0" - 11.25"	260-65 UF6 Vapor	7.6	0.74	2.6	39			2.2	0.20	0.0040	9.3	0.89	0.0000	
42	1866-MS-110623-9-7	0" - 11.5"	260-65 UF6 Vapor	5.0	0.55	2.2	12			0.65	0.060	0.0040	3.2	0.29	0.0001	
43	1856-MS-110622-9-3	0" - 6"	240-9 Laundry	0.0	0.11	1.7	1.1			0.057	0.0066	0.0044	0.52	0.048	0.0001	
44	1852-MS-110620-9-7	0" - 5.75"	240-3 Green Room	0.0	0.12	1.7	5.4			0.30	0.027	0.0040	1.7	0.16	0.0001	
45	1852-MS-110620-9-5	0" - 7.25"	240-14 Maint Shop	0.0	0.056	2.5	2.7			0.14	0.014	0.0040	1.9	0.18	0.0001	
46	1852-MS-110620-9-3	0" - 6.5"	240-14 Maint Shop	0.0	0.047	1.7	15			0.78	0.071	0.0040	6.2	0.58	0.0001	
47	1856-MS-110622-9-5	0" - 5.7"	253-25 Ring Storage	0.0	0.10	1.7	1.4			0.080	0.0089	0.0044	0.41	0.040	0.0001	
48	1856-MS-110622-9-11	0" - 5"	253-29 Waste Prep	2.5	0.28	1.7	3.0			0.17	0.017	0.0040	0.72	0.066	0.0001	
49	1856-MS-110622-9-13	0" - 7.5"	254-33 Ceramic	0.0	0.057	1.7	0.18			0.0090	0.0016	0.0044	0.13	0.013	0.0001	
50	1867-MS-110624-9-3	0" - 5.5"	256-38 Pellet Kardex	0.0	0.050	1.8	0.32			0.017	0.0020	0.0044	0.18	0.018	0.0001	
51	1867-MS-110624-9-1	0" - 5.5"	256-64 Warehouse	0.0	0.061	1.7	0.23			0.012	0.0014	0.0044	0.16	0.015	0.0001	
52	1852-MS-110620-9-1b	0" - 7.5"	252 South Vault	8.4	0.85	1.7	51			2.8	0.26	0.0040	10	0.96	0.0000	
53	1843-MS-110617-9-1	0" - 8.5"	252 South Vault	3.0	0.31	1.7	40			2.2	0.20	0.0040	4.4	0.41	0.0000	

Appendix D
Process Building Slab – Sampling Data and Gamma Walkover Survey (GWS)

Table 4, Sample Results, stations 31 – 59 (Tc-99, U-234, U-235, and U-238)

Station ID	Sample ID	Sample Depth	Building / Room	Tc-99			U-234			U-235			U-238			Notes
				(pCi/g)			(pCi/g)			(pCi/g)			(pCi/g)			
				Conc.	±2s	MDC	Conc.	±2s	MDC	Conc.	±2s	MDC	Conc.	±2s	MDC	
54	1867-MS-110624-9-5	0" - 8.25"	235 West Vault	0.0	0.052	1.8	9.2			0.50	0.048	0.0040	0.75	0.068	0.0001	
55	1867-MS-110624-9-7	0" - 7.25"	235 West Vault	0.0	0.059	2.0	34			1.7	0.15	0.0040	0.98	0.093	0.0001	
56	1902-MS-110810-09-05	0 - 0.25"	South Vault	1.8	0.71	1.0	2290	200	2.0	92	15	1.0	140	18	2.0	
	1902-MS-110810-09-06	0.25" - 0.75"		1.4	0.67	1.0	2010	180	3.0	89	19	5.0	177	26	4.0	
				1.6			2103.3			90.0			164.7			1
57	1902-MS-110810-09-07	0 - 0.25"	South Vault	0.89	0.79	1.3	1150	200	40	64	48	41	7.0	20	42	
	1902-MS-110810-09-08	0.25" - 0.75"		4.6	0.94	1.1	1830	290	60	71	54	27	0.0	7.0	22	
				3.4			1603.3			68.7			2.3			1
58	1902-MS-110810-09-01	0 - 0.25"	254 (Elevated Area 3)	0.14	0.69	1.2	2010	180	2.0	80	14	2.0	313	35	2.0	
	1902-MS-110810-09-02	0.25" - 0.75"		-0.42	0.59	1.1	437	44	2.0	18	5.8	2.1	64	11	2.0	
				0.8			961.3			38.8			147.0			1
59	1902-MS-110810-09-03	0 - 0.25"	254 (Elevated Area 3)	2.2	0.86	1.3	3260	280	2.0	147	21	1.0	524	53	3.0	
	1902-MS-110810-09-04	0.25" - 0.75"		2.0	0.80	1.2	2400	210	3.0	101	17	3.0	372	40	2.0	
				2.1			2686.7			116.3			422.7			1

Notes: 1 - weighted average over entire core

Appendix E
Process Building Slab –Radium 226 Data, Two Sample t-test
(upper and lower samples)

Figure E-1, Q-Q Plot for Ra-226 Concentration in Upper Core Section, Adjusted to Account for U-234 Corrolated Component





Figure E-2, Q-Q Plot for Ra-226 Concentration in Upper Core Section, Adjusted to Account for U-234 Corrolated Component



Appendix E
Process Building Slab –Radium 226 Data, Two Sample t-test
(upper and lower samples)

Figure E-3, Pro-UCL Two-Sample T-Test, Ra-226 in Upper and Lower Core Segments

t-Test Site vs Background Comparison for Full Data Sets without NDs

User Selected Options

From File P:\hematite project\US Ecology\Concrete 2\characterization data\radium data.wst
 Full Precision OFF
 Confidence Coefficient 95%
 Substantial Difference (S) 0
 Selected Null Hypothesis Site or AOC Mean Less Than or Equal to Background Mean (Form 1)
 Alternative Hypothesis Site or AOC Mean Greater Than the Background Mean
 Area of Concern Data: Ra-226 Upper (Adj)
 Background Data: Ra-226 Lower (Adj)

Raw Statistics	Site	Background
Number of Valid Observations	23	23
Number of Distinct Observations	22	20
Minimum	0	0.21
Maximum	1.04	0.73
Mean	0.541	0.513
Median	0.51	0.53
SD	0.312	0.158
SE of Mean	0.065	0.033

Site vs. Background Two-Sample t-Test

H0: Mu of Site - Mu of Background <= 0

Method	DF	t-Test Value	Critical t (0.050)	P-Value
Pooled (Equal Variance)	44	0.388	1.68	0.35
Welch-Satterthwaite (Unequal Variance)	32.7	0.388	1.692	0.35

Pooled SD 0.247

Conclusion with Alpha = 0.050

* Student t (Pooled) Test: Do Not Reject H0, Conclude Site <= Background

* Welch-Satterthwaite Test: Do Not Reject H0, Conclude Site <= Background

Test of Equality of Variances

Variance of Site	0.0971		
Variance of Background	0.0251		
Numerator DF	Denominator DF	F-Test Value	P-Value
22	22	3.87	0.002

Conclusion with Alpha = 0.05

* Two variances are not equal

**Appendix F
Volume Estimates for Underground Piping**

Building-Room	Line Designation		Direction	Length (ft)	Pipe OD (in)	Pipe ID (in)	Pipe Material of Construction	Volume (wall) (ft ³)	Volume (interior) (ft ³)	% Filled (debris)	Mass (wall) (g)	Mass (debris) (g)
	From	To/Toward										
Building 230 Northernmost System												
230	CO-231	CO-301	South	37	4.50000	4.026	PVC	0.82	3.27	40%	3.1E+04	5.6E+04
230	WC-301	CO 231 - CO301	East	5	4.50000	4.026	PVC	0.11	0.44	40%	4.2E+03	7.5E+03
230	FD-308	CO 231 - CO301	East	8	4.50000	4.026	PVC	0.18	0.71	40%	6.8E+03	1.2E+04
230	WC-303	CO 232 - CO302	West	11	4.50000	4.026	PVC	0.24	0.97	40%	9.3E+03	1.7E+04
230	CO-232	CO302	South	37	4.50000	4.026	PVC	0.82	3.27	40%	3.1E+04	5.6E+04
230	FD-304	CO 232 - CO302	East	8	4.50000	4.026	PVC	0.18	0.71	40%	6.8E+03	1.2E+04
230	FD-312	CO 232 - CO302	West	6	4.50000	4.026	PVC	0.13	0.53	40%	5.1E+03	9.0E+03
230	WC-302	CO 231 - CO301	West	7	4.50000	4.026	PVC	0.15	0.62	40%	5.9E+03	1.1E+04
230	FD-306	CO 232 - CO302	SouthWest	8	4.50000	4.026	PVC	0.18	0.71	40%	6.8E+03	1.2E+04
230	FD-307	FD-306	North	8	4.50000	4.026	PVC	0.18	0.71	40%	6.8E+03	1.2E+04
230	WC-303	CO 231 - CO301	West	11	4.50000	4.026	PVC	0.24	0.97	40%	9.3E+03	1.7E+04
230	FD-309	CO 232 - CO301	West	7	4.50000	4.026	PVC	0.15	0.62	40%	5.9E+03	1.1E+04
230	CO-301	CO-303	East	34	4.50000	4.026	PVC	0.75	3.00	40%	2.9E+04	5.1E+04
230	FD-310	CO 301 - CO303	West	11	4.50000	4.026	PVC	0.24	0.97	40%	9.3E+03	1.7E+04
230	FD-308	CO 232 - CO 302	East	8	4.50000	4.026	PVC	0.18	0.71	40%	6.8E+03	1.2E+04
230	FD-311	CO 302 - CO 303	South	8	4.50000	4.026	PVC	0.18	0.71	40%	6.8E+03	1.2E+04
230	CO-302	CO-304	East	35	4.50000	4.026	PVC	0.77	3.09	40%	3.0E+04	5.3E+04
230	CO-303	MH 05 - MH 21	SouthEast	70	4.50000	4.026	PVC	1.54	6.19	40%	5.9E+04	1.1E+05
230	CO-304	MH 04 - MH 13	SouthEast	60	4.50000	4.026	PVC	1.32	5.30	40%	5.1E+04	9.0E+04
Building 230 Middle System												
230	CO-305	MH 04 - MH 13	East	72	4.50000	4.026	PVC	1.59	6.36	40%	6.1E+04	1.1E+05
230	FD 312	CO 305	West	15	4.50000	4.026	PVC	0.33	1.33	40%	1.3E+04	2.3E+04
230	FD 313	FD 312	South	8	4.50000	4.026	PVC	0.18	0.71	40%	6.8E+03	1.2E+04
230	FD 315	CO 305	North	10	4.50000	4.026	PVC	0.22	0.88	40%	8.5E+03	1.5E+04
230	FD-316	CO-305	North	10	4.50000	4.026	PVC	0.22	0.88	40%	8.5E+03	1.5E+04
Building 230 Southernmost System												
230	CO-233	FD-319	East then	21	4.50000	4.026	PVC	0.90	3.62	40%	3.5E+04	6.2E+04
			SouthEast	20								
230	FD-317	CO-233	South	1	4.00000	4	PVC	0.00	0.09	40%	0.0E+00	1.5E+03
230	FD-318	CO-233	South	4	4.50000	4.026	PVC	0.09	0.35	40%	3.4E+03	6.0E+03
230	FD-319	MH 22 - MH 01	East then	40	4.50000	4.026	PVC	2.49	9.98	40%	9.6E+04	1.7E+05
			South	73								
Northernmost System Building 240												

**Appendix F
Volume Estimates for Underground Piping**

Building-Room	Line Designation		Direction	Length (ft)	Pipe OD (in)	Pipe ID (in)	Pipe Material of Construction	Volume (wall) (ft ³)	Volume (interior) (ft ³)	% Filled (debris)	Mass (wall) (g)	Mass (debris) (g)
	From	To/Toward										
240-09	FD 203	SD-204- MH 17	North then	4	5.00000	4	Cast Iron	1.18	2.09	40%	2.4E+05	3.6E+04
			South	20								
240-09	FD-202	FD-320	North	44	5.00000	4	Cast Iron	2.16	3.84	40%	4.4E+05	6.5E+04
240-09	FD-201	FD-202	East	2	5.00000	4	Cast Iron	0.10	0.17	40%	2.0E+04	3.0E+03
240-05	FD-320	FD-321 (CO-Lab North)	West	50	5.00000	4	Cast Iron	2.45	4.36	40%	5.0E+05	7.4E+04
240-09	CO-306	FD-321	West	8	5.00000	4	Cast Iron	0.39	0.70	40%	8.0E+04	1.2E+04
240-07	FD-321 (Co Lab North)	CO-308	South	35	5.00000	4	Cast Iron	5.84	10.38	40%	1.2E+06	1.8E+05
			West	84								
240-09	CO-306	FD-321	West	8	5.00000	4	Cast Iron	0.39	0.70	40%	8.0E+04	1.2E+04
240-09	FD-322	FD-321	West	3	5.00000	4	Cast Iron	0.15	0.26	40%	3.0E+04	4.4E+03
240-07	FD-326	FD-321	West	8	5.00000	4	Cast Iron	0.39	0.70	40%	8.0E+04	1.2E+04
240-07	FD-327	FD-321	West	8	5.00000	4	Cast Iron	0.39	0.70	40%	8.0E+04	1.2E+04
240-07	CO-307	MH 04 - MH-13	West	18	4.50000	4	PVC	3.54	13.35	40%	1.4E+05	2.3E+05
			North	46								
			West	89								
240-07	CO-308	FD-321	West then	32	5.00000	4	Cast Iron	1.86	3.31	40%	3.8E+05	5.6E+04
			North	6								
240-07	FD-325	CO-307	North	2	4.50000	4	PVC	0.05	0.17	40%	1.8E+03	3.0E+03
240-07	FD-328	CO-307	North	2	4.50000	4	PVC	0.05	0.17	40%	1.8E+03	3.0E+03
240-07	FD-324	CO-307	North	2	4.50000	4	PVC	0.05	0.17	40%	1.8E+03	3.0E+03
240-07	FD-329	CO-307	West	8	4.50000	4	PVC	0.19	0.70	40%	7.1E+03	1.2E+04
Middle System Building 240												
240-02	Co-209	8" Process Drain	West	110	5.00000	4	Cast Iron	5.40	9.59	100%	1.1E+06	4.1E+05
240-02	PD-209	Co-209	South	6	5.00000	4	Cast Iron	0.29	0.52	40%	6.0E+04	8.9E+03
240-02	PD-208	Co-209	South	5	5.00000	4	Cast Iron	0.25	0.44	40%	5.0E+04	7.4E+03
240-02	PD-207	Co-209	North	3	5.00000	4	Cast Iron	0.15	0.26	40%	3.0E+04	4.4E+03
240-02	CO-37	Co-209	North	57	5.00000	4	Cast Iron	2.80	4.97	20%	5.7E+05	4.2E+04
240-02	PD-37	CO-37	North	5	5.00000	4	Cast Iron	0.25	0.44	40%	5.0E+04	7.4E+03
240-03	PD-336	PD-333	West	46	5.00000	4	Cast Iron	2.26	4.01	40%	4.6E+05	6.8E+04
240-03	PD-335	PD-336	North	37	5.00000	4	Cast Iron	1.82	3.23	40%	3.7E+05	5.5E+04
240-03	PD-334	PD-335	East	18	5.00000	4	Cast Iron	0.88	1.57	40%	1.8E+05	2.7E+04
240-03	PD-332	PD-333	North	38	5.00000	4	Cast Iron	1.86	3.31	40%	3.8E+05	5.6E+04
240-03	PD-333	Co-209	North	56	5.00000	4	Cast Iron	2.75	4.88	40%	5.6E+05	8.3E+04
240-02	FP-36	PD-333	West	4	5.00000	4	Cast Iron	0.20	0.35	40%	4.0E+04	5.9E+03

**Appendix F
Volume Estimates for Underground Piping**

Building-Room	Line Designation		Direction	Length (ft)	Pipe OD (in)	Pipe ID (in)	Pipe Material of Construction	Volume (wall) (ft ³)	Volume (interior) (ft ³)	% Filled (debris)	Mass (wall) (g)	Mass (debris) (g)
	From	To/Toward										
240-03	PD-331	PD-333	West	4	5.00000	4	Cast Iron	0.20	0.35	40%	4.0E+04	5.9E+03
240-03	PD-330-1	PD-333	West	4	5.00000	4	Cast Iron	0.20	0.35	40%	4.0E+04	5.9E+03
Southernmost System Building 240												
240-14	CO-311 (NEMS)	8" Process Drain	West	88	5.00000	4	Cast Iron	4.32	7.68	40%	8.8E+05	1.3E+05
240-14	PD-339	CO-311	South	4	5.00000	4	Cast Iron	0.20	0.35	40%	4.0E+04	5.9E+03
240-14	PD-338	CO-311	South	4	5.00000	4	Cast Iron	0.20	0.35	40%	4.0E+04	5.9E+03
240-14	PD-41	CO-311	South	4	5.00000	4	Cast Iron	0.20	0.35	40%	4.0E+04	5.9E+03
240-14	PD-337	CO-311	North	35	5.00000	4	Cast Iron	1.72	3.05	40%	3.5E+05	5.2E+04
240-14	CO-312	PD-337	West	20	5.00000	4	Cast Iron	0.98	1.74	40%	2.0E+05	3.0E+04
240-14	CO-313	CO-311	West	31	5.00000	4	Cast Iron	1.52	2.70	40%	3.1E+05	4.6E+04
240-14	PD-44	CO-313	East	9	5.00000	4	Cast Iron	0.44	0.79	40%	9.0E+04	1.3E+04
240-14	PD-43	CO-313	West	10	5.00000	4	Cast Iron	0.49	0.87	40%	1.0E+05	1.5E+04
240-14	CO-45	CO-311	East	19	5.00000	4	Cast Iron	0.93	1.66	20%	1.9E+05	1.4E+04
Northernmost Process System in Building 255												
255	PD-340	CO-226	South	15	5.00000	4	Cast Iron	0.74	1.31	40%	1.5E+05	2.2E+04
255	PD-233	CO-226	South	15	5.00000	4	Cast Iron	0.74	1.31	40%	1.5E+05	2.2E+04
255	PD-341	CO-226	South	15	5.00000	4	Cast Iron	0.74	1.31	40%	1.5E+05	2.2E+04
255	PD-342	CO-226	South	15	5.00000	4	Cast Iron	0.74	1.31	40%	1.5E+05	2.2E+04
255	PD-226	CO-225	West	74	5.00000	4	Cast Iron	3.63	6.45	15%	7.4E+05	4.1E+04
255	Co-225	MH 15 - MH-12	South	40	5.00000	4	PVC	1.96	6.11	40%	7.6E+04	1.0E+05
			West	30								
255	PD-343	CO-225	South	10	5.00000	4	Cast Iron	0.49	0.87	40%	1.0E+05	1.5E+04
255	CO-315	CO-316	West	74	5.00000	4	Cast Iron	3.63	6.45	40%	7.4E+05	1.1E+05
255	CO-344	CO-315	North	24	5.00000	4	Cast Iron	1.18	2.09	40%	2.4E+05	3.6E+04
255	CO-345	CO-315	South	3	5.00000	4	Cast Iron	0.15	0.26	40%	3.0E+04	4.4E+03
255	PD-229	CO-315	North	24	5.00000	4	Cast Iron	1.18	2.09	40%	2.4E+05	3.6E+04
255	PD-228	CO-315	South	2	5.00000	4	Cast Iron	0.10	0.17	20%	2.0E+04	1.5E+03
255	CO-316	CO-225	North	15	5.00000	4	Cast Iron	0.74	1.31	40%	1.5E+05	2.2E+04
Southernmost Process System in Building 255												
255	CO-320	MH 15 - MH 12	West	100	5.00000	4	Cast Iron	4.91	8.72	10%	1.0E+06	3.7E+04
255	PD-142	CO-320	South	40	5.00000	4	Cast Iron	1.96	3.49	10%	4.0E+05	1.5E+04
255	Co-232	CO-320	North	39	5.00000	4	Cast Iron	1.91	3.40	10%	3.9E+05	1.4E+04

Appendix F
Volume Estimates for Underground Piping

Building-Room	Line Designation		Direction	Length (ft)	Pipe OD (in)	Pipe ID (in)	Pipe Material of Construction	Volume (wall) (ft ³)	Volume (interior) (ft ³)	% Filled (debris)	Mass (wall) (g)	Mass (debris) (g)
	From	To/Toward										
255	PD-232	CO-320	North	8	5.00000	4	Cast Iron	0.39	0.70	10%	8.0E+04	3.0E+03
255	PD-231	CO-320	North	8	5.00000	4	Cast Iron	0.39	0.70	40%	8.0E+04	1.2E+04
255	PD-153	CO-320	South	15	5.00000	4	Cast Iron	0.74	1.31	40%	1.5E+05	2.2E+04
255	PD-152	CO-320	South	15	5.00000	4	Cast Iron	0.74	1.31	40%	1.5E+05	2.2E+04
255	CO-319	CO-320	South	30	5.00000	4	Cast Iron	1.47	2.62	40%	3.0E+05	4.4E+04
255	CO-230	CO-320	North	41	5.00000	4	Cast Iron	2.01	3.58	25%	4.1E+05	3.8E+04
255	CO-317	CO-318	West	64	5.00000	4	Cast Iron	3.14	5.58	40%	6.4E+05	9.5E+04
255	PD-345	CO-317	North	3	5.00000	4	Cast Iron	0.15	0.26	40%	3.0E+04	4.4E+03
255	PD-346	CO-317	North	3	5.00000	4	Cast Iron	0.15	0.26	40%	3.0E+04	4.4E+03
255	PD-230	CO-317	North	3	5.00000	4	Cast Iron	0.15	0.26	40%	3.0E+04	4.4E+03
Sanitary Lines in Building 255												
255	FD-120	MH 10 - FD224	North	9	4.50000	4	PVC	1.71	6.45	40%	6.6E+04	1.1E+05
			East	15								
			North	50								
255	FD-121	FD-120	North	5	4.50000	4	PVC	0.12	0.44	40%	4.5E+03	7.4E+03
255	FD-122	FD-120	south	4	4.50000	4	PVC	0.09	0.35	40%	3.6E+03	5.9E+03
255	FD-123	FD-120	South	4	4.50000	4	PVC	0.09	0.35	40%	3.6E+03	5.9E+03
255	FD-124	FD-120	North	8	4.50000	4	PVC	0.19	0.70	40%	7.1E+03	1.2E+04
255	CO-220	FD-120	North	34	4.50000	4	PVC	0.79	2.97	40%	3.0E+04	5.0E+04
Sanitary and Grey Water lines in Building 255												
255	FD-224	MH-10	North	10	4.50000	4	PVC	1.95	7.33	40%	7.5E+04	1.2E+05
			NorthWest	24								
			West	50								
255	FD-348	FD-224	North	10	4.50000	4	PVC	0.23	0.87	40%	8.9E+03	1.5E+04
255	Co-222	MH-11	West	10	4.50000	4	PVC	1.60	6.02	40%	6.2E+04	1.0E+05
			North	39								
			West	20								
255	FD-347	FD-224	SouthWest	8	4.50000	4	PVC	0.19	0.70	40%	7.1E+03	1.2E+04
255	FD-349	FD-224	East	12	4.50000	4	PVC	0.28	1.05	40%	1.1E+04	1.8E+04
255	Co-221	MH-11	East	25	4.50000	4	PVC	1.34	5.06	40%	5.2E+04	8.6E+04
			North	33								
255	FD-350	FD-221	East	12	4.50000	4	PVC	0.28	1.05	40%	1.1E+04	1.8E+04
Building 260												

**Appendix F
Volume Estimates for Underground Piping**

Building-Room	Line Designation		Direction	Length (ft)	Pipe OD (in)	Pipe ID (in)	Pipe Material of Construction	Volume (wall) (ft ³)	Volume (interior) (ft ³)	% Filled (debris)	Mass (wall) (g)	Mass (debris) (g)
	From	To/Toward										
2260	PD-170	MH-16	East	20	4.50000	4	PVC	1.46	5.50	5%	5.6E+04	1.2E+04
			North	43								
255	PD-164	MH-16	East	21	5.00000	4	Cast Iron	1.03	1.83	40%	2.1E+05	3.1E+04
Building 254												
254	FD-354	MH-11 -MH-05	South	8	4.5	4	PVC	1.34	5.06	40%	5.2E+04	8.6E+04
			East	20								
			North	30								
254	FD-351	FD-354	North	6	4.5	4	PVC	0.14	0.52	40%	5.4E+03	8.9E+03
240-07	FD-355	FD-354	South	8	5	4	PVC	2.01	3.58	40%	7.7E+04	6.1E+04
			West	33								
254	FD-356	FD-354	North	6	4.5	4	PVC	0.14	0.52	40%	5.4E+03	8.9E+03
254	FD-353	FD-354	North	8	4.5	4	PVC	0.93	3.49	40%	3.6E+04	5.9E+04
			East	12								
			North	20								
254	352	FD-353	West	8	4.5	4	PVC	0.19	0.70	40%	7.1E+03	1.2E+04
254-256	MH-12	MH15	North	225	19.75	15	RCP	202.46	275.98	5%	1.4E+07	5.9E+05
254-256	DS-97	MH15	West	14	19.75	15	RCP	12.60	17.17	40%	8.9E+05	2.9E+05
254-256	DS-96	MH15	West	14	19.75	15	RCP	12.60	17.17	40%	8.9E+05	2.9E+05
254-256	DS-95	MH15	West	14	19.75	15	RCP	12.60	17.17	40%	8.9E+05	2.9E+05
254-256	DS-94	MH15	West	14	19.75	15	RCP	12.60	17.17	40%	8.9E+05	2.9E+05
254-256	DS-93	MH15	West	14	19.75	15	RCP	12.60	17.17	40%	8.9E+05	2.9E+05
Building 253												
253	FD-360	MH10-MH 05	West	30	4.5000	4	PVC	3.01	11.34	40%	1.2E+05	1.9E+05
			North	100								
253	MH-08	MH-15	East	114	4.5000	4	PVC	2.64	9.94	5%	1.0E+05	2.1E+04
253	DS-113	MH-15 - MH 08	North	12	4.5000	4	PVC	0.28	1.05	40%	1.1E+04	1.8E+04
Sanitary and Grey Water lines in Building 253												
253	FD-361	FD-360	East	15	4.5000	4	PVC	0.35	1.31	40%	1.3E+04	2.2E+04
253	FD-362	FD-361	North	2	4.5000	4	PVC	0.05	0.17	40%	1.8E+03	3.0E+03
253	FD-363	FD-361	North	2	4.5000	4	PVC	0.05	0.17	40%	1.8E+03	3.0E+03
253	FD-364	FD-361	South	2	4.5000	4	PVC	0.05	0.17	40%	1.8E+03	3.0E+03


**Appendix F
Volume Estimates for Underground Piping**

Building-Room	Line Designation		Direction	Length (ft)	Pipe OD (in)	Pipe ID (in)	Pipe Material of Construction	Volume (wall) (ft ³)	Volume (interior) (ft ³)	% Filled (debris)	Mass (wall) (g)	Mass (debris) (g)
	From	To/Toward										
Storm Water Lines Building 253												
253	DS-57	MH08-MH 15	East	35	4.5000	4	PVC	5.65	21.28	40%	2.2E+05	3.6E+05
			North	209								
253	DS-105	DS-57 - MH 08	West	10	4.5000	4	PVC	0.23	0.87	40%	8.9E+03	1.5E+04
253	DS-50	DS-57 - MH 08	East	35	4.5000	4	PVC	0.81	3.05	40%	3.1E+04	5.2E+04
253	DS-49	DS-57 - MH 08	East	35	4.5000	4	PVC	0.81	3.05	40%	3.1E+04	5.2E+04
253	DS-48	DS-57 - MH 08	East	35	4.5000	4	PVC	0.81	3.05	40%	3.1E+04	5.2E+04
253	DS-210	DS-57 - MH 08	East	37	4.5000	4	PVC	0.86	3.23	40%	3.3E+04	5.5E+04
253	DS-106	DS-57 - MH 08	West	18	8.6250	8	PVC	1.02	6.28	40%	3.9E+04	1.1E+05
253	DS-107	DS-57 - MH 08	West	48	4.5000	4	PVC	1.11	4.19	40%	4.3E+04	7.1E+04
253	DS-WH	DS-57 - MH 08	West	18	4.5000	4	PVC	0.42	1.57	40%	1.6E+04	2.7E+04
Outside												
N/A	MH-40	MH-27	South	150	16.50000	12	RFCP	104.87	117.75	10%	7.4E+06	5.0E+05
N/A	LD Dock	MH-27	South	75	16.5	12	RFCP	52.44	58.88	10%	3.7E+06	2.5E+05
N/A	MH-27	MH-12	West	95	12	10.75	HDPE	14.73	59.85	10%	6.3E+05	2.5E+05
N/A	DS-103	DS-57 - MH 08	South	5	4.5000	4	PVC	0.12	0.44	10%	4.5E+03	1.9E+03
N/A	DS-104	DS-57 - MH 08	South	5	4.5000	4	PVC	0.12	0.44	10%	4.5E+03	1.9E+03
N/A	DS-105	DS-57 - MH 08	South	5	4.5000	4	PVC	0.12	0.44	10%	4.5E+03	1.9E+03
N/A	Storm Grate	MH-12	East	75	12	10.75	HDPE	11.63	47.25	10%	4.9E+05	2.0E+05
N/A	Mh-10	MH-04	East	292	8.625	7.981	HDPE	17.02	101.39	10%	7.2E+05	4.3E+05
N/A	Mh-11	MH-05	East	296	8.625	7.981	HDPE	17.26	102.78	10%	7.3E+05	4.4E+05
N/A	Mh-04	MH-13	South	296	8.625	7.981	HDPE	17.26	102.78	10%	7.3E+05	4.4E+05
N/A	Mh-05	MH-04 MH-13	South	170	8.625	7.981	HDPE	9.91	59.03	10%	4.2E+05	2.5E+05
N/A	Mh-31	CO-311	South	180	8.625	7.981	HDPE	10.49	62.50	10%	4.5E+05	2.7E+05
N/A	Mh-18	MH-09	West	122	12.75	12	HDPE	12.35	95.77	10%	5.2E+05	4.1E+05
N/A	DS-109	MH 09- MH 18	North	34	4.5000	4	PVC	0.79	2.97	10%	3.0E+04	1.3E+04
N/A	DS-110	MH 09- MH 18	North	28	4.5000	4	PVC	0.65	2.44	10%	2.5E+04	1.0E+04
N/A	DS-111	MH 09- MH 18	North	25	4.5000	4	PVC	0.58	2.18	10%	2.2E+04	9.3E+03
N/A	DS-112	MH 09- MH 18	North	25	4.5000	4	PVC	0.58	2.18	10%	2.2E+04	9.3E+03
N/A	DS-114	MH 09- MH 18	South	12	4.5000	4	PVC	0.28	1.05	10%	1.1E+04	4.4E+03
N/A	DS-115	MH 09- MH 18	South	12	4.5000	4	PVC	0.28	1.05	10%	1.1E+04	4.4E+03
N/A	DS-116	MH 09- MH 18	South	12	4.5000	4	PVC	0.28	1.05	10%	1.1E+04	4.4E+03
N/A	DS-117	MH 09- MH 18	South	12	4.5000	4	PVC	0.28	1.05	10%	1.1E+04	4.4E+03
N/A	DS-118	MH 09- MH 18	South	12	4.5000	4	PVC	0.28	1.05	10%	1.1E+04	4.4E+03

Appendix F
Volume Estimates for Underground Piping

Building-Room	Line Designation		Direction	Length (ft)	Pipe OD (in)	Pipe ID (in)	Pipe Material of Construction	Volume (wall) (ft ³)	Volume (interior) (ft ³)	% Filled (debris)	Mass (wall) (g)	Mass (debris) (g)
	From	To/Toward										
N/A	Mh-25	MH-07	North	72	8.625	7.981	HDPE	4.20	25.00	10%	1.8E+05	1.1E+05
N/A	MH-07	MH-19	North	80	8.625	7.981	HDPE	4.66	27.78	10%	2.0E+05	1.2E+05
N/A	Mh-25	MH-03	East	173	8.625	7.981	HDPE	10.09	60.07	10%	4.3E+05	2.6E+05
N/A	Mh-03	Outfall	South	314	8.625	7.981	HDPE	18.31	109.03	10%	7.8E+05	4.6E+05
N/A	Mh-03	DS-134	South	87	4.5000	4	HDPE	2.02	7.59	10%	8.6E+04	3.2E+04
N/A	DS-136	MH-22 - MH DS	West	14	4.5000	4	PVC	0.32	1.22	10%	1.2E+04	5.2E+03
N/A	DS-137	MH-22 - MH DS	South	14	4.5000	4	PVC	0.32	1.22	5%	1.2E+04	2.6E+03
N/A	DS-124	MH-03 - MH 02	North	18	4.5000	4	PVC	0.42	1.57	10%	1.6E+04	6.7E+03
N/A	DS-121	MH-03 - MH 02	South	14	4.5000	4	PVC	0.32	1.22	10%	1.2E+04	5.2E+03
N/A	DS-123	MH-03 - MH 02	South	12	4.5000	4	PVC	0.28	1.05	10%	1.1E+04	4.4E+03
N/A	DS-125	MH-03 - MH 02	South	10	4.5000	4	PVC	0.23	0.87	10%	8.9E+03	3.7E+03
N/A	DS-126	MH-03 - MH 02	South	11	4.5000	4	PVC	0.25	0.96	10%	9.8E+03	4.1E+03
N/A	MH-17	MH06	West	25	4.50000	4	PVC	2.15	8.11	5%	8.3E+04	1.7E+04
		MH08	North	24								
		240 laundry room	West	44								
N/A	DS-137	MH-17	South	8	4.5000	4	PVC	0.19	0.70	10%	7.1E+03	3.0E+03
N/A	MH-22	MH-01	East	150	8.625	7.981	HDPE	8.74	52.09	10%	3.7E+05	2.2E+05
N/A	DS-133	MH-01 - MH-22	South	8	4.5000	4	PVC	0.19	0.70	10%	7.1E+03	3.0E+03
N/A	DS-	MH-01 - MH-22	South	8	4.5000	4	PVC	0.19	0.70	10%	7.1E+03	3.0E+03
N/A	DS-	MH-01 - MH-22	South	8	4.5000	4	PVC	0.19	0.70	10%	7.1E+03	3.0E+03
N/A	DS-	MH-01 - MH-22	South	30	4.5000	4	PVC	0.70	2.62	10%	2.7E+04	1.1E+04
N/A	DS-	MH-01 - MH-22	South	11	4.5000	4	PVC	0.25	0.96	10%	9.8E+03	4.1E+03
N/A	DS-	MH-01 - MH-22	South	8	4.5000	4	PVC	0.19	0.70	10%	7.1E+03	3.0E+03
N/A	DS-	MH-01 - MH-22	South	8	4.5000	4	PVC	0.19	0.70	10%	7.1E+03	3.0E+03
N/A	Mh-01	MH-02	North	233	8.625	7.981	HDPE	13.58	80.91	10%	5.8E+05	3.4E+05
N/A	Mh-02	MH-31	North	69	8.625	7.981	HDPE	4.02	23.96	10%	1.7E+05	1.0E+05
Building 110												
110	FD-300	MH04-MH10	South	81	4.50000	4.026	PVC	1.78	7.16	10%	6.9E+04	3.0E+04
110	FD-301	FD-300	East	8	4.5	4.026	PVC	0.18	0.71	10%	6.8E+03	3.0E+03
110	FD-302	FD-300	East	8	4.5	4.026	PVC	0.18	0.71	10%	6.8E+03	3.0E+03
110	FD-303	CO-300	South	40	4.5	4.026	PVC	0.88	3.53	10%	3.4E+04	1.5E+04
110	CO-300	FD-300	SouthEast	12	4.5	4.026	PVC	0.26	1.06	10%	1.0E+04	4.5E+03
110	WC-300	MH04-MH10	South	30	4.5	4.026	PVC	0.66	2.65	10%	2.5E+04	1.1E+04

Appendix G
Radiological Sampling Results – Underground Piping
Figure 1, Sampling Results for the Process Buildings Underground Piping and Site Sewer Lines



**Appendix G
Radiological Sampling Results – Underground Piping**

Table 1

Bldg-Rm	Location ID	Direction	Distance (ft)	UNITS	Tc-99			U-234			U-235			U-238		
					Value	Error	MDC	Value	Error	MDC	Value	Error	MDC	Value	Error	MDC
Building 240																
240-11	PD-36	-	-	pCi/g	1.0E+03	8.7E+01	1.0E+00	3.2E+03	-	1.9E+00	1.2E+02	-	2.7E-03	4.5E+02	-	4.0E-04
240-11	CO-37	north	57	pCi/g	4.3E+03	3.7E+02	6.0E+00	1.7E+02	-	2.2E-03	5.6E+00	-	6.9E-05	1.3E+01	-	9.9E-06
240-11	CO-209	west	23	pCi/g	5.8E+01	5.1E+00	4.0E-01	1.3E+03	-	1.9E-01	4.4E+01	-	6.7E-03	6.4E+01	-	9.9E-03
240-11	PD-36	N/A	N/A	pCi/g	6.3E+03	5.4E+02	8.0E+00	1.1E+01	-	2.2E-03	4.0E-01	-	2.7E-06	1.0E+00	-	4.0E-07
240-14	CO-NEMS	west	to 8	pCi/g	1.1E+03	9.6E+01	1.0E+00	4.7E+04	-	9.3E-01	1.6E+03	-	1.4E-02	3.3E+03	-	4.0E-03
240-14	CO-45	-	7	pCi/g	2.3E+00	3.8E-01	3.9E-01	3.0E+02	-	1.9E-01	1.2E+01	-	2.7E-04	3.2E+01	-	4.0E-05
240-14	PD-46	N/A	N/A	pCi/g	1.3E+02	1.1E+01	5.0E-01	1.9E+04	-	1.9E-01	7.9E+02	-	6.7E-03	2.8E+03	-	9.9E-03
240-14	PD-44	N/A	N/A	pCi/g	2.0E+00	3.7E-01	4.0E-01	4.4E+04	-	4.7E+00	1.1E+03	-	6.8E-02	2.1E+02	-	9.9E-03
240-14	PD-42	N/A	N/A	pCi/g	4.4E+02	3.7E+01	6.0E-01	8.1E+03	-	1.9E-01	2.9E+02	-	6.7E-03	8.4E+02	-	9.9E-03
240-14	CO-45	north	to 7	pCi/g	5.0E+02	4.2E+01	2.0E+00	3.7E+01	-	2.2E-03	1.3E+00	-	6.9E-05	6.0E+00	-	9.9E-06
240-7	Vent 2 Lab	N/A	N/A	pCi/g	4.9E+01	4.3E+00	4.0E-01	7.5E+02	-	1.9E-01	2.9E+01	-	6.7E-03	8.8E+01	-	9.9E-03
240-7	CO-Lab-North	south	to 43	pCi/g	1.2E+01	1.2E+00	4.0E-01	1.1E+03	-	1.9E-01	5.0E+01	-	6.7E-03	2.6E+02	-	9.9E-03
				Average	1.2E+03			1.0E+04			3.3E+02			6.7E+02		
				Min	2.0E+00			4.7E+04			1.6E+03			3.3E+03		
				Max	6.3E+03			1.1E+01			4.0E-01			1.0E+00		
Building 255																
255-47	CO-225	South	to-32	pCi/g	2.8E+01	2.6E+00	5.0E-01	3.1E+03	-	4.7E+00	1.2E+02	-	6.7E-03	7.7E+02	-	9.9E-04
255-53	PD-228	-	13	pCi/g	1.7E+00	3.5E-01	4.0E-01	1.1E+02	-	1.9E-01	4.5E+00	-	2.7E-04	3.2E+01	-	9.9E-03
255-53	PD-228	west	to 12	pCi/g	3.6E+01	3.1E+00	8.0E-01	4.7E+00	-	2.2E-03	1.6E-01	-	2.7E-06	9.1E-01	-	4.0E-07
255-56	CO-230	north	to 35	pCi/g	4.4E+01	3.9E+00	5.0E-01	6.9E+03	-	1.9E+00	2.6E+02	-	2.7E-03	6.3E+02	-	4.0E-04
255-59	PD-232	north	to 12	pCi/g	2.3E+00	4.1E-01	4.2E-01	1.6E+03	-	1.9E-01	6.0E+01	-	6.7E-03	1.7E+02	-	9.9E-03
255-61	CO-232	north	30	pCi/g	3.4E+00	5.4E-01	5.4E-01	4.5E+02	-	1.9E-01	1.5E+01	-	2.7E-04	3.6E+01	-	4.0E-05
				Average	1.9E+01			2.0E+03			7.7E+01			2.7E+02		
				Min	1.7E+00			4.7E+00			1.6E-01			9.1E-01		
				Max	4.4E+01			6.9E+03			2.6E+02			7.7E+02		
Building 260																
260-65	CO-164	east	to 12	pCi/g	1.4E+02	1.2E+01	5.0E-01	5.5E+04	-	4.7E+01	2.1E+03	-	6.8E-02	8.2E+03	-	9.9E-03
260-66	CO-170	-	-	pCi/g	8.9E+00	9.4E-01	4.2E-01	4.4E+03	-	1.9E-01	1.9E+02	-	6.7E-03	6.7E+02	-	9.9E-03
260-66	CO-170	N/A	N/A	pCi/g	3.1E+01	2.8E+00	4.0E-01	4.8E+04	-	4.7E+00	2.3E+03	-	6.8E-02	8.2E+03	-	9.9E-03
				Average	5.9E+01			3.6E+04			1.5E+03			5.7E+03		
				Min	8.9E+00			4.4E+03			1.9E+02			6.7E+02		
				Max	1.4E+02			5.5E+04			2.3E+03			8.2E+03		

**Appendix G
Radiological Sampling Results – Underground Piping**


Table 1 (continued)

Bldg-Rm	Location ID	Direction	Distance (ft)	UNITS	Tc-99			U-234			U-235			U-238		
					Value	Error	MDC	Value	Error	MDC	Value	Error	MDC	Value	Error	MDC
Outside Process Building																
N/A	MH-5	east	190	pCi/g	5.6E+00	7.0E-01	5.2E-01	3.7E+00	-	1.9E-01	1.3E-01	-	2.7E-04	6.6E-01	-	4.0E-05
N/A	MH-16	south	47	pCi/g	1.7E+02	1.5E+01	5.0E-01	2.4E+03	-	1.9E+00	1.0E+02	-	2.7E-03	4.3E+02	-	4.0E-04
N/A	MH-8	east	120	pCi/g	3.3E+01	3.0E+00	4.0E-01	1.5E+02	-	1.9E-01	5.9E+00	-	2.7E-04	2.5E+01	-	4.0E-05
N/A	MH-14	northeast	120	pCi/g	1.6E+00	6.2E-01	9.7E-01	1.4E-01	-	2.2E-04	5.3E-03	-	2.7E-07	2.7E-02	-	4.0E-08
				Average	5.4E+01			6.5E+02			2.7E+01			1.1E+02		
				Min	1.6E+00			1.4E-01			5.3E-03			2.7E-02		
				Max	1.7E+02			2.4E+03			1.0E+02			4.3E+02		

APPENDIX H

Sub-Slab Sample Data Summary

Figure H-1, Process Building Sub Slab Excavation Contours (conceptual)




LEGEND:

[White Box]	Building
[Grey Box]	Concrete Driveway
[X-Line]	Fence
[Yellow Line]	Gate

Conceptual Excavation Contour


Depth	10'
1'	12'
2'	14'
3'	16'
4'	18'
5'	20'
6'	22'
8'	24'



Remediation Excavations Volume Estimate Areas		
Requested By: J. Guido	Document/Reason: Internal Use Only	
Hematite Decommissioning Project Jefferson County Hematite, MO		
Prepared By: DJH	Rev: 0	Date: 11-02-11

C:\GIS Data\Projects\Owners\Guido\Process Building Excavation Volume.mxd

APPENDIX H
Sub-Slab Sample Data Summary
Figure H-2, Process Building Sub Slab Sample Locations



**APPENDIX H
Sub-Slab Sample Data Summary**

Table H-1, Surface CSM Data Summary - Beneath Bldg. 253

	Tc-99 pCi/g	U-234 pCi/g	U-235 pCi/g	U-238 pCi/g
Count	5	6	6	6
Count <MDA	0	0	1	0
Minimum, pCi/g	109	10	1	3
Maximum, pCi/g	168	99	5	7
Average, pCi/g	143	31	2	4
st dev	30	34	2	2

Table H-2, Surface CSM - (Bldg. 253) Sample Data

Sample ID	Tc-99 pCi/g	U-234 pCi/g	U-235 pCi/g	U-238 pCi/g
Location #08	112	15.5	0.84	6.6
Location #36	160	18.1	0.99	5.1
Location #37	166	98.9	5.0	3.5
Location #36	160	18.1	18.1	5.1
Location #47	109	9.5	0.52	2.9
Location #48	168	19.1	1.1	5.6
BLD253-02-Fill	-	21.9	1.2	2.6

**APPENDIX H
Sub-Slab Sample Data Summary**

Table H-3, Surface CSM Data Summary - Excluding Bldg. 253

	Tc-99 pCi/g	U-234 pCi/g	U-235 pCi/g	U-238 pCi/g
Count	43	48	48	48
Count <MDA	13	0	5	5
Minimum, pCi/g	-0.40	0.28	0.02	0.09
Maximum, pCi/g	12	1842	100	685
Average, pCi/g	3	105	5.4	32
st dev	3	284	15	104

Table H-4, Surface CSM- (Excluding Bldg. 253) Sample Data

Sample ID	Tc-99 pCi/g	U-234 pCi/g	U-235 pCi/g	U-238 pCi/g
BD-19-0.5-SL	0.0	3.0	0.2	0.6
BD-24-0.5-SL	0.8	8.6	0.4	2.0
BD-28-0.5-SL	0.7	12.7	0.4	2.0
BLD240-01-Fill	-	106.9	5.9	17.0
BLD240-03-Fill	-	324.3	17.9	71.0
BLD240-04-Fill	-	12.7	0.7	2.6
BLD255-05-Fill	-	3.2	0.2	1.7
BLD260-06-Fill	-	60.7	3.3	16.4
Location #01	-0.40	28.1	1.5	2.8
Location #02	-0.13	2.6	0.049	0.56
Location #03	12	1842.1	100	685
Location #04	-0.18	426.7	23	178
Location #05	1.3	490.5	27	173
Location #06	0.71	6.1	0.31	0.23
Location #07	0.27	1.1	0.059	0.31
Location #09	0.12	8.9	0.49	1.1
Location #11	0.85	0.8	0.038	0.75
Location #12	0	3.0	0.16	1.6
Location #13	0.97	320.8	18	72
Location #14	0.54	408.2	20	11
Location #15	2.1	79.9	4.3	30
Location #16	2.3	103.6	5.5	55

**APPENDIX H
Sub-Slab Sample Data Summary**

Table H-4, Surface CSM- (Excluding Bldg. 253) Sample Data

Sample ID	Tc-99 pCi/g	U-234 pCi/g	U-235 pCi/g	U-238 pCi/g
Location #17	0.23	3.5	0.18	2.3
Location #18	0.31	78.4	4.1	46
Location #19	10	26.6	1.4	13
Location #20	5.2	235.7	13	74
Location #21	11	85.2	4.7	28
Location #31	1.8	0.4	0.020	0.15
Location #32	1.9	0.4	0.020	0.25
Location #33	2.0	0.4	0.022	0.093
Location #34	1.7	3.3	0.18	0.33
Location #35	8.8	52.8	2.4	0.71
Location #38	2.0	2.7	0.15	0.62
Location #39	2.6	4.3	0.24	1.3
Location #40	10	56.1	3.1	14
Location #41	3.9	39.6	2.2	10.0
Location #42	10.0	13.8	0.76	3.1
Location #43	2.0	0.5	0.027	0.19
Location #44	1.7	3.2	0.18	0.90
Location #45	1.9	1.2	0.063	0.51
Location #46	2.0	0.4	0.023	0.27
Location #49	2.0	0.3	0.015	0.12
Location #50	2.2	137.7	6.0	1.5
Location #51	1.8	2.9	0.16	0.53
Location #52	3.9	11.2	0.62	1.7
Location #53	2.1	8.6	0.47	1.3
Location #54	2.2	0.4	0.019	0.30
Location #55	2.2	0.6	0.033	0.29
BLD253-02-01	28.7	16.3	0.9	3.7
BLD255-08-01	30.2	250.8	13.4	17.3
BLD260-06-01	25.2	17.8	0.8	5.0

**APPENDIX H
Sub-Slab Sample Data Summary**

Table H-5, Root CSM Data Summary – Beneath Bldg. 253

	Tc-99 pCi/g	U-234 pCi/g	U-235 pCi/g	U-238 pCi/g
Count	5	6	6	6
Count <MDA	0	0	2	0
Minimum, pCi/g	8	1	0.1	2
Maximum, pCi/g	151	172	8	11
Average, pCi/g	47	37	2	6
st dev	60	66	3	4

Table H-6, Root CSM - (Bldg. 253) Sample Data

Sample ID	Tc-99 pCi/g	U-234 pCi/g	U-235 pCi/g	U-238 pCi/g
BD-30-2.5-SL	151.0	16.1	0.7	3.3
BD-30-4.5-SL	20.2	10.0	2.6	10.4
BD-33-2.5-SL	47.3	8.7	0.4	2.4
BD-33-4.5-SL	7.8	1.4	0.1	2.1
BLD253-02-01	-	16.3	0.9	3.7
BLD253-02-04	7.5	172.0	7.7	11.1

**APPENDIX H
Sub-Slab Sample Data Summary**

Table H-7, Root CSM Data Summary - Excluding Bldg. 253

	Tc-99 pCi/g	U-234 pCi/g	U-235 pCi/g	U-238 pCi/g
Count	12	20	20	20
Count <MDA	7	0 / 9	11	8
Minimum	-0.3	0.6	-0.4	-0.4
Maximum	30	251	13	17
Average	3	20	1	3
st dev	9	56	3	4

Table H-8, Root CSM - (Excluding Bldg. 253) Sample Data

Sample ID	Tc-99 pCi/g	U-234 pCi/g	U-235 pCi/g	U-238 pCi/g
BD-17-2.5-SL	5.0	69.0	3.2	11.8
BD-17-4.5-SL	-0.2	2.4	0.1	1.3
BD-18-2.5-SL	-0.1	0.6	0.0	0.6
BD-18-4.5-SL	-0.3	2.2	0.1	0.4
BD-21-2.5-SL	-0.1	3.1	0.1	0.7
BD-21-4.5-SL	0.3	0.7	0.1	0.7
BD-26-2.5-SL	1.9	1.2	0.1	0.7
BD-26-4.5-SL	1.6	0.8	0.0	0.8
BD-29-2.5-SL	1.3	12.2	0.5	2.6
BD-29-4.5-SL	0.0	2.9	0.2	0.7
BD-36-4.5-SL	-0.2	16.4	0.7	1.8
BLD240-01-01	-	2.3	0.1	1.1
BLD240-04-02	-	0.7	0.0	1.7
BLD240-04-04	-	5.4	0.3	0.9
BLD240-05-01	-	1.4	-0.1	1.4
BLD240-05-02	-	1.6	-0.4	1.6
BLD255-07-02	-	1.3	0.1	1.7
BLD255-08-01	30.2	250.8	13.4	17.3
BLD260-06-01	-	17.8	0.8	5.0
BLD260-06-03	-	2.2	0.1	0.6

**APPENDIX H
Sub-Slab Sample Data Summary**

Table H-9, Deep CSM Data Summary - Excluding Bldg. 253

	Tc-99 pCi/g	U-234 pCi/g	U-235 pCi/g	U-238 pCi/g
Count	7	9	9	9
Count <MDA	0	0	9	8
Minimum, pCi/g	5	1	-0.1	1
Maximum, pCi/g	28	7	0	2
Average, pCi/g	13	4	0.2	2
st dev	8	2	0.1	0.3

Table H-10, Deep CSM - (Bldg. 253) Sample Data

Sample ID	Tc-99 pCi/g	U-234 pCi/g	U-235 pCi/g	U-238 pCi/g
BD-30-16.5-SL	14.4	3.31	0.18	1.2
BD-30-20.5-SL	8.12	4.78	0.26	1.74
BD-30-8.5-SL	5.22	1.10	-0.13	1.1
BD-30-9-SL	-	3.90	0.21	1.6
BD-33-12.5-SL	-	3.22	0.17	1.7
BD-33-12-SL	15.4	3.36	0.18	1.5
BD-33-16.5-SL	27.5	7.44	0.41	1.78
BD-33-20.5-SL	15.4	5.86	0.32	1.9
BD-33-8.5-SL	5.61	4.92	0.27	1.4

**APPENDIX H
Sub-Slab Sample Data Summary**

Table H-11, Deep CSM Data Summary - Excluding Bldg. 253

	Tc-99 pCi/g	U-234 pCi/g	U-235 pCi/g	U-238 pCi/g
Count	22	31	31	31
Count <MDA	19	0	30	30.0
Minimum	-0.3	0.1	-0.09	0.000
Maximum	1	7	0	3
Average	0	3	0.1	1
st dev	0.4	2	0.1	1

Table H-12, Deep CSM - (Excluding Bldg. 253) Sample Data

Sample ID	Tc-99 pCi/g	U-234 pCi/g	U-235 pCi/g	U-238 pCi/g
BD-17-12.5-SL	0.09	3.91	0.21	1.7
BD-17-16.5-SL	-0.31	2.62	0.14	1.2
BD-17-20.5-SL	-0.3	1.10	-0.09	1.1
BD-17-8.5-SL	-	2.54	0.14	0.4
BD-17-8-SL	0.3	4.79	0.26	1.8
BD-18-12.5-SL	-0.2	3.09	0.17	0.84
BD-18-16-SL	-0.17	5.16	0.28	1.9
BD-18-20.5-SL	-0.14	1.63	0.05	0
BD-18-8.5-SL	-	0.71	0.01	1.0
BD-18-8-SL	0.03	2.16	0.1	2.5
BD-21-12-SL	0.21	3.56	0.18	2.7
BD-21-16.5-SL	0.21	2.40	0.13	0.9
BD-21-20.5-SL	0.16	1.77	0.08	2.24
BD-21-8.5-SL	0.45	1.24	0.06	1.2
BD-21-9-SL	-	5.04	0.27	2.3
BD-26-12-SL	0.31	0.14	0.003	1.9
BD-26-16.5-SL	-0.22	2.05	0.11	0.9
BD-26-20-SL	0.36	2.95	0.16	1.1
BD-26-7.5-SL	-	1.22	0.05	2.0
BD-29-12.5-SL	0.87	1.18	0.04	2.7
BD-29-16.5-SL	0.99	5.62	0.31	1.3
BD-29-20.5-SL	1.13	5.58	0.3	2.4

APPENDIX H
Sub-Slab Sample Data Summary

Table H-12, Deep CSM - (Excluding Bldg. 253) Sample Data

Sample ID	Tc-99 pCi/g	U-234 pCi/g	U-235 pCi/g	U-238 pCi/g
BD-29-8.5-SL	-	4.39	0.22	1.0
BD-29-8-SL	0.26	2.00	0.1	1.6
BD-36-12.5-SL	-	1.38	0.07	1.0
BD-36-12-SL	-0.06	2.49	0.13	1.46
BD-36-16.5-SL	0.31	1.70	-0.09	1.7
BD-36-8-SL	-0.25	3.66	0.2	1.2
BLD240-01-09	-	4.17	0.23	0.9
BLD255-07-15	-	6.70	0.37	1.1
BLD255-08-08	-	6.18	0.34	0.9

APPENDIX I

Visual Sample Plan© Software Evaluation

VSP© Software Sample Design Report for Calculating a One-Sided Confidence Interval for the Population Mean Using Simple Random Sampling

Summary

This report summarizes the sampling design used, associated statistical assumptions, as well as general guidelines for conducting post-sampling data analysis. Sampling plan components presented here include how many sampling locations to choose and where within the sampling area to collect those samples. The type of medium to sample (i.e., soil, groundwater, etc.) and how to analyze the samples (in-situ, fixed laboratory, etc.) are addressed in other sections of the sampling plan.

The following table summarizes the sampling design developed.

SUMMARY OF SAMPLING DESIGN	
Primary Objective of Design	Construct a Confidence Interval on the True Mean
Type of Sampling Design	Parametric
Sample Placement (Location) in the Field	Simple random sampling
Formula for calculating number of sampling locations	Confidence Limits using Student's t-distribution
Calculated total number of samples	85

Primary Sampling Objective

The primary purpose of sampling at this site is to construct a confidence interval on the true population mean value. After the samples are collected and analyzed, the resulting sample values can be used to construct a one-sided confidence interval. Once the confidence interval is computed (which will be an upper threshold), you can have the specified confidence that the true population mean is less than the upper threshold.

Selected Sampling Approach

A parametric random sampling approach was used to determine the number of samples and to specify sampling locations. A parametric formula was chosen because the conceptual model and historical information (e.g., historical data from this site or a very similar site) indicate that parametric assumptions are true. These assumptions will be examined in post-sampling data analysis.

Both parametric and non-parametric equations rely on assumptions about the population. Typically, however, non-parametric equations require fewer assumptions and allow for more uncertainty about the statistical distribution of values at the site. The trade-off is that if the parametric assumptions are valid, the required number of samples is usually less than if a non-parametric equation was used.

Locating the sample points randomly provides data that are separated by many distances, whereas systematic samples are all equidistant apart. Therefore, random sampling provides more information about the spatial structure of the potential contamination than systematic sampling

APPENDIX I

Visual Sample Plan© Software Evaluation

does. As with systematic sampling, random sampling also provides information regarding the mean value, but there is the possibility that areas of the site will not be represented with the same frequency as if uniform grid sampling were performed

Number of Total Samples: Calculation Equation and Inputs

The equation used to calculate the number of samples is based on a confidence interval calculation using the Student's t-distribution. The formula used to calculate the number of samples is:

$$n = \left[\frac{t_{1-\alpha,df} S_{total}}{d} \right]^2$$

where

n is the recommended minimum sample size for the study area,

S_{total} is the estimated standard deviation due to both sampling and analytical variability,

α is the maximum acceptable probability that the true mean will not lie in the confidence interval (the confidence level is 1-*α*),

d is the width of the confidence interval,

t_{1-α,df} is the value of the Student's t-distribution with *df=n-1* degrees of freedom such that the proportion of the distribution less than *t_{1-α}* is 1-*α*.

Because *n* appears on both sides of the equation (on the right side it appears in the degrees of freedom of the t-statistic), the equation must be solved iteratively. VSP© Software does this automatically using the iteration scheme in Gilbert (1987, pg. 32).

The values of these inputs that result in the calculated number of sampling locations are:


Analyte	n	Parameter			
		S	d	α	t _{1-α,df}
Analyte 1	85	36	6.5	5%	1.66388 ^a

^a This value is automatically calculated by VSP© Software based upon the user defined value of *α*

The following figure is a graph representing the relationship between the width of the confidence interval and the number of samples. The blue dashed line illustrates the specified maximum desirable confidence interval width. Where this dashed line intersects the red curve is the number of samples calculated by VSP© Software.

APPENDIX I
Visual Sample Plan© Software Evaluation

95% One-Sided C.I. on True Mean



Attachment 2 to Enclosure 1 to HEM-12-2

**Input Parameters, Microshield®¹ Software 7.02
Westinghouse Electric Company LLC (08-MSD-7.02-1424)
(1 page)**

**Input Data
Assessed Concentrations¹**

Radionuclide ²	Concentration ³	
	pCi/g	μCi/cm ³
U-234	66	9.5E-05
U-238	12	1.9E-05
Pa-234 ⁴		3.1E-08
Pa-234m ⁴		1.9E-05
Th-234 ⁴		1.9E-05
U-235	2.8	4.3E-06
Th-231 ⁵		4.3E-06

- 1 Unit concentrations were used to derive (mrem) / (μCi/cm³) values which were in turn multiplied by the listed concentration values to arrive at exposure estimates.
- 2 Tc-99 not assess as it has no gamma emissions
- 3 Conversion from pCi/g to μCi/cm³ was based on the weighted average density of the materials as shipped
- 4 Pa-234, Pa-234m, and Th-234 are U-238 progeny.
- 5 Th-231 is a U-235 progeny.

Case Summary Data^a

Job Category	Geometry	Dose factor (mR/hr / μCi/cm ³)		
		U-234	U-235	U-238
Gondola Surveyor	1 meter from gondola (9 ft x 4 ft x 60 ft), centerline – side, 5/16 inch iron shield	3.0E-03	2.2E+01	4.4E+00
Excavator Operator	2 meter from gondola (9 ft x 4 ft x 60 ft) centerline – top, 1 inch iron shield)	1.0E-05	5.6E-01	6.1E-01
Truck Surveyor	1 meter from truck bed (8 ft x 15 ft x 5 ft), centerline – front, 0.25 inch aluminum shield	7.8E-03	2.5E+01	4.0E+00
Truck Driver	2 feet from truck bed (8 ft x 15 ft x 5 ft), centerline – front, 0.25 inch aluminum shield	9.1E-03	2.9E+01	4.6E+00
Cell Operator	1 meter from slab source (1m x 2 m x 35 m) with 0.6 cm iron shield	3.6E-03	2.3E+01	4.1E+00
Gondola Cleanout	1 foot from an infinite plane source of 0.5 inch thickness.	2.3E-01	3.1E+01	3.8E+00
Transportation Worker	1 foot from gondola (9 ft x 4 ft x 60 ft), centerline – side, 5/16 inch iron shield	3.4E-03	2.7E+01	5.9E+00
Stabilization Operator	Same as Excavator Operator			

a – Microshield® Software case files are contained in Exhibits A

¹MicroShield® is a registered trademark of Yale Security Inc., an ASSA ABLOY Group company

Enclosure 1 to HEM-12-2
January 16, 2012

Attachment 3 to HEM-12-2

**Case Files, Microshield®¹ Software 7.02
Westinghouse Electric Company LLC (08-MSD-7.02-1424)**

(36 pages)

¹MicroShield® is a registered trademark of Yale Security Inc., an ASSA ABLOY Group company

MicroShield 7.02
Westinghouse Electric Company (08-MSD-7.02-1424)

Date	By	Checked


Filename	Run Date	Run Time	Duration
CellSurface_U234_concrete 2.ms7	January 8, 2012	2:50:51 AM	00:00:00

Project Info	
Case Title	Case 1
Description	Case 1
Geometry	13 - Rectangular Volume

Source Dimensions	
Length	100.0 cm (3 ft 3.4 in)
Width	200.0 cm (6 ft 6.7 in)
Height	3.5e+3 cm (114 ft 10.0 in)

Dose Points			
A	X	Y	Z
#1	200.6 cm (6 ft 7.0 in)	1.8e+3 cm (57 ft 5.0 in)	100.0 cm (3 ft 3.4 in)

Shields			
Shield N	Dimension	Material	Density
Source	7.00e+07 cm ³	Concrete	1.54
Shield 1	.6 cm	Iron	7.86
Air Gap		Air	0.00122



Source Input: Grouping Method - Actual Photon Energies				
Nuclide	Ci	Bq	μCi/cm ³	Bq/cm ³
Pa-234				
Pa-234m				
Th-231				
Th-234				
U-234	7.0002e+001	2.5901e+012	1.0000e+000	3.7000e+004
U-235				
U-238				

Buildup: The material reference is Source Integration Parameters	
X Direction	10
Y Direction	20
Z Direction	20

Results					
Energy (MeV)	Activity (Photons/sec)	Fluence Rate MeV/cm ² /sec No Buildup	Fluence Rate MeV/cm ² /sec With Buildup	Exposure Rate mR/hr No Buildup	Exposure Rate mR/hr With Buildup
0.013	2.720e+11	4.366e-126	1.484e-23	5.874e-127	1.996e-24
0.0532	3.056e+09	1.650e-04	8.343e-04	3.925e-07	1.984e-06
0.1214	1.037e+09	3.569e-01	2.275e+00	5.590e-04	3.563e-03
Totals	2.761e+11	3.571e-01	2.275e+00	5.594e-04	3.565e-03


MicroShield 7.02
Westinghouse Electric Company (08-MSD-7.02-1424)

Date	By	Checked

Filename	Run Date	Run Time	Duration
CellSurface_U235_concrete 2.ms7	January 8, 2012	2:53:18 AM	00:00:00

Project Info	
Case Title	Case 1
Description	Case 1
Geometry	13 - Rectangular Volume

Source Dimensions	
Length	100.0 cm (3 ft 3.4 in)
Width	200.0 cm (6 ft 6.7 in)
Height	3.5e+3 cm (114 ft 10.0 in)



Dose Points			
A	X	Y	Z
#1	200.6 cm (6 ft 7.0 in)	1.8e+3 cm (57 ft 5.0 in)	100.0 cm (3 ft 3.4 in)

Shields			
Shield N	Dimension	Material	Density
Source	7.00e+07 cm ³	Concrete	1.54
Shield 1	.6 cm	Iron	7.86
Air Gap		Air	0.00122

Source Input: Grouping Method - Standard Indices
Number of Groups: 25
Lower Energy Cutoff: 0.015
Photons < 0.015: Included
Library: Grove

Nuclide	Ci	Bq	μCi/cm ³	Bq/cm ³
Pa-234				
Pa-234m				
Th-231	7.0002e+001	2.5901e+012	1.0000e+000	3.7000e+004
Th-234				
U-234				
U-235	7.0002e+001	2.5901e+012	1.0000e+000	3.7000e+004
U-238				

Buildup: The material reference is Source	
Integration Parameters	
X Direction	10
Y Direction	20
Z Direction	20

Results

Energy (MeV)	Activity (Photons/sec)	Fluence Rate MeV/cm²/sec No Buildup	Fluence Rate MeV/cm²/sec With Buildup	Exposure Rate mR/hr No Buildup	Exposure Rate mR/hr With Buildup
0.015	2.639e+12	4.887e-125	1.660e-22	4.192e-126	1.424e-23
0.03	3.795e+11	3.869e-17	7.832e-17	3.835e-19	7.762e-19
0.06	1.231e+10	8.409e-03	4.934e-02	1.670e-05	9.801e-05
0.08	3.038e+11	8.776e+00	6.040e+01	1.389e-02	9.558e-02
0.1	2.707e+11	3.826e+01	2.605e+02	5.854e-02	3.985e-01
0.15	4.034e+11	2.749e+02	1.596e+03	4.526e-01	2.629e+00
0.2	1.598e+12	2.157e+03	1.103e+04	3.806e+00	1.947e+01
Totals	5.607e+12	2.478e+03	1.295e+04	4.331e+00	2.259e+01


MicroShield 7.02
Westinghouse Electric Company (08-MSD-7.02-1424)

Date	By	Checked

Filename	Run Date	Run Time	Duration
CellSurface_U238_concrete 2.ms7	January 8, 2012	2:54:51 AM	00:00:00

Project Info	
Case Title	Case 1
Description	Case 1
Geometry	13 - Rectangular Volume

Source Dimensions	
Length	100.0 cm (3 ft 3.4 in)
Width	200.0 cm (6 ft 6.7 in)
Height	3.5e+3 cm (114 ft 10.0 in)



Dose Points			
A	X	Y	Z
#1	200.6 cm (6 ft 7.0 in)	1.8e+3 cm (57 ft 5.0 in)	100.0 cm (3 ft 3.4 in)

Shields			
Shield N	Dimension	Material	Density
Source	7.00e+07 cm ³	Concrete	1.54
Shield 1	.6 cm	Iron	7.86
Air Gap		Air	0.00122

Source Input: Grouping Method - Standard Indices
Number of Groups: 25
Lower Energy Cutoff: 0.015
Photons < 0.015: Included
Library: Grove

Nuclide	Ci	Bq	μCi/cm ³	Bq/cm ³
Pa-234	1.1200e-001	4.1441e+009	1.6000e-003	5.9200e+001
Pa-234m	7.0002e+001	2.5901e+012	1.0000e+000	3.7000e+004
Th-231				
Th-234	7.0002e+001	2.5901e+012	1.0000e+000	3.7000e+004
U-234				
U-235				
U-238	7.0002e+001	2.5901e+012	1.0000e+000	3.7000e+004

Buildup: The material reference is Source	
Integration Parameters	
X Direction	10
Y Direction	20
Z Direction	20

Results

Energy (MeV)	Activity (Photons/sec)	Fluence Rate MeV/cm ² /sec No Buildup	Fluence Rate MeV/cm ² /sec With Buildup	Exposure Rate mR/hr No Buildup	Exposure Rate mR/hr With Buildup
0.015	4.942e+11	9.153e-126	3.110e-23	7.851e-127	2.668e-24
0.04	5.072e+06	7.536e-12	2.405e-11	3.333e-14	1.064e-13
0.06	1.014e+11	6.927e-02	4.064e-01	1.376e-04	8.073e-04
0.08	3.682e+09	1.064e-01	7.320e-01	1.683e-04	1.158e-03
0.1	1.590e+11	2.247e+01	1.530e+02	3.438e-02	2.340e-01
0.15	1.307e+09	8.903e-01	5.170e+00	1.466e-03	8.514e-03
0.2	8.741e+08	1.179e+00	6.033e+00	2.082e-03	1.065e-02
0.3	3.010e+08	8.735e-01	3.738e+00	1.657e-03	7.090e-03
0.4	2.545e+08	1.213e+00	4.567e+00	2.363e-03	8.899e-03
0.5	3.779e+08	2.624e+00	8.958e+00	5.150e-03	1.758e-02
0.6	1.544e+09	1.455e+01	4.577e+01	2.839e-02	8.934e-02
0.8	8.599e+09	1.312e+02	3.656e+02	2.495e-01	6.954e-01
1.0	2.749e+10	6.101e+02	1.558e+03	1.125e+00	2.871e+00
1.5	5.799e+08	2.543e+01	5.608e+01	4.279e-02	9.436e-02
2.0	7.482e+07	5.269e+00	1.067e+01	8.148e-03	1.651e-02
Totals	7.997e+11	8.159e+02	2.219e+03	1.501e+00	4.056e+00

MicroShield 7.02
Westinghouse Electric Company (08-MSD-7.02-1424)

Date	By	Checked


Filename	Run Date	Run Time	Duration
gondola_cleanout_U234_concrete 2.ms7	January 8, 2012	2:56:48 AM	00:00:00

Project Info	
Case Title	Case 2
Description	Case 2
Geometry	16 - Infinite Slab

Source Dimensions	
Thickness	1.27 cm (0.5 in)

Dose Points			
A	X	Y	Z
#1	31.27 cm (1 ft 0.3 in)	0.0 cm (0.0 in)	0.0 cm (0.0 in)

Shields			
Shield N	Dimension	Material	Density
Source	Infinite	Concrete	1.54
Air Gap		Air	0.00122



Source Input: Grouping Method - Actual Photon Energies		
Nuclide	$\mu\text{Ci}/\text{cm}^3$	Bq/cm^3
Pa-234		
Pa-234m		
Th-231		
Th-234		
U-234	1.0000e+000	3.7000e+004
U-235		
U-238		

Buildup: The material reference is Source
Integration Parameters

Results					
Energy (MeV)	Activity (Photons/sec)	Fluence Rate $\text{MeV}/\text{cm}^2/\text{sec}$ No Buildup	Fluence Rate $\text{MeV}/\text{cm}^2/\text{sec}$ With Buildup	Exposure Rate mR/hr No Buildup	Exposure Rate mR/hr With Buildup
0.013	3.886e+03	1.653e+00	1.675e+00	2.224e-01	2.253e-01
0.0532	4.366e+01	1.624e+00	1.628e+00	3.863e-03	3.872e-03
0.1214	1.482e+01	1.928e+00	1.928e+00	3.020e-03	3.019e-03
Totals	3.945e+03	5.205e+00	5.231e+00	2.293e-01	2.322e-01

MicroShield 7.02
Westinghouse Electric Company (08-MSD-7.02-1424)

Date	By	Checked


Filename	Run Date	Run Time	Duration
gondola_cleanout_U235_concrete_2.ms7	January 8, 2012	2:57:26 AM	00:00:00

Project Info	
Case Title	Case 2
Description	Case 2
Geometry	16 - Infinite Slab

Source Dimensions	
Thickness	1.27 cm (0.5 in)

Dose Points			
A	X	Y	Z
#1	31.27 cm (1 ft 0.3 in)	0.0 cm (0.0 in)	0.0 cm (0.0 in)

Shields			
Shield N	Dimension	Material	Density
Source	Infinite	Concrete	1.47
Air Gap		Air	0.00122



Source Input: Grouping Method - Standard Indices		
Number of Groups: 25		
Lower Energy Cutoff: 0.015		
Photons < 0.015: Included		
Library: Grove		
Nuclide	μCi/cm ³	Bq/cm ³
Pa-234		
Pa-234m		
Th-231	1.0000e+000	3.7000e+004
Th-234		
U-234		
U-235	1.0000e+000	3.7000e+004
U-238		

Buildup: The material reference is Source
Integration Parameters

Results					
Energy (MeV)	Activity (Photons/sec)	Fluence Rate MeV/cm ² /sec No Buildup	Fluence Rate MeV/cm ² /sec With Buildup	Exposure Rate mR/hr No Buildup	Exposure Rate mR/hr With Buildup
0.015	3.769e+04	1.938e+01	1.964e+01	1.662e+00	1.685e+00
0.03	5.421e+03	4.413e+01	5.083e+01	4.374e-01	5.037e-01
0.06	1.758e+02	8.469e+00	1.434e+01	1.682e-02	2.847e-02

0.08	4.340e+03	3.323e+02	6.032e+02	5.259e-01	9.546e-01
0.1	3.867e+03	4.021e+02	8.345e+02	6.151e-01	1.277e+00
0.15	5.762e+03	9.893e+02	2.316e+03	1.629e+00	3.814e+00
0.2	2.283e+04	5.509e+03	1.291e+04	9.723e+00	2.278e+01
Totals	8.009e+04	7.305e+03	1.675e+04	1.461e+01	3.104e+01

MicroShield 7.02
Westinghouse Electric Company (08-MSD-7.02-1424)

Date	By	Checked


Filename	Run Date	Run Time	Duration
gondola_cleanout_U238_concrete 2.ms7	January 8, 2012	2:57:50 AM	00:00:00

Project Info	
Case Title	Case 2
Description	Case 2
Geometry	16 - Infinite Slab

Source Dimensions	
Thickness	1.27 cm (0.5 in)

Dose Points			
A	X	Y	Z
#1	31.27 cm (1 ft 0.3 in)	0.0 cm (0.0 in)	0.0 cm (0.0 in)

Shields			
Shield N	Dimension	Material	Density
Source	Infinite	Concrete	1.47
Air Gap		Air	0.00122



Source Input: Grouping Method - Standard Indices		
Number of Groups: 25		
Lower Energy Cutoff: 0.015		
Photons < 0.015: Included		
Library: Grove		
Nuclide	μCi/cm ³	Bq/cm ³
Pa-234	1.6000e-003	5.9200e+001
Pa-234m	1.0000e+000	3.7000e+004
Th-231		
Th-234	1.0000e+000	3.7000e+004
U-234		
U-235		
U-238	1.0000e+000	3.7000e+004

Buildup: The material reference is Source
Integration Parameters

Results					
Energy (MeV)	Activity (Photons/sec)	Fluence Rate MeV/cm ² /sec No Buildup	Fluence Rate MeV/cm ² /sec With Buildup	Exposure Rate mR/hr No Buildup	Exposure Rate mR/hr With Buildup
0.015	7.060e+03	3.630e+00	3.679e+00	3.114e-01	3.155e-01
0.04	7.246e-02	1.426e-03	1.902e-03	6.306e-06	8.411e-06
0.06	1.448e+03	6.976e+01	1.181e+02	1.386e-01	2.345e-01

0.08	5.260e+01	4.027e+00	7.310e+00	6.373e-03	1.157e-02
0.1	2.271e+03	2.361e+02	4.901e+02	3.613e-01	7.497e-01
0.15	1.866e+01	3.205e+00	7.502e+00	5.277e-03	1.235e-02
0.2	1.249e+01	3.013e+00	7.059e+00	5.318e-03	1.246e-02
0.3	4.299e+00	1.667e+00	3.703e+00	3.163e-03	7.023e-03
0.4	3.635e+00	1.974e+00	4.080e+00	3.847e-03	7.949e-03
0.5	5.398e+00	3.810e+00	7.394e+00	7.479e-03	1.451e-02
0.6	2.206e+01	1.929e+01	3.537e+01	3.765e-02	6.904e-02
0.8	1.228e+02	1.508e+02	2.510e+02	2.868e-01	4.773e-01
1.0	3.927e+02	6.275e+02	9.774e+02	1.157e+00	1.802e+00
1.5	8.285e+00	2.139e+01	2.967e+01	3.599e-02	4.992e-02
2.0	1.069e+00	3.872e+00	5.078e+00	5.987e-03	7.853e-03
Totals	1.142e+04	1.150e+03	1.947e+03	2.366e+00	3.772e+00

MicroShield 7.02
Westinghouse Electric Company (08-MSD-7.02-1424)

Date	By	Checked


Filename	Run Date	Run Time	Duration
gondola excavation op U234 concrete2.ms7	January 8, 2012	3:13:46 AM	00:00:00

Project Info	
Case Title	Case 1
Description	Case 1
Geometry	13 - Rectangular Volume

Source Dimensions	
Length	274.32 cm (9 ft)
Width	121.92 cm (4 ft)
Height	1.8e+3 cm (60 ft)

Dose Points			
A	X	Y	Z
#1	476.86 cm (15 ft 7.7 in)	914.4 cm (30 ft)	60.96 cm (2 ft)

Shields			
Shield N	Dimension	Material	Density
Source	6.12e+07 cm ³	Concrete	1.54
Shield 1	2.54 cm	Iron	7.86
Air Gap		Air	0.00122



Source Input: Grouping Method - Actual Photon Energies				
Nuclide	Ci	Bq	μCi/cm ³	Bq/cm ³
Pa-234				
Pa-234m				
Th-231				
Th-234				
U-234	6.1164e+001	2.2631e+012	1.0000e+000	3.7000e+004
U-235				
U-238				

Buildup: The material reference is Shield 1 Integration Parameters	
X Direction	20
Y Direction	20
Z Direction	20

Results					
Energy (MeV)	Activity (Photons/sec)	Fluence Rate MeV/cm ² /sec No Buildup	Fluence Rate MeV/cm ² /sec With Buildup	Exposure Rate mR/hr No Buildup	Exposure Rate mR/hr With Buildup
0.013	2.377e+11	0.000e+00	9.094e-24	0.000e+00	1.223e-24
0.0532	2.670e+09	1.659e-15	2.404e-15	3.945e-18	5.718e-18
0.1214	9.065e+08	2.271e-03	6.525e-03	3.556e-06	1.022e-05
Totals	2.413e+11	2.271e-03	6.525e-03	3.556e-06	1.022e-05


MicroShield 7.02
Westinghouse Electric Company (08-MSD-7.02-1424)

Date	By	Checked

Filename	Run Date	Run Time	Duration
gondola_excavation_op_U235_concrete2.ms7	January 8, 2012	3:12:14 AM	00:00:01

Project Info	
Case Title	Case 1
Description	Case 1
Geometry	13 - Rectangular Volume

Source Dimensions	
Length	274.32 cm (9 ft)
Width	121.92 cm (4 ft)
Height	1.8e+3 cm (60 ft)



Dose Points			
A	X	Y	Z
#1	476.86 cm (15 ft 7.7 in)	914.4 cm (30 ft)	60.96 cm (2 ft)

Shields			
Shield N	Dimension	Material	Density
Source	6.12e+07 cm ³	Concrete	1.54
Shield 1	2.54 cm	Iron	7.86
Air Gap		Air	0.00122

Source Input: Grouping Method - Standard Indices
Number of Groups: 25
Lower Energy Cutoff: 0.015
Photons < 0.015: Included
Library: Grove

Nuclide	Ci	Bq	μCi/cm ³	Bq/cm ³
Pa-234				
Pa-234m				
Th-231	6.1164e+001	2.2631e+012	1.0000e+000	3.7000e+004
Th-234				
U-234				
U-235	6.1164e+001	2.2631e+012	1.0000e+000	3.7000e+004
U-238				

Buildup: The material reference is Shield 1	
Integration Parameters	
X Direction	20
Y Direction	20
Z Direction	20

Results

Energy (MeV)	Activity (Photons/sec)	Fluence Rate MeV/cm ² /sec No Buildup	Fluence Rate MeV/cm ² /sec With Buildup	Exposure Rate mR/hr No Buildup	Exposure Rate mR/hr With Buildup
0.015	2.306e+12	0.000e+00	1.018e-22	0.000e+00	8.730e-24
0.03	3.316e+11	4.339e-70	3.159e-23	4.300e-72	3.131e-25
0.06	1.075e+10	6.476e-11	1.020e-10	1.286e-13	2.026e-13
0.08	2.655e+11	4.930e-04	9.840e-04	7.802e-07	1.557e-06
0.1	2.365e+11	5.300e-02	1.295e-01	8.109e-05	1.981e-04
0.15	3.524e+11	4.577e+00	1.558e+01	7.536e-03	2.565e-02
0.2	1.397e+12	7.300e+01	3.053e+02	1.288e-01	5.388e-01
Totals	4.899e+12	7.763e+01	3.210e+02	1.365e-01	5.646e-01