



EQUIP. NO.	DWG. NO.	COORDINATE LOCATION
B004-N	M-1098	D-3
B005-N	M-1098	C-2

EQUIP. NO.	LOCATION	HS	TS	FS	TI	TY	HY	FO	FOI	FOI2	CO <sub>2</sub> PANEL
B004-N	SWGR. RM. EL. 133'-0"	A	A	A	A	A	A	A	A	A	(D-4)
B005-N	SWGR. RM. EL. 133'-0"	B	B	B	B	B	B	B	B	B	(D-4)

EQUIP. NO.	DWG. NO.	COORDINATE LOCATION
B006-N	M-1098	D-5
B007-N	M-1098	C-4
B008-N	M-1098	D-8
B009-N	M-1098	C-8
B010-N	M-1098	G-6
B011-N	M-1098	E-7
B012-N	M-1098	C-4
B013-N	M-1098	C-6
B014-N	M-1098	F-5
B015-N	M-1098	H-5
B016-N	M-1098	C-5

EQUIP. NO.	LOCATION	HS	TS	FS	TI	TY	HY	FO	FOI	FOI2	CO <sub>2</sub> PANEL
B016-N	M-1098	A	A	A	A	A	A	A	A	A	(D-4)
B017-N	M-1098	B	B	B	B	B	B	B	B	B	(D-4)
B018-N	M-1098	C	C	C	C	C	C	C	C	C	(D-4)
B019-N	M-1098	D	D	D	D	D	D	D	D	D	(D-4)
B020-N	M-1098	E	E	E	E	E	E	E	E	E	(D-4)
B021-N	M-1098	F	F	F	F	F	F	F	F	F	(D-4)
B022-N	M-1098	G	G	G	G	G	G	G	G	G	(D-4)
B023-N	M-1098	H	H	H	H	H	H	H	H	H	(D-4)
B024-N	M-1098	J	J	J	J	J	J	J	J	J	(D-4)
B025-N	M-1098	K	K	K	K	K	K	K	K	K	(D-4)
B026-N	M-1098	L	L	L	L	L	L	L	L	L	(D-4)
B027-N	M-1098	M	M	M	M	M	M	M	M	M	(D-4)
B028-N	M-1098	N	N	N	N	N	N	N	N	N	(D-4)

- NOTES:
- ALL EQUIPMENT NUMBERS ON THIS DRAWING ARE PREFIXED BY NUM1 UNLESS OTHERWISE NOTED.
  - FOR HVAC LEGEND SEE M-0047A.
  - ALL INSTRUMENT NUMBERS ON THIS DRAWING ARE PREFIXED BY I1H1 UNLESS OTHERWISE NOTED.
  - BYPASS LINE BLANKED OFF.
  - ALL PIPING 2" & SMALLER IS CLASSIFIED AS A "B-A" RADIATION LEVEL UNLESS OTHERWISE NOTED.
  - DELETED.
  - SEE INSTRUMENT INSTALLATION DETAIL FOR INSTALLATION REQUIREMENTS.
9. FOR IH22-P171/P172 INFO SEE DWG. J-909.0 SERIES.
10. THE SOUTHEAST MOST ROOF HATCH MAY BE USED AS AN OCCASIONAL RELEASE POINT. USE OF THE OCCASIONAL RELEASE POINT SHALL BE GOVERNED BY THE REQUIREMENTS OF THE ODCM AND ER 2007-0014.

036	AS-BUILT PER EC 6636	WE	N/A	N/A	EX	MM	3-28-88
035	AS-BUILT PER EC 4594	WE	N/A	N/A	WEL	MM	1-14-88
034	AS-BUILT PER DRN 07-130				SIGN-OFF	ON RECORD	
033	AS-BUILT PER DRN 06-1498				SIGN-OFF	ON RECORD	
032	AS-BUILT PER DRN 99-388	SIP	N/A	N/A	WE	MM	11-23-2005
031	AS-BUILT PER DRN 03-157 REF. ER 00-2003-0192-000-00				SIGN-OFF	ON RECORD	

GRAND GULF NUCLEAR STATION  
UNIT 1  
NUCLEAR PLANT ENGINEERING  
**UPDATED FINAL SAFETY ANALYSIS REPORT**  
FIGURE NUMBER - 9.4-006

P & I DIAGRAM  
TURBINE BLDG. VENTILATION SYSTEM

SCALE: NONE  
DRAWING No. M-1105A  
REV. 036

COMPONENTS SUBJECT TO AMR

NON-SAFETY RELATED SYSTEMS & COMPONENTS AFFECTING SAFETY RELATED SYSTEMS AMM20

NO.	DATE	DESCRIPTION	BY	ENG	CHK	APP
REVISIONS						
LRA-M-1105A						

DATE: 10-13-2011  
DRAWING No. M-1105A  
REV. 036  
HYBRID DFN: m1105a.dgn