



- NOTES:
- FOR GEN. NOTES, SEE DRAWING M-1109A.
 - PROCESS PIPE AND SLEEVE ARE ONE AND THE SAME WITHIN AREA MARKED "SCHEDULE CHANGE". THIS DIMENSION IS INDICATED ON DRAWING 9645-C-1004 FOR CONTAINMENT PENETRATIONS.
 - VALVES F480 THRU F492 ARE BELL & GOSSET CIRCUIT SETTERS. VALVES ARE PROCURED ON MISCELLANEOUS BILL OF MATERIALS M-0054.
 - A 1/2" DRIFTE HOLE SHALL BE DRILLED THROUGH THE HEADER PIPE ON CENTER OF THE BRANCH CONNECTION.
 - VALVES F306, F301, F302 AND F303 GAGGED OPEN BY EC-0026

NO.	REVISIONS	DATE	BY	CHK	APP	DATE	
022	AS-BUILT PER EC 13132		WC	N/A	N/A	SP	11-18-08
021	AS-BUILT PER EC 0026		WC	N/A	N/A	SP	11-18-08
020	AS-BUILT PER DRN 04-688		WC	SIGN-OFF	ON RECORD		

GRAND GULF NUCLEAR STATION UNIT 1 NUCLEAR PLANT ENGINEERING UPDATED FINAL SAFETY ANALYSIS REPORT FIGURE NUMBER - 9.2-020 P & I DIAGRAM PLANT CHILLED WATER SYSTEM UNIT 1						
SCALE:	NONE	DRAWING No.	M-1109D	REV.	022	
MPL No. IP71 1015M			HYBRID DFN: m1109d.dgn			

COMPONENTS SUBJECT TO AMR

- PLANT CHILLED WATER SYSTEM AMM14
- NON-SAFETY RELATED SYSTEMS & COMPONENTS AFFECTING SAFETY RELATED SYSTEMS AMM20

0	10-13-2011					
NO.	DATE	DESCRIPTION	BY	ENG	CHK	APP
REVISIONS						
LRA-M-1109D						
DRAWING: m1109d.dgn						
PLOT FILE:						

138