



- NOTES:**
1. ALL EQUIPMENT NUMBERS ON THIS DRAWING ARE PREFIXED BY NP72 UNLESS OTHERWISE NOTED.
 2. ALL INSTRUMENT NUMBERS ON THIS DRAWING ARE PREFIXED BY IP72 UNLESS OTHERWISE NOTED.
 3. ALL START-UP STRAINERS SHALL BE REPLACED BY RING SPACERS IN ACCORDANCE WITH THE LATEST REVISION OF 9045-MS-03, GENERAL NOTE 17.
 4. ALL DRAINS SHALL BE DISCHARGED TO NEARBY CHRW ONLY UNLESS OTHERWISE NOTED.
 5. ALL PIPING 2" & SMALLER IS CLASSIFIED AS II-"A" RADIATION LEVEL.
 6. NOT USED.
 7. FOR ADDITIONAL INFORMATION INCLUDING PIPING & VALVES SUPPLIED BY THE VENDOR, SEE DWG. M-1198.
 8. FOR ADDITIONAL INFORMATION INCLUDING PIPING & VALVES SUPPLIED BY THE VENDOR, SEE DWG. M-1198 & M-1199.

008	AS-BUILT PER EC1011	WEN	AN/A	SP	6-26-2007		
007	AS-BUILT PER DRN 5178, DRN 5164 & ADDED ADDITIONAL INFORMATION FOR CLARITY	W	B	N/A	4-18-96		
006	AS-BUILT PER DRR 93/0003			SIGN-OFF ON RECORD			
005	AS-BUILT PER DCP 86/2005, DCP 86/2007, CN 86/2006 AND CN 87/0279	TRG	MAC	RTM	KMB	RKD	6/8/98

GRAND GULF NUCLEAR STATION
 UNIT 1
 NUCLEAR PLANT ENGINEERING
UPDATED FINAL SAFETY ANALYSIS REPORT
 FIGURE NUMBER - 9.2-048
 P&I DIAGRAM
 DRYWELL CHILLED WATER SYSTEM

SCALE:	NONE	DRAWING No.:	M-1119A	REV.:	008
--------	------	--------------	---------	-------	-----

COMPONENTS SUBJECT TO AMR

NON-SAFETY RELATED SYSTEMS & COMPONENTS AFFECTING SAFETY RELATED SYSTEMS AMR20

NO.	DATE	DESCRIPTION	BY	ENG	CHK	APP
REVISIONS						
LRA-M-1119A						
DGN FILE: m1119a.DGN						
PLOT FILE:						

0094